	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
450002	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
450003	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
450004	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
450005	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Accumulated Fault Duty A Ph V	3.69	%
450006	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Accumulated Fault Duty B Ph V	5.53	%
450007	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Accumulated Fault Duty C Ph V	4.3	%
450008	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Amps A Ø	87.0	
450009	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Amps B Ø	89.0	
450010	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Amps C Ø	85.0	
450011	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
450012	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
450013	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
450014	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Operations A Ø	0	
450015	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Operations B Ø	0	
450016	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Operations C Ø	0	
450017	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Operations Ground	0	
450018	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Follow-up Action Required?	n	
450019	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	General Comments		
450020	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Maintenance Operations	0	
450021	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Operations Counter AF	70	
450022	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Operations Counter AL	70	
450023	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Operations This Read Vac	0	
450024	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Switching Operations	0	
450025	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Unknown Operations	0	
450026	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Totalizer Meter Reading	.7460	
450027	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
450028	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
450029	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
450030	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
450031	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
450032	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
450033	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
450034	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
450035	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
450036	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
450037	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
450038	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
450039	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
450040	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
450041	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Follow-up Action Required?	n	
450042	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
450043	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	General Comments		
450044	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	General Comments		
450045	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
450046	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
450047	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
450048	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
450049	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
450050	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
450051	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
450052	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
450053	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Amps B Ø	0.0	
450054	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Amps A Ø	0.0	
450055	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
450056	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
450057	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
450058	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
450059	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
450060	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Operations This Read Vac	0	
450061	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Switching Operations	0	
450062	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Tank Paint Condition	Good	
450063	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Unknown Operations	0	
450064	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
450065	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
450066	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Operations A Ø	0	
450067	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Operations B Ø	0	
450068	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Operations C Ø	0	
450069	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Operations Ground	0	
450070	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Follow-up Action Required?	n	
450071	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	General Comments		
450072	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Maintenance Operations	0	
450073	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Operations Counter AF	67	
450074	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Operations Counter AL	67	
450075	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Operations This Read Vac	4	
450076	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Switching Operations	4	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
450077	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Unknown Operations	0	
450078	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	9 Month Operations	3	
450079	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
450080	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	9 Month Operations	9	
450081	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
450082	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
450083	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Amps A Ø	5.0	
450084	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Amps B Ø	10.0	
450085	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Amps C Ø	10.0	
450086	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Bushing Condition	Good	
450087	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Bushings Connection/Risers	Good	
450088	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
450089	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
450090	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
450091	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Cabinet Paint Condition	Good	
450092	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Equipment Properly Labeled?	y	
450093	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
450094	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
450095	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
450096	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Operations A Ø	0	
450097	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Operations B Ø	0	
450098	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Operations C Ø	0	
450099	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Operations Ground	0	
450100	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Follow-up Action Required?	n	
450101	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Follow-up Action Required?	n	
450102	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Foundation Condition	Good	
450103	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
450104	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Cabinet Paint Condition	Good	
450105	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Equipment Properly Labeled?	y	
450106	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
450107	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
450108	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
450109	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Operations A Ø	0	
450110	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Operations B Ø	0	
450111	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Operations C Ø	0	
450112	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Operations Ground	0	
450113	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Follow-up Action Required?	n	
450114	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Follow-up Action Required?	n	
450115	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Unknown Operations	0	
450116	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Foundation Condition	Good	
450117	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	General Comments		
450118	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	General Comments		
450119	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Grounds in Place?	y	
450120	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Maintenance Operations	0	
450121	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Moisture and Leak Free?	y	
450122	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Operations Counter AF	208	
450123	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Operations Counter AL	208	
450124	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Tank Paint Condition	Good	
450125	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Switching Operations	0	
450126	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
450127	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Operations This Read Vac	0	
450128	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Operations Counter AL	112	
450129	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Operations Counter AF	112	
450130	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Moisture and Leak Free?	y	
450131	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Maintenance Operations	0	
450132	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Grounds in Place?	y	
450133	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	General Comments		
450134	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	General Comments		
450135	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Foundation Condition	Good	
450136	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Follow-up Action Required?	n	
450137	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Follow-up Action Required?	n	
450138	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Operations Ground	0	
450139	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Operations C Ø	0	
450140	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Operations B Ø	0	
450141	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Operations A Ø	0	
450142	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
450143	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
450144	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
450145	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
450146	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Equipment Properly Labeled?	y	
450147	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Cabinet Paint Condition	Good	
450148	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
450149	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
450150	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
450151	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Amps C Ø	0.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
450152	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
450153	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BCH000217	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
450154	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BCH000217	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
450155	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BCH000217	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
450156	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BCH000217	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
450157	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BCH000217	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
450158	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Follow-up Action Required?	n	
450159	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
450160	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
450161	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
450162	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
450163	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Clear of Trash?	y	
450164	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
450165	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
450166	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
450167	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
450168	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
450169	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
450170	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	General Comments		
450171	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Adjusted Amps B Phase V	25.08	
450172	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Adjusted Amps C Phase V	25.08	
450173	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Operations A Ø	0	
450174	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Operations B Ø	4	
450175	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Operations C Ø	4	
450176	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Operations Ground	0	
450177	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Follow-up Action Required?	n	
450178	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Follow-up Action Required?	n	
450179	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Foundation Condition	Good	
450180	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	General Comments		
450181	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	General Comments		
450182	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Grounds in Place?	y	
450183	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Maintenance Operations	7	
450184	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Moisture and Leak Free?	y	
450185	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Operations Counter AF	198	
450186	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Operations Counter AL	198	
450187	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Operations This Read Vac	16	
450188	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Switching Operations	1	
450189	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Tank Paint Condition	Good	
450190	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Unknown Operations	0	
450191	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	9 Month Operations	2	
450192	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
450193	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
450194	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
450195	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Amps A Ø	135.0	
450196	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Amps B Ø	160.0	
450197	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Amps C Ø	150.0	
450198	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Bushing Condition	Good	
450199	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
450200	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
450201	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
450202	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
450203	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
450204	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
450205	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
450206	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
450207	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
450208	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Operations A Ø	0	
450209	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Operations B Ø	0	
450210	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Operations C Ø	0	
450211	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Operations Ground	0	
450212	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Follow-up Action Required?	n	
450213	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Follow-up Action Required?	n	
450214	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
450215	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
450216	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
450217	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	General Comments		
450218	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	General Comments		
450219	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
450220	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
450221	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Trash Emptied?	n	
450222	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
450223	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	General Comments		
450224	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Grounds in Place?	y	
450225	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Maintenance Operations	0	
450226	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
450227	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Operations Counter AF	188	
450228	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Operations Counter AL	188	
450229	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Operations This Read Vac	0	
450230	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Switching Operations	0	
450231	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Tank Paint Condition	Good	
450232	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Unknown Operations	0	
450233	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
450234	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
450235	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
450236	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
450237	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	114	
450238	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
450239	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC Max Tap Position	14R	
450240	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
450241	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
450242	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC As Left Counter	20649	
450243	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC As Found Counter	20649	
450244	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
450245	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	General Comments		
450246	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
450247	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
450248	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	9 Month Operations	19	
450249	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
450250	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
450251	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
450252	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Amps A Ø	145.0	
450253	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Amps B Ø	145.0	
450254	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
450255	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
450256	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Floor Swept?	y	
450257	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
450258	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
450259	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Evidence of Insects	None	
450260	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
450261	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
450262	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
450263	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Broom on Site?	y	
450264	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
450265	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
450266	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Amps C Ø	55.0	
450267	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Bushing Condition	Good	
450268	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Bushings Connection/Risers	Good	
450269	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
450270	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
450271	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
450272	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Cabinet Paint Condition	Good	
450273	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Equipment Properly Labeled?	y	
450274	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
450275	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
450276	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Ambient Temp	83	°F
450277	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
450278	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
450279	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Clear of Trash?	y	
450280	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	16L	
450281	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	12R	
450282	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
450283	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
450284	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
450285	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
450286	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
450287	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
450288	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1R	
450289	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
450290	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
450291	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
450292	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
450293	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
450294	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
450295	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
450296	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
450297	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	9 Month Operations	3	
450298	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Accumulated Fault Duty A Ph V	84.96	%
450299	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Accumulated Fault Duty B Ph V	84.96	%
450300	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Accumulated Fault Duty C Ph V	84.96	%
450301	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Amps A Ø	0.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
450302	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Amps B Ø	0.0	
450303	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Amps C Ø	0.0	
450304	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
450305	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
450306	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
450307	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Operations A Ø	0	
450308	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Operations B Ø	0	
450309	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Operations C Ø	0	
450310	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Operations Ground	0	
450311	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Follow-up Action Required?	n	
450312	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	General Comments		
450313	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
450314	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
450315	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	General Comments		
450316	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
450317	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Vegetation	None	
450318	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
450319	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Maintenance Operations	0	
450320	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Operations Counter AF	279	
450321	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Operations Counter AL	279	
450322	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Operations This Read Vac	0	
450323	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Switching Operations	0	
450324	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Unknown Operations	0	
450325	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LTCC000573	LTCControl	HB-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
450326	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LTCC000573	LTCControl	HB-TRANS 1	LTC Control Insp	General Comments		
450327	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LTCC000573	LTCControl	HB-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
450328	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LTCC000573	LTCControl	HB-TRANS 1	LTC Control Insp	All Connections OK?	y	
450329	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	9 Month Operations	2	
450330	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Accumulated Fault Duty A Ph V	84.96	%
450331	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Accumulated Fault Duty B Ph V	84.96	%
450332	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Accumulated Fault Duty C Ph V	84.96	%
450333	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Amps A Ø	0.0	
450334	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Amps B Ø	0.0	
450335	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Amps C Ø	0.0	
450336	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
450337	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
450338	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	General Comments		
450339	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
450340	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
450341	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
450342	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
450343	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
450344	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
450345	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Clear of Trash?	y	
450346	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
450347	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
450348	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
450349	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
450350	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
450351	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	93210	
450352	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
450353	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
450354	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
450355	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
450356	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
450357	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	1L	
450358	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	4R	
450359	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
450360	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
450361	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
450362	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
450363	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
450364	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
450365	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
450366	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
450367	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
450368	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
450369	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
450370	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
450371	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
450372	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
450373	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
450374	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	976234	
450375	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
450376	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
450377	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
450378	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
450379	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
450380	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	8L	
450381	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	8R	
450382	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	n	
450383	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
450384	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
450385	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
450386	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
450387	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
450388	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
450389	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
450390	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
450391	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
450392	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
450393	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
450394	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
450395	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
450396	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
450397	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	107320	
450398	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
450399	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
450400	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
450401	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	9 Month Operations	0	
450402	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	2.88	%
450403	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	2.88	%
450404	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	2.88	%
450405	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Amps A Ø	114.0	
450406	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
450407	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
450408	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
450409	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC Operations Since Last Insp	248	
450410	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC Min Tap Position	6L	
450411	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC Max Tap Position	4L	
450412	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC Current Tap Position	5L	
450413	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
450414	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC As Left Counter	25004	
450415	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC As Found Counter	24991	
450416	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	General Comments		
450417	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	General Comments		
450418	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
450419	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	Follow-up Action Required?	n	
450420	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Unknown Operations	0	
450421	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Tank Paint Condition	Good	
450422	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Switching Operations	0	
450423	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
450424	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Operations This Read Vac	0	
450425	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Operations Counter AL	323	
450426	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Operations Counter AF	323	
450427	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Moisture and Leak Free?	y	
450428	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Maintenance Operations	0	
450429	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Heaters (All) Functioning?	y	
450430	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Grounds in Place?	y	
450431	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	General Comments	breaker open	
450432	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	General Comments		
450433	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Foundation Condition	Good	
450434	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Follow-up Action Required?	n	
450435	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Follow-up Action Required?	n	
450436	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Operations Ground	0	
450437	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Operations C Ø	0	
450438	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Operations B Ø	0	
450439	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Operations A Ø	0	
450440	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Adjusted Amps C Phase V	0	
450441	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Adjusted Amps B Phase V	0	
450442	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Adjusted Amps A Phase V	0	
450443	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Equipment Properly Labeled?	y	
450444	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Cabinet Paint Condition	Good	
450445	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Amps B Ø	117.0	
450446	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Amps C Ø	115.0	
450447	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
450448	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
450449	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
450450	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Operations A Ø	0	
450451	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
450452	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
450453	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Operations B Ø	0	
450454	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Operations C Ø	0	
450455	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Operations Ground	0	
450456	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Follow-up Action Required?	n	
450457	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	General Comments		
450458	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Maintenance Operations	0	
450459	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
450460	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Bushings Connection/Risers	Good	
450461	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Bushing Condition	Good	
450462	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Amps C Ø	0	
450463	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Amps B Ø	0	
450464	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Amps A Ø	0	
450465	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
450466	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
450467	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Operations A Ø	0	
450468	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Operations B Ø	0	
450469	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Operations C Ø	0	
450470	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Operations Ground	0	
450471	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Follow-up Action Required?	n	
450472	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	General Comments		
450473	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Maintenance Operations	0	
450474	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Operations Counter AF	279	
450475	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Operations Counter AL	279	
450476	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Operations This Read Vac	0	
450477	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Switching Operations	0	
450478	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Unknown Operations	0	
450479	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
450480	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
450481	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
450482	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
450483	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	200.0	
450484	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	220.0	
450485	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	210.0	
450486	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
450487	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Unknown Operations	0	
450488	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	9 Month Operations	0	
450489	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	2.88	%
450490	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	2.88	%
450491	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	2.88	%
450492	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Amps A Ø	140.0	
450493	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Amps B Ø	140.0	
450494	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Amps C Ø	140.0	
450495	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Tank Paint Condition	Good	
450496	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Switching Operations	0	
450497	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
450498	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
450499	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
450500	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
450501	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
450502	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
450503	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
450504	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
450505	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
450506	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
450507	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
450508	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
450509	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	70	
450510	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	70	
450511	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
450512	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
450513	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
450514	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
450515	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
450516	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
450517	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Operations A Ø	0	
450518	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Operations B Ø	0	
450519	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Operations C Ø	0	
450520	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Operations Ground	0	
450521	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Follow-up Action Required?	n	
450522	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	General Comments		
450523	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Maintenance Operations	0	
450524	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Operations Counter AF	49	
450525	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Operations Counter AL	49	
450526	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Operations This Read Vac	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
450527	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Switching Operations	0	
450528	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Unknown Operations	0	
450529	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
450530	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
450531	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
450532	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
450533	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
450534	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
450535	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
450536	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
450537	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
450538	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
450539	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	100.0	
450540	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	110.0	
450541	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	
450542	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
450543	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
450544	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
450545	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
450546	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	VRR Time Delay	60	Seconds
450547	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
450548	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
450549	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
450550	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	LTC Operation Checked?	n	
450551	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	General Comments		
450552	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	Follow-up Action Required?	n	
450553	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	All Connections OK?	y	
450554	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations	2	
450555	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
450556	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
450557	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
450558	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
450559	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
450560	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
450561	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Bushing Condition	Good	
450562	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
450563	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
450564	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
450565	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
450566	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
450567	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
450568	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
450569	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
450570	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
450571	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
450572	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
450573	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
450574	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
450575	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
450576	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
450577	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Foundation Condition	Good	
450578	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
450579	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	General Comments		
450580	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Grounds in Place?	y	
450581	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
450582	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
450583	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
450584	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	125	
450585	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	125	
450586	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Operations This Read Vac	0	
450587	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
450588	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Switching Operations	0	
450589	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Tank Paint Condition	Good	
450590	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
450591	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
450592	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
450593	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
450594	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	90	
450595	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	140	
450596	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	180	
450597	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
450598	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
450599	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
450600	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
450601	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
450602	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
450603	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
450604	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
450605	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
450606	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	313	
450607	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	313	
450608	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
450609	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
450610	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
450611	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
450612	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
450613	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
450614	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
450615	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
450616	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
450617	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
450618	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
450619	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
450620	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
450621	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
450622	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
450623	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	General Comments		
450624	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
450625	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
450626	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
450627	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
450628	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
450629	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
450630	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
450631	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	190.0	
450632	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	200.0	
450633	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	190.0	
450634	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
450635	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
450636	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
450637	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	21	
450638	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
450639	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	5	
450640	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	78	
450641	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	78	
450642	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
450643	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
450644	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
450645	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
450646	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
450647	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
450648	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
450649	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
450650	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
450651	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
450652	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	29	
450653	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	29	
450654	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
450655	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
450656	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
450657	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	General Comments		
450658	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	General Comments		
450659	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
450660	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	Follow-up Action Required?	n	
450661	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BAT000167	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
450662	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BAT000167	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
450663	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BAT000167	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
450664	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BAT000167	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
450665	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BAT000167	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
450666	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BAT000167	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
450667	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BAT000167	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
450668	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
450669	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	General Comments		
450670	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC As Found Counter	52642	
450671	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC As Left Counter	52642	
450672	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
450673	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
450674	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
450675	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	149	
450676	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
450677	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
450678	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	General Comments	.	
450679	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC As Found Counter	52714	
450680	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC As Left Counter	52714	
450681	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
450682	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
450683	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
450684	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	72	
450685	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
450686	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Operations B Ø	0	
450687	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Operations C Ø	0	
450688	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Operations Ground	0	
450689	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Follow-up Action Required?	n	
450690	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	General Comments		
450691	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Maintenance Operations	0	
450692	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Operations Counter AF	95	
450693	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Operations Counter AL	95	
450694	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Operations This Read Vac	0	
450695	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Switching Operations	0	
450696	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Unknown Operations	0	
450697	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	9 Month Operations	1	
450698	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Accumulated Fault Duty A Ph V	30.24	%
450699	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Accumulated Fault Duty B Ph V	31.68	%
450700	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Accumulated Fault Duty C Ph V	24.48	%
450701	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Amps A Ø	28.0	
450702	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Amps B Ø	28.0	
450703	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Amps C Ø	29.0	
450704	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
450705	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
450706	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
450707	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Operations A Ø	0	
450708	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Operations B Ø	0	
450709	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Operations C Ø	0	
450710	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Operations Ground	0	
450711	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Follow-up Action Required?	n	
450712	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	General Comments		
450713	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Maintenance Operations	0	
450714	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Operations Counter AF	95	
450715	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Operations Counter AL	95	
450716	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Operations This Read Vac	0	
450717	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Switching Operations	0	
450718	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Unknown Operations	0	
450719	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Vegetation	None	
450720	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
450721	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
450722	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
450723	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
450724	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
450725	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
450726	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
450727	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
450728	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
450729	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
450730	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
450731	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
450732	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
450733	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
450734	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
450735	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC Operations Since Last Insp	285	
450736	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC Min Tap Position	7L	
450737	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
450738	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	9 Month Operations	2	
450739	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Accumulated Fault Duty A Ph V	30.24	%
450740	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Accumulated Fault Duty B Ph V	31.68	%
450741	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Accumulated Fault Duty C Ph V	24.48	%
450742	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Amps A Ø	49.0	
450743	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Amps B Ø	51.0	
450744	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Amps C Ø	47.0	
450745	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
450746	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
450747	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
450748	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Operations A Ø	0	
450749	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
450750	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
450751	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
450752	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
450753	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
450754	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
450755	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
450756	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
450757	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
450758	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
450759	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
450760	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
450761	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
450762	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
450763	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	General Comments		
450764	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
450765	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
450766	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BAT000167	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
450767	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BAT000167	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
450768	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC Max Tap Position	4L	
450769	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC Current Tap Position	5L	
450770	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
450771	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BAT000167	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
450772	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BAT000167	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
450773	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BAT000167	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
450774	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BAT000167	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
450775	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BAT000167	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
450776	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC As Left Counter	10934	
450777	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Foundation Condition	Good	
450778	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
450779	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
450780	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
450781	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
450782	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
450783	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
450784	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC As Found Counter	10924	
450785	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Tank Paint Condition	Good	
450786	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Follow-up Action Required?	n	
450787	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Patrol Inspection	Follow-up Action Required?	n	
450788	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations Ground	0	
450789	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations C Ø	0	
450790	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations B Ø	0	
450791	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations A Ø	0	
450792	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
450793	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
450794	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
450795	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Patrol Inspection	Equipment Properly Labeled?	y	
450796	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Amps C Ø	0.0	
450797	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Amps B Ø	0.0	
450798	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Amps A Ø	0.0	
450799	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
450800	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
450801	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
450802	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	9 Month Operations	0	
450803	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Unknown Operations	0	
450804	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Switching Operations	0	
450805	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Operations This Read Vac	0	
450806	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Operations Counter AL	196	
450807	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Operations Counter AF	196	
450808	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Maintenance Operations	0	
450809	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Unknown Operations	0	
450810	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Tank Paint Condition	Good	
450811	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Switching Operations	0	
450812	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
450813	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Operations This Read Vac	0	
450814	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Operations Counter AL	176	
450815	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Operations Counter AF	176	
450816	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
450817	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Maintenance Operations	0	
450818	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Grounds in Place?	y	
450819	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	General Comments		
450820	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
450821	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	Follow-up Action Required?	n	
450822	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	General Comments		
450823	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	General Comments		
450824	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Foundation Condition	Good	
450825	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Follow-up Action Required?	n	
450826	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
450827	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Operations Ground	0	
450828	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Operations C Ø	0	
450829	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Operations B Ø	0	
450830	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Operations A Ø	0	
450831	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
450832	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
450833	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
450834	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
450835	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
450836	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
450837	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
450838	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
450839	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
450840	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Bushings Connection/Risers	Good	
450841	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Bushing Condition	Good	
450842	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Amps C Ø	20.0	
450843	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Amps B Ø	0.0	
450844	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Amps A Ø	20.0	
450845	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
450846	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
450847	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
450848	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	9 Month Operations	4	
450849	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
450850	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
450851	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
450852	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
450853	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Amps C Ø	0.0	
450854	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Amps B Ø	0.0	
450855	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Amps A Ø	0.0	
450856	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
450857	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
450858	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
450859	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	9 Month Operations	29	
450860	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Foundation Condition	Good	
450861	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
450862	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
450863	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
450864	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Operations A Ø	0	
450865	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Operations B Ø	0	
450866	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Operations C Ø	0	
450867	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Operations Ground	0	
450868	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
450869	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Follow-up Action Required?	n	
450870	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Follow-up Action Required?	n	
450871	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Foundation Condition	Good	
450872	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	General Comments		
450873	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	General Comments		
450874	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Grounds in Place?	y	
450875	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Heaters (All) Functioning?	y	
450876	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Maintenance Operations	0	
450877	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Moisture and Leak Free?	y	
450878	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Operations Counter AF	189	
450879	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Operations Counter AL	189	
450880	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Operations This Read Vac	2	
450881	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Follow-up Action Required?	n	
450882	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Follow-up Action Required?	n	
450883	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Operations Ground	0	
450884	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Operations C Ø	0	
450885	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Operations B Ø	0	
450886	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Operations A Ø	0	
450887	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
450888	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
450889	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
450890	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Equipment Properly Labeled?	y	
450891	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Cabinet Paint Condition	Good	
450892	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Unknown Operations	0	
450893	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Switching Operations	0	
450894	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Operations This Read Vac	0	
450895	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Operations Counter AL	151	
450896	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Operations Counter AF	151	
450897	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Maintenance Operations	0	
450898	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	General Comments		
450899	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Patrol Inspection	General Comments		
450900	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
450901	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
450902	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
450903	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC Operations Since Last Insp	283	
450904	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
450905	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC Min Tap Position	9L	
450906	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC Max Tap Position	4L	
450907	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC Current Tap Position	6L	
450908	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
450909	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC As Left Counter	65093	
450910	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC As Found Counter	65093	
450911	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	General Comments		
450912	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Switching Operations	2	
450913	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
450914	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
450915	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Cabinet Paint Condition	Good	
450916	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Equipment Properly Labeled?	y	
450917	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
450918	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
450919	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
450920	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Operations A Ø	0	
450921	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Operations B Ø	0	
450922	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Operations C Ø	0	
450923	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Unknown Operations	0	
450924	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Tank Paint Condition	Good	
450925	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Switching Operations	0	
450926	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
450927	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Unknown Operations	0	
450928	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Switching Operations	0	
450929	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Operations This Read Vac	0	
450930	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Operations Counter AL	193	
450931	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Operations Counter AF	193	
450932	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Maintenance Operations	0	
450933	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	General Comments		
450934	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Patrol Inspection	General Comments		
450935	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Follow-up Action Required?	n	
450936	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Patrol Inspection	Follow-up Action Required?	n	
450937	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Operations Ground	0	
450938	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Operations C Ø	0	
450939	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Operations B Ø	0	
450940	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Operations A Ø	0	
450941	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
450942	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
450943	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
450944	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Patrol Inspection	Equipment Properly Labeled?	y	
450945	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Amps C Ø	190.0	
450946	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Amps B Ø	190.0	
450947	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Amps A Ø	190.0	
450948	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
450949	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
450950	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
450951	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Operations Ground	0	
450952	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Follow-up Action Required?	n	
450953	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Follow-up Action Required?	n	
450954	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Foundation Condition	Good	
450955	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	General Comments		
450956	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	General Comments		
450957	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Grounds in Place?	y	
450958	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Maintenance Operations	0	
450959	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Moisture and Leak Free?	y	
450960	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Operations Counter AF	171	
450961	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Operations Counter AL	171	
450962	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Operations This Read Vac	2	
450963	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Switching Operations	2	
450964	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Tank Paint Condition	Good	
450965	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Unknown Operations	0	
450966	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	9 Month Operations	40	
450967	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Operations This Read Vac	0	
450968	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Operations Counter AL	147	
450969	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
450970	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Unknown Operations	0	
450971	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Switching Operations	0	
450972	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Operations This Read Vac	0	
450973	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Operations Counter AL	51	
450974	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Operations Counter AF	51	
450975	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Maintenance Operations	0	
450976	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
450977	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
450978	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
450979	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Amps C Ø	255.0	
450980	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Amps B Ø	260.0	
450981	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Amps A Ø	230.0	
450982	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
450983	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
450984	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
450985	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	9 Month Operations	59	
450986	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	General Comments		
450987	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Patrol Inspection	General Comments		
450988	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Follow-up Action Required?	n	
450989	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Patrol Inspection	Follow-up Action Required?	n	
450990	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Operations Ground	0	
450991	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Operations C Ø	0	
450992	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Operations B Ø	0	
450993	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Operations A Ø	0	
450994	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
450995	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
450996	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
450997	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Patrol Inspection	Equipment Properly Labeled?	y	
450998	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Amps C Ø	50.0	
450999	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Amps B Ø	50.0	
451000	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Amps A Ø	50.0	
451001	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
451002	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
451003	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
451004	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	9 Month Operations	1	
451005	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Unknown Operations	0	
451006	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Switching Operations	0	
451007	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Operations This Read Vac	0	
451008	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Operations Counter AL	164	
451009	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Operations Counter AF	164	
451010	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Maintenance Operations	0	
451011	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	General Comments		
451012	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Patrol Inspection	General Comments		
451013	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Follow-up Action Required?	n	
451014	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Patrol Inspection	Follow-up Action Required?	n	
451015	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Operations Ground	0	
451016	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Operations C Ø	0	
451017	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Operations B Ø	0	
451018	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Operations A Ø	0	
451019	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
451020	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
451021	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
451022	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Patrol Inspection	Equipment Properly Labeled?	y	
451023	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Amps C Ø	190.0	
451024	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Amps B Ø	190.0	
451025	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Amps A Ø	180.0	
451026	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
451027	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
451028	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
451029	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	9 Month Operations	8	
451030	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Unknown Operations	0	
451031	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	9 Month Operations	2	
451032	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
451033	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
451034	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
451035	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Amps A Ø	330.0	
451036	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Amps B Ø	330.0	
451037	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Amps C Ø	330.0	
451038	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Bushing Condition	Good	
451039	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Bushings Connection/Risers	Good	
451040	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
451041	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	6	
451042	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
451043	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
451044	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
451045	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
451046	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	General Comments		
451047	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
451048	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
451049	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
451050	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
451051	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
451052	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
451053	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
451054	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
451055	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
451056	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
451057	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
451058	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	9 Month Operations	2	
451059	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
451060	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
451061	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
451062	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Amps A Ø	0.0	
451063	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Amps B Ø	0.0	
451064	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Amps C Ø	3.0	
451065	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Bushing Condition	Good	
451066	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Bushings Connection/Risers	Good	
451067	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	7	
451068	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
451069	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
451070	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
451071	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
451072	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Cabinet Paint Condition	Good	
451073	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Equipment Properly Labeled?	y	
451074	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
451075	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
451076	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
451077	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
451078	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
451079	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	190.0	
451080	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Operations A Ø	0	
451081	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Operations B Ø	0	
451082	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Operations C Ø	0	
451083	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Operations Ground	0	
451084	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Follow-up Action Required?	n	
451085	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	200.0	
451086	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	200.0	
451087	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
451088	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
451089	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
451090	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
451091	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
451092	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
451093	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
451094	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
451095	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Follow-up Action Required?	n	
451096	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Foundation Condition	Good	
451097	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	General Comments		
451098	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	General Comments		
451099	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Grounds in Place?	y	
451100	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Maintenance Operations	0	
451101	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Moisture and Leak Free?	y	
451102	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Operations Counter AF	165	
451103	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Operations Counter AL	165	
451104	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Operations This Read Vac	2	
451105	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Accumulated Fault Duty C Ph V	0	%
451106	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Accumulated Fault Duty B Ph V	0	%
451107	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Accumulated Fault Duty A Ph V	0	%
451108	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	9 Month Operations	5	
451109	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Operations Counter AF	49	
451110	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Operations Counter AL	49	
451111	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Operations This Read Vac	0	
451112	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Switching Operations	0	
451113	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Unknown Operations	0	
451114	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	57	
451115	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
451116	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
451117	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
451118	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	150.0	
451119	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	170.0	
451120	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	190.0	
451121	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
451122	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
451123	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
451124	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
451125	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
451126	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
451127	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
451128	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
451129	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
451130	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
451131	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
451132	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
451133	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
451134	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1526	
451135	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
451136	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
451137	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
451138	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
451139	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
451140	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
451141	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1526	
451142	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
451143	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
451144	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
451145	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
451146	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Operations This Read Vac	0	
451147	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Operations Counter AL	1	
451148	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Operations Counter AF	1	
451149	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Moisture and Leak Free?	y	
451150	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Maintenance Operations	0	
451151	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
451152	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
451153	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
451154	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
451155	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
451156	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
451157	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
451158	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	General Comments		
451159	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
451160	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
451161	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
451162	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
451163	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
451164	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
451165	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
451166	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
451167	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	82	
451168	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	82	
451169	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
451170	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Maintenance Operations	0	
451171	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Grounds in Place?	y	
451172	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	General Comments		
451173	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	General Comments		
451174	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Foundation Condition	Good	
451175	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Follow-up Action Required?	n	
451176	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
451177	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Operations Ground	0	
451178	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Operations C Ø	0	
451179	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Operations B Ø	0	
451180	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Operations A Ø	0	
451181	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
451182	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
451183	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
451184	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
451185	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
451186	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
451187	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
451188	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
451189	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Amps C Ø	0.0	
451190	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Amps B Ø	0.0	
451191	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Amps A Ø	0.0	
451192	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	9 Month Operations	2	
451193	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
451194	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
451195	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
451196	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Amps A Ø	6.0	
451197	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Amps B Ø	6.0	
451198	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Amps C Ø	7.0	
451199	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Bushing Condition	Good	
451200	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
451201	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
451202	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
451203	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	9 Month Operations	0	
451204	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Unknown Operations	0	
451205	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Tank Paint Condition	Good	
451206	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Switching Operations	0	
451207	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
451208	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Operations This Read Vac	0	
451209	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Operations Counter AL	142	
451210	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Operations Counter AF	142	
451211	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
451212	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Maintenance Operations	0	
451213	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Bushings Connection/Risers	Good	
451214	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
451215	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
451216	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
451217	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Cabinet Paint Condition	Good	
451218	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Equipment Properly Labeled?	y	
451219	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Grounds in Place?	y	
451220	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	General Comments		
451221	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	General Comments		
451222	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Foundation Condition	Good	
451223	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Follow-up Action Required?	n	
451224	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
451225	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Operations Ground	0	
451226	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Operations C Ø	0	
451227	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Operations B Ø	0	
451228	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Operations A Ø	0	
451229	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
451230	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
451231	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
451232	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
451233	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Switching Operations	2	
451234	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Tank Paint Condition	Good	
451235	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Unknown Operations	0	
451236	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
451237	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
451238	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Grounds in Place?	y	
451239	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	General Comments		
451240	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	General Comments		
451241	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
451242	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
451243	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	100	
451244	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	120	
451245	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	120	
451246	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Ambient Temp	79	°F
451247	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
451248	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
451249	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
451250	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
451251	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Clear of Trash?	y	
451252	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
451253	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
451254	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
451255	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
451256	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
451257	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
451258	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	General Comments		
451259	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
451260	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
451261	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Vegetation	None	
451262	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
451263	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
451264	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
451265	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	485	
451266	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	485	
451267	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
451268	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
451269	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
451270	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
451271	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
451272	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
451273	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
451274	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Foundation Condition	Good	
451275	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
451276	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
451277	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	General Comments		
451278	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
451279	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
451280	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
451281	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
451282	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
451283	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
451284	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
451285	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
451286	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
451287	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
451288	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
451289	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
451290	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Unknown Operations	0	
451291	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Tank Paint Condition	Good	
451292	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Switching Operations	0	
451293	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
451294	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Operations This Read Vac	0	
451295	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Operations Counter AL	0	
451296	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Operations Counter AF	0	
451297	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
451298	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Clear of Trash?	y	
451299	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
451300	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
451301	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
451302	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
451303	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
451304	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
451305	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
451306	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
451307	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
451308	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
451309	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
451310	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
451311	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
451312	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
451313	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
451314	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
451315	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
451316	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Follow-up Action Required?	n	
451317	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
451318	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
451319	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	General Comments		
451320	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	General Comments		
451321	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
451322	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Kwh Reading	0	KwH
451323	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	LTC Totalizer Reading	17448.00	kw
451324	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
451325	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
451326	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
451327	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Oil Temp Max	35	°C
451328	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Oil Temp Present	30	°C
451329	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
451330	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
451331	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
451332	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
451333	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
451334	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
451335	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	General Comments		
451336	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
451337	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Vegetation	None	
451338	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
451339	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
451340	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
451341	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Totalizer Meter Reading	.7270	
451342	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Winding Temp Max	40	°C
451343	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Winding Temp Present	35	°C
451344	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
451345	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
451346	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	All Connections OK?	y	
451347	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	Follow-up Action Required?	n	
451348	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	General Comments		
451349	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	LTC Operation Checked?	y	
451350	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
451351	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
451352	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
451353	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	VRR Time Delay	30	Seconds
451354	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
451355	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
451356	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
451357	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
451358	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
451359	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
451360	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Foundation Condition	Good	
451361	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
451362	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
451363	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	General Comments		
451364	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
451365	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
451366	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
451367	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
451368	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
451369	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
451370	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
451371	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
451372	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	9 Month Operations	4	
451373	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
451374	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
451375	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
451376	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Amps A Ø	50.0	
451377	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Amps B Ø	55.0	
451378	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Amps C Ø	55.0	
451379	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Bushing Condition	Good	
451380	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Bushings Connection/Risers	Good	
451381	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
451382	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
451383	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
451384	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Cabinet Paint Condition	Good	
451385	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Equipment Properly Labeled?	y	
451386	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
451387	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
451388	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
451389	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Operations A Ø	0	
451390	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Operations B Ø	0	
451391	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Operations C Ø	0	
451392	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Operations Ground	0	
451393	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Follow-up Action Required?	n	
451394	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Maintenance Operations	0	
451395	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Follow-up Action Required?	n	
451396	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Foundation Condition	Good	
451397	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Moisture and Leak Free?	y	
451398	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Operations Counter AF	60	
451399	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	General Comments		
451400	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Operations Counter AL	60	
451401	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Operations This Read Vac	0	
451402	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
451403	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Switching Operations	0	
451404	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Tank Paint Condition	Good	
451405	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Unknown Operations	0	
451406	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	General Comments		
451407	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Grounds in Place?	y	
451408	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Heaters (All) Functioning?	y	
451409	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Maintenance Operations	0	
451410	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Moisture and Leak Free?	y	
451411	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Operations Counter AF	229	
451412	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Operations Counter AL	229	
451413	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Operations This Read Vac	0	
451414	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
451415	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Switching Operations	0	
451416	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Tank Paint Condition	Good	
451417	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Unknown Operations	0	
451418	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
451419	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
451420	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
451421	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
451422	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
451423	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
451424	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
451425	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
451426	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
451427	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
451428	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
451429	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
451430	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
451431	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	General Comments	fabric is rusty	
451432	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
451433	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Ambient Temp	74	°F
451434	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Operations C Ø	0	
451435	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Operations B Ø	0	
451436	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Operations A Ø	0	
451437	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
451438	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
451439	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
451440	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Operations C Ø	0	
451441	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Operations B Ø	0	
451442	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Operations A Ø	0	
451443	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
451444	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
451445	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
451446	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
451447	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
451448	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
451449	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
451450	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Totalizer Meter Reading	.2920	
451451	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
451452	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
451453	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
451454	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
451455	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
451456	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Equipment Properly Labeled?	y	
451457	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Cabinet Paint Condition	Good	
451458	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
451459	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
451460	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
451461	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Bushings Connection/Risers	Good	
451462	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Bushing Condition	Good	
451463	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Amps C Ø	170.0	
451464	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Amps B Ø	178.0	
451465	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Amps A Ø	180.0	
451466	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
451467	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
451468	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
451469	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	9 Month Operations	53	
451470	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
451471	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
451472	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
451473	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
451474	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Amps C Ø	0.0	
451475	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Amps B Ø	0.0	
451476	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Amps A Ø	0.0	
451477	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
451478	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
451479	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
451480	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	9 Month Operations	2	
451481	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
451482	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
451483	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Oil Temp Present	35	°C
451484	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Oil Temp Max	35	°C
451485	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
451486	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
451487	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	LTC Totalizer Reading	4204.80	kw
451488	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
451489	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	General Comments		
451490	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	General Comments		
451491	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
451492	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
451493	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Follow-up Action Required?	n	
451494	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
451495	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
451496	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
451497	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
451498	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
451499	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
451500	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
451501	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
451502	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
451503	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
451504	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
451505	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
451506	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
451507	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
451508	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
451509	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
451510	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
451511	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
451512	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
451513	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	Follow-up Action Required?	n	
451514	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
451515	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	General Comments		
451516	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	General Comments		
451517	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC As Found Counter	3056	
451518	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC As Left Counter	3056	
451519	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
451520	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC Current Tap Position	8L	
451521	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC Max Tap Position	2L	
451522	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC Min Tap Position	12L	
451523	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
451524	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
451525	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
451526	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
451527	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC Operations Since Last Insp	494	
451528	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
451529	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
451530	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
451531	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
451532	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	PF000173	PowerFuse	HB-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
451533	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	PF000173	PowerFuse	HB-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
451534	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	PF000172	PowerFuse	HB-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
451535	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	PF000172	PowerFuse	HB-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
451536	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	PF000171	PowerFuse	HB-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
451537	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	PF000171	PowerFuse	HB-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
451538	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	PF000170	PowerFuse	HB-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
451539	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	PF000170	PowerFuse	HB-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
451540	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Unknown Operations	0	
451541	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
451542	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Switching Operations	0	
451543	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
451544	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Operations This Read Vac	0	
451545	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Operations Counter AL	113	
451546	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Operations Counter AF	113	
451547	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
451548	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Maintenance Operations	0	
451549	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
451550	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	General Comments		
451551	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	General Comments		
451552	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
451553	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Follow-up Action Required?	n	
451554	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
451555	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Operations Ground	0	
451556	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Unknown Operations	0	
451557	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Tank Paint Condition	Good	
451558	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Switching Operations	0	
451559	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Operations This Read Vac	0	
451560	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Operations Counter AL	177	
451561	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Operations Counter AF	177	
451562	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Moisture and Leak Free?	y	
451563	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Maintenance Operations	0	
451564	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Grounds in Place?	y	
451565	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	General Comments		
451566	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	General Comments		
451567	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Foundation Condition	Good	
451568	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Follow-up Action Required?	n	
451569	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Follow-up Action Required?	n	
451570	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Operations Ground	0	
451571	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Operations Counter AF	633	
451572	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Operations Counter AL	633	
451573	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Operations This Read Vac	0	
451574	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
451575	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Switching Operations	0	
451576	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
451577	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Unknown Operations	0	
451578	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
451579	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
451580	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
451581	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
451582	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
451583	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
451584	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
451585	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
451586	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
451587	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Vegetation	None	
451588	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Trash Emptied?	y	
451589	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
451590	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
451591	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
451592	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
451593	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
451594	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
451595	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
451596	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
451597	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
451598	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Panels Dusted?	y	
451599	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
451600	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Foundation Condition	Good	
451601	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
451602	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	General Comments		
451603	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
451604	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
451605	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
451606	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
451607	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
451608	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
451609	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
451610	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	General Comments		
451611	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
451612	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
451613	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Floor Swept?	y	
451614	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
451615	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
451616	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Evidence of Insects	None	
451617	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
451618	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
451619	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
451620	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
451621	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Broom on Site?	y	
451622	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
451623	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
451624	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
451625	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	LTCC000369	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
451626	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	LTCC000369	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
451627	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	LTCC000369	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
451628	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	LTCC000369	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
451629	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	LTCC000369	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
451630	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	LTCC000369	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
451631	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
451632	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
451633	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
451634	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
451635	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
451636	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
451637	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
451638	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
451639	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Amps A Ø	20.0	
451640	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Amps B Ø	20.0	
451641	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Amps C Ø	20.0	
451642	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Bushing Condition	Good	
451643	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Bushings Connection/Risers	Good	
451644	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
451645	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
451646	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
451647	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Cabinet Paint Condition	Good	
451648	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
451649	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
451650	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
451651	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
451652	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
451653	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
451654	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
451655	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
451656	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
451657	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
451658	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
451659	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
451660	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
451661	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	General Comments		
451662	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
451663	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Equipment Properly Labeled?	y	
451664	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
451665	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
451666	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
451667	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Operations A Ø	0	
451668	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Operations B Ø	0	
451669	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Operations C Ø	0	
451670	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Operations Ground	0	
451671	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Follow-up Action Required?	n	
451672	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
451673	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
451674	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
451675	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
451676	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
451677	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
451678	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
451679	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
451680	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
451681	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
451682	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Ambient Temp	76	°F
451683	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
451684	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
451685	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Clear of Trash?	y	
451686	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
451687	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
451688	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
451689	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
451690	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
451691	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
451692	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
451693	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
451694	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
451695	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
451696	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
451697	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	General Comments		
451698	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
451699	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
451700	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
451701	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Follow-up Action Required?	n	
451702	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Foundation Condition	Good	
451703	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	General Comments		
451704	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	General Comments		
451705	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Grounds in Place?	y	
451706	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Maintenance Operations	0	
451707	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Moisture and Leak Free?	y	
451708	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
451709	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	Oil Temp Max	60	°C
451710	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
451711	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
451712	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	LTC Totalizer Reading	5360	kw
451713	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
451714	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	General Comments		
451715	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	General Comments		
451716	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
451717	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
451718	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	Follow-up Action Required?	n	
451719	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
451720	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
451721	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
451722	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	General Comments		
451723	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Maintenance Operations	0	
451724	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Operations Counter AF	52	
451725	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Operations Counter AL	52	
451726	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Operations This Read Vac	1	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
451727	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Switching Operations	1	
451728	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Unknown Operations	0	
451729	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
451730	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
451731	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
451732	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
451733	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
451734	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
451735	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
451736	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
451737	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
451738	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	9 Month Operations	5	
451739	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Accumulated Fault Duty A Ph V	1.93	%
451740	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Accumulated Fault Duty B Ph V	1.93	%
451741	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Accumulated Fault Duty C Ph V	0	%
451742	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Amps A Ø	180	
451743	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Amps B Ø	200	
451744	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Amps C Ø	200	
451745	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Bushing Condition	Good	
451746	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Bushings Connection/Risers	Good	
451747	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
451748	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
451749	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
451750	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Cabinet Paint Condition	Good	
451751	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Equipment Properly Labeled?	y	
451752	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Adjusted Amps A Phase V	0	
451753	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Adjusted Amps B Phase V	0	
451754	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Adjusted Amps C Phase V	0	
451755	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Operations A Ø	0	
451756	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Operations B Ø	0	
451757	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Operations C Ø	0	
451758	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Operations Ground	0	
451759	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Follow-up Action Required?	n	
451760	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Follow-up Action Required?	n	
451761	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Foundation Condition	Good	
451762	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	General Comments		
451763	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	General Comments		
451764	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Grounds in Place?	y	
451765	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Heaters (All) Functioning?	y	
451766	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
451767	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
451768	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
451769	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
451770	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
451771	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
451772	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
451773	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
451774	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
451775	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
451776	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
451777	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
451778	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
451779	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
451780	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
451781	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
451782	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
451783	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
451784	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
451785	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
451786	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
451787	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
451788	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
451789	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	General Comments		
451790	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
451791	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
451792	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
451793	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
451794	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
451795	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	General Comments		
451796	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
451797	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
451798	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
451799	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
451800	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
451801	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
451802	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
451803	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
451804	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	°F
451805	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
451806	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	General Comments		
451807	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
451808	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
451809	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
451810	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
451811	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC
451812	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
451813	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	LTCC000369	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
451814	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	LTCC000369	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
451815	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	LTCC000369	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
451816	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	9 Month Operations	1	
451817	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
451818	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
451819	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
451820	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1336	BreakerVacuum	HB-Sec 1 Spare Vac Bkr	VCB Readings	Operations This Read Vac	0	
451821	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1336	BreakerVacuum	HB-Sec 1 Spare Vac Bkr	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
451822	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1336	BreakerVacuum	HB-Sec 1 Spare Vac Bkr	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
451823	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1336	BreakerVacuum	HB-Sec 1 Spare Vac Bkr	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
451824	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1336	BreakerVacuum	HB-Sec 1 Spare Vac Bkr	VCB Readings	9 Month Operations	0	
451825	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Amps A Ø	150.0	
451826	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Amps B Ø	150.0	
451827	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Amps C Ø	150.0	
451828	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
451829	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
451830	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
451831	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Operations A Ø	0	
451832	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Operations B Ø	0	
451833	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Operations C Ø	0	
451834	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Operations Ground	0	
451835	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Follow-up Action Required?	n	
451836	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
451837	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20	
451838	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	Totalizer Meter Reading	.67	
451839	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
451840	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
451841	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
451842	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
451843	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
451844	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
451845	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
451846	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
451847	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
451848	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
451849	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	9 Month Operations	7	
451850	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Unknown Operations	0	
451851	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Tank Paint Condition	Good	
451852	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Switching Operations	0	
451853	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
451854	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Operations This Read Vac	0	
451855	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Operations Counter AL	159	
451856	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Operations Counter AF	159	
451857	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
451858	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Maintenance Operations	0	
451859	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Grounds in Place?	y	
451860	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	General Comments		
451861	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	General Comments		
451862	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Foundation Condition	Good	
451863	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Follow-up Action Required?	n	
451864	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Follow-up Action Required?	n	
451865	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC Current Tap Position	7L	
451866	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC Max Tap Position	3L	
451867	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC Min Tap Position	11L	
451868	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC Operations Since Last Insp	379	
451869	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
451870	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
451871	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
451872	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Operations Ground	0	
451873	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Operations C Ø	0	
451874	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Operations B Ø	0	
451875	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Operations A Ø	0	
451876	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
451877	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
451878	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
451879	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
451880	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
451881	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
451882	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
451883	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
451884	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Amps C Ø	190.0	
451885	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Amps B Ø	205.0	
451886	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Amps A Ø	185.0	
451887	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
451888	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
451889	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
451890	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	9 Month Operations	19	
451891	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Unknown Operations	0	
451892	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Tank Paint Condition	Good	
451893	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Switching Operations	0	
451894	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
451895	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Operations This Read Vac	0	
451896	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Operations Counter AL	226	
451897	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Operations Counter AF	226	
451898	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Moisture and Leak Free?	y	
451899	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Maintenance Operations	0	
451900	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Heaters (All) Functioning?	y	
451901	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Grounds in Place?	y	
451902	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	General Comments		
451903	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	General Comments		
451904	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Foundation Condition	Good	
451905	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Follow-up Action Required?	n	
451906	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Follow-up Action Required?	n	
451907	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Operations Ground	0	
451908	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Operations C Ø	0	
451909	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Operations B Ø	0	
451910	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Operations A Ø	0	
451911	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Adjusted Amps C Phase V	0	
451912	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Adjusted Amps B Phase V	0	
451913	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Adjusted Amps A Phase V	0	
451914	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Switching Operations	0	
451915	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
451916	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Operations This Read Vac	0	
451917	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Operations Counter AL	204	
451918	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Operations Counter AF	204	
451919	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Moisture and Leak Free?	y	
451920	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Maintenance Operations	0	
451921	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Grounds in Place?	y	
451922	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	General Comments		
451923	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	General Comments		
451924	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Foundation Condition	Good	
451925	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Follow-up Action Required?	n	
451926	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Follow-up Action Required?	n	
451927	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Operations Ground	0	
451928	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Operations C Ø	0	
451929	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Operations B Ø	0	
451930	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Operations A Ø	0	
451931	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
451932	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
451933	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
451934	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Equipment Properly Labeled?	y	
451935	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Cabinet Paint Condition	Good	
451936	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
451937	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
451938	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
451939	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Amps C Ø	65.0	
451940	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Amps B Ø	75.0	
451941	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Amps A Ø	65.0	
451942	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
451943	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
451944	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
451945	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	9 Month Operations	23	
451946	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Unknown Operations	0	
451947	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Tank Paint Condition	Good	
451948	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Switching Operations	0	
451949	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
451950	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Operations This Read Vac	0	
451951	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Operations Counter AL	173	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
451952	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Operations Counter AF	173	
451953	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Moisture and Leak Free?	y	
451954	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Maintenance Operations	0	
451955	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Grounds in Place?	y	
451956	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	General Comments		
451957	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	General Comments		
451958	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Foundation Condition	Good	
451959	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Follow-up Action Required?	n	
451960	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Follow-up Action Required?	n	
451961	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Operations Ground	0	
451962	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Operations C Ø	0	
451963	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Operations B Ø	0	
451964	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Operations A Ø	0	
451965	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
451966	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
451967	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
451968	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	Follow-up Action Required?	n	
451969	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
451970	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	General Comments		
451971	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	General Comments		
451972	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC As Found Counter	38028	
451973	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC As Left Counter	38028	
451974	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
451975	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Equipment Properly Labeled?	y	
451976	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Cabinet Paint Condition	Good	
451977	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
451978	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
451979	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
451980	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Amps C Ø	0.0	
451981	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Amps B Ø	0.0	
451982	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Amps A Ø	0.0	
451983	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
451984	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	LTC Totalizer Reading	2312	kw
451985	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
451986	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
451987	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	Oil Temp Max	50	°C
451988	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
451989	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
451990	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
451991	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
451992	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
451993	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
451994	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
451995	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
451996	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	Totalizer Meter Reading	.289	
451997	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	65	
451998	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
451999	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
452000	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
452001	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	Follow-up Action Required?	n	
452002	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
452003	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	General Comments		
452004	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	General Comments		
452005	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC As Found Counter	421945	
452006	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC As Left Counter	421956	
452007	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
452008	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC Current Tap Position	4L	
452009	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC Max Tap Position	4R	
452010	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC Min Tap Position	12L	
452011	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC Operations Since Last Insp	1862	
452012	4/18/2019 11:53	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
452013	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
452014	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Tank Leaks	None	
452015	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
452016	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Operations Counter	13	
452017	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
452018	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
452019	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	General Comments		
452020	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
452021	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
452022	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
452023	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
452024	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
452025	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
452026	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
452027	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
452028	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
452029	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
452030	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Amps C Ø	19.0	
452031	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Amps B Ø	15.0	
452032	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Amps A Ø	8.0	
452033	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
452034	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
452035	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
452036	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
452037	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
452038	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
452039	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
452040	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
452041	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
452042	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
452043	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
452044	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
452045	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
452046	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
452047	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
452048	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
452049	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
452050	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
452051	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
452052	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Equipment Properly Labeled?	y	
452053	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Cabinet Paint Condition	Good	
452054	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
452055	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
452056	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
452057	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Bushings Connection/Risers	Good	
452058	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Bushing Condition	Good	
452059	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Amps C Ø	90	
452060	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Amps B Ø	122	
452061	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Amps A Ø	118	
452062	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Accumulated Fault Duty C Ph V	3.86	%
452063	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Accumulated Fault Duty B Ph V	3.86	%
452064	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Accumulated Fault Duty A Ph V	5.79	%
452065	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	9 Month Operations	6	
452066	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	48	°C
452067	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	52	°C
452068	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	48	°C
452069	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
452070	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	42	°C
452071	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	51	°C
452072	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
452073	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
452074	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
452075	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
452076	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
452077	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
452078	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
452079	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
452080	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
452081	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
452082	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
452083	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
452084	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
452085	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
452086	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
452087	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
452088	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
452089	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	General Comments		
452090	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
452091	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
452092	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
452093	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
452094	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
452095	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
452096	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
452097	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
452098	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
452099	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
452100	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
452101	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
452102	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
452103	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
452104	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
452105	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
452106	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
452107	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
452108	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
452109	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
452110	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
452111	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
452112	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
452113	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
452114	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
452115	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
452116	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	Follow-up Action Required?	n	
452117	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
452118	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
452119	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	General Comments		
452120	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	General Comments		
452121	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	General Comments		
452122	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC As Found Counter	6167	
452123	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC As Left Counter	6167	
452124	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
452125	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC Current Tap Position	10L	
452126	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC Max Tap Position	Neutral	
452127	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC Min Tap Position	12L	
452128	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
452129	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
452130	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC Operations Since Last Insp	349	
452131	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
452132	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
452133	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
452134	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
452135	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Unknown Operations	0	
452136	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Switching Operations	0	
452137	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Operations This Read Vac	0	
452138	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Operations Counter AL	123	
452139	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Operations Counter AF	123	
452140	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Maintenance Operations	0	
452141	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	General Comments		
452142	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Follow-up Action Required?	n	
452143	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Operations Ground	0	
452144	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Operations C Ø	0	
452145	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Operations B Ø	0	
452146	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Operations A Ø	0	
452147	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
452148	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
452149	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
452150	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Amps C Ø	0.0	
452151	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Amps B Ø	0.0	
452152	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Amps A Ø	0.0	
452153	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Accumulated Fault Duty C Ph V	7.2	%
452154	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Accumulated Fault Duty B Ph V	7.2	%
452155	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Accumulated Fault Duty A Ph V	7.2	%
452156	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	9 Month Operations	1	
452157	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	All Connections OK?	y	
452158	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	Follow-up Action Required?	n	
452159	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	General Comments		
452160	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	LTC Operation Checked?	y	
452161	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
452162	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
452163	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
452164	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	VRR Time Delay	30	Seconds
452165	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Unknown Operations	0	
452166	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Switching Operations	1	
452167	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Operations This Read Vac	1	
452168	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Operations Counter AL	123	
452169	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Operations Counter AF	123	
452170	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Maintenance Operations	0	
452171	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	General Comments		
452172	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Follow-up Action Required?	n	
452173	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Operations Ground	0	
452174	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Operations C Ø	0	
452175	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Operations B Ø	0	
452176	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	9 Month Operations	2	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
452177	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Accumulated Fault Duty A Ph V	12.28	%
452178	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Accumulated Fault Duty B Ph V	14.13	%
452179	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Accumulated Fault Duty C Ph V	9.83	%
452180	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Amps A Ø	59.0	
452181	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Amps B Ø	57.0	
452182	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Amps C Ø	60.0	
452183	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
452184	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
452185	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
452186	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Unknown Operations	0	
452187	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Operations A Ø	0	
452188	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Switching Operations	0	
452189	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
452190	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
452191	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
452192	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
452193	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
452194	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
452195	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
452196	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
452197	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
452198	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
452199	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
452200	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
452201	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	243	
452202	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	243	
452203	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
452204	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
452205	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
452206	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
452207	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
452208	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
452209	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
452210	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
452211	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
452212	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
452213	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
452214	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
452215	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
452216	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	800.0	
452217	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	800.0	
452218	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	800.0	
452219	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
452220	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
452221	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
452222	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
452223	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
452224	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
452225	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
452226	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
452227	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
452228	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
452229	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
452230	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Follow-up Action Required?	n	
452231	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
452232	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
452233	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	General Comments		
452234	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	General Comments		
452235	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
452236	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	LTC Totalizer Reading	6768.00	kw
452237	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
452238	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
452239	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2000	psi
452240	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Oil Temp Max	35	°C
452241	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Oil Temp Present	35	°C
452242	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
452243	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
452244	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
452245	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
452246	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
452247	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
452248	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
452249	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
452250	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Totalizer Meter Reading	.4700	
452251	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Winding Temp Max	45	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
452252	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Winding Temp Present	45	°C
452253	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
452254	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
452255	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	Follow-up Action Required?	n	
452256	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
452257	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	General Comments		
452258	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	45	°C
452259	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
452260	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Patrol Inspection	General Comments		
452261	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
452262	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
452263	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations Ground	0	
452264	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
452265	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
452266	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
452267	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
452268	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
452269	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
452270	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
452271	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Amps C Ø	558.0	
452272	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Amps B Ø	550.0	
452273	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Amps A Ø	556.0	
452274	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
452275	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
452276	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
452277	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	275	
452278	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	Oil Temp Present	18	°C
452279	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
452280	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	General Comments		
452281	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
452282	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	9 Month Operations	0	
452283	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	All Connections OK?	y	
452284	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	Follow-up Action Required?	n	
452285	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	General Comments		
452286	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	LTC Operation Checked?	y	
452287	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	LTC Output Voltage Level	124	VAC
452288	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	VRR Base Voltage AF	124	VAC
452289	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	VRR Base Voltage AL	124	VAC
452290	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	VRR Time Delay	30	Seconds
452291	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Unknown Operations	0	
452292	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Tank Paint Condition	Good	
452293	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Switching Operations	0	
452294	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
452295	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Operations This Read Vac	0	
452296	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Operations Counter AL	241	
452297	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Operations Counter AF	241	
452298	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Moisture and Leak Free?	y	
452299	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Maintenance Operations	0	
452300	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Grounds in Place?	y	
452301	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	General Comments		
452302	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	General Comments		
452303	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Foundation Condition	Good	
452304	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Follow-up Action Required?	n	
452305	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Follow-up Action Required?	n	
452306	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Operations Ground	0	
452307	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Operations C Ø	0	
452308	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Operations B Ø	0	
452309	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Operations A Ø	0	
452310	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
452311	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
452312	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
452313	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Equipment Properly Labeled?	y	
452314	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Cabinet Paint Condition	Good	
452315	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
452316	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
452317	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
452318	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Amps C Ø	110.0	
452319	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Amps B Ø	115.0	
452320	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Amps A Ø	110.0	
452321	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
452322	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
452323	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
452324	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	9 Month Operations	6	
452325	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Unknown Operations	0	
452326	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
452327	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Operations This Read Vac	0	
452328	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Operations Counter AL	103	
452329	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Operations Counter AF	103	
452330	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Maintenance Operations	0	
452331	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	General Comments		
452332	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	25	°C
452333	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	42	°C
452334	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	12	°C
452335	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Operations B Ø	0	
452336	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Operations C Ø	0	
452337	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Operations Ground	0	
452338	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Follow-up Action Required?	n	
452339	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	General Comments		
452340	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Maintenance Operations	0	
452341	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Operations Counter AF	81	
452342	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Operations Counter AL	81	
452343	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Operations This Read Vac	0	
452344	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Switching Operations	0	
452345	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Unknown Operations	0	
452346	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	9 Month Operations	1	
452347	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Accumulated Fault Duty A Ph V	12.28	%
452348	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Accumulated Fault Duty B Ph V	14.13	%
452349	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Accumulated Fault Duty C Ph V	9.83	%
452350	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Amps A Ø	22.0	
452351	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Amps B Ø	22.0	
452352	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Amps C Ø	22.0	
452353	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
452354	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
452355	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
452356	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Operations A Ø	0	
452357	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Operations B Ø	0	
452358	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Operations C Ø	0	
452359	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Operations Ground	0	
452360	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Follow-up Action Required?	n	
452361	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	General Comments		
452362	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Maintenance Operations	0	
452363	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Operations Counter AF	81	
452364	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Operations Counter AL	81	
452365	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Operations This Read Vac	0	
452366	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Switching Operations	0	
452367	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Unknown Operations	0	
452368	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Operations A Ø	0	
452369	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
452370	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
452371	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
452372	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Amps C Ø	0.0	
452373	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Amps B Ø	0.0	
452374	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Amps A Ø	0.0	
452375	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Accumulated Fault Duty C Ph V	7.20	%
452376	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Accumulated Fault Duty B Ph V	7.20	%
452377	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Accumulated Fault Duty A Ph V	7.20	%
452378	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	9 Month Operations	1	
452379	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
452380	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	General Comments		
452381	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
452382	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
452383	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
452384	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
452385	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
452386	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
452387	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
452388	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
452389	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
452390	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
452391	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
452392	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
452393	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
452394	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
452395	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	25	°C
452396	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
452397	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
452398	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
452399	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
452400	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
452401	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
452402	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
452403	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	General Comments		
452404	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	General Comments		
452405	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Maintenance Operations	0	
452406	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
452407	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
452408	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
452409	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
452410	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Operations Counter AF	676	
452411	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Operations Counter AL	676	
452412	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Operations This Read Vac	2	
452413	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
452414	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Switching Operations	0	
452415	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Follow-up Action Required?	n	
452416	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
452417	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
452418	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
452419	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
452420	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
452421	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
452422	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Tank Paint Condition	Good	
452423	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Unknown Operations	0	
452424	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Heaters (All) Functioning?	y	
452425	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Maintenance Operations	0	
452426	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Operations Counter AF	75	
452427	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Operations Counter AL	75	
452428	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Operations This Read Vac	0	
452429	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Switching Operations	0	
452430	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Unknown Operations	0	
452431	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	46	°C
452432	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Cabinet Paint Condition	Good	
452433	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
452434	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
452435	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
452436	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Bushings Connection/Risers	Good	
452437	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Bushing Condition	Good	
452438	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Amps C Ø	220	
452439	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Amps B Ø	220	
452440	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Amps A Ø	200	
452441	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Accumulated Fault Duty C Ph V	1.93	%
452442	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Accumulated Fault Duty B Ph V	1.93	%
452443	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	46	°C
452444	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	50	°C
452445	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Accumulated Fault Duty A Ph V	23.04	%
452446	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
452447	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	General Comments		
452448	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	General Comments		
452449	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC As Found Counter	805	
452450	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
452451	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
452452	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
452453	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	VRR Time Delay	30	Seconds
452454	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC As Left Counter	815	
452455	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
452456	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	9 Month Operations	5	
452457	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	VRR Time Delay	60	Seconds
452458	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
452459	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
452460	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
452461	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	LTC Output Voltage Level	14.3	VAC
452462	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	LTC Operation Checked?	y	
452463	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	General Comments		
452464	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	Follow-up Action Required?	n	
452465	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	All Connections OK?	y	
452466	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Amps A Ø	52.0	
452467	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Amps B Ø	60.0	
452468	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Amps C Ø	73.0	
452469	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
452470	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
452471	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
452472	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
452473	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
452474	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
452475	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
452476	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
452477	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
452478	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
452479	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	General Comments		
452480	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
452481	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
452482	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Operations Counter	7	
452483	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
452484	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Tank Leaks	None	
452485	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
452486	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
452487	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
452488	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	General Comments		
452489	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Foundation Condition	Good	
452490	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	General Comments		
452491	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	General Comments		
452492	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Grounds in Place?	y	
452493	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
452494	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	67	°F
452495	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
452496	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
452497	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
452498	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC Current Tap Position	4L	
452499	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC Max Tap Position	2R	
452500	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC Min Tap Position	10L	
452501	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC Operations Since Last Insp	793	
452502	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
452503	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
452504	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
452505	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
452506	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Amps C Ø	87.0	
452507	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Amps B Ø	89.0	
452508	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Amps A Ø	85.0	
452509	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Accumulated Fault Duty C Ph V	10.08	%
452510	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Accumulated Fault Duty B Ph V	28.80	%
452511	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Accumulated Fault Duty A Ph V	23.04	%
452512	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	9 Month Operations	3	
452513	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
452514	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	General Comments		
452515	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
452516	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
452517	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
452518	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Moisture and Leak Free?	y	
452519	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Operations Counter AF	520	
452520	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Operations Counter AL	520	
452521	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Operations This Read Vac	0	
452522	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
452523	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
452524	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
452525	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
452526	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Switching Operations	0	
452527	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Tank Paint Condition	Good	
452528	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Unknown Operations	0	
452529	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
452530	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
452531	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
452532	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
452533	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
452534	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
452535	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
452536	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
452537	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
452538	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
452539	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
452540	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
452541	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
452542	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
452543	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
452544	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
452545	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
452546	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	54	°C
452547	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	50	°C
452548	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	58	°C
452549	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
452550	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
452551	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
452552	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
452553	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	All Connections OK?	y	
452554	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	Follow-up Action Required?	n	
452555	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	General Comments		
452556	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	LTC Operation Checked?	y	
452557	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
452558	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
452559	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
452560	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
452561	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	VRR Time Delay	30	Seconds
452562	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
452563	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
452564	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
452565	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
452566	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
452567	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
452568	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
452569	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Bushings Connection/Risers	Good	
452570	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Bushing Condition	Good	
452571	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Amps C Ø	60.0	
452572	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Accumulated Fault Duty A Ph V	1.93	%
452573	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	9 Month Operations	5	
452574	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Amps B Ø	100.0	
452575	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Amps A Ø	60.0	
452576	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
452577	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
452578	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
452579	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	9 Month Operations	9	
452580	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
452581	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	9 Month Operations	6	
452582	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Unknown Operations	0	
452583	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
452584	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Switching Operations	0	
452585	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Operations This Read Vac	0	
452586	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Operations Counter AL	71	
452587	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Operations Counter AF	71	
452588	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Maintenance Operations	0	
452589	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
452590	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	General Comments		
452591	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Follow-up Action Required?	n	
452592	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Operations Ground	0	
452593	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Operations C Ø	0	
452594	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Operations B Ø	0	
452595	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Operations A Ø	0	
452596	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
452597	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
452598	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Foundation Condition	Good	
452599	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
452600	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
452601	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	General Comments		
452602	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
452603	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
452604	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
452605	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Oil Temp Present	45	°C
452606	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Oil Temp Max	45	°C
452607	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
452608	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
452609	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
452610	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	LTC Totalizer Reading	8036.00	kw
452611	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Equipment Properly Labeled?	y	
452612	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
452613	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Cabinet Paint Condition	Good	
452614	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
452615	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
452616	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
452617	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
452618	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
452619	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
452620	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
452621	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
452622	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
452623	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
452624	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
452625	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
452626	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
452627	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
452628	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
452629	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	General Comments		
452630	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	General Comments		
452631	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
452632	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
452633	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
452634	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Adjusted Amps C Phase V	0	
452635	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Operations A Ø	0	
452636	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Amps C Ø	85.0	
452637	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Amps B Ø	89.0	
452638	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Amps A Ø	87.0	
452639	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Accumulated Fault Duty C Ph V	10.08	%
452640	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Accumulated Fault Duty B Ph V	34.56	%
452641	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Adjusted Amps B Phase V	0	
452642	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Adjusted Amps A Phase V	0	
452643	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Equipment Properly Labeled?	y	
452644	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
452645	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Operations B Ø	0	
452646	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Operations A Ø	0	
452647	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
452648	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
452649	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
452650	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Totalizer Meter Multiplier	14000	
452651	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Totalizer Meter Reading	.5740	
452652	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
452653	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
452654	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC As Left Counter	274319	
452655	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
452656	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC Current Tap Position	8L	
452657	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Adjusted Amps C Phase V	6.09	
452658	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC Max Tap Position	2L	
452659	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC Min Tap Position	13L	
452660	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC Operations Since Last Insp	908	
452661	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC As Found Counter	274309	
452662	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	General Comments		
452663	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	General Comments		
452664	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
452665	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	Follow-up Action Required?	n	
452666	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
452667	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
452668	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
452669	4/18/2019 15:10	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
452670	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Operations C Ø	2	
452671	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Operations Ground	0	
452672	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
452673	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Operations A Ø	0	
452674	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Operations B Ø	0	
452675	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Operations C Ø	0	
452676	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Operations Ground	0	
452677	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Follow-up Action Required?	n	
452678	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Follow-up Action Required?	n	
452679	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Follow-up Action Required?	n	
452680	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Foundation Condition	Good	
452681	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	General Comments		
452682	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	General Comments		
452683	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Grounds in Place?	y	
452684	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Maintenance Operations	0	
452685	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Moisture and Leak Free?	y	
452686	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
452687	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
452688	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
452689	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
452690	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
452691	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
452692	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
452693	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
452694	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
452695	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
452696	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
452697	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
452698	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
452699	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
452700	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
452701	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
452702	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
452703	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
452704	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
452705	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
452706	4/18/2019 13:33	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	Follow-up Action Required?	n	
452707	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
452708	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
452709	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	General Comments		
452710	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
452711	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
452712	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
452713	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	General Comments		
452714	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
452715	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
452716	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
452717	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
452718	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
452719	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC As Found Counter	26677	
452720	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC As Left Counter	26677	
452721	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
452722	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
452723	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
452724	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
452725	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
452726	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
452727	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
452728	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	All Connections OK?	y	
452729	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
452730	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
452731	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
452732	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
452733	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
452734	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
452735	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	328	
452736	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	All Connections OK?	y	
452737	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	Follow-up Action Required?	n	
452738	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	General Comments		
452739	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	LTC Operation Checked?	y	
452740	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
452741	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
452742	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
452743	4/18/2019 15:44	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	VRR Time Delay	30	Seconds
452744	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Operations B Ø	0	
452745	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Operations C Ø	0	
452746	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
452747	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	LTC Operation Checked?	y	
452748	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Operations Ground	0	
452749	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Follow-up Action Required?	n	
452750	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	General Comments		
452751	4/18/2019 10:56	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Follow-up Action Required?	n	
452752	4/18/2019 9:53	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
452753	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC Min Tap Position	14L	
452754	4/18/2019 11:14	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5L	
452755	4/18/2019 12:02	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	Follow-up Action Required?	n	
452756	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
452757	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	LTC Operation Checked?	y	
452758	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	General Comments		
452759	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	Follow-up Action Required?	n	
452760	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	All Connections OK?	y	
452761	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
452762	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
452763	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	VRR Time Delay	0	Seconds
452764	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
452765	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
452766	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
452767	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
452768	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
452769	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
452770	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
452771	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	General Comments		
452772	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Follow-up Action Required?	n	
452773	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
452774	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	General Comments		
452775	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
452776	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
452777	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
452778	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Operations Ground	0	
452779	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Operations C Ø	0	
452780	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
452781	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
452782	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Panels Dusted?	y	
452783	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	General Comments		
452784	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
452785	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
452786	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
452787	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
452788	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
452789	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Totalizer Meter Reading	.1866	
452790	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
452791	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Top Oil Temperature Present	41	°C
452792	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Top Oil Temperature Max	53	°C
452793	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
452794	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
452795	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
452796	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Operations B Ø	0	
452797	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Operations A Ø	0	
452798	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
452799	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
452800	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
452801	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
452802	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	General Comments		
452803	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Floor Swept?	y	
452804	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
452805	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
452806	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
452807	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
452808	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
452809	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
452810	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	LTC Totalizer Reading	1492.80	kw
452811	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
452812	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
452813	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
452814	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Foundation Condition	Good	
452815	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	General Comments		
452816	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
452817	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
452818	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
452819	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
452820	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
452821	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
452822	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Follow-up Action Required?	n	
452823	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Follow-up Action Required?	n	
452824	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Operations Ground	0	
452825	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Operations C Ø	0	
452826	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Operations B Ø	0	
452827	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Operations A Ø	0	
452828	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
452829	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	LTCC000549	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
452830	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	LTCC000549	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
452831	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Follow-up Action Required?	n	
452832	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
452833	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	LTCC000549	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
452834	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
452835	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
452836	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
452837	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Evidence of Insects	None	
452838	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
452839	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	General Comments		
452840	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Grounds in Place?	y	
452841	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
452842	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Heaters (All) Functioning?	y	
452843	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Maintenance Operations	0	
452844	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Moisture and Leak Free?	y	
452845	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Operations Counter AF	461	
452846	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Operations Counter AL	461	
452847	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
452848	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
452849	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
452850	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	LTCC000549	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
452851	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
452852	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Switching Operations	0	
452853	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Operations This Read Vac	0	
452854	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Operations Counter AL	285	
452855	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Operations Counter AF	285	
452856	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Maintenance Operations	0	
452857	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
452858	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
452859	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
452860	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
452861	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
452862	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
452863	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
452864	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	General Comments	nitro bottle needs to be filled	
452865	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
452866	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
452867	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
452868	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
452869	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
452870	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
452871	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
452872	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
452873	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
452874	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
452875	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
452876	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
452877	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BCH000206	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
452878	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BCH000206	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
452879	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BCH000206	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
452880	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BCH000206	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
452881	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BCH000206	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
452882	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
452883	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BCH000206	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.100	millivolts
452884	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
452885	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
452886	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
452887	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	PF000071	PowerFuse	CY-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
452888	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	PF000071	PowerFuse	CY-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
452889	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
452890	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
452891	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
452892	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
452893	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
452894	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
452895	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
452896	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
452897	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
452898	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Follow-up Action Required?	n	
452899	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
452900	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
452901	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	General Comments		
452902	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	1	
452903	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
452904	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
452905	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
452906	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	650.0	
452907	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	760.0	
452908	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	760.0	
452909	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
452910	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
452911	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
452912	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
452913	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
452914	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
452915	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
452916	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
452917	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
452918	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
452919	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
452920	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
452921	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
452922	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
452923	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
452924	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
452925	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
452926	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
452927	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
452928	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	VRR Time Delay	30	Seconds
452929	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
452930	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
452931	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
452932	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	LTC Operation Checked?	y	
452933	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	General Comments		
452934	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	Follow-up Action Required?	n	
452935	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	All Connections OK?	y	
452936	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	BCH001021	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
452937	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	BCH001021	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
452938	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	BCH001021	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
452939	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	BCH001021	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
452940	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	BCH001021	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
452941	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	BCH001021	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
452942	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	BCH001021	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
452943	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	BCH001021	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.930	millivolts
452944	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
452945	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
452946	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
452947	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
452948	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
452949	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
452950	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
452951	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
452952	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
452953	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
452954	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
452955	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
452956	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
452957	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
452958	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
452959	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
452960	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
452961	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
452962	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
452963	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
452964	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
452965	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
452966	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
452967	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
452968	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
452969	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	260	
452970	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	260	
452971	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
452972	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
452973	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
452974	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Totalizer Meter Reading	.3390	
452975	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
452976	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
452977	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
452978	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
452979	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
452980	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	17	
452981	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	9 Month Operations	9	
452982	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Accumulated Fault Duty A Ph V	25.51	%
452983	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Accumulated Fault Duty B Ph V	30.29	%
452984	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Accumulated Fault Duty C Ph V	15.15	%
452985	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Unknown Operations	0	
452986	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Tank Paint Condition	Good	
452987	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Switching Operations	4	
452988	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Operations This Read Vac	4	
452989	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Amps A Ø	356.0	
452990	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Amps B Ø	359.0	
452991	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Amps C Ø	333.0	
452992	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
452993	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
452994	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	General Comments		
452995	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
452996	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	LTC Totalizer Reading	2440.80	kw
452997	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	VRR Time Delay	30	Seconds
452998	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
452999	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
453000	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
453001	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	LTC Operation Checked?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
453002	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	General Comments		
453003	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	Follow-up Action Required?	n	
453004	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	All Connections OK?	y	
453005	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
453006	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
453007	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
453008	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Oil Temp Max	65	°C
453009	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Oil Temp Present	35	°C
453010	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
453011	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
453012	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
453013	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	16	
453014	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	16	
453015	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	144	
453016	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	144	
453017	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
453018	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
453019	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
453020	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
453021	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
453022	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
453023	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
453024	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
453025	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
453026	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
453027	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
453028	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
453029	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
453030	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
453031	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
453032	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
453033	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
453034	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
453035	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
453036	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
453037	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
453038	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
453039	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
453040	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
453041	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	°F
453042	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
453043	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
453044	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
453045	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
453046	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
453047	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
453048	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	General Comments		
453049	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
453050	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
453051	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
453052	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
453053	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Switching Operations	6	
453054	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Operations This Read Vac	6	
453055	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Operations Counter AL	304	
453056	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Operations Counter AF	304	
453057	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Moisture and Leak Free?	y	
453058	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Maintenance Operations	0	
453059	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
453060	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Grounds in Place?	y	
453061	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	General Comments		
453062	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	General Comments		
453063	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Foundation Condition	Good	
453064	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Follow-up Action Required?	n	
453065	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Follow-up Action Required?	n	
453066	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Operations Ground	0	
453067	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Operations C Ø	0	
453068	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Operations B Ø	0	
453069	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Operations A Ø	0	
453070	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
453071	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
453072	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
453073	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
453074	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
453075	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
453076	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
453077	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
453078	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Bushings Connection/Risers	Good	
453079	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Bushing Condition	Good	
453080	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Amps C Ø	230.0	
453081	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Amps B Ø	230.0	
453082	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Amps A Ø	240.0	
453083	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
453084	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
453085	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
453086	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	9 Month Operations	10	
453087	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Switching Operations	4	
453088	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Tank Paint Condition	Good	
453089	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Unknown Operations	0	
453090	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
453091	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
453092	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Floor Swept?	n	
453093	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
453094	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
453095	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
453096	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	6	
453097	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
453098	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	260	
453099	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
453100	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
453101	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
453102	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Trash Emptied?	n	
453103	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
453104	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
453105	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Panels Dusted?	y	
453106	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
453107	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
453108	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	General Comments		
453109	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
453110	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
453111	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Floor Swept?	y	
453112	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
453113	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
453114	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Evidence of Insects	None	
453115	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
453116	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
453117	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	General Comments		
453118	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
453119	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
453120	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
453121	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
453122	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
453123	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
453124	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
453125	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Broom on Site?	y	
453126	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
453127	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
453128	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
453129	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
453130	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
453131	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
453132	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
453133	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
453134	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
453135	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	61.61	%
453136	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	61.61	%
453137	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	61.61	%
453138	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	2	
453139	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Unknown Operations	0	
453140	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Tank Paint Condition	Good	
453141	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
453142	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
453143	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
453144	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.8	amps
453145	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Moisture and Leak Free?	y	
453146	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Operations Counter AF	460	
453147	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Operations Counter AL	460	
453148	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
453149	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
453150	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
453151	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	9 Month Operations	4	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
453152	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Operations This Read Vac	4	
453153	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
453154	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	y	
453155	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	General Comments	FLOAT VOLTAGE IS STATING TO HIGH	
453156	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
453157	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Follow-up Action Required?	n	
453158	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	General Comments		
453159	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Maintenance Operations	0	
453160	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Operations Counter AF	197	
453161	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Operations Counter AL	197	
453162	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Operations This Read Vac	0	
453163	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Switching Operations	0	
453164	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Unknown Operations	0	
453165	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
453166	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
453167	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
453168	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
453169	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
453170	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
453171	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
453172	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
453173	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
453174	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
453175	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
453176	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
453177	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
453178	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
453179	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
453180	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
453181	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
453182	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
453183	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
453184	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	9 Month Operations	8	
453185	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
453186	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
453187	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
453188	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Amps A Ø	100.0	
453189	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Amps B Ø	100.0	
453190	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Amps C Ø	100.0	
453191	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Bushing Condition	Good	
453192	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Bushings Connection/Risers	Good	
453193	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
453194	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
453195	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
453196	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Cabinet Paint Condition	Good	
453197	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Equipment Properly Labeled?	y	
453198	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
453199	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
453200	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
453201	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Operations A Ø	0	
453202	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Operations B Ø	0	
453203	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Patrol Inspection	General Comments		
453204	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Patrol Inspection	Follow-up Action Required?	n	
453205	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Patrol Inspection	Equipment Properly Labeled?	y	
453206	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Operations C Ø	0	
453207	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Operations Ground	0	
453208	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Follow-up Action Required?	n	
453209	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Follow-up Action Required?	n	
453210	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Foundation Condition	Good	
453211	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	General Comments		
453212	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	General Comments		
453213	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Grounds in Place?	y	
453214	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Heaters (All) Functioning?	y	
453215	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Maintenance Operations	0	
453216	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	6	
453217	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	811	
453218	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	811	
453219	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
453220	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	General Comments		
453221	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
453222	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Panels Dusted?	n	
453223	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
453224	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
453225	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Trash Emptied?	n	
453226	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
453227	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
453228	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
453229	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
453230	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
453231	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
453232	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
453233	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
453234	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
453235	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
453236	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
453237	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
453238	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	General Comments		
453239	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	General Comments		
453240	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
453241	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
453242	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	18	
453243	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
453244	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
453245	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
453246	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
453247	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
453248	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
453249	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
453250	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
453251	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	Top Oil Temperature Present	23	°C
453252	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
453253	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
453254	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	Top Oil Temperature Max	35	°C
453255	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
453256	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
453257	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
453258	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
453259	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
453260	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
453261	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	9 Month Operations	1	
453262	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Accumulated Fault Duty A Ph V	16.74	%
453263	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Accumulated Fault Duty B Ph V	18.33	%
453264	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Accumulated Fault Duty C Ph V	7.97	%
453265	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Amps A Ø	154.0	
453266	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Amps B Ø	164.0	
453267	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Amps C Ø	158.0	
453268	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
453269	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
453270	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
453271	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Operations A Ø	0	
453272	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Operations B Ø	0	
453273	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Operations C Ø	0	
453274	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Operations Ground	0	
453275	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Follow-up Action Required?	n	
453276	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Patrol Inspection	General Comments		
453277	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	General Comments		
453278	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Maintenance Operations	0	
453279	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Operations Counter AF	433	
453280	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Operations Counter AL	433	
453281	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Operations This Read AM	0	
453282	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
453283	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
453284	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
453285	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Foundation Condition	Good	
453286	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	General Comments		
453287	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
453288	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
453289	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
453290	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
453291	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Unknown Operations	0	
453292	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Tank Paint Condition	Good	
453293	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Switching Operations	4	
453294	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Operations This Read Vac	4	
453295	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
453296	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
453297	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
453298	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
453299	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
453300	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Switching Operations	0	
453301	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
453302	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
453303	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Unknown Operations	0	
453304	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	General Comments		
453305	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
453306	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Vegetation	None	
453307	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
453308	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	9 Month Operations	4	
453309	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Operations Counter AL	201	
453310	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Operations Counter AF	201	
453311	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
453312	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
453313	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
453314	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
453315	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
453316	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Broom on Site?	n	
453317	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
453318	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Amps A Ø	60.0	
453319	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Amps B Ø	100.0	
453320	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Amps C Ø	80.0	
453321	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Bushing Condition	Good	
453322	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Bushings Connection/Risers	Good	
453323	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Moisture and Leak Free?	y	
453324	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Maintenance Operations	0	
453325	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
453326	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Ambient Temp	74	°F
453327	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
453328	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
453329	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Clear of Trash?	y	
453330	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
453331	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
453332	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
453333	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
453334	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
453335	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
453336	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Equipment Properly Labeled?	y	
453337	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Cabinet Paint Condition	Good	
453338	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	LTCC000549	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
453339	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
453340	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
453341	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
453342	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Bushings Connection/Risers	Good	
453343	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Bushing Condition	Good	
453344	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Amps C Ø	80.0	
453345	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Amps B Ø	60.0	
453346	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	LTCC000549	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
453347	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	LTCC000549	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
453348	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	LTCC000549	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
453349	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	LTCC000549	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
453350	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Ambient Temp	72	°F
453351	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
453352	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Clear of Trash?	y	
453353	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
453354	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
453355	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Amps A Ø	60.0	
453356	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
453357	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
453358	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
453359	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
453360	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	9 Month Operations	4	
453361	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Ambient Temp	76	°F
453362	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
453363	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Clear of Trash?	y	
453364	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
453365	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
453366	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
453367	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
453368	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
453369	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
453370	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	General Comments		
453371	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
453372	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
453373	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Vegetation	None	
453374	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
453375	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	9 Months Operations	0	
453376	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
453377	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
453378	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
453379	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
453380	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
453381	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Amps A Ø	0.0	
453382	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Amps B Ø	0.0	
453383	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Amps C Ø	0.0	
453384	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
453385	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
453386	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
453387	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
453388	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Operations A Ø	0	
453389	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Operations B Ø	0	
453390	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Operations C Ø	0	
453391	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Operations Ground	0	
453392	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Patrol Inspection	Follow-up Action Required?	n	
453393	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
453394	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
453395	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
453396	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Equipment Properly Labeled?	y	
453397	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Cabinet Paint Condition	Good	
453398	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
453399	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
453400	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
453401	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Bushings Connection/Risers	Good	
453402	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
453403	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Bushing Condition	Good	
453404	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Amps C Ø	100.0	
453405	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
453406	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
453407	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Operations A Ø	0	
453408	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Operations B Ø	0	
453409	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Amps B Ø	110.0	
453410	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Amps A Ø	100.0	
453411	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Operations C Ø	0	
453412	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Operations Ground	0	
453413	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Follow-up Action Required?	n	
453414	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Follow-up Action Required?	n	
453415	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Foundation Condition	Good	
453416	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	General Comments		
453417	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
453418	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
453419	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
453420	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Evidence of Insects	None	
453421	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	General Comments		
453422	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Grounds in Place?	y	
453423	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Heaters (All) Functioning?	y	
453424	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Maintenance Operations	0	
453425	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
453426	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
453427	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
453428	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	260	
453429	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Tank Paint Condition	Good	
453430	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Tank Leaks	None	
453431	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Surge Arrester Condition	Good	
453432	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
453433	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
453434	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Reg Operation Checked?	y	
453435	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Reg Oil Level	Good	
453436	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
453437	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Moisture and Leak Free?	y	
453438	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Min Tap Position	15L	
453439	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Max Tap Position	8R	
453440	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Grounds in Place?	y	
453441	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	General Comments		
453442	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Gauge(s) Condition	Good	
453443	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Foundation Condition	Good	
453444	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Follow-up Action Required?	n	
453445	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
453446	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Current Tap Position	1L	
453447	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
453448	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
453449	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
453450	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
453451	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
453452	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
453453	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
453454	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Cabinet Paint Condition	Good	
453455	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Equipment Properly Labeled?	y	
453456	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
453457	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
453458	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	General Comments		
453459	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
453460	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
453461	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
453462	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Heaters (All) Functioning?	y	
453463	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Grounds in Place?	y	
453464	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	General Comments		
453465	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	General Comments		
453466	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Foundation Condition	Good	
453467	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Follow-up Action Required?	n	
453468	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Follow-up Action Required?	n	
453469	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Operations Ground	0	
453470	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Operations C Ø	0	
453471	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Operations B Ø	0	
453472	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Operations A Ø	0	
453473	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
453474	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
453475	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Vegetation	None	
453476	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
453477	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
453478	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
453479	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
453480	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
453481	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
453482	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
453483	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
453484	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Oil Temp Max	65	°C
453485	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
453486	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
453487	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
453488	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
453489	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
453490	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
453491	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
453492	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
453493	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
453494	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
453495	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
453496	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
453497	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Foundation Condition	Good	
453498	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
453499	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
453500	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	General Comments		
453501	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
453502	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
453503	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
453504	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
453505	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
453506	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
453507	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
453508	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
453509	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
453510	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
453511	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
453512	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
453513	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Follow-up Action Required?	n	
453514	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
453515	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
453516	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Maintenance Operations	0	
453517	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Grounds in Place?	y	
453518	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	General Comments		
453519	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	General Comments		
453520	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Foundation Condition	Good	
453521	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	550.0	
453522	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	550.0	
453523	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
453524	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Follow-up Action Required?	n	
453525	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Follow-up Action Required?	n	
453526	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Accumulated Fault Duty C Ph AM	2.41	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
453527	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	General Comments		
453528	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Operations Ground	0	
453529	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Operations C Ø	0	
453530	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Operations B Ø	0	
453531	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Operations A Ø	0	
453532	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
453533	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
453534	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Accumulated Fault Duty B Ph AM	1.2	%
453535	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Accumulated Fault Duty A Ph AM	4.82	%
453536	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
453537	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Equipment Properly Labeled?	y	
453538	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Cabinet Paint Condition	Good	
453539	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
453540	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
453541	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
453542	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	9 Months Operations	7	
453543	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Bushings Connection/Risers	Good	
453544	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Bushing Condition	Good	
453545	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Amps C Ø	120.0	
453546	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Amps B Ø	120.0	
453547	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Amps A Ø	120.0	
453548	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
453549	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	Follow-up Action Required?	n	
453550	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
453551	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	General Comments		
453552	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	General Comments		
453553	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC As Found Counter	64791	
453554	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC As Left Counter	64800	
453555	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
453556	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC Current Tap Position	6L	
453557	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC Max Tap Position	2R	
453558	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC Min Tap Position	12L	
453559	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
453560	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC Operations Since Last Insp	742	
453561	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
453562	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
453563	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
453564	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
453565	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
453566	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	9 Month Operations	6	
453567	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Unknown Operations	0	
453568	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Tank Paint Condition	Good	
453569	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Switching Operations	4	
453570	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	General Comments		
453571	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
453572	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
453573	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Grounds in Place?	y	
453574	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	General Comments	y	
453575	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
453576	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Foundation Condition	Good	
453577	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Follow-up Action Required?	n	
453578	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
453579	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
453580	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
453581	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
453582	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
453583	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
453584	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	450.0	
453585	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
453586	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
453587	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
453588	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Ambient Temperature	76	°F
453589	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Unknown Operations	0	
453590	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Tank Paint Condition	Good	
453591	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Switching Operations	3	
453592	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Operations This Read Vac	3	
453593	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Operations Counter AL	176	
453594	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Operations Counter AF	176	
453595	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Moisture and Leak Free?	y	
453596	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Unknown Operations	0	
453597	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Switching Operations	0	
453598	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Operations This Read AM	0	
453599	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	PF000190	PowerFuse	KE-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
453600	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	PF000190	PowerFuse	KE-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
453601	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Operations Counter AL	962	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
453602	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Operations Counter AF	962	
453603	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Maintenance Operations	0	
453604	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	General Comments		
453605	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Follow-up Action Required?	n	
453606	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Operations Ground	0	
453607	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Operations C Ø	0	
453608	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Operations B Ø	0	
453609	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Operations A Ø	0	
453610	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
453611	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
453612	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
453613	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Amps C Ø	138.0	
453614	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Amps B Ø	119.0	
453615	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Amps A Ø	137.0	
453616	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
453617	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
453618	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
453619	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
453620	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
453621	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
453622	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
453623	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
453624	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
453625	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	PF000074	PowerFuse	CY-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
453626	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	PF000074	PowerFuse	CY-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
453627	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	PF000073	PowerFuse	CY-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
453628	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	PF000073	PowerFuse	CY-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
453629	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	PF000072	PowerFuse	CY-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
453630	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	PF000072	PowerFuse	CY-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
453631	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
453632	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	General Comments		
453633	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
453634	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
453635	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
453636	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
453637	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
453638	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
453639	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Foundation Condition	Good	
453640	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
453641	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Unknown Operations	0	
453642	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Tank Paint Condition	Good	
453643	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Switching Operations	1	
453644	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
453645	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Operations This Read Vac	1	
453646	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	General Comments		
453647	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
453648	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
453649	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
453650	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
453651	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Operations Counter AL	353	
453652	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Operations Counter AF	353	
453653	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
453654	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Maintenance Operations	0	
453655	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
453656	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Grounds in Place?	y	
453657	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	General Comments		
453658	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	General Comments		
453659	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Foundation Condition	Good	
453660	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Follow-up Action Required?	n	
453661	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
453662	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
453663	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Winding Temp Present	50	°C
453664	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Winding Temp Max	55	°C
453665	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
453666	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
453667	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
453668	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Follow-up Action Required?	n	
453669	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Follow-up Action Required?	n	
453670	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Operations Ground	0	
453671	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
453672	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
453673	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
453674	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
453675	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
453676	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
453677	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
453678	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
453679	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Operations C Ø	0	
453680	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Operations B Ø	0	
453681	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Operations A Ø	0	
453682	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
453683	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
453684	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
453685	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Equipment Properly Labeled?	y	
453686	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Cabinet Paint Condition	Good	
453687	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
453688	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
453689	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
453690	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Bushings Connection/Risers	Good	
453691	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Bushing Condition	Good	
453692	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Amps C Ø	80.0	
453693	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
453694	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	LTC Totalizer Reading	10008.00	kw
453695	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
453696	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
453697	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Oil Temp Max	40	°C
453698	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Oil Temp Present	40	°C
453699	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
453700	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	Follow-up Action Required?	n	
453701	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
453702	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	General Comments		
453703	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	General Comments		
453704	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC As Found Counter	2846	
453705	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC As Left Counter	2859	
453706	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
453707	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC Current Tap Position	5L	
453708	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC Max Tap Position	6R	
453709	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC Min Tap Position	10L	
453710	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC Operations Since Last Insp	953	
453711	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
453712	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
453713	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
453714	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
453715	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
453716	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
453717	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
453718	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
453719	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
453720	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
453721	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Operations This Read Vac	4	
453722	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
453723	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
453724	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Operations Counter AL	176	
453725	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Operations Counter AF	176	
453726	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
453727	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Totalizer Meter Reading	.4170	
453728	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Winding Temp Max	60	°C
453729	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Winding Temp Present	40	°C
453730	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
453731	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
453732	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
453733	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
453734	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
453735	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
453736	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
453737	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
453738	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
453739	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
453740	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Moisture and Leak Free?	y	
453741	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Maintenance Operations	0	
453742	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Grounds in Place?	y	
453743	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	General Comments		
453744	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	General Comments		
453745	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Foundation Condition	Good	
453746	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
453747	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
453748	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
453749	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
453750	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
453751	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
453752	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
453753	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
453754	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
453755	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
453756	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
453757	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Bushing Condition	Good	
453758	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Amps C Ø	320.0	
453759	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Amps B Ø	300.0	
453760	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Amps A Ø	310.0	
453761	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
453762	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
453763	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
453764	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	9 Month Operations	30	
453765	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
453766	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
453767	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
453768	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
453769	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
453770	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
453771	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
453772	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
453773	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	General Comments		
453774	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	General Comments		
453775	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Winding Temp Max	50	°C
453776	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Totalizer Meter Reading	.4180	
453777	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
453778	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
453779	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
453780	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
453781	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
453782	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
453783	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
453784	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	67.44	kw
453785	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
453786	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
453787	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
453788	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
453789	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
453790	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
453791	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
453792	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Unknown Operations	0	
453793	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Tank Paint Condition	Good	
453794	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Switching Operations	1	
453795	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Operations This Read Vac	1	
453796	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Operations Counter AL	152	
453797	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Operations Counter AF	152	
453798	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
453799	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Maintenance Operations	0	
453800	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Grounds in Place?	y	
453801	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	General Comments		
453802	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	General Comments		
453803	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Foundation Condition	Good	
453804	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
453805	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
453806	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
453807	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Follow-up Action Required?	n	
453808	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Follow-up Action Required?	n	
453809	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Operations Ground	0	
453810	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Operations C Ø	0	
453811	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Operations B Ø	0	
453812	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Operations A Ø	0	
453813	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
453814	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
453815	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Amps C Ø	0.0	
453816	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Bushing Condition	Good	
453817	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
453818	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
453819	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
453820	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
453821	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
453822	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
453823	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
453824	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
453825	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
453826	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
453827	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Operations B Ø	0	
453828	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Operations C Ø	0	
453829	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Operations Ground	0	
453830	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
453831	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Follow-up Action Required?	n	
453832	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Foundation Condition	Good	
453833	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	General Comments		
453834	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	General Comments		
453835	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Grounds in Place?	y	
453836	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Maintenance Operations	0	
453837	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
453838	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Operations Counter AF	189	
453839	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Operations Counter AL	189	
453840	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Operations This Read Vac	3	
453841	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Switching Operations	3	
453842	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Tank Paint Condition	Good	
453843	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Unknown Operations	0	
453844	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
453845	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Amps B Ø	0.0	
453846	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Amps A Ø	0.0	
453847	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
453848	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
453849	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
453850	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	9 Month Operations	9	
453851	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Unknown Operations	0	
453852	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Tank Paint Condition	Good	
453853	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Switching Operations	1	
453854	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Operations This Read Vac	1	
453855	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Operations Counter AL	155	
453856	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Operations Counter AF	155	
453857	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
453858	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Maintenance Operations	0	
453859	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Grounds in Place?	y	
453860	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	General Comments		
453861	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	General Comments		
453862	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Foundation Condition	Good	
453863	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Follow-up Action Required?	n	
453864	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Follow-up Action Required?	n	
453865	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Operations Ground	0	
453866	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Operations C Ø	0	
453867	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Operations B Ø	0	
453868	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Operations A Ø	0	
453869	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
453870	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
453871	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
453872	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
453873	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
453874	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
453875	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Operations C Ø	0	
453876	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Operations B Ø	0	
453877	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Operations A Ø	0	
453878	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
453879	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
453880	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
453881	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Equipment Properly Labeled?	y	
453882	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Cabinet Paint Condition	Good	
453883	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
453884	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
453885	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
453886	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Bushings Connection/Risers	Good	
453887	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Bushing Condition	Good	
453888	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Amps C Ø	120.0	
453889	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Amps B Ø	135.0	
453890	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Amps A Ø	125.0	
453891	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
453892	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
453893	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
453894	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	9 Month Operations	43	
453895	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Tank Paint Condition	Good	
453896	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
453897	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
453898	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
453899	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
453900	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
453901	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
453902	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	General Comments	y	
453903	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
453904	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Foundation Condition	Good	
453905	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Follow-up Action Required?	n	
453906	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
453907	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
453908	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
453909	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
453910	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
453911	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Ambient Temperature	76	°F
453912	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
453913	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
453914	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
453915	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
453916	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
453917	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
453918	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
453919	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
453920	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	General Comments		
453921	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	General Comments		
453922	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
453923	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
453924	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
453925	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
453926	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
453927	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
453928	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
453929	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
453930	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
453931	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	Top Oil Temperature Present	33	°C
453932	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Tank Paint Condition	Good	
453933	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
453934	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
453935	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
453936	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
453937	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
453938	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
453939	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
453940	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
453941	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
453942	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
453943	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
453944	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
453945	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
453946	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Bushing Condition	Good	
453947	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Amps C Ø	400.0	
453948	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Amps B Ø	400.0	
453949	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Amps A Ø	400.0	
453950	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
453951	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
453952	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
453953	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	9 Month Operations	1	
453954	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
453955	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Top Oil Temperature Max	40	°C
453956	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Top Oil Temperature Present	30	°C
453957	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
453958	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Oil Temp Present	40	°C
453959	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Oil Temp Max	50	°C
453960	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
453961	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
453962	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	LTC Totalizer Reading	7524.00	kw
453963	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
453964	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	General Comments		
453965	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	General Comments		
453966	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
453967	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
453968	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Follow-up Action Required?	n	
453969	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
453970	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
453971	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
453972	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
453973	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
453974	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
453975	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
453976	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
453977	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
453978	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
453979	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.1124	
453980	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
453981	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
453982	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Unknown Operations	0	
453983	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Tank Paint Condition	Good	
453984	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Switching Operations	0	
453985	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Operations This Read Vac	0	
453986	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Operations Counter AL	175	
453987	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Operations Counter AF	175	
453988	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Moisture and Leak Free?	y	
453989	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Maintenance Operations	0	
453990	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Grounds in Place?	y	
453991	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	General Comments		
453992	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	General Comments		
453993	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Foundation Condition	Good	
453994	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Follow-up Action Required?	n	
453995	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Follow-up Action Required?	n	
453996	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Operations Ground	0	
453997	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
453998	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
453999	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
454000	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Equipment Properly Labeled?	y	
454001	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Cabinet Paint Condition	Good	
454002	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
454003	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
454004	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
454005	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Bushings Connection/Risers	Good	
454006	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Bushing Condition	Good	
454007	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Amps C Ø	290.0	
454008	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Amps B Ø	260.0	
454009	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Amps A Ø	280.0	
454010	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
454011	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
454012	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
454013	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	9 Month Operations	47	
454014	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
454015	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
454016	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
454017	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
454018	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
454019	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
454020	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
454021	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
454022	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
454023	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Ambient Temp	77	°F
454024	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
454025	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Clear of Trash?	y	
454026	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
454027	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
454028	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
454029	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
454030	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
454031	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	General Comments		
454032	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
454033	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Vegetation	None	
454034	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
454035	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
454036	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	General Comments		
454037	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
454038	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
454039	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
454040	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
454041	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
454042	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
454043	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
454044	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
454045	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
454046	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
454047	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
454048	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
454049	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
454050	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
454051	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
454052	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
454053	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
454054	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
454055	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
454056	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Foundation Condition	Good	
454057	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
454058	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
454059	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
454060	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
454061	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
454062	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
454063	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
454064	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	231	
454065	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	231	
454066	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	3	
454067	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
454068	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	3	
454069	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
454070	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
454071	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
454072	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
454073	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	9 Month Operations	2	
454074	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
454075	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Bushing Condition	Good	
454076	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
454077	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
454078	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
454079	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
454080	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
454081	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
454082	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
454083	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
454084	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Unknown Operations	0	
454085	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Tank Paint Condition	Good	
454086	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Switching Operations	0	
454087	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Operations This Read Vac	0	
454088	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Operations Counter AL	187	
454089	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Operations Counter AF	187	
454090	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Moisture and Leak Free?	y	
454091	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
454092	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Current Tap Position	Neutral	
454093	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
454094	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Follow-up Action Required?	n	
454095	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Foundation Condition	Good	
454096	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Gauge(s) Condition	Good	
454097	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	General Comments		
454098	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Grounds in Place?	y	
454099	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Moisture and Leak Free?	y	
454100	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
454101	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Reg Oil Level	Good	
454102	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Maintenance Operations	0	
454103	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Grounds in Place?	y	
454104	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Reg Operation Checked?	y	
454105	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
454106	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Surge Arrester Condition	Good	
454107	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Tank Leaks	None	
454108	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Tank Paint Condition	Good	
454109	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	General Comments		
454110	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	General Comments		
454111	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Foundation Condition	Good	
454112	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Follow-up Action Required?	n	
454113	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Follow-up Action Required?	n	
454114	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Operations Ground	0	
454115	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Operations C Ø	0	
454116	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Operations B Ø	0	
454117	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Operations A Ø	0	
454118	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
454119	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
454120	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
454121	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	2	
454122	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
454123	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
454124	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	17.52	
454125	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
454126	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
454127	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	VRR Time Delay	60	Seconds
454128	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
454129	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
454130	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
454131	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	General Comments		
454132	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
454133	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC As Found Counter	254249	
454134	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC As Left Counter	254249	
454135	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
454136	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
454137	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
454138	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
454139	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	91	
454140	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
454141	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
454142	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
454143	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
454144	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
454145	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
454146	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
454147	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
454148	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
454149	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
454150	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
454151	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
454152	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
454153	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
454154	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
454155	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
454156	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
454157	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
454158	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
454159	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Patrol Inspection	Equipment Properly Labeled?	y	
454160	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Patrol Inspection	Follow-up Action Required?	n	
454161	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Patrol Inspection	General Comments		
454162	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	LTC Operation Checked?	y	
454163	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	General Comments		
454164	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	Follow-up Action Required?	n	
454165	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	All Connections OK?	y	
454166	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
454167	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
454168	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
454169	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	General Comments		
454170	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
454171	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
454172	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
454173	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
454174	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
454175	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
454176	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
454177	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
454178	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
454179	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Unknown Operations	0	
454180	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
454181	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
454182	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
454183	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Tank Paint Condition	Good	
454184	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Switching Operations	7	
454185	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
454186	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Operations This Read Vac	7	
454187	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Operations Counter AL	226	
454188	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Operations Counter AF	226	
454189	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Moisture and Leak Free?	y	
454190	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Maintenance Operations	0	
454191	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Heaters (All) Functioning?	y	
454192	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
454193	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Grounds in Place?	y	
454194	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	General Comments		
454195	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	General Comments		
454196	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
454197	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
454198	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	66	
454199	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	66	
454200	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
454201	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
454202	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Follow-up Action Required?	n	
454203	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Follow-up Action Required?	n	
454204	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Operations Ground	0	
454205	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Operations C Ø	0	
454206	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Operations B Ø	0	
454207	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Operations A Ø	0	
454208	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
454209	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
454210	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
454211	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Equipment Properly Labeled?	y	
454212	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Cabinet Paint Condition	Good	
454213	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
454214	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
454215	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
454216	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Bushings Connection/Risers	Good	
454217	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Bushing Condition	Good	
454218	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Amps C Ø	100.0	
454219	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Amps B Ø	40.0	
454220	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Amps A Ø	80.0	
454221	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
454222	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
454223	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
454224	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	9 Month Operations	7	
454225	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
454226	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
454227	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
454228	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
454229	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
454230	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
454231	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	General Comments		
454232	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
454233	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
454234	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
454235	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
454236	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
454237	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
454238	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
454239	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
454240	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Operations B Ø	0	
454241	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Operations A Ø	0	
454242	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
454243	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
454244	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
454245	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
454246	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
454247	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
454248	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
454249	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
454250	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
454251	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Bushing Condition	Good	
454252	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Amps C Ø	225.0	
454253	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Amps B Ø	275.0	
454254	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Amps A Ø	300.0	
454255	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
454256	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
454257	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
454258	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	9 Month Operations	1	
454259	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
454260	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
454261	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
454262	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
454263	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
454264	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
454265	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Equipment Properly Labeled?	y	
454266	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Cabinet Paint Condition	Good	
454267	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
454268	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
454269	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
454270	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Bushings Connection/Risers	Good	
454271	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Bushing Condition	Good	
454272	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Amps C Ø	30.0	
454273	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Amps B Ø	50.0	
454274	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Amps A Ø	30.0	
454275	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
454276	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
454277	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
454278	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	9 Month Operations	2	
454279	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
454280	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
454281	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
454282	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
454283	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Winding Temp Present	40	°C
454284	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Winding Temp Max	50	°C
454285	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Totalizer Meter Reading	.5430	
454286	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
454287	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
454288	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
454289	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
454290	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
454291	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
454292	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
454293	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
454294	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
454295	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
454296	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
454297	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
454298	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
454299	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
454300	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Amps B Ø	80.0	
454301	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Amps A Ø	80.0	
454302	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
454303	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
454304	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
454305	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	9 Month Operations	42	
454306	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Unknown Operations	0	
454307	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Tank Paint Condition	Good	
454308	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Totalizer Meter Reading	.7780	
454309	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
454310	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
454311	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
454312	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
454313	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
454314	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
454315	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
454316	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
454317	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
454318	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
454319	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Oil Temp Present	45	°C
454320	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Oil Temp Max	50	°C
454321	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
454322	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
454323	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	LTC Totalizer Reading	18672.00	kw
454324	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Switching Operations	2	
454325	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Operations This Read Vac	2	
454326	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Operations Counter AL	172	
454327	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Operations Counter AF	172	
454328	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Moisture and Leak Free?	y	
454329	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Maintenance Operations	0	
454330	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Grounds in Place?	y	
454331	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	General Comments		
454332	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
454333	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	General Comments		
454334	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	General Comments		
454335	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
454336	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
454337	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Follow-up Action Required?	n	
454338	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
454339	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
454340	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
454341	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
454342	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
454343	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
454344	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
454345	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
454346	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
454347	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	General Comments		
454348	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Foundation Condition	Good	
454349	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Follow-up Action Required?	n	
454350	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Follow-up Action Required?	n	
454351	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
454352	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
454353	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
454354	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Operations Ground	0	
454355	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Operations C Ø	0	
454356	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Operations B Ø	0	
454357	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Operations A Ø	0	
454358	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Follow-up Action Required?	n	
454359	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Operations Ground	0	
454360	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Operations C Ø	0	
454361	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
454362	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
454363	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1700	psi
454364	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
454365	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
454366	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
454367	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
454368	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
454369	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
454370	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
454371	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	Follow-up Action Required?	n	
454372	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
454373	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	General Comments		
454374	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	General Comments		
454375	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC As Found Counter	3411	
454376	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC As Left Counter	3411	
454377	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
454378	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC Current Tap Position	10L	
454379	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC Max Tap Position	9L	
454380	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC Min Tap Position	12L	
454381	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
454382	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	42	°C
454383	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	29	°C
454384	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC Operations Since Last Insp	337	
454385	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
454386	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
454387	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
454388	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
454389	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	Follow-up Action Required?	n	
454390	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Patrol Inspection	General Comments		
454391	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Patrol Inspection	Follow-up Action Required?	n	
454392	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
454393	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	General Comments		
454394	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	General Comments		
454395	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Patrol Inspection	Equipment Properly Labeled?	y	
454396	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC As Found Counter	69931	
454397	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC As Left Counter	69931	
454398	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
454399	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC Current Tap Position	4L	
454400	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
454401	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC Min Tap Position	8L	
454402	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
454403	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC Operations Since Last Insp	335	
454404	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
454405	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
454406	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
454407	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Operations A Ø	0	
454408	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
454409	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
454410	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
454411	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Equipment Properly Labeled?	y	
454412	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Cabinet Paint Condition	Good	
454413	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
454414	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
454415	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
454416	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
454417	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Bushings Connection/Risers	Good	
454418	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Bushing Condition	Good	
454419	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Amps C Ø	90.0	
454420	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Amps B Ø	85.0	
454421	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Amps A Ø	84.0	
454422	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
454423	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
454424	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
454425	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
454426	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
454427	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Oil Temp Present	50	°C
454428	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Oil Temp Max	55	°C
454429	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
454430	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
454431	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	LTC Totalizer Reading	13032.00	kw
454432	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
454433	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	General Comments		
454434	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	General Comments		
454435	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
454436	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
454437	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Follow-up Action Required?	n	
454438	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
454439	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
454440	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
454441	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
454442	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
454443	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
454444	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
454445	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
454446	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
454447	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
454448	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
454449	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
454450	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
454451	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Unknown Operations	0	
454452	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Tank Paint Condition	Good	
454453	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Switching Operations	2	
454454	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Operations This Read Vac	2	
454455	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Operations Counter AL	179	
454456	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Operations Counter AF	179	
454457	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Moisture and Leak Free?	y	
454458	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Maintenance Operations	0	
454459	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Grounds in Place?	y	
454460	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
454461	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
454462	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
454463	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
454464	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
454465	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
454466	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	General Comments		
454467	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	General Comments		
454468	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Foundation Condition	Good	
454469	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Follow-up Action Required?	n	
454470	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Follow-up Action Required?	n	
454471	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Operations Ground	0	
454472	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Operations C Ø	0	
454473	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Operations B Ø	0	
454474	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
454475	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
454476	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
454477	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
454478	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
454479	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
454480	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
454481	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	General Comments		
454482	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
454483	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
454484	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
454485	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
454486	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
454487	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
454488	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
454489	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	General Comments		
454490	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Grounds in Place?	y	
454491	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Heaters (All) Functioning?	y	
454492	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Maintenance Operations	0	
454493	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Moisture and Leak Free?	y	
454494	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Operations Counter AF	550	
454495	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Operations Counter AL	550	
454496	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Operations This Read Vac	5	
454497	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Switching Operations	5	
454498	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Tank Paint Condition	Good	
454499	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
454500	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
454501	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
454502	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
454503	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
454504	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
454505	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
454506	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
454507	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
454508	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
454509	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
454510	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
454511	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
454512	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
454513	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	751	
454514	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	751	
454515	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
454516	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
454517	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
454518	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Unknown Operations	0	
454519	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	9 Months Operations	17	
454520	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
454521	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Accumulated Fault Duty B Ph AM	1.2	%
454522	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
454523	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Amps A Ø	23.0	
454524	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
454525	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
454526	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
454527	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
454528	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
454529	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
454530	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
454531	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
454532	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
454533	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
454534	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Amps A Ø	60.0	
454535	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Amps B Ø	120.0	
454536	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Amps C Ø	100.0	
454537	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	General Comments		
454538	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	General Comments		
454539	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Bushing Condition	Good	
454540	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Bushings Connection/Risers	Good	
454541	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Foundation Condition	Good	
454542	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC As Found Counter	200247	
454543	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC As Left Counter	200247	
454544	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
454545	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC Current Tap Position	9L	
454546	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Follow-up Action Required?	n	
454547	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Follow-up Action Required?	n	
454548	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Operations Ground	0	
454549	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Operations C Ø	0	
454550	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Operations B Ø	0	
454551	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Operations A Ø	0	
454552	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
454553	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
454554	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
454555	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
454556	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
454557	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
454558	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
454559	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
454560	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	545	
454561	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	545	
454562	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
454563	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
454564	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	1	
454565	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
454566	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
454567	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
454568	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Cabinet Paint Condition	Good	
454569	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Equipment Properly Labeled?	y	
454570	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
454571	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
454572	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
454573	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Operations A Ø	0	
454574	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Operations B Ø	0	
454575	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Operations C Ø	0	
454576	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
454577	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Follow-up Action Required?	n	
454578	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Follow-up Action Required?	n	
454579	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Foundation Condition	Good	
454580	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	General Comments		
454581	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
454582	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
454583	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
454584	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
454585	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
454586	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
454587	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
454588	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Equipment Properly Labeled?	y	
454589	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Cabinet Paint Condition	Good	
454590	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
454591	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
454592	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
454593	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Bushings Connection/Risers	Good	
454594	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Bushing Condition	Good	
454595	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Amps C Ø	180.0	
454596	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Amps B Ø	190.0	
454597	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Amps A Ø	160.0	
454598	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
454599	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
454600	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
454601	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	9 Month Operations	6	
454602	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Operations Ground	0	
454603	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Follow-up Action Required?	n	
454604	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
454605	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
454606	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
454607	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
454608	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
454609	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
454610	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
454611	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	726	
454612	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	726	
454613	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
454614	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
454615	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
454616	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	General Comments	A,B&C Phase IOC & TOC	
454617	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Maintenance Operations	0	
454618	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Operations Counter AF	694	
454619	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Operations Counter AL	694	
454620	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
454621	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
454622	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
454623	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
454624	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
454625	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
454626	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
454627	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Operations This Read AM	9	
454628	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Switching Operations	0	
454629	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Unknown Operations	0	
454630	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
454631	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
454632	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
454633	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
454634	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
454635	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
454636	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
454637	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	General Comments		
454638	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	General Comments	no surge arrestor counter	
454639	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
454640	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
454641	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
454642	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1350	psi
454643	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC Max Tap Position	9L	
454644	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC Min Tap Position	12L	
454645	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC Operations Since Last Insp	2135	
454646	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
454647	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
454648	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Oil Temp Present	41	°C
454649	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
454650	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
454651	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
454652	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
454653	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Counter A Ø	0	
454654	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Counter B Ø	0	
454655	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Counter C Ø	0	
454656	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
454657	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
454658	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
454659	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Top Oil Temperature Max	45	°C
454660	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Top Oil Temperature Present	41	°C
454661	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
454662	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
454663	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	36	°C
454664	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	32	°C
454665	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	45	°C
454666	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	41	°C
454667	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	45	°C
454668	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	41	°C
454669	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Amps B Ø	18.0	
454670	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Amps C Ø	24.0	
454671	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Adjusted Amps A Phase AM	33.54	
454672	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Adjusted Amps B Phase AM	33.54	
454673	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Adjusted Amps C Phase AM	33.54	
454674	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Operations A Ø	3	
454675	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Operations B Ø	3	
454676	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Operations C Ø	3	
454677	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
454678	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
454679	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
454680	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	5.78	%
454681	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	9 Month Operations	1	
454682	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
454683	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Adjusted Amps A Phase V	44.72	
454684	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Amps C Ø	54.0	
454685	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Amps B Ø	56.0	
454686	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Amps A Ø	54.0	
454687	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Accumulated Fault Duty C Ph V	18.33	%
454688	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Accumulated Fault Duty B Ph V	18.33	%
454689	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Accumulated Fault Duty A Ph V	36.67	%
454690	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	9 Month Operations	17	
454691	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	9 Month Operations	1	
454692	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
454693	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
454694	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
454695	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Amps A Ø	15.0	
454696	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Amps B Ø	13.0	
454697	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Amps C Ø	48.0	
454698	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Bushing Condition	Good	
454699	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Bushings Connection/Risers	Good	
454700	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
454701	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
454702	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
454703	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Cabinet Paint Condition	Good	
454704	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Equipment Properly Labeled?	y	
454705	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
454706	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
454707	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
454708	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Operations A Ø	0	
454709	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Operations B Ø	0	
454710	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LTCC000538	LTCControl	CY-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
454711	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LTCC000538	LTCControl	CY-TRANS 1	LTC Control Insp	General Comments		
454712	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LTCC000538	LTCControl	CY-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
454713	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Operations C Ø	0	
454714	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Operations Ground	0	
454715	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Follow-up Action Required?	n	
454716	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Follow-up Action Required?	n	
454717	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Foundation Condition	Good	
454718	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	General Comments		
454719	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	General Comments		
454720	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Grounds in Place?	y	
454721	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Maintenance Operations	0	
454722	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Moisture and Leak Free?	y	
454723	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Operations Counter AF	148	
454724	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Operations Counter AL	148	
454725	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Operations This Read Vac	0	
454726	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Switching Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
454727	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Tank Paint Condition	Good	
454728	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Unknown Operations	0	
454729	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Amps A Ø	130.0	
454730	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
454731	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
454732	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
454733	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	9 Month Operations	9	
454734	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Unknown Operations	0	
454735	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Switching Operations	0	
454736	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Operations This Read Vac	0	
454737	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Operations Counter AL	112	
454738	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Operations Counter AF	112	
454739	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Maintenance Operations	0	
454740	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	General Comments		
454741	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
454742	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Operations Ground	0	
454743	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
454744	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
454745	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
454746	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
454747	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
454748	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
454749	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
454750	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Bushings Connection/Risers	Good	
454751	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Bushing Condition	Good	
454752	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Amps C Ø	60.0	
454753	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Amps B Ø	60.0	
454754	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Amps A Ø	60.0	
454755	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Unknown Operations	0	
454756	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Switching Operations	0	
454757	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Operations This Read Vac	4	
454758	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
454759	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
454760	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
454761	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	9 Month Operations	5	
454762	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Operations Counter AL	326	
454763	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Operations Counter AF	326	
454764	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Maintenance Operations	0	
454765	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	General Comments	A Phase IOC	
454766	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Follow-up Action Required?	n	
454767	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Operations Ground	0	
454768	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Operations C Ø	0	
454769	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Operations B Ø	0	
454770	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Operations A Ø	4	
454771	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
454772	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
454773	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
454774	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Amps C Ø	596.0	
454775	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Amps B Ø	627.0	
454776	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Amps A Ø	607.0	
454777	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	5.78	%
454778	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	5.78	%
454779	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
454780	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
454781	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
454782	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
454783	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
454784	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
454785	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
454786	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
454787	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	8.00	
454788	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	8.00	
454789	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	8.00	
454790	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
454791	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
454792	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
454793	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
454794	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	Follow-up Action Required?	n	
454795	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
454796	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	General Comments		
454797	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	General Comments		
454798	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Unknown Operations	0	
454799	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Tank Paint Condition	Good	
454800	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Switching Operations	4	
454801	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Operations This Read Vac	4	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
454802	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Operations Counter AL	234	
454803	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Operations Counter AF	234	
454804	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Moisture and Leak Free?	y	
454805	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
454806	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Maintenance Operations	0	
454807	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
454808	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
454809	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
454810	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
454811	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
454812	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
454813	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Heaters (All) Functioning?	y	
454814	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
454815	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
454816	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
454817	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
454818	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
454819	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
454820	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
454821	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
454822	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
454823	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Grounds in Place?	y	
454824	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
454825	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
454826	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	9 Month Operations	5	
454827	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
454828	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	9 Month Operations	1	
454829	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
454830	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
454831	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
454832	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Amps A Ø	33.0	
454833	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Amps B Ø	28.0	
454834	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Amps C Ø	34.0	
454835	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Bushing Condition	Good	
454836	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Bushings Connection/Risers	Good	
454837	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
454838	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
454839	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
454840	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Cabinet Paint Condition	Good	
454841	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Equipment Properly Labeled?	y	
454842	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
454843	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
454844	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
454845	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Operations A Ø	0	
454846	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Operations B Ø	0	
454847	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Operations C Ø	0	
454848	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Operations Ground	0	
454849	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Follow-up Action Required?	n	
454850	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Follow-up Action Required?	n	
454851	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Foundation Condition	Good	
454852	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	General Comments		
454853	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	General Comments		
454854	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Grounds in Place?	y	
454855	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Maintenance Operations	0	
454856	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Moisture and Leak Free?	y	
454857	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Operations Counter AF	198	
454858	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Operations Counter AL	198	
454859	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Operations This Read Vac	0	
454860	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Switching Operations	0	
454861	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Tank Paint Condition	Good	
454862	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Unknown Operations	0	
454863	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
454864	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	Follow-up Action Required?	n	
454865	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
454866	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	General Comments		
454867	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	General Comments		
454868	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC As Found Counter	63182	
454869	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC As Left Counter	63182	
454870	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
454871	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC Current Tap Position	6L	
454872	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
454873	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC Min Tap Position	8L	
454874	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.5	psi
454875	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC Operations Since Last Insp	259	
454876	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
454877	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
454878	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Foundation Condition	Good	
454879	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
454880	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
454881	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
454882	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
454883	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
454884	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
454885	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
454886	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
454887	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
454888	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
454889	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
454890	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
454891	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
454892	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
454893	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
454894	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
454895	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	General Comments		
454896	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
454897	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
454898	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
454899	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
454900	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
454901	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
454902	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
454903	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
454904	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
454905	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
454906	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
454907	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
454908	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
454909	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Oil Temp Max	50	°C
454910	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
454911	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
454912	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
454913	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
454914	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
454915	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
454916	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
454917	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
454918	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
454919	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC Operations Since Last Insp	378	
454920	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
454921	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC Min Tap Position	10L	
454922	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
454923	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC Current Tap Position	8L	
454924	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
454925	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC As Left Counter	69098	
454926	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC As Found Counter	69098	
454927	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Patrol Inspection	Follow-up Action Required?	n	
454928	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Follow-up Action Required?	n	
454929	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Patrol Inspection	General Comments		
454930	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
454931	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Cabinet Paint Condition	Good	
454932	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Equipment Properly Labeled?	y	
454933	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
454934	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
454935	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
454936	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Operations A Ø	0	
454937	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Operations B Ø	0	
454938	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Operations C Ø	0	
454939	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Operations Ground	0	
454940	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Follow-up Action Required?	n	
454941	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Follow-up Action Required?	n	
454942	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Foundation Condition	Good	
454943	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	General Comments		
454944	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	General Comments		
454945	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Grounds in Place?	y	
454946	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Heaters (All) Functioning?	y	
454947	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Maintenance Operations	0	
454948	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Moisture and Leak Free?	y	
454949	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Operations Counter AF	760	
454950	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Operations Counter AL	760	
454951	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Operations This Read Vac	7	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
454952	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
454953	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Switching Operations	7	
454954	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Tank Paint Condition	Good	
454955	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Unknown Operations	0	
454956	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
454957	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
454958	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
454959	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
454960	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
454961	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
454962	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
454963	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
454964	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
454965	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
454966	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	General Comments		
454967	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Maintenance Operations	0	
454968	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Operations Counter AF	99968	
454969	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Operations Counter AL	99968	
454970	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Operations This Read AM	0	
454971	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Switching Operations	0	
454972	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Unknown Operations	0	
454973	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
454974	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	General Comments		
454975	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
454976	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
454977	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
454978	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
454979	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
454980	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
454981	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
454982	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
454983	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
454984	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	264	
454985	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	264	
454986	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
454987	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
454988	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
454989	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
454990	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
454991	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
454992	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
454993	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
454994	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
454995	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
454996	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
454997	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	497	
454998	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	497	
454999	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
455000	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
455001	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
455002	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	LTCC000257	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
455003	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	LTCC000257	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
455004	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	LTCC000257	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
455005	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	LTCC000257	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
455006	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	LTCC000257	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
455007	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	LTCC000257	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
455008	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	LTCC000257	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
455009	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	LTCC000257	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
455010	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	9 Months Operations	22	
455011	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
455012	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Accumulated Fault Duty B Ph AM	2.41	%
455013	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Accumulated Fault Duty C Ph AM	1.2	%
455014	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Amps A Ø	79.0	
455015	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Amps B Ø	96.0	
455016	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Amps C Ø	87.0	
455017	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
455018	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Adjusted Amps B Phase AM	22.36	
455019	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Adjusted Amps C Phase AM	22.36	
455020	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Operations A Ø	0	
455021	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Operations B Ø	2	
455022	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Operations C Ø	2	
455023	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Operations Ground	0	
455024	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Follow-up Action Required?	n	
455025	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	General Comments	B&C Phase IOC	
455026	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
455027	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	General Comments		
455028	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
455029	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	Follow-up Action Required?	n	
455030	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
455031	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
455032	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
455033	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
455034	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
455035	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
455036	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
455037	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
455038	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
455039	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
455040	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
455041	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
455042	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
455043	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
455044	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
455045	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
455046	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
455047	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
455048	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
455049	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
455050	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
455051	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
455052	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
455053	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
455054	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
455055	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
455056	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
455057	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
455058	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
455059	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Unknown Operations	0	
455060	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Switching Operations	0	
455061	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Operations This Read AM	4	
455062	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
455063	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
455064	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
455065	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Operations Counter AL	200	
455066	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Operations Counter AF	200	
455067	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Maintenance Operations	0	
455068	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
455069	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
455070	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
455071	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
455072	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
455073	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
455074	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
455075	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
455076	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
455077	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
455078	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
455079	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
455080	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC As Left Counter	11156	
455081	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
455082	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
455083	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5L	
455084	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
455085	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
455086	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	36	°C
455087	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	32	°C
455088	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	231	
455089	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
455090	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
455091	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
455092	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
455093	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
455094	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
455095	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
455096	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
455097	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
455098	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
455099	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
455100	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
455101	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
455102	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
455103	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
455104	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
455105	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99965	
455106	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99965	
455107	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
455108	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
455109	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
455110	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LTCC000737	LTCControl	CY-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
455111	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LTCC000737	LTCControl	CY-TRANS 2	LTC Control Insp	General Comments		
455112	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LTCC000737	LTCControl	CY-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
455113	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
455114	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
455115	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Patrol Inspection	Equipment Properly Labeled?	y	
455116	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Patrol Inspection	Follow-up Action Required?	n	
455117	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Patrol Inspection	General Comments		
455118	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	9 Months Operations	0	
455119	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
455120	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
455121	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	9 Months Operations	11	
455122	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Accumulated Fault Duty A Ph AM	1.2	%
455123	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Accumulated Fault Duty B Ph AM	2.41	%
455124	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Accumulated Fault Duty C Ph AM	2.41	%
455125	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
455126	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
455127	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
455128	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	General Comments		
455129	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
455130	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
455131	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
455132	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
455133	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
455134	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
455135	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
455136	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
455137	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Vegetation	None	
455138	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
455139	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	General Comments		
455140	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
455141	4/17/2019 14:50	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
455142	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
455143	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
455144	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
455145	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
455146	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
455147	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
455148	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Clear of Trash?	y	
455149	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
455150	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
455151	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Ambient Temp	59	°F
455152	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
455153	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	General Comments		
455154	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
455155	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
455156	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
455157	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
455158	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
455159	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
455160	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
455161	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
455162	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
455163	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
455164	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
455165	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
455166	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
455167	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
455168	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	General Comments		
455169	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	LTC Oil Filter shows LOW FLOW OR LEAK DETECTED	
455170	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC As Found Counter	11156	
455171	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
455172	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
455173	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
455174	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
455175	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
455176	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	284	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
455177	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	284	
455178	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
455179	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
455180	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
455181	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
455182	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
455183	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
455184	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
455185	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
455186	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
455187	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
455188	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
455189	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
455190	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
455191	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	150.0	
455192	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	152.0	
455193	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	165.0	
455194	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
455195	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
455196	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
455197	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
455198	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Patrol Inspection	Equipment Properly Labeled?	y	
455199	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Patrol Inspection	Follow-up Action Required?	n	
455200	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Patrol Inspection	General Comments		
455201	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	9 Month Operations	7	
455202	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
455203	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
455204	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
455205	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
455206	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Amps A Ø	230.0	
455207	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Amps B Ø	230.0	
455208	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Amps C Ø	250.0	
455209	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Bushing Condition	Good	
455210	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Bushings Connection/Risers	Good	
455211	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
455212	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Amps A Ø	0.0	
455213	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Amps B Ø	0.0	
455214	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Amps C Ø	0.0	
455215	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
455216	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
455217	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
455218	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
455219	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Operations A Ø	0	
455220	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Operations B Ø	0	
455221	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Operations C Ø	0	
455222	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
455223	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Operations Ground	0	
455224	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Amps A Ø	55.0	
455225	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Amps B Ø	46.0	
455226	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Amps C Ø	51.0	
455227	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Adjusted Amps A Phase AM	33.54	
455228	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
455229	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Adjusted Amps C Phase AM	33.54	
455230	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Operations A Ø	3	
455231	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Operations B Ø	0	
455232	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Operations C Ø	3	
455233	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Operations Ground	0	
455234	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Follow-up Action Required?	n	
455235	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	General Comments	A&C Phase IOC	
455236	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Maintenance Operations	0	
455237	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Operations Counter AF	680	
455238	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Operations Counter AL	680	
455239	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Operations This Read AM	6	
455240	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Switching Operations	0	
455241	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Unknown Operations	0	
455242	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
455243	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
455244	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
455245	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
455246	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
455247	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
455248	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
455249	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
455250	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
455251	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
455252	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
455253	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
455254	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
455255	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	General Comments		
455256	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
455257	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Ambient Temp	66	°F
455258	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
455259	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
455260	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Clear of Trash?	y	
455261	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
455262	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
455263	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
455264	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
455265	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
455266	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
455267	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	General Comments		
455268	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
455269	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
455270	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Vegetation	None	
455271	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
455272	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
455273	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
455274	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
455275	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
455276	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
455277	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
455278	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
455279	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
455280	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
455281	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	66	°F
455282	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
455283	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Unknown Operations	0	
455284	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Tank Paint Condition	Good	
455285	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Switching Operations	9	
455286	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
455287	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Operations This Read Vac	9	
455288	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Operations Counter AL	628	
455289	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Operations Counter AF	628	
455290	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Moisture and Leak Free?	y	
455291	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Maintenance Operations	0	
455292	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Heaters (All) Functioning?	y	
455293	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
455294	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
455295	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
455296	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Grounds in Place?	y	
455297	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
455298	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
455299	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
455300	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
455301	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
455302	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
455303	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
455304	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	General Comments		
455305	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	General Comments		
455306	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Cabinet Paint Condition	Good	
455307	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Equipment Properly Labeled?	y	
455308	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
455309	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
455310	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Patrol Inspection	General Comments		
455311	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Patrol Inspection	Follow-up Action Required?	n	
455312	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Patrol Inspection	Equipment Properly Labeled?	y	
455313	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
455314	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
455315	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
455316	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
455317	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
455318	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
455319	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
455320	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
455321	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
455322	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
455323	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
455324	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
455325	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
455326	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	37	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
455327	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	37	
455328	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
455329	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
455330	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
455331	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
455332	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	General Comments		
455333	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
455334	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
455335	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
455336	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	447	
455337	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
455338	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
455339	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	64	
455340	4/17/2019 15:30	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	48	
455341	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
455342	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
455343	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
455344	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
455345	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
455346	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
455347	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
455348	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
455349	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
455350	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
455351	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
455352	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
455353	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
455354	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	General Comments		
455355	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
455356	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
455357	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
455358	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	VRR Time Delay	45	Seconds
455359	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
455360	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Operations A Ø	0	
455361	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Operations B Ø	0	
455362	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Operations C Ø	0	
455363	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
455364	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
455365	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
455366	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
455367	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
455368	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
455369	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
455370	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
455371	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
455372	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
455373	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
455374	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
455375	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	LTC Operation Checked?	y	
455376	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	General Comments		
455377	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	Follow-up Action Required?	n	
455378	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	All Connections OK?	y	
455379	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
455380	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
455381	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
455382	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
455383	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	General Comments		
455384	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Switching Operations	8	
455385	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	General Comments		
455386	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	General Comments		
455387	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Grounds in Place?	y	
455388	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Heaters (All) Functioning?	y	
455389	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Maintenance Operations	0	
455390	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Accumulated Fault Duty C Ph V	9.57	%
455391	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Amps A Ø	24.0	
455392	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Amps B Ø	33.0	
455393	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Amps C Ø	27.0	
455394	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Moisture and Leak Free?	y	
455395	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Operations Counter AF	461	
455396	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Operations Counter AL	461	
455397	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
455398	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
455399	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
455400	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Operations A Ø	0	
455401	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Operations This Read Vac	5	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
455402	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Operations B Ø	0	
455403	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Operations C Ø	0	
455404	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Unknown Operations	0	
455405	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Operations Ground	0	
455406	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Follow-up Action Required?	n	
455407	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Switching Operations	5	
455408	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	General Comments		
455409	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Maintenance Operations	0	
455410	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Operations Counter AF	262	
455411	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Operations Counter AL	262	
455412	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Operations This Read Vac	0	
455413	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Switching Operations	0	
455414	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Tank Paint Condition	Good	
455415	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Unknown Operations	0	
455416	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
455417	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
455418	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Unknown Operations	0	
455419	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Tank Paint Condition	Good	
455420	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
455421	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
455422	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Operations A Ø	0	
455423	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Operations B Ø	0	
455424	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Operations C Ø	0	
455425	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Operations Ground	0	
455426	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Follow-up Action Required?	n	
455427	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Follow-up Action Required?	n	
455428	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Operations This Read Vac	8	
455429	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Operations Counter AL	606	
455430	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Foundation Condition	Good	
455431	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Operations Counter AF	606	
455432	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Moisture and Leak Free?	y	
455433	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Foundation Condition	Good	
455434	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Amps B Ø	130.0	
455435	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Amps C Ø	220.0	
455436	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Bushing Condition	Good	
455437	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Bushings Connection/Risers	Good	
455438	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Operations Ground	0	
455439	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Follow-up Action Required?	n	
455440	4/17/2019 10:18	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Follow-up Action Required?	n	
455441	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
455442	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
455443	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
455444	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
455445	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
455446	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Cabinet Paint Condition	Good	
455447	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
455448	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Accumulated Fault Duty B Ph V	14.35	%
455449	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
455450	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Equipment Properly Labeled?	y	
455451	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	9 Month Operations	6	
455452	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
455453	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
455454	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
455455	4/17/2019 12:23	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
455456	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
455457	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Accumulated Fault Duty A Ph V	7.97	%
455458	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
455459	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	General Comments		
455460	4/17/2019 13:57	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
455461	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
455462	4/17/2019 15:04	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
455463	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
455464	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
455465	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
455466	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
455467	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	123	VAC
455468	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	123	VAC
455469	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
455470	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	123	VAC
455471	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
455472	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
455473	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
455474	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
455475	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
455476	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
455477	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
455478	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
455479	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	Follow-up Action Required?	n	
455480	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
455481	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
455482	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
455483	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
455484	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
455485	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
455486	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
455487	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
455488	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
455489	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Current Tap Position	3L	
455490	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	General Comments		
455491	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
455492	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
455493	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	15.9	
455494	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	377	
455495	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Totalizer Meter Reading	.1750	
455496	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
455497	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
455498	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
455499	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
455500	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
455501	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
455502	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
455503	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	General Comments		
455504	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
455505	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
455506	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
455507	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
455508	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
455509	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
455510	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
455511	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
455512	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	73	°F
455513	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
455514	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Bushing Condition	Good	
455515	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Amps C Ø	58.0	
455516	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Amps B Ø	60.0	
455517	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Amps A Ø	97.0	
455518	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
455519	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
455520	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
455521	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	9 Month Operations	5	
455522	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
455523	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Broom on Site?	n	
455524	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
455525	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
455526	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
455527	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
455528	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
455529	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Min Tap Position	10L	
455530	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Max Tap Position	1L	
455531	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
455532	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	General Comments		
455533	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
455534	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
455535	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	General Comments		
455536	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	General Comments		
455537	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Foundation Condition	Good	
455538	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Follow-up Action Required?	n	
455539	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Follow-up Action Required?	n	
455540	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Operations Ground	0	
455541	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Operations C Ø	0	
455542	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Operations B Ø	0	
455543	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Operations A Ø	0	
455544	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
455545	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
455546	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
455547	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Equipment Properly Labeled?	y	
455548	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Cabinet Paint Condition	Good	
455549	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
455550	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
455551	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
455552	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Bushings Connection/Risers	Good	
455553	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Bushing Condition	Good	
455554	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Amps C Ø	20.0	
455555	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Amps B Ø	25.0	
455556	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Amps A Ø	15.0	
455557	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
455558	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
455559	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
455560	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	9 Month Operations	4	
455561	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Unknown Operations	0	
455562	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Tank Paint Condition	Good	
455563	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Switching Operations	2	
455564	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Operations This Read Vac	2	
455565	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Operations Counter AL	173	
455566	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Operations Counter AF	173	
455567	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Moisture and Leak Free?	y	
455568	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Maintenance Operations	0	
455569	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
455570	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
455571	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Cabinet Paint Condition	Good	
455572	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Equipment Properly Labeled?	y	
455573	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
455574	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
455575	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Grounds in Place?	y	
455576	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	General Comments		
455577	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	General Comments		
455578	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
455579	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Foundation Condition	Good	
455580	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Follow-up Action Required?	n	
455581	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Follow-up Action Required?	n	
455582	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Operations Ground	0	
455583	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Operations C Ø	0	
455584	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Operations B Ø	0	
455585	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Operations A Ø	0	
455586	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	General Comments		
455587	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
455588	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	LTC Totalizer Reading	1392.00	kw
455589	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
455590	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
455591	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	Oil Temp Max	40	°C
455592	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
455593	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
455594	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	9 Month Operations	8	
455595	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
455596	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
455597	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
455598	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
455599	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
455600	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
455601	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
455602	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
455603	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	Totalizer Meter Reading	.2900	
455604	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
455605	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
455606	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
455607	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Amps A Ø	95.0	
455608	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
455609	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Amps B Ø	80.0	
455610	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Amps C Ø	85.0	
455611	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	9 Month Operations	6	
455612	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Accumulated Fault Duty A Ph V	5.06	%
455613	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Accumulated Fault Duty B Ph V	5.06	%
455614	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Accumulated Fault Duty C Ph V	2.53	%
455615	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Amps A Ø	100	
455616	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Amps B Ø	100	
455617	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Amps C Ø	100	
455618	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Bushing Condition	Good	
455619	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Bushings Connection/Risers	Good	
455620	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
455621	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
455622	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
455623	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Cabinet Paint Condition	Good	
455624	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Equipment Properly Labeled?	y	
455625	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Adjusted Amps A Phase V	0	
455626	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
455627	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Tank Paint Condition	Good	
455628	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Switching Operations	2	
455629	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Operations This Read Vac	2	
455630	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Bushing Condition	Good	
455631	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Bushings Connection/Risers	Good	
455632	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
455633	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Operations Counter AL	163	
455634	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Operations Counter AF	163	
455635	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Moisture and Leak Free?	y	
455636	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Maintenance Operations	0	
455637	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Grounds in Place?	y	
455638	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
455639	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
455640	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
455641	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Clear of Trash?	y	
455642	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
455643	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
455644	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
455645	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
455646	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
455647	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
455648	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
455649	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
455650	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	9L	
455651	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
455652	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
455653	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
455654	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
455655	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
455656	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
455657	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	9L	
455658	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	9L	
455659	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
455660	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
455661	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
455662	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
455663	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	122.9	volts
455664	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	78655	
455665	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
455666	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
455667	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
455668	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
455669	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
455670	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
455671	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Broom on Site?	y	
455672	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
455673	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
455674	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
455675	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Trash Emptied?	y	
455676	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
455677	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
455678	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
455679	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
455680	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Evidence of Insects	None	
455681	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
455682	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Operations A Ø	2	
455683	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Adjusted Amps C Phase V	4.31	
455684	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
455685	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Panels Dusted?	y	
455686	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Panel Lights OK?	y	
455687	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
455688	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	General Comments	not a control house, outdoor switchgear	
455689	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
455690	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
455691	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Floor Swept?	y	
455692	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
455693	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
455694	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	336	
455695	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	13.8	
455696	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	19.4	
455697	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
455698	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
455699	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
455700	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
455701	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
455702	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
455703	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Unknown Operations	0	
455704	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Tank Paint Condition	Good	
455705	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Switching Operations	0	
455706	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Operations This Read Vac	3	
455707	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Operations Counter AL	216	
455708	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Operations Counter AF	216	
455709	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Moisture and Leak Free?	y	
455710	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Maintenance Operations	0	
455711	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Grounds in Place?	y	
455712	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	General Comments		
455713	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	General Comments		
455714	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Foundation Condition	Good	
455715	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Follow-up Action Required?	n	
455716	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Follow-up Action Required?	n	
455717	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Operations Ground	0	
455718	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Operations C Ø	1	
455719	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Operations B Ø	0	
455720	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
455721	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
455722	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
455723	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
455724	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
455725	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
455726	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
455727	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
455728	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
455729	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
455730	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
455731	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
455732	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
455733	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
455734	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	General Comments		
455735	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
455736	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
455737	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Foundation Condition	Good	
455738	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
455739	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
455740	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
455741	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
455742	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
455743	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
455744	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
455745	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Vegetation	None	
455746	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
455747	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	General Comments		
455748	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
455749	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
455750	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
455751	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC As Left Counter	108275	
455752	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
455753	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC Current Tap Position	2L	
455754	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	BCH000105	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.500	millivolts
455755	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	BCH000105	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	26.4	VDC
455756	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	BCH000105	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	26.4	VDC
455757	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
455758	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
455759	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
455760	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
455761	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Follow-up Action Required?	n	
455762	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
455763	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
455764	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	General Comments		
455765	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	General Comments		
455766	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
455767	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	LTC Totalizer Reading	840.00	kw
455768	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
455769	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
455770	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Oil Temp Max	44	°C
455771	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	BCH000105	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
455772	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	BCH000105	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
455773	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	BCH000105	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
455774	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	BCH000105	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
455775	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Oil Temp Present	25	°C
455776	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
455777	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Door Alarms OK?	y	
455778	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
455779	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Adjusted Amps A Phase V	8.63	
455780	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Equipment Properly Labeled?	y	
455781	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
455782	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Floor Swept?	y	
455783	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
455784	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
455785	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	General Comments		
455786	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
455787	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC Max Tap Position	5R	
455788	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC Min Tap Position	6L	
455789	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC Operations Since Last Insp	471	
455790	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
455791	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
455792	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
455793	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Panels Dusted?	y	
455794	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Trash Emptied?	n	
455795	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
455796	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
455797	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Cabinet Paint Condition	Good	
455798	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
455799	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
455800	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
455801	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Bushings Connection/Risers	Good	
455802	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
455803	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
455804	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
455805	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
455806	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
455807	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
455808	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
455809	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
455810	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	99992	
455811	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	99992	
455812	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
455813	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
455814	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
455815	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
455816	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
455817	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
455818	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
455819	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
455820	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
455821	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
455822	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
455823	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
455824	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
455825	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
455826	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
455827	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
455828	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
455829	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
455830	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
455831	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
455832	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
455833	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
455834	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
455835	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	180.0	
455836	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	200.0	
455837	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
455838	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
455839	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
455840	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
455841	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
455842	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
455843	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
455844	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
455845	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
455846	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
455847	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
455848	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
455849	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
455850	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
455851	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
455852	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	Follow-up Action Required?	n	
455853	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
455854	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	General Comments		
455855	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	General Comments		
455856	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	General Comments		
455857	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
455858	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
455859	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
455860	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
455861	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
455862	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
455863	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC As Found Counter	108275	
455864	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0	
455865	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
455866	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
455867	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
455868	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
455869	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Vegetation	None	
455870	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
455871	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	General Comments		
455872	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
455873	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
455874	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
455875	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
455876	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
455877	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
455878	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
455879	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
455880	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
455881	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
455882	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
455883	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
455884	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
455885	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
455886	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Follow-up Action Required?	n	
455887	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
455888	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
455889	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	VRR Time Delay	30	Seconds
455890	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
455891	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
455892	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
455893	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Amps C Ø	0	
455894	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Amps B Ø	0	
455895	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Amps A Ø	0	
455896	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0	%
455897	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0	%
455898	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0	%
455899	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	9 Month Operations	2	
455900	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
455901	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
455902	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
455903	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
455904	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
455905	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
455906	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
455907	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
455908	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
455909	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	LTC Operation Checked?	y	
455910	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	General Comments		
455911	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	Follow-up Action Required?	n	
455912	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	General Comments		
455913	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	General Comments		
455914	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
455915	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	LTC Totalizer Reading	3139.20	kw
455916	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
455917	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
455918	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Operations C Ø	0	
455919	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Operations B Ø	0	
455920	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Operations A Ø	0	
455921	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
455922	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
455923	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
455924	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Equipment Properly Labeled?	y	
455925	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Cabinet Paint Condition	Good	
455926	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
455927	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
455928	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
455929	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Bushings Connection/Risers	Good	
455930	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Bushing Condition	Good	
455931	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Amps C Ø	40.0	
455932	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Amps B Ø	35.0	
455933	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Amps A Ø	40.0	
455934	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
455935	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
455936	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
455937	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	9 Month Operations	2	
455938	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Operations Ground	0	
455939	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Operations C Ø	0	
455940	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Operations B Ø	0	
455941	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Operations A Ø	0	
455942	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0	
455943	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
455944	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
455945	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
455946	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
455947	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
455948	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
455949	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
455950	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Regulator As Left Counter	5950	
455951	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
455952	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
455953	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Tank Leaks	None	
455954	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
455955	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
455956	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
455957	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
455958	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
455959	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
455960	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
455961	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
455962	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
455963	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
455964	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	General Comments		
455965	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
455966	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
455967	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
455968	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
455969	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
455970	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
455971	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
455972	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0	
455973	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
455974	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
455975	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
455976	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
455977	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
455978	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
455979	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
455980	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
455981	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
455982	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Totalizer Meter Reading	.3270	
455983	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
455984	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
455985	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
455986	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
455987	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
455988	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
455989	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	General Comments		
455990	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
455991	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
455992	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
455993	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
455994	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
455995	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
455996	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
455997	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
455998	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
455999	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
456000	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
456001	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
456002	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	General Comments		
456003	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
456004	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
456005	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Foundation Condition	Good	
456006	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
456007	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
456008	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
456009	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
456010	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
456011	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
456012	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
456013	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
456014	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
456015	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
456016	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
456017	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
456018	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
456019	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
456020	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
456021	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
456022	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	VRR Time Delay	30	Seconds
456023	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
456024	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
456025	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
456026	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
456027	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	LTC Operation Checked?	y	
456028	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Oil Temp Max	50	°C
456029	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Oil Temp Present	27	°C
456030	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
456031	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Clear of Trash?	y	
456032	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
456033	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
456034	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	All Connections OK?	y	
456035	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
456036	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
456037	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
456038	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
456039	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
456040	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
456041	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
456042	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
456043	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
456044	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	All Connections OK?	y	
456045	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	Follow-up Action Required?	n	
456046	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	General Comments		
456047	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	LTC Operation Checked?	y	
456048	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
456049	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
456050	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
456051	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
456052	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	VRR Time Delay	60	Seconds
456053	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
456054	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	General Comments		
456055	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
456056	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
456057	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
456058	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
456059	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
456060	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
456061	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
456062	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
456063	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
456064	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
456065	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
456066	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
456067	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
456068	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
456069	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
456070	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
456071	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
456072	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	General Comments		
456073	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
456074	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
456075	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
456076	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Tank Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
456077	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
456078	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
456079	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
456080	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
456081	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
456082	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
456083	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	279	
456084	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	279	
456085	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
456086	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
456087	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
456088	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
456089	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
456090	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
456091	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
456092	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
456093	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Foundation Condition	Good	
456094	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
456095	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
456096	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
456097	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
456098	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
456099	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
456100	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	240.0	
456101	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	General Comments		
456102	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
456103	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
456104	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
456105	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Unknown Operations	0	
456106	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
456107	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Switching Operations	2	
456108	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
456109	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Operations This Read Vac	2	
456110	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Operations Counter AL	162	
456111	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Operations Counter AF	160	
456112	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
456113	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Maintenance Operations	0	
456114	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	300.0	
456115	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	240.0	
456116	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
456117	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
456118	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
456119	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
456120	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
456121	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
456122	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
456123	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
456124	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
456125	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
456126	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
456127	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
456128	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
456129	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
456130	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
456131	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
456132	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
456133	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
456134	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
456135	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
456136	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
456137	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
456138	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
456139	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
456140	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
456141	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
456142	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
456143	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Regulator As Left Counter	153307	
456144	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
456145	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
456146	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Tank Leaks	None	
456147	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
456148	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Adjusted Amps B Phase V	0	
456149	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Adjusted Amps C Phase V	0	
456150	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Operations A Ø	0	
456151	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
456152	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Operations C Ø	0	
456153	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Operations Ground	0	
456154	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Follow-up Action Required?	n	
456155	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Follow-up Action Required?	n	
456156	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Foundation Condition	Good	
456157	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	General Comments		
456158	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	General Comments		
456159	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Grounds in Place?	y	
456160	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Heaters (All) Functioning?	y	
456161	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Maintenance Operations	0	
456162	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Moisture and Leak Free?	y	
456163	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Operations Counter AF	395	
456164	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Operations Counter AL	399	
456165	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Operations This Read Vac	4	
456166	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
456167	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Switching Operations	4	
456168	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Tank Paint Condition	Good	
456169	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Unknown Operations	0	
456170	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
456171	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
456172	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Clear of Trash?	y	
456173	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
456174	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
456175	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
456176	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
456177	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
456178	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
456179	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	General Comments		
456180	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
456181	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Vegetation	None	
456182	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
456183	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
456184	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
456185	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
456186	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
456187	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
456188	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
456189	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
456190	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
456191	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
456192	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
456193	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
456194	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
456195	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
456196	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Operations B Ø	0	
456197	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Operations A Ø	0	
456198	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Adjusted Amps C Phase V	0	
456199	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Adjusted Amps B Phase V	0	
456200	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Adjusted Amps A Phase V	0	
456201	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Equipment Properly Labeled?	y	
456202	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Cabinet Paint Condition	Good	
456203	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Readings	General Comments		
456204	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
456205	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
456206	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
456207	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
456208	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
456209	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
456210	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
456211	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
456212	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
456213	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
456214	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
456215	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
456216	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
456217	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
456218	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	110.0	
456219	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	140.0	
456220	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	140.0	
456221	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
456222	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
456223	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
456224	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Bushings Connection/Risers	Good	
456225	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Bushing Condition	Good	
456226	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Amps C Ø	168	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
456227	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Amps B Ø	171	
456228	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Amps A Ø	169	
456229	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Accumulated Fault Duty C Ph V	.48	%
456230	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Accumulated Fault Duty B Ph V	.48	%
456231	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Accumulated Fault Duty A Ph V	.48	%
456232	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	9 Month Operations	5	
456233	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Unknown Operations	0	
456234	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Tank Paint Condition	Good	
456235	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Switching Operations	2	
456236	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Operations This Read Vac	2	
456237	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Operations Counter AL	170	
456238	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Operations Counter AF	170	
456239	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Moisture and Leak Free?	y	
456240	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Maintenance Operations	0	
456241	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Grounds in Place?	y	
456242	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	General Comments		
456243	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	General Comments		
456244	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Foundation Condition	Good	
456245	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Follow-up Action Required?	n	
456246	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Follow-up Action Required?	n	
456247	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Operations Ground	0	
456248	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
456249	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
456250	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
456251	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
456252	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
456253	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
456254	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
456255	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
456256	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
456257	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	331	
456258	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	331	
456259	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
456260	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
456261	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
456262	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
456263	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
456264	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
456265	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	General Comments		
456266	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	General Comments		
456267	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
456268	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
456269	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
456270	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
456271	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
456272	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
456273	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
456274	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
456275	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
456276	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
456277	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
456278	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
456279	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
456280	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
456281	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	General Comments		
456282	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
456283	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Follow-up Action Required?	n	
456284	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
456285	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Unknown Operations	0	
456286	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Tank Paint Condition	Good	
456287	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Switching Operations	2	
456288	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
456289	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Operations This Read Vac	2	
456290	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Operations Counter AL	221	
456291	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Operations Counter AF	219	
456292	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Moisture and Leak Free?	y	
456293	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Maintenance Operations	0	
456294	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Heaters (All) Functioning?	y	
456295	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Grounds in Place?	y	
456296	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	General Comments		
456297	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	General Comments		
456298	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Foundation Condition	Good	
456299	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Follow-up Action Required?	n	
456300	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Follow-up Action Required?	n	
456301	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
456302	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Operations C Ø	0	
456303	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Amps B Ø	40.0	
456304	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Amps C Ø	45.0	
456305	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Bushing Condition	Good	
456306	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Bushings Connection/Risers	Good	
456307	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
456308	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
456309	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
456310	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Cabinet Paint Condition	Good	
456311	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Equipment Properly Labeled?	y	
456312	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
456313	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
456314	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
456315	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BCH001236	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
456316	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BCH001236	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
456317	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BCH001236	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
456318	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BCH001236	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
456319	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BCH001236	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
456320	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Operations A Ø	0	
456321	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BCH001236	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
456322	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BCH001236	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
456323	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BCH001236	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
456324	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Operations B Ø	0	
456325	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Operations C Ø	0	
456326	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Operations Ground	0	
456327	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Follow-up Action Required?	n	
456328	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Follow-up Action Required?	n	
456329	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Foundation Condition	Good	
456330	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	General Comments		
456331	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	General Comments		
456332	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Grounds in Place?	y	
456333	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Heaters (All) Functioning?	y	
456334	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Maintenance Operations	0	
456335	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Moisture and Leak Free?	y	
456336	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Operations Counter AF	214	
456337	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Operations Counter AL	214	
456338	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Operations This Read Vac	0	
456339	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
456340	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Switching Operations	0	
456341	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Tank Paint Condition	Good	
456342	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Unknown Operations	0	
456343	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
456344	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
456345	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
456346	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
456347	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	General Comments		
456348	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
456349	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
456350	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
456351	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
456352	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
456353	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
456354	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
456355	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
456356	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
456357	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
456358	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Unknown Operations	0	
456359	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Switching Operations	0	
456360	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Operations This Read AM	0	
456361	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
456362	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
456363	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
456364	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
456365	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
456366	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
456367	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
456368	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
456369	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0	VDC
456370	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0	VDC
456371	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
456372	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
456373	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
456374	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
456375	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
456376	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
456377	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
456378	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
456379	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
456380	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
456381	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
456382	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
456383	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
456384	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
456385	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
456386	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
456387	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
456388	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
456389	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
456390	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
456391	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
456392	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
456393	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
456394	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
456395	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
456396	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
456397	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	General Comments		
456398	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	General Comments	Added nitrogen	
456399	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
456400	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
456401	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
456402	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	892.80	kw
456403	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
456404	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
456405	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Oil Temp Max	69	°C
456406	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Oil Temp Present	39	°C
456407	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	9 Month Operations	7	
456408	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
456409	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
456410	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
456411	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
456412	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
456413	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
456414	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
456415	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3720	
456416	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
456417	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
456418	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
456419	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Amps A Ø	40.0	
456420	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
456421	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
456422	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
456423	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Operations Ground	0	
456424	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Operations C Ø	0	
456425	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Operations B Ø	0	
456426	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Operations A Ø	0	
456427	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
456428	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
456429	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
456430	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
456431	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Amps C Ø	240.0	
456432	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Amps B Ø	180.0	
456433	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Amps A Ø	100.0	
456434	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
456435	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
456436	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
456437	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	9 Months Operations	0	
456438	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
456439	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	5.73	%
456440	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	70	
456441	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
456442	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
456443	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
456444	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
456445	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
456446	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Current Tap Position	2L	
456447	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
456448	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
456449	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
456450	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
456451	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
456452	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
456453	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Max Tap Position	1R	
456454	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Min Tap Position	8L	
456455	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
456456	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
456457	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
456458	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
456459	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
456460	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Regulator As Left Counter	135492	
456461	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
456462	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
456463	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Tank Leaks	None	
456464	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
456465	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
456466	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
456467	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
456468	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
456469	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	General Comments		
456470	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
456471	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
456472	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
456473	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
456474	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
456475	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
456476	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
456477	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	80	
456478	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
456479	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Operations Counter AL	351	
456480	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Operations Counter AF	351	
456481	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Maintenance Operations	0	
456482	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
456483	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	General Comments		
456484	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Operations A Ø	0	
456485	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
456486	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
456487	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
456488	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
456489	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Cabinet Paint Condition	Good	
456490	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
456491	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
456492	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
456493	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Bushings Connection/Risers	Good	
456494	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Bushing Condition	Good	
456495	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Amps C Ø	17.0	
456496	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Amps B Ø	28.0	
456497	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Amps A Ø	54.0	
456498	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
456499	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
456500	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
456501	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	9 Month Operations	2	
456502	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Patrol Inspection	General Comments		
456503	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Follow-up Action Required?	n	
456504	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
456505	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Winding Temp Present	25	°C
456506	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Winding Temp Max	35	°C
456507	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Totalizer Meter Reading	.4358	
456508	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
456509	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
456510	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
456511	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
456512	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
456513	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
456514	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Oil Temp Present	30	°C
456515	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Oil Temp Max	35	°C
456516	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	700	psi
456517	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3	psi
456518	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
456519	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	LTC Totalizer Reading	6275.52	kw
456520	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
456521	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	General Comments		
456522	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	General Comments		
456523	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Follow-up Action Required?	n	
456524	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
456525	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
456526	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
456527	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
456528	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
456529	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
456530	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
456531	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
456532	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
456533	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
456534	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
456535	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	9.55	%
456536	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	8.12	%
456537	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
456538	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
456539	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
456540	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
456541	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
456542	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
456543	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
456544	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
456545	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
456546	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
456547	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Operations A Ø	0	
456548	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Operations B Ø	0	
456549	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Operations C Ø	0	
456550	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Operations Ground	0	
456551	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Follow-up Action Required?	n	
456552	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
456553	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
456554	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
456555	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC Operations Since Last Insp	415	
456556	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC Min Tap Position	11L	
456557	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC Max Tap Position	2L	
456558	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC Current Tap Position	10L	
456559	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
456560	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC As Left Counter	25592	
456561	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC As Found Counter	25592	
456562	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	General Comments		
456563	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	General Comments		
456564	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
456565	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	Follow-up Action Required?	n	
456566	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
456567	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
456568	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
456569	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
456570	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
456571	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Follow-up Action Required?	n	
456572	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	LTCC000505	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
456573	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	LTCC000505	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
456574	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
456575	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	General Comments		
456576	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
456577	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
456578	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
456579	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
456580	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
456581	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
456582	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
456583	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
456584	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
456585	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
456586	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
456587	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
456588	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
456589	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	LTCC000505	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
456590	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	LTCC000505	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
456591	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	LTCC000505	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
456592	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	LTCC000505	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
456593	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	LTCC000505	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
456594	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	LTCC000505	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
456595	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Foundation Condition	Good	
456596	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	General Comments		
456597	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	9 Month Operations	2	
456598	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
456599	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
456600	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
456601	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Amps A Ø	200.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
456602	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Amps B Ø	230.0	
456603	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Amps C Ø	230.0	
456604	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Bushing Condition	Good	
456605	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	Follow-up Action Required?	n	
456606	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
456607	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Bushings Connection/Risers	Good	
456608	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
456609	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
456610	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
456611	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Cabinet Paint Condition	Good	
456612	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Equipment Properly Labeled?	y	
456613	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
456614	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
456615	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
456616	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Operations A Ø	0	
456617	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Operations B Ø	0	
456618	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	General Comments		
456619	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	General Comments		
456620	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC As Found Counter	136915	
456621	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC As Left Counter	136915	
456622	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
456623	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Operations C Ø	0	
456624	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC Current Tap Position	7L	
456625	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC Max Tap Position	1R	
456626	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC Min Tap Position	8L	
456627	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Operations Ground	0	
456628	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Follow-up Action Required?	n	
456629	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Follow-up Action Required?	n	
456630	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Foundation Condition	Good	
456631	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	General Comments		
456632	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	General Comments		
456633	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Grounds in Place?	y	
456634	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Heaters (All) Functioning?	y	
456635	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Maintenance Operations	0	
456636	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Moisture and Leak Free?	y	
456637	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Operations Counter AF	176	
456638	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC Operations Since Last Insp	498	
456639	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
456640	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
456641	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
456642	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Operations Counter AL	1176	
456643	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Operations This Read Vac	0	
456644	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
456645	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Switching Operations	0	
456646	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Tank Paint Condition	Good	
456647	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Unknown Operations	0	
456648	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	9 Month Operations	2	
456649	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
456650	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
456651	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
456652	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Amps A Ø	236	
456653	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Amps B Ø	215	
456654	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Amps C Ø	240	
456655	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Bushing Condition	Good	
456656	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Adjusted Amps A Phase V	33.91	
456657	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Adjusted Amps B Phase V	0	
456658	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Adjusted Amps C Phase V	0	
456659	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Operations A Ø	2	
456660	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Operations B Ø	0	
456661	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Operations C Ø	0	
456662	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Operations Ground	0	
456663	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Follow-up Action Required?	n	
456664	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Follow-up Action Required?	n	
456665	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Foundation Condition	Good	
456666	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	General Comments		
456667	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	General Comments		
456668	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Grounds in Place?	y	
456669	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Heaters (All) Functioning?	y	
456670	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Maintenance Operations	0	
456671	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Moisture and Leak Free?	y	
456672	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Operations Counter AF	441	
456673	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Operations Counter AL	445	
456674	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Operations This Read Vac	4	
456675	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
456676	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Switching Operations	2	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
456677	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Tank Paint Condition	Good	
456678	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Unknown Operations	0	
456679	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
456680	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
456681	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
456682	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
456683	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
456684	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Unknown Operations	0	
456685	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Tank Paint Condition	Good	
456686	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Switching Operations	0	
456687	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
456688	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Operations This Read Vac	0	
456689	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Operations Counter AL	218	
456690	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Operations Counter AF	218	
456691	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Moisture and Leak Free?	y	
456692	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Maintenance Operations	0	
456693	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Heaters (All) Functioning?	y	
456694	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Grounds in Place?	y	
456695	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	General Comments		
456696	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	General Comments		
456697	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Foundation Condition	Good	
456698	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Follow-up Action Required?	n	
456699	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Follow-up Action Required?	n	
456700	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Operations Ground	0	
456701	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Operations C Ø	0	
456702	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Operations B Ø	0	
456703	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Vegetation	None	
456704	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
456705	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
456706	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
456707	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	General Comments		
456708	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
456709	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
456710	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
456711	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
456712	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
456713	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Clear of Trash?	y	
456714	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
456715	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	General Comments		
456716	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Grounds in Place?	y	
456717	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
456718	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Maintenance Operations	0	
456719	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
456720	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Operations Counter AF	154	
456721	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	9 Month Operations	6	
456722	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Accumulated Fault Duty A Ph V	17.69	%
456723	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Accumulated Fault Duty B Ph V	5.06	%
456724	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Accumulated Fault Duty C Ph V	3.79	%
456725	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Operations Counter AL	156	
456726	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Operations This Read Vac	2	
456727	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
456728	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
456729	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
456730	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
456731	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
456732	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
456733	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
456734	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
456735	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
456736	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
456737	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
456738	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Switching Operations	2	
456739	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Tank Paint Condition	Good	
456740	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
456741	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
456742	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
456743	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	General Comments		
456744	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Unknown Operations	0	
456745	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
456746	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	-60	°C
456747	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	-60	°C
456748	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
456749	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
456750	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	Oil Temp Max	70	°C
456751	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
456752	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
456753	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
456754	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
456755	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
456756	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
456757	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
456758	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
456759	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
456760	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Amps A Ø	100	
456761	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Amps B Ø	100	
456762	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
456763	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
456764	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
456765	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
456766	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Amps C Ø	100	
456767	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Bushing Condition	Good	
456768	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Bushings Connection/Risers	Good	
456769	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
456770	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
456771	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
456772	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Cabinet Paint Condition	Good	
456773	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Equipment Properly Labeled?	y	
456774	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
456775	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
456776	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
456777	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Oil Temp Max	50	°C
456778	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Oil Temp Present	40	°C
456779	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
456780	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
456781	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
456782	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
456783	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
456784	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
456785	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
456786	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
456787	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
456788	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
456789	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
456790	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC Operations Since Last Insp	383	
456791	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
456792	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
456793	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
456794	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
456795	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC Min Tap Position	6L	
456796	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
456797	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Totalizer Meter Reading	.672	
456798	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Winding Temp Max	60	°C
456799	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Winding Temp Present	40	°C
456800	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
456801	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
456802	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC Current Tap Position	3L	
456803	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
456804	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC As Left Counter	69626	
456805	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	LTCC000357	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
456806	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	LTCC000357	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
456807	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	LTCC000357	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
456808	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	LTCC000357	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
456809	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	LTCC000357	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
456810	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	LTCC000357	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
456811	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	LTCC000357	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
456812	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	LTCC000357	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
456813	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC As Found Counter	69626	
456814	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	General Comments		
456815	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	General Comments		
456816	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
456817	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	Follow-up Action Required?	n	
456818	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
456819	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
456820	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
456821	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
456822	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC Operations Since Last Insp	307	
456823	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.5	psi
456824	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC Min Tap Position	7L	
456825	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC Max Tap Position	1R	
456826	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC Current Tap Position	6L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
456827	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
456828	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC As Left Counter	14775	
456829	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC As Found Counter	14775	
456830	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	General Comments		
456831	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	General Comments		
456832	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
456833	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	Follow-up Action Required?	n	
456834	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	All Connections OK?	y	
456835	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
456836	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
456837	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
456838	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
456839	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
456840	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Oil Temp Present	45	°C
456841	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Oil Temp Max	65	°C
456842	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
456843	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
456844	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	6233.76	kw
456845	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
456846	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.7	psi
456847	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
456848	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	General Comments		
456849	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	General Comments		
456850	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
456851	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
456852	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
456853	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
456854	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
456855	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
456856	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
456857	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
456858	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
456859	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
456860	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
456861	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
456862	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
456863	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
456864	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
456865	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
456866	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
456867	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
456868	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
456869	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
456870	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
456871	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
456872	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
456873	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
456874	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Follow-up Action Required?	n	
456875	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
456876	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
456877	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
456878	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
456879	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
456880	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
456881	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
456882	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
456883	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
456884	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Follow-up Action Required?	n	
456885	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
456886	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
456887	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	General Comments		
456888	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	General Comments		
456889	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
456890	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	LTC Totalizer Reading	9676.8	kw
456891	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
456892	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
456893	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
456894	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
456895	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
456896	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	404	
456897	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
456898	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
456899	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
456900	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
456901	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
456902	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
456903	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
456904	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
456905	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
456906	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
456907	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
456908	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Foundation Condition	Good	
456909	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
456910	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
456911	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
456912	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	125	
456913	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	123	
456914	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
456915	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
456916	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
456917	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
456918	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
456919	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
456920	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
456921	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
456922	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
456923	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
456924	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
456925	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
456926	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
456927	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
456928	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
456929	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
456930	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
456931	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
456932	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
456933	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
456934	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
456935	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
456936	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
456937	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	320	
456938	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	320	
456939	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	320	
456940	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0	%
456941	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0	%
456942	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0	%
456943	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
456944	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	General Comments		
456945	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
456946	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
456947	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
456948	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
456949	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
456950	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
456951	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
456952	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	General Comments		
456953	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	General Comments		
456954	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	Follow-up Action Required?	n	
456955	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
456956	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
456957	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
456958	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Clear of Trash?	y	
456959	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
456960	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
456961	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
456962	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
456963	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
456964	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	General Comments		
456965	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
456966	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Vegetation	None	
456967	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
456968	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
456969	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	LTC Totalizer Reading	8572.80	kw
456970	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
456971	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
456972	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Oil Temp Max	55	°C
456973	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
456974	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
456975	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
456976	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
456977	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Totalizer Meter Reading	.6310	
456978	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
456979	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
456980	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Oil Temp Present	30	°C
456981	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
456982	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
456983	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
456984	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
456985	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
456986	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
456987	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
456988	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
456989	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Totalizer Meter Reading	.8930	
456990	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
456991	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
456992	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
456993	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
456994	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
456995	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
456996	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	General Comments		
456997	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
456998	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
456999	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
457000	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
457001	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
457002	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
457003	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
457004	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
457005	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
457006	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
457007	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
457008	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
457009	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
457010	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
457011	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
457012	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
457013	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Follow-up Action Required?	n	
457014	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
457015	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
457016	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
457017	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
457018	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
457019	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
457020	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
457021	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
457022	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
457023	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
457024	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
457025	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Oil Temp Max	55	°C
457026	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Oil Temp Present	35	°C
457027	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
457028	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
457029	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
457030	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
457031	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
457032	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
457033	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
457034	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
457035	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
457036	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Totalizer Meter Multiplier	14000	
457037	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Totalizer Meter Reading	.4900	
457038	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	LTC Totalizer Reading	6057.60	kw
457039	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
457040	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
457041	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Winding Temp Max	55	°C
457042	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Oil Temp Max	60	°C
457043	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
457044	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
457045	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
457046	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
457047	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
457048	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
457049	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Winding Temp Present	35	°C
457050	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	60.0	
457051	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	60.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
457052	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	220.00	
457053	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
457054	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	80.0	
457055	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
457056	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
457057	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
457058	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
457059	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
457060	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
457061	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
457062	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
457063	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
457064	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
457065	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
457066	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
457067	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
457068	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
457069	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
457070	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
457071	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
457072	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
457073	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
457074	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
457075	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
457076	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Follow-up Action Required?	n	
457077	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
457078	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	80	
457079	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
457080	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
457081	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
457082	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	General Comments	barbwire and gate posts rusty. Briar limbs growing over one corner of the fence. Some tree limbs starting to grow over the top of the	
457083	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
457084	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
457085	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	General Comments		
457086	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	General Comments		
457087	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
457088	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
457089	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
457090	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Totalizer Meter Reading	.8700	
457091	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
457092	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
457093	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
457094	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
457095	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
457096	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
457097	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
457098	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
457099	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Oil Temp Present	45	°C
457100	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Oil Temp Max	55	°C
457101	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
457102	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
457103	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	LTC Totalizer Reading	6264.00	kw
457104	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
457105	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	General Comments		
457106	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	General Comments		
457107	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
457108	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
457109	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
457110	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
457111	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
457112	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
457113	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
457114	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
457115	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
457116	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
457117	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
457118	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
457119	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
457120	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Follow-up Action Required?	n	
457121	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
457122	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
457123	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	General Comments		
457124	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	General Comments		
457125	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
457126	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	LTC Totalizer Reading	6860.00	kw

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
457127	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
457128	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
457129	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
457130	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
457131	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
457132	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
457133	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
457134	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
457135	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
457136	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
457137	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
457138	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
457139	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
457140	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	783	
457141	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	783	
457142	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
457143	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
457144	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
457145	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
457146	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
457147	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
457148	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
457149	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
457150	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
457151	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
457152	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
457153	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
457154	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
457155	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
457156	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	120	
457157	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	124	
457158	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
457159	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
457160	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
457161	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
457162	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
457163	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
457164	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
457165	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
457166	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
457167	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
457168	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
457169	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
457170	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
457171	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
457172	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Totalizer Meter Reading	.8658	
457173	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
457174	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	VRR Time Delay	30	Seconds
457175	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
457176	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
457177	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
457178	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
457179	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
457180	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
457181	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
457182	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	VRR Base Voltage AL	124	VAC
457183	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	VRR Base Voltage AF	124	VAC
457184	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	LTC Output Voltage Level	124	VAC
457185	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	LTC Operation Checked?	n	
457186	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	General Comments		
457187	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
457188	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
457189	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
457190	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
457191	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
457192	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
457193	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
457194	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
457195	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	15	
457196	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
457197	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
457198	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
457199	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	12.0	
457200	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	12.0	
457201	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	12.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
457202	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
457203	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
457204	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
457205	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
457206	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	2	
457207	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
457208	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
457209	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
457210	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
457211	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
457212	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Readings	General Comments		
457213	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
457214	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
457215	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
457216	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
457217	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	14	
457218	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	135	
457219	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	135	
457220	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	6	
457221	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
457222	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
457223	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
457224	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
457225	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
457226	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
457227	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
457228	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
457229	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
457230	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
457231	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
457232	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
457233	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
457234	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
457235	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
457236	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
457237	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
457238	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
457239	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
457240	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
457241	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
457242	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
457243	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
457244	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
457245	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
457246	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100	
457247	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100	
457248	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100	
457249	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
457250	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	128	
457251	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	128	
457252	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
457253	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
457254	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
457255	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
457256	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
457257	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
457258	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
457259	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
457260	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
457261	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
457262	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
457263	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
457264	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
457265	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
457266	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
457267	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
457268	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
457269	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	9 Months Operations	3	
457270	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
457271	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
457272	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
457273	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Amps A Ø	100.0	
457274	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Amps B Ø	335.0	
457275	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	General Comments		
457276	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
457277	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
457278	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
457279	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Tank Leaks	None	
457280	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
457281	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
457282	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Regulator As Left Counter	473856	
457283	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
457284	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
457285	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Foundation Condition	Good	
457286	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
457287	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
457288	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
457289	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
457290	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
457291	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
457292	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	13	
457293	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
457294	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
457295	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
457296	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	
457297	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	40.0	
457298	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	40.0	
457299	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
457300	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
457301	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
457302	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
457303	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
457304	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
457305	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
457306	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
457307	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
457308	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	Follow-up Action Required?	n	
457309	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
457310	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	General Comments		
457311	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	General Comments		
457312	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC As Found Counter	25905	
457313	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC As Left Counter	25905	
457314	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
457315	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
457316	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
457317	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
457318	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
457319	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
457320	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
457321	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
457322	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
457323	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
457324	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
457325	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
457326	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
457327	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
457328	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
457329	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
457330	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
457331	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
457332	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.87	%
457333	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.43	%
457334	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
457335	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.43	%
457336	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Maintenance Operations	0	
457337	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
457338	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
457339	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
457340	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
457341	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
457342	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
457343	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	9 Month Operations	6	
457344	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	All Connections OK?	y	
457345	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	Follow-up Action Required?	n	
457346	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	General Comments		
457347	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	LTC Operation Checked?	y	
457348	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
457349	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
457350	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
457351	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	VRR Time Delay	30	Seconds

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
457352	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
457353	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
457354	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
457355	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
457356	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
457357	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
457358	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
457359	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
457360	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
457361	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
457362	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
457363	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
457364	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
457365	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
457366	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
457367	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
457368	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
457369	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	237	
457370	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
457371	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
457372	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
457373	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Amps A Ø	0.0	
457374	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
457375	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
457376	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
457377	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
457378	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
457379	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
457380	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
457381	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
457382	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
457383	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Vegetation	None	
457384	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
457385	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
457386	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
457387	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
457388	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
457389	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
457390	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	23156	
457391	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	23156	
457392	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
457393	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	6.41	
457394	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
457395	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
457396	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	40.0	
457397	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	30.0	
457398	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
457399	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
457400	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
457401	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
457402	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Unknown Operations	0	
457403	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
457404	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
457405	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
457406	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
457407	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
457408	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
457409	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
457410	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
457411	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BCH000369	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
457412	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BCH000369	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
457413	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
457414	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	1	
457415	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
457416	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
457417	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	All Connections OK?	y	
457418	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Switching Operations	0	
457419	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
457420	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Operations This Read Vac	0	
457421	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Operations Counter AL	254	
457422	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Operations Counter AF	254	
457423	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
457424	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	Follow-up Action Required?	n	
457425	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	General Comments		
457426	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
457427	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Operations Counter AF	445	
457428	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Maintenance Operations	0	
457429	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
457430	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	General Comments		
457431	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	General Comments		
457432	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC As Found Counter	70394	
457433	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	General Comments		
457434	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Patrol Inspection	General Comments		
457435	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Follow-up Action Required?	n	
457436	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
457437	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Operations Ground	0	
457438	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Operations C Ø	0	
457439	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Operations B Ø	0	
457440	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
457441	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	General Comments		
457442	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
457443	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
457444	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
457445	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Operations A Ø	0	
457446	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
457447	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	18	
457448	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
457449	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
457450	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
457451	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
457452	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
457453	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
457454	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
457455	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
457456	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
457457	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
457458	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
457459	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
457460	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
457461	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
457462	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	641	
457463	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
457464	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC As Left Counter	70404	
457465	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
457466	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC Current Tap Position	3L	
457467	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC Max Tap Position	4R	
457468	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC Min Tap Position	10L	
457469	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC Operations Since Last Insp	585	
457470	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
457471	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	Follow-up Action Required?	n	
457472	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
457473	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
457474	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
457475	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
457476	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
457477	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Ambient Temp	73	°F
457478	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
457479	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Clear of Trash?	y	
457480	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
457481	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
457482	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
457483	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
457484	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	14	
457485	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
457486	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
457487	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
457488	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
457489	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
457490	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	40.0	
457491	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	
457492	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
457493	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
457494	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
457495	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
457496	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
457497	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
457498	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
457499	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Tank Leaks	None	
457500	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
457501	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
457502	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Regulator As Left Counter	109092	
457503	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
457504	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
457505	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
457506	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	Follow-up Action Required?	n	
457507	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
457508	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
457509	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
457510	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
457511	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Operations A Ø	0	
457512	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Operations B Ø	0	
457513	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Unknown Operations	0	
457514	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Switching Operations	0	
457515	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Operations This Read AM	0	
457516	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Operations Counter AL	445	
457517	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
457518	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
457519	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC As Left Counter	367660	
457520	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC As Found Counter	367660	
457521	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
457522	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	General Comments		
457523	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
457524	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
457525	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
457526	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
457527	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
457528	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
457529	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Operations C Ø	0	
457530	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Operations Ground	0	
457531	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
457532	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
457533	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Follow-up Action Required?	n	
457534	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
457535	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
457536	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
457537	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
457538	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
457539	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
457540	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
457541	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	General Comments		
457542	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
457543	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
457544	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
457545	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
457546	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
457547	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
457548	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Vegetation	None	
457549	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
457550	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
457551	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
457552	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
457553	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
457554	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
457555	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
457556	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
457557	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	General Comments		
457558	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
457559	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
457560	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
457561	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
457562	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
457563	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
457564	4/16/2019 10:35	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
457565	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	Follow-up Action Required?	n	
457566	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
457567	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	General Comments		
457568	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	General Comments		
457569	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC As Found Counter	29555	
457570	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
457571	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
457572	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC As Left Counter	29555	
457573	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
457574	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
457575	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
457576	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC Current Tap Position	1L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
457577	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
457578	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	General Comments		
457579	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	General Comments		
457580	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC Min Tap Position	4L	
457581	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC Operations Since Last Insp	646	
457582	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
457583	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
457584	4/16/2019 15:07	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
457585	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC As Found Counter	365431	
457586	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC As Left Counter	365441	
457587	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
457588	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
457589	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC Current Tap Position	1L	
457590	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC Max Tap Position	1L	
457591	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC Min Tap Position	8L	
457592	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC Operations Since Last Insp	764	
457593	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
457594	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
457595	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
457596	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
457597	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
457598	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
457599	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	General Comments		
457600	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
457601	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
457602	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
457603	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
457604	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
457605	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
457606	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
457607	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
457608	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
457609	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
457610	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	488	
457611	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	488	
457612	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
457613	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
457614	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
457615	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
457616	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
457617	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
457618	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
457619	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
457620	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
457621	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Vegetation	None	
457622	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
457623	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
457624	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Adjusted Amps C Phase V	0	
457625	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Adjusted Amps B Phase V	0	
457626	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Adjusted Amps A Phase V	0	
457627	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Equipment Properly Labeled?	y	
457628	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Cabinet Paint Condition	Good	
457629	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
457630	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
457631	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
457632	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Bushings Connection/Risers	Good	
457633	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Bushing Condition	Good	
457634	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Amps C Ø	62	
457635	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Amps B Ø	45	
457636	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Amps A Ø	63	
457637	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Accumulated Fault Duty C Ph V	2.53	%
457638	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Accumulated Fault Duty B Ph V	8.85	%
457639	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Accumulated Fault Duty A Ph V	10.11	%
457640	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	9 Month Operations	4	
457641	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
457642	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
457643	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
457644	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
457645	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
457646	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
457647	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	General Comments		
457648	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
457649	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
457650	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Operations B Ø	0	
457651	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
457652	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Maintenance Operations	0	
457653	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Operations Counter AF	537	
457654	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Operations Counter AL	537	
457655	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
457656	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
457657	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
457658	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
457659	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
457660	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
457661	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	General Comments		
457662	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
457663	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
457664	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
457665	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
457666	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
457667	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
457668	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
457669	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
457670	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
457671	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
457672	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Foundation Condition	Good	
457673	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
457674	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
457675	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
457676	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
457677	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
457678	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
457679	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Operations This Read AM	0	
457680	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Switching Operations	0	
457681	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Unknown Operations	0	
457682	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BCH000369	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
457683	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	9 Months Operations	0	
457684	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BCH000369	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
457685	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BCH000369	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
457686	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
457687	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
457688	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
457689	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
457690	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
457691	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
457692	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
457693	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
457694	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
457695	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
457696	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
457697	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
457698	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
457699	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
457700	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	378	
457701	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	378	
457702	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
457703	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
457704	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Clear of Trash?	y	
457705	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
457706	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Equipment Properly Labeled?	y	
457707	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Cabinet Paint Condition	Good	
457708	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
457709	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
457710	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
457711	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Bushings Connection/Risers	Good	
457712	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Bushing Condition	Good	
457713	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Amps C Ø	81.0	
457714	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Amps B Ø	115.0	
457715	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Amps A Ø	92.0	
457716	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
457717	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
457718	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
457719	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	9 Month Operations	6	
457720	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
457721	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
457722	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
457723	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
457724	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
457725	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
457726	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
457727	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC Current Tap Position	6L	
457728	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
457729	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC Min Tap Position	11L	
457730	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC Operations Since Last Insp	728	
457731	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
457732	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
457733	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
457734	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
457735	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	General Comments		
457736	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	General Comments		
457737	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
457738	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
457739	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
457740	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
457741	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
457742	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
457743	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
457744	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
457745	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
457746	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
457747	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	General Comments		
457748	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
457749	4/16/2019 14:27	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
457750	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
457751	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
457752	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Switching Operations	0	
457753	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Operations This Read Vac	0	
457754	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Operations Counter AL	189	
457755	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Operations Counter AF	189	
457756	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Moisture and Leak Free?	y	
457757	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Maintenance Operations	0	
457758	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Grounds in Place?	y	
457759	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	General Comments		
457760	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	General Comments		
457761	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Foundation Condition	Good	
457762	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Follow-up Action Required?	n	
457763	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Follow-up Action Required?	n	
457764	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Operations Ground	0	
457765	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	General Comments		
457766	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
457767	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BCH000369	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
457768	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
457769	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Operations C Ø	0	
457770	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Operations B Ø	0	
457771	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Operations A Ø	0	
457772	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
457773	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
457774	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
457775	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
457776	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Foundation Condition	Good	
457777	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
457778	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Amps B Ø	0.0	
457779	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	General Comments		
457780	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	General Comments		
457781	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Amps C Ø	0.0	
457782	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
457783	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Grounds in Place?	y	
457784	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
457785	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
457786	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
457787	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
457788	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Heaters (All) Functioning?	y	
457789	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Operations This Read Vac	2	
457790	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
457791	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
457792	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
457793	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
457794	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
457795	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
457796	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Maintenance Operations	0	
457797	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
457798	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Moisture and Leak Free?	y	
457799	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Operations Counter AF	215	
457800	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Operations Counter AL	217	
457801	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
457802	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
457803	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
457804	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	241	
457805	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
457806	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
457807	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
457808	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
457809	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
457810	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
457811	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
457812	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
457813	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
457814	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
457815	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
457816	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
457817	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Amps A Ø	100.0	
457818	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Amps B Ø	25.0	
457819	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Amps C Ø	50.0	
457820	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
457821	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
457822	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
457823	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
457824	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
457825	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
457826	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
457827	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
457828	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
457829	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Tank Paint Condition	Good	
457830	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Unknown Operations	0	
457831	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Operations Ground	0	
457832	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
457833	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Operations C Ø	0	
457834	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Operations B Ø	0	
457835	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
457836	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
457837	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Operations A Ø	0	
457838	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
457839	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
457840	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
457841	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
457842	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
457843	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
457844	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
457845	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
457846	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Amps C Ø	210.0	
457847	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	General Comments		
457848	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Patrol Inspection	General Comments		
457849	4/16/2019 14:19	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
457850	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
457851	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
457852	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Operations Ground	0	
457853	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Follow-up Action Required?	n	
457854	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Follow-up Action Required?	n	
457855	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Switching Operations	2	
457856	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
457857	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Tank Paint Condition	Good	
457858	4/16/2019 13:44	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
457859	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Unknown Operations	0	
457860	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Follow-up Action Required?	n	
457861	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
457862	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
457863	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
457864	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
457865	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
457866	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
457867	4/16/2019 13:53	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
457868	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
457869	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
457870	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
457871	4/16/2019 12:00	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	General Comments		
457872	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
457873	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
457874	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
457875	4/16/2019 11:18	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
457876	4/16/2019 9:13	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
457877	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LTCC000517	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
457878	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LTCC000517	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
457879	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LTCC000517	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
457880	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LTCC000517	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
457881	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
457882	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
457883	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
457884	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
457885	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
457886	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
457887	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
457888	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
457889	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	1	
457890	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
457891	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
457892	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
457893	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
457894	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	138	
457895	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	138	
457896	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
457897	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
457898	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	30.0	
457899	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	30.0	
457900	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
457901	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
457902	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
457903	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
457904	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
457905	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
457906	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
457907	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
457908	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
457909	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
457910	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
457911	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
457912	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
457913	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
457914	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
457915	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
457916	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
457917	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
457918	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
457919	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
457920	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
457921	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
457922	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
457923	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
457924	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
457925	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
457926	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
457927	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
457928	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
457929	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
457930	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
457931	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	482	
457932	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	486	
457933	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
457934	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
457935	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
457936	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
457937	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
457938	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
457939	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
457940	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
457941	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
457942	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
457943	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
457944	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
457945	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
457946	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
457947	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
457948	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
457949	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
457950	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
457951	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
457952	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
457953	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
457954	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
457955	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
457956	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
457957	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
457958	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
457959	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
457960	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
457961	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	247	
457962	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
457963	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
457964	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
457965	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
457966	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
457967	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
457968	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	242	
457969	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
457970	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
457971	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
457972	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
457973	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
457974	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
457975	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
457976	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
457977	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
457978	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
457979	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
457980	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
457981	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
457982	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
457983	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
457984	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
457985	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
457986	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
457987	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
457988	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
457989	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
457990	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
457991	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
457992	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	UG Pothead Condition Good?	y	
457993	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
457994	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Steel Structures Rust Free?	y	
457995	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
457996	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
457997	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Site Service Trans Condition	OK	
457998	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
457999	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
458000	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Operating Linkage OK?	y	
458001	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Moisture and Leak Free?	y	
458002	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
458003	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
458004	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
458005	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
458006	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Linkage Grounds in Place?	y	
458007	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
458008	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
458009	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	General Comments		
458010	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
458011	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
458012	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
458013	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
458014	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
458015	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
458016	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
458017	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
458018	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
458019	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Foundation Condition	Good	
458020	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
458021	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Operations Counter AF	336	
458022	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Operations Counter AL	336	
458023	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
458024	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Cabinet Paint Condition	Good	
458025	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Equipment Properly Labeled?	y	
458026	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
458027	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
458028	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
458029	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
458030	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
458031	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000305	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
458032	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
458033	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	General Comments		
458034	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	General Comments	Added nitrogen	
458035	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
458036	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Unknown Operations	0	
458037	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Tank Paint Condition	Good	
458038	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Follow-up Action Required?	n	
458039	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Foundation Condition	Good	
458040	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
458041	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Switching Operations	0	
458042	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
458043	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Operations This Read Vac	2	
458044	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
458045	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
458046	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Amps C Ø	0.0	
458047	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Bushing Condition	Good	
458048	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Amps B Ø	0.0	
458049	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Moisture and Leak Free?	y	
458050	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
458051	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Equipment Properly Labeled?	y	
458052	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Cabinet Paint Condition	Good	
458053	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
458054	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
458055	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Amps A Ø	0.0	
458056	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	General Comments		
458057	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
458058	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
458059	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
458060	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Maintenance Operations	2	
458061	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
458062	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
458063	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
458064	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
458065	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
458066	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Bushings Connection/Risers	Good	
458067	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Operations Counter AL	343	
458068	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Operations Counter AF	343	
458069	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	9 Month Operations	40	
458070	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
458071	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
458072	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
458073	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
458074	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Amps A Ø	0.0	
458075	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Fault Operations B Ø	0	
458076	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
458077	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	General Comments	Transformer needs Nitrogen added	
458078	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
458079	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
458080	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Patrol Inspection	General Comments		
458081	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Fault Operations C Ø	0	
458082	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
458083	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
458084	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Fault Operations A Ø	0	
458085	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
458086	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Amps B Ø	0.0	
458087	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Amps C Ø	0.0	
458088	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	General Comments		
458089	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
458090	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Grounds in Place?	n	
458091	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
458092	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
458093	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
458094	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
458095	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
458096	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
458097	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
458098	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
458099	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
458100	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Heaters (All) Functioning?	y	
458101	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
458102	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	General Comments		
458103	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Foundation Condition	Good	
458104	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Follow-up Action Required?	n	
458105	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Follow-up Action Required?	n	
458106	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
458107	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Clear of Trash?	y	
458108	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
458109	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Fault Operations Ground	0	
458110	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
458111	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
458112	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
458113	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
458114	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
458115	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
458116	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
458117	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
458118	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
458119	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
458120	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
458121	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	General Comments		
458122	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
458123	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Vegetation	None	
458124	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	General Comments		
458125	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
458126	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
458127	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
458128	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
458129	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
458130	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
458131	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
458132	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
458133	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
458134	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
458135	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Tank Paint Condition	Good	
458136	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
458137	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Moisture and Leak Free?	y	
458138	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Heaters (All) Functioning?	y	
458139	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Grounds in Place?	y	
458140	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
458141	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	General Comments		
458142	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
458143	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Operations Counter AL	371	
458144	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Operations This Read Vac	2	
458145	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
458146	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Switching Operations	0	
458147	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
458148	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Unknown Operations	0	
458149	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
458150	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
458151	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
458152	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
458153	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
458154	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Patrol Inspection	General Comments		
458155	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
458156	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	y	
458157	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
458158	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	General Comments	there are not any amp meteres on GND-TR-2	
458159	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
458160	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Operations Counter	66	
458161	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
458162	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
458163	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
458164	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Operations Counter	1689	
458165	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
458166	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
458167	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	General Comments		
458168	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
458169	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
458170	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
458171	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
458172	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
458173	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
458174	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
458175	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
458176	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
458177	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
458178	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
458179	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
458180	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
458181	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	General Comments		
458182	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
458183	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
458184	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
458185	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
458186	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
458187	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
458188	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
458189	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
458190	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
458191	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
458192	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	25.0	
458193	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	25.0	
458194	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	25.0	
458195	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Amps B Ø	427.0	
458196	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Amps C Ø	429.0	
458197	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
458198	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
458199	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
458200	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
458201	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
458202	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
458203	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
458204	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
458205	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
458206	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
458207	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
458208	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
458209	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
458210	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
458211	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
458212	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PF000158	PowerFuse	GR-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
458213	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PF000158	PowerFuse	GR-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
458214	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
458215	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
458216	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
458217	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
458218	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
458219	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
458220	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
458221	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Operations Ground	0	
458222	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
458223	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
458224	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
458225	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	General Comments		
458226	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
458227	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
458228	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
458229	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	92	
458230	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
458231	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
458232	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	310	
458233	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
458234	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
458235	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
458236	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	679	
458237	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
458238	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
458239	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
458240	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	General Comments		
458241	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	General Comments		
458242	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
458243	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
458244	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Maintenance Operations	2	
458245	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
458246	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Operations Counter AF	371	
458247	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
458248	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Amps C Ø	130.0	
458249	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Amps B Ø	140.0	
458250	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Amps A Ø	120.0	
458251	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
458252	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
458253	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
458254	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	9 Months Operations	0	
458255	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
458256	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
458257	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
458258	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
458259	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
458260	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Current Tap Position	12L	
458261	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
458262	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
458263	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
458264	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
458265	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	General Comments		
458266	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
458267	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Max Tap Position	8L	
458268	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Min Tap Position	16L	
458269	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
458270	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
458271	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
458272	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
458273	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
458274	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Regulator As Left Counter	201779	
458275	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
458276	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
458277	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Tank Leaks	None	
458278	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
458279	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	LTCC000667	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
458280	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	LTCC000667	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
458281	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	LTCC000667	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
458282	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	LTCC000667	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
458283	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	LTCC000667	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
458284	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	LTCC000667	LTCControl	930-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
458285	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	LTCC000667	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
458286	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	LTCC000667	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
458287	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	LTCC000667	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
458288	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
458289	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
458290	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
458291	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
458292	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
458293	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
458294	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
458295	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
458296	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
458297	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
458298	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
458299	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
458300	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
458301	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
458302	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
458303	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
458304	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
458305	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
458306	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
458307	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
458308	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
458309	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
458310	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
458311	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Follow-up Action Required?	n	
458312	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
458313	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
458314	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	General Comments		
458315	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	General Comments	added nitrogen	
458316	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
458317	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	LTC Totalizer Reading	6701.76	kw
458318	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
458319	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
458320	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Oil Temp Max	65	°C
458321	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Oil Temp Present	34	°C
458322	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
458323	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
458324	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
458325	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
458326	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Tank Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
458327	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
458328	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
458329	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
458330	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Totalizer Meter Reading	1.3962	
458331	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
458332	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
458333	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Unknown Operations	0	
458334	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Switching Operations	0	
458335	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Operations This Read AM	0	
458336	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Operations Counter AL	489	
458337	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Operations Counter AF	489	
458338	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Maintenance Operations	0	
458339	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
458340	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	General Comments		
458341	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Patrol Inspection	General Comments		
458342	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Follow-up Action Required?	n	
458343	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
458344	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Operations Ground	0	
458345	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Operations C Ø	0	
458346	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Operations B Ø	0	
458347	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Operations A Ø	0	
458348	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
458349	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
458350	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
458351	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
458352	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
458353	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
458354	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
458355	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
458356	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
458357	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
458358	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
458359	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
458360	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	General Comments		
458361	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
458362	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
458363	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
458364	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	9 Month Operations	2	
458365	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
458366	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
458367	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
458368	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
458369	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
458370	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
458371	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
458372	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
458373	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Amps A Ø	125.0	
458374	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
458375	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
458376	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
458377	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
458378	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
458379	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
458380	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
458381	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
458382	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
458383	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
458384	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
458385	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
458386	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
458387	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
458388	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
458389	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
458390	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Amps B Ø	125.0	
458391	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Amps C Ø	105.0	
458392	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Bushing Condition	Good	
458393	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Bushings Connection/Risers	Good	
458394	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
458395	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
458396	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
458397	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Cabinet Paint Condition	Good	
458398	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Equipment Properly Labeled?	y	
458399	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
458400	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
458401	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
458402	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Operations A Ø	0	
458403	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
458404	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
458405	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
458406	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
458407	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
458408	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
458409	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Bushings Connection/Risers	Good	
458410	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Bushing Condition	Good	
458411	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
458412	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
458413	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
458414	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
458415	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
458416	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
458417	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
458418	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
458419	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
458420	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
458421	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
458422	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
458423	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
458424	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
458425	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
458426	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
458427	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Clear of Trash?	y	
458428	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
458429	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
458430	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
458431	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
458432	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
458433	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	General Comments		
458434	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
458435	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
458436	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Vegetation	None	
458437	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
458438	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
458439	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
458440	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
458441	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
458442	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	General Comments		
458443	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
458444	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
458445	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
458446	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
458447	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
458448	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
458449	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
458450	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
458451	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
458452	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
458453	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
458454	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
458455	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
458456	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
458457	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Operations A Ø	0	
458458	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Operations B Ø	0	
458459	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Energization Inspection	General Comments	this needs to be removed	
458460	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Commissioning Inspection	General Comments	this needs to be removed.	
458461	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Operations C Ø	0	
458462	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Operations Ground	0	
458463	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Annual Control Inspection	Ground Lead 1 Resistance Set 1	0.0	Micro Ohms
458464	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Annual Control Inspection	Ground Lead 1 Resistance Set 2	0.0	Micro Ohms
458465	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Annual Control Inspection	Ground Lead 2 Resistance Set 1	0.0	Micro Ohms
458466	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Annual Control Inspection	Ground Lead 2 Resistance Set 2	0.0	Micro Ohms
458467	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Follow-up Action Required?	n	
458468	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Follow-up Action Required?	n	
458469	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Annual Control Inspection	Ground Lead 3 Resistance Set 1	0.0	Micro Ohms
458470	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Annual Control Inspection	Ground Lead 3 Resistance Set 2	0.0	Micro Ohms
458471	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Foundation Condition	Good	
458472	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	General Comments		
458473	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	General Comments		
458474	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Grounds in Place?	y	
458475	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Heaters (All) Functioning?	y	
458476	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
458477	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Moisture and Leak Free?	y	
458478	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Operations Counter AF	197	
458479	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Operations Counter AL	197	
458480	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Operations This Read Vac	0	
458481	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Switching Operations	0	
458482	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Tank Paint Condition	Good	
458483	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Unknown Operations	0	
458484	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
458485	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
458486	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
458487	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
458488	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
458489	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
458490	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
458491	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
458492	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PF000156	PowerFuse	GR-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
458493	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PF000156	PowerFuse	GR-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
458494	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
458495	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
458496	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
458497	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
458498	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
458499	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	9 Month Operations	60	
458500	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
458501	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
458502	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
458503	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Amps A Ø	438.0	
458504	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
458505	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
458506	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
458507	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Operations B Ø	0	
458508	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Operations C Ø	0	
458509	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Operations Ground	0	
458510	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Follow-up Action Required?	n	
458511	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Follow-up Action Required?	n	
458512	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Foundation Condition	Good	
458513	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	General Comments		
458514	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	General Comments		
458515	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Grounds in Place?	y	
458516	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Heaters (All) Functioning?	y	
458517	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Maintenance Operations	0	
458518	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Moisture and Leak Free?	y	
458519	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Operations Counter AF	197	
458520	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Operations Counter AL	197	
458521	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Operations This Read Vac	0	
458522	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Switching Operations	0	
458523	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Tank Paint Condition	Good	
458524	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Unknown Operations	0	
458525	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	9 Month Operations	2	
458526	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
458527	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
458528	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
458529	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Amps A Ø	0.0	
458530	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
458531	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
458532	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
458533	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
458534	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
458535	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
458536	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
458537	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
458538	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
458539	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
458540	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
458541	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
458542	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
458543	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
458544	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
458545	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Amps B Ø	0.0	
458546	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Amps C Ø	0.0	
458547	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Bushing Condition	Good	
458548	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Bushings Connection/Risers	Good	
458549	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Energization Inspection	Cascade Nameplate Correct	n	
458550	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
458551	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
458552	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
458553	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Cabinet Paint Condition	Good	
458554	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Commissioning Inspection	Commissioning Steps Complete	n	
458555	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Energization Inspection	Energization Steps Complete	n	
458556	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Equipment Properly Labeled?	y	
458557	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
458558	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Annual Control Inspection	Follow-up Action Required?	y	
458559	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Annual Control Inspection	General Comments	this needs to be removed	
458560	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Moisture and Leak Free?	y	
458561	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Maintenance Operations	10	
458562	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Heaters (All) Functioning?	y	
458563	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Grounds in Place?	y	
458564	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	General Comments		
458565	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	General Comments		
458566	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Foundation Condition	Good	
458567	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Follow-up Action Required?	n	
458568	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Follow-up Action Required?	n	
458569	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Fault Operations Ground	0	
458570	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Fault Operations C Ø	0	
458571	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Fault Operations B Ø	0	
458572	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Fault Operations A Ø	0	
458573	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
458574	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
458575	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
458576	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
458577	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
458578	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
458579	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
458580	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
458581	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Equipment Properly Labeled?	y	
458582	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Cabinet Paint Condition	Good	
458583	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
458584	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
458585	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
458586	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Bushings Connection/Risers	Good	
458587	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Bushing Condition	Good	
458588	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Amps C Ø	84.0	
458589	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Amps B Ø	88.0	
458590	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Amps A Ø	99.0	
458591	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
458592	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
458593	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
458594	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
458595	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
458596	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
458597	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	26	
458598	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	20.48	%
458599	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
458600	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
458601	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
458602	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
458603	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
458604	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Foundation Condition	Good	
458605	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
458606	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
458607	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	General Comments		
458608	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
458609	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
458610	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	50	°C
458611	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
458612	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
458613	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Readings	LTC Totalizer Reading	547.20	kw
458614	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
458615	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
458616	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
458617	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
458618	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
458619	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
458620	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
458621	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
458622	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
458623	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
458624	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
458625	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
458626	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
458627	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
458628	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
458629	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
458630	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
458631	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
458632	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
458633	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	147	
458634	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	147	
458635	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
458636	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
458637	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
458638	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
458639	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
458640	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
458641	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
458642	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	
458643	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Unknown Operations	0	
458644	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Tank Paint Condition	Good	
458645	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Switching Operations	0	
458646	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
458647	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Operations This Read Vac	10	
458648	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
458649	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
458650	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
458651	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
458652	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
458653	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Switching Operations	0	
458654	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Tank Paint Condition	Good	
458655	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Unknown Operations	0	
458656	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
458657	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
458658	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
458659	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Operations Counter AL	332	
458660	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Operations Counter AF	332	
458661	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
458662	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
458663	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Cabinet Paint Condition	Good	
458664	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Equipment Properly Labeled?	y	
458665	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
458666	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
458667	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
458668	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Operations A Ø	0	
458669	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Operations B Ø	0	
458670	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
458671	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
458672	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
458673	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
458674	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
458675	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
458676	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
458677	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
458678	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	121	
458679	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	9 Month Operations	0	
458680	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
458681	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
458682	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
458683	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Amps A Ø	700.0	
458684	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Amps B Ø	700.0	
458685	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Amps C Ø	700.0	
458686	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Bushing Condition	Good	
458687	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
458688	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
458689	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Bushings Connection/Risers	Good	
458690	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
458691	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
458692	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
458693	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Cabinet Paint Condition	Good	
458694	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
458695	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
458696	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
458697	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	General Comments		
458698	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Equipment Properly Labeled?	y	
458699	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
458700	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Operations C Ø	0	
458701	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
458702	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Follow-up Action Required?	n	
458703	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Follow-up Action Required?	n	
458704	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Foundation Condition	Good	
458705	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	General Comments		
458706	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	General Comments		
458707	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Grounds in Place?	y	
458708	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
458709	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Vegetation	None	
458710	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	VRR Time Delay	30	Seconds
458711	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
458712	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
458713	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
458714	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
458715	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
458716	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
458717	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
458718	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
458719	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
458720	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
458721	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
458722	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
458723	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Clear of Trash?	y	
458724	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
458725	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
458726	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
458727	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
458728	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	12.05	%
458729	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	4.82	%
458730	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	120.0	
458731	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
458732	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
458733	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
458734	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
458735	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	141	
458736	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	141	
458737	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
458738	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
458739	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
458740	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
458741	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
458742	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
458743	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
458744	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	30.0	
458745	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	30.0	
458746	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	30.0	
458747	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
458748	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
458749	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	130.0	
458750	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	240.0	
458751	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
458752	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
458753	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
458754	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
458755	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
458756	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
458757	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
458758	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
458759	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
458760	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
458761	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Bushings Connection/Risers	Good	
458762	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
458763	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Operations B Ø	0	
458764	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
458765	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
458766	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
458767	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
458768	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
458769	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
458770	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
458771	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
458772	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
458773	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
458774	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
458775	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
458776	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
458777	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
458778	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	General Comments		
458779	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
458780	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
458781	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
458782	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Bushings Connection/Risers	Good	
458783	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Bushing Condition	Good	
458784	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Amps C Ø	211.0	
458785	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Operations C Ø	0	
458786	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Operations Ground	0	
458787	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Follow-up Action Required?	n	
458788	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Follow-up Action Required?	n	
458789	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Foundation Condition	Good	
458790	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	General Comments		
458791	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	General Comments		
458792	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Grounds in Place?	y	
458793	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Heaters (All) Functioning?	y	
458794	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Maintenance Operations	0	
458795	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Moisture and Leak Free?	y	
458796	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Operations Counter AF	382	
458797	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Operations Counter AL	382	
458798	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Operations This Read Vac	0	
458799	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
458800	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Switching Operations	0	
458801	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Tank Paint Condition	Good	
458802	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Unknown Operations	0	
458803	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Operations Counter AL	345	
458804	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
458805	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
458806	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
458807	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
458808	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
458809	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
458810	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
458811	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	General Comments	25 foot wood arm, that is the backside of the double arm of the line is rotten and needs replaced.	
458812	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Operations This Read Vac	2	
458813	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
458814	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Heaters (All) Functioning?	y	
458815	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Grounds in Place?	y	
458816	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Maintenance Operations	2	
458817	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Moisture and Leak Free?	y	
458818	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Operations Counter AF	345	
458819	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	General Comments		
458820	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	General Comments		
458821	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Foundation Condition	Good	
458822	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Follow-up Action Required?	n	
458823	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Follow-up Action Required?	n	
458824	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Operations Ground	0	
458825	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Operations C Ø	0	
458826	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Operations B Ø	0	
458827	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Operations A Ø	0	
458828	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Cabinet Paint Condition	Good	
458829	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
458830	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
458831	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
458832	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
458833	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
458834	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
458835	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
458836	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
458837	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
458838	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
458839	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
458840	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
458841	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
458842	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
458843	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
458844	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
458845	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Equipment Properly Labeled?	y	
458846	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Cabinet Paint Condition	Good	
458847	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
458848	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
458849	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
458850	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	General Comments		
458851	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
458852	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	9 Month Operations	4	
458853	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
458854	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
458855	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
458856	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Amps A Ø	0.0	
458857	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Amps B Ø	0.0	
458858	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Amps C Ø	0.0	
458859	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Bushing Condition	Good	
458860	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Equipment Properly Labeled?	y	
458861	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
458862	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
458863	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
458864	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Operations A Ø	0	
458865	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
458866	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
458867	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
458868	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
458869	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
458870	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
458871	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
458872	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
458873	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	General Comments		
458874	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
458875	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
458876	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
458877	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
458878	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
458879	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
458880	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
458881	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
458882	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
458883	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
458884	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
458885	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
458886	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
458887	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
458888	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
458889	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Bushing Condition	Good	
458890	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Bushings Connection/Risers	Good	
458891	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
458892	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
458893	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
458894	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Cabinet Paint Condition	Good	
458895	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
458896	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Follow-up Action Required?	n	
458897	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Foundation Condition	Good	
458898	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	General Comments		
458899	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Grounds in Place?	y	
458900	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Moisture and Leak Free?	y	
458901	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Tank Leaks	None	
458902	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Tank Oil Level	Good	
458903	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Tank Paint Condition	Good	
458904	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
458905	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
458906	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
458907	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Reading	.1140	
458908	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
458909	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
458910	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
458911	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
458912	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
458913	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
458914	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
458915	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
458916	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
458917	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Bushings Connection/Risers	Good	
458918	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Bushing Condition	Good	
458919	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Amps C Ø	250.0	
458920	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Amps B Ø	250.0	
458921	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Amps A Ø	300.0	
458922	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
458923	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
458924	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
458925	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	9 Month Operations	11	
458926	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Amps B Ø	219.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
458927	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Amps A Ø	205.0	
458928	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
458929	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
458930	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
458931	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	9 Month Operations	25	
458932	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
458933	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
458934	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
458935	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
458936	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
458937	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
458938	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
458939	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
458940	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
458941	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
458942	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
458943	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
458944	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
458945	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
458946	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
458947	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
458948	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
458949	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
458950	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
458951	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
458952	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
458953	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
458954	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
458955	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
458956	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
458957	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
458958	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
458959	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
458960	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10.0	
458961	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Wood Structures OK?	n	
458962	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
458963	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
458964	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
458965	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
458966	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
458967	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
458968	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	9 Month Operations	26	
458969	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
458970	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
458971	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
458972	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
458973	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
458974	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
458975	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Unknown Operations	0	
458976	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Tank Paint Condition	Good	
458977	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PF000161	PowerFuse	GR-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
458978	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PF000161	PowerFuse	GR-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
458979	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Switching Operations	0	
458980	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
458981	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Tank Leaks	None	
458982	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
458983	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
458984	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Regulator As Left Counter	160344	
458985	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
458986	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
458987	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
458988	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
458989	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
458990	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Min Tap Position	16L	
458991	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
458992	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
458993	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	General Comments		
458994	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
458995	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
458996	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
458997	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
458998	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
458999	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
459000	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
459001	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
459002	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
459003	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
459004	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
459005	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Operations This Read Vac	12	
459006	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Operations Counter AL	349	
459007	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Operations Counter AF	349	
459008	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Moisture and Leak Free?	y	
459009	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Maintenance Operations	12	
459010	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Heaters (All) Functioning?	y	
459011	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Grounds in Place?	y	
459012	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	General Comments		
459013	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	General Comments		
459014	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Foundation Condition	Good	
459015	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Follow-up Action Required?	n	
459016	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Follow-up Action Required?	n	
459017	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
459018	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Operations B Ø	0	
459019	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Operations A Ø	0	
459020	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
459021	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
459022	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
459023	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Equipment Properly Labeled?	y	
459024	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Cabinet Paint Condition	Good	
459025	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
459026	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
459027	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
459028	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
459029	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PF000155	PowerFuse	GR-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
459030	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PF000155	PowerFuse	GR-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
459031	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
459032	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
459033	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PF000157	PowerFuse	GR-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
459034	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PF000157	PowerFuse	GR-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
459035	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
459036	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
459037	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PF000159	PowerFuse	GR-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
459038	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PF000159	PowerFuse	GR-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
459039	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
459040	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
459041	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
459042	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PF000160	PowerFuse	GR-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
459043	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PF000160	PowerFuse	GR-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
459044	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Tank Leaks	None	
459045	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
459046	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
459047	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
459048	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
459049	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
459050	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
459051	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
459052	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
459053	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
459054	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
459055	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
459056	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
459057	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
459058	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
459059	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
459060	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
459061	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
459062	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Bushings Connection/Risers	Good	
459063	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Bushing Condition	Good	
459064	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Amps C Ø	153.0	
459065	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Amps B Ø	159.0	
459066	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Amps A Ø	156.0	
459067	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
459068	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
459069	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
459070	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
459071	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
459072	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
459073	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	15	
459074	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
459075	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	484	
459076	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	484	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
459077	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000305	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
459078	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000305	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
459079	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000305	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
459080	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
459081	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Bushings Connection/Risers	Good	
459082	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Bushing Condition	Good	
459083	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Amps C Ø	88.0	
459084	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Amps B Ø	90.0	
459085	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Amps A Ø	90.0	
459086	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
459087	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	15	
459088	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
459089	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
459090	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
459091	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
459092	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
459093	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
459094	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
459095	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
459096	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
459097	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
459098	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
459099	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
459100	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
459101	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
459102	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
459103	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	Oil Temp Max	35	°C
459104	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
459105	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
459106	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
459107	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
459108	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
459109	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
459110	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
459111	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	9 Month Operations	42	
459112	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
459113	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
459114	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
459115	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
459116	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
459117	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
459118	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
459119	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Transformer needs Nitrogen added	
459120	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
459121	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
459122	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
459123	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
459124	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
459125	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
459126	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
459127	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
459128	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Operations Ground	0	
459129	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
459130	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
459131	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
459132	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
459133	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Operations C Ø	0	
459134	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Operations B Ø	0	
459135	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	General Comments		
459136	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
459137	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
459138	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
459139	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
459140	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
459141	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
459142	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
459143	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
459144	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Regulator As Left Counter	41633	
459145	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Operations A Ø	0	
459146	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
459147	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
459148	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Patrol Inspection	General Comments		
459149	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
459150	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
459151	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
459152	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
459153	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Equipment Properly Labeled?	y	
459154	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
459155	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Tank Leaks	None	
459156	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
459157	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	29	
459158	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	13.25	%
459159	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Cabinet Paint Condition	Good	
459160	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
459161	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	18.07	%
459162	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	24.09	%
459163	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	200.0	
459164	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	240.0	
459165	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	280.0	
459166	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
459167	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
459168	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
459169	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
459170	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
459171	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
459172	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
459173	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
459174	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
459175	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
459176	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
459177	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	421	
459178	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	421	
459179	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	5	
459180	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	5	
459181	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
459182	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
459183	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
459184	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
459185	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
459186	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
459187	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
459188	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
459189	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
459190	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000305	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
459191	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
459192	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
459193	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
459194	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
459195	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
459196	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
459197	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
459198	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
459199	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
459200	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
459201	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Operations A Ø	0	
459202	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
459203	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
459204	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
459205	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
459206	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	General Comments		
459207	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
459208	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
459209	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
459210	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
459211	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
459212	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
459213	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
459214	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Operations B Ø	0	
459215	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Operations C Ø	0	
459216	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Operations Ground	0	
459217	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
459218	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
459219	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
459220	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	295	
459221	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	7L	
459222	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
459223	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
459224	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	LTC Operation Checked?	y	
459225	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	General Comments		
459226	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
459227	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Moisture and Leak Free?	y	
459228	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Operations Counter AF	281	
459229	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Operations Counter AL	281	
459230	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Operations This Read Vac	0	
459231	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
459232	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Switching Operations	0	
459233	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Tank Paint Condition	Good	
459234	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Unknown Operations	0	
459235	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
459236	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
459237	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
459238	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	Follow-up Action Required?	n	
459239	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	All Connections OK?	y	
459240	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
459241	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
459242	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	192	
459243	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
459244	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
459245	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
459246	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC Current Tap Position	2L	
459247	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	121	
459248	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
459249	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
459250	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
459251	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
459252	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC As Left Counter	288988	
459253	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC As Found Counter	288988	
459254	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
459255	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	General Comments		
459256	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
459257	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
459258	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
459259	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
459260	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
459261	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
459262	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
459263	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
459264	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
459265	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
459266	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
459267	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
459268	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
459269	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
459270	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
459271	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
459272	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	9 Month Operations	31	
459273	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
459274	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
459275	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	General Comments		
459276	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	General Comments		
459277	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC As Found Counter	52869	
459278	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
459279	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
459280	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
459281	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
459282	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
459283	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
459284	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
459285	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Unknown Operations	0	
459286	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Tank Paint Condition	Good	
459287	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC As Left Counter	52874	
459288	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
459289	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC Current Tap Position	1L	
459290	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC Max Tap Position	2R	
459291	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC Min Tap Position	13L	
459292	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC Operations Since Last Insp	1371	
459293	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
459294	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
459295	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
459296	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Switching Operations	0	
459297	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
459298	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Operations This Read Vac	17	
459299	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Operations Counter AL	337	
459300	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Operations Counter AF	337	
459301	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
459302	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
459303	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
459304	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Regulator As Left Counter	43162	
459305	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
459306	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
459307	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
459308	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
459309	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
459310	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Maintenance Operations	17	
459311	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Heaters (All) Functioning?	y	
459312	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Grounds in Place?	y	
459313	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	General Comments		
459314	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	General Comments		
459315	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Foundation Condition	Good	
459316	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Follow-up Action Required?	n	
459317	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PF000154	PowerFuse	GR-GND TR 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
459318	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	PF000154	PowerFuse	GR-GND TR 2	Disconnect Powerfuse Inspection	General Comments	ok	
459319	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
459320	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
459321	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Follow-up Action Required?	n	
459322	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Operations Ground	0	
459323	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Operations C Ø	0	
459324	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	Neutral	
459325	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	5L	
459326	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
459327	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Follow-up Action Required?	n	
459328	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Follow-up Action Required?	n	
459329	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Foundation Condition	Good	
459330	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	General Comments		
459331	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	General Comments		
459332	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Grounds in Place?	y	
459333	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Maintenance Operations	0	
459334	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Moisture and Leak Free?	y	
459335	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
459336	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Regulator As Left Counter	41495	
459337	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
459338	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
459339	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Tank Leaks	None	
459340	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
459341	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
459342	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BCH000514	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
459343	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BCH000514	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
459344	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BCH000514	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
459345	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BCH000514	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
459346	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000305	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
459347	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000305	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
459348	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000305	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	121.2	VAC
459349	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Operations Counter AF	150	
459350	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Operations Counter AL	150	
459351	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Operations This Read Vac	0	
459352	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
459353	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Switching Operations	0	
459354	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Tank Paint Condition	Good	
459355	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Unknown Operations	0	
459356	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
459357	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
459358	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
459359	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
459360	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
459361	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
459362	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
459363	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
459364	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
459365	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
459366	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	General Comments		
459367	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	212563	
459368	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	212563	
459369	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0246	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments		
459370	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BCH000514	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
459371	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BCH000514	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
459372	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BCH000514	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
459373	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
459374	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	Follow-up Action Required?	n	
459375	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
459376	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Operations Counter AF	223	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
459377	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Oil Temp Max	42	°C
459378	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Oil Temp Present	32	°C
459379	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
459380	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
459381	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
459382	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
459383	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
459384	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	BCH000202	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
459385	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	BCH000202	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
459386	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	BCH000202	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
459387	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
459388	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Operations Counter AL	223	
459389	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
459390	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
459391	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
459392	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
459393	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
459394	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
459395	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
459396	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2820	
459397	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	550.0	
459398	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	500.0	
459399	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
459400	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
459401	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
459402	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
459403	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Operations This Read Vac	0	
459404	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
459405	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	500.0	
459406	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
459407	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
459408	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
459409	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
459410	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
459411	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
459412	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
459413	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	General Comments		
459414	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
459415	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Ambient Temp	40	°F
459416	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
459417	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
459418	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
459419	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
459420	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
459421	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	General Comments	barb wire rusty	
459422	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
459423	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
459424	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
459425	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
459426	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
459427	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	SWG000194	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
459428	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	SWG000194	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Panels Dusted?	y	
459429	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	SWG000194	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Panel Lights OK?	y	
459430	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	SWG000194	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
459431	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	SWG000194	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
459432	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	VRR Time Delay	30	Seconds
459433	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	SWG000194	Switchgear	Retired Distribution	Switchgear Patrol Inspection	General Comments		
459434	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
459435	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Vegetation	None	
459436	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
459437	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
459438	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
459439	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
459440	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
459441	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	General Comments		
459442	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	SWG000194	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
459443	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
459444	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
459445	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	SWG000194	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Follow-up Action Required?	n	
459446	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	SWG000194	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
459447	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	SWG000194	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Evidence of Insects	None	
459448	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	SWG000194	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
459449	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	SWG000194	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
459450	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	SWG000194	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
459451	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
459452	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Clear of Trash?	y	
459453	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	507.60	kw
459454	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
459455	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Cabinet Paint Condition	Good	
459456	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Equipment Properly Labeled?	y	
459457	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
459458	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
459459	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
459460	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Operations A Ø	0	
459461	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Operations B Ø	0	
459462	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
459463	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
459464	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Operations C Ø	0	
459465	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Operations Ground	0	
459466	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Follow-up Action Required?	n	
459467	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Follow-up Action Required?	n	
459468	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Foundation Condition	Good	
459469	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	General Comments		
459470	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	General Comments		
459471	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
459472	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
459473	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
459474	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
459475	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
459476	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
459477	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Grounds in Place?	y	
459478	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Maintenance Operations	0	
459479	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Moisture and Leak Free?	y	
459480	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	2.6	%
459481	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
459482	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Follow-up Action Required?	n	
459483	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
459484	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
459485	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
459486	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
459487	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
459488	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
459489	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
459490	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
459491	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
459492	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
459493	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
459494	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
459495	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Clear of Trash?	y	
459496	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
459497	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
459498	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
459499	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
459500	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
459501	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
459502	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
459503	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
459504	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
459505	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
459506	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
459507	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
459508	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
459509	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
459510	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
459511	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
459512	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	General Comments		
459513	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	General Comments	Added nitrogen	
459514	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
459515	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
459516	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
459517	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
459518	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	LTC Operation Checked?	y	
459519	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	General Comments		
459520	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	Follow-up Action Required?	n	
459521	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
459522	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
459523	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
459524	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
459525	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
459526	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
459527	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	General Comments	LTC Counter rolled over	
459528	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC As Found Counter	100394	
459529	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC As Left Counter	100394	
459530	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
459531	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
459532	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
459533	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
459534	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
459535	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Switching Operations	0	
459536	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Tank Paint Condition	Good	
459537	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Unknown Operations	0	
459538	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
459539	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
459540	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	General Comments		
459541	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
459542	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	40	°C
459543	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	LTC Totalizer Reading	3368.00	kw
459544	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
459545	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	General Comments		
459546	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	General Comments		
459547	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
459548	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
459549	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
459550	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	25	°C
459551	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
459552	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
459553	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
459554	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
459555	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	Oil Temp Max	30	°C
459556	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
459557	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
459558	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
459559	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	General Comments		
459560	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
459561	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
459562	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
459563	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
459564	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
459565	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
459566	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
459567	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
459568	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
459569	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
459570	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
459571	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
459572	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
459573	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
459574	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
459575	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
459576	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
459577	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
459578	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
459579	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
459580	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
459581	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
459582	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
459583	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
459584	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
459585	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
459586	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
459587	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	Follow-up Action Required?	n	
459588	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
459589	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
459590	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
459591	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
459592	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
459593	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
459594	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
459595	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
459596	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
459597	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
459598	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC As Left Counter	488222	
459599	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC As Found Counter	488222	
459600	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
459601	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
459602	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
459603	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
459604	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
459605	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
459606	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
459607	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
459608	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
459609	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
459610	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
459611	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
459612	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
459613	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LTCC000603	LTCControl	GR-CLASS-B TRANS 1	LTC Control Insp	All Connections OK?	y	
459614	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
459615	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
459616	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
459617	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
459618	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
459619	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
459620	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
459621	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
459622	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
459623	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
459624	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	530	
459625	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
459626	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
459627	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4L	
459628	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
459629	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
459630	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC As Left Counter	37930	
459631	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC As Found Counter	37930	
459632	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
459633	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	General Comments		
459634	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
459635	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
459636	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LTCC000603	LTCControl	GR-CLASS-B TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
459637	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LTCC000603	LTCControl	GR-CLASS-B TRANS 1	LTC Control Insp	General Comments		
459638	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
459639	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	85	
459640	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Amps A Ø	10.0	
459641	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Amps B Ø	31.5	
459642	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Amps C Ø	24.3	
459643	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
459644	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Vegetation	None	
459645	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
459646	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
459647	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	General Comments		
459648	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
459649	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
459650	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
459651	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
459652	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
459653	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
459654	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Clear of Trash?	y	
459655	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
459656	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
459657	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
459658	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	76	
459659	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
459660	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
459661	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	87	
459662	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
459663	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
459664	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
459665	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	General Comments		
459666	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
459667	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
459668	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
459669	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
459670	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
459671	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	General Comments		
459672	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
459673	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
459674	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
459675	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
459676	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
459677	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC Operations Since Last Insp	368	
459678	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.5	psi
459679	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC Min Tap Position	7L	
459680	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC Max Tap Position	3L	
459681	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC Current Tap Position	3L	
459682	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
459683	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC As Left Counter	53528	
459684	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC As Found Counter	23528	
459685	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	General Comments		
459686	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	852	
459687	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
459688	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
459689	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
459690	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
459691	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	General Comments		
459692	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
459693	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
459694	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
459695	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	689	
459696	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
459697	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	General Comments		
459698	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	General Comments		
459699	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
459700	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	LTC Totalizer Reading	1622.40	kw
459701	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
459702	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
459703	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	Oil Temp Max	65	°C
459704	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
459705	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
459706	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
459707	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Oil Temp Present	35	°C
459708	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3R	
459709	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
459710	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
459711	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
459712	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
459713	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
459714	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	Totalizer Meter Reading	.1690	
459715	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
459716	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
459717	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	9 Month Operations	4	
459718	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
459719	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
459720	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
459721	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Amps A Ø	0.0	
459722	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Amps B Ø	0.0	
459723	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Amps C Ø	0.0	
459724	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Bushing Condition	Good	
459725	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Bushings Connection/Risers	Good	
459726	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
459727	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
459728	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
459729	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
459730	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	LTC As Left Counter	99993	
459731	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	LTC As Found Counter	99993	
459732	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Oil Temp Max	40	°C
459733	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
459734	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	General Comments		
459735	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
459736	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
459737	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
459738	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
459739	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
459740	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
459741	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
459742	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
459743	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
459744	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	SWG000194	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
459745	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
459746	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
459747	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
459748	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
459749	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
459750	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
459751	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
459752	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
459753	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
459754	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
459755	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
459756	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
459757	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
459758	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
459759	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
459760	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
459761	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Totalizer Meter Reading	.4210	
459762	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	86	
459763	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
459764	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
459765	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
459766	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
459767	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
459768	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
459769	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
459770	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
459771	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
459772	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
459773	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
459774	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
459775	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	86	
459776	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
459777	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	Follow-up Action Required?	n	
459778	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
459779	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
459780	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
459781	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
459782	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	General Comments		
459783	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	General Comments		
459784	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
459785	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
459786	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
459787	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
459788	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
459789	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
459790	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
459791	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
459792	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
459793	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
459794	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
459795	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
459796	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
459797	4/15/2019 15:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
459798	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
459799	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
459800	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
459801	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Clear of Trash?	y	
459802	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
459803	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
459804	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
459805	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
459806	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
459807	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	General Comments		
459808	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
459809	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
459810	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Vegetation	None	
459811	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
459812	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
459813	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
459814	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	Oil Temp Present	28	°C
459815	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	Oil Temp Max	38	°C
459816	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
459817	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	General Comments		
459818	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
459819	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Vegetation	None	
459820	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Yard Lights Working?	y	
459821	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	All Identified and Legible?	y	
459822	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
459823	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
459824	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
459825	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
459826	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
459827	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
459828	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
459829	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
459830	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
459831	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
459832	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
459833	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
459834	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	240.0	
459835	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	280.0	
459836	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	250.0	
459837	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	7.23	%
459838	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	24.09	%
459839	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	24.09	%
459840	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	23	
459841	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
459842	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
459843	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
459844	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Battery Bank Amps	0.0	AMPS
459845	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Battery Bank Volts	24.0	VDC
459846	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
459847	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	Follow-up Action Required?	n	
459848	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
459849	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	General Comments		
459850	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Mechanism Patrol Inspection	General Comments		
459851	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC As Found Counter	94165	
459852	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC As Left Counter	94165	
459853	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
459854	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
459855	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC Max Tap Position	3L	
459856	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC Min Tap Position	5L	
459857	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
459858	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	697	
459859	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
459860	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
459861	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
459862	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
459863	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
459864	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
459865	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
459866	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
459867	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
459868	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
459869	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
459870	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
459871	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
459872	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
459873	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
459874	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
459875	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
459876	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
459877	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
459878	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
459879	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
459880	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
459881	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
459882	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
459883	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
459884	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
459885	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
459886	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
459887	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
459888	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
459889	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Wood Structures OK?	y	
459890	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
459891	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
459892	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
459893	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
459894	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	General Comments		
459895	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
459896	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
459897	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
459898	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
459899	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
459900	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
459901	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
459902	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
459903	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	BAT000813	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
459904	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	BAT000813	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
459905	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	BAT000813	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
459906	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
459907	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
459908	4/15/2019 11:46	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	All Connections OK?	y	
459909	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	BCH000801	Charger	362-2 Charger 2	Battery Charger Patrol Insp	General Comments		
459910	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	BCH000801	Charger	362-2 Charger 2	Battery Charger Patrol Insp	Follow-up Action Required?	n	
459911	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	BCH000801	Charger	362-2 Charger 2	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
459912	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	BCH000800	Charger	362-1 Charger 1	Battery Charger Patrol Insp	General Comments		
459913	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	BCH000800	Charger	362-1 Charger 1	Battery Charger Patrol Insp	Follow-up Action Required?	n	
459914	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	BCH000800	Charger	362-1 Charger 1	Battery Charger Patrol Insp	As Found Float Voltage	52.8	VDC
459915	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	BAT000814	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
459916	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	BAT000814	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
459917	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	BAT000814	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
459918	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	BAT000814	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
459919	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	BAT000814	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
459920	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	BAT000814	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
459921	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	BAT000814	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
459922	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	BAT000814	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
459923	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	BAT000814	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
459924	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	BAT000813	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
459925	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	BAT000813	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
459926	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	BAT000813	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
459927	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	BAT000813	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
459928	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	BAT000813	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
459929	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	BAT000813	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
459930	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
459931	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
459932	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
459933	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
459934	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
459935	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	General Comments		
459936	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
459937	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
459938	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC Operations Since Last Insp	67	
459939	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
459940	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
459941	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Unknown Operations	0	
459942	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Switching Operations	0	
459943	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Operations This Read AM	0	
459944	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Operations Counter AL	326	
459945	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Operations Counter AF	326	
459946	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Maintenance Operations	0	
459947	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
459948	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
459949	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
459950	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	General Comments		
459951	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Patrol Inspection	General Comments		
459952	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Follow-up Action Required?	n	
459953	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
459954	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Operations Ground	0	
459955	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Operations C Ø	0	
459956	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Operations B Ø	0	
459957	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Operations A Ø	0	
459958	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
459959	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
459960	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
459961	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
459962	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Amps C Ø	0.0	
459963	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Amps B Ø	0.0	
459964	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Amps A Ø	0.0	
459965	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	9 Months Operations	18	
459966	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
459967	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
459968	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
459969	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
459970	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
459971	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
459972	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
459973	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	General Comments		
459974	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
459975	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
459976	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
459977	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
459978	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	General Comments		
459979	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
459980	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
459981	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
459982	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
459983	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
459984	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
459985	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
459986	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
459987	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
459988	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
459989	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Operations Counter	942	
459990	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	.96	kw
459991	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
459992	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
459993	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Tank Leaks	None	
459994	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
459995	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
459996	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
459997	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
459998	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
459999	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
460000	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
460001	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
460002	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
460003	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
460004	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
460005	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
460006	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
460007	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
460008	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
460009	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
460010	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
460011	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
460012	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
460013	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
460014	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
460015	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
460016	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
460017	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
460018	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
460019	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
460020	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	General Comments		
460021	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
460022	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
460023	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
460024	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
460025	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0006	
460026	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
460027	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
460028	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
460029	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	Oil Temp Present	25	°C
460030	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	Oil Temp Max	40	°C
460031	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
460032	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
460033	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
460034	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
460035	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
460036	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	General Comments	Added nitrogen	
460037	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	General Comments		
460038	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
460039	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
460040	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
460041	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
460042	4/15/2019 11:00	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
460043	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	697	
460044	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	3	
460045	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	3	
460046	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
460047	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
460048	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
460049	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
460050	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
460051	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
460052	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
460053	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
460054	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
460055	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
460056	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
460057	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
460058	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
460059	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
460060	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
460061	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	421	
460062	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
460063	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
460064	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
460065	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
460066	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
460067	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
460068	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
460069	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
460070	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LTCC000425	LTCControl	GR-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
460071	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LTCC000425	LTCControl	GR-TRANS 1	LTC Control Insp	General Comments		
460072	4/15/2019 13:24	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
460073	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LTCC000425	LTCControl	GR-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
460074	4/15/2019 12:50	Distribution	Grady Quarterly Inspection	LTCC000425	LTCControl	GR-TRANS 1	LTC Control Insp	All Connections OK?	y	
460075	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
460076	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
460077	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
460078	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
460079	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Amps C Ø	68.0	
460080	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Amps B Ø	105.0	
460081	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
460082	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Amps A Ø	68.0	
460083	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
460084	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
460085	4/15/2019 15:18	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
460086	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LTCC000117	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
460087	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LTCC000117	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
460088	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LTCC000117	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
460089	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
460090	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
460091	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
460092	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
460093	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
460094	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
460095	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	69	
460096	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
460097	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
460098	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
460099	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
460100	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
460101	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
460102	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
460103	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	26	
460104	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
460105	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
460106	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	4	
460107	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	16.7	
460108	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	18.3	
460109	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
460110	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	14.1	
460111	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	5	
460112	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
460113	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
460114	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
460115	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
460116	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
460117	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Regulator As Left Counter	95193	
460118	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
460119	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
460120	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Tank Leaks	None	
460121	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
460122	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
460123	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
460124	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Regulator As Left Counter	113837	
460125	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
460126	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
460127	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
460128	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
460129	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
460130	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Tank Leaks	None	
460131	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
460132	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
460133	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
460134	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Bushings Connection/Risers	Good	
460135	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	16R	
460136	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	18	
460137	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	16L	
460138	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
460139	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
460140	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
460141	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
460142	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	256137	
460143	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
460144	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
460145	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Tank Paint Condition	Good	
460146	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
460147	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Unknown Operations	0	
460148	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Bushing Condition	Good	
460149	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
460150	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	General Comments		
460151	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
460152	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
460153	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
460154	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
460155	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
460156	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
460157	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
460158	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Regulator As Left Counter	41741	
460159	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
460160	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
460161	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
460162	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
460163	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	General Comments		
460164	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
460165	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
460166	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
460167	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
460168	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
460169	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
460170	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
460171	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
460172	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
460173	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
460174	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
460175	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
460176	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
460177	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
460178	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
460179	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
460180	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
460181	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
460182	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
460183	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
460184	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
460185	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
460186	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
460187	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	3L	
460188	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
460189	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
460190	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
460191	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
460192	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
460193	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
460194	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
460195	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	General Comments		
460196	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
460197	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
460198	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
460199	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
460200	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
460201	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
460202	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
460203	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
460204	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
460205	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
460206	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
460207	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
460208	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
460209	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Oil Temp Max	55	°C
460210	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
460211	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
460212	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
460213	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
460214	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	LTC Totalizer Reading	13939.20	kw
460215	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
460216	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	General Comments		
460217	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
460218	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
460219	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	60.0	
460220	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
460221	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
460222	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
460223	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
460224	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
460225	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LTCC000429	LTCControl	HK-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
460226	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LTCC000429	LTCControl	HK-TRANS 2	LTC Control Insp	General Comments		
460227	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LTCC000429	LTCControl	HK-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
460228	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
460229	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
460230	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
460231	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
460232	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	General Comments		
460233	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
460234	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
460235	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
460236	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	Follow-up Action Required?	n	
460237	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LTCC000429	LTCControl	HK-TRANS 2	LTC Control Insp	All Connections OK?	y	
460238	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	General Comments		
460239	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC As Found Counter	11783	
460240	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC As Left Counter	11783	
460241	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
460242	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	General Comments		
460243	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
460244	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
460245	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Foundation Condition	Good	
460246	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC Current Tap Position	4L	
460247	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
460248	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
460249	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
460250	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
460251	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
460252	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	18	
460253	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
460254	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
460255	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
460256	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
460257	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
460258	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC Max Tap Position	10L	
460259	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC Min Tap Position	1R	
460260	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC Operations Since Last Insp	777	
460261	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
460262	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
460263	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
460264	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
460265	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
460266	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	General Comments		
460267	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
460268	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
460269	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Follow-up Action Required?	n	
460270	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
460271	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
460272	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
460273	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
460274	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
460275	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
460276	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
460277	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Tank Leaks	None	
460278	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
460279	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	206	
460280	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
460281	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	60.0	
460282	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	206	
460283	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	18	
460284	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
460285	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
460286	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
460287	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
460288	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
460289	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
460290	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
460291	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
460292	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
460293	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
460294	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	60.0	
460295	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
460296	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
460297	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Clear of Trash?	y	
460298	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
460299	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
460300	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
460301	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
460302	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
460303	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
460304	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	General Comments		
460305	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
460306	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
460307	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
460308	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	n	
460309	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	n	
460310	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Tank Oil Level	Good	
460311	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Tank Leaks	None	
460312	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Switching Operations	0	
460313	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
460314	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
460315	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
460316	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Vegetation	None	
460317	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
460318	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	General Comments		
460319	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
460320	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
460321	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
460322	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
460323	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
460324	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Max Tap Position	8R	
460325	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
460326	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
460327	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
460328	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
460329	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
460330	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
460331	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
460332	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
460333	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
460334	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
460335	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Regulator As Left Counter	46255	
460336	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
460337	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
460338	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Tank Leaks	None	
460339	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
460340	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
460341	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1R	
460342	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	11L	
460343	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
460344	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	LTC Totalizer Reading	2700.00	kw
460345	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
460346	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	General Comments		
460347	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	General Comments		
460348	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
460349	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
460350	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Follow-up Action Required?	n	
460351	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
460352	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
460353	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
460354	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
460355	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
460356	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
460357	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
460358	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
460359	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
460360	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
460361	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
460362	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
460363	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
460364	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
460365	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
460366	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
460367	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
460368	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	5L	
460369	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	16L	
460370	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
460371	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
460372	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
460373	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
460374	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
460375	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	160567	
460376	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
460377	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
460378	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
460379	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
460380	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
460381	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
460382	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
460383	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	9 Month Operations	10	
460384	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
460385	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC Operations Since Last Insp	331	
460386	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
460387	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
460388	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC Min Tap Position	10L	
460389	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC Max Tap Position	2L	
460390	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC Current Tap Position	6L	
460391	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
460392	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC As Left Counter	30744	
460393	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC As Found Counter	30744	
460394	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Unknown Operations	0	
460395	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Tank Paint Condition	Good	
460396	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Switching Operations	0	
460397	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
460398	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Operations This Read Vac	0	
460399	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Operations Counter AL	619	
460400	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Operations Counter AF	619	
460401	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Moisture and Leak Free?	y	
460402	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Maintenance Operations	0	
460403	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Grounds in Place?	y	
460404	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	General Comments		
460405	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	General Comments		
460406	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
460407	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
460408	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	General Comments		
460409	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
460410	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
460411	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
460412	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Tank Leaks	None	
460413	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
460414	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
460415	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Regulator As Left Counter	44928	
460416	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
460417	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
460418	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
460419	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
460420	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
460421	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
460422	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
460423	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
460424	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	General Comments		
460425	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
460426	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
460427	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
460428	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
460429	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
460430	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
460431	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
460432	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
460433	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
460434	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
460435	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
460436	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
460437	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
460438	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
460439	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
460440	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
460441	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Bushings Connection/Risers	Good	
460442	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Bushing Condition	Good	
460443	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Amps C Ø	220.0	
460444	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Amps B Ø	100.0	
460445	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Amps A Ø	160.0	
460446	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
460447	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
460448	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
460449	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Totalizer Meter Reading	1.1250	
460450	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
460451	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
460452	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
460453	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
460454	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
460455	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
460456	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
460457	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
460458	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Oil Temp Present	48	°C
460459	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Oil Temp Max	65	°C
460460	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
460461	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
460462	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
460463	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
460464	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
460465	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
460466	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
460467	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
460468	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
460469	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
460470	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
460471	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
460472	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
460473	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	9 Month Operations	7	
460474	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Follow-up Action Required?	n	
460475	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Follow-up Action Required?	n	
460476	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	5	
460477	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
460478	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
460479	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
460480	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
460481	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
460482	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
460483	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
460484	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
460485	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
460486	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
460487	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
460488	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
460489	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
460490	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
460491	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
460492	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
460493	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
460494	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
460495	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
460496	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Tank Leaks	None	
460497	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
460498	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Operations Counter	34	
460499	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
460500	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
460501	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
460502	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
460503	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
460504	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
460505	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
460506	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
460507	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
460508	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
460509	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
460510	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
460511	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
460512	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
460513	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
460514	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
460515	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
460516	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
460517	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Amps C Ø	40.0	
460518	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Amps B Ø	40.0	
460519	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Amps A Ø	44.0	
460520	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
460521	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
460522	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
460523	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
460524	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	200.0	
460525	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Operations Ground	0	
460526	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Operations C Ø	0	
460527	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Operations B Ø	0	
460528	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
460529	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	200.0	
460530	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	200.0	
460531	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
460532	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
460533	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
460534	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Foundation Condition	Good	
460535	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Follow-up Action Required?	n	
460536	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Follow-up Action Required?	n	
460537	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Operations Ground	0	
460538	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Operations C Ø	0	
460539	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	General Comments		
460540	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Operations B Ø	0	
460541	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Operations A Ø	0	
460542	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
460543	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
460544	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
460545	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	General Comments		
460546	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
460547	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	Follow-up Action Required?	n	
460548	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
460549	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Equipment Properly Labeled?	y	
460550	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Cabinet Paint Condition	Good	
460551	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
460552	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
460553	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Unknown Operations	0	
460554	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Tank Paint Condition	Good	
460555	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
460556	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Bushings Connection/Risers	Good	
460557	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Bushing Condition	Good	
460558	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Amps C Ø	120.0	
460559	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Amps B Ø	120.0	
460560	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
460561	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
460562	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
460563	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	General Comments		
460564	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
460565	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
460566	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
460567	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	164	
460568	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
460569	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
460570	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Vegetation	None	
460571	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	General Comments		
460572	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
460573	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
460574	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
460575	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
460576	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
460577	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
460578	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Clear of Trash?	y	
460579	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
460580	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Ambient Temp	59	°F
460581	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	271	
460582	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Switching Operations	9	
460583	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Operations This Read Vac	9	
460584	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Operations Counter AL	187	
460585	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Operations Counter AF	187	
460586	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Amps C Ø	22.0	
460587	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Moisture and Leak Free?	y	
460588	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Maintenance Operations	0	
460589	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Grounds in Place?	y	
460590	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Amps B Ø	23.0	
460591	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Amps A Ø	25.0	
460592	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	218	
460593	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	General Comments		
460594	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	General Comments		
460595	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Foundation Condition	Good	
460596	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
460597	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Amps A Ø	120.0	
460598	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	General Comments		
460599	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	General Comments		
460600	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Foundation Condition	Good	
460601	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Follow-up Action Required?	n	
460602	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Follow-up Action Required?	n	
460603	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
460604	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
460605	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
460606	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
460607	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	General Comments		
460608	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	General Comments		
460609	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
460610	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	LTC Totalizer Reading	37670400.00	kw
460611	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
460612	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
460613	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Oil Temp Max	33	°C
460614	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Oil Temp Present	33	°C
460615	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
460616	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Operations Ground	0	
460617	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Operations C Ø	0	
460618	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
460619	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
460620	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
460621	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
460622	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Heaters (All) Functioning?	y	
460623	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Moisture and Leak Free?	y	
460624	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
460625	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Tank Paint Condition	Good	
460626	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
460627	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
460628	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
460629	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
460630	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
460631	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
460632	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
460633	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
460634	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
460635	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
460636	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
460637	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
460638	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	17553	
460639	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Operations B Ø	0	
460640	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
460641	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
460642	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
460643	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
460644	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
460645	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
460646	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
460647	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
460648	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
460649	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
460650	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
460651	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
460652	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	General Comments		
460653	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
460654	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
460655	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Foundation Condition	Good	
460656	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
460657	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
460658	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
460659	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
460660	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
460661	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
460662	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
460663	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
460664	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
460665	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
460666	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
460667	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
460668	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
460669	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
460670	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
460671	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
460672	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
460673	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
460674	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
460675	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
460676	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
460677	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
460678	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Cabinet Paint Condition	Good	
460679	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Equipment Properly Labeled?	y	
460680	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Follow-up Action Required?	n	
460681	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Foundation Condition	Good	
460682	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
460683	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
460684	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
460685	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
460686	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
460687	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
460688	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
460689	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
460690	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
460691	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
460692	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
460693	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
460694	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
460695	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
460696	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
460697	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Unknown Operations	0	
460698	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Tank Paint Condition	Good	
460699	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Switching Operations	6	
460700	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
460701	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
460702	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
460703	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
460704	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
460705	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
460706	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
460707	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Operations This Read Vac	6	
460708	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Operations Counter AL	347	
460709	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Operations Counter AF	347	
460710	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Moisture and Leak Free?	y	
460711	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Maintenance Operations	0	
460712	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Heaters (All) Functioning?	y	
460713	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Grounds in Place?	y	
460714	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
460715	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
460716	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
460717	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	General Comments		
460718	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
460719	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
460720	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
460721	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Follow-up Action Required?	n	
460722	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	General Comments		
460723	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Grounds in Place?	y	
460724	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
460725	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
460726	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
460727	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
460728	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Tank Leaks	None	
460729	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
460730	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
460731	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
460732	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
460733	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
460734	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
460735	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
460736	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Clear of Trash?	y	
460737	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Switching Operations	0	
460738	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Operations This Read Vac	0	
460739	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Operations Counter AL	375	
460740	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Operations Counter AF	375	
460741	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Maintenance Operations	0	
460742	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	General Comments		
460743	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Patrol Inspection	General Comments		
460744	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Follow-up Action Required?	n	
460745	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Patrol Inspection	Follow-up Action Required?	n	
460746	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Operations Ground	0	
460747	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Operations C Ø	0	
460748	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Operations B Ø	0	
460749	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Operations A Ø	0	
460750	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
460751	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
460752	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
460753	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Patrol Inspection	Equipment Properly Labeled?	y	
460754	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Amps C Ø	60.0	
460755	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Amps B Ø	60.0	
460756	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Amps A Ø	60.0	
460757	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
460758	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
460759	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
460760	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	9 Month Operations	2	
460761	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
460762	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
460763	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
460764	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
460765	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
460766	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Totalizer Meter Reading	2616.0000	
460767	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Winding Temp Max	33	°C
460768	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Winding Temp Present	33	°C
460769	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
460770	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
460771	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
460772	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
460773	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
460774	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
460775	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
460776	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
460777	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
460778	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
460779	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
460780	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
460781	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
460782	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
460783	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
460784	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
460785	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
460786	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
460787	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
460788	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
460789	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
460790	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Operations A Ø	0	
460791	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
460792	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
460793	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
460794	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Equipment Properly Labeled?	y	
460795	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Cabinet Paint Condition	Good	
460796	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
460797	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
460798	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
460799	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
460800	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
460801	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
460802	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2604	
460803	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
460804	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
460805	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
460806	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
460807	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
460808	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
460809	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
460810	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
460811	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
460812	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
460813	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
460814	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
460815	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	624.96	kw
460816	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
460817	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
460818	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	General Comments		
460819	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	General Comments		
460820	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
460821	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
460822	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
460823	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
460824	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
460825	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
460826	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
460827	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
460828	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
460829	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
460830	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
460831	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
460832	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
460833	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
460834	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	General Comments		
460835	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
460836	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
460837	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
460838	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Vegetation	None	
460839	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
460840	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
460841	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	General Comments		
460842	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Unknown Operations	0	
460843	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
460844	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
460845	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
460846	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
460847	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
460848	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
460849	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
460850	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
460851	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
460852	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
460853	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
460854	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Regulator As Left Counter	56518	
460855	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
460856	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
460857	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
460858	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	6000	
460859	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
460860	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	4	
460861	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	4	
460862	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Totalizer Meter Reading	.0948	
460863	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	General Comments		
460864	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	525	
460865	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	525	
460866	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
460867	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
460868	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
460869	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
460870	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
460871	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
460872	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
460873	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
460874	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
460875	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
460876	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
460877	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
460878	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	X3 Winding Temp Max	51	°C
460879	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	X2 Winding Temp Max	51	°C
460880	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	X1 Winding Temp Max	51	°C
460881	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
460882	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
460883	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Winding Temp Max	51	°C
460884	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
460885	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
460886	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
460887	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
460888	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
460889	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	All Connections OK?	y	
460890	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	Current Tap Position	7L	
460891	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	FCP Block Raise AF	0.0	VAC
460892	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	FCP Block Raise AL	0.0	VAC
460893	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	FCP Lower AF	0.0	VAC
460894	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	FCP Lower AL	0.0	VAC
460895	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	Follow-up Action Required?	n	
460896	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	General Comments		
460897	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	Max Tap Position	1R	
460898	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	Min Tap Position	10L	
460899	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
460900	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
460901	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
460902	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	VRR Base Voltage AF	121.0	VAC
460903	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	VRR Base Voltage AL	121.0	VAC
460904	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	VRR Counter AF	74804	
460905	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	VRR Counter AL	74804	
460906	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
460907	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
460908	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	VRR Time Delay	3	Seconds
460909	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	VRR X Compensation AF	0	Position
460910	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	VRR X Compensation AL	0	Position
460911	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
460912	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
460913	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
460914	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
460915	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
460916	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
460917	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
460918	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
460919	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
460920	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
460921	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	General Comments		
460922	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
460923	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Max Tap Position	8R	
460924	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
460925	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
460926	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC As Found Counter	61796	
460927	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC As Left Counter	61796	
460928	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
460929	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
460930	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3L	
460931	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	14L	
460932	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
460933	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
460934	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
460935	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
460936	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
460937	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
460938	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
460939	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
460940	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
460941	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
460942	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
460943	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
460944	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
460945	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
460946	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1035	
460947	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
460948	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
460949	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
460950	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
460951	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
460952	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
460953	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	General Comments		
460954	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
460955	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC As Found Counter	226862	
460956	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC As Left Counter	226862	
460957	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
460958	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Current Tap Position	11L	
460959	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Max Tap Position	7L	
460960	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Min Tap Position	16L	
460961	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
460962	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
460963	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
460964	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
460965	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	General Comments		
460966	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
460967	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
460968	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
460969	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
460970	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
460971	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
460972	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
460973	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
460974	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
460975	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	723	
460976	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
460977	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	568.80	kw
460978	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
460979	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
460980	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Oil Temp Max	50	°C
460981	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Oil Temp Present	40	°C
460982	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
460983	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
460984	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
460985	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
460986	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
460987	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
460988	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
460989	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
460990	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
460991	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
460992	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
460993	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
460994	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
460995	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
460996	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
460997	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
460998	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
460999	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
461000	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
461001	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
461002	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
461003	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
461004	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
461005	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
461006	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
461007	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
461008	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
461009	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
461010	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
461011	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
461012	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	9 Months Operations	2	
461013	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
461014	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
461015	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
461016	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Amps A Ø	110.0	
461017	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Amps B Ø	50.0	
461018	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Amps C Ø	25.0	
461019	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
461020	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
461021	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
461022	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
461023	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Operations A Ø	0	
461024	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Operations B Ø	0	
461025	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Operations C Ø	0	
461026	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
461027	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Patrol Inspection	Follow-up Action Required?	n	
461028	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Follow-up Action Required?	n	
461029	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Patrol Inspection	General Comments		
461030	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	General Comments		
461031	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Maintenance Operations	0	
461032	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Operations Counter AF	861	
461033	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Operations Counter AL	861	
461034	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Operations This Read AM	0	
461035	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Switching Operations	0	
461036	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Unknown Operations	0	
461037	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
461038	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
461039	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
461040	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
461041	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
461042	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
461043	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Follow-up Action Required?	n	
461044	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
461045	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
461046	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
461047	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
461048	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
461049	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
461050	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
461051	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
461052	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
461053	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
461054	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	360.0	
461055	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	340.0	
461056	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	320.0	
461057	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
461058	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
461059	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
461060	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
461061	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
461062	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
461063	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
461064	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
461065	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
461066	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
461067	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
461068	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
461069	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
461070	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
461071	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.6	volts
461072	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Regulator As Left Counter	34710	
461073	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
461074	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
461075	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Tank Leaks	None	
461076	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
461077	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
461078	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	General Comments	Repaired auto raise.	
461079	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Totalizer Meter Reading	.5808	
461080	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
461081	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
461082	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
461083	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Clear of Trash?	y	
461084	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
461085	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
461086	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	Needs Desiccant Changed	
461087	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
461088	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
461089	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
461090	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
461091	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
461092	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
461093	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
461094	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
461095	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Clear of Trash?	y	
461096	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
461097	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
461098	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
461099	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
461100	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
461101	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
461102	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	General Comments	repaired berm as well as i could...needs more gravel	
461103	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Exp Boom Corrected	
461104	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Vegetation	None	
461105	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
461106	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
461107	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
461108	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
461109	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
461110	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
461111	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
461112	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
461113	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
461114	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
461115	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
461116	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
461117	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
461118	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
461119	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
461120	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
461121	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
461122	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
461123	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
461124	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
461125	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
461126	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
461127	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3624	
461128	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
461129	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
461130	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
461131	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
461132	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
461133	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
461134	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
461135	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
461136	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Oil Temp Present	5	°C
461137	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Oil Temp Max	353	°C
461138	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
461139	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
461140	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC Min Tap Position	10L	
461141	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	36	°C
461142	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	35	°C
461143	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC Operations Since Last Insp	494	
461144	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	5.0	
461145	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	5.0	
461146	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	5.0	
461147	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
461148	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
461149	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
461150	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
461151	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
461152	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
461153	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
461154	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	Follow-up Action Required?	n	
461155	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
461156	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
461157	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	80714	
461158	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
461159	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
461160	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
461161	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	276.48	kw
461162	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	200.00	
461163	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
461164	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
461165	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	General Comments		
461166	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	General Comments		
461167	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
461168	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
461169	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
461170	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
461171	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
461172	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
461173	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
461174	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
461175	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
461176	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
461177	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	General Comments		
461178	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC As Found Counter	16023	
461179	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC As Left Counter	16023	
461180	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
461181	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
461182	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
461183	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
461184	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
461185	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC Current Tap Position	5L	
461186	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
461187	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
461188	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
461189	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Broom on Site?	y	
461190	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
461191	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
461192	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC Max Tap Position	3R	
461193	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC Min Tap Position	11L	
461194	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
461195	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
461196	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
461197	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	40	°C
461198	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC Operations Since Last Insp	321	
461199	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
461200	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
461201	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
461202	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
461203	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
461204	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
461205	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
461206	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
461207	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
461208	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
461209	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
461210	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
461211	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
461212	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
461213	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	5L	
461214	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
461215	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
461216	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	9R	
461217	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
461218	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	General Comments		
461219	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
461220	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
461221	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	Follow-up Action Required?	n	
461222	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
461223	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	General Comments		
461224	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	General Comments		
461225	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC As Found Counter	15824	
461226	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC As Left Counter	15824	
461227	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
461228	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC Current Tap Position	7L	
461229	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC Max Tap Position	5L	
461230	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC Min Tap Position	10L	
461231	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	32	°C
461232	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	32	°C
461233	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC Operations Since Last Insp	490	
461234	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
461235	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
461236	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
461237	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	269828	
461238	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
461239	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
461240	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
461241	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
461242	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
461243	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
461244	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
461245	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
461246	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	8L	
461247	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	6R	
461248	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
461249	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
461250	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
461251	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
461252	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
461253	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
461254	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	3L	
461255	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
461256	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
461257	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
461258	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
461259	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
461260	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
461261	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
461262	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
461263	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
461264	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
461265	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
461266	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
461267	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
461268	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
461269	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
461270	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
461271	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
461272	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Oil Temp Present	28	°C
461273	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
461274	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	Follow-up Action Required?	n	
461275	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
461276	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	General Comments		
461277	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	General Comments		
461278	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC As Found Counter	16767	
461279	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC As Left Counter	16767	
461280	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
461281	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC Current Tap Position	8L	
461282	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC Max Tap Position	6L	
461283	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
461284	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	General Comments		
461285	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
461286	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
461287	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
461288	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
461289	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
461290	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	2302	
461291	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	2302	
461292	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	4	
461293	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
461294	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
461295	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
461296	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	9 Month Operations	6	
461297	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
461298	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
461299	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
461300	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
461301	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
461302	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
461303	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
461304	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
461305	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
461306	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
461307	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	General Comments	No 911	
461308	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
461309	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Ambient Temp	51	°F
461310	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
461311	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Clear of Trash?	y	
461312	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
461313	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
461314	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
461315	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
461316	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
461317	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
461318	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	General Comments		
461319	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
461320	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Vegetation	None	
461321	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
461322	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
461323	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
461324	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Amps A Ø	25.0	
461325	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Amps B Ø	30.0	
461326	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Amps C Ø	30.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
461327	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Bushing Condition	Good	
461328	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Bushings Connection/Risers	Good	
461329	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
461330	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
461331	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
461332	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
461333	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
461334	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
461335	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
461336	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
461337	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
461338	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
461339	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
461340	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
461341	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
461342	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
461343	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	General Comments		
461344	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
461345	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
461346	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Tank Leaks	None	
461347	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
461348	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Regulator As Left Counter	93512	
461349	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
461350	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
461351	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
461352	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	General Comments		
461353	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
461354	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
461355	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1609	
461356	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1609	
461357	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	6	
461358	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
461359	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
461360	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
461361	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
461362	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	General Comments		
461363	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
461364	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
461365	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
461366	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
461367	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
461368	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
461369	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
461370	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
461371	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
461372	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
461373	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
461374	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
461375	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
461376	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
461377	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	170.0	
461378	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	170.0	
461379	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	170.0	
461380	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
461381	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
461382	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Evidence of Insects	None	
461383	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
461384	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
461385	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Floor Swept?	y	
461386	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
461387	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
461388	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	General Comments		
461389	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
461390	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
461391	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Panels Dusted?	y	
461392	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
461393	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
461394	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
461395	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Trash Emptied?	y	
461396	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
461397	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
461398	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
461399	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
461400	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
461401	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
461402	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
461403	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
461404	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
461405	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
461406	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
461407	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
461408	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
461409	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
461410	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
461411	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
461412	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
461413	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	General Comments		
461414	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	General Comments		
461415	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
461416	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
461417	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
461418	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
461419	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
461420	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
461421	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
461422	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
461423	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
461424	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
461425	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
461426	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
461427	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
461428	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
461429	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Gauge(s) Condition	Good	
461430	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Foundation Condition	Good	
461431	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Follow-up Action Required?	n	
461432	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
461433	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
461434	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Current Tap Position	7L	
461435	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
461436	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
461437	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
461438	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
461439	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
461440	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
461441	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
461442	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Bushing Condition	Good	
461443	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
461444	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
461445	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Foundation Condition	Good	
461446	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
461447	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
461448	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
461449	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
461450	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
461451	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
461452	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Patrol Inspection	General Comments		
461453	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Follow-up Action Required?	n	
461454	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Patrol Inspection	Follow-up Action Required?	n	
461455	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Operations Ground	0	
461456	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Operations C Ø	0	
461457	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Operations B Ø	0	
461458	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Operations A Ø	0	
461459	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
461460	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
461461	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
461462	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
461463	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Oil Temp Present	37	°C
461464	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Oil Temp Max	47	°C
461465	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
461466	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
461467	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
461468	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	General Comments		
461469	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	General Comments		
461470	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
461471	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	LTC Totalizer Reading	6921.60	kw
461472	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
461473	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	General Comments		
461474	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
461475	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
461476	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
461477	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
461478	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
461479	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
461480	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
461481	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
461482	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
461483	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
461484	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
461485	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
461486	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
461487	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
461488	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
461489	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
461490	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Oil Temp Max	50	°C
461491	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Oil Temp Present	40	°C
461492	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
461493	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
461494	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
461495	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
461496	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
461497	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
461498	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
461499	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
461500	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
461501	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Top Oil Temperature Max	40	°C
461502	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
461503	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Regulator As Left Counter	14662	
461504	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Top Oil Temperature Present	35	°C
461505	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
461506	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Amps A Ø	4.0	
461507	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Amps B Ø	4.0	
461508	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Amps C Ø	4.0	
461509	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
461510	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
461511	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
461512	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
461513	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
461514	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
461515	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
461516	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
461517	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
461518	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Reg Output Voltage Level	121.0	volts
461519	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
461520	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
461521	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
461522	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
461523	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
461524	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
461525	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
461526	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
461527	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
461528	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
461529	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	General Comments		
461530	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
461531	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
461532	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
461533	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Operations Counter	1854	
461534	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
461535	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Tank Leaks	None	
461536	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
461537	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	35	°C
461538	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	40	°C
461539	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	35	°C
461540	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
461541	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
461542	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	General Comments		
461543	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	40	°C
461544	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
461545	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
461546	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Reg Operation Checked?	y	
461547	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Reg Oil Level	Good	
461548	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
461549	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	40	°C
461550	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
461551	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
461552	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
461553	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
461554	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
461555	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
461556	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
461557	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Moisture and Leak Free?	y	
461558	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Min Tap Position	5L	
461559	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Max Tap Position	8L	
461560	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
461561	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
461562	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
461563	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
461564	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
461565	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Grounds in Place?	y	
461566	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	General Comments		
461567	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
461568	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	General Comments		
461569	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
461570	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
461571	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
461572	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
461573	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
461574	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
461575	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
461576	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
461577	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
461578	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
461579	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
461580	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
461581	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
461582	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
461583	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
461584	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	General Comments		
461585	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
461586	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
461587	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
461588	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
461589	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
461590	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
461591	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
461592	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	General Comments		
461593	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
461594	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
461595	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
461596	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	General Comments		
461597	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
461598	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
461599	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
461600	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
461601	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
461602	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
461603	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
461604	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.5	volts
461605	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Regulator As Left Counter	77369	
461606	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
461607	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
461608	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Tank Leaks	None	
461609	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
461610	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Winding Temp Max	40	°C
461611	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
461612	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Winding Temp Present	40	°C
461613	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
461614	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
461615	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
461616	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
461617	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
461618	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
461619	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
461620	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
461621	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
461622	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Foundation Condition	Good	
461623	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
461624	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
461625	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
461626	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
461627	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	General Comments		
461628	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
461629	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
461630	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
461631	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
461632	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
461633	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
461634	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
461635	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
461636	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
461637	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
461638	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
461639	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
461640	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
461641	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
461642	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
461643	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	General Comments		
461644	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
461645	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC As Found Counter	254705	
461646	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC As Left Counter	254705	
461647	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
461648	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
461649	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
461650	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
461651	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
461652	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Amps C Ø	0.0	
461653	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Amps B Ø	0.0	
461654	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Amps A Ø	0.0	
461655	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
461656	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
461657	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Bushing Condition	Good	
461658	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
461659	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1131	
461660	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
461661	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
461662	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
461663	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
461664	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	9 Months Operations	0	
461665	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Bushing Oil Level	Good	
461666	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Bushings Connection/Risers	Good	
461667	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
461668	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
461669	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
461670	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
461671	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Totalizer Meter Reading	.3432	
461672	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
461673	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Cabinet Paint Condition	Good	
461674	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
461675	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
461676	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
461677	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
461678	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
461679	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
461680	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
461681	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Equipment Properly Labeled?	y	
461682	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Totalizer Meter Reading	.7210	
461683	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Winding Temp Max	50	°C
461684	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Fault Operations	0	
461685	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Follow-up Action Required?	n	
461686	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Follow-up Action Required?	n	
461687	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Foundation Condition	Good	
461688	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Gauge(s) Condition	Good	
461689	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	General Comments		
461690	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	General Comments		
461691	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Grounds in Place?	y	
461692	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Heaters (All) Functioning?	y	
461693	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Hydraulic Leaks	None	
461694	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Hydraulic Oil Levels OK?	y	
461695	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Hydraulic Pressure Acceptable?	y	
461696	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Maintenance Operations	0	
461697	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Winding Temp Present	40	°C
461698	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
461699	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
461700	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Moisture and Leak Free?	y	
461701	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Number of Ops last 9 Months	1	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
461702	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Operations Counter AF	21	
461703	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Operations Counter AL	21	
461704	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Operations This Read Oil	0	
461705	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
461706	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
461707	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
461708	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
461709	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
461710	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
461711	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
461712	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
461713	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
461714	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
461715	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
461716	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
461717	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
461718	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
461719	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
461720	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
461721	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
461722	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
461723	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
461724	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
461725	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
461726	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
461727	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
461728	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
461729	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
461730	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
461731	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
461732	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
461733	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
461734	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
461735	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
461736	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Cabinet Paint Condition	Good	
461737	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Equipment Properly Labeled?	y	
461738	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
461739	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
461740	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
461741	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Operations A Ø	0	
461742	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Operations B Ø	0	
461743	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Operations C Ø	0	
461744	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Operations Ground	0	
461745	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Follow-up Action Required?	n	
461746	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Follow-up Action Required?	n	
461747	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Foundation Condition	Good	
461748	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	General Comments		
461749	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	General Comments		
461750	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Grounds in Place?	y	
461751	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
461752	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	General Comments		
461753	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
461754	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
461755	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
461756	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
461757	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
461758	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
461759	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
461760	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
461761	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
461762	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
461763	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	General Comments		
461764	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
461765	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Max Tap Position	7L	
461766	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
461767	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
461768	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
461769	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
461770	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
461771	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
461772	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	General Comments		
461773	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
461774	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	16	
461775	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
461776	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
461777	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Min Tap Position	6R	
461778	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
461779	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
461780	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
461781	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
461782	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
461783	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
461784	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
461785	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
461786	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
461787	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
461788	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	General Comments		
461789	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	General Comments		
461790	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
461791	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
461792	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
461793	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
461794	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
461795	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
461796	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1583.28	kw
461797	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
461798	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
461799	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
461800	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
461801	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
461802	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
461803	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
461804	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
461805	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
461806	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
461807	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
461808	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Top Oil Temperature Max	40	°C
461809	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Top Oil Temperature Present	40	°C
461810	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
461811	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4398	
461812	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Winding Temp Max	38	°C
461813	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Winding Temp Present	33	°C
461814	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
461815	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
461816	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
461817	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	89	
461818	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
461819	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
461820	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
461821	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
461822	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
461823	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
461824	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
461825	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
461826	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
461827	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
461828	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	General Comments		
461829	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
461830	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
461831	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Foundation Condition	Good	
461832	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
461833	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
461834	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
461835	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
461836	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
461837	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Vegetation	None	
461838	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
461839	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
461840	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
461841	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
461842	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
461843	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
461844	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
461845	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3479.04	kw
461846	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
461847	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
461848	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
461849	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
461850	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	89	
461851	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
461852	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	General Comments		
461853	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	General Comments		
461854	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
461855	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
461856	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
461857	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
461858	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
461859	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
461860	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
461861	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
461862	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
461863	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
461864	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
461865	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
461866	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	199	
461867	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
461868	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
461869	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	445	
461870	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
461871	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
461872	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
461873	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	General Comments		
461874	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
461875	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Unknown Operations	0	
461876	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Switching Operations	0	
461877	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Operations This Read AM	0	
461878	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
461879	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
461880	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
461881	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
461882	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
461883	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
461884	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
461885	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
461886	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
461887	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
461888	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
461889	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
461890	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
461891	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	General Comments		
461892	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
461893	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
461894	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
461895	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
461896	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
461897	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
461898	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
461899	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
461900	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
461901	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
461902	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
461903	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
461904	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
461905	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
461906	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
461907	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Follow-up Action Required?	n	
461908	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
461909	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
461910	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	General Comments		
461911	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Tank Paint Condition	Good	
461912	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Tank Leaks	None	
461913	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Surge Arrester Condition	Good	
461914	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Operations Counter AL	397	
461915	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Operations Counter AF	397	
461916	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Maintenance Operations	0	
461917	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	General Comments		
461918	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	General Comments		
461919	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
461920	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	LTC Totalizer Reading	8236.80	kw
461921	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
461922	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
461923	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
461924	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
461925	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
461926	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Regulator As Left Counter	36748	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
461927	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
461928	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
461929	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Tank Leaks	None	
461930	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
461931	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0384	
461932	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
461933	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
461934	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
461935	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
461936	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
461937	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
461938	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
461939	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
461940	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
461941	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
461942	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
461943	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
461944	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
461945	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
461946	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
461947	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Vegetation	None	
461948	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
461949	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	General Comments		
461950	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
461951	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
461952	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
461953	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
461954	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
461955	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
461956	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
461957	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
461958	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Heaters (All) Functioning?	y	
461959	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Maintenance Operations	0	
461960	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Moisture and Leak Free?	y	
461961	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Operations Counter AF	238	
461962	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Operations Counter AL	238	
461963	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Operations This Read Vac	5	
461964	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
461965	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Switching Operations	5	
461966	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
461967	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
461968	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
461969	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
461970	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
461971	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
461972	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
461973	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
461974	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
461975	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
461976	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Tank Paint Condition	Good	
461977	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Unknown Operations	0	
461978	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	General Comments		
461979	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
461980	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
461981	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
461982	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
461983	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
461984	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
461985	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	General Comments		
461986	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
461987	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
461988	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
461989	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
461990	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
461991	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
461992	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
461993	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
461994	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
461995	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	126	
461996	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
461997	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	1	
461998	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
461999	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
462000	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Equipment Properly Labeled?	y	
462001	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
462002	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
462003	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
462004	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
462005	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Bushings Connection/Risers	Good	
462006	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Bushing Condition	Good	
462007	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Amps C Ø	10.0	
462008	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
462009	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
462010	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
462011	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
462012	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
462013	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
462014	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
462015	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
462016	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	345	
462017	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
462018	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC Min Tap Position	14L	
462019	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC Max Tap Position	7L	
462020	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
462021	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Amps B Ø	10.0	
462022	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Amps A Ø	10.0	
462023	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
462024	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
462025	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
462026	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
462027	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	9 Month Operations	8	
462028	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC As Left Counter	15560	
462029	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC As Found Counter	15560	
462030	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
462031	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	General Comments		
462032	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
462033	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
462034	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
462035	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
462036	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Clear of Trash?	y	
462037	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
462038	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
462039	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
462040	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
462041	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
462042	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
462043	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
462044	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
462045	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
462046	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
462047	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
462048	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
462049	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
462050	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
462051	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
462052	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
462053	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
462054	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
462055	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
462056	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
462057	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	General Comments		
462058	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	General Comments		
462059	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
462060	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
462061	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
462062	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
462063	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
462064	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
462065	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	Oil Temp Max	50	°C
462066	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	Oil Temp Present	40	°C
462067	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
462068	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
462069	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Unknown Operations	0	
462070	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Tank Paint Condition	Good	
462071	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Switching Operations	0	
462072	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
462073	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Operations This Read Vac	0	
462074	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Operations Counter AL	240	
462075	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Operations Counter AF	240	
462076	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
462077	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Maintenance Operations	0	
462078	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Heaters (All) Functioning?	y	
462079	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Grounds in Place?	y	
462080	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	General Comments		
462081	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	General Comments		
462082	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Foundation Condition	Good	
462083	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Follow-up Action Required?	n	
462084	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Follow-up Action Required?	n	
462085	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Operations Ground	0	
462086	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Operations C Ø	0	
462087	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Operations B Ø	0	
462088	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Operations A Ø	0	
462089	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
462090	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
462091	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	216	
462092	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
462093	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
462094	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	180	
462095	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Amps C Ø	13.0	
462096	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Amps B Ø	12.0	
462097	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations B Ø	0	
462098	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
462099	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
462100	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
462101	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
462102	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
462103	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
462104	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
462105	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
462106	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
462107	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
462108	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
462109	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	General Comments		
462110	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
462111	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Foundation Condition	Good	
462112	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
462113	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
462114	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations C Ø	0	
462115	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations Ground	0	
462116	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	Follow-up Action Required?	n	
462117	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Follow-up Action Required?	n	
462118	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	General Comments		
462119	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	General Comments		
462120	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Maintenance Operations	0	
462121	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations Counter AF	181	
462122	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
462123	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
462124	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
462125	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
462126	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Amps A Ø	30.0	
462127	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	205	
462128	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations Counter AL	181	
462129	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations This Read Vac	0	
462130	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Switching Operations	0	
462131	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Unknown Operations	0	
462132	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	9 Month Operations	0	
462133	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
462134	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
462135	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
462136	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
462137	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
462138	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
462139	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
462140	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
462141	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
462142	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
462143	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
462144	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
462145	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
462146	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	General Comments		
462147	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
462148	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Vegetation	None	
462149	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
462150	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	9 Month Operations	6	
462151	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
462152	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
462153	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
462154	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps A Ø	350.0	
462155	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps B Ø	240.0	
462156	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps C Ø	300.0	
462157	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	Equipment Properly Labeled?	y	
462158	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
462159	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
462160	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
462161	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations A Ø	0	
462162	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
462163	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
462164	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
462165	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
462166	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
462167	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	General Comments		
462168	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
462169	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
462170	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
462171	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
462172	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
462173	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
462174	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
462175	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
462176	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
462177	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
462178	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
462179	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
462180	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	General Comments		
462181	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
462182	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
462183	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
462184	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	480.96	kw
462185	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
462186	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
462187	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
462188	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	General Comments		
462189	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	General Comments		
462190	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
462191	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
462192	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
462193	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
462194	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
462195	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
462196	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
462197	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
462198	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
462199	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
462200	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
462201	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
462202	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
462203	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
462204	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
462205	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
462206	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Ambient Temp	63	°F
462207	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
462208	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
462209	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
462210	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
462211	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
462212	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
462213	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Foundation Condition	Good	
462214	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
462215	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
462216	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	General Comments		
462217	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
462218	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Clear of Trash?	y	
462219	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
462220	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
462221	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
462222	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
462223	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
462224	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
462225	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	General Comments		
462226	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
462227	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
462228	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
462229	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
462230	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Ambient Temp	63	°F
462231	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Operations Counter AL	197	
462232	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Operations This Read Vac	0	
462233	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Switching Operations	0	
462234	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Unknown Operations	0	
462235	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	9 Month Operations	6	
462236	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
462237	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
462238	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
462239	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Amps A Ø	300.0	
462240	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Amps B Ø	370.0	
462241	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Amps C Ø	225.0	
462242	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	Equipment Properly Labeled?	y	
462243	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6012	
462244	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
462245	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
462246	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
462247	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
462248	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
462249	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
462250	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
462251	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
462252	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
462253	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
462254	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
462255	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
462256	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
462257	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
462258	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
462259	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
462260	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
462261	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	General Comments		
462262	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
462263	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
462264	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
462265	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
462266	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
462267	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
462268	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
462269	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
462270	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
462271	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
462272	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
462273	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
462274	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
462275	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
462276	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
462277	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
462278	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
462279	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Unknown Operations	0	
462280	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	9 Month Operations	0	
462281	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
462282	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
462283	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
462284	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Amps A Ø	270.0	
462285	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Amps B Ø	250.0	
462286	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Amps C Ø	250.0	
462287	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	Equipment Properly Labeled?	y	
462288	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
462289	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
462290	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
462291	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
462292	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
462293	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
462294	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
462295	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Operations A Ø	0	
462296	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Operations B Ø	0	
462297	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Operations C Ø	0	
462298	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Operations Ground	0	
462299	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	Follow-up Action Required?	n	
462300	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Follow-up Action Required?	n	
462301	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
462302	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	General Comments		
462303	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Maintenance Operations	0	
462304	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Operations Counter AF	319	
462305	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Operations Counter AL	319	
462306	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Operations This Read Vac	0	
462307	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Switching Operations	0	
462308	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Unknown Operations	0	
462309	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Unknown Operations	0	
462310	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Tank Paint Condition	Good	
462311	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Switching Operations	0	
462312	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
462313	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Operations This Read Vac	0	
462314	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Operations Counter AL	232	
462315	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Operations Counter AF	232	
462316	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
462317	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
462318	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
462319	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
462320	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Vegetation	None	
462321	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
462322	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
462323	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations A Ø	0	
462324	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations B Ø	0	
462325	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations C Ø	0	
462326	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations Ground	0	
462327	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	Follow-up Action Required?	n	
462328	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Follow-up Action Required?	n	
462329	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	General Comments		
462330	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	General Comments		
462331	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Maintenance Operations	0	
462332	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations Counter AF	204	
462333	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations Counter AL	204	
462334	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations This Read Vac	0	
462335	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Switching Operations	0	
462336	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
462337	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
462338	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
462339	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
462340	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
462341	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
462342	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
462343	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
462344	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
462345	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
462346	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
462347	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
462348	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
462349	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
462350	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
462351	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
462352	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
462353	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
462354	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
462355	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
462356	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
462357	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
462358	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
462359	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	General Comments		
462360	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
462361	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
462362	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
462363	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Unknown Operations	0	
462364	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
462365	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
462366	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
462367	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
462368	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
462369	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
462370	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
462371	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
462372	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
462373	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
462374	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	General Comments		
462375	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
462376	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
462377	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
462378	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
462379	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
462380	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
462381	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
462382	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
462383	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
462384	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Current Tap Position	13L	
462385	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
462386	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
462387	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
462388	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
462389	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	General Comments		
462390	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
462391	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Max Tap Position	9L	
462392	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
462393	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
462394	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
462395	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
462396	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
462397	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
462398	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Regulator As Left Counter	158141	
462399	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
462400	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
462401	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Tank Leaks	None	
462402	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
462403	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	General Comments		
462404	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
462405	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
462406	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Unknown Operations	0	
462407	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Switching Operations	0	
462408	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Operations This Read AM	4	
462409	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Operations Counter AL	820	
462410	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Operations Counter AF	820	
462411	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Maintenance Operations	0	
462412	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	General Comments	A/C Phase IOC	
462413	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Switching Operations	0	
462414	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Unknown Operations	0	
462415	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Moisture and Leak Free?	y	
462416	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Maintenance Operations	0	
462417	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Grounds in Place?	y	
462418	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	General Comments		
462419	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	General Comments		
462420	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Foundation Condition	Good	
462421	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Follow-up Action Required?	n	
462422	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Follow-up Action Required?	n	
462423	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
462424	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
462425	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
462426	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
462427	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
462428	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
462429	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
462430	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
462431	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Vegetation	None	
462432	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
462433	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
462434	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
462435	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
462436	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	General Comments		
462437	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
462438	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
462439	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
462440	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
462441	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
462442	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
462443	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Clear of Trash?	y	
462444	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
462445	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Ambient Temp	59	°F
462446	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
462447	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	General Comments		
462448	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
462449	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
462450	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
462451	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
462452	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
462453	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
462454	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
462455	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
462456	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
462457	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
462458	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
462459	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
462460	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	General Comments		
462461	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
462462	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
462463	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
462464	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
462465	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
462466	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
462467	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
462468	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
462469	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Regulator As Left Counter	301359	
462470	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
462471	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Tank Leaks	None	
462472	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
462473	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	9 Months Operations	1	
462474	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
462475	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
462476	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
462477	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Amps A Ø	450.0	
462478	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Amps B Ø	400.0	
462479	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Amps C Ø	450.0	
462480	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
462481	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
462482	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
462483	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
462484	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
462485	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
462486	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
462487	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
462488	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
462489	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
462490	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Patrol Inspection	General Comments		
462491	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	General Comments		
462492	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Maintenance Operations	0	
462493	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Operations Counter AF	54	
462494	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Operations Counter AL	54	
462495	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Operations This Read AM	0	
462496	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Switching Operations	0	
462497	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Unknown Operations	0	
462498	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
462499	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
462500	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
462501	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
462502	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
462503	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
462504	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2190	
462505	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Patrol Inspection	General Comments		
462506	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Follow-up Action Required?	n	
462507	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Patrol Inspection	Follow-up Action Required?	n	
462508	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Operations Ground	0	
462509	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Operations C Ø	2	
462510	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Operations B Ø	0	
462511	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Operations A Ø	2	
462512	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Adjusted Amps C Phase AM	22.36	
462513	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
462514	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Adjusted Amps A Phase AM	22.36	
462515	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
462516	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Amps C Ø	180.0	
462517	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Amps B Ø	100.0	
462518	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Amps A Ø	230.0	
462519	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
462520	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
462521	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
462522	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	9 Months Operations	7	
462523	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
462524	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
462525	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
462526	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
462527	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
462528	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
462529	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
462530	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	100.00	
462531	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	940.80	kw
462532	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
462533	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
462534	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
462535	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
462536	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
462537	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
462538	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
462539	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
462540	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	General Comments	Barbed wire is rusty, and trees are overhanging the fence	
462541	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
462542	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
462543	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
462544	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
462545	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
462546	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
462547	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
462548	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
462549	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
462550	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
462551	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	General Comments		
462552	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
462553	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Vegetation	None	
462554	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
462555	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	General Comments		
462556	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
462557	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
462558	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	9 Month Operations	6	
462559	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
462560	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
462561	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
462562	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Amps A Ø	230.0	
462563	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
462564	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
462565	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
462566	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
462567	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	General Comments		
462568	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
462569	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
462570	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
462571	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	172	
462572	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
462573	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
462574	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	191	
462575	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Amps C Ø	15.0	
462576	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Amps B Ø	20.0	
462577	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Amps A Ø	22.0	
462578	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Amps B Ø	190.0	
462579	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Amps C Ø	180.0	
462580	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Bushing Condition	Good	
462581	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Bushings Connection/Risers	Good	
462582	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
462583	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
462584	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
462585	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Cabinet Paint Condition	Good	
462586	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Equipment Properly Labeled?	y	
462587	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
462588	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
462589	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
462590	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Operations A Ø	0	
462591	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Operations B Ø	0	
462592	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Operations C Ø	0	
462593	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	182	
462594	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
462595	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
462596	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Operations Ground	0	
462597	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Amps A Ø	75.0	
462598	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Amps B Ø	100.0	
462599	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Amps C Ø	75.0	
462600	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	Equipment Properly Labeled?	y	
462601	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
462602	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
462603	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
462604	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
462605	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
462606	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
462607	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Clear of Trash?	y	
462608	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
462609	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
462610	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
462611	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
462612	4/12/2019 17:12	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
462613	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Operations A Ø	0	
462614	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Operations B Ø	0	
462615	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Operations C Ø	0	
462616	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
462617	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Vegetation	None	
462618	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
462619	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
462620	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
462621	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
462622	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	General Comments		
462623	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
462624	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
462625	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
462626	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
462627	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
462628	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
462629	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Clear of Trash?	y	
462630	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
462631	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
462632	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
462633	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
462634	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
462635	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
462636	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
462637	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
462638	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
462639	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
462640	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
462641	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Foundation Condition	Good	
462642	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
462643	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Follow-up Action Required?	n	
462644	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Follow-up Action Required?	n	
462645	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Foundation Condition	Good	
462646	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	General Comments		
462647	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	General Comments		
462648	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Grounds in Place?	y	
462649	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Heaters (All) Functioning?	y	
462650	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Maintenance Operations	0	
462651	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Moisture and Leak Free?	y	
462652	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Operations Counter AF	187	
462653	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Operations Counter AL	187	
462654	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Operations This Read Vac	0	
462655	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	General Comments		
462656	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	General Comments		
462657	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
462658	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Switching Operations	0	
462659	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Tank Paint Condition	Good	
462660	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Unknown Operations	0	
462661	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
462662	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
462663	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
462664	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
462665	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
462666	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
462667	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
462668	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
462669	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
462670	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
462671	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
462672	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
462673	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
462674	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
462675	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
462676	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
462677	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
462678	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
462679	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
462680	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
462681	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
462682	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
462683	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
462684	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
462685	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Maintenance Operations	0	
462686	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Operations Counter AF	156	
462687	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Operations Counter AL	156	
462688	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Operations This Read Vac	0	
462689	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Follow-up Action Required?	n	
462690	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Follow-up Action Required?	n	
462691	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Foundation Condition	Good	
462692	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	General Comments		
462693	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	General Comments		
462694	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Grounds in Place?	y	
462695	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Maintenance Operations	0	
462696	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Moisture and Leak Free?	y	
462697	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Operations Counter AF	177	
462698	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Operations Counter AL	177	
462699	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Operations This Read Vac	0	
462700	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Switching Operations	0	
462701	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Tank Paint Condition	Good	
462702	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Unknown Operations	0	
462703	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
462704	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
462705	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
462706	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
462707	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
462708	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
462709	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
462710	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
462711	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	9 Month Operations	5	
462712	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
462713	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Operations Ground	0	
462714	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	Follow-up Action Required?	n	
462715	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Follow-up Action Required?	n	
462716	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
462717	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
462718	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
462719	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Amps A Ø	90.0	
462720	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Amps B Ø	90.0	
462721	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Amps C Ø	90.0	
462722	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Bushing Condition	Good	
462723	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Bushings Connection/Risers	Good	
462724	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
462725	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
462726	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
462727	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Cabinet Paint Condition	Good	
462728	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Equipment Properly Labeled?	y	
462729	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
462730	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
462731	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
462732	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Operations A Ø	0	
462733	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Operations B Ø	0	
462734	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Operations C Ø	0	
462735	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Operations Ground	0	
462736	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
462737	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
462738	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
462739	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
462740	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
462741	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
462742	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
462743	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
462744	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
462745	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
462746	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
462747	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
462748	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
462749	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
462750	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
462751	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
462752	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	General Comments		
462753	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
462754	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
462755	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
462756	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
462757	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
462758	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
462759	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
462760	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
462761	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
462762	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
462763	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
462764	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	General Comments		
462765	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
462766	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
462767	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
462768	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
462769	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
462770	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
462771	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
462772	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
462773	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
462774	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
462775	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
462776	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
462777	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
462778	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
462779	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
462780	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
462781	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
462782	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
462783	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Regulator As Left Counter	34871	
462784	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
462785	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
462786	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Tank Leaks	None	
462787	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
462788	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
462789	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
462790	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
462791	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
462792	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
462793	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	General Comments		
462794	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Readings	General Comments		
462795	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
462796	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
462797	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
462798	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
462799	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
462800	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
462801	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Readings	Oil Temp Max	50	°C
462802	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Readings	Oil Temp Present	40	°C
462803	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
462804	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
462805	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
462806	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
462807	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
462808	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
462809	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
462810	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
462811	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
462812	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
462813	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Foundation Condition	Good	
462814	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
462815	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
462816	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
462817	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
462818	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
462819	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
462820	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
462821	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	General Comments	B phase Arrester blown 1709	
462822	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
462823	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
462824	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
462825	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
462826	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
462827	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
462828	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
462829	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
462830	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
462831	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Amps A Ø	600.0	
462832	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Amps B Ø	550.0	
462833	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Amps C Ø	570.0	
462834	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Bushing Condition	Good	
462835	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
462836	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
462837	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
462838	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
462839	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
462840	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
462841	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
462842	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
462843	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
462844	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Operations A Ø	0	
462845	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Operations B Ø	0	
462846	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Operations C Ø	0	
462847	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Operations Ground	0	
462848	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Follow-up Action Required?	n	
462849	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	VRR Time Delay	40	Seconds
462850	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
462851	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
462852	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
462853	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	LTC Operation Checked?	n	
462854	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	General Comments		
462855	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	Follow-up Action Required?	n	
462856	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4170	
462857	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	All Connections OK?	y	
462858	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	9 Month Operations	3	
462859	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
462860	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
462861	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
462862	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Amps A Ø	30.0	
462863	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Amps B Ø	26.0	
462864	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Amps C Ø	30.0	
462865	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Bushing Condition	Good	
462866	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Bushings Connection/Risers	Good	
462867	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
462868	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
462869	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
462870	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Cabinet Paint Condition	Good	
462871	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Equipment Properly Labeled?	y	
462872	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
462873	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
462874	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
462875	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
462876	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
462877	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
462878	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
462879	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
462880	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
462881	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	Oil Temp Present	50	°C
462882	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
462883	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
462884	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
462885	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
462886	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
462887	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
462888	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	General Comments		
462889	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	General Comments		
462890	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
462891	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
462892	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
462893	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
462894	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5639.04	kw
462895	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
462896	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
462897	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
462898	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
462899	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
462900	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
462901	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
462902	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
462903	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
462904	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
462905	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
462906	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
462907	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
462908	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
462909	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
462910	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
462911	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	50	°C
462912	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	45	°C
462913	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	52	°C
462914	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
462915	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	50	°C
462916	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
462917	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
462918	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5874	
462919	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	9 Month Operations	3	
462920	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
462921	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	General Comments		
462922	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
462923	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
462924	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
462925	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
462926	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
462927	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
462928	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
462929	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
462930	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
462931	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
462932	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
462933	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
462934	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
462935	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Switching Operations	0	
462936	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Tank Paint Condition	Good	
462937	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Unknown Operations	0	
462938	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
462939	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
462940	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
462941	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
462942	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
462943	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
462944	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
462945	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	General Comments		
462946	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	General Comments		
462947	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
462948	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
462949	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
462950	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
462951	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	552.48	kw
462952	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	207.50	
462953	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
462954	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
462955	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
462956	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
462957	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
462958	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
462959	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
462960	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
462961	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
462962	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
462963	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
462964	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6906	
462965	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
462966	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
462967	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
462968	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
462969	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
462970	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
462971	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
462972	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	3L	
462973	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	5R	
462974	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	8L	
462975	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
462976	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
462977	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
462978	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
462979	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
462980	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
462981	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
462982	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	133366	
462983	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
462984	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
462985	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
462986	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
462987	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
462988	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
462989	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
462990	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
462991	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
462992	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
462993	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
462994	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	General Comments		
462995	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	General Comments		
462996	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Grounds in Place?	y	
462997	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Heaters (All) Functioning?	y	
462998	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Maintenance Operations	0	
462999	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Moisture and Leak Free?	y	
463000	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Operations Counter AF	123	
463001	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Operations Counter AL	123	
463002	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Operations This Read Vac	0	
463003	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
463004	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
463005	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
463006	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
463007	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
463008	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
463009	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
463010	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Foundation Condition	Good	
463011	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
463012	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
463013	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
463014	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
463015	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
463016	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
463017	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
463018	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
463019	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
463020	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
463021	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Tank Leaks	None	
463022	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
463023	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Operations Counter	1421	
463024	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
463025	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
463026	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	General Comments		
463027	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
463028	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
463029	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
463030	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
463031	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
463032	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
463033	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
463034	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
463035	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
463036	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
463037	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
463038	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
463039	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
463040	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
463041	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
463042	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
463043	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
463044	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
463045	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
463046	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
463047	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	General Comments		
463048	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
463049	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Amps C Ø	200.0	
463050	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Amps B Ø	240.0	
463051	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Amps A Ø	240.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
463052	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
463053	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
463054	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
463055	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
463056	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
463057	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
463058	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
463059	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
463060	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
463061	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
463062	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
463063	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
463064	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
463065	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
463066	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
463067	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
463068	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
463069	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	General Comments		
463070	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
463071	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
463072	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
463073	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
463074	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
463075	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
463076	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
463077	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
463078	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
463079	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
463080	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Tank Leaks	None	
463081	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
463082	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
463083	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
463084	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
463085	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
463086	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
463087	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
463088	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	General Comments		
463089	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
463090	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
463091	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
463092	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
463093	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
463094	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
463095	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
463096	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
463097	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
463098	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
463099	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
463100	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
463101	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
463102	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
463103	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
463104	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
463105	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
463106	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
463107	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
463108	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
463109	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Totalizer Meter Reading	.5202	
463110	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
463111	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
463112	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Amps B Ø	373.0	
463113	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Amps A Ø	383.0	
463114	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
463115	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
463116	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
463117	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	9 Month Operations	1	
463118	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
463119	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
463120	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
463121	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Readings	General Comments		
463122	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
463123	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
463124	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
463125	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
463126	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
463127	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
463128	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
463129	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	General Comments		
463130	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
463131	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
463132	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
463133	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
463134	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
463135	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
463136	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
463137	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
463138	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Oil Temp Max	42	°C
463139	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
463140	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	General Comments		
463141	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
463142	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
463143	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Foundation Condition	Good	
463144	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
463145	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
463146	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
463147	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
463148	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
463149	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
463150	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
463151	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
463152	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
463153	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
463154	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
463155	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
463156	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
463157	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
463158	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
463159	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
463160	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
463161	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
463162	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
463163	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
463164	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
463165	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
463166	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	General Comments		
463167	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	General Comments		
463168	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
463169	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
463170	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	624.24	kw
463171	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
463172	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
463173	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
463174	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
463175	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Readings	Oil Temp Present	40	°C
463176	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Readings	Oil Temp Max	50	°C
463177	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
463178	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
463179	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
463180	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
463181	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
463182	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
463183	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
463184	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
463185	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
463186	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
463187	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
463188	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	General Comments		
463189	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
463190	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
463191	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Oil Temp Max	40	°C
463192	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Oil Temp Present	30	°C
463193	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
463194	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
463195	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
463196	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
463197	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
463198	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
463199	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
463200	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
463201	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
463202	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
463203	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
463204	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Clear of Trash?	y	
463205	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
463206	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
463207	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Ambient Temp	56	°F
463208	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
463209	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Clear of Trash?	y	
463210	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
463211	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
463212	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
463213	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	Follow-up Action Required?	n	
463214	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
463215	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	General Comments		
463216	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	General Comments		
463217	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC As Found Counter	14475	
463218	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC As Left Counter	14475	
463219	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
463220	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC Current Tap Position	7L	
463221	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC Max Tap Position	2L	
463222	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC Min Tap Position	10L	
463223	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC Operations Since Last Insp	9	
463224	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
463225	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
463226	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
463227	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
463228	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
463229	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
463230	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
463231	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
463232	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
463233	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Foundation Condition	Good	
463234	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
463235	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
463236	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	General Comments		
463237	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
463238	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
463239	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
463240	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
463241	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Maintenance Operations	0	
463242	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Operations Counter AF	197	
463243	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
463244	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	1941.12	kw
463245	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
463246	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
463247	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
463248	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
463249	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
463250	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
463251	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
463252	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
463253	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
463254	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
463255	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
463256	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	General Comments		
463257	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations Ground	0	
463258	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
463259	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
463260	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	General Comments		
463261	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	General Comments		
463262	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	General Comments		
463263	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
463264	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
463265	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
463266	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
463267	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
463268	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
463269	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
463270	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Vegetation	None	
463271	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
463272	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
463273	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
463274	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
463275	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
463276	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
463277	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
463278	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
463279	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
463280	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
463281	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
463282	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
463283	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Vegetation	None	
463284	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
463285	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	General Comments		
463286	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
463287	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
463288	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
463289	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
463290	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1000.80	kw
463291	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
463292	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
463293	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
463294	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	General Comments		
463295	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	General Comments		
463296	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
463297	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
463298	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
463299	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
463300	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
463301	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
463302	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
463303	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
463304	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
463305	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
463306	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
463307	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
463308	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
463309	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
463310	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
463311	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
463312	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
463313	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
463314	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Foundation Condition	Good	
463315	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Follow-up Action Required?	n	
463316	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Follow-up Action Required?	n	
463317	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Operations Ground	0	
463318	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Operations C Ø	0	
463319	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Operations B Ø	0	
463320	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
463321	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
463322	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
463323	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
463324	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
463325	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
463326	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
463327	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Unknown Operations	0	
463328	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Switching Operations	0	
463329	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Operations This Read Vac	0	
463330	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Operations Counter AL	79	
463331	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Operations Counter AF	79	
463332	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Maintenance Operations	0	
463333	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	General Comments		
463334	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Patrol Inspection	General Comments		
463335	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Follow-up Action Required?	n	
463336	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
463337	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Operations A Ø	0	
463338	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Operations B Ø	0	
463339	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Operations C Ø	0	
463340	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Follow-up Action Required?	n	
463341	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Foundation Condition	Good	
463342	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	General Comments		
463343	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	General Comments		
463344	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Grounds in Place?	y	
463345	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Maintenance Operations	0	
463346	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
463347	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Operations Counter AF	140	
463348	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Operations Counter AL	140	
463349	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Operations This Read Vac	0	
463350	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Switching Operations	0	
463351	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
463352	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Unknown Operations	0	
463353	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	45	°C
463354	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Operations Ground	0	
463355	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Follow-up Action Required?	n	
463356	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Follow-up Action Required?	n	
463357	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Foundation Condition	Good	
463358	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	General Comments		
463359	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	General Comments		
463360	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Grounds in Place?	y	
463361	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Heaters (All) Functioning?	y	
463362	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Maintenance Operations	0	
463363	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Moisture and Leak Free?	y	
463364	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Operations Counter AF	172	
463365	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Operations Counter AL	172	
463366	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Operations This Read Vac	0	
463367	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Switching Operations	0	
463368	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Tank Paint Condition	Good	
463369	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Unknown Operations	0	
463370	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
463371	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
463372	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
463373	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
463374	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
463375	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
463376	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
463377	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
463378	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
463379	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Oil Temp Max	70	°C
463380	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
463381	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	10.00	
463382	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Amps B Ø	116.0	
463383	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Amps A Ø	124.0	
463384	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
463385	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
463386	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
463387	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	9 Month Operations	11	
463388	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
463389	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
463390	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
463391	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
463392	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
463393	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
463394	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
463395	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Oil Temp Present	35	°C
463396	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	9 Month Operations	0	
463397	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
463398	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
463399	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
463400	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
463401	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
463402	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
463403	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	General Comments		
463404	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	General Comments		
463405	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
463406	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
463407	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
463408	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
463409	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	Oil Temp Max	40	°C
463410	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	Oil Temp Present	30	°C
463411	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
463412	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
463413	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
463414	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
463415	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
463416	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Amps A Ø	300.0	
463417	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Amps B Ø	300.0	
463418	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Amps C Ø	300.0	
463419	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
463420	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
463421	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
463422	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
463423	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
463424	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
463425	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
463426	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
463427	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Amps C Ø	377.0	
463428	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Patrol Inspection	Follow-up Action Required?	n	
463429	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Operations Ground	0	
463430	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Operations C Ø	0	
463431	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Operations B Ø	0	
463432	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Operations A Ø	0	
463433	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
463434	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
463435	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Operations A Ø	0	
463436	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
463437	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
463438	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
463439	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Equipment Properly Labeled?	y	
463440	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
463441	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	General Comments		
463442	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
463443	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
463444	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
463445	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	General Comments		
463446	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Cabinet Paint Condition	Good	
463447	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
463448	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
463449	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
463450	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Bushings Connection/Risers	Good	
463451	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	General Comments		
463452	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
463453	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
463454	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
463455	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
463456	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	Oil Temp Max	35	°C
463457	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	Oil Temp Present	30	°C
463458	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
463459	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
463460	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
463461	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
463462	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
463463	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
463464	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
463465	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
463466	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
463467	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
463468	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
463469	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
463470	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
463471	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Totalizer Meter Reading	.8088	
463472	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
463473	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Patrol Inspection	Equipment Properly Labeled?	y	
463474	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Amps C Ø	121.0	
463475	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Bushing Condition	Good	
463476	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
463477	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
463478	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
463479	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
463480	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
463481	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
463482	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
463483	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
463484	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
463485	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
463486	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
463487	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Oil Temp Present	29	°C
463488	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Oil Temp Max	37	°C
463489	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1350	psi
463490	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
463491	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
463492	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
463493	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	General Comments		
463494	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
463495	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
463496	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	130.0	
463497	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	120.0	
463498	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	130.0	
463499	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
463500	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
463501	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
463502	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
463503	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
463504	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
463505	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
463506	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
463507	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
463508	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
463509	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
463510	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
463511	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
463512	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
463513	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	General Comments		
463514	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
463515	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
463516	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
463517	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
463518	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Current Tap Position	1R	
463519	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
463520	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Follow-up Action Required?	n	
463521	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
463522	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	122.0	VAC
463523	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
463524	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
463525	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
463526	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
463527	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
463528	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
463529	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
463530	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
463531	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
463532	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	Follow-up Action Required?	n	
463533	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
463534	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
463535	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	General Comments		
463536	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	General Comments		
463537	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
463538	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	LTC Totalizer Reading	2496.00	kw
463539	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
463540	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	5.0	psi
463541	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	Oil Temp Max	40	°C
463542	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	Oil Temp Present	35	°C
463543	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
463544	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
463545	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
463546	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
463547	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
463548	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
463549	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
463550	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
463551	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	Totalizer Meter Reading	.7800	
463552	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
463553	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
463554	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
463555	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
463556	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
463557	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
463558	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
463559	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	30	°C
463560	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	38	°C
463561	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	30	°C
463562	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	38	°C
463563	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	24	°C
463564	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	33	°C
463565	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
463566	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
463567	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
463568	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
463569	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
463570	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
463571	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
463572	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
463573	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
463574	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
463575	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
463576	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
463577	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
463578	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
463579	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	General Comments		
463580	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
463581	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
463582	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
463583	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
463584	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
463585	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
463586	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
463587	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
463588	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
463589	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
463590	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
463591	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Tank Leaks	None	
463592	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4110	
463593	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
463594	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Top Oil Temperature Present	22	°C
463595	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Top Oil Temperature Max	50	°C
463596	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
463597	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
463598	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
463599	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
463600	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
463601	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
463602	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
463603	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
463604	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
463605	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2959.20	kw
463606	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
463607	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
463608	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
463609	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
463610	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	General Comments		
463611	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	General Comments		
463612	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
463613	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Foundation Condition	Good	
463614	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Gauge(s) Condition	Good	
463615	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	General Comments		
463616	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Grounds in Place?	y	
463617	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Max Tap Position	1R	
463618	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Min Tap Position	1R	
463619	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Moisture and Leak Free?	y	
463620	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
463621	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Reg Oil Level	Good	
463622	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Reg Operation Checked?	y	
463623	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Reg Output Voltage Level	121.0	volts
463624	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Regulator As Left Counter	47862	
463625	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
463626	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Surge Arrester Condition	Good	
463627	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Tank Leaks	None	
463628	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Tank Paint Condition	Good	
463629	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
463630	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	6	
463631	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1929	
463632	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1929	
463633	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	5	
463634	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	5	
463635	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
463636	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
463637	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
463638	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
463639	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
463640	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
463641	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
463642	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
463643	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
463644	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
463645	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Site Service Trans Condition	Exterior Stains	
463646	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
463647	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
463648	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
463649	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
463650	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
463651	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
463652	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
463653	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
463654	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	General Comments		
463655	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
463656	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
463657	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
463658	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
463659	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Oil Levels OK?	y	
463660	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
463661	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Tank Leaks	None	
463662	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
463663	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
463664	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Regulator As Left Counter	7319	
463665	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
463666	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
463667	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
463668	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
463669	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
463670	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
463671	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
463672	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
463673	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	General Comments		
463674	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
463675	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
463676	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
463677	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
463678	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Current Tap Position	9L	
463679	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
463680	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
463681	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
463682	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
463683	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
463684	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
463685	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Tank Leaks	None	
463686	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
463687	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
463688	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Regulator As Left Counter	8002	
463689	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
463690	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
463691	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
463692	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
463693	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
463694	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
463695	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
463696	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
463697	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	General Comments		
463698	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
463699	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
463700	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
463701	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
463702	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
463703	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
463704	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
463705	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
463706	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
463707	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
463708	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
463709	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
463710	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
463711	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
463712	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
463713	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
463714	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
463715	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
463716	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
463717	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
463718	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
463719	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	General Comments		
463720	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	General Comments		
463721	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
463722	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
463723	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	118.62	kw
463724	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
463725	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
463726	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Oil Temp Max	0	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
463727	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Oil Temp Present	0	°C
463728	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
463729	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
463730	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
463731	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
463732	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
463733	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
463734	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
463735	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
463736	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
463737	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
463738	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
463739	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Vegetation	None	
463740	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
463741	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	General Comments		
463742	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
463743	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.1977	
463744	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
463745	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	786	
463746	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	786	
463747	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
463748	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
463749	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
463750	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Pressure Acceptable?	y	
463751	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Regulator As Left Counter	45034	
463752	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
463753	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Surge Arrester Condition	Good	
463754	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Tank Leaks	None	
463755	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Tank Paint Condition	Good	
463756	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
463757	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
463758	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
463759	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
463760	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
463761	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
463762	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
463763	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	General Comments		
463764	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
463765	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
463766	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
463767	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
463768	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
463769	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
463770	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
463771	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
463772	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
463773	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
463774	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
463775	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
463776	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
463777	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
463778	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
463779	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
463780	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
463781	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
463782	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
463783	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Foundation Condition	Good	
463784	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
463785	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
463786	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	General Comments		
463787	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
463788	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
463789	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
463790	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
463791	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
463792	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
463793	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
463794	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
463795	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
463796	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
463797	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
463798	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
463799	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
463800	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
463801	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
463802	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
463803	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
463804	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
463805	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
463806	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Tank Leaks	None	
463807	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
463808	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
463809	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Regulator As Left Counter	47145	
463810	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.6	volts
463811	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
463812	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
463813	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
463814	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
463815	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
463816	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
463817	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
463818	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	General Comments		
463819	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
463820	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
463821	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
463822	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
463823	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
463824	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
463825	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
463826	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Current Tap Position	1R	
463827	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
463828	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Follow-up Action Required?	n	
463829	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Foundation Condition	Good	
463830	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
463831	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
463832	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Gauge(s) Condition	Good	
463833	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	General Comments		
463834	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
463835	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
463836	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Grounds in Place?	y	
463837	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Max Tap Position	1R	
463838	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Min Tap Position	1R	
463839	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Moisture and Leak Free?	y	
463840	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
463841	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Reg Oil Level	Good	
463842	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Reg Operation Checked?	y	
463843	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Reg Output Voltage Level	121.0	volts
463844	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
463845	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
463846	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
463847	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
463848	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Clear of Trash?	y	
463849	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
463850	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
463851	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Ambient Temp	63	°F
463852	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
463853	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
463854	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	5R	
463855	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
463856	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
463857	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
463858	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
463859	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
463860	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	30.00	
463861	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
463862	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
463863	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
463864	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
463865	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
463866	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
463867	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
463868	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
463869	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
463870	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
463871	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
463872	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
463873	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
463874	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
463875	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
463876	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
463877	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
463878	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
463879	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
463880	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	9 Month Operations	11	
463881	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
463882	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Vegetation	None	
463883	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
463884	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	General Comments	washout starting in back corner	
463885	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
463886	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
463887	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
463888	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
463889	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
463890	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
463891	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Operations A Ø	0	
463892	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Operations B Ø	0	
463893	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Dry Cell Battery Install Date	2016-05-05 00:00:00.000000	
463894	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
463895	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
463896	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
463897	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
463898	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Battery Bank Volts	53.2	VDC
463899	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
463900	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
463901	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
463902	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
463903	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	199	
463904	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
463905	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
463906	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
463907	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
463908	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
463909	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
463910	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
463911	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	20.0	
463912	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Operations C Ø	0	
463913	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Operations Ground	0	
463914	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Follow-up Action Required?	n	
463915	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Follow-up Action Required?	n	
463916	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Foundation Condition	Good	
463917	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	General Comments		
463918	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	General Comments		
463919	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Grounds in Place?	y	
463920	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Heaters (All) Functioning?	y	
463921	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Maintenance Operations	0	
463922	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Moisture and Leak Free?	y	
463923	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Operations Counter AF	230	
463924	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Operations Counter AL	230	
463925	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Operations This Read Vac	0	
463926	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
463927	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Switching Operations	0	
463928	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Tank Paint Condition	Good	
463929	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Unknown Operations	0	
463930	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
463931	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Vegetation	None	
463932	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
463933	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	General Comments		
463934	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
463935	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
463936	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
463937	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
463938	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
463939	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
463940	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
463941	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
463942	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	1	
463943	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
463944	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	5	
463945	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	528	
463946	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
463947	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	General Comments		
463948	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
463949	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
463950	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
463951	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
463952	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
463953	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Tank Leaks	None	
463954	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
463955	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	528	
463956	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
463957	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	4	
463958	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
463959	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
463960	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
463961	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
463962	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
463963	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
463964	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
463965	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Regulator As Left Counter	225738	
463966	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
463967	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Amps A Ø	125.0	
463968	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Amps B Ø	126.0	
463969	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
463970	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Amps C Ø	136.0	
463971	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Bushing Condition	Good	
463972	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Bushings Connection/Risers	Good	
463973	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
463974	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
463975	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
463976	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Cabinet Paint Condition	Good	
463977	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Equipment Properly Labeled?	y	
463978	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
463979	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
463980	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
463981	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Operations A Ø	0	
463982	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
463983	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Clear of Trash?	y	
463984	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
463985	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
463986	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
463987	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
463988	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
463989	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
463990	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
463991	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
463992	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
463993	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Equipment Properly Labeled?	y	
463994	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Cabinet Paint Condition	Good	
463995	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
463996	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
463997	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
463998	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Bushings Connection/Risers	Good	
463999	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Bushing Condition	Good	
464000	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Amps C Ø	120.0	
464001	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Amps B Ø	120.0	
464002	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Amps A Ø	120.0	
464003	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
464004	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
464005	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
464006	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	9 Month Operations	2	
464007	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
464008	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
464009	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
464010	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
464011	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
464012	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
464013	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
464014	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
464015	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
464016	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
464017	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
464018	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	General Comments		
464019	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
464020	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
464021	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
464022	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
464023	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
464024	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
464025	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
464026	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
464027	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
464028	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
464029	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
464030	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
464031	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
464032	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
464033	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
464034	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Clear of Trash?	y	
464035	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
464036	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Amps A Ø	0.0	
464037	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Amps B Ø	0.0	
464038	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Amps C Ø	0.0	
464039	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Bushing Condition	Good	
464040	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Bushings Connection/Risers	Good	
464041	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
464042	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
464043	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
464044	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
464045	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
464046	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
464047	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
464048	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
464049	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Cabinet Paint Condition	Good	
464050	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
464051	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
464052	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Ambient Temp	51	°F
464053	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Equipment Properly Labeled?	y	
464054	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
464055	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
464056	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
464057	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Operations A Ø	0	
464058	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Operations B Ø	0	
464059	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Operations C Ø	0	
464060	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Operations Ground	0	
464061	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Follow-up Action Required?	n	
464062	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Follow-up Action Required?	n	
464063	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Foundation Condition	Good	
464064	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	General Comments		
464065	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	General Comments		
464066	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Grounds in Place?	y	
464067	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Heaters (All) Functioning?	y	
464068	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Maintenance Operations	0	
464069	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Moisture and Leak Free?	y	
464070	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Operations Counter AF	150	
464071	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
464072	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
464073	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
464074	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
464075	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
464076	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
464077	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
464078	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
464079	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
464080	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
464081	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
464082	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
464083	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
464084	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Operations Counter	9	
464085	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
464086	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
464087	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	General Comments		
464088	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
464089	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
464090	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
464091	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Clear of Trash?	y	
464092	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
464093	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
464094	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
464095	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
464096	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
464097	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
464098	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
464099	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
464100	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
464101	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
464102	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
464103	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
464104	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Amps C Ø	36.0	
464105	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Amps B Ø	29.0	
464106	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Amps A Ø	24.0	
464107	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
464108	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
464109	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
464110	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	General Comments		
464111	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
464112	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Vegetation	None	
464113	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
464114	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
464115	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
464116	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	9 Month Operations	2	
464117	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	9 Month Operations	5	
464118	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
464119	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
464120	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Operations A Ø	0	
464121	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
464122	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
464123	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
464124	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Vegetation	None	
464125	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Exp Boom Needs Corr	
464126	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
464127	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
464128	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
464129	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
464130	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
464131	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	30	°C
464132	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	60	°C
464133	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
464134	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
464135	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
464136	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
464137	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
464138	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
464139	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	24.0	VDC
464140	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
464141	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
464142	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
464143	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	58651	
464144	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	General Comments		
464145	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
464146	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
464147	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
464148	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
464149	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
464150	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Clear of Trash?	y	
464151	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
464152	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
464153	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
464154	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
464155	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
464156	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
464157	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
464158	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
464159	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	12R	
464160	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	1R	
464161	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
464162	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	General Comments		
464163	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
464164	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
464165	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
464166	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
464167	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
464168	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Operations Counter AL	150	
464169	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Operations This Read Vac	1	
464170	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
464171	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Switching Operations	1	
464172	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Tank Paint Condition	Good	
464173	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Unknown Operations	0	
464174	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
464175	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
464176	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Amps A Ø	300.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
464177	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Amps B Ø	300.0	
464178	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Amps C Ø	300.0	
464179	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Bushing Condition	Good	
464180	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Bushings Connection/Risers	Good	
464181	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
464182	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
464183	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
464184	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Cabinet Paint Condition	Good	
464185	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Equipment Properly Labeled?	y	
464186	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
464187	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
464188	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	LTCC000420	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
464189	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	LTCC000420	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
464190	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	LTCC000420	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
464191	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	LTCC000420	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
464192	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	LTCC000420	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
464193	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	LTCC000420	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
464194	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	LTCC000420	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
464195	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	LTCC000420	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
464196	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Unknown Operations	0	
464197	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Tank Paint Condition	Good	
464198	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Switching Operations	0	
464199	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Operations This Read Vac	0	
464200	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Operations Counter AL	179	
464201	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Operations Counter AF	179	
464202	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Moisture and Leak Free?	y	
464203	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Maintenance Operations	0	
464204	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Grounds in Place?	y	
464205	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	General Comments		
464206	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	General Comments		
464207	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Foundation Condition	Good	
464208	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Follow-up Action Required?	n	
464209	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Follow-up Action Required?	n	
464210	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Operations Ground	0	
464211	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Operations C Ø	0	
464212	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Operations B Ø	0	
464213	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	55.0	
464214	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
464215	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Equipment Properly Labeled?	y	
464216	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Cabinet Paint Condition	Good	
464217	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
464218	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
464219	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
464220	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Bushings Connection/Risers	Good	
464221	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Bushing Condition	Good	
464222	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Amps C Ø	0.0	
464223	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Amps B Ø	0.0	
464224	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Amps A Ø	0.0	
464225	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
464226	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
464227	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
464228	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	9 Month Operations	1	
464229	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
464230	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
464231	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
464232	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
464233	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	14	
464234	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Unknown Operations	0	
464235	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Tank Paint Condition	Good	
464236	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Switching Operations	1	
464237	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
464238	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Operations This Read Vac	1	
464239	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Operations Counter AL	230	
464240	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
464241	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Vegetation	None	
464242	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
464243	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	General Comments		
464244	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
464245	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
464246	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
464247	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
464248	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
464249	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Clear of Trash?	y	
464250	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
464251	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Operations Counter AF	230	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
464252	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Moisture and Leak Free?	y	
464253	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Maintenance Operations	0	
464254	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Heaters (All) Functioning?	y	
464255	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Grounds in Place?	y	
464256	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	General Comments		
464257	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	General Comments		
464258	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Foundation Condition	Good	
464259	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Cabinet Paint Condition	Good	
464260	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
464261	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
464262	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
464263	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Bushings Connection/Risers	Good	
464264	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
464265	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
464266	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
464267	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
464268	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
464269	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
464270	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Bushing Condition	Good	
464271	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Amps C Ø	108.0	
464272	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Amps B Ø	108.0	
464273	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
464274	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
464275	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
464276	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
464277	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
464278	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
464279	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Amps A Ø	120.0	
464280	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Amps A Ø	350.0	
464281	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
464282	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
464283	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
464284	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
464285	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	General Comments		
464286	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
464287	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
464288	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
464289	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
464290	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
464291	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
464292	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
464293	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
464294	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
464295	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
464296	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
464297	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
464298	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
464299	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
464300	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
464301	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
464302	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
464303	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
464304	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
464305	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
464306	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
464307	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
464308	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
464309	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
464310	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
464311	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
464312	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
464313	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
464314	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
464315	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
464316	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
464317	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
464318	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
464319	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
464320	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
464321	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
464322	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	1R	
464323	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
464324	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
464325	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
464326	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
464327	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
464328	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
464329	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
464330	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
464331	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Unknown Operations	0	
464332	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Switching Operations	0	
464333	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Operations This Read Vac	0	
464334	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
464335	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Operations Counter AL	1167	
464336	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Operations Counter AF	1167	
464337	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Maintenance Operations	0	
464338	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	General Comments	R&C	
464339	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Patrol Inspection	General Comments		
464340	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Follow-up Action Required?	n	
464341	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Patrol Inspection	Follow-up Action Required?	n	
464342	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Operations Ground	0	
464343	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Operations C Ø	0	
464344	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Operations B Ø	0	
464345	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Operations A Ø	0	
464346	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
464347	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
464348	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
464349	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Patrol Inspection	Equipment Properly Labeled?	y	
464350	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Amps C Ø	0.0	
464351	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Follow-up Action Required?	n	
464352	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Follow-up Action Required?	n	
464353	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Operations Ground	0	
464354	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Operations C Ø	0	
464355	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Operations B Ø	0	
464356	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Operations A Ø	0	
464357	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
464358	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
464359	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
464360	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	VRR Time Delay	30	Seconds
464361	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
464362	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
464363	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
464364	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	LTC Operation Checked?	y	
464365	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	General Comments		
464366	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	Follow-up Action Required?	n	
464367	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	All Connections OK?	y	
464368	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Equipment Properly Labeled?	y	
464369	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Cabinet Paint Condition	Good	
464370	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
464371	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
464372	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
464373	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Bushings Connection/Risers	Good	
464374	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Bushing Condition	Good	
464375	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Amps C Ø	130.0	
464376	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Amps B Ø	130.0	
464377	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Amps A Ø	130.0	
464378	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
464379	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
464380	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
464381	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	9 Month Operations	1	
464382	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
464383	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
464384	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
464385	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
464386	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
464387	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
464388	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
464389	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
464390	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
464391	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	9R	
464392	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	12R	
464393	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
464394	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
464395	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
464396	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
464397	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
464398	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Regulator As Left Counter	51885	
464399	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
464400	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
464401	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Tank Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
464402	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
464403	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
464404	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Operations This Read Vac	1	
464405	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Operations Counter AL	532	
464406	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Operations Counter AF	532	
464407	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
464408	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Maintenance Operations	0	
464409	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
464410	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Grounds in Place?	y	
464411	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	General Comments		
464412	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	General Comments		
464413	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Foundation Condition	Good	
464414	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Follow-up Action Required?	n	
464415	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Follow-up Action Required?	n	
464416	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Operations Ground	0	
464417	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Operations C Ø	0	
464418	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Operations B Ø	0	
464419	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
464420	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
464421	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
464422	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
464423	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
464424	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
464425	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
464426	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
464427	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Operations A Ø	0	
464428	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
464429	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
464430	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
464431	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
464432	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
464433	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
464434	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
464435	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
464436	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
464437	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
464438	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
464439	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
464440	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
464441	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
464442	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
464443	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3800	
464444	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
464445	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
464446	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
464447	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
464448	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
464449	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
464450	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
464451	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
464452	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2940	
464453	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
464454	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
464455	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
464456	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
464457	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
464458	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Oil Temp Max	102	°C
464459	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
464460	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	220.00	
464461	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	832.20	kw
464462	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
464463	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
464464	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	General Comments		
464465	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	General Comments		
464466	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
464467	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
464468	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
464469	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Tank Paint Condition	Good	
464470	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Switching Operations	1	
464471	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
464472	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
464473	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
464474	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
464475	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
464476	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Current Tap Position	9L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
464477	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
464478	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
464479	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
464480	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
464481	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	General Comments		
464482	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
464483	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
464484	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
464485	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
464486	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
464487	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
464488	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
464489	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Operations B Ø	0	
464490	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Operations A Ø	0	
464491	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
464492	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Maintenance Operations	0	
464493	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	General Comments		
464494	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Patrol Inspection	General Comments		
464495	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
464496	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
464497	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Operations Ground	0	
464498	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
464499	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
464500	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
464501	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
464502	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
464503	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
464504	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
464505	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	General Comments		
464506	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
464507	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
464508	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
464509	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
464510	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
464511	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	14	
464512	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
464513	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	14	
464514	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	240	
464515	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
464516	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
464517	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	240	
464518	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
464519	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
464520	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
464521	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
464522	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
464523	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
464524	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
464525	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Amps C Ø	350.0	
464526	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Amps B Ø	350.0	
464527	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Operations Ground	0	
464528	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Operations C Ø	0	
464529	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Operations B Ø	0	
464530	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Operations A Ø	0	
464531	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
464532	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
464533	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
464534	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Equipment Properly Labeled?	y	
464535	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	1R	
464536	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	3L	
464537	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
464538	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
464539	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
464540	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
464541	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
464542	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	483127	
464543	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
464544	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
464545	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
464546	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
464547	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
464548	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
464549	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
464550	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Unknown Operations	0	
464551	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
464552	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Switching Operations	1	
464553	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Operations This Read Vac	1	
464554	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Operations Counter AL	211	
464555	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
464556	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
464557	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Operations Counter AF	211	
464558	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Moisture and Leak Free?	y	
464559	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Maintenance Operations	0	
464560	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Grounds in Place?	y	
464561	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	General Comments		
464562	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
464563	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Foundation Condition	Good	
464564	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
464565	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Unknown Operations	0	
464566	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Switching Operations	0	
464567	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Operations This Read Vac	0	
464568	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Operations Counter AL	205	
464569	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Operations Counter AF	205	
464570	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
464571	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
464572	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
464573	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
464574	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
464575	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
464576	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	General Comments		
464577	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Foundation Condition	Good	
464578	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Follow-up Action Required?	n	
464579	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Follow-up Action Required?	n	
464580	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Operations Ground	0	
464581	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Operations C Ø	0	
464582	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
464583	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
464584	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
464585	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
464586	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
464587	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
464588	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
464589	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
464590	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
464591	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
464592	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
464593	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
464594	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
464595	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
464596	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
464597	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
464598	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
464599	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Clear of Trash?	y	
464600	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
464601	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
464602	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
464603	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
464604	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
464605	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
464606	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	General Comments		
464607	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
464608	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
464609	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Vegetation	None	
464610	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
464611	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
464612	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
464613	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
464614	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	General Comments		
464615	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
464616	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
464617	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
464618	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
464619	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
464620	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
464621	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	Follow-up Action Required?	n	
464622	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
464623	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	General Comments		
464624	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	General Comments		
464625	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC As Found Counter	51145	
464626	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC As Left Counter	51145	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
464627	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
464628	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
464629	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
464630	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
464631	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	General Comments	Barb wire rusted.	
464632	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
464633	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
464634	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Max Tap Position	7R	
464635	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
464636	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	General Comments		
464637	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
464638	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
464639	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
464640	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LTCC000519	LTCControl	HK-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
464641	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LTCC000519	LTCControl	HK-TRANS 1	LTC Control Insp	General Comments		
464642	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LTCC000519	LTCControl	HK-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
464643	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LTCC000519	LTCControl	HK-TRANS 1	LTC Control Insp	All Connections OK?	y	
464644	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Tank Leaks	None	
464645	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
464646	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Regulator As Left Counter	272005	
464647	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
464648	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
464649	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
464650	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
464651	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
464652	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
464653	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
464654	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
464655	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	General Comments		
464656	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
464657	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
464658	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
464659	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
464660	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
464661	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
464662	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
464663	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
464664	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
464665	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	VRR Time Delay	30	Seconds
464666	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
464667	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
464668	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
464669	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
464670	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	LTC Operation Checked?	y	
464671	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	General Comments		
464672	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	Follow-up Action Required?	n	
464673	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	All Connections OK?	y	
464674	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Operations C Ø	0	
464675	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Operations Ground	0	
464676	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
464677	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
464678	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Patrol Inspection	Follow-up Action Required?	n	
464679	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Follow-up Action Required?	n	
464680	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Patrol Inspection	General Comments		
464681	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	General Comments	A&B Phase IOC & HSI	
464682	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Maintenance Operations	0	
464683	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Operations Counter AF	50	
464684	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Operations Counter AL	50	
464685	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Operations This Read Vac	2	
464686	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Switching Operations	0	
464687	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Unknown Operations	0	
464688	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
464689	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
464690	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
464691	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
464692	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
464693	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
464694	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
464695	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
464696	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
464697	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
464698	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
464699	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
464700	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
464701	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
464702	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
464703	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
464704	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
464705	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
464706	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
464707	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
464708	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
464709	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	General Comments		
464710	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
464711	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
464712	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Foundation Condition	Good	
464713	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
464714	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
464715	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
464716	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
464717	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
464718	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
464719	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
464720	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC Current Tap Position	10L	
464721	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC Max Tap Position	5L	
464722	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC Min Tap Position	12L	
464723	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC Operations Since Last Insp	217	
464724	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
464725	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
464726	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
464727	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
464728	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
464729	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Tank Leaks	None	
464730	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
464731	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	Follow-up Action Required?	n	
464732	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
464733	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	General Comments		
464734	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	General Comments		
464735	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC As Found Counter	44440	
464736	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC As Left Counter	44440	
464737	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
464738	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC Current Tap Position	7L	
464739	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC Max Tap Position	2R	
464740	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC Min Tap Position	8L	
464741	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC Operations Since Last Insp	290	
464742	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
464743	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
464744	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
464745	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
464746	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	9 Month Operations	12	
464747	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
464748	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
464749	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	General Comments		
464750	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
464751	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
464752	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
464753	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
464754	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
464755	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
464756	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
464757	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
464758	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Amps A Ø	80.0	
464759	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Amps B Ø	80.0	
464760	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Amps C Ø	80.0	
464761	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Patrol Inspection	Equipment Properly Labeled?	y	
464762	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
464763	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
464764	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
464765	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Operations A Ø	1	
464766	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Operations B Ø	1	
464767	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
464768	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
464769	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
464770	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
464771	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
464772	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
464773	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
464774	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Tank Leaks	None	
464775	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
464776	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Regulator As Left Counter	285153	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
464777	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
464778	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
464779	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
464780	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
464781	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
464782	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
464783	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
464784	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
464785	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	General Comments		
464786	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
464787	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
464788	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
464789	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
464790	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Current Tap Position	9L	
464791	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
464792	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
464793	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
464794	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
464795	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
464796	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
464797	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
464798	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Totalizer Meter Reading	.2142	
464799	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
464800	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
464801	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
464802	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
464803	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
464804	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
464805	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
464806	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
464807	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Oil Temp Present	31	°C
464808	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Oil Temp Max	78	°C
464809	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
464810	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
464811	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	LTC Totalizer Reading	1542.24	kw
464812	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
464813	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Amps B Ø	0.0	
464814	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Amps A Ø	0.0	
464815	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
464816	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
464817	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
464818	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	9 Month Operations	0	
464819	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
464820	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Tank Leaks	None	
464821	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
464822	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	9 Month Operations	3	
464823	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
464824	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
464825	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
464826	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	9 Month Operations	9	
464827	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
464828	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Regulator As Left Counter	374512	
464829	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
464830	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
464831	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
464832	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Broken skirts	
464833	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
464834	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
464835	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
464836	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
464837	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
464838	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
464839	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
464840	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	General Comments		
464841	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	General Comments		
464842	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
464843	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
464844	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
464845	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
464846	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	Oil Temp Max	43	°C
464847	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	Oil Temp Present	41	°C
464848	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
464849	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
464850	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
464851	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
464852	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
464853	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
464854	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
464855	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
464856	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
464857	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
464858	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
464859	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	All Connections OK?	y	
464860	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
464861	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
464862	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
464863	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
464864	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
464865	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
464866	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
464867	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
464868	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
464869	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
464870	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
464871	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
464872	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
464873	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
464874	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
464875	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.700	millivolts
464876	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.4	VDC
464877	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.4	VDC
464878	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.9	amps
464879	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
464880	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
464881	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	General Comments		
464882	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
464883	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
464884	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
464885	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
464886	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
464887	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
464888	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
464889	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Tank Leaks	None	
464890	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
464891	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Regulator As Left Counter	23877	
464892	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
464893	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
464894	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
464895	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
464896	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
464897	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
464898	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
464899	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
464900	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
464901	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
464902	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
464903	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
464904	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
464905	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	General Comments		
464906	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	General Comments		
464907	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
464908	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
464909	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Follow-up Action Required?	n	
464910	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
464911	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
464912	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
464913	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
464914	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
464915	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
464916	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
464917	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
464918	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
464919	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
464920	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
464921	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
464922	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	VRR Time Delay	30	Seconds
464923	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
464924	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Bushing Condition	Good	
464925	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Amps C Ø	600.0	
464926	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Amps B Ø	600.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
464927	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Amps A Ø	600.0	
464928	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
464929	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
464930	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
464931	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	9 Month Operations	1	
464932	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
464933	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
464934	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
464935	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
464936	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
464937	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
464938	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
464939	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
464940	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
464941	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
464942	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
464943	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
464944	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	General Comments		
464945	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
464946	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
464947	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
464948	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
464949	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	LTC Operation Checked?	y	
464950	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	General Comments		
464951	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	Follow-up Action Required?	n	
464952	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
464953	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
464954	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
464955	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
464956	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
464957	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
464958	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	Oil Temp Max	35	°C
464959	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
464960	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
464961	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
464962	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	General Comments		
464963	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
464964	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
464965	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
464966	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Tank Leaks	None	
464967	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
464968	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
464969	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Regulator As Left Counter	59176	
464970	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
464971	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
464972	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
464973	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
464974	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
464975	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
464976	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
464977	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
464978	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	General Comments		
464979	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
464980	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
464981	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
464982	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
464983	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
464984	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
464985	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
464986	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
464987	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
464988	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
464989	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
464990	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
464991	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
464992	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
464993	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
464994	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
464995	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
464996	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
464997	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
464998	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
464999	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
465000	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
465001	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
465002	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
465003	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
465004	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
465005	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Tank Leaks	None	
465006	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
465007	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
465008	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Regulator As Left Counter	53898	
465009	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
465010	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
465011	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
465012	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
465013	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
465014	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
465015	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
465016	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
465017	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	General Comments		
465018	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
465019	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
465020	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
465021	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
465022	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
465023	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
465024	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
465025	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
465026	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
465027	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
465028	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
465029	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
465030	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Switching Operations	0	
465031	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Unknown Operations	0	
465032	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	VRR Time Delay	30	Seconds
465033	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
465034	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Grounds in Place?	y	
465035	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	General Comments		
465036	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	General Comments		
465037	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
465038	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Foundation Condition	Good	
465039	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Follow-up Action Required?	n	
465040	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Follow-up Action Required?	n	
465041	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Fault Operations	0	
465042	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
465043	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
465044	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
465045	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
465046	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
465047	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Ambient Temperature	65	°F
465048	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LTCC000099	LTCControl	HK-TRANS 3	LTC Control Insp	All Connections OK?	y	
465049	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LTCC000099	LTCControl	HK-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
465050	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LTCC000099	LTCControl	HK-TRANS 3	LTC Control Insp	General Comments		
465051	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LTCC000099	LTCControl	HK-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
465052	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	LTCC000107	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
465053	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	LTCC000107	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
465054	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	LTCC000107	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
465055	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	LTCC000107	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
465056	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	LTCC000107	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
465057	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	LTCC000107	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
465058	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	LTCC000107	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
465059	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	LTCC000107	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
465060	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	PF000182	PowerFuse	HK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
465061	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	PF000182	PowerFuse	HK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
465062	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	PF000181	PowerFuse	HK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
465063	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	PF000181	PowerFuse	HK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
465064	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	PF000196	PowerFuse	LO-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
465065	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	PF000196	PowerFuse	LO-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
465066	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	PF000195	PowerFuse	LO-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
465067	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	PF000195	PowerFuse	LO-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
465068	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
465069	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
465070	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
465071	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
465072	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
465073	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	n	If no, which cells in comments
465074	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
465075	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
465076	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
465077	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	y	
465078	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	Cell 28 and 29 have crack on top	
465079	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
465080	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
465081	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
465082	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	57	°F
465083	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
465084	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
465085	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
465086	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
465087	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
465088	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
465089	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
465090	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
465091	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.9	VDC
465092	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.9	VDC
465093	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
465094	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
465095	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	BCH000298	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.5	VDC
465096	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	BCH000298	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
465097	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	BCH000298	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
465098	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	55	°C
465099	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	60	°C
465100	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	47	°C
465101	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	52	°C
465102	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	47	°C
465103	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	47	°C
465104	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
465105	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
465106	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
465107	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
465108	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
465109	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
465110	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
465111	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
465112	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
465113	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
465114	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
465115	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
465116	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
465117	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
465118	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
465119	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	Follow-up Action Required?	n	
465120	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
465121	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	General Comments		
465122	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	General Comments		
465123	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC As Found Counter	3066	
465124	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC As Left Counter	3077	
465125	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
465126	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC Current Tap Position	11L	
465127	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC Max Tap Position	7L	
465128	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC Min Tap Position	15L	
465129	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
465130	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC Operations Since Last Insp	227	
465131	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
465132	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
465133	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
465134	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
465135	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
465136	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
465137	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
465138	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
465139	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
465140	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	General Comments		
465141	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
465142	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
465143	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
465144	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
465145	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
465146	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
465147	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
465148	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
465149	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
465150	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Totalizer Meter Reading	.3522	
465151	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Winding Temp Max	36	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
465152	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Winding Temp Present	36	°C
465153	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
465154	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
465155	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	Follow-up Action Required?	n	
465156	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
465157	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	General Comments		
465158	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	General Comments		
465159	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC As Found Counter	77756	
465160	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC As Left Counter	77756	
465161	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
465162	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC Current Tap Position	3L	
465163	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC Max Tap Position	5R	
465164	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC Min Tap Position	7L	
465165	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
465166	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
465167	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
465168	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
465169	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
465170	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
465171	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
465172	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
465173	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
465174	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
465175	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
465176	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
465177	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
465178	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	General Comments		
465179	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
465180	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
465181	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
465182	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
465183	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Clear of Trash?	y	
465184	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC Operations Since Last Insp	687	
465185	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
465186	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
465187	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Tank Leaks	None	
465188	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
465189	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
465190	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Regulator As Left Counter	56789	
465191	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
465192	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
465193	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
465194	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
465195	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
465196	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
465197	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
465198	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
465199	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	General Comments		
465200	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
465201	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
465202	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
465203	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
465204	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
465205	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
465206	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
465207	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
465208	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
465209	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
465210	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
465211	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
465212	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
465213	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
465214	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
465215	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	Oil Temp Present	40	°C
465216	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	Oil Temp Max	50	°C
465217	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
465218	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
465219	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
465220	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
465221	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
465222	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
465223	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	General Comments		
465224	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	General Comments		
465225	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
465226	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
465227	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
465228	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
465229	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
465230	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
465231	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
465232	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
465233	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
465234	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
465235	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
465236	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
465237	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
465238	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
465239	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
465240	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
465241	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
465242	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
465243	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
465244	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
465245	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
465246	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
465247	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
465248	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
465249	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
465250	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
465251	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
465252	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
465253	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
465254	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Follow-up Action Required?	n	
465255	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
465256	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
465257	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	General Comments		
465258	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	General Comments		
465259	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
465260	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	LTC Totalizer Reading	5071.68	kw
465261	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
465262	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
465263	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Oil Temp Max	35	°C
465264	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Oil Temp Present	35	°C
465265	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
465266	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
465267	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
465268	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
465269	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
465270	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
465271	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
465272	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
465273	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
465274	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
465275	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
465276	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
465277	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
465278	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
465279	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
465280	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
465281	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	9 Months Operations	0	
465282	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
465283	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
465284	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
465285	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
465286	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC Operations Since Last Insp	267	
465287	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
465288	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC Min Tap Position	12L	
465289	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
465290	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC Current Tap Position	8L	
465291	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
465292	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC As Left Counter	15460	
465293	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC As Found Counter	15460	
465294	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	General Comments		
465295	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	General Comments		
465296	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
465297	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	Follow-up Action Required?	n	
465298	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
465299	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	General Comments		
465300	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
465301	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
465302	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
465303	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	General Comments		
465304	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	General Comments		
465305	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Foundation Condition	Good	
465306	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Follow-up Action Required?	n	
465307	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Follow-up Action Required?	n	
465308	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Operations Ground	0	
465309	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Operations C Ø	0	
465310	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Operations B Ø	0	
465311	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Operations A Ø	0	
465312	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
465313	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
465314	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
465315	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
465316	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
465317	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
465318	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
465319	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
465320	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
465321	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
465322	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
465323	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
465324	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
465325	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
465326	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Equipment Properly Labeled?	y	
465327	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Cabinet Paint Condition	Good	
465328	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
465329	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
465330	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
465331	4/12/2019 11:50	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
465332	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
465333	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
465334	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
465335	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Clear of Trash?	y	
465336	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
465337	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
465338	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
465339	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
465340	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
465341	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
465342	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	General Comments		
465343	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
465344	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
465345	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
465346	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
465347	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	General Comments		
465348	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
465349	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
465350	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
465351	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
465352	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
465353	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
465354	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	9 Month Operations	8	
465355	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
465356	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
465357	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
465358	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Amps A Ø	60.0	
465359	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Amps B Ø	60.0	
465360	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Amps C Ø	25.0	
465361	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Bushing Condition	Good	
465362	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Bushings Connection/Risers	Good	
465363	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
465364	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
465365	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
465366	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Cabinet Paint Condition	Good	
465367	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
465368	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Equipment Properly Labeled?	y	
465369	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
465370	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
465371	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
465372	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
465373	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
465374	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
465375	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
465376	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
465377	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
465378	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
465379	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	General Comments		
465380	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
465381	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
465382	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
465383	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
465384	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	General Comments		
465385	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
465386	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
465387	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
465388	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
465389	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	7	
465390	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	2241	
465391	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	2241	
465392	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Operations A Ø	0	
465393	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Operations B Ø	0	
465394	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Operations C Ø	0	
465395	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Operations Ground	0	
465396	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Follow-up Action Required?	n	
465397	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Follow-up Action Required?	n	
465398	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Foundation Condition	Good	
465399	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	General Comments		
465400	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	General Comments		
465401	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Grounds in Place?	y	
465402	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Heaters (All) Functioning?	y	
465403	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Maintenance Operations	0	
465404	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Moisture and Leak Free?	y	
465405	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	5	
465406	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	5	
465407	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
465408	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
465409	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Operations Counter AF	282	
465410	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Operations Counter AL	282	
465411	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Operations This Read Vac	5	
465412	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
465413	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Switching Operations	5	
465414	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Tank Paint Condition	Good	
465415	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Unknown Operations	0	
465416	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
465417	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	General Comments		
465418	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
465419	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
465420	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
465421	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
465422	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
465423	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Operations A Ø	0	
465424	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Operations B Ø	0	
465425	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Operations C Ø	0	
465426	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Operations Ground	0	
465427	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
465428	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Tank Leaks	None	
465429	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
465430	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Operations Counter	3	
465431	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
465432	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
465433	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	General Comments		
465434	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
465435	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
465436	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
465437	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
465438	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
465439	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
465440	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
465441	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
465442	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
465443	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
465444	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Amps C Ø	1.0	
465445	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Amps B Ø	3.0	
465446	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Amps A Ø	3.0	
465447	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Bushing Condition	Good	
465448	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
465449	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
465450	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
465451	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
465452	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
465453	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
465454	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
465455	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
465456	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
465457	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Operations A Ø	0	
465458	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.000	millivolts
465459	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	135.0	VDC
465460	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	135.0	VDC
465461	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	3.0	amps
465462	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
465463	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
465464	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
465465	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
465466	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Operations B Ø	0	
465467	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Operations C Ø	0	
465468	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Operations Ground	0	
465469	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Follow-up Action Required?	n	
465470	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Follow-up Action Required?	n	
465471	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Foundation Condition	Good	
465472	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	General Comments		
465473	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	General Comments		
465474	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Grounds in Place?	y	
465475	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
465476	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Maintenance Operations	0	
465477	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
465478	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Operations Counter AF	161	
465479	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Operations Counter AL	161	
465480	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Operations This Read Vac	0	
465481	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Switching Operations	0	
465482	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Tank Paint Condition	Good	
465483	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Unknown Operations	0	
465484	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	All Connections OK?	y	
465485	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	Follow-up Action Required?	n	
465486	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	General Comments		
465487	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	LTC Operation Checked?	y	
465488	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	LTC Output Voltage Level	120.4	VAC
465489	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
465490	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
465491	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Patrol Inspection	Follow-up Action Required?	n	
465492	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Follow-up Action Required?	n	
465493	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Patrol Inspection	General Comments		
465494	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	General Comments		
465495	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Maintenance Operations	0	
465496	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Operations Counter AF	13	
465497	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Operations Counter AL	13	
465498	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Operations This Read AM	0	
465499	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
465500	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
465501	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
465502	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
465503	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
465504	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Vegetation	None	
465505	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
465506	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
465507	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
465508	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
465509	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Amps A Ø	0.0	
465510	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Amps B Ø	0.0	
465511	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Amps C Ø	0.0	
465512	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
465513	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
465514	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	9 Month Operations	1	
465515	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
465516	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
465517	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Bushings Connection/Risers	Good	
465518	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Bushing Condition	Good	
465519	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Amps C Ø	10.0	
465520	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Amps B Ø	10.0	
465521	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Amps A Ø	10.0	
465522	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Accumulated Fault Duty C Ph V	7.83	%
465523	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Accumulated Fault Duty B Ph V	7.12	%
465524	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Accumulated Fault Duty A Ph V	7.83	%
465525	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	9 Month Operations	5	
465526	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
465527	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
465528	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
465529	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
465530	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
465531	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
465532	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
465533	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
465534	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
465535	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
465536	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	General Comments		
465537	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
465538	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
465539	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Min Tap Position	14L	
465540	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
465541	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
465542	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Reg Oil Level	Undetermined	
465543	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
465544	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
465545	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
465546	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
465547	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Tank Leaks	None	
465548	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
465549	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
465550	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Amps A Ø	222.0	
465551	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Amps B Ø	150.0	
465552	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
465553	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
465554	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
465555	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
465556	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
465557	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
465558	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
465559	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
465560	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
465561	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
465562	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	General Comments		
465563	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
465564	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
465565	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
465566	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
465567	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
465568	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Reg Oil Level	Undetermined	
465569	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
465570	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
465571	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
465572	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
465573	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Tank Leaks	None	
465574	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
465575	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	PF000101	PowerFuse	DX-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
465576	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	PF000101	PowerFuse	DX-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
465577	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Amps C Ø	250.0	
465578	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
465579	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	LTC Totalizer Reading	10699.20	kw
465580	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
465581	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	General Comments		
465582	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	General Comments		
465583	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
465584	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
465585	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Follow-up Action Required?	n	
465586	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
465587	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
465588	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
465589	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
465590	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
465591	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
465592	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
465593	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
465594	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
465595	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
465596	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
465597	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
465598	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
465599	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	571	
465600	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	18.2	
465601	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	13.1	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
465602	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	1.0	
465603	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	412	
465604	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
465605	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
465606	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	544	
465607	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
465608	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
465609	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
465610	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
465611	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
465612	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
465613	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
465614	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
465615	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
465616	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
465617	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
465618	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
465619	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
465620	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
465621	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
465622	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
465623	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
465624	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
465625	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
465626	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
465627	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
465628	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
465629	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
465630	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
465631	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
465632	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
465633	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
465634	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
465635	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
465636	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
465637	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
465638	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
465639	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
465640	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
465641	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
465642	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
465643	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
465644	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	394	
465645	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	394	
465646	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	8	
465647	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
465648	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
465649	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
465650	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
465651	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
465652	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
465653	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
465654	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
465655	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
465656	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
465657	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
465658	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
465659	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
465660	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
465661	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
465662	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
465663	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
465664	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	127	
465665	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
465666	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
465667	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
465668	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
465669	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
465670	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
465671	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
465672	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
465673	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
465674	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
465675	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
465676	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
465677	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
465678	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Tank Leaks	None	
465679	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Totalizer Meter Reading	.6162	
465680	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Winding Temp Max	45	°C
465681	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Winding Temp Present	45	°C
465682	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
465683	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
465684	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
465685	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Operations Counter	1133	
465686	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
465687	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
465688	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	General Comments		
465689	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
465690	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
465691	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
465692	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
465693	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
465694	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
465695	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
465696	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
465697	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
465698	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
465699	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Amps C Ø	30.0	
465700	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Amps B Ø	56.0	
465701	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Amps A Ø	56.0	
465702	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
465703	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
465704	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Winding Temp Present	45	°C
465705	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Winding Temp Max	45	°C
465706	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Totalizer Meter Reading	.4458	
465707	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
465708	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Top Oil Temperature Present	40	°C
465709	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Top Oil Temperature Max	45	°C
465710	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
465711	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
465712	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
465713	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
465714	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
465715	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	PF000180	PowerFuse	HL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
465716	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	PF000180	PowerFuse	HL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
465717	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	Follow-up Action Required?	n	
465718	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
465719	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	General Comments		
465720	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	General Comments		
465721	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC As Found Counter	326835	
465722	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC As Left Counter	326835	
465723	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
465724	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC Current Tap Position	7L	
465725	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC Max Tap Position	1R	
465726	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC Min Tap Position	8L	
465727	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC Operations Since Last Insp	266	
465728	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
465729	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
465730	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
465731	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
465732	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
465733	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
465734	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
465735	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Bushings Connection/Risers	Good	
465736	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	Follow-up Action Required?	n	
465737	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	General Comments		
465738	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC As Found Counter	10290	
465739	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC As Left Counter	10290	
465740	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC Current Tap Position	5L	
465741	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Bushing Condition	Good	
465742	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Amps C Ø	0.0	
465743	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Amps B Ø	10.0	
465744	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Amps A Ø	10.0	
465745	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
465746	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
465747	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
465748	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
465749	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	General Comments		
465750	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
465751	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
465752	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
465753	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
465754	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
465755	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
465756	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
465757	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
465758	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
465759	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
465760	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
465761	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
465762	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
465763	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
465764	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
465765	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
465766	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
465767	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
465768	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
465769	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
465770	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
465771	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
465772	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
465773	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
465774	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	63	°F
465775	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
465776	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
465777	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Oil Temp Present	30	°C
465778	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Oil Temp Max	30	°C
465779	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
465780	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
465781	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	LTC Totalizer Reading	792.00	kw
465782	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Totalizer Meter Reading	.1914	
465783	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
465784	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
465785	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
465786	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
465787	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
465788	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
465789	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
465790	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Oil Temp Present	34	°C
465791	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC Max Tap Position	1L	
465792	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
465793	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	General Comments		
465794	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	General Comments		
465795	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
465796	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
465797	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Follow-up Action Required?	n	
465798	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
465799	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
465800	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
465801	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Tank Leaks	None	
465802	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
465803	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
465804	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.6	volts
465805	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
465806	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
465807	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
465808	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
465809	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
465810	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
465811	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
465812	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
465813	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BCH000585	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
465814	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BCH000585	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
465815	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BCH000585	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
465816	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BCH000585	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
465817	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BCH000585	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
465818	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BCH000585	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
465819	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BCH000589	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
465820	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BCH000589	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
465821	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BCH000589	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
465822	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
465823	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
465824	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
465825	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
465826	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
465827	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
465828	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Max Tap Position	10R	
465829	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
465830	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
465831	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BCH000589	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
465832	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BCH000589	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
465833	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BCH000589	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
465834	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
465835	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
465836	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
465837	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
465838	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
465839	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.5	volts
465840	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Regulator As Left Counter	179626	
465841	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
465842	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
465843	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Tank Leaks	None	
465844	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
465845	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Totalizer Meter Reading	.1320	
465846	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
465847	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
465848	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
465849	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
465850	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
465851	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
465852	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
465853	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
465854	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	68	
465855	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
465856	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
465857	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
465858	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
465859	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
465860	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
465861	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
465862	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
465863	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
465864	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Unknown Operations	0	
465865	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Tank Paint Condition	Good	
465866	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Switching Operations	0	
465867	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
465868	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Operations This Read Vac	2	
465869	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Operations Counter AL	261	
465870	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Operations Counter AF	261	
465871	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Moisture and Leak Free?	y	
465872	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Maintenance Operations	1	
465873	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Heaters (All) Functioning?	y	
465874	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Grounds in Place?	y	
465875	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	General Comments		
465876	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	General Comments		
465877	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Foundation Condition	Good	
465878	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Follow-up Action Required?	n	
465879	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Follow-up Action Required?	n	
465880	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Operations Ground	0	
465881	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Operations C Ø	0	
465882	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Operations B Ø	1	
465883	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Operations A Ø	0	
465884	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
465885	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Adjusted Amps B Phase V	7.55	
465886	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
465887	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Equipment Properly Labeled?	y	
465888	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Cabinet Paint Condition	Good	
465889	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
465890	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
465891	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Unknown Operations	0	
465892	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Amps A Ø	5.0	
465893	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Amps B Ø	12.0	
465894	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Amps C Ø	5.0	
465895	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
465896	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
465897	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
465898	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
465899	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
465900	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	General Comments		
465901	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
465902	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
465903	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Operations Counter	394	
465904	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
465905	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	General Comments		
465906	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
465907	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
465908	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
465909	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
465910	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
465911	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Amps C Ø	16.3	
465912	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Amps B Ø	15.2	
465913	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Amps A Ø	20.2	
465914	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
465915	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
465916	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
465917	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
465918	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
465919	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
465920	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Foundation Condition	Good	
465921	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
465922	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
465923	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
465924	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Operations Counter	398	
465925	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
465926	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
465927	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	9 Month Operations	9	
465928	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Accumulated Fault Duty A Ph V	7.83	%
465929	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Accumulated Fault Duty B Ph V	9.96	%
465930	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Accumulated Fault Duty C Ph V	11.39	%
465931	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Amps A Ø	190.0	
465932	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Amps B Ø	190.0	
465933	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Amps C Ø	190.0	
465934	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Bushing Condition	Good	
465935	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Bushings Connection/Risers	Good	
465936	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
465937	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
465938	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
465939	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Cabinet Paint Condition	Good	
465940	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Equipment Properly Labeled?	y	
465941	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
465942	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
465943	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
465944	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Operations A Ø	0	
465945	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
465946	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Tank Leaks	None	
465947	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
465948	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Regulator As Left Counter	24296	
465949	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
465950	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
465951	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
465952	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
465953	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
465954	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
465955	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
465956	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
465957	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Max Tap Position	16R	
465958	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
465959	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
465960	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
465961	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
465962	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
465963	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
465964	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
465965	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
465966	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	General Comments		
465967	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
465968	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
465969	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
465970	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
465971	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
465972	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
465973	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
465974	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
465975	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
465976	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
465977	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	General Comments		
465978	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
465979	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
465980	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
465981	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
465982	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
465983	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
465984	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Vegetation	None	
465985	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
465986	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	Follow-up Action Required?	n	
465987	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
465988	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
465989	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
465990	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
465991	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
465992	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
465993	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
465994	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
465995	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
465996	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
465997	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
465998	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
465999	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
466000	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	General Comments		
466001	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
466002	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Operations Counter	202	
466003	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
466004	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
466005	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
466006	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	General Comments		
466007	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
466008	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Foundation Condition	Good	
466009	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
466010	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	General Comments		
466011	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
466012	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
466013	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
466014	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	LTCC000581	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
466015	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	LTCC000581	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
466016	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	LTCC000581	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
466017	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	LTCC000581	LTCControl	930-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
466018	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	LTCC000581	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
466019	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	LTCC000581	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
466020	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	LTCC000581	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
466021	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	LTCC000581	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
466022	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	General Comments		
466023	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC As Found Counter	95080	
466024	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC As Left Counter	95080	
466025	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
466026	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC Current Tap Position	2L	
466027	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC Max Tap Position	8R	
466028	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC Min Tap Position	8L	
466029	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
466030	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC Operations Since Last Insp	744	
466031	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
466032	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
466033	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
466034	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
466035	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
466036	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
466037	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	LTCC000581	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
466038	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
466039	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
466040	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
466041	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
466042	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
466043	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
466044	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
466045	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
466046	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
466047	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
466048	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
466049	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Regulator As Left Counter	23649	
466050	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
466051	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
466052	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
466053	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
466054	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
466055	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
466056	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
466057	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
466058	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	General Comments		
466059	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
466060	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
466061	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
466062	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
466063	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
466064	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
466065	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
466066	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
466067	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
466068	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
466069	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
466070	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
466071	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
466072	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
466073	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
466074	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
466075	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
466076	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
466077	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
466078	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
466079	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
466080	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
466081	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
466082	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	7.0	VDC
466083	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	7.0	VDC
466084	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
466085	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
466086	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
466087	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Bushing Condition	Good	
466088	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Amps C Ø	160.0	
466089	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Amps B Ø	370.0	
466090	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Amps A Ø	382.0	
466091	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
466092	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
466093	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
466094	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	9 Month Operations	1	
466095	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
466096	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
466097	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
466098	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
466099	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
466100	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
466101	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
466102	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
466103	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
466104	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
466105	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
466106	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
466107	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
466108	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Follow-up Action Required?	n	
466109	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
466110	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
466111	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	General Comments		
466112	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	General Comments		
466113	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
466114	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	LTC Totalizer Reading	8873.28	kw
466115	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
466116	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
466117	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Oil Temp Max	45	°C
466118	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Oil Temp Present	40	°C
466119	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
466120	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
466121	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
466122	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
466123	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
466124	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
466125	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
466126	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
466127	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
466128	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
466129	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
466130	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
466131	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
466132	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
466133	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
466134	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
466135	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
466136	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Operations B Ø	0	
466137	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Operations C Ø	0	
466138	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Operations Ground	0	
466139	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Follow-up Action Required?	n	
466140	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Follow-up Action Required?	n	
466141	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Foundation Condition	Good	
466142	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	General Comments		
466143	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	General Comments		
466144	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Grounds in Place?	y	
466145	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Heaters (All) Functioning?	y	
466146	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Maintenance Operations	0	
466147	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Moisture and Leak Free?	y	
466148	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Operations Counter AF	341	
466149	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Operations Counter AL	341	
466150	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Operations This Read Vac	4	
466151	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
466152	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Switching Operations	4	
466153	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Tank Paint Condition	Good	
466154	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Unknown Operations	0	
466155	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Tank Paint Condition	Good	
466156	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Bushing Condition	Good	
466157	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
466158	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
466159	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
466160	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
466161	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Current Tap Position	7L	
466162	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
466163	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Follow-up Action Required?	n	
466164	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Foundation Condition	Good	
466165	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Gauge(s) Condition	Good	
466166	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	General Comments		
466167	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Grounds in Place?	y	
466168	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Switching Operations	0	
466169	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Operations This Read Vac	0	
466170	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Operations Counter AL	167	
466171	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Operations Counter AF	167	
466172	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
466173	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Maintenance Operations	0	
466174	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
466175	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Grounds in Place?	y	
466176	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	General Comments		
466177	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	General Comments		
466178	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Foundation Condition	Good	
466179	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Follow-up Action Required?	n	
466180	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Follow-up Action Required?	n	
466181	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Operations Ground	0	
466182	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Operations C Ø	0	
466183	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Operations B Ø	0	
466184	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Operations A Ø	0	
466185	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
466186	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Max Tap Position	1R	
466187	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Min Tap Position	10L	
466188	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Moisture and Leak Free?	y	
466189	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
466190	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Reg Oil Level	Good	
466191	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Reg Operation Checked?	y	
466192	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
466193	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Regulator As Left Counter	74804	
466194	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
466195	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	63	°F
466196	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
466197	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
466198	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
466199	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
466200	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Tank Leaks	None	
466201	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
466202	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Surge Arrester Condition	Good	
466203	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Tank Leaks	None	
466204	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Tank Paint Condition	Good	
466205	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Operations Counter AF	171	
466206	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Maintenance Operations	0	
466207	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	General Comments		
466208	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	General Comments		
466209	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
466210	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
466211	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations Ground	0	
466212	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
466213	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
466214	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
466215	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
466216	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
466217	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
466218	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BCH000906	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
466219	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BCH000906	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
466220	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
466221	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps C Ø	240.0	
466222	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps B Ø	224.0	
466223	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps A Ø	240.0	
466224	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
466225	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
466226	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
466227	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	9 Month Operations	0	
466228	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Unknown Operations	1	
466229	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Tank Paint Condition	Good	
466230	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Switching Operations	0	
466231	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
466232	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Operations This Read Vac	1	
466233	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Operations Counter AL	151	
466234	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Operations Counter AF	151	
466235	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Moisture and Leak Free?	y	
466236	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Maintenance Operations	0	
466237	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Tank Paint Condition	Good	
466238	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Switching Operations	0	
466239	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
466240	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
466241	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
466242	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Operations This Read SF6	0	
466243	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Operations Counter AL	52	
466244	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Operations Counter AF	52	
466245	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Num Operations Last 9 Months	7	
466246	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
466247	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Maintenance Operations	0	
466248	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
466249	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Grounds in Place?	y	
466250	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	General Comments		
466251	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	General Comments		
466252	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
466253	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Foundation Condition	Good	
466254	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Follow-up Action Required?	n	
466255	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Follow-up Action Required?	n	
466256	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Fault Operations	0	
466257	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
466258	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
466259	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
466260	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
466261	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
466262	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Ambient Temperature	64	°F
466263	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Heaters (All) Functioning?	y	
466264	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Grounds in Place?	y	
466265	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	General Comments		
466266	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	General Comments		
466267	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Foundation Condition	Good	
466268	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Follow-up Action Required?	n	
466269	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BCH000906	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
466270	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Unknown Operations	0	
466271	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Switching Operations	0	
466272	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations This Read Vac	2	
466273	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations Counter AL	307	
466274	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations Counter AF	307	
466275	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Maintenance Operations	0	
466276	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	General Comments	AB Phase IOC	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
466277	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	General Comments		
466278	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Follow-up Action Required?	n	
466279	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	Follow-up Action Required?	n	
466280	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations Ground	0	
466281	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations C Ø	0	
466282	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations B Ø	1	
466283	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
466284	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
466285	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	9 Month Operations	13	
466286	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
466287	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
466288	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Follow-up Action Required?	n	
466289	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
466290	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
466291	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	General Comments		
466292	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	General Comments		
466293	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
466294	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	LTC Totalizer Reading	15138.00	kw
466295	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
466296	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
466297	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
466298	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
466299	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
466300	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
466301	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
466302	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
466303	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
466304	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
466305	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
466306	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Top Oil Temperature Max	60	°C
466307	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Top Oil Temperature Present	50	°C
466308	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
466309	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Totalizer Meter Reading	.8410	
466310	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Winding Temp Max	60	°C
466311	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Winding Temp Present	45	°C
466312	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
466313	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
466314	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Unknown Operations	0	
466315	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Switching Operations	0	
466316	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Operations This Read Vac	0	
466317	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Operations Counter AL	162	
466318	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Operations Counter AF	162	
466319	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Maintenance Operations	0	
466320	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	General Comments		
466321	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Patrol Inspection	General Comments		
466322	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Follow-up Action Required?	n	
466323	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Patrol Inspection	Follow-up Action Required?	n	
466324	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations Ground	0	
466325	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations C Ø	0	
466326	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations B Ø	0	
466327	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations A Ø	0	
466328	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
466329	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
466330	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
466331	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Patrol Inspection	Equipment Properly Labeled?	y	
466332	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Amps C Ø	81.0	
466333	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Amps B Ø	57.0	
466334	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Amps A Ø	71.0	
466335	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
466336	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
466337	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	63	°F
466338	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
466339	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
466340	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
466341	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
466342	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
466343	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
466344	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
466345	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
466346	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
466347	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
466348	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	22.0	VDC
466349	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
466350	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
466351	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
466352	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
466353	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	9 Month Operations	0	
466354	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BCH000906	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
466355	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Unknown Operations	0	
466356	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Switching Operations	0	
466357	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Operations This Read Vac	0	
466358	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BCH000906	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
466359	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	BCH000906	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
466360	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Operations Counter AL	171	
466361	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
466362	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
466363	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
466364	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
466365	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
466366	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
466367	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
466368	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Panels Dusted?	y	
466369	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
466370	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
466371	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	General Comments		
466372	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
466373	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
466374	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Floor Swept?	y	
466375	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
466376	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
466377	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Evidence of Insects	None	
466378	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
466379	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
466380	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
466381	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
466382	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
466383	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
466384	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Unknown Operations	0	
466385	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Switching Operations	0	
466386	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Operations This Read AM	0	
466387	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Operations Counter AL	510	
466388	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Operations Counter AF	510	
466389	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Maintenance Operations	0	
466390	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	General Comments		
466391	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Patrol Inspection	General Comments		
466392	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
466393	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
466394	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
466395	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
466396	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
466397	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
466398	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
466399	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
466400	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
466401	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
466402	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Panels Dusted?	y	
466403	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
466404	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
466405	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	General Comments		
466406	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
466407	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
466408	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
466409	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
466410	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Amps C Ø	257.0	
466411	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Amps B Ø	262.0	
466412	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Amps A Ø	258.0	
466413	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
466414	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
466415	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
466416	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	9 Months Operations	0	
466417	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
466418	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Floor Swept?	y	
466419	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
466420	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
466421	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Evidence of Insects	None	
466422	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
466423	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
466424	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
466425	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
466426	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
466427	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
466428	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
466429	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Tank Leaks	None	
466430	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
466431	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
466432	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Regulator As Left Counter	256134	
466433	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
466434	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
466435	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
466436	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
466437	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
466438	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
466439	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations A Ø	1	
466440	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
466441	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
466442	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
466443	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	Equipment Properly Labeled?	y	
466444	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps C Ø	37.0	
466445	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps B Ø	43.0	
466446	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps A Ø	33.0	
466447	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
466448	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
466449	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
466450	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	9 Month Operations	18	
466451	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Follow-up Action Required?	n	
466452	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Operations Ground	0	
466453	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Operations C Ø	0	
466454	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Operations B Ø	0	
466455	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Operations A Ø	0	
466456	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Adjusted Amps C Phase V	4.44	
466457	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Adjusted Amps B Phase V	4.44	
466458	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Adjusted Amps A Phase V	4.44	
466459	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
466460	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
466461	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
466462	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
466463	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
466464	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
466465	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
466466	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
466467	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Equipment Properly Labeled?	y	
466468	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Cabinet Paint Condition	Good	
466469	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
466470	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
466471	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
466472	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Bushings Connection/Risers	Good	
466473	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Bushing Condition	Good	
466474	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Amps C Ø	50.0	
466475	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Amps B Ø	100.0	
466476	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Amps A Ø	60.0	
466477	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
466478	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
466479	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
466480	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
466481	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
466482	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Broom on Site?	y	
466483	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
466484	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
466485	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
466486	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
466487	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Evidence of Insects	None	
466488	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
466489	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
466490	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
466491	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
466492	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
466493	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
466494	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
466495	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
466496	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
466497	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
466498	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
466499	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
466500	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
466501	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
466502	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Floor Swept?	y	
466503	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
466504	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
466505	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	General Comments		
466506	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
466507	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
466508	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Panels Dusted?	y	
466509	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
466510	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
466511	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
466512	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Trash Emptied?	y	
466513	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
466514	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
466515	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
466516	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
466517	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
466518	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Follow-up Action Required?	n	
466519	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
466520	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
466521	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
466522	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
466523	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
466524	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Totalizer Meter Reading	.5260	
466525	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
466526	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
466527	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	LTCC000352	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
466528	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	LTCC000352	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
466529	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	LTCC000352	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
466530	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	LTCC000352	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
466531	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	LTCC000352	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
466532	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	LTCC000352	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
466533	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	LTCC000352	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
466534	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	LTCC000352	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
466535	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	LTCC000352	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
466536	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Patrol Inspection	Follow-up Action Required?	n	
466537	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations Ground	0	
466538	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations C Ø	0	
466539	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations B Ø	0	
466540	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations A Ø	0	
466541	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	9 Month Operations	1	
466542	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
466543	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
466544	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
466545	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Amps A Ø	218.0	
466546	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Amps B Ø	150.0	
466547	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Amps C Ø	22200.0	
466548	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Bushing Condition	Good	
466549	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Bushings Connection/Risers	Good	
466550	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
466551	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
466552	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
466553	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
466554	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
466555	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
466556	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Amps C Ø	100.0	
466557	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Amps B Ø	100.0	
466558	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Amps A Ø	100.0	
466559	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
466560	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
466561	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
466562	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	9 Months Operations	3	
466563	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
466564	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
466565	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
466566	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	Oil Temp Present	41	°C
466567	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	Oil Temp Max	43	°C
466568	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
466569	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
466570	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
466571	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
466572	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
466573	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Tank Leaks	None	
466574	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
466575	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Cabinet Paint Condition	Good	
466576	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
466577	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
466578	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Operations Counter	2333	
466579	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
466580	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
466581	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	General Comments		
466582	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
466583	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
466584	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
466585	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
466586	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Operations A Ø	0	
466587	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Operations B Ø	0	
466588	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Operations C Ø	0	
466589	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Operations Ground	0	
466590	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
466591	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
466592	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
466593	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
466594	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
466595	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
466596	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
466597	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
466598	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
466599	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
466600	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
466601	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
466602	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
466603	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
466604	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
466605	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
466606	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
466607	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
466608	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
466609	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
466610	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
466611	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
466612	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
466613	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
466614	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
466615	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
466616	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
466617	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
466618	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Amps A Ø	15.0	
466619	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Amps B Ø	17.0	
466620	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Amps C Ø	19.0	
466621	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
466622	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
466623	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Unknown Operations	0	
466624	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Switching Operations	0	
466625	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Operations This Read AM	0	
466626	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
466627	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
466628	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
466629	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
466630	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
466631	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
466632	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
466633	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
466634	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	General Comments		
466635	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
466636	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
466637	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Operations Counter	5	
466638	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
466639	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Tank Leaks	None	
466640	4/12/2019 15:11	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
466641	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
466642	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
466643	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
466644	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
466645	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
466646	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
466647	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
466648	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
466649	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
466650	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
466651	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
466652	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
466653	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
466654	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
466655	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Follow-up Action Required?	n	
466656	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
466657	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
466658	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	General Comments		
466659	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	General Comments		
466660	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
466661	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	LTC Totalizer Reading	3156.00	kw
466662	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
466663	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
466664	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Oil Temp Max	60	°C
466665	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Oil Temp Present	38	°C
466666	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
466667	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
466668	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
466669	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Operations Counter AL	192	
466670	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Operations Counter AF	192	
466671	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Maintenance Operations	0	
466672	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	General Comments		
466673	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Patrol Inspection	General Comments		
466674	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Foundation Condition	Good	
466675	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	General Comments		
466676	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	General Comments		
466677	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Grounds in Place?	y	
466678	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Heaters (All) Functioning?	y	
466679	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Maintenance Operations	0	
466680	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Moisture and Leak Free?	y	
466681	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Operations Counter AF	111	
466682	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Operations Counter AL	111	
466683	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Operations This Read Vac	0	
466684	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
466685	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Switching Operations	0	
466686	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Tank Paint Condition	Good	
466687	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Unknown Operations	0	
466688	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Unknown Operations	0	
466689	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Switching Operations	0	
466690	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Operations This Read Vac	0	
466691	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Operations Counter AL	184	
466692	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Operations Counter AF	184	
466693	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Maintenance Operations	0	
466694	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	General Comments		
466695	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	General Comments		
466696	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Follow-up Action Required?	n	
466697	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	Follow-up Action Required?	n	
466698	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations Ground	0	
466699	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations C Ø	0	
466700	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations B Ø	0	
466701	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations A Ø	0	
466702	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
466703	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
466704	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
466705	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	Equipment Properly Labeled?	y	
466706	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Amps C Ø	0.0	
466707	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Amps B Ø	0.0	
466708	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Amps A Ø	0.0	
466709	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
466710	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
466711	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
466712	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	9 Month Operations	0	
466713	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
466714	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
466715	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
466716	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
466717	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
466718	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
466719	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
466720	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
466721	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
466722	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
466723	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
466724	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Unknown Operations	0	
466725	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Switching Operations	0	
466726	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Operations This Read Vac	2	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
466727	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Operations Counter AL	309	
466728	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Operations Counter AF	309	
466729	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Maintenance Operations	0	
466730	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	BCH000390	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
466731	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	BCH000390	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
466732	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	BCH000390	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
466733	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	BCH000390	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
466734	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	BCH000390	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
466735	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	BCH000390	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
466736	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	General Comments	BC Phase IOC	
466737	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	General Comments		
466738	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Follow-up Action Required?	n	
466739	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	Follow-up Action Required?	n	
466740	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations Ground	0	
466741	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations C Ø	1	
466742	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations B Ø	1	
466743	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations A Ø	0	
466744	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
466745	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
466746	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
466747	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	Equipment Properly Labeled?	y	
466748	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Amps C Ø	105.0	
466749	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Amps B Ø	110.0	
466750	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Amps A Ø	119.0	
466751	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
466752	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
466753	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
466754	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
466755	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
466756	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
466757	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	General Comments		
466758	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	General Comments		
466759	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
466760	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
466761	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
466762	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
466763	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
466764	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
466765	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
466766	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
466767	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
466768	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
466769	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
466770	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
466771	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
466772	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
466773	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
466774	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
466775	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
466776	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	1.2	VDC
466777	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.6	VDC
466778	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
466779	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
466780	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	0	
466781	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	0	
466782	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	218	
466783	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	218	
466784	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
466785	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	General Comments		
466786	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
466787	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
466788	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
466789	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
466790	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
466791	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
466792	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
466793	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
466794	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
466795	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
466796	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
466797	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
466798	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
466799	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
466800	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
466801	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
466802	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
466803	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	2	
466804	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Unknown Operations	0	
466805	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Switching Operations	0	
466806	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations This Read Vac	0	
466807	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations Counter AL	282	
466808	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations Counter AF	282	
466809	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Maintenance Operations	0	
466810	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	General Comments		
466811	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	General Comments		
466812	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Follow-up Action Required?	n	
466813	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	Follow-up Action Required?	n	
466814	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations Ground	0	
466815	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations C Ø	0	
466816	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations B Ø	0	
466817	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations A Ø	0	
466818	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
466819	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
466820	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
466821	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	Equipment Properly Labeled?	y	
466822	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps C Ø	12.0	
466823	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps B Ø	14.0	
466824	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps A Ø	12.0	
466825	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
466826	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
466827	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
466828	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	9 Month Operations	0	
466829	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Follow-up Action Required?	n	
466830	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Follow-up Action Required?	n	
466831	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
466832	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	PF000100	PowerFuse	DX-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
466833	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
466834	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
466835	4/12/2019 11:35	Distribution	Dixie Quarterly Inspection	PF000100	PowerFuse	DX-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
466836	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
466837	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
466838	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
466839	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
466840	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
466841	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
466842	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
466843	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
466844	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
466845	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
466846	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
466847	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
466848	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
466849	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
466850	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
466851	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
466852	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Clear of Trash?	y	
466853	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
466854	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
466855	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
466856	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
466857	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
466858	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
466859	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	General Comments		
466860	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
466861	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
466862	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
466863	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
466864	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
466865	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Vegetation	None	
466866	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
466867	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Amps A Ø	350.0	
466868	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Amps B Ø	320.0	
466869	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Amps C Ø	360.0	
466870	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
466871	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
466872	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
466873	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
466874	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations A Ø	0	
466875	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations B Ø	0	
466876	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
466877	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations Ground	0	
466878	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Patrol Inspection	Follow-up Action Required?	n	
466879	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Follow-up Action Required?	n	
466880	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
466881	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
466882	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
466883	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
466884	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
466885	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
466886	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Foundation Condition	Good	
466887	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
466888	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
466889	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	General Comments		
466890	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
466891	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
466892	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
466893	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
466894	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
466895	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Patrol Inspection	General Comments		
466896	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	General Comments		
466897	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Maintenance Operations	0	
466898	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Operations Counter AF	265	
466899	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Operations Counter AL	265	
466900	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
466901	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
466902	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
466903	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Operations This Read AM	0	
466904	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Switching Operations	0	
466905	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Unknown Operations	0	
466906	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
466907	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
466908	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
466909	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
466910	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
466911	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	3.0	VDC
466912	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	3.0	VDC
466913	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
466914	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
466915	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Unknown Operations	0	
466916	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Tank Paint Condition	Good	
466917	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Switching Operations	0	
466918	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
466919	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Operations This Read Vac	0	
466920	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Operations Counter AL	195	
466921	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Operations Counter AF	195	
466922	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
466923	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
466924	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
466925	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
466926	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
466927	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
466928	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
466929	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
466930	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
466931	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
466932	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
466933	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	65.0	VDC
466934	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	66.0	VDC
466935	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
466936	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
466937	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Moisture and Leak Free?	y	
466938	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Maintenance Operations	0	
466939	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Heaters (All) Functioning?	y	
466940	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Grounds in Place?	y	
466941	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	General Comments		
466942	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	General Comments		
466943	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Foundation Condition	Good	
466944	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Follow-up Action Required?	n	
466945	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Follow-up Action Required?	n	
466946	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Operations Ground	0	
466947	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Operations C Ø	0	
466948	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Operations B Ø	0	
466949	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Operations A Ø	0	
466950	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
466951	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
466952	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
466953	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Equipment Properly Labeled?	y	
466954	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Cabinet Paint Condition	Good	
466955	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
466956	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
466957	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
466958	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Bushings Connection/Risers	Good	
466959	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Bushing Condition	Good	
466960	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Amps C Ø	40.0	
466961	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Amps B Ø	40.0	
466962	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Amps A Ø	100.0	
466963	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
466964	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
466965	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
466966	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	9 Months Operations	58	
466967	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
466968	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
466969	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
466970	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	BCH000269	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
466971	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	BCH000269	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
466972	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	BCH000269	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
466973	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
466974	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
466975	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
466976	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
466977	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
466978	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
466979	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
466980	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
466981	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
466982	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
466983	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
466984	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
466985	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
466986	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
466987	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
466988	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
466989	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Radiators are seeping oil. Small amount of oil on ground.	
466990	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Operations Counter AL	637	
466991	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Operations Counter AF	637	
466992	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Maintenance Operations	0	
466993	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	General Comments	A&B Phase IOC & HSI	A Phase TOC
466994	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Patrol Inspection	General Comments		
466995	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Follow-up Action Required?	n	
466996	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Patrol Inspection	Follow-up Action Required?	n	
466997	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Operations Ground	0	
466998	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Operations C Ø	0	
466999	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Operations B Ø	4	
467000	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Operations A Ø	4	
467001	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
467002	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Adjusted Amps B Phase V	44.72	
467003	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Adjusted Amps A Phase V	44.72	
467004	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Patrol Inspection	Equipment Properly Labeled?	y	
467005	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Amps C Ø	100.0	
467006	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	25.0	
467007	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	25.0	
467008	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
467009	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
467010	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
467011	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
467012	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	General Comments		
467013	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
467014	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
467015	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
467016	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
467017	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
467018	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
467019	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
467020	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
467021	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
467022	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
467023	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
467024	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
467025	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
467026	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
467027	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
467028	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
467029	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
467030	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
467031	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
467032	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
467033	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
467034	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
467035	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Amps B Ø	100.0	
467036	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Amps A Ø	100.0	
467037	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
467038	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
467039	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
467040	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	9 Month Operations	17	
467041	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Switching Operations	5	
467042	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
467043	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
467044	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
467045	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
467046	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
467047	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
467048	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
467049	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
467050	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
467051	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
467052	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Operations This Read Vac	5	
467053	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Operations Counter AL	258	
467054	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Operations Counter AF	258	
467055	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Moisture and Leak Free?	y	
467056	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Maintenance Operations	0	
467057	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Heaters (All) Functioning?	y	
467058	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Grounds in Place?	y	
467059	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
467060	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
467061	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
467062	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
467063	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
467064	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
467065	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
467066	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Totalizer Meter Reading	.5870	
467067	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
467068	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
467069	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
467070	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
467071	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Oil Temp Present	43	°C
467072	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Oil Temp Max	44	°C
467073	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
467074	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	VRR Time Delay	30	Seconds
467075	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
467076	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
467077	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	LTC Output Voltage Level	120.4	VAC
467078	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	LTC Operation Checked?	y	
467079	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	General Comments		
467080	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	Follow-up Action Required?	n	
467081	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	All Connections OK?	y	
467082	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
467083	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	704.40	kw
467084	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
467085	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
467086	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	General Comments		
467087	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	General Comments		
467088	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
467089	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
467090	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
467091	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
467092	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
467093	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
467094	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
467095	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
467096	4/12/2019 10:20	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
467097	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
467098	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
467099	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
467100	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
467101	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
467102	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
467103	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
467104	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	General Comments		
467105	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
467106	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	45	°C
467107	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	55	°C
467108	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	34	°C
467109	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	46	°C
467110	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	50	°C
467111	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	55	°C
467112	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
467113	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
467114	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
467115	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
467116	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
467117	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
467118	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
467119	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	Seeping	
467120	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
467121	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
467122	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
467123	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C
467124	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
467125	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
467126	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Tank Paint Condition	Good	
467127	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Switching Operations	0	
467128	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
467129	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	SF6 Pressure	66	psi
467130	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
467131	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Operations This Read SF6	0	
467132	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Operations Counter AL	81	
467133	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Operations Counter AF	81	
467134	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Num Operations Last 9 Months	1	
467135	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
467136	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Maintenance Operations	0	
467137	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Unknown Operations	0	
467138	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Tank Paint Condition	Good	
467139	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	251.0	
467140	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Unknown Operations	0	
467141	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Switching Operations	0	
467142	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Operations This Read Vac	8	
467143	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
467144	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
467145	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
467146	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
467147	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
467148	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
467149	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
467150	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
467151	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
467152	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
467153	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC Current Tap Position	12L	
467154	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC Max Tap Position	8L	
467155	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC Min Tap Position	15L	
467156	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	23	°C
467157	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	32	°C
467158	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	567	
467159	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
467160	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
467161	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
467162	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
467163	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	5.0	
467164	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	5.0	
467165	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	5.0	
467166	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
467167	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
467168	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
467169	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
467170	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
467171	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	67	°F
467172	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
467173	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
467174	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
467175	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
467176	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
467177	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
467178	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
467179	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
467180	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	General Comments		
467181	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
467182	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
467183	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
467184	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
467185	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	LTCC000321	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
467186	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	LTCC000321	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
467187	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	LTCC000321	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
467188	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	LTCC000321	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
467189	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	LTCC000321	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
467190	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	LTCC000321	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
467191	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	LTCC000321	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
467192	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	LTCC000321	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
467193	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Tank Paint Condition	Good	
467194	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Switching Operations	0	
467195	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
467196	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	SF6 Pressure	66	psi
467197	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
467198	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Operations This Read SF6	0	
467199	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Operations Counter AL	80	
467200	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Operations Counter AF	80	
467201	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Num Operations Last 9 Months	1	
467202	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
467203	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Maintenance Operations	0	
467204	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
467205	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	VRR Time Delay	30	Seconds
467206	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
467207	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
467208	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	LTC Output Voltage Level	120.7	VAC
467209	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	LTC Operation Checked?	y	
467210	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	General Comments		
467211	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	Follow-up Action Required?	n	
467212	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	All Connections OK?	y	
467213	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
467214	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
467215	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
467216	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
467217	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
467218	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
467219	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
467220	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	9 Months Operations	7	
467221	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
467222	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
467223	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
467224	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	General Comments		
467225	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
467226	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
467227	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
467228	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
467229	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
467230	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
467231	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
467232	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
467233	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
467234	4/12/2019 12:06	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
467235	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	BCH000399	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
467236	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	BCH000399	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
467237	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	BCH000399	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
467238	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	BCH000399	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
467239	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	BCH000399	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
467240	4/12/2019 8:37	Distribution	Lancaster 1 Quarterly Inspection	BCH000399	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
467241	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	All Connections OK?	y	
467242	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	Follow-up Action Required?	n	
467243	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	General Comments		
467244	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	LTC Operation Checked?	y	
467245	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	LTC Output Voltage Level	122.0	VAC
467246	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
467247	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
467248	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
467249	4/12/2019 11:11	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	VRR Time Delay	30	Seconds
467250	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	PF001218	PowerFuse	529-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	YES	
467251	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	PF001218	PowerFuse	529-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
467252	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
467253	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
467254	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	General Comments		
467255	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
467256	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
467257	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
467258	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
467259	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
467260	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Panels Dusted?	y	
467261	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
467262	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
467263	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	General Comments		
467264	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
467265	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
467266	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Floor Swept?	y	
467267	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
467268	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
467269	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Evidence of Insects	None	
467270	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
467271	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
467272	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
467273	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
467274	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
467275	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
467276	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
467277	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	11	
467278	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
467279	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
467280	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
467281	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC As Found Counter	34227	
467282	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC As Left Counter	34227	
467283	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
467284	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	11	
467285	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	196	
467286	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	196	
467287	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
467288	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
467289	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
467290	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
467291	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
467292	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
467293	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
467294	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
467295	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
467296	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
467297	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
467298	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
467299	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
467300	4/12/2019 11:43	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
467301	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
467302	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
467303	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	General Comments		
467304	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
467305	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
467306	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
467307	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
467308	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	General Comments		
467309	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
467310	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
467311	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
467312	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Foundation Condition	Good	
467313	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
467314	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	PF000184	PowerFuse	HK-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
467315	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	PF000184	PowerFuse	HK-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
467316	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
467317	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
467318	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
467319	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BCH000376	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
467320	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BCH000376	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
467321	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BCH000376	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
467322	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	PF000183	PowerFuse	HK-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
467323	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	PF000183	PowerFuse	HK-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
467324	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BCH000376	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
467325	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BCH000376	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
467326	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BCH000376	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
467327	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
467328	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
467329	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
467330	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Vegetation	None	
467331	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
467332	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
467333	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	General Comments		
467334	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
467335	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
467336	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
467337	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
467338	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
467339	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
467340	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	PF000179	PowerFuse	HL-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
467341	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	PF000179	PowerFuse	HL-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
467342	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Clear of Trash?	y	
467343	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
467344	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
467345	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
467346	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
467347	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
467348	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
467349	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
467350	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
467351	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
467352	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
467353	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
467354	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
467355	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
467356	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	General Comments		
467357	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
467358	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
467359	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
467360	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
467361	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
467362	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
467363	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
467364	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
467365	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Regulator As Left Counter	85594	
467366	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
467367	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
467368	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Tank Leaks	None	
467369	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
467370	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
467371	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	63	°F
467372	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
467373	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
467374	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
467375	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
467376	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
467377	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
467378	4/12/2019 9:35	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
467379	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
467380	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
467381	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Amps A Ø	300.0	
467382	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	BCH000453	Charger	822-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
467383	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	BCH000453	Charger	822-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
467384	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	BCH000453	Charger	822-Battery Charger	Battery Charger Patrol Insp	General Comments		
467385	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
467386	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
467387	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
467388	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
467389	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
467390	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
467391	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
467392	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
467393	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
467394	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
467395	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Amps B Ø	250.0	
467396	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Amps C Ø	260.0	
467397	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
467398	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Adjusted Amps A Phase AM	22.36	
467399	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Adjusted Amps B Phase AM	22.36	
467400	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Adjusted Amps C Phase AM	22.36	
467401	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Operations A Ø	2	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
467402	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Operations B Ø	2	
467403	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Operations C Ø	2	
467404	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Operations Ground	0	
467405	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Patrol Inspection	Follow-up Action Required?	n	
467406	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Follow-up Action Required?	n	
467407	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Patrol Inspection	General Comments		
467408	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	General Comments	A/B/C Phase IOC, A/B Phase HSI	
467409	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Maintenance Operations	0	
467410	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
467411	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
467412	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
467413	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
467414	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
467415	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
467416	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
467417	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
467418	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
467419	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
467420	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Operations Counter AF	1276	
467421	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Operations Counter AL	11276	
467422	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Operations This Read AM	6	
467423	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Switching Operations	0	
467424	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Unknown Operations	0	
467425	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	PF001161	PowerFuse	HK-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
467426	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	PF001161	PowerFuse	HK-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	OK	
467427	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Grounds in Place?	y	
467428	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	General Comments		
467429	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	General Comments		
467430	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
467431	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Foundation Condition	Good	
467432	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Follow-up Action Required?	n	
467433	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Follow-up Action Required?	n	
467434	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Fault Operations	0	
467435	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	PF001162	PowerFuse	HK-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
467436	4/12/2019 15:39	Distribution	Harrods Creek Quarterly Inspection	PF001162	PowerFuse	HK-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	OK	
467437	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
467438	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
467439	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
467440	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
467441	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
467442	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
467443	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
467444	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
467445	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
467446	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
467447	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
467448	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Ambient Temperature	65	°F
467449	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
467450	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
467451	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
467452	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
467453	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
467454	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
467455	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
467456	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
467457	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
467458	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	General Comments		
467459	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
467460	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
467461	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Operations C Ø	0	
467462	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Operations Ground	0	
467463	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
467464	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Follow-up Action Required?	n	
467465	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
467466	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
467467	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
467468	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
467469	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
467470	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
467471	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
467472	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
467473	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
467474	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
467475	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
467476	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
467477	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC Operations Since Last Insp	534	
467478	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
467479	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
467480	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC Min Tap Position	9L	
467481	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC Max Tap Position	5L	
467482	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC Current Tap Position	6L	
467483	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Follow-up Action Required?	n	
467484	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Follow-up Action Required?	n	
467485	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
467486	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Foundation Condition	Good	
467487	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	General Comments		
467488	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
467489	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC As Left Counter	154622	
467490	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC As Found Counter	154622	
467491	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Regulator As Left Counter	7320	
467492	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
467493	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	General Comments		
467494	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	General Comments		
467495	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
467496	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	Follow-up Action Required?	n	
467497	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
467498	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
467499	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
467500	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Tank Leaks	None	
467501	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
467502	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
467503	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
467504	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
467505	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
467506	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
467507	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
467508	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
467509	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	Yes_sprayed	
467510	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
467511	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	n	
467512	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	y	
467513	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
467514	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
467515	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
467516	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
467517	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Clear of Trash?	y	
467518	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
467519	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	Need 2 pieces of 18x9 filter material cut for doors	
467520	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
467521	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
467522	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
467523	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
467524	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
467525	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Ambient Temp	63	°F
467526	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
467527	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
467528	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
467529	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
467530	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
467531	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Trash Emptied?	y	
467532	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
467533	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
467534	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
467535	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
467536	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
467537	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
467538	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
467539	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
467540	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
467541	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BCH000438	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
467542	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
467543	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Operations A Ø	0	
467544	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Operations B Ø	0	
467545	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
467546	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
467547	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
467548	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
467549	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
467550	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	General Comments		
467551	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BCH000438	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
467552	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Amps A Ø	0.0	
467553	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Amps B Ø	0.0	
467554	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
467555	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
467556	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
467557	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
467558	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
467559	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
467560	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
467561	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
467562	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
467563	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
467564	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
467565	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
467566	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
467567	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
467568	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Foundation Condition	Good	
467569	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
467570	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
467571	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.1	VDC
467572	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Operations B Ø	0	
467573	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	BCH000598	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
467574	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Operations A Ø	0	
467575	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
467576	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
467577	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
467578	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
467579	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Amps C Ø	25.0	
467580	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Amps B Ø	100.0	
467581	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Amps A Ø	340.0	
467582	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	BCH000598	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
467583	4/12/2019 12:25	Distribution	Garrard Ct Quarterly Inspection	BCH000598	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
467584	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
467585	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
467586	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
467587	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
467588	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
467589	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
467590	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	9 Months Operations	2	
467591	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
467592	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
467593	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	General Comments		
467594	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
467595	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
467596	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Unknown Operations	0	
467597	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Switching Operations	0	
467598	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Operations This Read AM	0	
467599	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Operations Counter AL	873	
467600	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Operations Counter AF	873	
467601	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Maintenance Operations	0	
467602	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	General Comments		
467603	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Patrol Inspection	General Comments		
467604	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Follow-up Action Required?	n	
467605	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Panels Dusted?	y	
467606	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
467607	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
467608	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	General Comments		
467609	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
467610	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
467611	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Floor Swept?	y	
467612	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
467613	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
467614	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
467615	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
467616	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Amps A Ø	19.0	
467617	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Amps B Ø	26.0	
467618	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Amps C Ø	20.0	
467619	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
467620	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
467621	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
467622	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
467623	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
467624	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Patrol Inspection	Follow-up Action Required?	n	
467625	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Operations Ground	0	
467626	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
467627	4/12/2019 10:40	Distribution	Fredonia Quarry Quarterly Inspection	BCH000438	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
467628	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
467629	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
467630	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
467631	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
467632	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
467633	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Evidence of Insects	None	
467634	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
467635	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
467636	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
467637	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
467638	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Broom on Site?	y	
467639	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
467640	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
467641	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
467642	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
467643	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
467644	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
467645	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
467646	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
467647	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
467648	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
467649	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	804	
467650	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Amps C Ø	24.0	
467651	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Amps B Ø	23.0	
467652	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Amps A Ø	25.0	
467653	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
467654	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
467655	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
467656	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
467657	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
467658	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
467659	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
467660	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Totalizer Meter Reading	.7500	
467661	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
467662	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
467663	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	867	
467664	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	9 Month Operations	4	
467665	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
467666	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
467667	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
467668	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
467669	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
467670	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
467671	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
467672	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
467673	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
467674	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
467675	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
467676	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
467677	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
467678	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
467679	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
467680	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
467681	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
467682	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	General Comments		
467683	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
467684	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
467685	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Foundation Condition	Good	
467686	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
467687	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
467688	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	General Comments		
467689	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
467690	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
467691	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
467692	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
467693	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
467694	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
467695	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Clear of Trash?	y	
467696	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
467697	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
467698	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	1217	
467699	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
467700	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
467701	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
467702	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
467703	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
467704	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
467705	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
467706	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
467707	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
467708	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
467709	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
467710	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
467711	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
467712	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
467713	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
467714	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
467715	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
467716	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
467717	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
467718	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
467719	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
467720	4/13/2019 9:51	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
467721	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
467722	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
467723	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
467724	4/12/2019 10:28	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
467725	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC As Found Counter	32329	
467726	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC As Left Counter	32334	
467727	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
467728	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Operations Counter AL	245	
467729	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Operations Counter AF	245	
467730	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
467731	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
467732	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	LTC Totalizer Reading	2400.00	kw
467733	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
467734	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Operations Counter	485	
467735	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
467736	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	General Comments		
467737	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	General Comments		
467738	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Fans Operational?	y	
467739	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
467740	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
467741	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
467742	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	General Comments		
467743	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
467744	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
467745	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
467746	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
467747	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
467748	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
467749	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
467750	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
467751	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
467752	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
467753	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
467754	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
467755	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
467756	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
467757	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
467758	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
467759	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
467760	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
467761	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
467762	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
467763	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
467764	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
467765	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Vegetation	None	
467766	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
467767	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
467768	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	General Comments		
467769	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
467770	4/12/2019 9:05	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
467771	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
467772	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
467773	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
467774	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
467775	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	Follow-up Action Required?	n	
467776	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
467777	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
467778	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Maintenance Operations	0	
467779	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
467780	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Operations This Read Vac	1	
467781	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
467782	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Switching Operations	1	
467783	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Tank Paint Condition	Good	
467784	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Unknown Operations	0	
467785	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
467786	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
467787	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
467788	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
467789	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
467790	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
467791	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC
467792	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
467793	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
467794	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
467795	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
467796	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	General Comments		
467797	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Oil Temp Present	30	°C
467798	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
467799	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
467800	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
467801	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
467802	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
467803	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Oil Temp Max	35	°C
467804	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
467805	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
467806	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
467807	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
467808	4/12/2019 13:47	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Fans Condition	Good	
467809	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
467810	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
467811	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
467812	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
467813	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
467814	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
467815	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
467816	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
467817	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
467818	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
467819	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
467820	4/12/2019 14:35	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
467821	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
467822	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
467823	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
467824	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
467825	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
467826	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
467827	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Amps A Ø	25.0	
467828	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
467829	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
467830	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
467831	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Tank Leaks	None	
467832	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	9 Month Operations	1	
467833	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
467834	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
467835	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
467836	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Amps A Ø	600.0	
467837	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
467838	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
467839	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
467840	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	General Comments		
467841	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	BAT000391	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
467842	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	BAT000391	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
467843	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
467844	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
467845	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
467846	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
467847	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
467848	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
467849	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
467850	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
467851	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
467852	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
467853	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	General Comments		
467854	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
467855	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
467856	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
467857	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
467858	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
467859	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
467860	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
467861	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
467862	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
467863	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Amps B Ø	600.0	
467864	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
467865	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
467866	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
467867	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
467868	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
467869	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
467870	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Amps C Ø	600.0	
467871	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Bushing Condition	Good	
467872	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
467873	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
467874	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
467875	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
467876	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
467877	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC Operations Since Last Insp	810	
467878	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
467879	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
467880	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Nitro gauge at 0	
467881	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
467882	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
467883	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
467884	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
467885	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
467886	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
467887	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
467888	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	58	°F
467889	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
467890	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
467891	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
467892	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Regulator As Left Counter	117372	
467893	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
467894	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
467895	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
467896	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
467897	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
467898	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
467899	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
467900	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
467901	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
467902	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
467903	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
467904	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
467905	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
467906	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	General Comments		
467907	4/12/2019 10:30	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Grounds in Place?	y	
467908	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	BAT000391	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
467909	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	BAT000391	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.2	VDC
467910	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	BAT000391	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.2	VDC
467911	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	BAT000391	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
467912	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
467913	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
467914	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	General Comments		
467915	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	General Comments		
467916	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
467917	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
467918	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
467919	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
467920	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
467921	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	BAT000391	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
467922	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	BAT000391	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
467923	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	General Comments		
467924	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
467925	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
467926	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Operations Counter	83	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
467927	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
467928	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
467929	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
467930	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
467931	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	BAT000391	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
467932	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	BAT000391	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
467933	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
467934	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	BAT000391	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
467935	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
467936	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	General Comments		
467937	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Grounds in Place?	y	
467938	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
467939	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
467940	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
467941	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
467942	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
467943	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
467944	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
467945	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
467946	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
467947	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Amps B Ø	26.0	
467948	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
467949	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
467950	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Amps C Ø	23.0	
467951	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
467952	4/12/2019 11:29	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
467953	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
467954	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
467955	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
467956	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
467957	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
467958	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Operations Counter	174	
467959	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
467960	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	General Comments		
467961	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
467962	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
467963	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
467964	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
467965	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
467966	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
467967	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
467968	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
467969	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
467970	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
467971	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
467972	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
467973	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
467974	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
467975	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	General Comments		
467976	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
467977	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
467978	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
467979	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
467980	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Bushing Condition	Good	
467981	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
467982	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
467983	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
467984	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Switching Operations	1	
467985	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Tank Paint Condition	Good	
467986	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Unknown Operations	0	
467987	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	General Comments		
467988	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
467989	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Vegetation	None	
467990	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
467991	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
467992	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
467993	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
467994	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
467995	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
467996	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Amps C Ø	0.0	
467997	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	38	
467998	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	38	
467999	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
468000	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
468001	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
468002	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC Min Tap Position	11L	
468003	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
468004	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
468005	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
468006	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
468007	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
468008	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
468009	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
468010	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
468011	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
468012	4/12/2019 12:43	Distribution	Cedar Bluff Quarterly Inspection	BAT000391	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
468013	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
468014	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
468015	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
468016	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.1	VDC
468017	4/12/2019 13:55	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
468018	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Maintenance Operations	0	
468019	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	459.36	kw
468020	4/12/2019 13:31	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
468021	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
468022	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
468023	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
468024	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Amps A Ø	2.0	
468025	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Amps B Ø	2.0	
468026	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
468027	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
468028	4/12/2019 13:05	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Amps C Ø	2.0	
468029	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
468030	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Operations A Ø	0	
468031	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Operations B Ø	0	
468032	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
468033	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
468034	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
468035	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Operations Counter AF	179	
468036	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Operations Counter AL	179	
468037	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Operations This Read Vac	1	
468038	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Operations C Ø	0	
468039	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Operations Ground	0	
468040	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Follow-up Action Required?	n	
468041	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
468042	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	67	°F
468043	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
468044	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
468045	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
468046	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
468047	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
468048	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
468049	4/12/2019 13:21	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
468050	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Follow-up Action Required?	n	
468051	4/12/2019 10:38	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Foundation Condition	Good	
468052	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
468053	4/12/2019 9:13	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
468054	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
468055	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
468056	4/12/2019 14:51	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
468057	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC Current Tap Position	8L	
468058	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC Max Tap Position	3L	
468059	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC Min Tap Position	14L	
468060	4/12/2019 17:12	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC Operations Since Last Insp	1772	
468061	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
468062	4/12/2019 10:19	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
468063	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AF	641	
468064	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Num Operations Last 9 Months	1	
468065	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AL	641	
468066	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Operations This Read SF6	0	
468067	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Maintenance Operations	0	
468068	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	General Comments		
468069	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Follow-up Action Required?	n	
468070	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Fault Operations	0	
468071	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Switching Operations	0	
468072	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Foundation Condition	Good	
468073	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Ambient Temperature	81	°F
468074	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Tank Paint Condition	Good	
468075	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Bushings Connection/Risers	Good	
468076	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
468077	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Grounds in Place?	y	
468078	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
468079	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
468080	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Heaters (All) Functioning?	y	
468081	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Pressure Indicator	good	
468082	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Bushing Condition	Good	
468083	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Gauge(s) Condition	Good	
468084	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Follow-up Action Required?	n	
468085	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Moisture and Leak Free?	y	
468086	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Paint Condition	Good	
468087	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	General Comments		
468088	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
468089	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	LTCC000828	LTCControl	863-1	LTC Control Insp	LTC Operation Checked?	y	
468090	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	LTCC000828	LTCControl	863-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
468091	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	LTCC000828	LTCControl	863-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
468092	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	LTCC000828	LTCControl	863-1	LTC Control Insp	General Comments		
468093	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	LTCC000828	LTCControl	863-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
468094	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	LTCC000828	LTCControl	863-1	LTC Control Insp	VRR Time Delay	30	Seconds
468095	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	LTCC000828	LTCControl	863-1	LTC Control Insp	All Connections OK?	y	
468096	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	LTCC000828	LTCControl	863-1	LTC Control Insp	Follow-up Action Required?	n	
468097	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
468098	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	40	°C
468099	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.3120	
468100	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	50	°C
468101	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
468102	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
468103	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
468104	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
468105	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
468106	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	998.40	kw
468107	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
468108	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
468109	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
468110	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
468111	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
468112	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
468113	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
468114	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
468115	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
468116	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
468117	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
468118	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
468119	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
468120	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
468121	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
468122	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
468123	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
468124	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
468125	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
468126	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
468127	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
468128	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
468129	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
468130	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
468131	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
468132	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	General Comments		
468133	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Operations B Ø	0	
468134	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
468135	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
468136	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
468137	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
468138	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
468139	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Broom on Site?	y	
468140	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
468141	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Follow-up Action Required?	n	
468142	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Follow-up Action Required?	n	
468143	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Operations A Ø	0	
468144	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
468145	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Panels Dusted?	y	
468146	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
468147	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
468148	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
468149	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
468150	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
468151	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
468152	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	General Comments		
468153	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
468154	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
468155	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
468156	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
468157	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
468158	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Floor Swept?	y	
468159	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
468160	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Foundation Condition	Good	
468161	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	General Comments		
468162	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	General Comments		
468163	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
468164	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
468165	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	General Comments		
468166	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Grounds in Place?	y	
468167	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Maintenance Operations	0	
468168	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Evidence of Insects	None	
468169	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Heaters (All) Functioning?	y	
468170	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
468171	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Maintenance Operations	0	
468172	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
468173	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
468174	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
468175	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
468176	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
468177	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
468178	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
468179	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
468180	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
468181	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
468182	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
468183	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
468184	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Amps B Ø	50.0	
468185	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Amps A Ø	60.0	
468186	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
468187	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
468188	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Operations Counter AF	255	
468189	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Operations Counter AL	255	
468190	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
468191	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	9 Months Operations	1	
468192	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Operations A Ø	0	
468193	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
468194	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
468195	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
468196	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Operations This Read Vac	0	
468197	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Switching Operations	0	
468198	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
468199	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	74	°F
468200	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4938	
468201	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
468202	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Operations A Ø	0	
468203	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Unknown Operations	0	
468204	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Patrol Inspection	Equipment Properly Labeled?	y	
468205	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Amps C Ø	47.0	
468206	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Amps B Ø	37.0	
468207	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	General Comments		
468208	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Foundation Condition	Good	
468209	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Follow-up Action Required?	n	
468210	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Follow-up Action Required?	n	
468211	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Operations Ground	0	
468212	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
468213	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
468214	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Follow-up Action Required?	n	
468215	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
468216	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
468217	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	9 Month Operations	0	
468218	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
468219	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
468220	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
468221	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
468222	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
468223	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
468224	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Operations B Ø	0	
468225	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
468226	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
468227	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Operations Ground	0	
468228	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
468229	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
468230	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
468231	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
468232	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
468233	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
468234	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
468235	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Operations C Ø	0	
468236	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
468237	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
468238	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
468239	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Equipment Properly Labeled?	y	
468240	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Cabinet Paint Condition	Good	
468241	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
468242	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
468243	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
468244	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Bushings Connection/Risers	Good	
468245	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Operations C Ø	0	
468246	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Operations B Ø	0	
468247	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Grounds in Place?	y	
468248	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Operations A Ø	0	
468249	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
468250	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
468251	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
468252	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Maintenance Operations	0	
468253	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
468254	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
468255	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
468256	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Maintenance Operations	0	
468257	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Operations Counter AF	111	
468258	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Operations Counter AL	111	
468259	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
468260	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC Operations Since Last Insp	952	
468261	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC Min Tap Position	11L	
468262	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Operations Counter AF	166	
468263	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Operations Counter AL	166	
468264	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Operations This Read Vac	0	
468265	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
468266	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
468267	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Switching Operations	0	
468268	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Tank Paint Condition	Good	
468269	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
468270	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Operations This Read Vac	1	
468271	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
468272	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
468273	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC As Found Counter	30739	
468274	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC As Left Counter	30740	
468275	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Bushing Condition	Good	
468276	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Amps C Ø	320.0	
468277	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC Current Tap Position	4L	
468278	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC Max Tap Position	2L	
468279	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Amps B Ø	320.0	
468280	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Amps A Ø	320.0	
468281	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
468282	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
468283	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Switching Operations	0	
468284	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Unknown Operations	1	
468285	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	9 Month Operations	21	
468286	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
468287	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
468288	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Unknown Operations	0	
468289	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Operations C Ø	0	
468290	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Operations B Ø	0	
468291	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Operations A Ø	0	
468292	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
468293	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
468294	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
468295	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Amps A Ø	38.0	
468296	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC Min Tap Position	9L	
468297	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC Operations Since Last Insp	674	
468298	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
468299	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
468300	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	Follow-up Action Required?	n	
468301	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	9 Month Operations	10	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
468302	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC Max Tap Position	Neutral	
468303	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
468304	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
468305	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Amps A Ø	98.0	
468306	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Amps B Ø	85.0	
468307	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Amps C Ø	93.0	
468308	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Patrol Inspection	Equipment Properly Labeled?	y	
468309	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
468310	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
468311	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	General Comments	as left counter was incorrectly entered as 3065	
468312	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC As Found Counter	30065	
468313	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC As Left Counter	30065	
468314	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC Current Tap Position	3L	
468315	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
468316	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
468317	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
468318	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
468319	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Trash Emptied?	y	
468320	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Moisture and Leak Free?	y	
468321	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
468322	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
468323	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
468324	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	PF000306	PowerFuse	SY-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
468325	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
468326	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Operations A Ø	0	
468327	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Operations B Ø	0	
468328	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Operations C Ø	0	
468329	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Operations Ground	0	
468330	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Patrol Inspection	Follow-up Action Required?	n	
468331	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Follow-up Action Required?	n	
468332	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Patrol Inspection	General Comments		
468333	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	General Comments		
468334	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	General Comments		
468335	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
468336	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
468337	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
468338	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
468339	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Equipment Properly Labeled?	y	
468340	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Cabinet Paint Condition	Good	
468341	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
468342	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	General Comments		
468343	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
468344	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
468345	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
468346	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
468347	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	PF000307	PowerFuse	SY-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
468348	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	PF000307	PowerFuse	SY-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
468349	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
468350	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
468351	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Patrol Inspection	General Comments		
468352	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Clear of Trash?	y	
468353	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Follow-up Action Required?	n	
468354	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Patrol Inspection	Follow-up Action Required?	n	
468355	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
468356	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
468357	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
468358	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Operations Counter AF	303	
468359	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Operations Counter AL	303	
468360	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Operations Ground	0	
468361	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Operations This Read Vac	4	
468362	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
468363	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Bushing Condition	Good	
468364	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Amps C Ø	170.0	
468365	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Amps B Ø	130.0	
468366	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Amps A Ø	180.0	
468367	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
468368	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
468369	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
468370	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
468371	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	Follow-up Action Required?	n	
468372	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	General Comments	LTC counter was entered wrong last check.	
468373	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Switching Operations	4	
468374	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
468375	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
468376	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	9 Month Operations	4	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
468377	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	General Comments		
468378	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	General Comments		
468379	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Foundation Condition	Good	
468380	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Tank Paint Condition	Good	
468381	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Follow-up Action Required?	n	
468382	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Unknown Operations	0	
468383	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Follow-up Action Required?	n	
468384	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Operations Ground	0	
468385	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Maintenance Operations	0	
468386	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Moisture and Leak Free?	y	
468387	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Operations Counter AF	156	
468388	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Operations Counter AL	156	
468389	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Operations This Read Vac	4	
468390	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Maintenance Operations	0	
468391	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Grounds in Place?	y	
468392	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	General Comments		
468393	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	General Comments		
468394	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Foundation Condition	Good	
468395	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Follow-up Action Required?	n	
468396	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Follow-up Action Required?	n	
468397	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Operations Ground	0	
468398	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	General Comments		
468399	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
468400	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
468401	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Operations C Ø	0	
468402	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Operations B Ø	0	
468403	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Operations A Ø	0	
468404	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
468405	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
468406	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
468407	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Equipment Properly Labeled?	y	
468408	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Cabinet Paint Condition	Good	
468409	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
468410	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
468411	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
468412	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Bushings Connection/Risers	Good	
468413	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Bushing Condition	Good	
468414	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Amps C Ø	97.0	
468415	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Amps B Ø	74.0	
468416	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Amps A Ø	68.0	
468417	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
468418	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	General Comments		
468419	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Grounds in Place?	y	
468420	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
468421	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Maintenance Operations	0	
468422	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
468423	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Operations Counter AF	393	
468424	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Operations Counter AL	393	
468425	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Operations This Read Vac	3	
468426	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
468427	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
468428	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
468429	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
468430	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
468431	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
468432	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
468433	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
468434	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Switching Operations	3	
468435	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
468436	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
468437	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
468438	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
468439	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
468440	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Tank Paint Condition	Good	
468441	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Unknown Operations	0	
468442	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
468443	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	General Comments		
468444	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
468445	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
468446	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Foundation Condition	Good	
468447	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
468448	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
468449	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	9 Month Operations	1	
468450	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC As Left Counter	102026	
468451	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC As Found Counter	102022	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
468452	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Amps A Ø	64.0	
468453	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	General Comments		
468454	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	General Comments		
468455	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
468456	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	Follow-up Action Required?	n	
468457	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
468458	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
468459	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
468460	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
468461	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	208	
468462	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	208	
468463	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
468464	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
468465	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
468466	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
468467	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
468468	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
468469	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
468470	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
468471	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	9 Month Operations	2	
468472	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Unknown Operations	0	
468473	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Tank Paint Condition	Good	
468474	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Switching Operations	1	
468475	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Operations This Read Vac	1	
468476	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Operations Counter AL	169	
468477	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Operations Counter AF	169	
468478	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Moisture and Leak Free?	y	
468479	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	General Comments		
468480	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
468481	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
468482	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
468483	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
468484	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
468485	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
468486	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
468487	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
468488	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
468489	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
468490	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
468491	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
468492	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Foundation Condition	Good	
468493	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
468494	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
468495	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
468496	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
468497	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	345	
468498	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
468499	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	8L	
468500	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	2L	
468501	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	6L	
468502	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
468503	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	1365	
468504	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	1357	
468505	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
468506	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
468507	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	General Comments		
468508	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
468509	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
468510	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
468511	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
468512	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
468513	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
468514	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Grounds in Place?	y	
468515	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Heaters (All) Functioning?	y	
468516	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
468517	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
468518	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
468519	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
468520	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
468521	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
468522	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
468523	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
468524	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
468525	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
468526	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	221	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
468527	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	221	
468528	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
468529	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
468530	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
468531	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
468532	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
468533	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
468534	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
468535	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
468536	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	480.0	
468537	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	480.0	
468538	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	470.0	
468539	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
468540	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
468541	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
468542	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
468543	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
468544	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
468545	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
468546	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	VRR Time Delay	30	Seconds
468547	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
468548	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
468549	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
468550	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
468551	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
468552	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
468553	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
468554	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
468555	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
468556	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
468557	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
468558	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	5.0	
468559	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	5.0	
468560	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	5.0	
468561	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
468562	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
468563	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
468564	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
468565	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
468566	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
468567	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
468568	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
468569	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
468570	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
468571	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
468572	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
468573	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
468574	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
468575	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
468576	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	LTC Operation Checked?	y	
468577	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	General Comments		
468578	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
468579	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
468580	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
468581	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
468582	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Switching Operations	4	
468583	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
468584	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
468585	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
468586	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
468587	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Tank Paint Condition	Good	
468588	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Unknown Operations	0	
468589	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
468590	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
468591	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
468592	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
468593	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
468594	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
468595	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
468596	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Vegetation	None	
468597	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
468598	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
468599	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
468600	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
468601	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
468602	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	General Comments		
468603	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
468604	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
468605	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
468606	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
468607	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
468608	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Switching Operations	0	
468609	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Unknown Operations	0	
468610	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
468611	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
468612	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
468613	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Amps A Ø	90.0	
468614	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Amps B Ø	90.0	
468615	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Amps C Ø	70.0	
468616	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
468617	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
468618	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
468619	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
468620	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
468621	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
468622	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
468623	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
468624	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
468625	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
468626	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
468627	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
468628	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
468629	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
468630	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
468631	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
468632	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
468633	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Clear of Trash?	y	
468634	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
468635	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
468636	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
468637	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Amps C Ø	85.0	
468638	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Patrol Inspection	Equipment Properly Labeled?	y	
468639	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
468640	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
468641	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
468642	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
468643	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
468644	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
468645	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
468646	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
468647	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC Current Tap Position	12L	
468648	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC Max Tap Position	7L	
468649	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
468650	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
468651	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	154	
468652	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
468653	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
468654	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
468655	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
468656	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Heaters (All) Functioning?	y	
468657	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Maintenance Operations	0	
468658	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Moisture and Leak Free?	y	
468659	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Operations Counter AF	186	
468660	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	9 Month Operations	13	
468661	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
468662	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
468663	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
468664	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
468665	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Vegetation	None	
468666	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
468667	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
468668	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	General Comments		
468669	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
468670	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
468671	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
468672	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
468673	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
468674	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	LTC Totalizer Reading	2213.76	kw
468675	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
468676	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
468677	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Oil Temp Max	60	°C
468678	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Oil Temp Present	45	°C
468679	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
468680	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
468681	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
468682	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
468683	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
468684	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
468685	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
468686	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
468687	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Totalizer Meter Reading	.6918	
468688	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Amps A Ø	89.0	
468689	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Operations Counter AF	168	
468690	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Operations Counter AL	168	
468691	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Operations This Read Vac	0	
468692	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Switching Operations	0	
468693	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Unknown Operations	0	
468694	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	9 Month Operations	22	
468695	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
468696	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
468697	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
468698	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Amps A Ø	25.0	
468699	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Amps B Ø	16.0	
468700	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Amps C Ø	17.0	
468701	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Patrol Inspection	Equipment Properly Labeled?	y	
468702	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
468703	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
468704	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
468705	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
468706	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
468707	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
468708	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
468709	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Clear of Trash?	y	
468710	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
468711	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Ambient Temp	57	°F
468712	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
468713	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
468714	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
468715	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
468716	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LTCC000518	LTCControl	HN-TRANS 1	LTC Control Insp	All Connections OK?	y	
468717	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LTCC000518	LTCControl	HN-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
468718	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LTCC000518	LTCControl	HN-TRANS 1	LTC Control Insp	General Comments		
468719	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
468720	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	General Comments		
468721	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
468722	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
468723	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Foundation Condition	Good	
468724	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
468725	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Operations B Ø	0	
468726	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Operations C Ø	0	
468727	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Operations Ground	0	
468728	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Patrol Inspection	Follow-up Action Required?	n	
468729	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Follow-up Action Required?	n	
468730	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Patrol Inspection	General Comments		
468731	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	General Comments		
468732	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Maintenance Operations	0	
468733	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	General Comments		
468734	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
468735	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
468736	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
468737	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
468738	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Operations A Ø	0	
468739	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
468740	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
468741	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
468742	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
468743	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
468744	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
468745	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
468746	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
468747	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	General Comments		
468748	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Amps C Ø	60.0	
468749	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
468750	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
468751	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
468752	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
468753	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Operations A Ø	0	
468754	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Operations B Ø	0	
468755	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Operations C Ø	0	
468756	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Operations Ground	0	
468757	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Patrol Inspection	Follow-up Action Required?	n	
468758	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Follow-up Action Required?	n	
468759	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Operations B Ø	0	
468760	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Operations C Ø	0	
468761	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Operations Ground	0	
468762	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Follow-up Action Required?	n	
468763	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Follow-up Action Required?	n	
468764	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Foundation Condition	Good	
468765	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	General Comments		
468766	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	General Comments		
468767	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Grounds in Place?	y	
468768	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	General Comments		
468769	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	General Comments		
468770	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
468771	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
468772	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
468773	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
468774	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
468775	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC As Found Counter	252123	
468776	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC As Left Counter	252123	
468777	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
468778	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	General Comments		
468779	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Foundation Condition	Good	
468780	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Follow-up Action Required?	n	
468781	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Follow-up Action Required?	n	
468782	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Operations Ground	0	
468783	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Operations C Ø	0	
468784	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Operations B Ø	0	
468785	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Operations A Ø	0	
468786	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
468787	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Patrol Inspection	Equipment Properly Labeled?	y	
468788	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
468789	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
468790	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
468791	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Operations A Ø	0	
468792	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Operations B Ø	0	
468793	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Operations C Ø	0	
468794	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Operations Ground	0	
468795	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Patrol Inspection	Follow-up Action Required?	n	
468796	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Follow-up Action Required?	n	
468797	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Patrol Inspection	General Comments		
468798	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	VRR Time Delay	30	Seconds
468799	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
468800	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	General Comments		
468801	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Maintenance Operations	0	
468802	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
468803	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
468804	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	LTC Output Voltage Level	123.1	VAC
468805	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
468806	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
468807	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Operations A Ø	0	
468808	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Operations B Ø	0	
468809	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Operations C Ø	0	
468810	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Operations Ground	0	
468811	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Follow-up Action Required?	n	
468812	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Follow-up Action Required?	n	
468813	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Foundation Condition	Good	
468814	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	General Comments		
468815	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
468816	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
468817	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
468818	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
468819	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
468820	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC Operations Since Last Insp	158	
468821	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC Min Tap Position	8L	
468822	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC Max Tap Position	4L	
468823	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Operations Counter AF	150	
468824	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Operations Counter AL	150	
468825	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Operations This Read Vac	0	
468826	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Switching Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
468827	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
468828	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Equipment Properly Labeled?	y	
468829	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Cabinet Paint Condition	Good	
468830	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
468831	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
468832	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
468833	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Bushings Connection/Risers	Good	
468834	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Bushing Condition	Good	
468835	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Amps C Ø	62.0	
468836	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Unknown Operations	0	
468837	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Amps B Ø	71.0	
468838	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	LTC Operation Checked?	y	
468839	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	General Comments		
468840	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	Follow-up Action Required?	n	
468841	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	All Connections OK?	y	
468842	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC Current Tap Position	6L	
468843	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
468844	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Operations A Ø	0	
468845	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Operations B Ø	0	
468846	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Operations C Ø	0	
468847	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Operations Ground	0	
468848	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Patrol Inspection	Follow-up Action Required?	n	
468849	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Follow-up Action Required?	n	
468850	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Patrol Inspection	General Comments		
468851	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	General Comments		
468852	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
468853	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
468854	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
468855	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
468856	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
468857	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
468858	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
468859	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
468860	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
468861	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Patrol Inspection	General Comments		
468862	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	General Comments		
468863	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Maintenance Operations	0	
468864	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	9 Month Operations	3	
468865	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
468866	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
468867	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
468868	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Amps A Ø	320.0	
468869	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Amps B Ø	320.0	
468870	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Amps C Ø	320.0	
468871	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Bushing Condition	Good	
468872	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
468873	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
468874	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
468875	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
468876	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
468877	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
468878	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Operations Counter AF	94	
468879	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Operations Counter AL	94	
468880	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Operations This Read AM	0	
468881	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Maintenance Operations	0	
468882	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Operations Counter AF	137	
468883	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Operations Counter AL	137	
468884	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Operations This Read Vac	0	
468885	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Switching Operations	0	
468886	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Unknown Operations	0	
468887	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	9 Month Operations	0	
468888	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
468889	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Amps B Ø	86.0	
468890	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Operations Counter AL	186	
468891	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Operations This Read Vac	0	
468892	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Switching Operations	0	
468893	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Unknown Operations	0	
468894	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Tank Paint Condition	Good	
468895	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
468896	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
468897	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Amps A Ø	0.0	
468898	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Amps B Ø	0.0	
468899	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Amps C Ø	0.0	
468900	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Tank Paint Condition	Good	
468901	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
468902	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Switching Operations	1	
468903	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Operations This Read Vac	1	
468904	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Operations Counter AL	181	
468905	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Operations Counter AF	181	
468906	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Moisture and Leak Free?	y	
468907	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Maintenance Operations	0	
468908	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Grounds in Place?	y	
468909	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	General Comments		
468910	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
468911	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
468912	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	General Comments		
468913	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
468914	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
468915	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
468916	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
468917	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
468918	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
468919	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
468920	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
468921	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Amps B Ø	50.0	
468922	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Amps A Ø	0.0	
468923	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Amps B Ø	0.0	
468924	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
468925	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
468926	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
468927	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Amps C Ø	0.0	
468928	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Bushing Condition	Good	
468929	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Bushings Connection/Risers	Good	
468930	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Bushings Connection/Risers	Good	
468931	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
468932	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
468933	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
468934	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
468935	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Cabinet Paint Condition	Good	
468936	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Equipment Properly Labeled?	y	
468937	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
468938	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
468939	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
468940	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Operations A Ø	0	
468941	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Operations B Ø	0	
468942	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Operations C Ø	0	
468943	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Operations Ground	0	
468944	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
468945	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
468946	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
468947	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Foundation Condition	Good	
468948	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
468949	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
468950	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	General Comments		
468951	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
468952	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
468953	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
468954	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
468955	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
468956	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
468957	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
468958	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
468959	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
468960	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
468961	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
468962	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
468963	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Follow-up Action Required?	n	
468964	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Follow-up Action Required?	n	
468965	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Foundation Condition	Good	
468966	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	General Comments		
468967	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	General Comments		
468968	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Grounds in Place?	y	
468969	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Heaters (All) Functioning?	y	
468970	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Maintenance Operations	0	
468971	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Moisture and Leak Free?	y	
468972	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Operations Counter AF	284	
468973	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Operations Counter AL	284	
468974	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Operations This Read Vac	1	
468975	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Switching Operations	1	
468976	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
468977	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Unknown Operations	0	
468978	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Operations Counter AL	191	
468979	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Operations This Read Vac	0	
468980	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
468981	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
468982	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
468983	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
468984	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	180	
468985	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
468986	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Switching Operations	0	
468987	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Tank Paint Condition	Good	
468988	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Unknown Operations	0	
468989	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	9 Month Operations	4	
468990	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
468991	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
468992	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
468993	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Amps A Ø	50.0	
468994	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
468995	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
468996	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
468997	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
468998	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
468999	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
469000	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
469001	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
469002	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
469003	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Winding Temp Present	50	°C
469004	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Winding Temp Max	60	°C
469005	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Totalizer Meter Reading	1.0990	
469006	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
469007	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
469008	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
469009	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
469010	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
469011	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
469012	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Max Tap Position	14R	
469013	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
469014	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	General Comments		
469015	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
469016	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	9 Month Operations	8	
469017	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
469018	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
469019	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
469020	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
469021	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
469022	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
469023	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
469024	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
469025	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
469026	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Oil Temp Present	50	°C
469027	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Oil Temp Max	70	°C
469028	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
469029	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
469030	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	LTC Totalizer Reading	19782.00	kw
469031	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
469032	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
469033	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Amps A Ø	90.0	
469034	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Amps B Ø	70.0	
469035	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Amps C Ø	70.0	
469036	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Bushing Condition	Good	
469037	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
469038	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
469039	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
469040	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	9 Month Operations	1	
469041	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
469042	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
469043	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
469044	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
469045	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
469046	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
469047	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
469048	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
469049	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
469050	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
469051	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Oil Temp Present	40	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
469052	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
469053	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
469054	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
469055	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
469056	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
469057	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Operations This Read Vac	5	
469058	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Operations Counter AL	146	
469059	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Operations Counter AF	146	
469060	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Moisture and Leak Free?	y	
469061	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Maintenance Operations	0	
469062	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Heaters (All) Functioning?	y	
469063	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Grounds in Place?	y	
469064	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	General Comments		
469065	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	General Comments		
469066	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Foundation Condition	Good	
469067	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Follow-up Action Required?	n	
469068	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Follow-up Action Required?	n	
469069	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Operations Ground	0	
469070	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Operations C Ø	0	
469071	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Operations B Ø	0	
469072	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Operations A Ø	1	
469073	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
469074	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
469075	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Adjusted Amps A Phase V	6.13	
469076	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
469077	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
469078	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	General Comments		
469079	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
469080	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
469081	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Operations Counter	152	
469082	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
469083	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
469084	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
469085	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
469086	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
469087	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	General Comments		
469088	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
469089	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
469090	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
469091	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
469092	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
469093	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	606	
469094	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	606	
469095	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
469096	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
469097	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3120	
469098	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Winding Temp Max	50	°C
469099	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
469100	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
469101	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
469102	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
469103	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	General Comments		
469104	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
469105	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
469106	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
469107	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Amps C Ø	50.0	
469108	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Patrol Inspection	Equipment Properly Labeled?	y	
469109	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
469110	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
469111	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
469112	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
469113	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
469114	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
469115	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
469116	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
469117	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
469118	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
469119	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
469120	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
469121	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
469122	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
469123	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
469124	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
469125	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
469126	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
469127	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Amps A Ø	55.0	
469128	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Amps B Ø	36.0	
469129	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Amps C Ø	42.0	
469130	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
469131	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
469132	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
469133	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
469134	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
469135	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
469136	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
469137	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
469138	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
469139	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	General Comments		
469140	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	General Comments		
469141	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
469142	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
469143	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Follow-up Action Required?	n	
469144	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
469145	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
469146	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
469147	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
469148	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
469149	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
469150	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
469151	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
469152	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
469153	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
469154	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
469155	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
469156	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
469157	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	General Comments		
469158	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	General Comments		
469159	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
469160	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Unknown Operations	0	
469161	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Tank Paint Condition	Good	
469162	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Switching Operations	4	
469163	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
469164	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
469165	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
469166	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	125	
469167	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	140	
469168	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
469169	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
469170	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
469171	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
469172	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Tank Leaks	None	
469173	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
469174	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
469175	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2995.20	kw
469176	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
469177	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Regulator As Left Counter	12981	
469178	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
469179	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
469180	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
469181	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
469182	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
469183	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Amps C Ø	120.0	
469184	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Bushing Condition	Good	
469185	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
469186	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
469187	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
469188	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Bushings Connection/Risers	Good	
469189	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
469190	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
469191	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
469192	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Cabinet Paint Condition	Good	
469193	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Equipment Properly Labeled?	y	
469194	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
469195	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
469196	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
469197	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
469198	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
469199	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
469200	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
469201	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
469202	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	115	
469203	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120	
469204	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.84	%
469205	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.84	%
469206	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.84	%
469207	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	20	
469208	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
469209	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
469210	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
469211	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Follow-up Action Required?	n	
469212	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
469213	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
469214	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	General Comments		
469215	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	General Comments		
469216	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
469217	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	LTC Totalizer Reading	6182.40	kw
469218	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
469219	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
469220	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Oil Temp Max	35	°C
469221	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Oil Temp Present	35	°C
469222	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
469223	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
469224	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
469225	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
469226	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
469227	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
469228	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
469229	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
469230	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
469231	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
469232	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
469233	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
469234	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Follow-up Action Required?	n	
469235	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
469236	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
469237	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	General Comments		
469238	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	General Comments		
469239	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
469240	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	LTC Totalizer Reading	7754.40	kw
469241	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
469242	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
469243	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Oil Temp Max	40	°C
469244	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Oil Temp Present	40	°C
469245	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
469246	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
469247	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
469248	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
469249	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
469250	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
469251	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Moisture and Leak Free?	y	
469252	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Operations Counter AF	203	
469253	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Operations Counter AL	203	
469254	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Operations This Read Vac	5	
469255	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
469256	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Switching Operations	5	
469257	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
469258	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
469259	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
469260	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	892	
469261	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	892	
469262	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
469263	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
469264	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
469265	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
469266	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
469267	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
469268	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
469269	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
469270	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	PF000177	PowerFuse	HN-12KV SEC 1 BUS POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
469271	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	PF000177	PowerFuse	HN-12KV SEC 1 BUS POTS	Disconnect Powerfuse Inspection	General Comments	ok	
469272	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
469273	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
469274	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
469275	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
469276	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	360.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
469277	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	360.0	
469278	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	360.0	
469279	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
469280	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
469281	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
469282	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
469283	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
469284	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
469285	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
469286	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
469287	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
469288	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
469289	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
469290	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
469291	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
469292	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	9 Month Operations	7	
469293	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
469294	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
469295	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
469296	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
469297	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
469298	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
469299	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
469300	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
469301	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
469302	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
469303	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
469304	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
469305	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
469306	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
469307	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
469308	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	87	
469309	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
469310	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
469311	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	87	
469312	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
469313	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
469314	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
469315	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
469316	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
469317	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
469318	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Amps A Ø	130.0	
469319	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Amps B Ø	120.0	
469320	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
469321	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
469322	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
469323	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
469324	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
469325	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
469326	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
469327	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
469328	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.84	%
469329	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.84	%
469330	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.84	%
469331	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
469332	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Tank Paint Condition	Good	
469333	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
469334	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Moisture and Leak Free?	y	
469335	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Heaters (All) Functioning?	y	
469336	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Grounds in Place?	y	
469337	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	General Comments		
469338	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Foundation Condition	Good	
469339	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Follow-up Action Required?	n	
469340	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Equipment Properly Labeled?	y	
469341	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Cabinet Paint Condition	Good	
469342	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
469343	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
469344	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
469345	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Bushings Connection/Risers	Good	
469346	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Bushing Condition	Good	
469347	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
469348	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
469349	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
469350	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Amps A Ø	76.0	
469351	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Amps B Ø	78.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
469352	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Amps C Ø	74.0	
469353	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Bushing Condition	Good	
469354	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Bushings Connection/Risers	Good	
469355	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
469356	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
469357	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
469358	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Cabinet Paint Condition	Good	
469359	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Equipment Properly Labeled?	y	
469360	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
469361	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
469362	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
469363	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Operations A Ø	0	
469364	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Operations B Ø	0	
469365	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Operations C Ø	0	
469366	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Operations Ground	0	
469367	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Follow-up Action Required?	n	
469368	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Follow-up Action Required?	n	
469369	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Foundation Condition	Good	
469370	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	General Comments		
469371	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	General Comments		
469372	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Grounds in Place?	y	
469373	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC Operations Since Last Insp	421	
469374	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
469375	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Heaters (All) Functioning?	y	
469376	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Maintenance Operations	0	
469377	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Moisture and Leak Free?	y	
469378	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Operations Counter AF	191	
469379	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
469380	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0	%
469381	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.75	%
469382	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0	%
469383	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
469384	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Tank Leaks	None	
469385	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
469386	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
469387	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Regulator As Left Counter	12959	
469388	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
469389	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
469390	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Totalizer Meter Reading	.4308	
469391	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Winding Temp Max	45	°C
469392	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Winding Temp Present	45	°C
469393	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
469394	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
469395	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
469396	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
469397	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
469398	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
469399	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
469400	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
469401	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Totalizer Meter Reading	.6440	
469402	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
469403	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
469404	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Tank Paint Condition	Good	
469405	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Unknown Operations	0	
469406	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	All Connections OK?	y	
469407	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Bushing Condition	Good	
469408	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
469409	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
469410	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
469411	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Operations A Ø	0	
469412	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Operations B Ø	0	
469413	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
469414	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	897	
469415	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	897	
469416	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
469417	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
469418	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
469419	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
469420	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Condition	Good	
469421	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
469422	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
469423	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
469424	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
469425	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
469426	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
469427	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Follow-up Action Required?	y	
469428	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Foundation Condition	Good	
469429	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
469430	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Fuses Blown? Y / N	y	
469431	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	General Comments	One fuse blown.	
469432	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Grounds in Place?	y	
469433	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
469434	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
469435	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Tank Leaks	None	
469436	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Operations C Ø	0	
469437	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Operations Ground	0	
469438	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Follow-up Action Required?	n	
469439	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Follow-up Action Required?	n	
469440	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Foundation Condition	Good	
469441	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	General Comments		
469442	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	General Comments		
469443	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Grounds in Place?	y	
469444	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Heaters (All) Functioning?	y	
469445	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
469446	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Warning Signs OK?	y	
469447	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Maintenance Operations	0	
469448	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Moisture and Leak Free?	y	
469449	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Operations Counter AF	379	
469450	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Operations Counter AL	379	
469451	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Operations This Read Vac	7	
469452	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
469453	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
469454	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Switching Operations	7	
469455	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Tank Paint Condition	Good	
469456	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Unknown Operations	0	
469457	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
469458	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC As Left Counter	66287	
469459	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC As Found Counter	66283	
469460	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
469461	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
469462	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
469463	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
469464	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
469465	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
469466	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	9 Month Operations	4	
469467	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
469468	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
469469	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
469470	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
469471	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
469472	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
469473	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
469474	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
469475	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
469476	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
469477	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
469478	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	General Comments		
469479	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
469480	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
469481	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Foundation Condition	Good	
469482	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
469483	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
469484	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Patrol Inspection	Heaters (All) Functioning?	y	
469485	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Maintenance Operations	0	
469486	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	14	
469487	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
469488	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
469489	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
469490	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	240.0	
469491	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	240.0	
469492	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	240.0	
469493	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
469494	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
469495	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
469496	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
469497	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
469498	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
469499	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
469500	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
469501	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
469502	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
469503	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
469504	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Operations Counter AF	192	
469505	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Operations Counter AL	192	
469506	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Operations This Read Vac	1	
469507	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Switching Operations	0	
469508	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Unknown Operations	0	
469509	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	All Connections OK?	y	
469510	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	Follow-up Action Required?	n	
469511	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
469512	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
469513	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
469514	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
469515	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
469516	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
469517	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
469518	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	General Comments		
469519	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	General Comments	ok	
469520	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
469521	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
469522	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
469523	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
469524	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
469525	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Operations This Read Vac	5	
469526	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Operations Counter AL	302	
469527	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Operations Counter AF	302	
469528	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Moisture and Leak Free?	y	
469529	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Maintenance Operations	0	
469530	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Heaters (All) Functioning?	y	
469531	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Grounds in Place?	y	
469532	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	General Comments		
469533	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	General Comments		
469534	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Foundation Condition	Good	
469535	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Follow-up Action Required?	n	
469536	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Follow-up Action Required?	n	
469537	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Operations Ground	0	
469538	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Operations C Ø	0	
469539	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Operations B Ø	0	
469540	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Operations A Ø	0	
469541	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
469542	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
469543	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
469544	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Equipment Properly Labeled?	y	
469545	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Cabinet Paint Condition	Good	
469546	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
469547	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
469548	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
469549	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Bushings Connection/Risers	Good	
469550	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Bushing Condition	Good	
469551	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Amps C Ø	60.0	
469552	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Amps B Ø	80.0	
469553	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Amps A Ø	70.0	
469554	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Amps C Ø	60.0	
469555	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Patrol Inspection	Equipment Properly Labeled?	y	
469556	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
469557	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
469558	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
469559	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Operations A Ø	0	
469560	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Operations B Ø	1	
469561	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Operations C Ø	0	
469562	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Operations Ground	0	
469563	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
469564	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
469565	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
469566	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	General Comments		
469567	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
469568	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Patrol Inspection	Follow-up Action Required?	n	
469569	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	9 Month Operations	8	
469570	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
469571	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
469572	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Follow-up Action Required?	n	
469573	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Patrol Inspection	General Comments		
469574	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	General Comments		
469575	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
469576	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
469577	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
469578	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
469579	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
469580	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	9 Month Operations	10	
469581	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
469582	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Amps A Ø	10.0	
469583	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Amps B Ø	10.0	
469584	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Amps C Ø	10.0	
469585	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Bushing Condition	Good	
469586	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
469587	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
469588	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
469589	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
469590	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC Operations Since Last Insp	319	
469591	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC Min Tap Position	8L	
469592	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC Max Tap Position	3L	
469593	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC Current Tap Position	6L	
469594	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Operations Ground	0	
469595	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Patrol Inspection	Follow-up Action Required?	n	
469596	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Follow-up Action Required?	n	
469597	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Patrol Inspection	General Comments		
469598	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	General Comments		
469599	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Maintenance Operations	0	
469600	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Operations Counter AF	170	
469601	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Operations Counter AL	170	
469602	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Operations This Read AM	2	
469603	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
469604	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Amps A Ø	30.0	
469605	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Amps B Ø	50.0	
469606	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Amps C Ø	52.0	
469607	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Patrol Inspection	Equipment Properly Labeled?	y	
469608	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
469609	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
469610	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
469611	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
469612	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
469613	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
469614	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
469615	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
469616	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
469617	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
469618	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
469619	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Switching Operations	0	
469620	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Unknown Operations	0	
469621	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
469622	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
469623	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
469624	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	General Comments		
469625	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
469626	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
469627	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
469628	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
469629	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
469630	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Vegetation	None	
469631	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
469632	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
469633	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
469634	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
469635	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
469636	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Oil Temp Max	80	°C
469637	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	PF000306	PowerFuse	SY-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
469638	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Tank Paint Condition	Good	
469639	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
469640	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Moisture and Leak Free?	y	
469641	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Heaters (All) Functioning?	y	
469642	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Grounds in Place?	y	
469643	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	General Comments		
469644	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Foundation Condition	Good	
469645	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Follow-up Action Required?	n	
469646	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Equipment Properly Labeled?	y	
469647	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Cabinet Paint Condition	Good	
469648	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
469649	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
469650	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
469651	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
469652	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
469653	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
469654	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
469655	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
469656	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
469657	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
469658	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
469659	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
469660	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Bushings Connection/Risers	Good	
469661	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Bushing Condition	Good	
469662	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
469663	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
469664	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
469665	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
469666	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
469667	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
469668	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
469669	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	543	
469670	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	543	
469671	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
469672	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
469673	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
469674	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
469675	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
469676	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
469677	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
469678	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC Operations Since Last Insp	322	
469679	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC Min Tap Position	12L	
469680	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC Max Tap Position	5L	
469681	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC Current Tap Position	11L	
469682	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
469683	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC As Left Counter	87024	
469684	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC As Found Counter	87020	
469685	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	General Comments		
469686	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	General Comments		
469687	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
469688	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	Follow-up Action Required?	n	
469689	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
469690	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	General Comments		
469691	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	LTC Operation Checked?	y	
469692	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
469693	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
469694	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
469695	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
469696	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
469697	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
469698	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1777.68	kw
469699	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	26.00	
469700	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	VRR Time Delay	30	Seconds
469701	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Bushings Connection/Risers	Good	
469702	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
469703	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
469704	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
469705	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Cabinet Paint Condition	Good	
469706	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
469707	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
469708	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	PF000304	PowerFuse	SY-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
469709	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	9 Months Operations	5	
469710	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
469711	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
469712	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
469713	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Amps A Ø	80.0	
469714	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Amps B Ø	70.0	
469715	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	PF000304	PowerFuse	SY-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
469716	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	PF000305	PowerFuse	SY-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
469717	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	PF000305	PowerFuse	SY-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
469718	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	General Comments		
469719	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	General Comments		
469720	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
469721	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	Follow-up Action Required?	n	
469722	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
469723	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Amps C Ø	80.0	
469724	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
469725	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
469726	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
469727	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
469728	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Operations A Ø	1	
469729	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Operations B Ø	1	
469730	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Operations C Ø	0	
469731	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Amps B Ø	0.0	
469732	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Amps C Ø	0.0	
469733	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Patrol Inspection	Equipment Properly Labeled?	y	
469734	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
469735	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
469736	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
469737	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
469738	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
469739	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
469740	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Operations A Ø	0	
469741	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Operations B Ø	1	
469742	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Operations C Ø	0	
469743	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Operations Ground	0	
469744	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Patrol Inspection	Follow-up Action Required?	n	
469745	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
469746	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
469747	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
469748	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
469749	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Equipment Properly Labeled?	y	
469750	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Cabinet Paint Condition	Good	
469751	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Ambient Temp	73	°F
469752	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
469753	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Clear of Trash?	y	
469754	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
469755	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
469756	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
469757	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
469758	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
469759	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
469760	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	General Comments		
469761	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
469762	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Vegetation	None	
469763	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
469764	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
469765	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
469766	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
469767	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Operations A Ø	0	
469768	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Operations B Ø	0	
469769	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Operations C Ø	0	
469770	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Operations Ground	0	
469771	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Patrol Inspection	Follow-up Action Required?	n	
469772	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Follow-up Action Required?	n	
469773	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Patrol Inspection	General Comments		
469774	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	General Comments		
469775	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Maintenance Operations	0	
469776	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Operations Counter AF	559	
469777	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Operations Counter AL	559	
469778	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Operations This Read Vac	0	
469779	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Switching Operations	0	
469780	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Unknown Operations	0	
469781	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
469782	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
469783	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
469784	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Bushings Connection/Risers	Good	
469785	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Bushing Condition	Good	
469786	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Amps C Ø	10.0	
469787	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Amps B Ø	10.0	
469788	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Amps A Ø	10.0	
469789	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
469790	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
469791	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
469792	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
469793	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Totalizer Meter Reading	.6606	
469794	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
469795	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
469796	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
469797	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
469798	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
469799	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Winding Temp Present	40	°C
469800	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
469801	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
469802	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
469803	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
469804	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
469805	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
469806	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
469807	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
469808	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Operations A Ø	0	
469809	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Operations B Ø	0	
469810	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Operations C Ø	0	
469811	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Operations Ground	0	
469812	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
469813	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
469814	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
469815	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
469816	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
469817	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
469818	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Current Tap Position	4R	
469819	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
469820	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
469821	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
469822	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
469823	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	General Comments		
469824	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
469825	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
469826	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Min Tap Position	1L	
469827	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
469828	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
469829	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
469830	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
469831	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
469832	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Regulator As Left Counter	29652	
469833	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
469834	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
469835	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Tank Leaks	None	
469836	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
469837	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
469838	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Patrol Inspection	Follow-up Action Required?	n	
469839	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Follow-up Action Required?	n	
469840	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Patrol Inspection	General Comments		
469841	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	General Comments		
469842	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
469843	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
469844	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Patrol Inspection	Heaters (All) Functioning?	y	
469845	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Maintenance Operations	0	
469846	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Operations Counter AF	161	
469847	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Operations Counter AL	161	
469848	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Operations This Read Vac	0	
469849	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Switching Operations	0	
469850	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Unknown Operations	0	
469851	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	9 Month Operations	3	
469852	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
469853	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
469854	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
469855	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
469856	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
469857	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
469858	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
469859	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Amps A Ø	70.0	
469860	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Amps B Ø	100.0	
469861	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Amps C Ø	50.0	
469862	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Patrol Inspection	Equipment Properly Labeled?	y	
469863	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	9 Month Operations	0	
469864	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
469865	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
469866	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
469867	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Amps A Ø	0.0	
469868	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	General Comments	MAX & MIN HANDS STUCK	
469869	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
469870	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
469871	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
469872	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
469873	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
469874	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
469875	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
469876	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
469877	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
469878	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
469879	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
469880	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
469881	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
469882	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
469883	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
469884	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
469885	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
469886	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
469887	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
469888	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
469889	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	78	°F
469890	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
469891	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
469892	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
469893	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
469894	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Patrol Inspection	General Comments		
469895	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	General Comments		
469896	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Patrol Inspection	Heaters (All) Functioning?	y	
469897	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Maintenance Operations	0	
469898	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Operations Counter AF	148	
469899	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Operations Counter AL	148	
469900	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Operations This Read Vac	1	
469901	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Switching Operations	0	
469902	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Unknown Operations	0	
469903	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	9 Month Operations	15	
469904	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
469905	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
469906	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
469907	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Amps A Ø	80.0	
469908	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Amps B Ø	50.0	
469909	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
469910	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Tank Leaks	None	
469911	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
469912	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
469913	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Regulator As Left Counter	11636	
469914	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
469915	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
469916	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
469917	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
469918	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
469919	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
469920	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Max Tap Position	5L	
469921	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
469922	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	General Comments	ok	
469923	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
469924	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
469925	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
469926	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
469927	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
469928	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
469929	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
469930	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
469931	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
469932	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
469933	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Unknown Operations	0	
469934	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Tank Paint Condition	Good	
469935	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Switching Operations	5	
469936	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
469937	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
469938	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
469939	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Oil Temp Present	50	°C
469940	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Oil Temp Max	75	°C
469941	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
469942	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
469943	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	LTC Totalizer Reading	11890.80	kw
469944	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
469945	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	General Comments		
469946	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	General Comments		
469947	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
469948	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
469949	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Follow-up Action Required?	n	
469950	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
469951	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Fans Operational?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
469952	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
469953	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
469954	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
469955	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
469956	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
469957	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
469958	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
469959	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
469960	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
469961	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
469962	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
469963	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
469964	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
469965	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
469966	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	9 Month Operations	9	
469967	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	General Comments		
469968	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
469969	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	32	°C
469970	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	32	°C
469971	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
469972	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
469973	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1250	psi
469974	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	Oil Temp Max	35	°C
469975	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	Oil Temp Present	32	°C
469976	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
469977	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
469978	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
469979	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
469980	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
469981	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
469982	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
469983	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
469984	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
469985	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	37	°C
469986	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	31	°C
469987	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	32	°C
469988	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
469989	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	38	°C
469990	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	38	°C
469991	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Follow-up Action Required?	n	
469992	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
469993	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Tank Leaks	None	
469994	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
469995	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
469996	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Regulator As Left Counter	12556	
469997	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
469998	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
469999	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
470000	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
470001	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
470002	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Min Tap Position	1L	
470003	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
470004	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
470005	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
470006	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
470007	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
470008	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
470009	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
470010	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
470011	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
470012	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Oil Temp Present	35	°C
470013	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Oil Temp Max	35	°C
470014	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
470015	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
470016	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
470017	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
470018	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
470019	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	General Comments		
470020	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	General Comments		
470021	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
470022	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
470023	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
470024	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
470025	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
470026	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
470027	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
470028	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
470029	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
470030	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
470031	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
470032	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
470033	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
470034	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	173	
470035	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
470036	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
470037	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC Max Tap Position	12L	
470038	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
470039	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
470040	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
470041	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
470042	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
470043	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
470044	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
470045	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
470046	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
470047	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
470048	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
470049	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	General Comments		
470050	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
470051	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
470052	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
470053	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
470054	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
470055	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
470056	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
470057	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
470058	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	General Comments		
470059	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
470060	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
470061	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
470062	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.2	VDC
470063	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.2	VDC
470064	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	5.300	millivolts
470065	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
470066	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Regulator As Left Counter	5489	
470067	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
470068	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
470069	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Tank Leaks	None	
470070	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
470071	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Tank Leaks	None	
470072	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
470073	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
470074	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
470075	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	82	
470076	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	82	
470077	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	6	
470078	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	6	
470079	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
470080	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	1	
470081	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	4.22	%
470082	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	4.22	%
470083	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	4.22	%
470084	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20	
470085	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20	
470086	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20	
470087	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	14.15	
470088	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	14.15	
470089	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	14.15	
470090	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
470091	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
470092	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
470093	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
470094	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
470095	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
470096	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
470097	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	76	
470098	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	76	
470099	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
470100	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
470101	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
470102	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
470103	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
470104	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
470105	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	1	
470106	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
470107	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
470108	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
470109	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
470110	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
470111	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
470112	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
470113	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
470114	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
470115	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	General Comments		
470116	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
470117	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	Follow-up Action Required?	n	
470118	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
470119	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	General Comments		
470120	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	General Comments		
470121	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC As Found Counter	185180	
470122	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC As Left Counter	185187	
470123	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
470124	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC Current Tap Position	8L	
470125	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC Max Tap Position	6L	
470126	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC Min Tap Position	8L	
470127	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC Operations Since Last Insp	148	
470128	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
470129	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
470130	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
470131	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
470132	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
470133	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Winding Temp Present	35	°C
470134	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Winding Temp Max	40	°C
470135	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Accumulated Fault Duty C Ph V	.44	%
470136	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Amps A Ø	10.0	
470137	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Unknown Operations	0	
470138	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Tank Paint Condition	Good	
470139	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Operations Counter AF	257	
470140	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Switching Operations	0	
470141	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
470142	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Operations This Read Vac	1	
470143	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Operations Counter AL	167	
470144	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Operations Counter AF	167	
470145	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Moisture and Leak Free?	y	
470146	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Maintenance Operations	1	
470147	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Heaters (All) Functioning?	y	
470148	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Grounds in Place?	y	
470149	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	General Comments		
470150	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	General Comments		
470151	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Foundation Condition	Good	
470152	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Follow-up Action Required?	n	
470153	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Follow-up Action Required?	n	
470154	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Operations Ground	0	
470155	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Operations C Ø	0	
470156	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Operations B Ø	0	
470157	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Operations A Ø	0	
470158	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
470159	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
470160	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
470161	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Equipment Properly Labeled?	y	
470162	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Cabinet Paint Condition	Good	
470163	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
470164	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
470165	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
470166	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Bushings Connection/Risers	Good	
470167	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Bushing Condition	Good	
470168	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Amps C Ø	144.0	
470169	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Amps B Ø	155.0	
470170	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Amps A Ø	115.0	
470171	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
470172	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
470173	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
470174	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	9 Month Operations	2	
470175	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Adjusted Amps C Phase V	17.75	
470176	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Adjusted Amps B Phase V	17.75	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
470177	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Adjusted Amps A Phase V	17.75	
470178	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Equipment Properly Labeled?	y	
470179	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Cabinet Paint Condition	Good	
470180	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
470181	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
470182	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
470183	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Bushings Connection/Risers	Good	
470184	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Bushing Condition	Good	
470185	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Amps C Ø	100.0	
470186	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Amps B Ø	100.0	
470187	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Amps A Ø	100.0	
470188	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
470189	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
470190	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
470191	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	9 Month Operations	4	
470192	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Bushings Connection/Risers	Good	
470193	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
470194	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
470195	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
470196	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
470197	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
470198	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC Operations Since Last Insp	381	
470199	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC Min Tap Position	9L	
470200	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
470201	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
470202	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
470203	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
470204	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
470205	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
470206	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
470207	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
470208	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
470209	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	General Comments		
470210	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
470211	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
470212	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
470213	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
470214	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	General Comments		
470215	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
470216	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
470217	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
470218	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
470219	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
470220	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
470221	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
470222	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
470223	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
470224	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
470225	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
470226	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
470227	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
470228	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
470229	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.8	VDC
470230	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
470231	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
470232	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
470233	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.8	VDC
470234	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
470235	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
470236	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
470237	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Unknown Operations	0	
470238	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Tank Paint Condition	Good	
470239	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Switching Operations	0	
470240	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Operations This Read Vac	0	
470241	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Unknown Operations	4	
470242	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Operations Counter AL	257	
470243	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Tank Paint Condition	Good	
470244	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Switching Operations	0	
470245	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
470246	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Operations This Read Vac	4	
470247	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Operations Counter AL	443	
470248	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Operations Counter AF	443	
470249	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Moisture and Leak Free?	y	
470250	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Maintenance Operations	0	
470251	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Heaters (All) Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
470252	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Grounds in Place?	y	
470253	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	General Comments		
470254	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	General Comments		
470255	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Foundation Condition	Good	
470256	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Follow-up Action Required?	n	
470257	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Follow-up Action Required?	n	
470258	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Operations Ground	0	
470259	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Operations C Ø	0	
470260	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Operations B Ø	0	
470261	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Operations A Ø	0	
470262	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	9 Month Operations	25	
470263	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Accumulated Fault Duty A Ph V	.44	%
470264	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Accumulated Fault Duty B Ph V	.44	%
470265	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
470266	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
470267	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
470268	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
470269	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
470270	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
470271	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	66	°F
470272	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
470273	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Amps A Ø	240.0	
470274	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
470275	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Operations Counter AL	268	
470276	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Operations This Read Vac	2	
470277	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
470278	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Switching Operations	0	
470279	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Tank Paint Condition	Good	
470280	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Unknown Operations	0	
470281	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
470282	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
470283	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
470284	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
470285	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
470286	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Bushing Condition	Good	
470287	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
470288	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
470289	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
470290	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
470291	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
470292	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
470293	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Follow-up Action Required?	n	
470294	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Foundation Condition	Good	
470295	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	General Comments		
470296	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
470297	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
470298	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
470299	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
470300	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
470301	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
470302	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
470303	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	264	
470304	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	264	
470305	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
470306	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
470307	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
470308	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
470309	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
470310	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
470311	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
470312	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
470313	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	9 Month Operations	11	
470314	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Grounds in Place?	y	
470315	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
470316	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
470317	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
470318	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Tank Paint Condition	Good	
470319	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
470320	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
470321	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
470322	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
470323	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
470324	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
470325	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
470326	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
470327	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
470328	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
470329	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
470330	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
470331	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
470332	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
470333	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Operations Counter AL	192	
470334	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Operations Counter AF	192	
470335	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Moisture and Leak Free?	y	
470336	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Maintenance Operations	0	
470337	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Heaters (All) Functioning?	y	
470338	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Grounds in Place?	y	
470339	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	General Comments		
470340	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	General Comments		
470341	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Foundation Condition	Good	
470342	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Follow-up Action Required?	n	
470343	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Follow-up Action Required?	n	
470344	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Operations Ground	0	
470345	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Operations C Ø	0	
470346	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Amps B Ø	120.0	
470347	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Amps C Ø	100.0	
470348	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Bushing Condition	Good	
470349	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
470350	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
470351	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
470352	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
470353	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Compressor Oil Status	Good	
470354	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Leaks	None	
470355	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Pressure OK?	y	
470356	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
470357	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
470358	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
470359	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	LTC Totalizer Reading	6902.40	kw
470360	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
470361	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	General Comments		
470362	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	General Comments		
470363	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
470364	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
470365	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Follow-up Action Required?	n	
470366	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Bushings Connection/Risers	Good	
470367	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
470368	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
470369	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
470370	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Cabinet Paint Condition	Good	
470371	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Equipment Properly Labeled?	y	
470372	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Operations B Ø	0	
470373	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Operations A Ø	0	
470374	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
470375	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
470376	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
470377	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Equipment Properly Labeled?	y	
470378	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Cabinet Paint Condition	Good	
470379	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
470380	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
470381	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
470382	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Bushings Connection/Risers	Good	
470383	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Bushing Condition	Good	
470384	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Amps C Ø	240.0	
470385	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Amps B Ø	240.0	
470386	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
470387	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Bushing Condition	Good	
470388	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
470389	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
470390	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
470391	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
470392	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
470393	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
470394	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
470395	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Min Tap Position	Neutral	
470396	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
470397	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
470398	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
470399	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
470400	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
470401	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Regulator As Left Counter	70631	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
470402	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
470403	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
470404	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Tank Leaks	None	
470405	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
470406	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
470407	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
470408	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
470409	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
470410	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Regulator As Left Counter	5658	
470411	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
470412	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
470413	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Switching Operations	5	
470414	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Tank Paint Condition	Good	
470415	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Unknown Operations	0	
470416	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Tank Leaks	None	
470417	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
470418	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
470419	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	5.27	%
470420	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	5.27	%
470421	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	5.27	%
470422	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
470423	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
470424	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
470425	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
470426	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
470427	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
470428	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
470429	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
470430	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
470431	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
470432	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BCH000573	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
470433	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BCH000573	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
470434	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BCH000573	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
470435	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BCH000573	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
470436	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BCH000573	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
470437	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	25.0	
470438	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	25.0	
470439	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	25.0	
470440	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
470441	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
470442	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
470443	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
470444	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
470445	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
470446	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BCH000573	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
470447	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
470448	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
470449	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	General Comments		
470450	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
470451	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Max Tap Position	7L	
470452	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
470453	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
470454	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
470455	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
470456	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
470457	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
470458	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Regulator As Left Counter	4260	
470459	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
470460	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
470461	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
470462	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
470463	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
470464	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
470465	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
470466	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
470467	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
470468	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
470469	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
470470	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
470471	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10.0	
470472	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
470473	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
470474	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
470475	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
470476	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
470477	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
470478	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
470479	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
470480	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Operations A Ø	0	
470481	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Operations B Ø	0	
470482	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Operations C Ø	0	
470483	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Operations Ground	0	
470484	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Bushing Oil Level	Good	
470485	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Follow-up Action Required?	n	
470486	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Follow-up Action Required?	n	
470487	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Foundation Condition	Good	
470488	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	General Comments		
470489	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	General Comments		
470490	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Grounds in Place?	y	
470491	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Heaters (All) Functioning?	y	
470492	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Maintenance Operations	0	
470493	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Moisture and Leak Free?	y	
470494	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Operations Counter AF	334	
470495	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Operations Counter AL	334	
470496	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Operations This Read Vac	5	
470497	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
470498	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
470499	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
470500	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
470501	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
470502	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
470503	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
470504	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
470505	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
470506	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BCH000573	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
470507	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
470508	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	General Comments		
470509	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
470510	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
470511	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
470512	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
470513	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
470514	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
470515	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
470516	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
470517	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
470518	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
470519	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
470520	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
470521	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
470522	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
470523	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	General Comments		
470524	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
470525	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Max Tap Position	11L	
470526	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Operations C Ø	0	
470527	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Operations Ground	0	
470528	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Follow-up Action Required?	n	
470529	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Follow-up Action Required?	n	
470530	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Foundation Condition	Good	
470531	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	General Comments		
470532	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	General Comments		
470533	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Grounds in Place?	y	
470534	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Heaters (All) Functioning?	y	
470535	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Maintenance Operations	1	
470536	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
470537	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
470538	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
470539	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Moisture and Leak Free?	y	
470540	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Operations Counter AF	207	
470541	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Operations Counter AL	207	
470542	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Follow-up Action Required?	n	
470543	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Operations Ground	0	
470544	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Operations C Ø	0	
470545	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Operations B Ø	0	
470546	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Operations A Ø	0	
470547	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Adjusted Amps C Phase V	0	
470548	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Adjusted Amps B Phase V	0	
470549	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Adjusted Amps A Phase V	0	
470550	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Amps C Ø	10	
470551	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Amps B Ø	10	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
470552	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Amps A Ø	10	
470553	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Accumulated Fault Duty C Ph V	1.31	%
470554	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Accumulated Fault Duty B Ph V	.44	%
470555	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Accumulated Fault Duty A Ph V	.44	%
470556	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	9 Month Operations	17	
470557	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Operations This Read Vac	1	
470558	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
470559	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Switching Operations	0	
470560	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Tank Paint Condition	Good	
470561	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Unknown Operations	0	
470562	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
470563	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
470564	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Totalizer Meter Reading	.2778	
470565	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
470566	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
470567	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
470568	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
470569	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
470570	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
470571	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
470572	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
470573	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Oil Temp Present	40	°C
470574	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Oil Temp Max	40	°C
470575	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
470576	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
470577	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	LTC Totalizer Reading	1333.44	kw
470578	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
470579	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	General Comments	FANS RUNNING ALL THE TIME ON AUTO	
470580	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	General Comments		
470581	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
470582	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
470583	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Follow-up Action Required?	n	
470584	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
470585	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
470586	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
470587	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
470588	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
470589	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
470590	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
470591	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Foundation Condition	Good	
470592	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	General Comments		
470593	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	General Comments		
470594	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	9 Month Operations	1	
470595	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
470596	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Tank Leaks	None	
470597	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Heaters (All) Functioning?	y	
470598	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Grounds in Place?	y	
470599	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
470600	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
470601	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Regulator As Left Counter	71551	
470602	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
470603	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
470604	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
470605	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
470606	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
470607	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
470608	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
470609	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
470610	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	General Comments		
470611	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
470612	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
470613	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
470614	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
470615	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
470616	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
470617	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
470618	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
470619	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
470620	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
470621	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
470622	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
470623	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
470624	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Amps A Ø	20.0	
470625	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Amps B Ø	19.0	
470626	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Amps C Ø	19.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
470627	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Bushing Condition	Good	
470628	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Bushings Connection/Risers	Good	
470629	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
470630	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
470631	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
470632	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
470633	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Unknown Operations	0	
470634	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
470635	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
470636	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
470637	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
470638	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
470639	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Totalizer Meter Reading	.4530	
470640	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Switching Operations	10	
470641	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Operations This Read Vac	10	
470642	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Operations Counter AL	361	
470643	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Operations Counter AF	351	
470644	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Maintenance Operations	0	
470645	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	General Comments		
470646	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
470647	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
470648	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
470649	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Cabinet Paint Condition	Good	
470650	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Equipment Properly Labeled?	y	
470651	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
470652	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
470653	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
470654	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Operations A Ø	0	
470655	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Operations B Ø	0	
470656	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
470657	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
470658	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	General Comments	barb wire is broken on NE fence	
470659	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
470660	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
470661	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
470662	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
470663	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
470664	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
470665	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
470666	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	40	°C
470667	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	60	°C
470668	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
470669	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
470670	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	LTC Totalizer Reading	2985.12	kw
470671	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
470672	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
470673	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
470674	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
470675	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
470676	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
470677	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
470678	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
470679	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
470680	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
470681	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
470682	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
470683	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
470684	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
470685	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
470686	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
470687	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
470688	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
470689	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	135.0	VDC
470690	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
470691	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	Counter was verified	
470692	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
470693	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	135.0	VDC
470694	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.600	millivolts
470695	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Maintenance Operations	0	
470696	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	General Comments		
470697	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
470698	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
470699	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
470700	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
470701	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	496	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
470702	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	496	
470703	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Follow-up Action Required?	n	
470704	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
470705	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
470706	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
470707	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	9 Month Operations	17	
470708	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Accumulated Fault Duty A Ph V	.44	%
470709	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Accumulated Fault Duty B Ph V	.44	%
470710	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Accumulated Fault Duty C Ph V	1.31	%
470711	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Amps A Ø	10.0	
470712	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Amps B Ø	10.0	
470713	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Amps C Ø	10.0	
470714	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
470715	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
470716	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
470717	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Operations A Ø	0	
470718	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Operations B Ø	0	
470719	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Operations Ground	0	
470720	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Operations C Ø	0	
470721	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
470722	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
470723	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
470724	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
470725	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
470726	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
470727	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	325.0	
470728	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	320.0	
470729	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	325.0	
470730	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Unknown Operations	0	
470731	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Switching Operations	3	
470732	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Operations This Read Vac	3	
470733	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Operations Counter AL	364	
470734	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Operations Counter AF	364	
470735	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
470736	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Vegetation	None	
470737	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
470738	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
470739	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	General Comments		
470740	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
470741	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
470742	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
470743	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
470744	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
470745	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
470746	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Clear of Trash?	y	
470747	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
470748	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Ambient Temp	74	°F
470749	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
470750	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	General Comments		
470751	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
470752	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
470753	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.0	amps
470754	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
470755	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
470756	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
470757	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
470758	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
470759	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Reading	.4146	
470760	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
470761	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
470762	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
470763	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
470764	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
470765	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
470766	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
470767	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
470768	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
470769	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
470770	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
470771	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
470772	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
470773	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
470774	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
470775	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
470776	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
470777	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
470778	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
470779	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
470780	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
470781	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
470782	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
470783	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
470784	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
470785	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
470786	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
470787	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Amps A Ø	306.0	
470788	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	9 Month Operations	14	
470789	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Amps B Ø	310.0	
470790	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Accumulated Fault Duty A Ph V	.44	%
470791	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Accumulated Fault Duty B Ph V	.44	%
470792	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Accumulated Fault Duty C Ph V	.44	%
470793	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Amps A Ø	10	
470794	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Amps B Ø	10	
470795	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Amps C Ø	10	
470796	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Adjusted Amps A Phase V	0	
470797	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Adjusted Amps B Phase V	0	
470798	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Adjusted Amps C Phase V	0	
470799	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Amps C Ø	312.0	
470800	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Bushing Condition	Good	
470801	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Unknown Operations	0	
470802	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Switching Operations	0	
470803	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Operations This Read AM	1	
470804	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Operations Counter AL	299	
470805	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Operations Counter AF	299	
470806	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Maintenance Operations	0	
470807	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	General Comments		
470808	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Patrol Inspection	General Comments		
470809	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Follow-up Action Required?	n	
470810	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Patrol Inspection	Follow-up Action Required?	n	
470811	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
470812	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC As Left Counter	72002	
470813	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC As Found Counter	72002	
470814	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
470815	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	General Comments		
470816	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Operations A Ø	0	
470817	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Operations B Ø	0	
470818	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Operations C Ø	0	
470819	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Operations Ground	0	
470820	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Follow-up Action Required?	n	
470821	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	General Comments		
470822	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Maintenance Operations	0	
470823	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Operations Counter AF	298	
470824	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Operations Counter AL	308	
470825	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Operations This Read Vac	10	
470826	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Switching Operations	10	
470827	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Unknown Operations	0	
470828	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
470829	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
470830	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LTCC000328	LTCControl	SY-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
470831	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LTCC000328	LTCControl	SY-TRANS 1	LTC Control Insp	General Comments		
470832	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LTCC000328	LTCControl	SY-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
470833	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LTCC000328	LTCControl	SY-TRANS 1	LTC Control Insp	All Connections OK?	y	
470834	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
470835	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
470836	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
470837	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
470838	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
470839	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
470840	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
470841	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
470842	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
470843	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
470844	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
470845	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
470846	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Foundation Condition	Good	
470847	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
470848	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
470849	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
470850	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
470851	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
470852	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC Max Tap Position	2L	
470853	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Amps B Ø	10.0	
470854	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC Current Tap Position	6L	
470855	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Amps C Ø	10.0	
470856	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
470857	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC As Left Counter	4024	
470858	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC As Found Counter	4025	
470859	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	General Comments		
470860	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	General Comments		
470861	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
470862	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
470863	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Cabinet Paint Condition	Good	
470864	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Equipment Properly Labeled?	y	
470865	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Fault Operations	0	
470866	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Follow-up Action Required?	n	
470867	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Follow-up Action Required?	n	
470868	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Foundation Condition	Good	
470869	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Gauge(s) Condition	Good	
470870	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	General Comments		
470871	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	General Comments		
470872	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Grounds in Place?	y	
470873	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Heaters (All) Functioning?	y	
470874	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Maintenance Operations	0	
470875	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
470876	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
470877	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
470878	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Operations A Ø	0	
470879	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Moisture and Leak Free?	y	
470880	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Number of Ops last 9 Months	2	
470881	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Operations Counter AF	99988	
470882	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Operations Counter AL	99988	
470883	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Operations This Read Oil	0	
470884	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Pop-off Valve Tested Date	2019-04-11 00:00:00.000000	
470885	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Operations B Ø	0	
470886	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Operations C Ø	0	
470887	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Pressure Vessel Condition	Good	
470888	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Switching Operations	0	
470889	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank 1 Oil Level	Good	
470890	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank 2 Oil level	Good	
470891	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank 3 Oil Level	Good	
470892	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank Leaks	None	
470893	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank Paint Condition	Good	
470894	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Unknown Operations	0	
470895	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Operations Ground	0	
470896	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Moisture and Leak Free?	y	
470897	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Maintenance Operations	0	
470898	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
470899	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
470900	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
470901	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
470902	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
470903	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
470904	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Follow-up Action Required?	n	
470905	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	General Comments		
470906	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Maintenance Operations	0	
470907	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Operations Counter AF	309	
470908	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Operations Counter AL	309	
470909	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Operations This Read Vac	11	
470910	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Switching Operations	11	
470911	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Unknown Operations	0	
470912	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	9 Month Operations	0	
470913	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
470914	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
470915	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	Follow-up Action Required?	n	
470916	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
470917	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
470918	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Follow-up Action Required?	n	
470919	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
470920	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
470921	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	General Comments		
470922	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	General Comments		
470923	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
470924	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Bushings Connection/Risers	Good	
470925	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	9 Month Operations	1	
470926	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
470927	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
470928	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
470929	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Amps A Ø	30.0	
470930	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Amps B Ø	39.0	
470931	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Amps C Ø	34.0	
470932	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Bushing Condition	Good	
470933	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Bushings Connection/Risers	Good	
470934	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
470935	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
470936	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
470937	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Cabinet Paint Condition	Good	
470938	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Equipment Properly Labeled?	y	
470939	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
470940	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
470941	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
470942	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Operations A Ø	0	
470943	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Operations B Ø	0	
470944	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Operations C Ø	0	
470945	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Operations Ground	0	
470946	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Follow-up Action Required?	n	
470947	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Follow-up Action Required?	n	
470948	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Foundation Condition	Good	
470949	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	General Comments		
470950	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	General Comments		
470951	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Grounds in Place?	y	
470952	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Heaters (All) Functioning?	y	
470953	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Maintenance Operations	1	
470954	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Moisture and Leak Free?	y	
470955	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Operations Counter AF	160	
470956	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Operations Counter AL	160	
470957	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Operations This Read Vac	1	
470958	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	LTC Totalizer Reading	8154.00	kw
470959	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
470960	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
470961	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Oil Temp Max	67	°C
470962	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Oil Temp Present	47	°C
470963	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
470964	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
470965	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
470966	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
470967	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
470968	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Cabinet Paint Condition	Good	
470969	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Equipment Properly Labeled?	y	
470970	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Switching Operations	0	
470971	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Tank Paint Condition	Good	
470972	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Unknown Operations	0	
470973	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
470974	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
470975	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
470976	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Operations A Ø	0	
470977	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Operations B Ø	0	
470978	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Operations C Ø	0	
470979	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Operations Ground	0	
470980	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Follow-up Action Required?	n	
470981	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Follow-up Action Required?	n	
470982	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
470983	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	General Comments		
470984	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
470985	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
470986	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	General Comments		
470987	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
470988	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
470989	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
470990	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
470991	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
470992	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
470993	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
470994	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
470995	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
470996	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
470997	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
470998	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
470999	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC Operations Since Last Insp	11	
471000	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC Min Tap Position	14L	
471001	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC Max Tap Position	7L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
471002	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC Current Tap Position	10L	
471003	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
471004	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
471005	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
471006	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
471007	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
471008	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	General Comments		
471009	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
471010	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
471011	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
471012	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC As Left Counter	750	
471013	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC As Found Counter	744	
471014	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	General Comments		
471015	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	General Comments		
471016	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
471017	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
471018	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
471019	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
471020	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
471021	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Operations Ground	0	
471022	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Operations C Ø	0	
471023	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Operations B Ø	1	
471024	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Operations A Ø	0	
471025	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
471026	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
471027	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
471028	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
471029	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Amps C Ø	100.0	
471030	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Amps B Ø	100.0	
471031	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Amps A Ø	90.0	
471032	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
471033	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
471034	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
471035	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	9 Months Operations	11	
471036	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
471037	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	Follow-up Action Required?	n	
471038	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	67	°F
471039	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
471040	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
471041	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
471042	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
471043	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
471044	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
471045	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
471046	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
471047	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
471048	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
471049	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
471050	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
471051	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
471052	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
471053	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
471054	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Amps B Ø	193.0	
471055	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Amps A Ø	204.0	
471056	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
471057	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
471058	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
471059	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	9 Month Operations	2	
471060	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Current Tap Position	3R	
471061	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
471062	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
471063	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
471064	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
471065	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	General Comments		
471066	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Follow-up Action Required?	n	
471067	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
471068	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
471069	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
471070	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
471071	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
471072	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Battery Overall Condition	Good	
471073	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Battery Area Ambient Temp	78	°F
471074	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	All Connections OK?	y	
471075	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
471076	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
471077	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
471078	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
471079	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
471080	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
471081	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
471082	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
471083	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
471084	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
471085	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
471086	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
471087	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
471088	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
471089	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
471090	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	General Comments		
471091	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
471092	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
471093	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
471094	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
471095	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Foundation Condition	Good	
471096	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
471097	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
471098	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
471099	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
471100	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
471101	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
471102	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
471103	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Oil Temp Present	45	°C
471104	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Oil Temp Max	45	°C
471105	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
471106	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
471107	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	LTC Totalizer Reading	6513.60	kw
471108	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
471109	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	General Comments		
471110	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	General Comments		
471111	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
471112	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
471113	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
471114	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
471115	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
471116	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
471117	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
471118	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
471119	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
471120	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
471121	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
471122	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
471123	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
471124	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Min Tap Position	Neutral	
471125	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Max Tap Position	8R	
471126	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
471127	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	General Comments		
471128	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
471129	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
471130	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
471131	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
471132	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	General Comments		
471133	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
471134	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
471135	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
471136	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
471137	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
471138	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
471139	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
471140	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	General Comments		
471141	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
471142	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
471143	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
471144	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.8	VDC
471145	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.8	VDC
471146	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
471147	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
471148	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
471149	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
471150	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
471151	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
471152	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
471153	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
471154	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
471155	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
471156	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
471157	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
471158	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
471159	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
471160	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
471161	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
471162	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
471163	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
471164	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
471165	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
471166	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
471167	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
471168	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
471169	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
471170	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
471171	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
471172	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
471173	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
471174	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
471175	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
471176	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Totalizer Meter Reading	1.3570	
471177	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
471178	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Operations This Read Vac	0	
471179	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Operations Counter AL	154	
471180	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Operations Counter AF	154	
471181	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Moisture and Leak Free?	y	
471182	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Maintenance Operations	0	
471183	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Heaters (All) Functioning?	y	
471184	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Grounds in Place?	y	
471185	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	General Comments		
471186	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	General Comments		
471187	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	General Comments		
471188	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
471189	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	Follow-up Action Required?	n	
471190	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
471191	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
471192	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
471193	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Patrol Inspection	General Comments		
471194	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	General Comments		
471195	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	General Comments		
471196	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
471197	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
471198	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
471199	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Foundation Condition	Good	
471200	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Follow-up Action Required?	n	
471201	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Follow-up Action Required?	n	
471202	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Operations Ground	0	
471203	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Operations C Ø	0	
471204	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
471205	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Maintenance Operations	0	
471206	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Operations Counter AF	485	
471207	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Operations Counter AL	485	
471208	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Operations This Read Vac	0	
471209	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Operations B Ø	0	
471210	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Operations A Ø	0	
471211	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
471212	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Switching Operations	0	
471213	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Unknown Operations	0	
471214	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
471215	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
471216	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Equipment Properly Labeled?	y	
471217	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Maintenance Operations	0	
471218	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
471219	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Tank Leaks	None	
471220	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
471221	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Operations Counter	108	
471222	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
471223	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
471224	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	General Comments	ok	
471225	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
471226	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
471227	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
471228	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
471229	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
471230	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
471231	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
471232	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
471233	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
471234	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
471235	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Amps C Ø	35.0	
471236	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Amps B Ø	29.0	
471237	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Amps A Ø	29.0	
471238	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Operations Counter AF	634	
471239	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Operations Counter AL	634	
471240	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Operations This Read Vac	0	
471241	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Switching Operations	0	
471242	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Unknown Operations	0	
471243	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Follow-up Action Required?	n	
471244	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
471245	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
471246	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
471247	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
471248	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
471249	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
471250	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
471251	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
471252	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
471253	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
471254	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
471255	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
471256	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
471257	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
471258	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
471259	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
471260	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
471261	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
471262	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	9 Month Operations	16	
471263	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
471264	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
471265	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
471266	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Amps A Ø	125.0	
471267	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Amps B Ø	125.0	
471268	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Amps C Ø	125.0	
471269	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Patrol Inspection	Equipment Properly Labeled?	y	
471270	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
471271	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
471272	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
471273	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Operations A Ø	0	
471274	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Operations B Ø	0	
471275	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Operations C Ø	0	
471276	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Operations Ground	0	
471277	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Patrol Inspection	Follow-up Action Required?	n	
471278	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Follow-up Action Required?	n	
471279	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	7	
471280	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
471281	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
471282	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
471283	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
471284	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
471285	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
471286	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
471287	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
471288	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
471289	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
471290	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
471291	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
471292	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
471293	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
471294	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
471295	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
471296	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
471297	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
471298	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
471299	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	56	
471300	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	56	
471301	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC As Left Counter	97682	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
471302	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC As Found Counter	97682	
471303	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	General Comments		
471304	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Unknown Operations	0	
471305	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Tank Paint Condition	Good	
471306	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Switching Operations	0	
471307	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
471308	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
471309	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
471310	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	General Comments		
471311	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
471312	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
471313	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
471314	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
471315	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
471316	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
471317	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
471318	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
471319	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
471320	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
471321	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
471322	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
471323	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
471324	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
471325	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
471326	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
471327	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
471328	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
471329	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
471330	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
471331	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
471332	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
471333	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
471334	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	General Comments		
471335	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	General Comments		
471336	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
471337	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
471338	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
471339	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
471340	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
471341	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
471342	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6969.60	kw
471343	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
471344	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
471345	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
471346	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
471347	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
471348	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
471349	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
471350	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
471351	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
471352	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
471353	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
471354	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC Operations Since Last Insp	339	
471355	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
471356	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
471357	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC Min Tap Position	10L	
471358	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC Max Tap Position	6L	
471359	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
471360	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
471361	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
471362	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Bushing Condition	Good	
471363	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Bushings Connection/Risers	Good	
471364	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
471365	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
471366	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
471367	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
471368	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
471369	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Cabinet Paint Condition	Good	
471370	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Equipment Properly Labeled?	y	
471371	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Adjusted Amps A Phase V	5.66	
471372	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
471373	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
471374	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
471375	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
471376	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
471377	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
471378	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
471379	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
471380	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	151	
471381	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	151	
471382	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
471383	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
471384	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
471385	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
471386	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
471387	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
471388	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
471389	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
471390	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	Follow-up Action Required?	n	
471391	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	All Connections OK?	y	
471392	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
471393	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
471394	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
471395	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
471396	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
471397	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
471398	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
471399	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
471400	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
471401	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
471402	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
471403	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
471404	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	BCH000607	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
471405	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	BCH000607	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.9	VDC
471406	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	BCH000607	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.9	VDC
471407	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	BCH000607	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
471408	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	BCH000607	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
471409	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	BCH000607	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
471410	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
471411	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Operations A Ø	0	
471412	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Operations B Ø	0	
471413	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Operations C Ø	0	
471414	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Operations Ground	0	
471415	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Patrol Inspection	Follow-up Action Required?	n	
471416	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Follow-up Action Required?	n	
471417	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Patrol Inspection	General Comments		
471418	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	General Comments		
471419	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
471420	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
471421	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
471422	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
471423	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
471424	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
471425	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
471426	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
471427	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
471428	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
471429	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
471430	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
471431	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
471432	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
471433	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
471434	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
471435	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
471436	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
471437	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Foundation Condition	Good	
471438	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Operations Ground	0	
471439	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Operations C Ø	0	
471440	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Operations B Ø	0	
471441	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Operations A Ø	0	
471442	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
471443	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	General Comments		
471444	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
471445	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
471446	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
471447	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
471448	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
471449	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
471450	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
471451	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
471452	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Amps C Ø	217.0	
471453	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
471454	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
471455	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
471456	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
471457	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
471458	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
471459	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Foundation Condition	Good	
471460	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
471461	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
471462	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
471463	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
471464	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
471465	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	General Comments		
471466	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
471467	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
471468	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
471469	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
471470	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
471471	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
471472	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
471473	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
471474	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
471475	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	BAT001096	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
471476	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	BAT001096	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
471477	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	BAT001096	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	85	°F
471478	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	BAT001096	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
471479	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
471480	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
471481	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
471482	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
471483	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
471484	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
471485	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
471486	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
471487	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
471488	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Tank Leaks	None	
471489	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
471490	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
471491	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Regulator As Left Counter	32059	
471492	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	General Comments		
471493	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
471494	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
471495	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
471496	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
471497	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
471498	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
471499	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
471500	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
471501	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
471502	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
471503	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
471504	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
471505	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Top Oil Temperature Max	38	°C
471506	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Top Oil Temperature Present	38	°C
471507	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
471508	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7260	
471509	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Winding Temp Max	40	°C
471510	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Winding Temp Present	50	°C
471511	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
471512	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
471513	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Operations A Ø	2	
471514	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Operations B Ø	0	
471515	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Operations C Ø	0	
471516	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Operations Ground	0	
471517	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Follow-up Action Required?	n	
471518	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Follow-up Action Required?	n	
471519	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Foundation Condition	Good	
471520	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	General Comments		
471521	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	General Comments		
471522	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Grounds in Place?	y	
471523	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Heaters (All) Functioning?	y	
471524	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Maintenance Operations	0	
471525	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
471526	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
471527	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC Current Tap Position	8L	
471528	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Moisture and Leak Free?	y	
471529	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Operations Counter AF	268	
471530	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
471531	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
471532	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
471533	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
471534	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	BAT001096	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
471535	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	General Comments		
471536	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	BAT001096	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
471537	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	BAT001096	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.5	VDC
471538	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
471539	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
471540	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
471541	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Clear of Trash?	y	
471542	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
471543	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
471544	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
471545	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
471546	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
471547	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
471548	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	General Comments		
471549	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
471550	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
471551	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Vegetation	None	
471552	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
471553	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Unknown Operations	0	
471554	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Switching Operations	0	
471555	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Operations This Read Vac	0	
471556	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Operations Counter AL	139	
471557	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Operations Counter AF	139	
471558	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	BAT001096	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	26.5	VDC
471559	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	BAT001096	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
471560	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	BAT001096	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
471561	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	BAT001096	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
471562	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	BAT001096	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
471563	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	BAT001096	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
471564	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Maintenance Operations	0	
471565	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	General Comments		
471566	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Patrol Inspection	General Comments		
471567	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Follow-up Action Required?	n	
471568	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Patrol Inspection	Follow-up Action Required?	n	
471569	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Evidence of Insects	None	
471570	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
471571	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
471572	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
471573	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
471574	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
471575	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
471576	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
471577	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
471578	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
471579	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
471580	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
471581	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
471582	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	Oil Temp Present	33	°C
471583	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	Oil Temp Max	36	°C
471584	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
471585	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
471586	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
471587	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
471588	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	General Comments		
471589	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
471590	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
471591	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
471592	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
471593	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
471594	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
471595	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
471596	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
471597	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
471598	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
471599	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
471600	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
471601	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
471602	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
471603	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
471604	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
471605	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
471606	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	40.0	
471607	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	33.0	
471608	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	31.0	
471609	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
471610	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
471611	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
471612	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
471613	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
471614	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
471615	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
471616	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
471617	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
471618	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
471619	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	General Comments	ok	
471620	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
471621	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
471622	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Operations Counter	161	
471623	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
471624	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
471625	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
471626	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
471627	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
471628	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
471629	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
471630	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
471631	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Broom on Site?	y	
471632	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
471633	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
471634	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Bushings Connection/Risers	Good	
471635	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
471636	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
471637	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
471638	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
471639	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
471640	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
471641	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
471642	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
471643	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
471644	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
471645	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
471646	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Bushing Condition	Good	
471647	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Amps C Ø	20.0	
471648	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Amps B Ø	30.0	
471649	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4854	
471650	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
471651	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
471652	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
471653	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
471654	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
471655	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
471656	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
471657	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
471658	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
471659	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
471660	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
471661	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	10.00	
471662	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	582.48	kw
471663	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
471664	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
471665	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	123	
471666	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	123	
471667	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
471668	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
471669	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
471670	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
471671	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
471672	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
471673	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	General Comments		
471674	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
471675	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
471676	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
471677	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
471678	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
471679	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
471680	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
471681	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
471682	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
471683	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	General Comments		
471684	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	General Comments		
471685	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
471686	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
471687	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
471688	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
471689	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
471690	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
471691	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Amps A Ø	20.0	
471692	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
471693	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
471694	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
471695	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	9 Month Operations	11	
471696	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Floor Swept?	y	
471697	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
471698	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
471699	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
471700	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
471701	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
471702	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	9 Month Operations	4	
471703	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Amps C Ø	120.0	
471704	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Bushing Condition	Good	
471705	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Bushings Connection/Risers	Good	
471706	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
471707	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
471708	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
471709	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Cabinet Paint Condition	Good	
471710	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Equipment Properly Labeled?	y	
471711	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Adjusted Amps A Phase V	4.81	
471712	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
471713	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Adjusted Amps C Phase V	4.81	
471714	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Operations A Ø	1	
471715	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Operations B Ø	0	
471716	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Operations C Ø	1	
471717	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Operations Ground	0	
471718	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Follow-up Action Required?	n	
471719	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Follow-up Action Required?	n	
471720	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Foundation Condition	Good	
471721	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	General Comments		
471722	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	General Comments		
471723	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Grounds in Place?	y	
471724	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Heaters (All) Functioning?	y	
471725	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Maintenance Operations	0	
471726	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Moisture and Leak Free?	y	
471727	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Operations Counter AF	219	
471728	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Operations Counter AL	219	
471729	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Operations This Read Vac	7	
471730	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
471731	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Switching Operations	5	
471732	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Tank Paint Condition	Good	
471733	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Unknown Operations	0	
471734	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
471735	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
471736	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
471737	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
471738	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
471739	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
471740	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
471741	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
471742	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
471743	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
471744	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
471745	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
471746	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
471747	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
471748	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
471749	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	General Comments		
471750	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
471751	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
471752	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
471753	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
471754	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
471755	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
471756	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
471757	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
471758	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
471759	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
471760	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
471761	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Operations This Read Vac	0	
471762	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Top Oil Temperature Max	40	°C
471763	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
471764	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BAT000317	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
471765	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BAT000317	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
471766	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BAT000317	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	2.1	VDC
471767	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BAT000317	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	2.1	VDC
471768	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BAT000317	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
471769	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BAT000317	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
471770	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BAT000317	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
471771	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BAT000317	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
471772	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BAT000317	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
471773	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BAT000317	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
471774	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BAT000317	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
471775	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	9 Month Operations	15	
471776	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
471777	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
471778	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BAT000317	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
471779	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BAT000317	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
471780	4/11/2019 10:12	Distribution	Salem 12kV Quarterly Inspection	BAT000317	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
471781	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Unknown Operations	0	
471782	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
471783	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
471784	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Totalizer Meter Reading	.7190	
471785	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
471786	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Top Oil Temperature Present	40	°C
471787	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Tank Paint Condition	Good	
471788	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Switching Operations	0	
471789	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Unknown Operations	0	
471790	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Tank Paint Condition	Good	
471791	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Switching Operations	0	
471792	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
471793	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Operations This Read Vac	0	
471794	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Operations Counter AL	436	
471795	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Operations Counter AF	436	
471796	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Moisture and Leak Free?	y	
471797	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Maintenance Operations	0	
471798	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Heaters (All) Functioning?	y	
471799	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	9 Month Operations	9	
471800	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
471801	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
471802	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Grounds in Place?	y	
471803	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	General Comments		
471804	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	General Comments		
471805	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Foundation Condition	Good	
471806	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
471807	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Amps A Ø	110.0	
471808	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
471809	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Amps A Ø	120.0	
471810	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Amps B Ø	120.0	
471811	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Follow-up Action Required?	n	
471812	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Follow-up Action Required?	n	
471813	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Operations Ground	0	
471814	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Operations C Ø	0	
471815	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Operations B Ø	0	
471816	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Operations A Ø	0	
471817	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
471818	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
471819	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
471820	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Equipment Properly Labeled?	y	
471821	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Cabinet Paint Condition	Good	
471822	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
471823	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
471824	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
471825	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Bushings Connection/Risers	Good	
471826	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
471827	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Amps C Ø	240.0	
471828	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Amps B Ø	240.0	
471829	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Amps A Ø	240.0	
471830	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
471831	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	7	
471832	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
471833	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
471834	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
471835	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	General Comments		
471836	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
471837	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
471838	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
471839	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
471840	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
471841	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
471842	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Cabinet Paint Condition	Good	
471843	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
471844	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
471845	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
471846	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
471847	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
471848	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
471849	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
471850	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
471851	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
471852	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
471853	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
471854	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
471855	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
471856	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
471857	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
471858	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
471859	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
471860	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
471861	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
471862	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
471863	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
471864	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
471865	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
471866	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Bushings Connection/Risers	Good	
471867	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	General Comments		
471868	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
471869	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
471870	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
471871	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
471872	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
471873	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
471874	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
471875	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
471876	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
471877	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
471878	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
471879	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
471880	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
471881	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
471882	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Moisture and Leak Free?	y	
471883	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Heaters (All) Functioning?	y	
471884	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Grounds in Place?	y	
471885	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	General Comments		
471886	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Foundation Condition	Good	
471887	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Follow-up Action Required?	n	
471888	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
471889	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
471890	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
471891	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
471892	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
471893	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
471894	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Bushing Condition	Good	
471895	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Tank Paint Condition	Good	
471896	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
471897	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
471898	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
471899	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
471900	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
471901	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
471902	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
471903	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
471904	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
471905	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
471906	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
471907	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	General Comments	ok	
471908	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
471909	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
471910	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
471911	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
471912	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
471913	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
471914	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
471915	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
471916	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Regulator As Left Counter	66624	
471917	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
471918	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
471919	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Tank Leaks	None	
471920	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
471921	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
471922	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.7	VDC
471923	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	25.8	VDC
471924	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
471925	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
471926	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
471927	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
471928	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
471929	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
471930	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
471931	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
471932	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
471933	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
471934	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
471935	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
471936	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.7	VDC
471937	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.9	VDC
471938	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
471939	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
471940	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
471941	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
471942	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
471943	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
471944	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
471945	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	89	°F
471946	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
471947	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
471948	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
471949	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
471950	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
471951	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
471952	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
471953	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
471954	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	205	
471955	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Amps A Ø	20.0	
471956	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Amps B Ø	12.0	
471957	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Amps C Ø	15.0	
471958	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	149	
471959	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
471960	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
471961	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
471962	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
471963	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Cabinet Paint Condition	Good	
471964	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Equipment Properly Labeled?	y	
471965	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Follow-up Action Required?	n	
471966	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Foundation Condition	Good	
471967	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	General Comments		
471968	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Grounds in Place?	y	
471969	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Heaters (All) Functioning?	y	
471970	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Moisture and Leak Free?	y	
471971	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
471972	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	33	°C
471973	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	37	°C
471974	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Tank Paint Condition	Good	
471975	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
471976	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
471977	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
471978	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
471979	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
471980	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
471981	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
471982	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Unknown Operations	0	
471983	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Tank Paint Condition	Good	
471984	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Switching Operations	5	
471985	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Operations This Read Vac	5	
471986	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Operations Counter AL	380	
471987	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Operations Counter AF	380	
471988	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Moisture and Leak Free?	y	
471989	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Maintenance Operations	0	
471990	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Heaters (All) Functioning?	y	
471991	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Grounds in Place?	y	
471992	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	General Comments		
471993	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	General Comments		
471994	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Foundation Condition	Good	
471995	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Follow-up Action Required?	n	
471996	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Follow-up Action Required?	n	
471997	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Operations Ground	0	
471998	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Operations C Ø	0	
471999	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
472000	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
472001	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	Totalizer Meter Reading	.6474	
472002	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
472003	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
472004	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Operations B Ø	0	
472005	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	33	°C
472006	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	37	°C
472007	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
472008	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	35	°C
472009	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
472010	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
472011	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
472012	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
472013	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
472014	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
472015	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
472016	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Operations A Ø	0	
472017	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
472018	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
472019	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
472020	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Equipment Properly Labeled?	y	
472021	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Cabinet Paint Condition	Good	
472022	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
472023	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
472024	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
472025	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Amps C Ø	5.0	
472026	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Amps B Ø	5.0	
472027	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Amps A Ø	0.0	
472028	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
472029	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
472030	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
472031	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	9 Month Operations	2	
472032	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
472033	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
472034	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
472035	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
472036	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
472037	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
472038	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
472039	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
472040	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
472041	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Equipment Properly Labeled?	y	
472042	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Cabinet Paint Condition	Good	
472043	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
472044	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
472045	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
472046	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
472047	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
472048	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
472049	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
472050	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
472051	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Fans Operational?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
472052	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
472053	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	Follow-up Action Required?	n	
472054	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
472055	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
472056	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
472057	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	General Comments		
472058	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	General Comments		
472059	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
472060	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	LTC Totalizer Reading	11653.20	kw
472061	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
472062	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	Oil Temp Max	45	°C
472063	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	Oil Temp Present	40	°C
472064	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
472065	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
472066	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
472067	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
472068	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
472069	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
472070	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
472071	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
472072	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Bushings Connection/Risers	Good	
472073	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Bushing Condition	Good	
472074	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
472075	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
472076	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
472077	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
472078	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
472079	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	General Comments		
472080	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
472081	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
472082	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Trash Emptied?	y	
472083	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
472084	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
472085	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
472086	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Panels Dusted?	y	
472087	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
472088	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
472089	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Bushing Condition	Good	
472090	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Bushings Connection/Risers	Good	
472091	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
472092	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
472093	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
472094	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
472095	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
472096	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
472097	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	General Comments		
472098	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC Operations Since Last Insp	533	
472099	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
472100	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Operations This Read Vac	0	
472101	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Operations Counter AL	256	
472102	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Operations Counter AF	256	
472103	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Moisture and Leak Free?	y	
472104	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Maintenance Operations	0	
472105	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Heaters (All) Functioning?	y	
472106	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Grounds in Place?	y	
472107	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	General Comments		
472108	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	General Comments		
472109	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Foundation Condition	Good	
472110	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Follow-up Action Required?	n	
472111	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Follow-up Action Required?	n	
472112	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
472113	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
472114	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
472115	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
472116	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
472117	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
472118	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC Min Tap Position	11L	
472119	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
472120	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
472121	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
472122	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
472123	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
472124	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
472125	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
472126	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
472127	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Operations Ground	0	
472128	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Operations C Ø	0	
472129	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Operations B Ø	0	
472130	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Operations A Ø	0	
472131	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
472132	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
472133	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
472134	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Equipment Properly Labeled?	y	
472135	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Cabinet Paint Condition	Good	
472136	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	LTCC000298	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
472137	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	LTCC000298	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
472138	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	LTCC000298	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
472139	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC Max Tap Position	5L	
472140	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	9 Month Operations	8	
472141	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
472142	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
472143	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
472144	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Amps A Ø	5.0	
472145	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Amps B Ø	5.0	
472146	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Amps C Ø	5.0	
472147	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Bushing Condition	Good	
472148	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Bushings Connection/Risers	Good	
472149	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
472150	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
472151	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
472152	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Cabinet Paint Condition	Good	
472153	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Equipment Properly Labeled?	y	
472154	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
472155	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC Current Tap Position	8L	
472156	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
472157	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC As Left Counter	10626	
472158	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
472159	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
472160	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
472161	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
472162	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
472163	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
472164	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Panels Dusted?	y	
472165	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
472166	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
472167	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
472168	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
472169	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Clear of Trash?	y	
472170	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
472171	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
472172	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
472173	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
472174	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
472175	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
472176	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	General Comments		
472177	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
472178	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
472179	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
472180	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Vegetation	None	
472181	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
472182	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
472183	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	General Comments	ok	
472184	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
472185	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
472186	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
472187	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
472188	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
472189	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
472190	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
472191	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
472192	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
472193	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
472194	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
472195	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
472196	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
472197	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Unknown Operations	0	
472198	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Tank Paint Condition	Good	
472199	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Switching Operations	0	
472200	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
472201	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
472202	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
472203	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
472204	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
472205	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
472206	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
472207	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
472208	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
472209	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
472210	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
472211	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Switching Operations	0	
472212	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
472213	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
472214	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
472215	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Tank Paint Condition	Good	
472216	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Unknown Operations	0	
472217	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
472218	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
472219	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	General Comments		
472220	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
472221	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
472222	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Foundation Condition	Good	
472223	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
472224	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
472225	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
472226	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
472227	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
472228	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
472229	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
472230	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
472231	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Follow-up Action Required?	n	
472232	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
472233	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
472234	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	General Comments		
472235	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	General Comments		
472236	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
472237	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	LTC Totalizer Reading	3047.04	kw
472238	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
472239	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
472240	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Oil Temp Max	40	°C
472241	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Foundation Condition	Good	
472242	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	General Comments		
472243	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	General Comments		
472244	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Grounds in Place?	y	
472245	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Heaters (All) Functioning?	y	
472246	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Maintenance Operations	0	
472247	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Moisture and Leak Free?	y	
472248	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Operations Counter AF	144	
472249	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Operations Counter AL	144	
472250	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Operations This Read Vac	4	
472251	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
472252	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Oil Temp Present	35	°C
472253	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
472254	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
472255	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
472256	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
472257	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
472258	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
472259	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
472260	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
472261	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
472262	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
472263	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
472264	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
472265	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
472266	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
472267	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Totalizer Meter Reading	.3174	
472268	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
472269	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
472270	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
472271	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
472272	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
472273	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
472274	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Switching Operations	4	
472275	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Tank Paint Condition	Good	
472276	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
472277	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
472278	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
472279	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
472280	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
472281	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
472282	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Foundation Condition	Good	
472283	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
472284	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	General Comments		
472285	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
472286	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
472287	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1258	
472288	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1258	
472289	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
472290	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
472291	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
472292	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC As Found Counter	10623	
472293	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	General Comments		
472294	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	General Comments		
472295	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
472296	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	Follow-up Action Required?	n	
472297	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	LTCC000298	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
472298	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	LTCC000298	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
472299	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	LTCC000298	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
472300	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	LTCC000298	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
472301	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	LTCC000298	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
472302	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
472303	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	General Comments		
472304	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
472305	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
472306	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Floor Swept?	y	
472307	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
472308	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
472309	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Evidence of Insects	None	
472310	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
472311	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
472312	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	All Connections OK?	y	
472313	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	Follow-up Action Required?	n	
472314	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	General Comments		
472315	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	LTC Operation Checked?	y	
472316	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
472317	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
472318	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
472319	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	VRR Time Delay	30	Seconds
472320	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
472321	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
472322	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
472323	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
472324	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
472325	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
472326	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Operations A Ø	0	
472327	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Operations B Ø	0	
472328	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Operations C Ø	0	
472329	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
472330	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
472331	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	General Comments		
472332	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	Desiccant needs to be replaced	
472333	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC As Found Counter	55348	
472334	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC As Left Counter	55348	
472335	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
472336	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11L	
472337	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	9L	
472338	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
472339	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	218	
472340	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
472341	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
472342	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
472343	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
472344	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Operations Ground	0	
472345	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Follow-up Action Required?	n	
472346	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Follow-up Action Required?	n	
472347	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Bushings Connection/Risers	Good	
472348	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Bushing Condition	Good	
472349	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Amps C Ø	90.0	
472350	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
472351	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
472352	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
472353	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Amps B Ø	100.0	
472354	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Amps A Ø	120.0	
472355	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
472356	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
472357	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
472358	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
472359	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
472360	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
472361	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	38	°C
472362	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	40	°C
472363	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
472364	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	LTC Totalizer Reading	9624.00	kw
472365	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
472366	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	General Comments		
472367	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	General Comments		
472368	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
472369	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
472370	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Follow-up Action Required?	n	
472371	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
472372	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
472373	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
472374	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
472375	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
472376	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
472377	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
472378	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
472379	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
472380	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
472381	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
472382	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
472383	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
472384	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
472385	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	43	°C
472386	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	43	°C
472387	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	45	°C
472388	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
472389	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
472390	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
472391	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
472392	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
472393	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
472394	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
472395	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
472396	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
472397	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
472398	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
472399	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
472400	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
472401	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
472402	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
472403	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
472404	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	General Comments	MISSING 3 FANS.	
472405	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
472406	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Vegetation	None	
472407	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
472408	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	General Comments		
472409	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
472410	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
472411	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
472412	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
472413	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
472414	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
472415	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Clear of Trash?	y	
472416	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
472417	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
472418	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Ambient Temp	82	°F
472419	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
472420	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
472421	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
472422	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
472423	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	General Comments		
472424	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
472425	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
472426	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
472427	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
472428	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Amps A Ø	5.0	
472429	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Amps B Ø	5.0	
472430	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Amps C Ø	5.0	
472431	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Bushing Condition	Good	
472432	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Bushings Connection/Risers	Good	
472433	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
472434	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
472435	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
472436	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
472437	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
472438	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
472439	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
472440	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Cabinet Paint Condition	Good	
472441	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Equipment Properly Labeled?	y	
472442	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
472443	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
472444	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
472445	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Operations A Ø	0	
472446	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Operations B Ø	0	
472447	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Operations C Ø	0	
472448	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Operations Ground	0	
472449	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Follow-up Action Required?	n	
472450	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Follow-up Action Required?	n	
472451	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Foundation Condition	Good	
472452	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	General Comments		
472453	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	General Comments		
472454	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Grounds in Place?	y	
472455	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Heaters (All) Functioning?	y	
472456	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Amps A Ø	10.0	
472457	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
472458	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
472459	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
472460	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	9 Month Operations	10	
472461	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
472462	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
472463	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Winding Temp Present	33	°C
472464	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Winding Temp Max	55	°C
472465	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Totalizer Meter Reading	.4010	
472466	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
472467	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
472468	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
472469	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
472470	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
472471	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
472472	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
472473	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
472474	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
472475	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
472476	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Oil Temp Present	33	°C
472477	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Oil Temp Max	54	°C
472478	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	750	psi
472479	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
472480	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Maintenance Operations	0	
472481	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Moisture and Leak Free?	y	
472482	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Operations Counter AF	168	
472483	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Operations Counter AL	168	
472484	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Operations This Read Vac	5	
472485	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Switching Operations	5	
472486	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Tank Paint Condition	Good	
472487	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Unknown Operations	0	
472488	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
472489	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
472490	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
472491	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
472492	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
472493	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
472494	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
472495	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
472496	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
472497	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
472498	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
472499	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
472500	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
472501	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
472502	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
472503	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
472504	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
472505	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	General Comments		
472506	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
472507	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
472508	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
472509	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
472510	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	General Comments		
472511	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
472512	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
472513	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
472514	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
472515	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
472516	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
472517	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Operations A Ø	0	
472518	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Operations B Ø	0	
472519	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Operations C Ø	0	
472520	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Operations Ground	0	
472521	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Follow-up Action Required?	n	
472522	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Follow-up Action Required?	n	
472523	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Foundation Condition	Good	
472524	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	General Comments		
472525	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	General Comments		
472526	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Grounds in Place?	y	
472527	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
472528	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Maintenance Operations	0	
472529	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
472530	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Operations Counter AF	43	
472531	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
472532	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
472533	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
472534	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
472535	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
472536	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
472537	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
472538	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
472539	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
472540	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
472541	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
472542	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
472543	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Operations Counter AL	43	
472544	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Operations This Read Vac	0	
472545	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
472546	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
472547	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	General Comments	no spare fuses	
472548	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
472549	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
472550	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
472551	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
472552	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
472553	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
472554	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
472555	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Foundation Condition	Good	
472556	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
472557	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
472558	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
472559	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
472560	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
472561	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
472562	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
472563	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
472564	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Vegetation	None	
472565	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
472566	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	General Comments		
472567	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
472568	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
472569	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
472570	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
472571	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
472572	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
472573	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Clear of Trash?	y	
472574	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
472575	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
472576	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Ambient Temp	73	°F

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
472577	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
472578	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
472579	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Follow-up Action Required?	n	
472580	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
472581	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
472582	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	General Comments		
472583	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	General Comments		
472584	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	General Comments		
472585	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	9 Month Operations	0	
472586	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
472587	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
472588	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
472589	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Amps A Ø	0.0	
472590	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Amps B Ø	0.0	
472591	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
472592	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
472593	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
472594	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
472595	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
472596	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
472597	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
472598	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
472599	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
472600	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
472601	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
472602	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
472603	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
472604	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
472605	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
472606	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
472607	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
472608	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Amps C Ø	0.0	
472609	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Bushing Condition	Good	
472610	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
472611	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
472612	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
472613	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
472614	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
472615	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
472616	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
472617	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
472618	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
472619	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
472620	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	LTC Totalizer Reading	16800.00	kw
472621	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
472622	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
472623	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
472624	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
472625	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
472626	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
472627	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
472628	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
472629	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
472630	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
472631	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
472632	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
472633	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
472634	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
472635	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
472636	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Tank Paint Condition	Good	
472637	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
472638	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Moisture and Leak Free?	y	
472639	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Heaters (All) Functioning?	y	
472640	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Grounds in Place?	y	
472641	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	General Comments		
472642	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Foundation Condition	Good	
472643	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	PF000360	PowerFuse	TT-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
472644	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	PF000360	PowerFuse	TT-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
472645	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	PF000361	PowerFuse	TT-34KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
472646	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	PF000361	PowerFuse	TT-34KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
472647	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	PF000362	PowerFuse	TT-34KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
472648	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	PF000362	PowerFuse	TT-34KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
472649	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Follow-up Action Required?	n	
472650	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Equipment Properly Labeled?	y	
472651	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
472652	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
472653	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
472654	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	9 Months Operations	2	
472655	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
472656	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
472657	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
472658	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Amps A Ø	345.0	
472659	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Amps B Ø	387.0	
472660	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Amps C Ø	368.0	
472661	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
472662	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
472663	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
472664	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
472665	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
472666	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
472667	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
472668	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Bushings Connection/Risers	Good	
472669	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Bushing Condition	Good	
472670	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Operations C Ø	0	
472671	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Operations B Ø	0	
472672	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Operations A Ø	0	
472673	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Adjusted Amps C Phase V	0	
472674	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
472675	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Adjusted Amps B Phase V	0	
472676	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Adjusted Amps A Phase V	0	
472677	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Amps C Ø	0	
472678	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Amps B Ø	0	
472679	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
472680	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
472681	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
472682	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
472683	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Amps C Ø	0.0	
472684	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Amps B Ø	0.0	
472685	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Amps A Ø	0.0	
472686	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
472687	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
472688	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
472689	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
472690	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
472691	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
472692	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Patrol Inspection	General Comments		
472693	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	General Comments		
472694	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
472695	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	General Comments		
472696	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
472697	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Max Tap Position	8L	
472698	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
472699	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
472700	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
472701	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
472702	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
472703	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
472704	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Regulator As Left Counter	5764	
472705	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Unknown Operations	0	
472706	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
472707	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
472708	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
472709	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
472710	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
472711	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
472712	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Switching Operations	0	
472713	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
472714	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
472715	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Operations This Read Vac	0	
472716	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Operations Counter AL	255	
472717	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Operations Counter AF	255	
472718	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Maintenance Operations	0	
472719	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	General Comments		
472720	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
472721	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
472722	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Tank Leaks	None	
472723	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
472724	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Unknown Operations	0	
472725	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Switching Operations	0	
472726	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Operations This Read AM	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
472727	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Operations Counter AL	114	
472728	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Operations Counter AF	114	
472729	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Maintenance Operations	0	
472730	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	General Comments		
472731	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Patrol Inspection	General Comments		
472732	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	Follow-up Action Required?	n	
472733	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
472734	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	General Comments		
472735	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	General Comments		
472736	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Follow-up Action Required?	n	
472737	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Patrol Inspection	Follow-up Action Required?	n	
472738	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Operations Ground	0	
472739	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Operations C Ø	0	
472740	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Operations B Ø	0	
472741	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC As Found Counter	590084	
472742	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC As Left Counter	590086	
472743	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
472744	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC Current Tap Position	11L	
472745	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC Max Tap Position	7L	
472746	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC Min Tap Position	14L	
472747	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
472748	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC Operations Since Last Insp	226	
472749	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
472750	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
472751	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
472752	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Follow-up Action Required?	n	
472753	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Operations Ground	0	
472754	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
472755	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
472756	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	6.0	VDC
472757	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	8.0	VDC
472758	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Operations A Ø	0	
472759	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
472760	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
472761	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
472762	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
472763	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Amps A Ø	3.0	
472764	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
472765	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	LTC Operation Checked?	y	
472766	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	General Comments		
472767	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	Follow-up Action Required?	n	
472768	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	All Connections OK?	y	
472769	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	36	
472770	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
472771	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
472772	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
472773	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
472774	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
472775	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
472776	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
472777	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
472778	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
472779	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
472780	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
472781	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
472782	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
472783	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
472784	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
472785	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
472786	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
472787	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
472788	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
472789	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
472790	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
472791	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
472792	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
472793	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC Operations Since Last Insp	276	
472794	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.5	psi
472795	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC Min Tap Position	10L	
472796	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC Max Tap Position	5L	
472797	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC Current Tap Position	7L	
472798	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
472799	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC As Left Counter	150004	
472800	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC As Found Counter	150000	
472801	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
472802	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	General Comments		
472803	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
472804	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	Follow-up Action Required?	n	
472805	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
472806	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
472807	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
472808	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
472809	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
472810	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
472811	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
472812	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
472813	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
472814	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	247	
472815	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	5.0	
472816	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	5.0	
472817	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	5.0	
472818	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
472819	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
472820	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
472821	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
472822	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
472823	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
472824	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	9 Month Operations	4	
472825	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
472826	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
472827	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
472828	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Maintenance Operations	0	
472829	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Operations Counter AF	18	
472830	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Operations Counter AL	18	
472831	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Operations This Read AM	0	
472832	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Switching Operations	0	
472833	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Unknown Operations	0	
472834	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	Follow-up Action Required?	n	
472835	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
472836	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	General Comments		
472837	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	General Comments		
472838	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC As Found Counter	31286	
472839	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC As Left Counter	31288	
472840	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
472841	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC Current Tap Position	4L	
472842	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC Max Tap Position	2L	
472843	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC Min Tap Position	4L	
472844	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC Operations Since Last Insp	98	
472845	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
472846	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
472847	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
472848	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Amps A Ø	0	
472849	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Accumulated Fault Duty C Ph V	0	%
472850	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Accumulated Fault Duty B Ph V	0	%
472851	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Accumulated Fault Duty A Ph V	0	%
472852	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	9 Month Operations	2	
472853	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
472854	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
472855	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
472856	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
472857	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
472858	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
472859	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
472860	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
472861	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
472862	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
472863	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
472864	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	General Comments	ok	
472865	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
472866	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Max Tap Position	5L	
472867	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
472868	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
472869	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
472870	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
472871	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
472872	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
472873	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Regulator As Left Counter	185644	
472874	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
472875	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
472876	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Tank Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
472877	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
472878	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	9 Months Operations	0	
472879	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
472880	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Operations Counter	195	
472881	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
472882	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	General Comments		
472883	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
472884	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
472885	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
472886	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	0	
472887	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
472888	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
472889	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
472890	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Amps C Ø	3.0	
472891	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Amps B Ø	5.0	
472892	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	VRR Time Delay	30	Seconds
472893	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
472894	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
472895	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Equipment Properly Labeled?	y	
472896	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
472897	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
472898	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
472899	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Operations A Ø	0	
472900	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Operations B Ø	0	
472901	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Operations C Ø	0	
472902	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Operations Ground	0	
472903	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Follow-up Action Required?	n	
472904	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Follow-up Action Required?	n	
472905	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Foundation Condition	Good	
472906	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	General Comments		
472907	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	General Comments		
472908	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	General Comments		
472909	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
472910	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Max Tap Position	7L	
472911	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
472912	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
472913	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	Follow-up Action Required?	n	
472914	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
472915	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	General Comments		
472916	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	General Comments		
472917	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC As Found Counter	16342	
472918	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC As Left Counter	16352	
472919	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
472920	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
472921	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Oil Temp Max	65	°C
472922	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Oil Temp Present	45	°C
472923	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
472924	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
472925	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
472926	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
472927	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
472928	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
472929	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
472930	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
472931	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Unknown Operations	0	
472932	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Tank Paint Condition	Good	
472933	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Switching Operations	0	
472934	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
472935	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Operations This Read Vac	0	
472936	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Operations Counter AL	159	
472937	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Operations Counter AF	159	
472938	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
472939	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
472940	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
472941	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
472942	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
472943	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
472944	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
472945	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
472946	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Maintenance Operations	0	
472947	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
472948	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Grounds in Place?	y	
472949	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	General Comments		
472950	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	General Comments		
472951	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
472952	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Follow-up Action Required?	n	
472953	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Follow-up Action Required?	n	
472954	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Operations Ground	0	
472955	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Operations C Ø	0	
472956	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Operations B Ø	0	
472957	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Operations A Ø	0	
472958	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
472959	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
472960	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
472961	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
472962	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
472963	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
472964	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
472965	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
472966	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
472967	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
472968	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
472969	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
472970	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
472971	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
472972	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
472973	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
472974	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	9	
472975	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
472976	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
472977	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	n	
472978	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
472979	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	General Comments		
472980	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
472981	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
472982	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
472983	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
472984	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
472985	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
472986	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
472987	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
472988	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
472989	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
472990	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
472991	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
472992	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
472993	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
472994	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
472995	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
472996	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
472997	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
472998	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Vegetation	None	
472999	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
473000	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	General Comments		
473001	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
473002	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
473003	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
473004	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
473005	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
473006	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
473007	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Clear of Trash?	y	
473008	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
473009	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
473010	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Ambient Temp	85	°F
473011	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Amps A Ø	30.0	
473012	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Amps B Ø	30.0	
473013	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Amps C Ø	30.0	
473014	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
473015	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
473016	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
473017	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
473018	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
473019	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
473020	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	20.0	
473021	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	20.0	
473022	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	20.0	
473023	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Bushing Condition	Good	
473024	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Bushings Connection/Risers	Good	
473025	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
473026	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
473027	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
473028	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Cabinet Paint Condition	Good	
473029	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
473030	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
473031	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
473032	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Clear of Trash?	y	
473033	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
473034	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
473035	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Ambient Temp	82	°F
473036	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC Current Tap Position	9L	
473037	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
473038	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
473039	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
473040	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
473041	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	General Comments		
473042	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
473043	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC Max Tap Position	8L	
473044	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC Min Tap Position	15L	
473045	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
473046	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Patrol Inspection	General Comments		
473047	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	General Comments	Phase C High Set Instantaneous	
473048	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Maintenance Operations	0	
473049	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Operations Counter AF	157	
473050	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Operations Counter AL	157	
473051	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Operations This Read Vac	0	
473052	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Switching Operations	0	
473053	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Unknown Operations	0	
473054	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
473055	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
473056	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
473057	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
473058	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Vegetation	None	
473059	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
473060	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
473061	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Current Tap Position	11L	
473062	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
473063	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
473064	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
473065	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
473066	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
473067	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	General Comments		
473068	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
473069	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
473070	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
473071	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
473072	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
473073	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	General Comments		
473074	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
473075	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Max Tap Position	9L	
473076	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
473077	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
473078	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
473079	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
473080	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
473081	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
473082	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Regulator As Left Counter	4807	
473083	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
473084	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
473085	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Tank Leaks	None	
473086	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
473087	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
473088	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
473089	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
473090	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
473091	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
473092	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Current Tap Position	10L	
473093	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
473094	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
473095	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
473096	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
473097	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
473098	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
473099	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
473100	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
473101	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
473102	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Amps C Ø	900.0	
473103	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Amps B Ø	900.0	
473104	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Amps A Ø	900.0	
473105	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
473106	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Totalizer Meter Reading	.7000	
473107	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Winding Temp Max	50	°C
473108	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Winding Temp Present	45	°C
473109	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
473110	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
473111	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
473112	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
473113	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Regulator As Left Counter	5093	
473114	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
473115	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
473116	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Tank Leaks	None	
473117	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
473118	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Clear of Trash?	y	
473119	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	9 Month Operations	0	
473120	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
473121	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
473122	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
473123	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Amps A Ø	300.0	
473124	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Amps B Ø	300.0	
473125	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Amps C Ø	350.0	
473126	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
473127	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
473128	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
473129	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
473130	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
473131	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
473132	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
473133	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Grounds in Place?	y	
473134	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Heaters (All) Functioning?	y	
473135	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Maintenance Operations	0	
473136	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Moisture and Leak Free?	y	
473137	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Operations Counter AF	148	
473138	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Operations Counter AL	148	
473139	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Operations This Read Vac	0	
473140	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
473141	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Switching Operations	0	
473142	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Tank Paint Condition	Good	
473143	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Unknown Operations	0	
473144	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Operations Ground	0	
473145	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
473146	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
473147	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
473148	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Vegetation	None	
473149	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
473150	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
473151	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
473152	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
473153	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
473154	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	9 Month Operations	2	
473155	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	General Comments		
473156	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
473157	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
473158	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
473159	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
473160	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
473161	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
473162	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
473163	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	9 Month Operations	8	
473164	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Ambient Temp	66	°F
473165	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
473166	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Clear of Trash?	y	
473167	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
473168	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
473169	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
473170	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
473171	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
473172	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Unknown Operations	0	
473173	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Tank Paint Condition	Good	
473174	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Switching Operations	0	
473175	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Operations This Read Vac	0	
473176	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
473177	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Operations Counter AL	174	
473178	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Operations Counter AF	174	
473179	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Moisture and Leak Free?	y	
473180	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
473181	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
473182	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	General Comments		
473183	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	9 Month Operations	9	
473184	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
473185	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
473186	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
473187	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Amps A Ø	5.0	
473188	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Amps B Ø	5.0	
473189	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Amps C Ø	5.0	
473190	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Bushing Condition	Good	
473191	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
473192	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Unknown Operations	0	
473193	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Bushings Connection/Risers	Good	
473194	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
473195	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
473196	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
473197	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Cabinet Paint Condition	Good	
473198	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Maintenance Operations	0	
473199	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Grounds in Place?	y	
473200	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	General Comments		
473201	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	General Comments		
473202	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Foundation Condition	Good	
473203	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Follow-up Action Required?	n	
473204	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Follow-up Action Required?	n	
473205	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Operations Ground	0	
473206	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Operations C Ø	0	
473207	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Operations B Ø	0	
473208	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Operations A Ø	0	
473209	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
473210	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
473211	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
473212	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Equipment Properly Labeled?	y	
473213	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Cabinet Paint Condition	Good	
473214	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
473215	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
473216	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
473217	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Bushings Connection/Risers	Good	
473218	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Bushing Condition	Good	
473219	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Amps C Ø	110.0	
473220	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Amps B Ø	105.0	
473221	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Amps A Ø	115.0	
473222	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
473223	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
473224	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
473225	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	9 Month Operations	55	
473226	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Equipment Properly Labeled?	y	
473227	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
473228	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
473229	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
473230	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Follow-up Action Required?	n	
473231	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Follow-up Action Required?	n	
473232	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Operations Ground	0	
473233	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Operations C Ø	0	
473234	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Operations B Ø	0	
473235	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Min Tap Position	Neutral	
473236	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Max Tap Position	7R	
473237	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
473238	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	General Comments		
473239	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
473240	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
473241	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
473242	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
473243	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
473244	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
473245	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
473246	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
473247	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
473248	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
473249	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Cabinet Paint Condition	Good	
473250	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Operations A Ø	0	
473251	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
473252	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
473253	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
473254	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Equipment Properly Labeled?	y	
473255	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Cabinet Paint Condition	Good	
473256	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
473257	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
473258	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
473259	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Bushings Connection/Risers	Good	
473260	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Bushing Condition	Good	
473261	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Amps C Ø	0.0	
473262	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Amps B Ø	0.0	
473263	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Amps A Ø	0.0	
473264	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
473265	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
473266	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
473267	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	9 Month Operations	44	
473268	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
473269	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
473270	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
473271	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
473272	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
473273	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
473274	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
473275	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
473276	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
473277	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
473278	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
473279	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
473280	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
473281	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
473282	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
473283	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
473284	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	General Comments		
473285	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
473286	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
473287	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
473288	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Bushings Connection/Risers	Good	
473289	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Bushing Condition	Good	
473290	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Amps C Ø	256.0	
473291	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Amps B Ø	250.0	
473292	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Amps A Ø	230.0	
473293	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
473294	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
473295	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
473296	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
473297	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
473298	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
473299	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
473300	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
473301	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
473302	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	General Comments		
473303	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	General Comments		
473304	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Foundation Condition	Good	
473305	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Follow-up Action Required?	n	
473306	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Follow-up Action Required?	n	
473307	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
473308	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
473309	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
473310	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	LTCC000712	LTCControl	601-1	LTC Control Insp	VRR Time Delay	30	Seconds
473311	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	LTCC000712	LTCControl	601-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
473312	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	LTCC000712	LTCControl	601-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
473313	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	LTCC000712	LTCControl	601-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
473314	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	LTCC000712	LTCControl	601-1	LTC Control Insp	LTC Operation Checked?	y	
473315	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	LTCC000712	LTCControl	601-1	LTC Control Insp	General Comments		
473316	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	LTCC000712	LTCControl	601-1	LTC Control Insp	Follow-up Action Required?	n	
473317	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	LTCC000712	LTCControl	601-1	LTC Control Insp	All Connections OK?	y	
473318	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Operations Ground	0	
473319	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Operations C Ø	0	
473320	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Operations B Ø	0	
473321	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Operations A Ø	0	
473322	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
473323	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
473324	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
473325	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Equipment Properly Labeled?	y	
473326	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
473327	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Ambient Temp	74	°F
473328	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
473329	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Clear of Trash?	y	
473330	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
473331	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
473332	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
473333	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
473334	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
473335	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
473336	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	General Comments		
473337	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
473338	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
473339	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Vegetation	None	
473340	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
473341	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
473342	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
473343	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
473344	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
473345	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
473346	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
473347	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
473348	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
473349	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
473350	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
473351	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
473352	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
473353	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
473354	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
473355	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
473356	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
473357	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
473358	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
473359	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
473360	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Cabinet Paint Condition	Good	
473361	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
473362	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
473363	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
473364	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Operations A Ø	0	
473365	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Operations B Ø	0	
473366	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Operations C Ø	0	
473367	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Operations Ground	0	
473368	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Follow-up Action Required?	n	
473369	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Follow-up Action Required?	n	
473370	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Foundation Condition	Good	
473371	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	General Comments		
473372	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	General Comments		
473373	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Grounds in Place?	y	
473374	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
473375	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	General Comments		
473376	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
473377	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
473378	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
473379	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Vegetation	None	
473380	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
473381	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Heaters (All) Functioning?	y	
473382	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Maintenance Operations	0	
473383	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
473384	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
473385	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
473386	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
473387	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
473388	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
473389	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
473390	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
473391	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Moisture and Leak Free?	y	
473392	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Operations Counter AF	123	
473393	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Tank Paint Condition	Good	
473394	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Switching Operations	0	
473395	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
473396	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Operations This Read Vac	1	
473397	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Operations Counter AL	0	
473398	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Operations Counter AF	183	
473399	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Moisture and Leak Free?	y	
473400	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Maintenance Operations	1	
473401	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Heaters (All) Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
473402	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Grounds in Place?	y	
473403	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Operations Counter AL	123	
473404	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
473405	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	General Comments		
473406	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
473407	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
473408	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
473409	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
473410	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
473411	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
473412	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
473413	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
473414	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
473415	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
473416	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
473417	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
473418	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
473419	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Foundation Condition	Good	
473420	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
473421	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
473422	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	General Comments		
473423	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
473424	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
473425	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
473426	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
473427	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
473428	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
473429	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
473430	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
473431	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
473432	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
473433	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
473434	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
473435	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
473436	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
473437	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	674	
473438	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	674	
473439	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
473440	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
473441	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
473442	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
473443	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
473444	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
473445	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
473446	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
473447	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
473448	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
473449	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
473450	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
473451	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	
473452	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.84	%
473453	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
473454	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Oil Temp Max	48	°C
473455	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	4.59	%
473456	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
473457	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
473458	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
473459	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	LTC Totalizer Reading	6226.56	kw
473460	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
473461	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Vegetation	None	
473462	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
473463	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
473464	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	General Comments		
473465	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	General Comments		
473466	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
473467	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Cabinet Paint Condition	Good	
473468	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Equipment Properly Labeled?	y	
473469	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
473470	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
473471	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
473472	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Operations A Ø	0	
473473	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Operations B Ø	0	
473474	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Operations C Ø	0	
473475	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Operations Ground	0	
473476	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
473477	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Follow-up Action Required?	n	
473478	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Foundation Condition	Good	
473479	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	General Comments		
473480	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	General Comments		
473481	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Grounds in Place?	y	
473482	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Unknown Operations	0	
473483	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Tank Paint Condition	Good	
473484	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Switching Operations	1	
473485	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Operations This Read Vac	1	
473486	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Operations Counter AL	139	
473487	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Operations Counter AF	139	
473488	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
473489	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Heaters (All) Functioning?	y	
473490	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	General Comments		
473491	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
473492	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
473493	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
473494	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
473495	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
473496	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
473497	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Clear of Trash?	y	
473498	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
473499	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
473500	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
473501	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
473502	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
473503	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
473504	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
473505	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
473506	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
473507	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
473508	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
473509	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	General Comments		
473510	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
473511	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
473512	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Foundation Condition	Good	
473513	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
473514	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
473515	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
473516	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
473517	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
473518	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
473519	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
473520	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
473521	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	General Comments		
473522	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
473523	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
473524	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
473525	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
473526	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
473527	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	4.59	%
473528	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0	%
473529	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
473530	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
473531	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Totalizer Meter Reading	.6486	
473532	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
473533	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
473534	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
473535	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
473536	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
473537	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Positive DC Ground	22.0	VDC
473538	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Negative DC Ground	24.0	VDC
473539	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	General Comments		
473540	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
473541	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
473542	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
473543	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
473544	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
473545	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
473546	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
473547	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
473548	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Oil Temp Present	43	°C
473549	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
473550	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
473551	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
473552	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
473553	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
473554	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
473555	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
473556	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	9 Month Operations	9	
473557	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
473558	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
473559	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
473560	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Amps A Ø	5.0	
473561	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Amps B Ø	5.0	
473562	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Amps C Ø	5.0	
473563	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Bushing Condition	Good	
473564	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Bushings Connection/Risers	Good	
473565	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Cabinet Paint Condition	Good	
473566	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
473567	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
473568	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
473569	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Bushings Connection/Risers	Good	
473570	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Bushing Condition	Good	
473571	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Amps C Ø	127.0	
473572	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Amps B Ø	125.0	
473573	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Amps A Ø	122.0	
473574	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
473575	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
473576	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
473577	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	9 Month Operations	1	
473578	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Unknown Operations	0	
473579	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
473580	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
473581	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
473582	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
473583	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
473584	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
473585	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
473586	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
473587	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Ambient Temp	83	°F
473588	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Unknown Operations	0	
473589	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Tank Paint Condition	Good	
473590	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Switching Operations	1	
473591	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
473592	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Operations This Read Vac	1	
473593	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Operations Counter AL	235	
473594	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Operations Counter AF	235	
473595	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Moisture and Leak Free?	y	
473596	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Maintenance Operations	0	
473597	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Grounds in Place?	y	
473598	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	General Comments		
473599	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	General Comments		
473600	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Foundation Condition	Good	
473601	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Follow-up Action Required?	n	
473602	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Operations Ground	0	
473603	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Operations C Ø	0	
473604	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Operations B Ø	0	
473605	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
473606	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Tank Leaks	None	
473607	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
473608	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
473609	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Regulator As Left Counter	28970	
473610	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Operations A Ø	0	
473611	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
473612	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
473613	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
473614	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Equipment Properly Labeled?	y	
473615	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
473616	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
473617	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
473618	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
473619	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
473620	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Unknown Operations	0	
473621	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Tank Paint Condition	Good	
473622	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Switching Operations	2	
473623	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Operations This Read Vac	2	
473624	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Operations Counter AL	193	
473625	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Operations Counter AF	193	
473626	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
473627	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Maintenance Operations	0	
473628	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Grounds in Place?	y	
473629	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	General Comments		
473630	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	General Comments		
473631	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Foundation Condition	Good	
473632	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
473633	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Maintenance Operations	0	
473634	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Moisture and Leak Free?	y	
473635	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Operations Counter AF	715	
473636	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Operations Counter AL	715	
473637	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Operations This Read Vac	7	
473638	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
473639	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Switching Operations	7	
473640	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Tank Paint Condition	Good	
473641	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
473642	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Follow-up Action Required?	n	
473643	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
473644	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
473645	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
473646	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
473647	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Maintenance Operations	0	
473648	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Grounds in Place?	y	
473649	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	General Comments		
473650	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	General Comments		
473651	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Foundation Condition	Good	
473652	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Follow-up Action Required?	n	
473653	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Follow-up Action Required?	n	
473654	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Operations Ground	0	
473655	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Operations C Ø	0	
473656	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Operations B Ø	0	
473657	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Operations A Ø	0	
473658	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
473659	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
473660	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
473661	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
473662	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
473663	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
473664	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
473665	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Unknown Operations	0	
473666	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Tank Paint Condition	Good	
473667	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Switching Operations	1	
473668	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
473669	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Operations This Read Vac	1	
473670	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Operations Counter AL	227	
473671	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Operations Counter AF	227	
473672	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Moisture and Leak Free?	y	
473673	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Maintenance Operations	0	
473674	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Grounds in Place?	y	
473675	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	General Comments		
473676	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	General Comments		
473677	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Foundation Condition	Good	
473678	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Follow-up Action Required?	n	
473679	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
473680	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
473681	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
473682	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Bushing Condition	Good	
473683	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Amps C Ø	455.0	
473684	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Amps B Ø	460.0	
473685	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Amps A Ø	450.0	
473686	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
473687	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
473688	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
473689	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Follow-up Action Required?	n	
473690	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Operations Ground	0	
473691	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Operations C Ø	0	
473692	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Operations B Ø	0	
473693	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Operations A Ø	0	
473694	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
473695	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	9 Month Operations	1	
473696	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
473697	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
473698	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Equipment Properly Labeled?	y	
473699	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Operations C Ø	0	
473700	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Operations B Ø	0	
473701	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
473702	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Operations Ground	0	
473703	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	320.0	
473704	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	320.0	
473705	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
473706	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
473707	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
473708	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
473709	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
473710	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Follow-up Action Required?	n	
473711	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Follow-up Action Required?	n	
473712	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Foundation Condition	Good	
473713	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	General Comments		
473714	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	General Comments		
473715	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Grounds in Place?	y	
473716	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Maintenance Operations	0	
473717	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Moisture and Leak Free?	y	
473718	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Operations Counter AF	236	
473719	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Operations Counter AL	236	
473720	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Operations This Read Vac	0	
473721	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
473722	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Switching Operations	0	
473723	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Tank Paint Condition	Good	
473724	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Unknown Operations	0	
473725	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	General Comments		
473726	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
473727	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
473728	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
473729	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
473730	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Equipment Properly Labeled?	y	
473731	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Cabinet Paint Condition	Good	
473732	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
473733	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
473734	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
473735	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	43	°C
473736	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	43	°C
473737	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	39	°C
473738	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
473739	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
473740	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
473741	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
473742	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
473743	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
473744	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
473745	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Bushings Connection/Risers	Good	
473746	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Bushing Condition	Good	
473747	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Amps C Ø	49.0	
473748	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Amps B Ø	77.0	
473749	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Amps A Ø	52.0	
473750	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
473751	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
473752	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
473753	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	9 Month Operations	1	
473754	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	45	°C
473755	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
473756	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	45	°C
473757	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
473758	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
473759	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
473760	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
473761	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
473762	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
473763	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Unknown Operations	0	
473764	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Tank Paint Condition	Good	
473765	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Switching Operations	4	
473766	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	38	°C
473767	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	38	°C
473768	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	All Connections OK?	y	
473769	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
473770	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
473771	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
473772	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
473773	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
473774	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	9 Month Operations	4	
473775	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
473776	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
473777	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
473778	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
473779	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
473780	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
473781	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
473782	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
473783	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
473784	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
473785	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
473786	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
473787	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
473788	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Amps A Ø	10.0	
473789	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Amps B Ø	10.0	
473790	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Amps C Ø	10.0	
473791	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Bushing Condition	Good	
473792	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Bushings Connection/Risers	Good	
473793	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
473794	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
473795	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Unknown Operations	0	
473796	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Tank Paint Condition	Good	
473797	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
473798	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
473799	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
473800	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
473801	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Cabinet Paint Condition	Good	
473802	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Equipment Properly Labeled?	y	
473803	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
473804	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
473805	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
473806	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Operations A Ø	0	
473807	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Operations B Ø	0	
473808	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Operations C Ø	0	
473809	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
473810	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
473811	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
473812	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
473813	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
473814	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
473815	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Switching Operations	1	
473816	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
473817	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Operations This Read Vac	1	
473818	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Operations Counter AL	169	
473819	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Operations Counter AF	169	
473820	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Moisture and Leak Free?	y	
473821	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Maintenance Operations	0	
473822	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Heaters (All) Functioning?	y	
473823	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Grounds in Place?	y	
473824	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	General Comments		
473825	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	General Comments		
473826	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Foundation Condition	Good	
473827	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Follow-up Action Required?	n	
473828	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Follow-up Action Required?	n	
473829	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Operations Ground	0	
473830	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
473831	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
473832	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	320.0	
473833	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
473834	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
473835	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
473836	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Equipment Properly Labeled?	y	
473837	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
473838	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
473839	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
473840	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
473841	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC Operations Since Last Insp	342	
473842	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	28	°C
473843	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
473844	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
473845	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.5	psi
473846	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC Min Tap Position	11L	
473847	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
473848	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC Current Tap Position	8L	
473849	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
473850	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC As Left Counter	3712	
473851	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC As Found Counter	3712	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
473852	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	General Comments		
473853	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	General Comments		
473854	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
473855	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	Follow-up Action Required?	n	
473856	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Cabinet Paint Condition	Good	
473857	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
473858	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
473859	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
473860	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Bushings Connection/Risers	Good	
473861	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Bushing Condition	Good	
473862	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Amps C Ø	10.0	
473863	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Amps B Ø	10.0	
473864	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	VRR Time Delay	30	Seconds
473865	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
473866	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
473867	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
473868	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	LTC Operation Checked?	y	
473869	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	General Comments		
473870	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	Follow-up Action Required?	n	
473871	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	All Connections OK?	y	
473872	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Operations This Read SF6	1	
473873	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Operations Counter AL	65	
473874	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Operations Counter AF	65	
473875	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Num Operations Last 9 Months	1	
473876	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
473877	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Maintenance Operations	0	
473878	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
473879	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Grounds in Place?	y	
473880	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	General Comments	y	
473881	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	General Comments		
473882	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
473883	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Foundation Condition	Good	
473884	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Follow-up Action Required?	n	
473885	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Follow-up Action Required?	n	
473886	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Fault Operations	0	
473887	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
473888	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
473889	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
473890	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
473891	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
473892	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
473893	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
473894	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
473895	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
473896	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
473897	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
473898	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	9 Month Operations	9	
473899	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
473900	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
473901	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Operations This Read Vac	4	
473902	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Operations Counter AL	329	
473903	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Operations Counter AF	329	
473904	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Moisture and Leak Free?	y	
473905	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Maintenance Operations	0	
473906	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Heaters (All) Functioning?	y	
473907	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Grounds in Place?	y	
473908	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	General Comments		
473909	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	General Comments		
473910	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Foundation Condition	Good	
473911	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Follow-up Action Required?	n	
473912	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Follow-up Action Required?	n	
473913	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
473914	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
473915	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
473916	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
473917	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
473918	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
473919	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
473920	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
473921	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
473922	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1	
473923	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1	
473924	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
473925	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
473926	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
473927	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
473928	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
473929	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
473930	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
473931	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
473932	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
473933	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
473934	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
473935	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
473936	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
473937	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	General Comments	OIL UNDER PUMP	
473938	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	General Comments		
473939	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
473940	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
473941	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
473942	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
473943	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
473944	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
473945	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
473946	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
473947	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
473948	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
473949	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
473950	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
473951	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
473952	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
473953	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
473954	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
473955	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
473956	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
473957	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
473958	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
473959	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Tank Paint Condition	Good	
473960	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Switching Operations	1	
473961	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
473962	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
473963	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Operations Ground	0	
473964	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Operations C Ø	0	
473965	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Operations B Ø	0	
473966	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Operations A Ø	0	
473967	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
473968	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	General Comments		
473969	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Changed fans to bank one for 2019.	
473970	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
473971	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
473972	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
473973	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
473974	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
473975	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
473976	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
473977	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
473978	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
473979	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
473980	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Operations A Ø	0	
473981	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
473982	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
473983	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Operations B Ø	0	
473984	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Operations C Ø	0	
473985	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
473986	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
473987	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
473988	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
473989	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
473990	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Operations Ground	0	
473991	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Patrol Inspection	Follow-up Action Required?	n	
473992	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Follow-up Action Required?	n	
473993	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Patrol Inspection	General Comments		
473994	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	General Comments		
473995	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Maintenance Operations	0	
473996	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Operations Counter AF	234	
473997	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Operations Counter AL	234	
473998	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Operations This Read Vac	0	
473999	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
474000	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Switching Operations	0	
474001	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
474002	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
474003	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
474004	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
474005	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
474006	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
474007	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
474008	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
474009	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
474010	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
474011	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
474012	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
474013	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
474014	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	5.0	
474015	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	5.0	
474016	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	5.0	
474017	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
474018	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	General Comments		
474019	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
474020	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
474021	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Operations This Read Vac	5	
474022	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
474023	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Switching Operations	5	
474024	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Tank Paint Condition	Good	
474025	4/11/2019 10:44	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Unknown Operations	0	
474026	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	BAT001278	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
474027	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	BAT001278	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
474028	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	BAT001278	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	23.0	VDC
474029	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	BAT001278	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
474030	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	BAT001278	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	battries are swolen	
474031	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	BAT001278	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
474032	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	BAT001278	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
474033	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	BAT001278	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
474034	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Bushings Connection/Risers	Good	
474035	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Bushing Condition	Good	
474036	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Amps C Ø	120.0	
474037	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Amps B Ø	115.0	
474038	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Amps A Ø	125.0	
474039	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
474040	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
474041	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
474042	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
474043	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
474044	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
474045	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
474046	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Foundation Condition	Good	
474047	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
474048	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
474049	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	General Comments		
474050	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
474051	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
474052	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
474053	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
474054	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
474055	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
474056	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
474057	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
474058	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
474059	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
474060	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
474061	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
474062	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	9 Month Operations	0	
474063	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
474064	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
474065	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
474066	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
474067	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
474068	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	BCH001222	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
474069	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	BCH001222	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
474070	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	BCH001222	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
474071	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	BCH001222	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
474072	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	BCH001222	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
474073	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	BCH001222	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.000	millivolts
474074	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
474075	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
474076	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	1	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
474077	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	422	
474078	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
474079	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Amps A Ø	0.0	
474080	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Amps B Ø	0.0	
474081	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Amps C Ø	0.0	
474082	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Patrol Inspection	Equipment Properly Labeled?	y	
474083	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
474084	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	422	
474085	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	6	
474086	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
474087	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
474088	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
474089	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
474090	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
474091	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	General Comments		
474092	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
474093	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
474094	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
474095	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
474096	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
474097	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
474098	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
474099	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
474100	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
474101	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
474102	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Min Tap Position	9L	
474103	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Max Tap Position	5R	
474104	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
474105	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	General Comments		
474106	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
474107	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
474108	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
474109	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
474110	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Current Tap Position	1L	
474111	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
474112	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
474113	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
474114	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
474115	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
474116	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
474117	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
474118	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
474119	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
474120	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	275.00	
474121	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
474122	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Tank Leaks	None	
474123	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
474124	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
474125	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Regulator As Left Counter	9676	
474126	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
474127	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
474128	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
474129	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
474130	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
474131	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Min Tap Position	5R	
474132	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Max Tap Position	9L	
474133	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
474134	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	General Comments		
474135	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
474136	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
474137	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
474138	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
474139	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
474140	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
474141	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
474142	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
474143	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
474144	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
474145	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
474146	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Warning Signs OK?	y	
474147	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
474148	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Tank Leaks	None	
474149	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
474150	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
474151	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
474152	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	General Comments		
474153	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
474154	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
474155	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Foundation Condition	Good	
474156	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Follow-up Action Required?	n	
474157	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
474158	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
474159	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Condition	Good	
474160	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
474161	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
474162	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
474163	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Bushing Condition	Good	
474164	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	38	°C
474165	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	38	°C
474166	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	30	°C
474167	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
474168	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	BAT001278	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
474169	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	BAT001278	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
474170	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	BAT001278	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
474171	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	BAT001278	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
474172	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	BAT001278	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	85	°F
474173	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	BAT001278	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
474174	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BCH000603	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
474175	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.84	%
474176	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	118	
474177	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120	
474178	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	115	
474179	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
474180	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
474181	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
474182	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
474183	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
474184	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	9 Month Operations	2	
474185	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
474186	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BCH000603	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
474187	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BCH000603	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
474188	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BCH000603	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
474189	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BCH000603	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
474190	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	BCH000603	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
474191	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
474192	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
474193	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
474194	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
474195	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
474196	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
474197	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	669	
474198	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	669	
474199	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
474200	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
474201	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
474202	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
474203	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Tank Leaks	None	
474204	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
474205	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
474206	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Regulator As Left Counter	9036	
474207	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
474208	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
474209	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
474210	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
474211	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
474212	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Min Tap Position	11L	
474213	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Max Tap Position	3R	
474214	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
474215	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	General Comments		
474216	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
474217	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
474218	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
474219	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
474220	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Current Tap Position	2L	
474221	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
474222	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
474223	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
474224	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
474225	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
474226	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
474227	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Tank Leaks	None	
474228	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
474229	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
474230	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Regulator As Left Counter	9960	
474231	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
474232	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
474233	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
474234	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
474235	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
474236	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	9 Month Operations	12	
474237	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
474238	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Amps A Ø	0.0	
474239	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
474240	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Vegetation	None	
474241	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
474242	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
474243	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
474244	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
474245	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
474246	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
474247	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Amps A Ø	335.0	
474248	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	General Comments		
474249	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
474250	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
474251	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
474252	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
474253	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
474254	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
474255	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Clear of Trash?	y	
474256	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
474257	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
474258	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
474259	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Amps B Ø	0.0	
474260	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Amps C Ø	0.0	
474261	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Bushing Condition	Good	
474262	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Bushings Connection/Risers	Good	
474263	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
474264	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Amps B Ø	360.0	
474265	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Amps C Ø	350.0	
474266	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Bushings Connection/Risers	Good	
474267	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
474268	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
474269	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
474270	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
474271	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
474272	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
474273	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
474274	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
474275	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
474276	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
474277	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	TV Winding Temp Present	0	°C
474278	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	TV Winding Temp Max	0	°C
474279	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Totalizer Meter Reading	.5784	
474280	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Cabinet Paint Condition	Good	
474281	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Equipment Properly Labeled?	y	
474282	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
474283	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
474284	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
474285	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
474286	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
474287	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
474288	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
474289	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
474290	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
474291	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
474292	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
474293	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Follow-up Action Required?	n	
474294	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
474295	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
474296	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
474297	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
474298	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
474299	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
474300	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
474301	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
474302	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Operations C Ø	0	
474303	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Operations B Ø	0	
474304	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Operations A Ø	0	
474305	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
474306	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
474307	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
474308	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Equipment Properly Labeled?	y	
474309	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Cabinet Paint Condition	Good	
474310	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
474311	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
474312	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
474313	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Bushings Connection/Risers	Good	
474314	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Bushing Condition	Good	
474315	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Amps C Ø	240.0	
474316	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Amps B Ø	240.0	
474317	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Amps A Ø	240.0	
474318	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
474319	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
474320	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
474321	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
474322	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
474323	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
474324	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	99749	
474325	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	99749	
474326	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
474327	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
474328	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
474329	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Operations This Read Vac	2	
474330	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
474331	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	General Comments		
474332	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	General Comments		
474333	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
474334	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	HV Winding Temp Max	0	°C
474335	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	HV Winding Temp Present	0	°C
474336	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Switching Operations	2	
474337	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Tank Paint Condition	Good	
474338	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Unknown Operations	0	
474339	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Tank Paint Condition	Good	
474340	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	LTC Totalizer Reading	5552.64	kw
474341	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	LV Winding Temp Max	0	°C
474342	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
474343	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	LV Winding Temp Present	0	°C
474344	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
474345	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Switching Operations	0	
474346	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
474347	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	SF6 Pressure Indicator	good	
474348	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
474349	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LTCC000485	LTCControl	SY-TRANS 2	LTC Control Insp	All Connections OK?	y	
474350	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LTCC000485	LTCControl	SY-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
474351	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LTCC000485	LTCControl	SY-TRANS 2	LTC Control Insp	General Comments		
474352	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Unknown Operations	0	
474353	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Tank Paint Condition	Good	
474354	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Switching Operations	1	
474355	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Operations This Read Vac	1	
474356	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Operations Counter AL	176	
474357	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Operations Counter AF	176	
474358	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
474359	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Maintenance Operations	0	
474360	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Grounds in Place?	y	
474361	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	General Comments		
474362	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	General Comments		
474363	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Foundation Condition	Good	
474364	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Follow-up Action Required?	n	
474365	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Follow-up Action Required?	n	
474366	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Operations Ground	0	
474367	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Operations C Ø	0	
474368	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Operations B Ø	0	
474369	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Operations A Ø	0	
474370	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
474371	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
474372	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
474373	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
474374	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
474375	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
474376	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
474377	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
474378	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
474379	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Operations A Ø	0	
474380	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
474381	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	9 Month Operations	15	
474382	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
474383	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
474384	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
474385	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
474386	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
474387	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Cabinet Paint Condition	Good	
474388	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Equipment Properly Labeled?	y	
474389	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
474390	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
474391	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
474392	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Operations A Ø	0	
474393	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Operations B Ø	0	
474394	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Operations C Ø	0	
474395	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Operations Ground	0	
474396	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Follow-up Action Required?	n	
474397	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Follow-up Action Required?	n	
474398	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Foundation Condition	Good	
474399	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Operations B Ø	0	
474400	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Operations C Ø	0	
474401	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Operations Ground	0	
474402	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Follow-up Action Required?	n	
474403	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
474404	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
474405	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
474406	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
474407	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
474408	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Follow-up Action Required?	n	
474409	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
474410	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
474411	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
474412	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
474413	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	80.0	
474414	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	80.0	
474415	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	80.0	
474416	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
474417	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	General Comments		
474418	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	General Comments		
474419	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Grounds in Place?	y	
474420	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Maintenance Operations	0	
474421	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Moisture and Leak Free?	y	
474422	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Operations Counter AF	177	
474423	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Operations Counter AL	177	
474424	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	400	
474425	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Heaters (All) Functioning?	y	
474426	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Grounds in Place?	y	
474427	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	General Comments		
474428	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	General Comments		
474429	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Foundation Condition	Good	
474430	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Follow-up Action Required?	n	
474431	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	400	
474432	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	400	
474433	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
474434	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
474435	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
474436	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
474437	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
474438	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
474439	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
474440	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
474441	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
474442	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
474443	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
474444	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Ambient Temp	80	°F
474445	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
474446	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
474447	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Clear of Trash?	y	
474448	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
474449	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
474450	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
474451	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
474452	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
474453	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
474454	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	General Comments		
474455	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
474456	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
474457	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
474458	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
474459	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC Operations Since Last Insp	77	
474460	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.5	psi
474461	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC Min Tap Position	8L	
474462	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC Max Tap Position	12R	
474463	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC Current Tap Position	2L	
474464	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
474465	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC As Left Counter	14634	
474466	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC As Found Counter	14634	
474467	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	General Comments		
474468	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	General Comments		
474469	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
474470	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
474471	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Operations A Ø	0	
474472	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Operations B Ø	0	
474473	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Operations C Ø	0	
474474	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Operations Ground	0	
474475	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Follow-up Action Required?	n	
474476	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Follow-up Action Required?	n	
474477	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Foundation Condition	Good	
474478	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	General Comments		
474479	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	General Comments		
474480	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Grounds in Place?	y	
474481	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Heaters (All) Functioning?	y	
474482	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Maintenance Operations	0	
474483	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Moisture and Leak Free?	y	
474484	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Operations Counter AF	257	
474485	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Operations Counter AL	257	
474486	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Operations This Read Vac	2	
474487	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
474488	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Switching Operations	2	
474489	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Tank Paint Condition	Good	
474490	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Unknown Operations	0	
474491	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
474492	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
474493	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
474494	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
474495	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
474496	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
474497	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
474498	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
474499	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
474500	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
474501	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
474502	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
474503	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
474504	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
474505	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
474506	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
474507	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
474508	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
474509	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
474510	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
474511	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
474512	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
474513	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
474514	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	1	
474515	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0	%
474516	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0	%
474517	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0	%
474518	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
474519	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
474520	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
474521	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
474522	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Min Tap Position	1R	
474523	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
474524	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Tank Leaks	None	
474525	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	LTCC000137	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
474526	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	LTCC000137	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
474527	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	LTCC000137	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
474528	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	LTCC000137	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
474529	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	LTCC000137	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
474530	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	LTCC000137	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
474531	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	LTCC000137	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
474532	4/11/2019 10:12	Distribution	Danville Central Quarterly Inspection	LTCC000137	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
474533	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
474534	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
474535	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
474536	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
474537	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
474538	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
474539	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Regulator As Left Counter	92098	
474540	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
474541	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Regulator As Left Counter	80674	
474542	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
474543	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
474544	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
474545	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
474546	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
474547	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Min Tap Position	1L	
474548	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
474549	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
474550	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Tank Leaks	None	
474551	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
474552	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
474553	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	General Comments		
474554	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
474555	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
474556	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Vegetation	None	
474557	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
474558	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
474559	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Free of Audible Arcing?	n	
474560	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
474561	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	General Comments	CB204 B phase CT	
474562	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
474563	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
474564	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
474565	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	Follow-up Action Required?	n	
474566	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
474567	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	General Comments		
474568	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
474569	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
474570	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
474571	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
474572	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
474573	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
474574	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
474575	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
474576	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
474577	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
474578	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
474579	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
474580	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
474581	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Clear of Trash?	y	
474582	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
474583	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
474584	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Vegetation	None	
474585	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
474586	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
474587	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
474588	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
474589	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
474590	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
474591	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
474592	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Foundation Condition	Good	
474593	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
474594	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
474595	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
474596	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
474597	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
474598	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
474599	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
474600	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
474601	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Current Tap Position	4L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
474602	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
474603	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
474604	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
474605	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
474606	4/11/2019 15:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	General Comments		
474607	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
474608	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	General Comments		
474609	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
474610	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
474611	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
474612	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
474613	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Grounds in Place?	y	
474614	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Maintenance Operations	0	
474615	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Moisture and Leak Free?	y	
474616	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Operations Counter AF	173	
474617	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Operations Counter AL	2104	
474618	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Operations This Read Vac	0	
474619	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	BCH000396	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
474620	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	BCH000396	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
474621	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	All Connections OK?	y	
474622	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	Follow-up Action Required?	n	
474623	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	General Comments		
474624	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Unknown Operations	0	
474625	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Tank Paint Condition	Good	
474626	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Switching Operations	0	
474627	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Operations This Read Vac	0	
474628	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Operations Counter AL	191	
474629	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Operations Counter AF	191	
474630	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Moisture and Leak Free?	y	
474631	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Maintenance Operations	0	
474632	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Grounds in Place?	y	
474633	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	General Comments		
474634	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	General Comments		
474635	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Foundation Condition	Good	
474636	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Follow-up Action Required?	n	
474637	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Follow-up Action Required?	n	
474638	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Fault Operations Ground	0	
474639	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Fault Operations C Ø	0	
474640	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Fault Operations B Ø	0	
474641	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Fault Operations A Ø	0	
474642	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
474643	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
474644	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
474645	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Bushings Connection/Risers	Good	
474646	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Ambient Temperature	67	°F
474647	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Operations Counter AL	173	
474648	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Operations This Read Vac	0	
474649	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Switching Operations	0	
474650	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Tank Paint Condition	Good	
474651	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Unknown Operations	0	
474652	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
474653	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
474654	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Equipment Properly Labeled?	y	
474655	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Cabinet Paint Condition	Good	
474656	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
474657	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
474658	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
474659	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
474660	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
474661	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
474662	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	416	
474663	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	416	
474664	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
474665	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
474666	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
474667	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
474668	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC Current Tap Position	13L	
474669	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC Max Tap Position	8L	
474670	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC Min Tap Position	15L	
474671	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
474672	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
474673	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
474674	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	390	
474675	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
474676	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Amps C Ø	100.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
474677	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Heaters (All) Functioning?	y	
474678	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Grounds in Place?	y	
474679	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	General Comments		
474680	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	General Comments		
474681	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Gauge(s) Condition	Good	
474682	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Foundation Condition	Good	
474683	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Follow-up Action Required?	n	
474684	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Follow-up Action Required?	n	
474685	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Fault Operations	0	
474686	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Equipment Properly Labeled?	y	
474687	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Cabinet Paint Condition	Good	
474688	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Bushing Condition	Good	
474689	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Bushings Connection/Risers	Good	
474690	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
474691	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
474692	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
474693	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Cabinet Paint Condition	Good	
474694	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Equipment Properly Labeled?	y	
474695	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
474696	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
474697	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
474698	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Operations A Ø	0	
474699	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Operations B Ø	0	
474700	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Operations C Ø	0	
474701	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Operations Ground	0	
474702	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Follow-up Action Required?	n	
474703	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Follow-up Action Required?	n	
474704	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Foundation Condition	Good	
474705	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	General Comments		
474706	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	General Comments		
474707	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Follow-up Action Required?	n	
474708	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	General Comments		
474709	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
474710	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
474711	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	BCH000396	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
474712	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	BCH000396	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
474713	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
474714	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
474715	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
474716	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
474717	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Amps A Ø	200.0	
474718	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Amps B Ø	220.0	
474719	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Amps C Ø	240.0	
474720	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
474721	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
474722	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	Follow-up Action Required?	n	
474723	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
474724	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	General Comments		
474725	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Mechanism Patrol Inspection	General Comments		
474726	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC As Found Counter	138900	
474727	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC As Left Counter	138904	
474728	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
474729	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC Current Tap Position	6L	
474730	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
474731	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC Min Tap Position	8L	
474732	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC Operations Since Last Insp	364	
474733	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
474734	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
474735	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
474736	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
474737	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Unknown Operations	0	
474738	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Switching Operations	0	
474739	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Operations This Read Vac	0	
474740	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Operations Counter AL	149	
474741	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
474742	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
474743	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
474744	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Operations Ground	0	
474745	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
474746	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
474747	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Patrol Inspection	General Comments		
474748	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	General Comments		
474749	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
474750	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
474751	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Operations Counter AF	149	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
474752	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Maintenance Operations	0	
474753	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
474754	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Oil Temp Present	45	°C
474755	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Oil Temp Max	65	°C
474756	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Bushings Connection/Risers	Good	
474757	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Bushing Condition	Good	
474758	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Amps C Ø	220.0	
474759	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	LTC Operation Checked?	y	
474760	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
474761	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
474762	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
474763	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
474764	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
474765	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
474766	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	VRR Time Delay	30	Seconds
474767	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
474768	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Switching Operations	0	
474769	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Tank Paint Condition	Good	
474770	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Amps B Ø	215.0	
474771	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Amps A Ø	220.0	
474772	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
474773	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
474774	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
474775	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	9 Month Operations	49	
474776	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Unknown Operations	0	
474777	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	9 Month Operations	2	
474778	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
474779	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
474780	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
474781	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
474782	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	2	
474783	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
474784	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
474785	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
474786	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	613	
474787	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	613	
474788	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	7	
474789	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
474790	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
474791	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	BCH000396	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
474792	4/12/2019 7:06	Distribution	Springfield Quarterly Inspection	BCH000396	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
474793	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	All Connections OK?	y	
474794	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Battery Area Ambient Temp	67	°F
474795	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Battery Overall Condition	Good	
474796	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
474797	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
474798	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
474799	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
474800	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
474801	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Eyewash Solution	Good	
474802	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	General Comments		
474803	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
474804	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
474805	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
474806	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
474807	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Amps A Ø	0.0	
474808	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Amps B Ø	0.0	
474809	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Amps C Ø	0.0	
474810	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Bushing Condition	Good	
474811	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Bushings Connection/Risers	Good	
474812	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
474813	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
474814	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
474815	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Cabinet Paint Condition	Good	
474816	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Equipment Properly Labeled?	y	
474817	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
474818	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
474819	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
474820	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
474821	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
474822	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
474823	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
474824	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
474825	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	Follow-up Action Required?	n	
474826	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
474827	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
474828	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
474829	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
474830	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
474831	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
474832	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
474833	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
474834	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
474835	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
474836	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
474837	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
474838	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Operations A Ø	0	
474839	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Operations B Ø	0	
474840	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
474841	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
474842	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
474843	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
474844	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Operations C Ø	0	
474845	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Operations Ground	0	
474846	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Follow-up Action Required?	n	
474847	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Follow-up Action Required?	n	
474848	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Foundation Condition	Good	
474849	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
474850	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
474851	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
474852	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Bushing Condition	Good	
474853	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Amps C Ø	310.0	
474854	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Amps B Ø	295.0	
474855	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Amps A Ø	300.0	
474856	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
474857	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
474858	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
474859	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	9 Month Operations	43	
474860	4/11/2019 10:46	Distribution	Smyrna Quarterly Inspection	LTCC000485	LTCControl	SY-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
474861	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Follow-up Action Required?	n	
474862	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Foundation Condition	Good	
474863	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	General Comments		
474864	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	General Comments		
474865	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Grounds in Place?	y	
474866	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Maintenance Operations	0	
474867	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Moisture and Leak Free?	y	
474868	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Operations Counter AF	2104	
474869	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Unknown Operations	0	
474870	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
474871	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Switching Operations	1	
474872	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Operations This Read Vac	1	
474873	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Operations Counter AL	172	
474874	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Operations Counter AF	172	
474875	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
474876	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Maintenance Operations	0	
474877	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
474878	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	Totalizer Meter Reading	.3594	
474879	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
474880	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
474881	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
474882	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
474883	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
474884	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
474885	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	9 Month Operations	6	
474886	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
474887	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
474888	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
474889	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	Oil Temp Present	35	°C
474890	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	Oil Temp Max	55	°C
474891	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
474892	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
474893	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	LTC Totalizer Reading	1150.08	kw
474894	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
474895	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	General Comments		
474896	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
474897	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	General Comments		
474898	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
474899	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC As Found Counter	22312	
474900	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC As Left Counter	22312	
474901	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
474902	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
474903	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	LTC Operation Checked?	y	
474904	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	General Comments		
474905	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	Follow-up Action Required?	n	
474906	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	All Connections OK?	y	
474907	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	SF6 Bushing Condition	Good	
474908	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
474909	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
474910	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
474911	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Operations This Read SF6	0	
474912	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Operations Counter AL	58	
474913	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
474914	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Vegetation	None	
474915	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
474916	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	General Comments	ok	
474917	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
474918	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
474919	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
474920	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
474921	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
474922	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
474923	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Clear of Trash?	y	
474924	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
474925	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
474926	4/11/2019 9:11	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Ambient Temp	71	°F
474927	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
474928	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
474929	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Operations Counter AF	58	
474930	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Num Operations Last 9 Months	1	
474931	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Moisture and Leak Free?	y	
474932	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Maintenance Operations	0	
474933	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	9 Month Operations	32	
474934	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
474935	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
474936	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
474937	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Amps A Ø	105.0	
474938	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Amps B Ø	95.0	
474939	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
474940	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
474941	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
474942	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
474943	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
474944	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
474945	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
474946	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
474947	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
474948	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
474949	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	General Comments		
474950	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	General Comments		
474951	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Grounds in Place?	y	
474952	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Heaters (All) Functioning?	y	
474953	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Maintenance Operations	0	
474954	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Moisture and Leak Free?	y	
474955	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Operations Counter AF	196	
474956	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Operations Counter AL	196	
474957	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Operations This Read Vac	0	
474958	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Switching Operations	0	
474959	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	General Comments		
474960	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	General Comments		
474961	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
474962	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Follow-up Action Required?	n	
474963	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
474964	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Operations Ground	0	
474965	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Operations C Ø	0	
474966	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Operations B Ø	0	
474967	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Operations A Ø	0	
474968	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
474969	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
474970	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
474971	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
474972	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
474973	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
474974	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
474975	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
474976	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
474977	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
474978	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Amps C Ø	0.0	
474979	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Amps B Ø	0.0	
474980	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Amps A Ø	0.0	
474981	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
474982	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
474983	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
474984	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	9 Month Operations	19	
474985	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Tank Paint Condition	Good	
474986	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Unknown Operations	0	
474987	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	VRR Time Delay	30	Seconds
474988	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
474989	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
474990	4/9/2019 8:51	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
474991	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Ambient Temp	78	°F
474992	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
474993	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	16	
474994	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Follow-up Action Required?	n	
474995	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Patrol Inspection	General Comments		
474996	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
474997	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	General Comments		
474998	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.7	VDC
474999	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.5	VDC
475000	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
475001	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	General Comments		
475002	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
475003	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Grounds in Place?	y	
475004	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	General Comments		
475005	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	General Comments		
475006	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Foundation Condition	Good	
475007	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Follow-up Action Required?	n	
475008	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Follow-up Action Required?	n	
475009	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Operations Ground	0	
475010	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Operations C Ø	0	
475011	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Operations B Ø	0	
475012	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Operations A Ø	0	
475013	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	16	
475014	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Maintenance Operations	0	
475015	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
475016	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
475017	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
475018	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Equipment Properly Labeled?	y	
475019	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Operations Counter AF	313	
475020	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
475021	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Operations Counter AL	313	
475022	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
475023	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
475024	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
475025	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	General Comments		
475026	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
475027	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
475028	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
475029	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
475030	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.2	VDC
475031	4/11/2019 13:10	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.2	VDC
475032	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Unknown Operations	0	
475033	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Operations This Read Vac	1	
475034	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Switching Operations	0	
475035	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Tank Paint Condition	Good	
475036	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Switching Operations	0	
475037	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
475038	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Operations This Read Vac	0	
475039	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Operations Counter AL	198	
475040	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Operations Counter AF	198	
475041	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Moisture and Leak Free?	y	
475042	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Maintenance Operations	0	
475043	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Heaters (All) Functioning?	y	
475044	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Cabinet Paint Condition	Good	
475045	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Grounds in Place?	y	
475046	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	General Comments		
475047	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
475048	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
475049	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
475050	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
475051	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
475052	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Operations B Ø	0	
475053	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Operations C Ø	0	
475054	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
475055	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
475056	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
475057	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
475058	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
475059	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
475060	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Operations Ground	0	
475061	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Patrol Inspection	Follow-up Action Required?	n	
475062	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	General Comments		
475063	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
475064	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	General Comments		
475065	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
475066	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Follow-up Action Required?	n	
475067	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
475068	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
475069	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
475070	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
475071	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
475072	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
475073	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
475074	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Operations Ground	0	
475075	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Operations C Ø	0	
475076	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Operations B Ø	0	
475077	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Operations A Ø	0	
475078	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
475079	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
475080	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
475081	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
475082	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
475083	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
475084	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
475085	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
475086	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	General Comments		
475087	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
475088	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
475089	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
475090	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
475091	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
475092	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
475093	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
475094	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
475095	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
475096	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
475097	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
475098	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
475099	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
475100	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Clear of Trash?	y	
475101	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
475102	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
475103	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
475104	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
475105	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Amps A Ø	0.0	
475106	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Foundation Condition	Good	
475107	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Follow-up Action Required?	n	
475108	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Follow-up Action Required?	n	
475109	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Operations Ground	0	
475110	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
475111	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
475112	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
475113	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
475114	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
475115	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
475116	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	General Comments		
475117	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
475118	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Amps B Ø	0.0	
475119	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Amps C Ø	0.0	
475120	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Bushing Condition	Good	
475121	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	9 Month Operations	5	
475122	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
475123	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Bushings Connection/Risers	Good	
475124	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
475125	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
475126	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
475127	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
475128	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
475129	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
475130	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
475131	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	General Comments		
475132	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
475133	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
475134	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
475135	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
475136	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
475137	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
475138	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Foundation Condition	Good	
475139	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
475140	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
475141	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
475142	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
475143	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
475144	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
475145	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
475146	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Cabinet Paint Condition	Good	
475147	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
475148	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
475149	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Equipment Properly Labeled?	y	
475150	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
475151	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
475152	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
475153	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
475154	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
475155	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
475156	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Operations A Ø	0	
475157	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Operations B Ø	0	
475158	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Operations C Ø	0	
475159	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	General Comments		
475160	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
475161	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
475162	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
475163	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Tank Leaks	None	
475164	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
475165	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
475166	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Regulator As Left Counter	76884	
475167	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
475168	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
475169	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Equipment Properly Labeled?	y	
475170	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
475171	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
475172	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
475173	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
475174	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Unknown Operations	1	
475175	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Bushings Connection/Risers	Good	
475176	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
475177	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Tank Leaks	None	
475178	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Bushing Condition	Good	
475179	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Amps C Ø	130.0	
475180	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Amps B Ø	150.0	
475181	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Amps A Ø	80.0	
475182	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
475183	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
475184	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
475185	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
475186	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
475187	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Min Tap Position	1L	
475188	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Max Tap Position	11L	
475189	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
475190	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
475191	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
475192	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	General Comments		
475193	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
475194	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
475195	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
475196	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Operations Counter	218	
475197	4/11/2019 11:39	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	9 Month Operations	11	
475198	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
475199	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
475200	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
475201	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
475202	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
475203	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
475204	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
475205	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
475206	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
475207	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
475208	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
475209	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
475210	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
475211	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
475212	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	General Comments		
475213	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
475214	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
475215	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
475216	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
475217	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
475218	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
475219	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
475220	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Follow-up Action Required?	n	
475221	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Bushings Connection/Risers	Good	
475222	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
475223	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	20	
475224	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	2222	
475225	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Bushing Condition	Good	
475226	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Amps C Ø	75.0	
475227	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	2222	
475228	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
475229	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Tank Leaks	None	
475230	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
475231	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
475232	4/11/2019 14:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Regulator As Left Counter	19410	
475233	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Amps B Ø	60.0	
475234	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
475235	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
475236	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
475237	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	General Comments		
475238	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	General Comments		
475239	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
475240	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Amps A Ø	60.0	
475241	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
475242	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
475243	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	LTC Totalizer Reading	3445.20	kw
475244	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
475245	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
475246	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Oil Temp Max	45	°C
475247	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Oil Temp Present	40	°C
475248	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
475249	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
475250	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	11.45	
475251	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	11.45	
475252	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	11.45	
475253	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
475254	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
475255	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
475256	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
475257	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
475258	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
475259	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
475260	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
475261	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
475262	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
475263	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
475264	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	General Comments		
475265	4/11/2019 12:43	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
475266	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
475267	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
475268	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
475269	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
475270	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
475271	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Totalizer Meter Reading	.1914	
475272	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Winding Temp Max	20	°C
475273	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Amps A Ø	100.0	
475274	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
475275	4/11/2019 14:51	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
475276	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
475277	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
475278	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
475279	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
475280	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
475281	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
475282	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	General Comments		
475283	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
475284	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
475285	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
475286	4/11/2019 15:22	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
475287	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	247	
475288	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
475289	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
475290	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
475291	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Amps B Ø	100.0	
475292	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
475293	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	9 Month Operations	1	
475294	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
475295	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
475296	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Vegetation	None	
475297	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
475298	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
475299	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
475300	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
475301	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Amps A Ø	130.0	
475302	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
475303	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Amps B Ø	131.0	
475304	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Amps C Ø	137.0	
475305	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
475306	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
475307	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Cabinet Paint Condition	Good	
475308	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
475309	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
475310	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
475311	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Operations Counter	217	
475312	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
475313	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
475314	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
475315	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
475316	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
475317	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
475318	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
475319	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
475320	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
475321	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	General Comments		
475322	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
475323	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
475324	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
475325	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
475326	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
475327	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
475328	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
475329	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
475330	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Operations This Read Vac	0	
475331	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Operations Counter AL	52	
475332	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
475333	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
475334	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
475335	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Maintenance Operations	0	
475336	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Moisture and Leak Free?	y	
475337	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Operations Counter AF	212	
475338	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Operations Counter AL	212	
475339	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.75	%
475340	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
475341	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
475342	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
475343	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Operations Counter AF	52	
475344	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
475345	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	°F
475346	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
475347	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Operations This Read Vac	5	
475348	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
475349	4/11/2019 9:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	9 Month Operations	14	
475350	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
475351	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
475352	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
475353	4/11/2019 11:01	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Patrol Inspection	Equipment Properly Labeled?	y	
475354	4/11/2019 12:14	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
475355	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
475356	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Maintenance Operations	0	
475357	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
475358	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
475359	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Amps A Ø	25.0	
475360	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Amps B Ø	24.0	
475361	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Amps C Ø	24.0	
475362	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Switching Operations	5	
475363	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Tank Paint Condition	Good	
475364	4/11/2019 14:28	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Unknown Operations	0	
475365	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
475366	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
475367	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
475368	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
475369	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
475370	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
475371	4/11/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
475372	4/11/2019 14:08	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
475373	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	General Comments		
475374	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
475375	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Amps C Ø	100.0	
475376	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
475377	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
475378	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Maintenance Operations	0	
475379	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Switching Operations	0	
475380	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Amps B Ø	97.0	
475381	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
475382	4/11/2019 10:06	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Heaters (All) Functioning?	y	
475383	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Amps A Ø	89.0	
475384	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
475385	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Amps C Ø	92.0	
475386	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
475387	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
475388	4/11/2019 13:35	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Winding Temp Present	20	°C
475389	4/11/2019 13:06	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
475390	4/11/2019 11:05	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Unknown Operations	0	
475391	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
475392	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
475393	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
475394	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	written on card by Steve Diamato, 2 ops test	
475395	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
475396	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
475397	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
475398	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
475399	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Operations Counter AL	229	
475400	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Operations Counter AF	229	
475401	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
475402	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
475403	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
475404	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
475405	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
475406	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
475407	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Operations A Ø	0	
475408	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
475409	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
475410	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Oil Temp Max	60	°C
475411	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Maintenance Operations	0	
475412	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Oil Temp Present	50	°C
475413	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
475414	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Operations Counter AL	691	
475415	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
475416	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Operations Counter AF	691	
475417	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Maintenance Operations	0	
475418	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Bushings Connection/Risers	Good	
475419	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
475420	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	General Comments	B phase IOC	
475421	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments	possible cracked site glass	
475422	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	50.0	
475423	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Follow-up Action Required?	n	
475424	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Operations Ground	0	
475425	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Follow-up Action Required?	n	
475426	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	50.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
475427	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
475428	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
475429	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
475430	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Follow-up Action Required?	n	
475431	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Operations Ground	0	
475432	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
475433	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Cabinet Paint Condition	Good	
475434	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
475435	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
475436	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
475437	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
475438	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Operations C Ø	0	
475439	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
475440	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Operations B Ø	0	
475441	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
475442	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
475443	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Operations Counter AF	556	
475444	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
475445	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
475446	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
475447	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Operations A Ø	0	
475448	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
475449	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
475450	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
475451	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
475452	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
475453	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Maintenance Operations	0	
475454	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
475455	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
475456	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
475457	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
475458	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
475459	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	General Comments		
475460	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
475461	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
475462	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
475463	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
475464	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
475465	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
475466	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
475467	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
475468	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
475469	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Accumulated Fault Duty B Ph AM	0	%
475470	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
475471	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Operations C Ø	0	
475472	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	9 Month Operations	17	
475473	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
475474	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
475475	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
475476	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Equipment Properly Labeled?	y	
475477	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
475478	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
475479	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
475480	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
475481	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
475482	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Operations Ground	0	
475483	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
475484	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
475485	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
475486	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
475487	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Operations A Ø	0	
475488	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Operations C Ø	0	
475489	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
475490	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Follow-up Action Required?	n	
475491	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
475492	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	50	
475493	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	9 Months Operations	8	
475494	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
475495	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Operations This Read Vac	0	
475496	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
475497	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Unknown Operations	0	
475498	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
475499	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Operations B Ø	1	
475500	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Operations Counter AF	355	
475501	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Switching Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
475502	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Operations Counter AL	355	
475503	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	50	
475504	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Operations This Read AM	0	
475505	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
475506	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Operations Counter AL	556	
475507	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
475508	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
475509	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Operations A Ø	0	
475510	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
475511	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
475512	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Readings	General Comments		
475513	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	50.0	
475514	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
475515	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
475516	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
475517	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
475518	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
475519	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Operations B Ø	0	
475520	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Operations C Ø	0	
475521	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Operations Ground	0	
475522	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Follow-up Action Required?	n	
475523	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Follow-up Action Required?	n	
475524	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Foundation Condition	Good	
475525	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Cabinet Paint Condition	Good	
475526	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
475527	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Equipment Properly Labeled?	y	
475528	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Foundation Condition	Good	
475529	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	General Comments		
475530	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
475531	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
475532	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	y	
475533	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
475534	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Grounds in Place?	y	
475535	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	General Comments		
475536	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	General Comments		
475537	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
475538	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
475539	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
475540	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
475541	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
475542	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
475543	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
475544	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
475545	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
475546	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
475547	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Operations B Ø	0	
475548	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	General Comments		
475549	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
475550	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
475551	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
475552	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
475553	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Amps C Ø	24.0	
475554	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Amps B Ø	21.0	
475555	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Amps A Ø	33.0	
475556	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Operations Counter AF	317	
475557	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Regulator As Left Counter	296995	
475558	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Operations Counter AL	317	
475559	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Operations This Read AM	0	
475560	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Switching Operations	0	
475561	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Unknown Operations	0	
475562	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Operations Counter AL	151	
475563	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Operations Counter AF	151	
475564	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Moisture and Leak Free?	y	
475565	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
475566	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
475567	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
475568	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	9 Month Operations	6	
475569	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Maintenance Operations	0	
475570	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Grounds in Place?	y	
475571	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	General Comments		
475572	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	General Comments		
475573	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Foundation Condition	Good	
475574	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Follow-up Action Required?	n	
475575	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Follow-up Action Required?	n	
475576	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
475577	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Operations C Ø	0	
475578	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Operations B Ø	0	
475579	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Operations A Ø	0	
475580	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
475581	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
475582	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
475583	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
475584	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Grounds in Place?	y	
475585	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
475586	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	General Comments	2 blown arrestors	
475587	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	General Comments		
475588	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Foundation Condition	Good	
475589	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Follow-up Action Required?	n	
475590	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Follow-up Action Required?	n	
475591	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Equipment Properly Labeled?	y	
475592	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Cabinet Paint Condition	Good	
475593	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
475594	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
475595	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
475596	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Bushings Connection/Risers	Good	
475597	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Bushing Condition	Good	
475598	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Amps C Ø	0.0	
475599	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Amps B Ø	9.0	
475600	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Amps A Ø	5.0	
475601	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
475602	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
475603	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
475604	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
475605	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
475606	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
475607	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
475608	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
475609	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	9 Month Operations	2	
475610	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	9 Months Operations	35	
475611	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
475612	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
475613	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
475614	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Amps A Ø	280.0	
475615	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Amps B Ø	280.0	
475616	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Amps C Ø	300.0	
475617	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Operations Ground	0	
475618	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
475619	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
475620	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	General Comments		
475621	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
475622	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
475623	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
475624	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
475625	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations A Ø	1	
475626	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations B Ø	1	
475627	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations C Ø	1	
475628	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC Current Tap Position	10L	
475629	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
475630	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC As Left Counter	9199	
475631	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC As Found Counter	9199	
475632	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	General Comments	Counter not working.	
475633	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	General Comments		
475634	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
475635	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	Follow-up Action Required?	n	
475636	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Moisture and Leak Free?	y	
475637	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Operations Counter AF	241	
475638	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Operations Counter AL	241	
475639	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Maintenance Operations	0	
475640	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Unknown Operations	0	
475641	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Tank Paint Condition	Good	
475642	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	9 Months Operations	9	
475643	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Switching Operations	0	
475644	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Operations This Read Vac	0	
475645	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Heaters (All) Functioning?	y	
475646	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Grounds in Place?	y	
475647	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	General Comments		
475648	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	General Comments		
475649	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Foundation Condition	Good	
475650	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Operations This Read Vac	0	
475651	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
475652	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Switching Operations	0	
475653	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Tank Paint Condition	Good	
475654	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Unknown Operations	0	
475655	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Follow-up Action Required?	n	
475656	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
475657	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
475658	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
475659	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Amps A Ø	240.0	
475660	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Amps B Ø	200.0	
475661	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Amps C Ø	220.0	
475662	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
475663	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
475664	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
475665	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
475666	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
475667	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
475668	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
475669	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
475670	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
475671	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
475672	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
475673	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
475674	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	General Comments		
475675	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
475676	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
475677	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
475678	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
475679	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
475680	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations A Ø	0	
475681	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations B Ø	0	
475682	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	BCH001167	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.100	millivolts
475683	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	BCH001167	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
475684	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
475685	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
475686	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
475687	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
475688	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
475689	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	BCH001167	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
475690	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	BCH001167	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
475691	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	BCH001167	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
475692	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	BCH001167	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
475693	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	BCH001167	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
475694	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations C Ø	0	
475695	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations Ground	0	
475696	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Patrol Inspection	Follow-up Action Required?	n	
475697	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Follow-up Action Required?	n	
475698	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Patrol Inspection	General Comments		
475699	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	General Comments		
475700	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Maintenance Operations	0	
475701	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	9 Month Operations	1	
475702	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
475703	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
475704	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
475705	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
475706	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	80.0	
475707	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	140.0	
475708	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	140.0	
475709	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
475710	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
475711	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
475712	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
475713	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
475714	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
475715	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
475716	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
475717	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
475718	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
475719	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
475720	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Follow-up Action Required?	n	
475721	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
475722	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Amps A Ø	100.0	
475723	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Amps B Ø	100.0	
475724	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Amps C Ø	100.0	
475725	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Bushing Condition	Good	
475726	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
475727	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Switching Operations	0	
475728	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2694	
475729	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
475730	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Operations This Read AM	1	
475731	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
475732	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	General Comments		
475733	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	General Comments		
475734	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
475735	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
475736	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	LTC Totalizer Reading	15260.00	kw
475737	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
475738	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	9 Month Operations	0	
475739	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
475740	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
475741	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
475742	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
475743	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
475744	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
475745	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
475746	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
475747	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
475748	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
475749	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
475750	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Oil Temp Max	53	°C
475751	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
475752	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
475753	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
475754	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
475755	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
475756	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC Current Tap Position	9L	
475757	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC Max Tap Position	1L	
475758	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC Min Tap Position	12L	
475759	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC Operations Since Last Insp	804	
475760	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	323.28	kw
475761	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
475762	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
475763	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
475764	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	General Comments		
475765	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	General Comments		
475766	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
475767	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
475768	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
475769	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Amps A Ø	120.0	
475770	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Amps B Ø	120.0	
475771	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Amps C Ø	120.0	
475772	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Bushing Condition	Good	
475773	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations Ground	0	
475774	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Patrol Inspection	Follow-up Action Required?	n	
475775	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
475776	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
475777	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
475778	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
475779	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
475780	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
475781	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
475782	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	169	
475783	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Follow-up Action Required?	n	
475784	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Tank Leaks	None	
475785	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
475786	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	Follow-up Action Required?	n	
475787	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
475788	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	General Comments		
475789	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Patrol Inspection	General Comments		
475790	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	General Comments	A,B&C Phase IOC	
475791	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Maintenance Operations	0	
475792	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Operations Counter AF	569	
475793	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Operations Counter AL	569	
475794	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	General Comments		
475795	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC As Found Counter	21455	
475796	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC As Left Counter	21461	
475797	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
475798	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
475799	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
475800	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
475801	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
475802	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	169	
475803	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	5	
475804	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
475805	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
475806	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
475807	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Operations C Ø	5	
475808	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Operations B Ø	0	
475809	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Operations A Ø	0	
475810	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Adjusted Amps C Phase V	24.35	
475811	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Adjusted Amps B Phase V	9.13	
475812	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Adjusted Amps A Phase V	9.13	
475813	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
475814	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
475815	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
475816	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
475817	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	9 Months Operations	16	
475818	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Equipment Properly Labeled?	y	
475819	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Cabinet Paint Condition	Good	
475820	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
475821	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	68	
475822	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	68	
475823	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
475824	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
475825	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
475826	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
475827	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Amps A Ø	402.0	
475828	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Amps B Ø	380.0	
475829	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
475830	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
475831	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
475832	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Bushings Connection/Risers	Good	
475833	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Bushing Condition	Good	
475834	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Amps C Ø	10.0	
475835	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Amps B Ø	10.0	
475836	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
475837	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
475838	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Amps A Ø	42.0	
475839	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Amps C Ø	396.0	
475840	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
475841	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
475842	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Amps A Ø	10.0	
475843	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
475844	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
475845	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
475846	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
475847	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
475848	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
475849	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
475850	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
475851	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
475852	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
475853	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	450.0	
475854	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	400.0	
475855	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	425.0	
475856	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
475857	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
475858	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	0	
475859	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	970	
475860	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
475861	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
475862	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
475863	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
475864	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
475865	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
475866	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
475867	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
475868	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
475869	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
475870	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
475871	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
475872	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
475873	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	100.0	
475874	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
475875	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	
475876	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
475877	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
475878	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
475879	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
475880	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
475881	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
475882	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
475883	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
475884	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
475885	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
475886	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
475887	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
475888	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
475889	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
475890	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
475891	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Operations Counter AL	365	
475892	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
475893	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	160.0	
475894	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
475895	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
475896	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
475897	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
475898	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Operations This Read Vac	0	
475899	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Maintenance Operations	0	
475900	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
475901	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
475902	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Operations Counter AF	158	
475903	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Operations Counter AL	158	
475904	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Operations This Read Vac	1	
475905	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Switching Operations	1	
475906	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
475907	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
475908	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
475909	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
475910	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
475911	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC Operations Since Last Insp	780	
475912	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
475913	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	Follow-up Action Required?	n	
475914	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
475915	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	General Comments		
475916	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	General Comments		
475917	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
475918	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
475919	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
475920	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
475921	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
475922	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Tank Paint Condition	Good	
475923	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
475924	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
475925	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	7	
475926	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
475927	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
475928	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
475929	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	450.0	
475930	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	550.0	
475931	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	480.0	
475932	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Unknown Operations	0	
475933	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
475934	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
475935	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
475936	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
475937	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
475938	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
475939	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
475940	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
475941	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
475942	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
475943	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
475944	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
475945	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
475946	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	150.0	
475947	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
475948	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
475949	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
475950	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
475951	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
475952	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
475953	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
475954	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
475955	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	150.0	
475956	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
475957	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
475958	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
475959	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
475960	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
475961	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
475962	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
475963	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC As Found Counter	91015	
475964	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
475965	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
475966	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
475967	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
475968	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC As Left Counter	91015	
475969	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
475970	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC Current Tap Position	2L	
475971	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
475972	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
475973	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
475974	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
475975	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Unknown Operations	0	
475976	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
475977	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
475978	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
475979	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Follow-up Action Required?	n	
475980	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
475981	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
475982	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	General Comments	Substation is deenergized for transmission work	
475983	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	General Comments	Substation is deenergized for transmission work	
475984	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
475985	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
475986	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
475987	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
475988	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
475989	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
475990	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
475991	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	9 Month Operations	8	
475992	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Accumulated Fault Duty A Ph V	7.97	%
475993	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Accumulated Fault Duty B Ph V	14.35	%
475994	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
475995	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Switching Operations	0	
475996	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Tank Paint Condition	Good	
475997	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Unknown Operations	0	
475998	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Accumulated Fault Duty C Ph V	9.57	%
475999	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Amps A Ø	32.0	
476000	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Amps B Ø	53.0	
476001	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Amps C Ø	43.0	
476002	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
476003	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
476004	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
476005	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1279	
476006	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1279	
476007	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
476008	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
476009	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
476010	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
476011	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
476012	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
476013	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
476014	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
476015	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
476016	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
476017	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
476018	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Oil Temp Max	25	°C
476019	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Oil Temp Present	15	°C
476020	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Follow-up Action Required?	n	
476021	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Foundation Condition	Good	
476022	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	General Comments		
476023	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Follow-up Action Required?	n	
476024	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Follow-up Action Required?	n	
476025	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Operations Ground	0	
476026	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
476027	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Winding Temp Present	30	°C
476028	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Winding Temp Max	35	°C
476029	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
476030	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
476031	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
476032	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
476033	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
476034	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
476035	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
476036	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
476037	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Oil Temp Present	28	°C
476038	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
476039	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	General Comments		
476040	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Amps C Ø	200.0	
476041	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Bushing Condition	Good	
476042	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
476043	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
476044	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
476045	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
476046	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
476047	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
476048	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
476049	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
476050	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
476051	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	General Comments		
476052	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	General Comments		
476053	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
476054	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Operations B Ø	0	
476055	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Operations A Ø	0	
476056	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
476057	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
476058	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Operations This Read Vac	6	
476059	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
476060	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
476061	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Equipment Properly Labeled?	y	
476062	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Cabinet Paint Condition	Good	
476063	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
476064	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	9 Month Operations	4	
476065	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
476066	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
476067	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Amps A Ø	200.0	
476068	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Unknown Operations	0	
476069	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Operations A Ø	0	
476070	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
476071	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
476072	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
476073	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
476074	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
476075	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
476076	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
476077	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
476078	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
476079	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Bushing Condition	Good	
476080	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Amps C Ø	190.0	
476081	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Amps B Ø	190.0	
476082	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Amps A Ø	190.0	
476083	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
476084	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
476085	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
476086	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	9 Month Operations	2	
476087	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
476088	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
476089	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	0	
476090	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Operations Counter AL	99990	
476091	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Operations Counter AF	99990	
476092	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Moisture and Leak Free?	y	
476093	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Maintenance Operations	0	
476094	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Grounds in Place?	y	
476095	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	General Comments	1 blown arrestor	
476096	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
476097	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Patrol Inspection	Equipment Properly Labeled?	y	
476098	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Amps B Ø	200.0	
476099	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Operations B Ø	0	
476100	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Operations C Ø	0	
476101	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
476102	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	640.0	
476103	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	General Comments		
476104	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Foundation Condition	Good	
476105	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Operations Ground	0	
476106	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Follow-up Action Required?	n	
476107	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
476108	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC As Left Counter	51334	
476109	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
476110	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC Current Tap Position	10L	
476111	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Tank Paint Condition	Good	
476112	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Unknown Operations	0	
476113	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
476114	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Operations A Ø	0	
476115	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Operations B Ø	0	
476116	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Operations C Ø	0	
476117	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC Max Tap Position	5L	
476118	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC Min Tap Position	16L	
476119	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
476120	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Operations Ground	0	
476121	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Follow-up Action Required?	n	
476122	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
476123	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
476124	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
476125	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
476126	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
476127	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
476128	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
476129	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Follow-up Action Required?	n	
476130	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Foundation Condition	Good	
476131	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
476132	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
476133	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
476134	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
476135	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
476136	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
476137	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
476138	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
476139	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
476140	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	General Comments		
476141	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
476142	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	General Comments		
476143	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Grounds in Place?	y	
476144	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Heaters (All) Functioning?	y	
476145	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Maintenance Operations	0	
476146	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
476147	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Moisture and Leak Free?	y	
476148	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
476149	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
476150	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Operations Counter AF	365	
476151	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
476152	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
476153	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
476154	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
476155	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
476156	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
476157	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
476158	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Bushings Connection/Risers	Good	
476159	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Bushing Condition	Good	
476160	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Amps C Ø	10.0	
476161	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Amps B Ø	10.0	
476162	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Amps A Ø	10.0	
476163	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
476164	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
476165	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
476166	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	9 Month Operations	12	
476167	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
476168	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Tank Paint Condition	Good	
476169	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Switching Operations	0	
476170	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Switching Operations	6	
476171	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Bushings Connection/Risers	Good	
476172	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
476173	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Grounds in Place?	y	
476174	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
476175	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
476176	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
476177	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
476178	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
476179	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
476180	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
476181	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
476182	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	160.0	
476183	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	160.0	
476184	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Operations This Read Vac	0	
476185	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Operations Counter AL	344	
476186	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Operations Counter AF	344	
476187	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Cabinet Paint Condition	Good	
476188	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	Follow-up Action Required?	n	
476189	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
476190	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	General Comments		
476191	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	General Comments	substation is deenergized for transmission work	
476192	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC As Found Counter	51334	
476193	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Equipment Properly Labeled?	y	
476194	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
476195	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
476196	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
476197	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	LTCC000074	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
476198	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	LTCC000074	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
476199	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	411136	
476200	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.5	volts
476201	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
476202	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
476203	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
476204	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations A Ø	0	
476205	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations B Ø	0	
476206	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
476207	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
476208	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
476209	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
476210	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
476211	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
476212	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Current Tap Position	11L	
476213	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations C Ø	0	
476214	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations Ground	0	
476215	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
476216	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
476217	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
476218	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
476219	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
476220	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
476221	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	8L	
476222	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	5R	
476223	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	600.0	
476224	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	500.0	
476225	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	600.0	
476226	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
476227	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
476228	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
476229	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
476230	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
476231	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
476232	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
476233	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	General Comments		
476234	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
476235	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Max Tap Position	8L	
476236	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Min Tap Position	16L	
476237	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
476238	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Operations Counter AL	262	
476239	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Operations This Read Vac	1	
476240	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Switching Operations	1	
476241	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Unknown Operations	0	
476242	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
476243	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
476244	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
476245	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	General Comments		
476246	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	General Comments		
476247	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
476248	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	Follow-up Action Required?	n	
476249	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	LTCC000074	LTCControl	932-Offline Distribution	LTC Control Insp	All Connections OK?	y	
476250	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	LTCC000074	LTCControl	932-Offline Distribution	LTC Control Insp	Follow-up Action Required?	n	
476251	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	LTCC000074	LTCControl	932-Offline Distribution	LTC Control Insp	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
476252	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	LTCC000074	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Operation Checked?	y	
476253	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	640.0	
476254	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	640.0	
476255	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
476256	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
476257	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
476258	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
476259	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
476260	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
476261	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
476262	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	LTCC000074	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
476263	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
476264	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	LTCC000074	LTCControl	932-Offline Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
476265	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
476266	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
476267	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
476268	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
476269	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
476270	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
476271	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
476272	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	LTCC000074	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
476273	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	110.0	
476274	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
476275	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
476276	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
476277	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
476278	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
476279	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
476280	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
476281	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
476282	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
476283	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
476284	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Winding Temp Present	50	°C
476285	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Winding Temp Max	65	°C
476286	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Totalizer Meter Reading	1.0900	
476287	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
476288	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
476289	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
476290	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
476291	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
476292	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
476293	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
476294	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	General Comments		
476295	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
476296	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Moisture and Leak Free?	y	
476297	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Maintenance Operations	0	
476298	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Heaters (All) Functioning?	y	
476299	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Grounds in Place?	y	
476300	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
476301	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
476302	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
476303	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
476304	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
476305	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
476306	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
476307	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
476308	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
476309	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
476310	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
476311	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
476312	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
476313	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
476314	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	459	
476315	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
476316	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
476317	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
476318	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
476319	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
476320	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
476321	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Totalizer Meter Multiplier	14000	
476322	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
476323	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	459	
476324	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
476325	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
476326	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
476327	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
476328	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
476329	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
476330	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
476331	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
476332	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
476333	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Patrol Inspection	Follow-up Action Required?	n	
476334	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Follow-up Action Required?	n	
476335	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Patrol Inspection	General Comments		
476336	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	General Comments		
476337	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Maintenance Operations	0	
476338	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
476339	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Vegetation	None	
476340	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Exp Boom Corrected	
476341	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	General Comments	Yard light is not working	
476342	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
476343	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
476344	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
476345	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
476346	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
476347	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
476348	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
476349	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
476350	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Clear of Trash?	y	
476351	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
476352	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Regulator As Left Counter	55574	
476353	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
476354	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
476355	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Tank Leaks	None	
476356	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
476357	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
476358	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
476359	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
476360	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
476361	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
476362	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
476363	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
476364	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
476365	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
476366	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
476367	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
476368	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
476369	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
476370	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
476371	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
476372	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
476373	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
476374	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
476375	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
476376	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
476377	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
476378	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
476379	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	General Comments		
476380	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	VRR Time Delay	30	Seconds
476381	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
476382	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
476383	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
476384	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
476385	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
476386	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	LTC Operation Checked?	y	
476387	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	General Comments		
476388	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	Follow-up Action Required?	n	
476389	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	All Connections OK?	y	
476390	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
476391	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
476392	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
476393	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
476394	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
476395	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
476396	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Foundation Condition	Good	
476397	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
476398	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
476399	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	General Comments		
476400	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
476401	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
476402	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Unknown Operations	0	
476403	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Switching Operations	0	
476404	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Operations This Read AM	3	
476405	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
476406	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
476407	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
476408	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
476409	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
476410	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
476411	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
476412	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Switching Operations	1	
476413	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC Min Tap Position	4L	
476414	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC Operations Since Last Insp	474	
476415	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
476416	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
476417	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	9 Month Operations	1	
476418	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
476419	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
476420	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
476421	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
476422	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
476423	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
476424	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
476425	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
476426	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
476427	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
476428	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
476429	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
476430	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
476431	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
476432	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
476433	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
476434	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	143	
476435	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
476436	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	143	
476437	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	3	
476438	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
476439	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
476440	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
476441	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
476442	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
476443	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	General Comments		
476444	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
476445	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
476446	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
476447	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
476448	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
476449	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Amps A Ø	70.0	
476450	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Amps B Ø	70.0	
476451	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Amps C Ø	70.0	
476452	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
476453	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Bushing Condition	Good	
476454	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Bushings Connection/Risers	Good	
476455	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
476456	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Amps C Ø	28.0	
476457	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
476458	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
476459	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
476460	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
476461	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	120.0	
476462	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
476463	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
476464	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
476465	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Amps B Ø	45.0	
476466	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	120.0	
476467	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
476468	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
476469	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
476470	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
476471	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Operations This Read Vac	0	
476472	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
476473	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	General Comments	2 arresters blowed on cir,414.and one arrester blown on cir.415	
476474	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
476475	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
476476	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
476477	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Foundation Condition	Good	
476478	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
476479	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
476480	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
476481	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
476482	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
476483	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
476484	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Operations A Ø	0	
476485	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Operations B Ø	0	
476486	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Operations C Ø	0	
476487	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
476488	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC Operations Since Last Insp	152	
476489	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC Min Tap Position	9L	
476490	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC Max Tap Position	2L	
476491	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC Current Tap Position	7L	
476492	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
476493	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Operations Ground	0	
476494	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Follow-up Action Required?	n	
476495	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	General Comments		
476496	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Maintenance Operations	0	
476497	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Operations Counter AF	262	
476498	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC As Left Counter	35413	
476499	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC As Found Counter	35413	
476500	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
476501	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
476502	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
476503	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
476504	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
476505	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
476506	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
476507	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
476508	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
476509	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
476510	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
476511	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
476512	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
476513	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
476514	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
476515	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
476516	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
476517	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
476518	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
476519	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	172	
476520	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	172	
476521	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
476522	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
476523	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
476524	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
476525	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
476526	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
476527	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
476528	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
476529	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
476530	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
476531	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	596	
476532	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	596	
476533	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	3	
476534	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
476535	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Unknown Operations	0	
476536	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Tank Paint Condition	Good	
476537	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Switching Operations	0	
476538	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
476539	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
476540	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
476541	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
476542	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
476543	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
476544	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
476545	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	General Comments		
476546	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
476547	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
476548	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
476549	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
476550	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
476551	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
476552	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
476553	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
476554	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
476555	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
476556	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
476557	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
476558	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
476559	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
476560	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
476561	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
476562	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
476563	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
476564	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
476565	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	General Comments		
476566	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
476567	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	H2 Winding Temp Max	30	°C
476568	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	H2 Winding Temp Present	20	°C
476569	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
476570	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
476571	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
476572	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	Oil Temp Max	35	°C
476573	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	Oil Temp Present	25	°C
476574	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
476575	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
476576	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
476577	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
476578	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
476579	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
476580	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
476581	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
476582	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
476583	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
476584	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	General Comments		
476585	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	General Comments		
476586	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
476587	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
476588	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
476589	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
476590	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
476591	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
476592	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
476593	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
476594	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
476595	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	14L	
476596	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	8L	
476597	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	13L	
476598	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
476599	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Min Tap Position	9L	
476600	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Max Tap Position	4L	
476601	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Current Tap Position	6L	
476602	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
476603	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
476604	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC As Left Counter	74907	
476605	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC As Found Counter	74907	
476606	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC As Left Counter	16063	
476607	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
476608	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
476609	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	General Comments		
476610	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
476611	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
476612	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC As Found Counter	16063	
476613	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
476614	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
476615	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	General Comments		
476616	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
476617	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
476618	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Foundation Condition	Good	
476619	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
476620	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
476621	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
476622	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
476623	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
476624	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
476625	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
476626	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
476627	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
476628	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
476629	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
476630	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
476631	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
476632	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
476633	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	General Comments		
476634	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	All Connections OK?	y	
476635	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
476636	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
476637	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
476638	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
476639	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Cabinet Paint Condition	Good	
476640	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Equipment Properly Labeled?	y	
476641	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
476642	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
476643	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BCH000375	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
476644	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BCH000375	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
476645	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BCH000375	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
476646	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
476647	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
476648	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
476649	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
476650	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	General Comments		
476651	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
476652	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
476653	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Operations Counter	85	
476654	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
476655	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
476656	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
476657	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
476658	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Follow-up Action Required?	n	
476659	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
476660	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	General Comments		
476661	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Maintenance Operations	0	
476662	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Operations Counter AF	677	
476663	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Operations Counter AL	677	
476664	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Operations This Read AM	0	
476665	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Switching Operations	0	
476666	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Unknown Operations	0	
476667	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	9 Month Operations	15	
476668	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
476669	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
476670	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1080.00	kw
476671	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
476672	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
476673	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
476674	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
476675	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	Oil Temp Present	32	°C
476676	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	Oil Temp Max	37	°C
476677	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
476678	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
476679	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	65	°C
476680	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
476681	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	General Comments	can only reset one gauge.	
476682	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
476683	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
476684	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
476685	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
476686	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
476687	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
476688	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
476689	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
476690	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
476691	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
476692	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
476693	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
476694	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
476695	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
476696	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
476697	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
476698	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
476699	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
476700	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	25	°C
476701	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	25	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
476702	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	30	°C
476703	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	30	°C
476704	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	35	°C
476705	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	35	°C
476706	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
476707	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
476708	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Foundation Condition	Good	
476709	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Follow-up Action Required?	n	
476710	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Follow-up Action Required?	n	
476711	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Operations Ground	0	
476712	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Operations C Ø	0	
476713	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Operations B Ø	0	
476714	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Operations A Ø	0	
476715	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
476716	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	carded out	
476717	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
476718	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
476719	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Amps C Ø	0.0	
476720	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Amps B Ø	0.0	
476721	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
476722	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
476723	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
476724	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
476725	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Equipment Properly Labeled?	y	
476726	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Cabinet Paint Condition	Good	
476727	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Amps A Ø	0.0	
476728	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
476729	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
476730	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
476731	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	725	
476732	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	725	
476733	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
476734	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
476735	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
476736	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
476737	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
476738	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
476739	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	9 Month Operations	5	
476740	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BCH000375	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
476741	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BCH000375	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
476742	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BCH000375	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
476743	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Clear of Trash?	y	
476744	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
476745	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
476746	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
476747	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
476748	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Equipment Properly Labeled?	y	
476749	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Cabinet Paint Condition	Good	
476750	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
476751	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	General Comments	Fence on back right corner has big gap but has barbed wire running between fence bottom and the ground.	
476752	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
476753	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
476754	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
476755	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
476756	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
476757	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
476758	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
476759	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
476760	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
476761	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
476762	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
476763	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
476764	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
476765	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
476766	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
476767	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
476768	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
476769	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	9 Months Operations	16	
476770	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Accumulated Fault Duty A Ph AM	1.20	%
476771	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Accumulated Fault Duty B Ph AM	2.41	%
476772	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
476773	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
476774	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
476775	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
476776	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Accumulated Fault Duty C Ph AM	2.41	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
476777	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Amps A Ø	88.0	
476778	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Amps B Ø	54.0	
476779	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
476780	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
476781	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
476782	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
476783	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
476784	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
476785	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Amps C Ø	57.0	
476786	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
476787	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
476788	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Bushings Connection/Risers	Good	
476789	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Bushing Condition	Good	
476790	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Amps C Ø	50.0	
476791	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Fans Condition	Good	
476792	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Amps B Ø	50.0	
476793	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
476794	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
476795	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	55	°C
476796	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
476797	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
476798	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
476799	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
476800	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
476801	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Bushings Connection/Risers	Good	
476802	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
476803	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
476804	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Switching Operations	0	
476805	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Unknown Operations	0	
476806	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
476807	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
476808	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
476809	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
476810	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
476811	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
476812	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Unknown Operations	0	
476813	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Tank Paint Condition	Good	
476814	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Switching Operations	0	
476815	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
476816	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Operations This Read Vac	0	
476817	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Operations Counter AL	381	
476818	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Operations Counter AF	381	
476819	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Moisture and Leak Free?	y	
476820	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Maintenance Operations	0	
476821	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Heaters (All) Functioning?	y	
476822	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
476823	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Vegetation	None	
476824	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
476825	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Grounds in Place?	y	
476826	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	General Comments		
476827	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	General Comments		
476828	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Foundation Condition	Good	
476829	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Follow-up Action Required?	n	
476830	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Follow-up Action Required?	n	
476831	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Operations Ground	0	
476832	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Operations C Ø	0	
476833	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Operations B Ø	0	
476834	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Operations A Ø	0	
476835	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
476836	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
476837	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	General Comments		
476838	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
476839	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
476840	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
476841	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
476842	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
476843	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X3 Winding Temp Max	52	°C
476844	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X3 Winding Temp Present	42	°C
476845	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	General Comments		
476846	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	General Comments		
476847	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
476848	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
476849	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Follow-up Action Required?	n	
476850	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
476851	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Fans Operational?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
476852	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
476853	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
476854	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
476855	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
476856	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
476857	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
476858	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Amps A Ø	0.0	
476859	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Amps B Ø	0.0	
476860	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
476861	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
476862	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
476863	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
476864	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	375	
476865	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
476866	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
476867	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Amps C Ø	0.0	
476868	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Bushing Condition	Good	
476869	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Bushings Connection/Risers	Good	
476870	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
476871	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
476872	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
476873	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
476874	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
476875	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
476876	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Operations A Ø	0	
476877	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
476878	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Operations B Ø	0	
476879	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Operations C Ø	0	
476880	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Operations Ground	0	
476881	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	9 Month Operations	1	
476882	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
476883	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
476884	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
476885	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
476886	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	203	
476887	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
476888	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
476889	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
476890	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
476891	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
476892	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
476893	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Amps A Ø	50.0	
476894	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
476895	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
476896	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
476897	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
476898	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
476899	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
476900	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Fans Operational?	y	
476901	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
476902	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	General Comments	SOME FENCE POST, FABRIC AND TOP RAIL GETTING RUST	
476903	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
476904	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
476905	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
476906	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
476907	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	Follow-up Action Required?	y	
476908	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
476909	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
476910	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	General Comments		
476911	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	General Comments	X2 will not reset	
476912	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
476913	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
476914	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
476915	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	Oil Temp Max	50	°C
476916	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	Oil Temp Present	45	°C
476917	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
476918	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
476919	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
476920	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
476921	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
476922	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
476923	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
476924	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
476925	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
476926	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
476927	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
476928	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
476929	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
476930	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
476931	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
476932	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
476933	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
476934	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Tank Leaks	None	
476935	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
476936	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
476937	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
476938	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
476939	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X1 Winding Temp Max	45	°C
476940	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X1 Winding Temp Present	35	°C
476941	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X2 Winding Temp Max	90	°C
476942	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X2 Winding Temp Present	42	°C
476943	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
476944	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
476945	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
476946	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
476947	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
476948	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
476949	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
476950	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
476951	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Operations Counter AL	232	
476952	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Operations Counter AF	232	
476953	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Moisture and Leak Free?	y	
476954	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Maintenance Operations	0	
476955	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Heaters (All) Functioning?	y	
476956	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Grounds in Place?	y	
476957	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	General Comments		
476958	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1078	
476959	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	10	
476960	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
476961	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
476962	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	General Comments	B phase IOC	
476963	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Maintenance Operations	0	
476964	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Operations Counter AF	322	
476965	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Operations Counter AL	322	
476966	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Operations This Read Vac	2	
476967	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Switching Operations	0	
476968	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Unknown Operations	0	
476969	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Operations Ground	0	
476970	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
476971	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	General Comments		
476972	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
476973	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Maintenance Operations	0	
476974	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Operations Counter AF	112	
476975	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Operations Counter AL	112	
476976	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Operations This Read Vac	0	
476977	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Switching Operations	0	
476978	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
476979	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
476980	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
476981	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
476982	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	General Comments		
476983	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
476984	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
476985	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
476986	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
476987	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
476988	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	General Comments		
476989	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Foundation Condition	Good	
476990	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Follow-up Action Required?	n	
476991	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Follow-up Action Required?	n	
476992	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
476993	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
476994	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
476995	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
476996	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Switching Operations	0	
476997	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Tank Paint Condition	Good	
476998	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Unknown Operations	0	
476999	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Bushings Connection/Risers	Good	
477000	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Bushing Condition	Good	
477001	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Amps C Ø	20.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
477002	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
477003	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
477004	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Amps B Ø	20.0	
477005	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Amps A Ø	20.0	
477006	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
477007	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	General Comments		
477008	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
477009	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
477010	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
477011	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Operations Counter	32	
477012	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
477013	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Tank Leaks	None	
477014	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
477015	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
477016	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
477017	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
477018	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
477019	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
477020	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
477021	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
477022	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
477023	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
477024	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
477025	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
477026	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
477027	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
477028	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
477029	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
477030	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
477031	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1078	
477032	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Operations Ground	0	
477033	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Follow-up Action Required?	n	
477034	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	9 Month Operations	0	
477035	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Unknown Operations	0	
477036	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Tank Paint Condition	Good	
477037	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Switching Operations	0	
477038	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
477039	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Operations This Read Vac	0	
477040	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
477041	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	General Comments		
477042	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
477043	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	All Connections OK?	y	
477044	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	Follow-up Action Required?	n	
477045	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	General Comments		
477046	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	LTC Operation Checked?	y	
477047	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
477048	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
477049	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
477050	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations A Ø	0	
477051	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations B Ø	0	
477052	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
477053	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
477054	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	VRR Time Delay	60	Seconds
477055	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations C Ø	0	
477056	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations Ground	0	
477057	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
477058	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Cabinet Paint Condition	Good	
477059	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Equipment Properly Labeled?	y	
477060	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
477061	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
477062	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Patrol Inspection	Follow-up Action Required?	n	
477063	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Follow-up Action Required?	n	
477064	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Patrol Inspection	General Comments		
477065	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
477066	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Operations A Ø	0	
477067	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Operations B Ø	0	
477068	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Operations C Ø	0	
477069	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Operations Ground	0	
477070	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Follow-up Action Required?	n	
477071	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Follow-up Action Required?	n	
477072	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	General Comments		
477073	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Foundation Condition	Good	
477074	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	General Comments		
477075	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	General Comments		
477076	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
477077	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Maintenance Operations	0	
477078	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Moisture and Leak Free?	y	
477079	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Operations Counter AF	35	
477080	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Operations Counter AL	35	
477081	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Operations This Read Vac	0	
477082	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
477083	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Unknown Operations	0	
477084	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Tank Paint Condition	Good	
477085	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Maintenance Operations	0	
477086	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Operations Counter AF	230	
477087	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Operations Counter AL	230	
477088	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Operations This Read Vac	0	
477089	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Switching Operations	0	
477090	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Switching Operations	0	
477091	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Unknown Operations	0	
477092	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Operations Ground	0	
477093	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Unknown Operations	0	
477094	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Operations C Ø	0	
477095	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Operations B Ø	0	
477096	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Operations A Ø	0	
477097	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
477098	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
477099	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
477100	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Equipment Properly Labeled?	y	
477101	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Cabinet Paint Condition	Good	
477102	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
477103	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	9 Month Operations	4	
477104	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
477105	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
477106	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
477107	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
477108	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
477109	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	General Comments		
477110	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
477111	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
477112	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
477113	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Bushings Connection/Risers	Good	
477114	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Bushing Condition	Good	
477115	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Amps C Ø	120.0	
477116	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Amps B Ø	120.0	
477117	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Amps A Ø	120.0	
477118	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
477119	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
477120	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
477121	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	9 Month Operations	1	
477122	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
477123	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
477124	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
477125	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
477126	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
477127	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Amps A Ø	47.0	
477128	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Amps B Ø	49.0	
477129	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Amps C Ø	47.0	
477130	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
477131	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
477132	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
477133	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
477134	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
477135	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
477136	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
477137	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
477138	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
477139	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
477140	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
477141	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
477142	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
477143	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
477144	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
477145	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
477146	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
477147	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
477148	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
477149	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4500	
477150	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	9 Month Operations	3	
477151	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	5.78	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
477152	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	5.78	%
477153	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	5.78	%
477154	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Amps A Ø	688.0	
477155	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
477156	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Vegetation	None	
477157	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
477158	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Amps B Ø	702.0	
477159	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Amps C Ø	636.0	
477160	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
477161	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
477162	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
477163	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
477164	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
477165	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
477166	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Accumulated Fault Duty A Ph V	35.08	%
477167	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Accumulated Fault Duty B Ph V	18.33	%
477168	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Accumulated Fault Duty C Ph V	18.33	%
477169	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Amps A Ø	98.0	
477170	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
477171	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Tank Leaks	None	
477172	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
477173	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
477174	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Regulator As Left Counter	59047	
477175	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
477176	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
477177	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Amps B Ø	76.0	
477178	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	General Comments		
477179	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
477180	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
477181	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
477182	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Min Tap Position	16L	
477183	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Max Tap Position	6L	
477184	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
477185	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	General Comments		
477186	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
477187	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
477188	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
477189	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
477190	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Current Tap Position	10L	
477191	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
477192	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
477193	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
477194	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
477195	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
477196	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
477197	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
477198	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
477199	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
477200	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
477201	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
477202	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
477203	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
477204	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
477205	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
477206	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
477207	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
477208	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
477209	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
477210	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
477211	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
477212	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
477213	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
477214	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Operations A Ø	0	
477215	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Operations B Ø	0	
477216	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Operations C Ø	0	
477217	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Operations Ground	0	
477218	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Follow-up Action Required?	n	
477219	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
477220	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
477221	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
477222	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
477223	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
477224	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	General Comments		
477225	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
477226	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
477227	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Foundation Condition	Good	
477228	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
477229	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
477230	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
477231	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	667	
477232	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
477233	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC Min Tap Position	11L	
477234	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC Max Tap Position	5L	
477235	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC Current Tap Position	9L	
477236	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
477237	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC As Left Counter	59658	
477238	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC As Found Counter	59658	
477239	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
477240	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	General Comments		
477241	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
477242	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Operations This Read Vac	0	
477243	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
477244	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
477245	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
477246	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
477247	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
477248	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
477249	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
477250	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Operations A Ø	2	
477251	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
477252	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Operations B Ø	0	
477253	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
477254	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
477255	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
477256	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
477257	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
477258	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
477259	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
477260	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
477261	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
477262	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
477263	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
477264	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
477265	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
477266	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Operations C Ø	0	
477267	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Amps C Ø	20.0	
477268	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
477269	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
477270	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	6	
477271	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
477272	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
477273	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
477274	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
477275	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
477276	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
477277	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
477278	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
477279	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
477280	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
477281	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
477282	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
477283	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
477284	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
477285	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
477286	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
477287	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
477288	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
477289	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
477290	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
477291	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
477292	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
477293	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
477294	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
477295	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
477296	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
477297	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
477298	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
477299	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
477300	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
477301	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
477302	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
477303	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
477304	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Clear of Trash?	y	
477305	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
477306	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
477307	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
477308	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	260	
477309	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
477310	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
477311	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
477312	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	260	
477313	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
477314	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	General Comments		
477315	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
477316	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
477317	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
477318	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
477319	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
477320	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
477321	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
477322	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
477323	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
477324	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
477325	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
477326	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	61.61	%
477327	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	61.61	%
477328	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	61.61	%
477329	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Amps A Ø	22.0	
477330	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Amps B Ø	22.0	
477331	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Amps C Ø	71.0	
477332	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Follow-up Action Required?	n	
477333	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Foundation Condition	Good	
477334	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	General Comments		
477335	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	General Comments		
477336	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Grounds in Place?	y	
477337	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Heaters (All) Functioning?	y	
477338	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Maintenance Operations	0	
477339	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Moisture and Leak Free?	y	
477340	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Operations Counter AF	241	
477341	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Operations Counter AL	241	
477342	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
477343	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
477344	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Operations B Ø	0	
477345	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Operations A Ø	0	
477346	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
477347	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
477348	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
477349	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
477350	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	General Comments	tower foundations are crumbling	
477351	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
477352	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
477353	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
477354	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
477355	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
477356	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
477357	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
477358	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Amps C Ø	135.0	
477359	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Amps B Ø	159.0	
477360	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Amps A Ø	113.0	
477361	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Equipment Properly Labeled?	y	
477362	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Cabinet Paint Condition	Good	
477363	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
477364	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
477365	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
477366	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Bushings Connection/Risers	Good	
477367	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Bushing Condition	Good	
477368	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Amps C Ø	100.0	
477369	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Accumulated Fault Duty C Ph AM	1.20	%
477370	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	9 Months Operations	0	
477371	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
477372	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
477373	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
477374	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
477375	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
477376	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
477377	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
477378	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
477379	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
477380	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
477381	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	General Comments		
477382	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	General Comments		
477383	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	General Comments		
477384	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
477385	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	Follow-up Action Required?	n	
477386	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
477387	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Operations A Ø	0	
477388	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Operations B Ø	0	
477389	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Amps B Ø	100.0	
477390	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Amps A Ø	100.0	
477391	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
477392	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
477393	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
477394	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
477395	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
477396	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
477397	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Unknown Operations	0	
477398	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Tank Paint Condition	Good	
477399	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Switching Operations	0	
477400	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
477401	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Operations This Read Vac	0	
477402	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Operations Counter AL	91462	
477403	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Operations Counter AF	91462	
477404	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Moisture and Leak Free?	y	
477405	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Maintenance Operations	0	
477406	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Heaters (All) Functioning?	y	
477407	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Grounds in Place?	y	
477408	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
477409	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
477410	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
477411	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Foundation Condition	Good	
477412	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	General Comments		
477413	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	General Comments		
477414	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Foundation Condition	Good	
477415	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Follow-up Action Required?	n	
477416	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Follow-up Action Required?	n	
477417	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Operations Ground	0	
477418	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Operations C Ø	0	
477419	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Operations B Ø	0	
477420	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Operations A Ø	0	
477421	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
477422	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
477423	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
477424	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
477425	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
477426	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
477427	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
477428	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
477429	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Operations This Read AM	1	
477430	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Operations Counter AL	198	
477431	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Operations Counter AF	198	
477432	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Maintenance Operations	0	
477433	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	General Comments	this is the correct VC	
477434	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Follow-up Action Required?	n	
477435	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Operations Ground	0	
477436	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Operations C Ø	0	
477437	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
477438	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
477439	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
477440	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
477441	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
477442	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
477443	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
477444	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
477445	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
477446	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
477447	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
477448	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
477449	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
477450	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
477451	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
477452	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	60	°C
477453	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	35	°C
477454	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	120	°C
477455	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Amps B Ø	494.0	
477456	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Operations Ground	0	
477457	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
477458	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Follow-up Action Required?	n	
477459	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
477460	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
477461	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
477462	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
477463	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
477464	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
477465	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Operations A Ø	0	
477466	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Operations B Ø	0	
477467	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Operations C Ø	0	
477468	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Operations Ground	0	
477469	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	9 Month Operations	4	
477470	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	9 Month Operations	11	
477471	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	Follow-up Action Required?	n	
477472	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
477473	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	General Comments		
477474	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	General Comments		
477475	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC As Found Counter	58519	
477476	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC As Left Counter	58519	
477477	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
477478	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC Current Tap Position	4L	
477479	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC Max Tap Position	2R	
477480	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC Min Tap Position	5L	
477481	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC Operations Since Last Insp	523	
477482	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
477483	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
477484	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
477485	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Follow-up Action Required?	n	
477486	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Follow-up Action Required?	n	
477487	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Foundation Condition	Good	
477488	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	General Comments		
477489	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	50	°C
477490	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	General Comments		
477491	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
477492	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
477493	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
477494	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
477495	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	4	
477496	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	4	
477497	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
477498	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
477499	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	850	
477500	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	850	
477501	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
477502	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
477503	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
477504	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
477505	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
477506	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	9 Month Operations	1	
477507	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
477508	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
477509	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
477510	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Operations C Ø	0	
477511	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
477512	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
477513	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
477514	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
477515	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
477516	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Accumulated Fault Duty B Ph AM	2.41	%
477517	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
477518	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	9 Months Operations	18	
477519	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
477520	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
477521	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
477522	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
477523	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
477524	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
477525	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
477526	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
477527	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
477528	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
477529	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Amps A Ø	500.0	
477530	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
477531	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
477532	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
477533	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
477534	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
477535	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	General Comments		
477536	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
477537	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
477538	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
477539	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	Oil Temp Max	80	°C
477540	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	Oil Temp Present	50	°C
477541	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
477542	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
477543	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Readings	General Comments		
477544	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
477545	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
477546	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
477547	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
477548	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	5	
477549	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Operations This Read Vac	0	
477550	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Operations Counter AL	545	
477551	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Operations Counter AF	545	
477552	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Maintenance Operations	0	
477553	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	General Comments		
477554	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Patrol Inspection	General Comments		
477555	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Follow-up Action Required?	n	
477556	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Patrol Inspection	Follow-up Action Required?	n	
477557	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
477558	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations Ground	0	
477559	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1239	
477560	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1239	
477561	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
477562	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
477563	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
477564	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
477565	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
477566	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
477567	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	9 Month Operations	16	
477568	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
477569	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
477570	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
477571	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Amps A Ø	42.0	
477572	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Amps B Ø	45.0	
477573	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	Follow-up Action Required?	n	
477574	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
477575	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	General Comments		
477576	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	General Comments		
477577	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
477578	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
477579	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC As Found Counter	31165	
477580	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC As Left Counter	31165	
477581	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
477582	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC Current Tap Position	8L	
477583	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC Max Tap Position	8L	
477584	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC Min Tap Position	10L	
477585	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
477586	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC Operations Since Last Insp	630	
477587	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
477588	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
477589	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
477590	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
477591	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC Max Tap Position	1L	
477592	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC Min Tap Position	13L	
477593	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC Operations Since Last Insp	12	
477594	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
477595	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Maintenance Operations	0	
477596	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Moisture and Leak Free?	y	
477597	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Operations Counter AF	1277	
477598	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Operations Counter AL	1277	
477599	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Operations This Read Vac	12	
477600	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
477601	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Switching Operations	4	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
477602	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Tank Paint Condition	Good	
477603	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	538	
477604	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Amps A Ø	16.2	
477605	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Amps B Ø	24.1	
477606	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Amps C Ø	18.7	
477607	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	388	
477608	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
477609	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
477610	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	418	
477611	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
477612	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
477613	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Unknown Operations	3	
477614	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Unknown Operations	0	
477615	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Switching Operations	0	
477616	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
477617	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
477618	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
477619	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
477620	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
477621	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
477622	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
477623	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	General Comments		
477624	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
477625	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
477626	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
477627	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	9 Month Operations	4	
477628	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
477629	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
477630	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
477631	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Amps A Ø	0.0	
477632	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Amps B Ø	0.0	
477633	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Amps C Ø	0.0	
477634	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Bushing Condition	Good	
477635	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
477636	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
477637	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
477638	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
477639	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
477640	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
477641	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Switching Operations	0	
477642	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
477643	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	9 Month Operations	0	
477644	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
477645	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
477646	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
477647	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Amps A Ø	260.0	
477648	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Amps B Ø	260.0	
477649	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Amps C Ø	260.0	
477650	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
477651	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
477652	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
477653	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
477654	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Operations This Read Vac	0	
477655	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Operations Counter AL	267	
477656	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Operations Counter AF	267	
477657	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
477658	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Maintenance Operations	0	
477659	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
477660	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Panels Dusted?	y	
477661	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
477662	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	General Comments		
477663	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
477664	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
477665	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	General Comments		
477666	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
477667	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
477668	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Floor Swept?	y	
477669	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
477670	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
477671	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
477672	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC Operations Since Last Insp	956	
477673	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
477674	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC Min Tap Position	8L	
477675	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC Max Tap Position	6R	
477676	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
477677	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
477678	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Follow-up Action Required?	n	
477679	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
477680	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC Current Tap Position	2L	
477681	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
477682	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC As Left Counter	27566	
477683	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC As Found Counter	27566	
477684	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
477685	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
477686	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Evidence of Insects	None	
477687	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
477688	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
477689	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
477690	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
477691	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Amps C Ø	44.0	
477692	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Patrol Inspection	Equipment Properly Labeled?	y	
477693	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
477694	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
477695	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
477696	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Operations A Ø	0	
477697	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Operations B Ø	0	
477698	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Operations C Ø	0	
477699	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Operations Ground	0	
477700	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Patrol Inspection	Follow-up Action Required?	n	
477701	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Follow-up Action Required?	n	
477702	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Patrol Inspection	General Comments		
477703	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations C Ø	0	
477704	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations B Ø	0	
477705	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations A Ø	0	
477706	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
477707	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
477708	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
477709	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
477710	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Amps C Ø	152.0	
477711	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Amps B Ø	158.0	
477712	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Amps A Ø	168.0	
477713	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
477714	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	General Comments		
477715	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Maintenance Operations	0	
477716	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
477717	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
477718	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
477719	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
477720	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Operations Counter AF	118	
477721	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Operations Counter AL	118	
477722	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Operations This Read Vac	5	
477723	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
477724	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Switching Operations	5	
477725	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Unknown Operations	0	
477726	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Unknown Operations	0	
477727	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
477728	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
477729	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Clear of Trash?	y	
477730	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
477731	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	General Comments		
477732	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
477733	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
477734	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
477735	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
477736	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Vegetation	None	
477737	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
477738	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
477739	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
477740	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
477741	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
477742	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
477743	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
477744	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Amps C Ø	0.0	
477745	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Patrol Inspection	Equipment Properly Labeled?	y	
477746	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
477747	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
477748	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
477749	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations A Ø	0	
477750	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations B Ø	0	
477751	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
477752	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations Ground	0	
477753	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Patrol Inspection	Follow-up Action Required?	n	
477754	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Follow-up Action Required?	n	
477755	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
477756	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
477757	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
477758	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Patrol Inspection	General Comments		
477759	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
477760	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC Min Tap Position	15L	
477761	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC Max Tap Position	Neutral	
477762	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC Current Tap Position	10L	
477763	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
477764	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Unknown Operations	0	
477765	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Tank Paint Condition	Good	
477766	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Switching Operations	4	
477767	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
477768	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Operations This Read Vac	4	
477769	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Operations Counter AL	254	
477770	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	General Comments	R&C	
477771	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Maintenance Operations	0	
477772	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Operations Counter AF	254	
477773	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Moisture and Leak Free?	y	
477774	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC As Left Counter	222621	
477775	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC As Found Counter	222621	
477776	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	General Comments	needs nitro	
477777	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	General Comments	lots of moisture on glass	
477778	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
477779	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	Follow-up Action Required?	y	
477780	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	323	
477781	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
477782	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99964	
477783	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99964	
477784	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
477785	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	General Comments		
477786	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Maintenance Operations	0	
477787	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
477788	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
477789	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
477790	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
477791	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
477792	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
477793	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	8	
477794	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	General Comments		
477795	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
477796	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
477797	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Operations Counter	110	
477798	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
477799	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Tank Leaks	None	
477800	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
477801	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
477802	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
477803	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
477804	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
477805	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	535	
477806	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
477807	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
477808	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
477809	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
477810	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
477811	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
477812	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
477813	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	9 Month Operations	0	
477814	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
477815	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
477816	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
477817	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Amps A Ø	0.0	
477818	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Amps B Ø	0.0	
477819	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Totalizer Meter Reading	.1510	
477820	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
477821	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
477822	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
477823	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
477824	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
477825	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
477826	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
477827	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
477828	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
477829	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Switching Operations	0	
477830	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Unknown Operations	0	
477831	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
477832	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
477833	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
477834	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
477835	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Oil Temp Present	39	°C
477836	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Oil Temp Max	60	°C
477837	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
477838	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
477839	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	LTC Totalizer Reading	1087.20	kw
477840	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	General Comments		
477841	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
477842	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Trash Emptied?	n	
477843	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
477844	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
477845	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
477846	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
477847	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
477848	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
477849	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
477850	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
477851	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
477852	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	550.0	
477853	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	500.0	
477854	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	550.0	
477855	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
477856	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	55.90	
477857	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
477858	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
477859	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
477860	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
477861	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
477862	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
477863	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
477864	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
477865	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
477866	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	2	
477867	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	55.90	
477868	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
477869	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	5	
477870	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	5	
477871	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
477872	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
477873	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
477874	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
477875	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
477876	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
477877	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Operations This Read AM	0	
477878	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	9 Month Operations	8	
477879	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
477880	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
477881	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
477882	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Amps A Ø	300.0	
477883	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Amps B Ø	240.0	
477884	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Amps C Ø	300.0	
477885	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Bushing Condition	Good	
477886	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	350.0	
477887	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	350.0	
477888	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	350.0	
477889	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
477890	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
477891	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
477892	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
477893	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
477894	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
477895	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
477896	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
477897	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
477898	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
477899	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
477900	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
477901	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
477902	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
477903	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
477904	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Heaters (All) Functioning?	y	
477905	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
477906	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
477907	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Grounds in Place?	y	
477908	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	General Comments		
477909	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	9 Month Operations	4	
477910	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
477911	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
477912	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
477913	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Operations Counter AF	123	
477914	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Operations Counter AL	123	
477915	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Operations This Read Vac	0	
477916	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Switching Operations	0	
477917	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Unknown Operations	0	
477918	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
477919	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
477920	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
477921	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	General Comments		
477922	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
477923	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
477924	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	General Comments		
477925	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
477926	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
477927	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
477928	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
477929	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Maintenance Operations	0	
477930	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Operations Counter AF	549	
477931	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Operations Counter AL	549	
477932	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
477933	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Evidence of Insects	None	
477934	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
477935	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
477936	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Floor Swept?	y	
477937	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
477938	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	26	
477939	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
477940	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
477941	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
477942	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Operations A Ø	0	
477943	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Operations B Ø	0	
477944	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Operations C Ø	0	
477945	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Operations Ground	0	
477946	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations Ground	0	
477947	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Patrol Inspection	Follow-up Action Required?	n	
477948	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Follow-up Action Required?	n	
477949	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Patrol Inspection	General Comments		
477950	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Operations Ground	0	
477951	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Operations C Ø	0	
477952	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Operations B Ø	0	
477953	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Operations A Ø	0	
477954	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Follow-up Action Required?	n	
477955	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	General Comments		
477956	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Maintenance Operations	0	
477957	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Operations Counter AF	285	
477958	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Operations Counter AL	285	
477959	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Operations This Read Vac	0	
477960	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Unknown Operations	0	
477961	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
477962	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
477963	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
477964	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Switching Operations	0	
477965	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Unknown Operations	0	
477966	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
477967	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
477968	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
477969	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	0	
477970	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	0	
477971	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	323	
477972	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
477973	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
477974	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
477975	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
477976	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
477977	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99	
477978	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99	
477979	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
477980	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
477981	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Amps A Ø	120.0	
477982	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Amps B Ø	116.0	
477983	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Amps C Ø	116.0	
477984	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Patrol Inspection	Equipment Properly Labeled?	y	
477985	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
477986	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
477987	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Positive DC Ground	22.0	VDC
477988	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Negative DC Ground	12.0	VDC
477989	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
477990	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Grounds in Place?	y	
477991	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
477992	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Maintenance Operations	0	
477993	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
477994	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Operations Counter AF	218	
477995	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Operations Counter AL	218	
477996	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Operations This Read Vac	0	
477997	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
477998	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Switching Operations	0	
477999	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Tank Paint Condition	Good	
478000	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Amps C Ø	506.0	
478001	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
478002	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
478003	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Patrol Inspection	General Comments		
478004	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
478005	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Tank Leaks	None	
478006	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
478007	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Operations Counter	1989	
478008	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
478009	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
478010	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	General Comments	Substation is deenergized for transmission work	
478011	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
478012	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
478013	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	General Comments		
478014	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Maintenance Operations	0	
478015	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Operations Counter AF	68	
478016	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Operations Counter AL	68	
478017	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Operations This Read Vac	0	
478018	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
478019	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
478020	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations A Ø	0	
478021	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations B Ø	0	
478022	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations C Ø	0	
478023	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
478024	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
478025	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
478026	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
478027	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
478028	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
478029	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
478030	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
478031	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Accumulated Fault Duty A Ph V	25.51	%
478032	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Accumulated Fault Duty B Ph V	30.29	%
478033	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Accumulated Fault Duty C Ph V	15.15	%
478034	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Amps A Ø	360.0	
478035	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Amps B Ø	360.0	
478036	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Switching Operations	0	
478037	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Unknown Operations	0	
478038	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Amps C Ø	340.0	
478039	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
478040	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
478041	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
478042	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
478043	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
478044	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
478045	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
478046	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	520	
478047	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	14L	
478048	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2R	
478049	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
478050	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC As Left Counter	103422	
478051	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC As Found Counter	103422	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
478052	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	General Comments		
478053	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
478054	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Amps A Ø	22.0	
478055	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Amps B Ø	25.0	
478056	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Amps C Ø	30.0	
478057	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
478058	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
478059	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
478060	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
478061	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
478062	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
478063	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
478064	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
478065	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
478066	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
478067	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
478068	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
478069	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
478070	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
478071	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
478072	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
478073	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
478074	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
478075	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
478076	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
478077	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
478078	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	9 Month Operations	3	
478079	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
478080	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
478081	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
478082	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
478083	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
478084	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
478085	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	General Comments		
478086	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
478087	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
478088	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
478089	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
478090	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations A Ø	0	
478091	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations B Ø	0	
478092	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations C Ø	1	
478093	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations Ground	0	
478094	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Patrol Inspection	Follow-up Action Required?	n	
478095	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Follow-up Action Required?	n	
478096	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Patrol Inspection	General Comments		
478097	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	General Comments	C Phase IOC	
478098	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Maintenance Operations	0	
478099	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Operations Counter AF	565	
478100	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Operations Counter AL	565	
478101	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Operations This Read Vac	1	
478102	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Switching Operations	0	
478103	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Unknown Operations	0	
478104	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
478105	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Vegetation	None	
478106	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
478107	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	General Comments		
478108	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
478109	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
478110	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
478111	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
478112	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
478113	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Clear of Trash?	y	
478114	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
478115	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
478116	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
478117	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	General Comments		
478118	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
478119	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
478120	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
478121	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
478122	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
478123	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
478124	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
478125	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
478126	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
478127	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
478128	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	408	
478129	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
478130	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5L	
478131	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
478132	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC As Left Counter	103830	
478133	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC As Found Counter	103830	
478134	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	General Comments		
478135	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
478136	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
478137	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
478138	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
478139	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
478140	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	PF000252	PowerFuse	ML-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
478141	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	PF000252	PowerFuse	ML-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
478142	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
478143	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
478144	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Winding Temp Present	35	°C
478145	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Winding Temp Max	35	°C
478146	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Totalizer Meter Reading	.7620	
478147	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
478148	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
478149	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
478150	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
478151	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
478152	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
478153	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
478154	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
478155	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Oil Temp Present	30	°C
478156	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Oil Temp Max	30	°C
478157	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
478158	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
478159	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
478160	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	LTC Totalizer Reading	10972.80	kw
478161	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
478162	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	General Comments		
478163	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	General Comments		
478164	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
478165	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
478166	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Follow-up Action Required?	n	
478167	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
478168	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
478169	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
478170	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
478171	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
478172	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
478173	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
478174	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
478175	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Bushing Condition	Good	
478176	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
478177	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
478178	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
478179	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
478180	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
478181	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
478182	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
478183	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
478184	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
478185	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
478186	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations	11	
478187	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
478188	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Floor Swept?	y	
478189	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
478190	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
478191	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Evidence of Insects	None	
478192	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
478193	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
478194	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
478195	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
478196	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
478197	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
478198	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
478199	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
478200	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
478201	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
478202	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
478203	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
478204	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
478205	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
478206	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	9 Month Operations	0	
478207	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Grounds in Place?	y	
478208	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	General Comments	open	
478209	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
478210	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Foundation Condition	Good	
478211	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
478212	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
478213	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
478214	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
478215	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
478216	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
478217	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
478218	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
478219	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
478220	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
478221	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
478222	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
478223	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
478224	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	PF000350	PowerFuse	TA-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
478225	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	PF000350	PowerFuse	TA-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	OK	
478226	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	PF000351	PowerFuse	TA-12KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
478227	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	PF000351	PowerFuse	TA-12KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	OK	
478228	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	PF000352	PowerFuse	TA-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
478229	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	PF000352	PowerFuse	TA-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	OK	
478230	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	PF000353	PowerFuse	TA-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
478231	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	PF000353	PowerFuse	TA-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	OK	
478232	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	PF000248	PowerFuse	ML-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
478233	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	PF000248	PowerFuse	ML-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
478234	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	PF000249	PowerFuse	ML-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
478235	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
478236	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
478237	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
478238	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
478239	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
478240	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	160.0	
478241	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	160.0	
478242	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	160.0	
478243	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
478244	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
478245	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
478246	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
478247	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	PF000249	PowerFuse	ML-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	ok	
478248	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	PF000250	PowerFuse	ML-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
478249	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	PF000250	PowerFuse	ML-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
478250	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Amps C Ø	280.0	
478251	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Amps B Ø	280.0	
478252	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Amps A Ø	280.0	
478253	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
478254	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
478255	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
478256	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	9 Month Operations	14	
478257	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	LTCC000454	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
478258	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	LTCC000454	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
478259	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	LTCC000454	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
478260	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	LTCC000454	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
478261	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	LTCC000454	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
478262	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	LTCC000454	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
478263	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	LTCC000454	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
478264	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	LTCC000454	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
478265	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	LTCC000454	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
478266	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
478267	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
478268	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
478269	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Site Service Trans Condition	Exterior Stains	
478270	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
478271	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
478272	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
478273	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
478274	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
478275	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
478276	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	General Comments	station supply transformer fuse looking somewhat frayed	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
478277	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
478278	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
478279	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
478280	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
478281	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
478282	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
478283	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
478284	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
478285	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
478286	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations A Ø	0	
478287	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations B Ø	0	
478288	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations C Ø	0	
478289	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	9 Months Operations	30	
478290	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
478291	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
478292	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations Ground	0	
478293	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Patrol Inspection	Follow-up Action Required?	n	
478294	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Follow-up Action Required?	n	
478295	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
478296	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Amps A Ø	90.0	
478297	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Amps B Ø	100.0	
478298	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Amps C Ø	180.0	
478299	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
478300	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
478301	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
478302	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
478303	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Operations A Ø	0	
478304	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Operations B Ø	0	
478305	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Broom on Site?	y	
478306	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
478307	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
478308	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
478309	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
478310	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
478311	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Unknown Operations	0	
478312	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
478313	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Switching Operations	0	
478314	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
478315	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Operations This Read Vac	0	
478316	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Operations Counter AL	38	
478317	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Operations Counter AF	38	
478318	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
478319	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Maintenance Operations	0	
478320	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
478321	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
478322	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	General Comments		
478323	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	General Comments		
478324	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
478325	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
478326	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
478327	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Operations Ground	0	
478328	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
478329	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
478330	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
478331	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
478332	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
478333	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
478334	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
478335	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
478336	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
478337	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
478338	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
478339	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
478340	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
478341	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
478342	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
478343	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
478344	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
478345	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	General Comments	Substation is deenergized for transmission work	
478346	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
478347	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
478348	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Operations Counter	1487	
478349	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
478350	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Tank Leaks	None	
478351	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
478352	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
478353	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
478354	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
478355	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
478356	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
478357	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
478358	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
478359	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
478360	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
478361	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
478362	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
478363	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
478364	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
478365	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
478366	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
478367	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
478368	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
478369	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
478370	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
478371	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
478372	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Maintenance Operations	0	
478373	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Operations Counter AF	6	
478374	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Operations Counter AL	6	
478375	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Operations This Read AM	0	
478376	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
478377	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
478378	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
478379	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
478380	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	General Comments		
478381	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
478382	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
478383	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
478384	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
478385	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
478386	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
478387	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
478388	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
478389	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Switching Operations	0	
478390	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Unknown Operations	0	
478391	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
478392	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
478393	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
478394	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
478395	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
478396	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
478397	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
478398	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
478399	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
478400	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
478401	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
478402	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	General Comments		
478403	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
478404	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
478405	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
478406	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
478407	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
478408	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
478409	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
478410	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
478411	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Regulator As Left Counter	80374	
478412	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
478413	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
478414	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Tank Leaks	None	
478415	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
478416	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Operations C Ø	0	
478417	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Operations Ground	0	
478418	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
478419	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Follow-up Action Required?	n	
478420	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Patrol Inspection	General Comments		
478421	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	General Comments		
478422	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
478423	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Bushing Condition	Good	
478424	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Bushings Connection/Risers	Good	
478425	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
478426	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
478427	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
478428	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Cabinet Paint Condition	Good	
478429	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Equipment Properly Labeled?	y	
478430	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
478431	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
478432	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
478433	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Operations A Ø	0	
478434	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Operations B Ø	0	
478435	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Operations C Ø	0	
478436	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Operations Ground	0	
478437	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Follow-up Action Required?	n	
478438	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Follow-up Action Required?	n	
478439	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Foundation Condition	Good	
478440	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	General Comments		
478441	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	General Comments		
478442	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Grounds in Place?	y	
478443	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
478444	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	General Comments		
478445	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
478446	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
478447	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
478448	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
478449	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
478450	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
478451	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
478452	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
478453	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
478454	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
478455	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
478456	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
478457	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
478458	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Heaters (All) Functioning?	y	
478459	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Maintenance Operations	0	
478460	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Moisture and Leak Free?	y	
478461	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Operations Counter AF	437	
478462	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Operations Counter AL	437	
478463	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Operations This Read Vac	0	
478464	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
478465	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Switching Operations	0	
478466	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Tank Paint Condition	Good	
478467	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Unknown Operations	0	
478468	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
478469	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	General Comments		
478470	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
478471	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
478472	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
478473	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
478474	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
478475	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
478476	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
478477	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
478478	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
478479	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Amps C Ø	560.0	
478480	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Amps B Ø	595.0	
478481	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Amps A Ø	625.0	
478482	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
478483	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
478484	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
478485	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
478486	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
478487	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
478488	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
478489	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
478490	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Foundation Condition	Good	
478491	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
478492	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	General Comments		
478493	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
478494	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
478495	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
478496	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
478497	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
478498	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
478499	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
478500	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
478501	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
478502	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	358	
478503	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	358	
478504	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
478505	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
478506	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
478507	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
478508	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
478509	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
478510	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
478511	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
478512	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
478513	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
478514	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
478515	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
478516	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
478517	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
478518	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
478519	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
478520	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
478521	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
478522	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
478523	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
478524	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
478525	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
478526	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
478527	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
478528	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
478529	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
478530	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
478531	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
478532	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
478533	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
478534	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Bushing Condition	Good	
478535	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Amps C Ø	50.0	
478536	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Amps B Ø	50.0	
478537	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Amps A Ø	50.0	
478538	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
478539	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
478540	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
478541	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	9 Month Operations	25	
478542	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
478543	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Tank Paint Condition	Good	
478544	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Switching Operations	0	
478545	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
478546	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
478547	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
478548	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
478549	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Panels Dusted?	y	
478550	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
478551	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	General Comments		
478552	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
478553	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Unknown Operations	0	
478554	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Operations This Read Vac	0	
478555	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	148	
478556	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	148	
478557	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
478558	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
478559	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
478560	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
478561	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
478562	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
478563	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
478564	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
478565	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
478566	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
478567	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
478568	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
478569	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
478570	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	General Comments		
478571	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
478572	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Switching Operations	0	
478573	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Operations This Read Vac	0	
478574	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Operations Counter AL	365	
478575	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Operations Counter AF	365	
478576	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
478577	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	General Comments		
478578	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Patrol Inspection	General Comments		
478579	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
478580	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
478581	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations Ground	0	
478582	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
478583	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
478584	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
478585	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
478586	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
478587	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
478588	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
478589	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Foundation Condition	Good	
478590	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
478591	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
478592	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	General Comments		
478593	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
478594	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
478595	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
478596	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
478597	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
478598	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
478599	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
478600	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
478601	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
478602	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
478603	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
478604	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
478605	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
478606	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
478607	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
478608	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
478609	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
478610	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
478611	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
478612	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
478613	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
478614	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
478615	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
478616	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
478617	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
478618	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
478619	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
478620	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
478621	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	General Comments		
478622	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
478623	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
478624	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Vent Fans OK?	y	
478625	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
478626	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
478627	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Panels Dusted?	y	
478628	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Panel Lights OK?	y	
478629	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
478630	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
478631	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	General Comments		
478632	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
478633	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Follow-up Action Required?	n	
478634	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
478635	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
478636	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Evidence of Insects	None	
478637	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
478638	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
478639	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
478640	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
478641	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
478642	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
478643	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
478644	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
478645	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
478646	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
478647	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Follow-up Action Required?	n	
478648	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
478649	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
478650	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	General Comments		
478651	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
478652	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
478653	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	LTC Totalizer Reading	6151.68	kw
478654	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
478655	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
478656	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Oil Temp Max	51	°C
478657	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Oil Temp Present	42	°C
478658	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
478659	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
478660	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
478661	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
478662	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	9 Month Operations	31	
478663	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
478664	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
478665	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
478666	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
478667	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
478668	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
478669	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
478670	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
478671	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
478672	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
478673	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Totalizer Meter Reading	.8544	
478674	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
478675	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
478676	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	General Comments		
478677	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
478678	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
478679	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.2	amps
478680	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
478681	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
478682	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
478683	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
478684	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
478685	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
478686	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
478687	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	General Comments		
478688	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
478689	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
478690	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
478691	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
478692	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
478693	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
478694	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
478695	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
478696	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
478697	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Foundation Condition	Good	
478698	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
478699	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
478700	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	General Comments		
478701	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
478702	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
478703	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
478704	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
478705	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
478706	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
478707	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
478708	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
478709	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
478710	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
478711	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
478712	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
478713	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
478714	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
478715	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
478716	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Follow-up Action Required?	n	
478717	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
478718	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
478719	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
478720	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
478721	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
478722	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
478723	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
478724	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
478725	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
478726	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
478727	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
478728	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
478729	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
478730	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	11	
478731	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
478732	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
478733	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	17	
478734	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Amps C Ø	1.9	
478735	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Amps B Ø	2.2	
478736	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Amps A Ø	4.5	
478737	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	12	
478738	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
478739	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
478740	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
478741	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LTCC000337	LTCControl	TA-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
478742	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LTCC000337	LTCControl	TA-TRANS 4	LTC Control Insp	General Comments		
478743	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LTCC000337	LTCControl	TA-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
478744	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	9 Month Operations	1	
478745	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Accumulated Fault Duty A Ph V	15.94	%
478746	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Accumulated Fault Duty B Ph V	17.54	%
478747	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Accumulated Fault Duty C Ph V	7.17	%
478748	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Amps A Ø	192.0	
478749	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
478750	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Door Alarms OK?	y	
478751	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
478752	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
478753	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
478754	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
478755	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
478756	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
478757	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
478758	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
478759	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
478760	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
478761	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
478762	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
478763	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
478764	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
478765	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Clear of Trash?	y	
478766	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
478767	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
478768	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
478769	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
478770	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
478771	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
478772	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	General Comments		
478773	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
478774	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
478775	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
478776	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
478777	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Totalizer Meter Reading	.7074	
478778	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
478779	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
478780	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Vegetation	None	
478781	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
478782	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
478783	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
478784	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
478785	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
478786	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
478787	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
478788	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
478789	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	General Comments		
478790	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
478791	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
478792	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
478793	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
478794	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Oil Temp Present	38	°C
478795	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Oil Temp Max	52	°C
478796	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
478797	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
478798	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	LTC Totalizer Reading	3395.52	kw
478799	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
478800	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	General Comments		
478801	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
478802	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
478803	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
478804	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
478805	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	General Comments		
478806	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
478807	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
478808	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
478809	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
478810	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Amps A Ø	380.0	
478811	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
478812	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
478813	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
478814	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	9 Month Operations	20	
478815	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Patrol Inspection	General Comments		
478816	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	VRR Time Delay	30	Seconds
478817	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
478818	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
478819	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
478820	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	LTC Operation Checked?	y	
478821	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	General Comments		
478822	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	Follow-up Action Required?	n	
478823	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	All Connections OK?	y	
478824	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	General Comments		
478825	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Maintenance Operations	0	
478826	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Operations Counter AF	1	
478827	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Operations Counter AL	1	
478828	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Operations This Read AM	0	
478829	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Switching Operations	0	
478830	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Unknown Operations	0	
478831	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Unknown Operations	0	
478832	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Tank Paint Condition	Good	
478833	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Switching Operations	0	
478834	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
478835	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Operations This Read Vac	0	
478836	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Operations Counter AL	176	
478837	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
478838	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
478839	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Trash Emptied?	n	
478840	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
478841	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
478842	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Panels Dusted?	y	
478843	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
478844	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
478845	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	General Comments		
478846	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
478847	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
478848	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Floor Swept?	n	
478849	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
478850	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
478851	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Evidence of Insects	None	
478852	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
478853	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
478854	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
478855	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
478856	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Broom on Site?	n	
478857	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
478858	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
478859	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Operations Counter AF	176	
478860	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Operations C Ø	0	
478861	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Operations Ground	0	
478862	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
478863	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Follow-up Action Required?	n	
478864	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Patrol Inspection	General Comments		
478865	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	General Comments		
478866	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
478867	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Maintenance Operations	0	
478868	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Operations Counter AF	540	
478869	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Operations Counter AL	540	
478870	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Operations This Read AM	0	
478871	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Switching Operations	0	
478872	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	PF000251	PowerFuse	ML-12KV TR 6 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
478873	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	PF000251	PowerFuse	ML-12KV TR 6 POT	Disconnect Powerfuse Inspection	General Comments	ok	
478874	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Unknown Operations	0	
478875	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Tank Paint Condition	Good	
478876	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Switching Operations	1	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
478877	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
478878	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Operations This Read Vac	1	
478879	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Operations Counter AL	49	
478880	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Operations Counter AF	49	
478881	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Moisture and Leak Free?	y	
478882	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Maintenance Operations	0	
478883	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Unknown Operations	0	
478884	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Heaters (All) Functioning?	y	
478885	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Grounds in Place?	y	
478886	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	General Comments		
478887	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
478888	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	78	°F
478889	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
478890	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
478891	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
478892	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
478893	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
478894	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	General Comments		
478895	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Foundation Condition	Good	
478896	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Follow-up Action Required?	n	
478897	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
478898	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Follow-up Action Required?	n	
478899	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Operations Ground	0	
478900	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Operations C Ø	0	
478901	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Operations B Ø	0	
478902	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Operations A Ø	0	
478903	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
478904	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
478905	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
478906	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Equipment Properly Labeled?	y	
478907	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Cabinet Paint Condition	Good	
478908	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
478909	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
478910	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
478911	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Bushings Connection/Risers	Good	
478912	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Bushing Condition	Good	
478913	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Amps C Ø	375.0	
478914	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Amps B Ø	320.0	
478915	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
478916	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Foundation Condition	Good	
478917	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Follow-up Action Required?	n	
478918	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Follow-up Action Required?	n	
478919	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Operations Ground	0	
478920	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Operations C Ø	0	
478921	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Operations B Ø	0	
478922	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
478923	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Regulator As Left Counter	51663	
478924	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
478925	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
478926	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
478927	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
478928	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
478929	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Min Tap Position	16L	
478930	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
478931	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
478932	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	General Comments		
478933	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
478934	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
478935	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
478936	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
478937	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Current Tap Position	10L	
478938	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
478939	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
478940	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
478941	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
478942	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Operations A Ø	0	
478943	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
478944	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
478945	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
478946	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
478947	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Equipment Properly Labeled?	y	
478948	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
478949	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Clear of Trash?	y	
478950	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
478951	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
478952	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
478953	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
478954	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
478955	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Bushings Connection/Risers	Good	
478956	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Bushing Condition	Good	
478957	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Amps C Ø	530.0	
478958	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
478959	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
478960	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
478961	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
478962	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
478963	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	General Comments		
478964	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
478965	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
478966	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Amps B Ø	580.0	
478967	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Vegetation	None	
478968	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Amps A Ø	500.0	
478969	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
478970	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
478971	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
478972	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Maintenance Operations	0	
478973	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
478974	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Grounds in Place?	y	
478975	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	General Comments		
478976	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	General Comments		
478977	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Foundation Condition	Good	
478978	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Follow-up Action Required?	n	
478979	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Follow-up Action Required?	n	
478980	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Operations Ground	0	
478981	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Operations C Ø	0	
478982	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Operations B Ø	0	
478983	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Operations A Ø	0	
478984	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
478985	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
478986	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
478987	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
478988	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
478989	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
478990	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
478991	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
478992	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
478993	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Bushing Condition	Good	
478994	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Amps C Ø	190.0	
478995	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Amps B Ø	190.0	
478996	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Amps A Ø	190.0	
478997	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
478998	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
478999	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
479000	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	9 Month Operations	1	
479001	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.300	millivolts
479002	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	25.3	VDC
479003	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	25.3	VDC
479004	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
479005	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
479006	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
479007	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	General Comments		
479008	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
479009	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
479010	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
479011	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
479012	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Tank Leaks	None	
479013	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
479014	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Unknown Operations	0	
479015	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Tank Paint Condition	Good	
479016	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Switching Operations	0	
479017	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
479018	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Operations This Read Vac	0	
479019	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Operations Counter AL	87	
479020	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Operations Counter AF	87	
479021	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Moisture and Leak Free?	y	
479022	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Maintenance Operations	0	
479023	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Heaters (All) Functioning?	y	
479024	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Grounds in Place?	y	
479025	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	General Comments		
479026	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
479027	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
479028	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	LTC Totalizer Reading	8985.60	kw
479029	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
479030	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
479031	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Oil Temp Max	70	°C
479032	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
479033	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
479034	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
479035	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
479036	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
479037	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
479038	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
479039	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
479040	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Totalizer Meter Reading	1.1232	
479041	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
479042	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
479043	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	140.0	
479044	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	140.0	
479045	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	140.0	
479046	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
479047	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
479048	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
479049	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
479050	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
479051	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
479052	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
479053	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
479054	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Unknown Operations	0	
479055	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Switching Operations	0	
479056	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Operations This Read Vac	0	
479057	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Operations Counter AL	399	
479058	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Operations Counter AF	399	
479059	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Maintenance Operations	0	
479060	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	General Comments		
479061	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Patrol Inspection	General Comments		
479062	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Follow-up Action Required?	n	
479063	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Patrol Inspection	Follow-up Action Required?	n	
479064	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations Ground	0	
479065	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations C Ø	0	
479066	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
479067	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
479068	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	y	
479069	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
479070	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
479071	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Readings	General Comments		
479072	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments	possible crack in sight glass	
479073	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
479074	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
479075	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
479076	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
479077	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
479078	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
479079	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
479080	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
479081	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations B Ø	0	
479082	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
479083	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Tank Leaks	None	
479084	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
479085	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Unknown Operations	0	
479086	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
479087	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	PF000355	PowerFuse	TA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
479088	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Operations Counter AF	962	
479089	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Operations Counter AL	962	
479090	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Operations This Read AM	2	
479091	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Switching Operations	0	
479092	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Unknown Operations	0	
479093	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
479094	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
479095	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
479096	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	PF000355	PowerFuse	TA-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
479097	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
479098	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
479099	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
479100	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
479101	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
479102	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Current Tap Position	10L	
479103	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
479104	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
479105	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
479106	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
479107	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	General Comments		
479108	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
479109	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
479110	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Min Tap Position	16L	
479111	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
479112	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
479113	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
479114	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
479115	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
479116	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Regulator As Left Counter	36025	
479117	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
479118	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
479119	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Tank Leaks	None	
479120	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
479121	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
479122	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
479123	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
479124	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
479125	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
479126	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
479127	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
479128	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
479129	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
479130	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
479131	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
479132	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Follow-up Action Required?	n	
479133	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
479134	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
479135	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
479136	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	General Comments		
479137	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	General Comments	nests in radiators, need stick to remove. Left fans running for the summer	
479138	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
479139	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
479140	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
479141	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
479142	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
479143	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	9 Month Operations	8	
479144	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
479145	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
479146	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
479147	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
479148	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
479149	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
479150	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
479151	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
479152	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
479153	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
479154	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
479155	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
479156	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
479157	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
479158	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
479159	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
479160	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
479161	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
479162	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
479163	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
479164	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	45	°C
479165	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	45	°C
479166	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Unknown Operations	0	
479167	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Switching Operations	0	
479168	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Operations This Read AM	0	
479169	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Operations Counter AL	584	
479170	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Operations Counter AF	584	
479171	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Maintenance Operations	0	
479172	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
479173	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
479174	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
479175	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
479176	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
479177	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
479178	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
479179	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
479180	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
479181	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	40	°C
479182	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	111	
479183	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC Min Tap Position	4L	
479184	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6L	
479185	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
479186	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
479187	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC As Left Counter	410280	
479188	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC As Found Counter	410280	
479189	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
479190	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	General Comments		
479191	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
479192	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
479193	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations A Ø	0	
479194	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
479195	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
479196	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
479197	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
479198	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	6	
479199	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	75	
479200	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	75	
479201	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
479202	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
479203	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
479204	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	9 Months Operations	2	
479205	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
479206	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Patrol Inspection	Equipment Properly Labeled?	y	
479207	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Amps C Ø	238.0	
479208	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Amps B Ø	251.0	
479209	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	All Connections OK?	y	
479210	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Bushing Condition	Good	
479211	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
479212	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Capacitor Condition	Good	
479213	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
479214	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
479215	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Follow-up Action Required?	n	
479216	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	General Comments		
479217	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Grounds in Place?	y	
479218	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
479219	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Tank Leaks	None	
479220	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
479221	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
479222	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
479223	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Amps A Ø	150.0	
479224	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Amps B Ø	150.0	
479225	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Amps C Ø	150.0	
479226	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
479227	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
479228	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
479229	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
479230	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
479231	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
479232	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
479233	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
479234	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
479235	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
479236	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
479237	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
479238	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	General Comments		
479239	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
479240	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
479241	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Amps A Ø	261.0	
479242	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
479243	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
479244	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
479245	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
479246	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
479247	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
479248	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
479249	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
479250	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
479251	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
479252	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
479253	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Unknown Operations	0	
479254	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
479255	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
479256	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Amps A Ø	360.0	
479257	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Amps B Ø	420.0	
479258	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Amps C Ø	400.0	
479259	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
479260	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
479261	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Follow-up Action Required?	n	
479262	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Follow-up Action Required?	n	
479263	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Operations Ground	0	
479264	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Operations C Ø	0	
479265	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
479266	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
479267	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
479268	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
479269	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
479270	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
479271	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
479272	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
479273	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
479274	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
479275	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
479276	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
479277	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
479278	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
479279	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
479280	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
479281	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
479282	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
479283	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	159	
479284	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	159	
479285	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
479286	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
479287	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
479288	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
479289	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
479290	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Operations B Ø	0	
479291	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Operations A Ø	0	
479292	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
479293	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
479294	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
479295	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Equipment Properly Labeled?	y	
479296	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Cabinet Paint Condition	Good	
479297	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
479298	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
479299	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
479300	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
479301	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
479302	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations A Ø	0	
479303	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations B Ø	0	
479304	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
479305	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
479306	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Bushings Connection/Risers	Good	
479307	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Bushing Condition	Good	
479308	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Amps C Ø	91.0	
479309	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Amps B Ø	60.0	
479310	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Amps A Ø	86.0	
479311	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
479312	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
479313	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
479314	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	9 Month Operations	48	
479315	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
479316	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Cabinet Paint Condition	Good	
479317	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Equipment Properly Labeled?	y	
479318	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
479319	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
479320	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
479321	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Operations A Ø	0	
479322	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Operations B Ø	0	
479323	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Operations C Ø	0	
479324	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Operations Ground	0	
479325	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Follow-up Action Required?	n	
479326	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
479327	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Unknown Operations	0	
479328	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Tank Paint Condition	Good	
479329	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Switching Operations	0	
479330	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Operations This Read Vac	0	
479331	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Operations Counter AL	181	
479332	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Operations Counter AF	181	
479333	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Moisture and Leak Free?	y	
479334	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Maintenance Operations	0	
479335	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Grounds in Place?	y	
479336	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	General Comments		
479337	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	General Comments		
479338	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Foundation Condition	Good	
479339	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	General Comments		
479340	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	General Comments		
479341	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Grounds in Place?	y	
479342	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Maintenance Operations	0	
479343	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Moisture and Leak Free?	y	
479344	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Operations Counter AF	177	
479345	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Operations Counter AL	177	
479346	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Operations This Read Vac	0	
479347	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Switching Operations	0	
479348	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Tank Paint Condition	Good	
479349	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Foundation Condition	Good	
479350	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	9 Months Operations	4	
479351	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
479352	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
479353	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
479354	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
479355	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
479356	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
479357	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
479358	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
479359	4/10/2019 11:54	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
479360	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	9 Months Operations	65	
479361	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Accumulated Fault Duty A Ph AM	3.61	%
479362	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Accumulated Fault Duty B Ph AM	0	%
479363	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Accumulated Fault Duty C Ph AM	2.41	%
479364	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Amps A Ø	172.0	
479365	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Amps B Ø	144.0	
479366	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Amps C Ø	172.0	
479367	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
479368	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
479369	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
479370	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Amps A Ø	31.0	
479371	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
479372	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
479373	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
479374	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	9 Month Operations	1	
479375	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations Ground	0	
479376	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Patrol Inspection	Follow-up Action Required?	n	
479377	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Follow-up Action Required?	n	
479378	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Patrol Inspection	General Comments		
479379	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	General Comments		
479380	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Maintenance Operations	0	
479381	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Operations Counter AF	35	
479382	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Operations Counter AL	35	
479383	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Operations This Read AM	0	
479384	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Switching Operations	0	
479385	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Operations A Ø	1	
479386	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	PF000354	PowerFuse	TA-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
479387	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	PF000354	PowerFuse	TA-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
479388	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Operations B Ø	1	
479389	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Operations C Ø	0	
479390	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Operations Ground	0	
479391	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Follow-up Action Required?	n	
479392	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	General Comments	AB phase IOC	
479393	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Maintenance Operations	0	
479394	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
479395	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
479396	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
479397	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
479398	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
479399	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Current Tap Position	11L	
479400	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
479401	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
479402	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
479403	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
479404	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	General Comments		
479405	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
479406	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
479407	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Min Tap Position	15L	
479408	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
479409	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
479410	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
479411	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
479412	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
479413	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Regulator As Left Counter	61929	
479414	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
479415	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations C Ø	0	
479416	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Bushings Connection/Risers	Good	
479417	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
479418	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
479419	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
479420	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Bushing Condition	Good	
479421	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
479422	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Operations Since Last Insp	160	
479423	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
479424	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Min Tap Position	12L	
479425	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Max Tap Position	8L	
479426	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Current Tap Position	11L	
479427	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
479428	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC As Left Counter	13560	
479429	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC As Found Counter	13560	
479430	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	General Comments		
479431	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	General Comments		
479432	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
479433	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	Follow-up Action Required?	n	
479434	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Amps C Ø	29.0	
479435	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
479436	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
479437	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Winding Temp Max	35	°C
479438	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Totalizer Meter Reading	.1962	
479439	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
479440	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
479441	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
479442	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
479443	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
479444	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
479445	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
479446	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
479447	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Oil Temp Max	45	°C
479448	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
479449	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
479450	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	LTC Totalizer Reading	2825.28	kw
479451	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Amps B Ø	35.0	
479452	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
479453	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	General Comments		
479454	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	General Comments		
479455	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
479456	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
479457	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Follow-up Action Required?	n	
479458	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
479459	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
479460	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
479461	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
479462	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
479463	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
479464	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
479465	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
479466	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
479467	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
479468	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
479469	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
479470	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
479471	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
479472	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
479473	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
479474	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
479475	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
479476	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
479477	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Clear of Trash?	y	
479478	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
479479	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
479480	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
479481	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	General Comments		
479482	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC As Found Counter	56027	
479483	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC As Left Counter	56027	
479484	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
479485	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC Current Tap Position	8L	
479486	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC Max Tap Position	7L	
479487	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Unknown Operations	0	
479488	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Switching Operations	0	
479489	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Operations This Read AM	6	
479490	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Operations Counter AL	374	
479491	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Operations Counter AF	374	
479492	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Maintenance Operations	0	
479493	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	General Comments	A&B Phase IOC	
479494	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Patrol Inspection	General Comments		
479495	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Follow-up Action Required?	n	
479496	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Patrol Inspection	Follow-up Action Required?	n	
479497	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations Ground	0	
479498	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations C Ø	0	
479499	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations B Ø	3	
479500	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations A Ø	3	
479501	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
479502	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Adjusted Amps B Phase AM	33.54	
479503	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
479504	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
479505	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
479506	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Clear of Trash?	y	
479507	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC Min Tap Position	9L	
479508	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC Operations Since Last Insp	463	
479509	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
479510	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
479511	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
479512	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
479513	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
479514	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
479515	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	General Comments		
479516	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
479517	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Vegetation	None	
479518	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Adjusted Amps A Phase AM	33.54	
479519	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
479520	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Amps C Ø	400.0	
479521	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Amps B Ø	380.0	
479522	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Amps A Ø	400.0	
479523	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
479524	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
479525	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
479526	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
479527	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
479528	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
479529	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Vegetation	None	
479530	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
479531	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
479532	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
479533	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
479534	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Clear of Trash?	y	
479535	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
479536	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
479537	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
479538	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
479539	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
479540	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	General Comments		
479541	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
479542	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Vegetation	None	
479543	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
479544	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
479545	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
479546	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
479547	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
479548	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
479549	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
479550	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Foundation Condition	Good	
479551	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
479552	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
479553	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
479554	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
479555	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	General Comments		
479556	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
479557	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
479558	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
479559	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
479560	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
479561	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
479562	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
479563	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
479564	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Site Service Trans Condition	Exterior Stains	
479565	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
479566	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
479567	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
479568	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
479569	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Totalizer Meter Reading	.6924	
479570	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Winding Temp Max	40	°C
479571	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Winding Temp Present	35	°C
479572	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
479573	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
479574	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	Follow-up Action Required?	n	
479575	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
479576	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	General Comments		
479577	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
479578	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Vegetation	None	
479579	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
479580	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
479581	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	General Comments		
479582	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
479583	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
479584	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
479585	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
479586	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
479587	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
479588	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
479589	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
479590	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
479591	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Moisture and Leak Free?	y	
479592	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Maintenance Operations	0	
479593	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Heaters (All) Functioning?	y	
479594	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Grounds in Place?	y	
479595	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	General Comments		
479596	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	General Comments		
479597	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Foundation Condition	Good	
479598	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Follow-up Action Required?	n	
479599	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Follow-up Action Required?	n	
479600	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Operations Ground	0	
479601	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Operations C Ø	0	
479602	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Operations B Ø	0	
479603	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Operations A Ø	0	
479604	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
479605	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
479606	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
479607	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Equipment Properly Labeled?	y	
479608	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Cabinet Paint Condition	Good	
479609	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
479610	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
479611	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
479612	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Bushings Connection/Risers	Good	
479613	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
479614	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
479615	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	9 Month Operations	1	
479616	4/10/2019 15:56	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
479617	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	9 Month Operations	1	
479618	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
479619	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
479620	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	9 Months Operations	37	
479621	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
479622	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
479623	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Amps A Ø	200.0	
479624	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Amps B Ø	200.0	
479625	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Amps C Ø	200.0	
479626	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
479627	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
479628	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Amps A Ø	170.0	
479629	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Amps B Ø	140.0	
479630	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Amps C Ø	170.0	
479631	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
479632	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
479633	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
479634	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
479635	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Operations A Ø	0	
479636	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Operations B Ø	0	
479637	4/10/2019 11:02	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	9 Months Operations	6	
479638	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
479639	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
479640	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
479641	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
479642	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
479643	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Vegetation	None	
479644	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Exp Boom Corrected	
479645	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	General Comments		
479646	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
479647	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
479648	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
479649	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
479650	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
479651	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Clear of Trash?	y	
479652	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
479653	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Unknown Operations	0	
479654	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Tank Paint Condition	Good	
479655	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Switching Operations	0	
479656	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
479657	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Operations This Read Vac	0	
479658	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
479659	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	General Comments	barb wire is rusty, and top rail is getting rusty. Back left corner post needs replaced.	
479660	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
479661	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Ambient Temp	76	°F
479662	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
479663	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
479664	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
479665	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
479666	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
479667	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Operations Counter AL	79	
479668	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Operations Counter AF	79	
479669	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
479670	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	General Comments		
479671	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
479672	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
479673	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
479674	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
479675	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
479676	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
479677	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
479678	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
479679	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
479680	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
479681	4/10/2019 14:03	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
479682	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
479683	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
479684	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Foundation Condition	Good	
479685	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
479686	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
479687	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	General Comments		
479688	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
479689	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
479690	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
479691	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
479692	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
479693	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
479694	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
479695	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	LTCC000507	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
479696	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	LTCC000507	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
479697	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	LTCC000507	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
479698	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
479699	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
479700	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
479701	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Min Tap Position	8L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
479702	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
479703	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Oil Temp Max	45	°C
479704	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Oil Temp Present	40	°C
479705	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
479706	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
479707	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	General Comments		
479708	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
479709	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
479710	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
479711	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
479712	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
479713	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
479714	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
479715	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
479716	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
479717	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
479718	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	LTCC000507	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	122.0	VAC
479719	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	LTCC000507	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	122.0	VAC
479720	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	LTCC000507	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
479721	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
479722	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
479723	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
479724	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
479725	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
479726	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
479727	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
479728	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
479729	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
479730	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
479731	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
479732	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
479733	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
479734	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
479735	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
479736	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
479737	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
479738	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
479739	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
479740	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
479741	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
479742	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
479743	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
479744	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
479745	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
479746	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
479747	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
479748	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
479749	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	50	°C
479750	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
479751	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
479752	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
479753	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	General Comments		
479754	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
479755	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Follow-up Action Required?	n	
479756	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
479757	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
479758	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Patrol Inspection	General Comments		
479759	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	General Comments		
479760	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	General Comments		
479761	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
479762	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	LTC Totalizer Reading	9970.56	kw
479763	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Follow-up Action Required?	n	
479764	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
479765	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Operations Ground	0	
479766	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Operations C Ø	0	
479767	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Operations B Ø	0	
479768	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Operations A Ø	0	
479769	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
479770	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
479771	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
479772	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
479773	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Amps C Ø	120.0	
479774	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Amps B Ø	120.0	
479775	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Amps A Ø	100.0	
479776	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
479777	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
479778	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
479779	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	9 Months Operations	28	
479780	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Unknown Operations	0	
479781	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Tank Paint Condition	Good	
479782	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Switching Operations	0	
479783	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
479784	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Operations This Read Vac	0	
479785	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Operations Counter AL	450	
479786	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Operations Counter AF	450	
479787	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Tank Paint Condition	Adequate	
479788	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Tank Leaks	None	
479789	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
479790	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Regulator As Left Counter	350003	
479791	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
479792	4/10/2019 11:44	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
479793	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	LTCC000507	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
479794	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	LTCC000507	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
479795	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	LTCC000507	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
479796	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
479797	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Maintenance Operations	0	
479798	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
479799	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Grounds in Place?	y	
479800	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	General Comments		
479801	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	General Comments		
479802	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Foundation Condition	Good	
479803	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Follow-up Action Required?	n	
479804	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
479805	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
479806	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
479807	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
479808	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
479809	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
479810	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
479811	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
479812	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
479813	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Bushing Condition	Good	
479814	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Amps C Ø	320.0	
479815	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Amps B Ø	320.0	
479816	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Amps A Ø	320.0	
479817	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
479818	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
479819	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
479820	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
479821	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
479822	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
479823	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
479824	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
479825	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Clear of Trash?	y	
479826	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
479827	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
479828	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
479829	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
479830	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
479831	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
479832	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	General Comments		
479833	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	General Comments		
479834	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
479835	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
479836	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
479837	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
479838	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	Oil Temp Max	60	°C
479839	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	Oil Temp Present	40	°C
479840	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
479841	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
479842	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
479843	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
479844	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
479845	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
479846	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
479847	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
479848	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	All Connections OK?	y	
479849	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
479850	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
479851	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
479852	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	70	°C
479853	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	40	°C
479854	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	60	°C
479855	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	40	°C
479856	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	60	°C
479857	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	40	°C
479858	4/10/2019 14:16	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
479859	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
479860	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
479861	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC Operations Since Last Insp	774	
479862	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
479863	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
479864	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC Min Tap Position	16L	
479865	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC Max Tap Position	8R	
479866	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC Current Tap Position	5L	
479867	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
479868	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC As Left Counter	49880	
479869	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
479870	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
479871	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
479872	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
479873	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Follow-up Action Required?	n	
479874	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
479875	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
479876	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	General Comments		
479877	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	General Comments		
479878	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
479879	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	LTC Totalizer Reading	10166.40	kw
479880	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC As Found Counter	49870	
479881	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	General Comments		
479882	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	General Comments		
479883	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
479884	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
479885	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
479886	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Oil Temp Max	45	°C
479887	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Oil Temp Present	40	°C
479888	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
479889	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
479890	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
479891	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
479892	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
479893	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
479894	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
479895	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
479896	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Totalizer Meter Reading	.7060	
479897	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Winding Temp Max	45	°C
479898	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Winding Temp Present	40	°C
479899	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
479900	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
479901	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	VRR Time Delay	60	Seconds
479902	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
479903	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
479904	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
479905	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
479906	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	LTC Operation Checked?	n	
479907	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	General Comments	Substation is deenergized for transmission work	
479908	4/10/2019 13:54	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	Follow-up Action Required?	n	
479909	4/10/2019 12:49	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	Follow-up Action Required?	n	
479910	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Follow-up Action Required?	n	
479911	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Operations Ground	0	
479912	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Operations C Ø	0	
479913	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Operations B Ø	0	
479914	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Operations A Ø	0	
479915	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
479916	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
479917	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	VRR Time Delay	30	Seconds
479918	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	General Comments		
479919	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Follow-up Action Required?	n	
479920	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	Follow-up Action Required?	n	
479921	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	All Connections OK?	y	
479922	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
479923	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	General Comments	remove grnd lghts and alarm queston	
479924	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	y	
479925	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
479926	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
479927	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Operations Ground	0	
479928	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Operations C Ø	0	
479929	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Switching Operations	0	
479930	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Operations This Read Vac	1	
479931	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Operations Counter AL	197	
479932	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Operations Counter AF	197	
479933	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Operations B Ø	0	
479934	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
479935	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
479936	4/10/2019 12:36	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
479937	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Operations A Ø	0	
479938	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
479939	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
479940	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
479941	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Amps C Ø	195.0	
479942	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Amps B Ø	207.0	
479943	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Maintenance Operations	0	
479944	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LTCC000335	LTCControl	TA-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
479945	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LTCC000335	LTCControl	TA-TRANS 3	LTC Control Insp	General Comments		
479946	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
479947	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
479948	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
479949	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	n	If no, which cells in comments
479950	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
479951	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
479952	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
479953	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
479954	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
479955	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	y	
479956	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	corrosion on battery #1 positive post.	
479957	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
479958	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
479959	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
479960	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
479961	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
479962	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
479963	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
479964	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
479965	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
479966	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
479967	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
479968	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
479969	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LTCC000335	LTCControl	TA-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
479970	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
479971	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
479972	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
479973	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	All Connections OK?	y	
479974	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LTCC000336	LTCControl	TA-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
479975	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	Follow-up Action Required?	n	
479976	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	General Comments		
479977	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	LTC Operation Checked?	y	
479978	4/10/2019 10:58	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
479979	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LTCC000336	LTCControl	TA-TRANS 1	LTC Control Insp	General Comments		
479980	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	General Comments		
479981	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	LTC Operation Checked?	y	
479982	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
479983	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
479984	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
479985	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
479986	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
479987	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
479988	4/10/2019 11:35	Distribution	Taylor Quarterly Inspection	LTCC000336	LTCControl	TA-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
479989	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
479990	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
479991	4/10/2019 16:00	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
479992	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
479993	4/10/2019 10:18	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	VRR Time Delay	60	Seconds
479994	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Unknown Operations	1	
479995	4/10/2019 9:47	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
479996	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
479997	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC Operations Since Last Insp	697	
479998	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC Min Tap Position	4L	
479999	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
480000	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
480001	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC Max Tap Position	2R	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
480002	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC Current Tap Position	2L	
480003	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
480004	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC As Left Counter	189860	
480005	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC As Found Counter	189860	
480006	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	General Comments		
480007	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	General Comments		
480008	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
480009	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Oil Temp Present	40	°C
480010	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Oil Temp Max	40	°C
480011	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
480012	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
480013	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
480014	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
480015	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Tank Leaks	None	
480016	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
480017	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
480018	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Regulator As Left Counter	114374	
480019	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
480020	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
480021	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
480022	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
480023	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
480024	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
480025	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	General Comments		
480026	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
480027	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
480028	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
480029	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
480030	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
480031	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
480032	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
480033	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	General Comments		
480034	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Winding Temp Present	40	°C
480035	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
480036	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Winding Temp Max	45	°C
480037	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
480038	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Totalizer Meter Reading	.4900	
480039	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
480040	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
480041	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
480042	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
480043	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
480044	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
480045	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
480046	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
480047	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
480048	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
480049	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
480050	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
480051	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
480052	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
480053	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
480054	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
480055	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
480056	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
480057	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Min Tap Position	9L	
480058	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Max Tap Position	1L	
480059	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
480060	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	General Comments		
480061	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
480062	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
480063	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
480064	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
480065	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
480066	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
480067	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	9782.40	kw
480068	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
480069	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
480070	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
480071	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
480072	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	General Comments		
480073	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
480074	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
480075	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
480076	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
480077	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
480078	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
480079	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
480080	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
480081	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
480082	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	72	°F
480083	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
480084	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
480085	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
480086	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
480087	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
480088	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
480089	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
480090	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
480091	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
480092	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
480093	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	General Comments		
480094	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	General Comments		
480095	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
480096	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
480097	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
480098	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
480099	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
480100	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
480101	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
480102	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
480103	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
480104	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
480105	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
480106	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
480107	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
480108	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Follow-up Action Required?	n	
480109	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
480110	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
480111	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
480112	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	General Comments		
480113	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	General Comments		
480114	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
480115	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
480116	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
480117	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
480118	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
480119	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
480120	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
480121	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
480122	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
480123	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
480124	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	LTC Totalizer Reading	5057.28	kw
480125	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
480126	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Follow-up Action Required?	n	
480127	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Follow-up Action Required?	n	
480128	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Operations Ground	0	
480129	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Operations C Ø	0	
480130	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Operations B Ø	0	
480131	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Operations A Ø	0	
480132	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
480133	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
480134	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
480135	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
480136	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
480137	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Unknown Operations	0	
480138	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Tank Paint Condition	Good	
480139	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Switching Operations	7	
480140	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Operations This Read Vac	7	
480141	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Operations Counter AL	329	
480142	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Operations Counter AF	329	
480143	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
480144	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
480145	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
480146	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
480147	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
480148	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Moisture and Leak Free?	y	
480149	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
480150	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
480151	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.7	amps

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
480152	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
480153	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
480154	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
480155	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	General Comments		
480156	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Maintenance Operations	0	
480157	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Heaters (All) Functioning?	y	
480158	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Grounds in Place?	y	
480159	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	General Comments		
480160	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	General Comments		
480161	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Foundation Condition	Good	
480162	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Follow-up Action Required?	n	
480163	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Follow-up Action Required?	n	
480164	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
480165	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
480166	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Clear of Trash?	y	
480167	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
480168	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
480169	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	General Comments		
480170	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC As Found Counter	5250	
480171	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
480172	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
480173	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC As Left Counter	5250	
480174	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
480175	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Operations Ground	0	
480176	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Operations C Ø	0	
480177	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Operations B Ø	0	
480178	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Operations A Ø	0	
480179	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
480180	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
480181	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
480182	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Equipment Properly Labeled?	y	
480183	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Cabinet Paint Condition	Good	
480184	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
480185	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
480186	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
480187	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
480188	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	General Comments		
480189	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
480190	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
480191	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
480192	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Vegetation	None	
480193	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
480194	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
480195	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
480196	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
480197	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Bushings Connection/Risers	Good	
480198	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Bushing Condition	Good	
480199	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Amps C Ø	50.0	
480200	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Amps B Ø	50.0	
480201	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Amps A Ø	50.0	
480202	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
480203	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
480204	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
480205	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	Follow-up Action Required?	n	
480206	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
480207	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
480208	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
480209	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
480210	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
480211	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
480212	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1260.00	kw
480213	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
480214	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
480215	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
480216	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	General Comments		
480217	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	General Comments		
480218	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
480219	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
480220	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
480221	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
480222	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
480223	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	1	
480224	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	671	
480225	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	671	
480226	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
480227	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
480228	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	1	
480229	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
480230	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
480231	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	General Comments		
480232	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
480233	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
480234	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	71	°F
480235	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
480236	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
480237	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
480238	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
480239	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
480240	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
480241	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
480242	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
480243	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	General Comments		
480244	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
480245	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
480246	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
480247	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
480248	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
480249	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
480250	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
480251	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
480252	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
480253	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
480254	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
480255	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
480256	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
480257	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
480258	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
480259	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
480260	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
480261	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
480262	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
480263	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
480264	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
480265	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
480266	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
480267	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
480268	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
480269	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
480270	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
480271	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
480272	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
480273	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Operations Counter AF	224	
480274	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Moisture and Leak Free?	y	
480275	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Maintenance Operations	0	
480276	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Heaters (All) Functioning?	y	
480277	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Grounds in Place?	y	
480278	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	General Comments		
480279	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	General Comments		
480280	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Foundation Condition	Good	
480281	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Foundation Condition	Good	
480282	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Follow-up Action Required?	n	
480283	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Follow-up Action Required?	n	
480284	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Operations Ground	0	
480285	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Operations C Ø	0	
480286	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Operations B Ø	0	
480287	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Operations A Ø	0	
480288	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
480289	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Operations B Ø	0	
480290	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Operations C Ø	0	
480291	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Operations Ground	0	
480292	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Follow-up Action Required?	n	
480293	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
480294	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Follow-up Action Required?	n	
480295	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Foundation Condition	Good	
480296	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	General Comments		
480297	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	General Comments		
480298	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Grounds in Place?	y	
480299	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Tank Paint Condition	Good	
480300	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Heaters (All) Functioning?	y	
480301	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
480302	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
480303	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
480304	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
480305	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
480306	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Equipment Properly Labeled?	y	
480307	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	86	
480308	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	86	
480309	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Bushing Condition	Good	
480310	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
480311	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
480312	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
480313	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Foundation Condition	Good	
480314	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
480315	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	General Comments		
480316	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
480317	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
480318	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Grounds in Place?	y	
480319	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
480320	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Radiator Leaks	None	
480321	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
480322	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Tank Leaks	None	
480323	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
480324	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
480325	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
480326	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
480327	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Unknown Operations	0	
480328	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Tank Paint Condition	Good	
480329	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Switching Operations	1	
480330	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
480331	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Operations This Read Vac	1	
480332	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Pressure Acceptable?	y	
480333	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Oil Levels OK?	y	
480334	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Leaks	None	
480335	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
480336	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
480337	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
480338	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
480339	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
480340	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	General Comments		
480341	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
480342	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
480343	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
480344	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
480345	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
480346	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
480347	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Cabinet Paint Condition	Good	
480348	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
480349	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
480350	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
480351	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
480352	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
480353	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
480354	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
480355	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
480356	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
480357	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
480358	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	General Comments		
480359	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
480360	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Operations C Ø	0	
480361	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Operations Ground	0	
480362	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Follow-up Action Required?	n	
480363	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Follow-up Action Required?	n	
480364	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Foundation Condition	Good	
480365	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	General Comments		
480366	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	General Comments		
480367	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Grounds in Place?	y	
480368	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Maintenance Operations	0	
480369	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Moisture and Leak Free?	y	
480370	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Operations Counter AF	209	
480371	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Operations Counter AL	209	
480372	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
480373	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
480374	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Broom on Site?	y	
480375	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Control House Lighting OK?	y	
480376	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
480377	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Door Alarms OK?	y	
480378	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Doors and Locks Secure?	y	
480379	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Evidence of Insects	None	
480380	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
480381	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Floor Condition Acceptable?	y	
480382	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Floor Swept?	y	
480383	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Operations This Read Vac	1	
480384	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
480385	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
480386	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
480387	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
480388	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Follow-up Action Required?	n	
480389	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
480390	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	General Comments		
480391	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Moisture and Leak Free?	y	
480392	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Panel Lights OK?	y	
480393	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Panels Dusted?	y	
480394	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Station Ground Set On Site?	y	
480395	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Switch Diagram Present/Current	y	
480396	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Trash Emptied?	y	
480397	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Ventilation Free of Debris?	y	
480398	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
480399	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	General Comments		
480400	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
480401	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
480402	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
480403	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Vegetation	None	
480404	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
480405	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	BCH000586	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
480406	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Unknown Operations	0	
480407	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Tank Paint Condition	Good	
480408	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Switching Operations	10	
480409	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
480410	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Operations This Read Vac	10	
480411	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Operations Counter AL	199	
480412	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Operations Counter AF	199	
480413	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Switching Operations	1	
480414	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Moisture and Leak Free?	y	
480415	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Maintenance Operations	0	
480416	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Heaters (All) Functioning?	y	
480417	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Grounds in Place?	y	
480418	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	General Comments		
480419	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	General Comments		
480420	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
480421	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
480422	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Tank Paint Condition	Good	
480423	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Tank Oil Level	Good	
480424	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Tank Leaks	None	
480425	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
480426	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Moisture and Leak Free?	y	
480427	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Grounds in Place?	y	
480428	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	General Comments		
480429	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Foundation Condition	Good	
480430	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Follow-up Action Required?	n	
480431	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Equipment Properly Labeled?	y	
480432	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
480433	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
480434	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Operations A Ø	0	
480435	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	2	
480436	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
480437	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
480438	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
480439	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	General Comments		
480440	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
480441	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
480442	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Maintenance Operations	0	
480443	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
480444	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Operations Counter AF	187	
480445	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Operations Counter AL	188	
480446	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Operations This Read Vac	4	
480447	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Accumulated Fault Duty B Ph V	11.93	%
480448	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Accumulated Fault Duty A Ph V	7.16	%
480449	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
480450	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
480451	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
480452	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
480453	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
480454	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
480455	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
480456	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
480457	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
480458	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	9 Month Operations	12	
480459	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
480460	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
480461	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
480462	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
480463	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
480464	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
480465	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
480466	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
480467	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
480468	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
480469	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
480470	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
480471	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
480472	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Tank Leaks	None	
480473	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BCH000583	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
480474	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Switching Operations	4	
480475	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
480476	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Unknown Operations	0	
480477	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Bushings Connection/Risers	Good	
480478	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BCH000583	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
480479	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BCH000583	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
480480	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
480481	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Bushing Condition	Good	
480482	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BCH000583	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
480483	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BCH000583	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
480484	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BCH000583	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
480485	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	BCH000581	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
480486	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	BCH000581	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
480487	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	BCH000581	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
480488	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
480489	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5250	
480490	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
480491	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Foundation Condition	Good	
480492	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Regulator As Left Counter	130138	
480493	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
480494	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Oil Temp Present	50	°C
480495	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
480496	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
480497	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
480498	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
480499	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
480500	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
480501	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
480502	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
480503	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
480504	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
480505	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
480506	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
480507	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
480508	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Unknown Operations	0	
480509	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	BCH000581	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
480510	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	BCH000581	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC
480511	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	BCH000581	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
480512	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
480513	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
480514	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
480515	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
480516	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
480517	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
480518	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
480519	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Foundation Condition	Good	
480520	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
480521	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Maintenance Operations	0	
480522	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Moisture and Leak Free?	y	
480523	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Operations Counter AF	218	
480524	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
480525	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
480526	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
480527	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
480528	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
480529	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
480530	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Operations Counter AL	218	
480531	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Operations This Read Vac	2	
480532	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
480533	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Cabinet Paint Condition	Good	
480534	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
480535	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
480536	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
480537	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Switching Operations	2	
480538	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Tank Paint Condition	Good	
480539	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
480540	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
480541	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
480542	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
480543	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
480544	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
480545	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Totalizer Meter Reading	.5268	
480546	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Bushings Connection/Risers	Good	
480547	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	General Comments		
480548	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
480549	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Unknown Operations	0	
480550	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
480551	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Bushing Condition	Good	
480552	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Amps C Ø	61.0	
480553	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
480554	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Operations Counter AL	224	
480555	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Tank Leaks	None	
480556	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
480557	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
480558	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Regulator As Left Counter	42318	
480559	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
480560	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
480561	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
480562	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Amps B Ø	59.0	
480563	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	9 Month Operations	6	
480564	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
480565	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
480566	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
480567	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BCH000583	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
480568	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
480569	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
480570	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Amps A Ø	0.0	
480571	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Amps B Ø	0.0	
480572	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Amps C Ø	0.0	
480573	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
480574	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
480575	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Amps A Ø	59.0	
480576	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Accumulated Fault Duty C Ph V	7.75	%
480577	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
480578	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
480579	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
480580	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
480581	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
480582	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
480583	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
480584	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
480585	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Operations A Ø	0	
480586	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Operations B Ø	0	
480587	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Operations C Ø	0	
480588	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Operations Ground	0	
480589	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0190	
480590	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
480591	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
480592	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
480593	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
480594	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
480595	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Follow-up Action Required?	n	
480596	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
480597	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	General Comments		
480598	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
480599	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	General Comments		
480600	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
480601	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
480602	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
480603	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
480604	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
480605	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
480606	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
480607	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
480608	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Cabinet Paint Condition	Good	
480609	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Equipment Properly Labeled?	y	
480610	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
480611	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
480612	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
480613	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
480614	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
480615	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Cabinet Paint Condition	Good	
480616	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Equipment Properly Labeled?	y	
480617	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Adjusted Amps A Phase V	13.61	
480618	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
480619	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
480620	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC Operations Since Last Insp	618	
480621	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
480622	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC Min Tap Position	10L	
480623	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC Max Tap Position	2L	
480624	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC Current Tap Position	5L	
480625	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
480626	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC As Left Counter	56004	
480627	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC As Found Counter	56001	
480628	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	General Comments		
480629	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
480630	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
480631	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
480632	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
480633	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
480634	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
480635	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Cabinet Paint Condition	Good	
480636	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Equipment Properly Labeled?	y	
480637	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
480638	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
480639	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
480640	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Operations A Ø	0	
480641	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Operations B Ø	0	
480642	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Operations C Ø	0	
480643	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Operations Ground	0	
480644	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Follow-up Action Required?	n	
480645	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Follow-up Action Required?	n	
480646	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Foundation Condition	Good	
480647	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	General Comments		
480648	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	General Comments		
480649	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Grounds in Place?	y	
480650	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Heaters (All) Functioning?	y	
480651	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Maintenance Operations	0	
480652	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Moisture and Leak Free?	y	
480653	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Operations Counter AF	266	
480654	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Operations Counter AL	266	
480655	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Operations This Read Vac	0	
480656	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Switching Operations	0	
480657	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Tank Paint Condition	Good	
480658	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
480659	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
480660	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
480661	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pop-off Valve Tested Date	2019-01-22 00:00:00.000000	
480662	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	2	
480663	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	410	
480664	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	410	
480665	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
480666	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
480667	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	General Comments		
480668	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
480669	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	Follow-up Action Required?	n	
480670	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
480671	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
480672	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
480673	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
480674	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
480675	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
480676	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Current Tap Position	5L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
480677	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
480678	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
480679	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
480680	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
480681	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	General Comments		
480682	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
480683	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Max Tap Position	1L	
480684	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Min Tap Position	9L	
480685	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
480686	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
480687	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
480688	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
480689	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
480690	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Regulator As Left Counter	43019	
480691	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
480692	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
480693	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Tank Leaks	None	
480694	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
480695	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	BCH000594	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
480696	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	BCH000594	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
480697	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
480698	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
480699	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
480700	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
480701	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
480702	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	74	°F
480703	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
480704	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
480705	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
480706	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
480707	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
480708	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
480709	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
480710	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
480711	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
480712	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
480713	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	BCH000594	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
480714	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	BCH000594	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
480715	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
480716	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
480717	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
480718	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
480719	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	9 Month Operations	13	
480720	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
480721	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
480722	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
480723	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
480724	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
480725	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
480726	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
480727	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
480728	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
480729	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Follow-up Action Required?	n	
480730	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
480731	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
480732	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	9 Month Operations	4	
480733	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
480734	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
480735	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
480736	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Amps A Ø	160.0	
480737	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Amps B Ø	160.0	
480738	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Amps C Ø	160.0	
480739	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Bushing Condition	Good	
480740	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Bushings Connection/Risers	Good	
480741	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
480742	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
480743	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	General Comments		
480744	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	General Comments		
480745	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
480746	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	LTC Totalizer Reading	10425.60	kw
480747	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
480748	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Amps A Ø	360.0	
480749	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Amps B Ø	360.0	
480750	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Amps C Ø	360.0	
480751	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
480752	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Bushings Connection/Risers	Good	
480753	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
480754	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
480755	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
480756	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
480757	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
480758	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	General Comments	ONLY ONE BANK OF FANS WILL RUN	
480759	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	General Comments		
480760	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
480761	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
480762	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
480763	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
480764	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
480765	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
480766	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	2	
480767	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
480768	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Winding Temp Max	40	°C
480769	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Winding Temp Present	40	°C
480770	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
480771	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
480772	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
480773	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	General Comments		
480774	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
480775	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
480776	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
480777	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
480778	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
480779	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
480780	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
480781	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
480782	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	General Comments		
480783	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
480784	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
480785	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
480786	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
480787	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
480788	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Unknown Operations	0	
480789	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
480790	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
480791	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
480792	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
480793	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
480794	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
480795	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
480796	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
480797	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
480798	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
480799	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
480800	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
480801	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
480802	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
480803	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
480804	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
480805	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
480806	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
480807	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Clear of Trash?	y	
480808	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
480809	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
480810	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
480811	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
480812	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
480813	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
480814	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
480815	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	General Comments		
480816	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
480817	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
480818	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Vegetation	None	
480819	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
480820	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Tank Paint Condition	Good	
480821	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Switching Operations	5	
480822	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Switching Operations	4	
480823	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
480824	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
480825	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Operations This Read Vac	5	
480826	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
480827	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
480828	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
480829	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
480830	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
480831	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
480832	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
480833	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
480834	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
480835	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
480836	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
480837	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
480838	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
480839	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
480840	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
480841	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
480842	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	General Comments		
480843	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
480844	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
480845	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Foundation Condition	Good	
480846	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Equipment Properly Labeled?	y	
480847	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Cabinet Paint Condition	Good	
480848	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
480849	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1800	psi
480850	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
480851	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
480852	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
480853	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
480854	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
480855	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
480856	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
480857	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
480858	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
480859	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
480860	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
480861	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
480862	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
480863	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
480864	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
480865	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	General Comments		
480866	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
480867	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
480868	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
480869	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
480870	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Top Oil Temperature Max	40	°C
480871	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
480872	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Totalizer Meter Reading	.7240	
480873	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
480874	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
480875	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
480876	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
480877	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
480878	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
480879	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
480880	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Unknown Operations	0	
480881	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
480882	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Bushings Connection/Risers	Good	
480883	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Bushing Condition	Good	
480884	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Regulator As Left Counter	93725	
480885	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
480886	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
480887	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Tank Leaks	None	
480888	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
480889	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Amps C Ø	0.0	
480890	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Amps B Ø	0.0	
480891	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Amps A Ø	0.0	
480892	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
480893	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
480894	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
480895	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	9 Month Operations	4	
480896	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
480897	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
480898	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
480899	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
480900	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
480901	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
480902	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
480903	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
480904	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	BCH000594	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
480905	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	BCH000594	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
480906	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
480907	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
480908	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Bushing Condition	Good	
480909	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Amps C Ø	0.0	
480910	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Amps B Ø	0.0	
480911	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Amps A Ø	0.0	
480912	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
480913	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	Follow-up Action Required?	n	
480914	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
480915	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
480916	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	PF000042	PowerFuse	BR-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
480917	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	PF000042	PowerFuse	BR-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
480918	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	9 Month Operations	4	
480919	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
480920	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
480921	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC Current Tap Position	8L	
480922	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Amps C Ø	0.0	
480923	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Bushing Condition	Good	
480924	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
480925	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
480926	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
480927	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
480928	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
480929	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
480930	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
480931	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
480932	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
480933	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
480934	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
480935	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
480936	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
480937	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC Max Tap Position	3L	
480938	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC Min Tap Position	12L	
480939	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC Operations Since Last Insp	393	
480940	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
480941	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
480942	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
480943	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
480944	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
480945	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
480946	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC Operations Since Last Insp	487	
480947	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
480948	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC Min Tap Position	10L	
480949	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC Max Tap Position	1L	
480950	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC Current Tap Position	6L	
480951	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
480952	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC Max Tap Position	1R	
480953	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC Min Tap Position	8L	
480954	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
480955	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
480956	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Current Tap Position	5L	
480957	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
480958	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
480959	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
480960	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
480961	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
480962	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Vegetation	None	
480963	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
480964	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
480965	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	General Comments		
480966	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
480967	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
480968	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC As Left Counter	4217	
480969	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC As Found Counter	4215	
480970	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	General Comments		
480971	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	General Comments		
480972	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
480973	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
480974	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
480975	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
480976	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
480977	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Operations B Ø	0	
480978	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Operations C Ø	0	
480979	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Operations Ground	0	
480980	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
480981	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	Follow-up Action Required?	n	
480982	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
480983	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
480984	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
480985	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
480986	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
480987	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	9 Month Operations	9	
480988	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Unknown Operations	0	
480989	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Tank Paint Condition	Good	
480990	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Switching Operations	10	
480991	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
480992	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
480993	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
480994	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
480995	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Operations This Read Vac	10	
480996	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Operations Counter AL	208	
480997	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
480998	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
480999	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
481000	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
481001	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
481002	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
481003	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Foundation Condition	Good	
481004	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
481005	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
481006	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	General Comments		
481007	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
481008	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
481009	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
481010	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
481011	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
481012	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
481013	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
481014	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
481015	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
481016	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
481017	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
481018	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
481019	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Operations Counter AF	208	
481020	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Moisture and Leak Free?	y	
481021	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Maintenance Operations	0	
481022	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Heaters (All) Functioning?	y	
481023	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
481024	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
481025	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
481026	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1161	
481027	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1161	
481028	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	11	
481029	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
481030	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
481031	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
481032	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
481033	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
481034	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Grounds in Place?	y	
481035	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	General Comments		
481036	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	General Comments		
481037	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Foundation Condition	Good	
481038	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Follow-up Action Required?	n	
481039	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Follow-up Action Required?	n	
481040	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Operations Ground	0	
481041	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Operations C Ø	0	
481042	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	9 Month Operations	4	
481043	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
481044	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
481045	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
481046	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	VRR Time Delay	30	Seconds
481047	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
481048	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
481049	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
481050	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	LTC Operation Checked?	y	
481051	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
481052	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	Follow-up Action Required?	n	
481053	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	All Connections OK?	y	
481054	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
481055	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Amps A Ø	0.0	
481056	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Amps B Ø	0.0	
481057	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Equipment Properly Labeled?	y	
481058	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Cabinet Paint Condition	Good	
481059	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
481060	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
481061	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
481062	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Bushings Connection/Risers	Good	
481063	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
481064	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
481065	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
481066	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	General Comments		
481067	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
481068	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Switching Operations	1	
481069	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
481070	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Operations This Read Vac	1	
481071	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Operations Counter AL	223	
481072	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
481073	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
481074	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	General Comments		
481075	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
481076	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
481077	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
481078	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
481079	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	VRR Time Delay	30	Seconds
481080	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
481081	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
481082	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
481083	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
481084	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
481085	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
481086	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Operations Counter AF	223	
481087	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Moisture and Leak Free?	y	
481088	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Unknown Operations	0	
481089	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Tank Paint Condition	Good	
481090	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Oil Temp Present	35	°C
481091	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Oil Temp Max	45	°C
481092	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
481093	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	General Comments		
481094	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
481095	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
481096	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
481097	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
481098	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
481099	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Maintenance Operations	0	
481100	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Heaters (All) Functioning?	y	
481101	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Grounds in Place?	y	
481102	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	General Comments		
481103	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	General Comments		
481104	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Foundation Condition	Good	
481105	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Follow-up Action Required?	n	
481106	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Follow-up Action Required?	n	
481107	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Operations Ground	0	
481108	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Operations C Ø	0	
481109	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
481110	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	LTC Totalizer Reading	7056.00	kw
481111	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
481112	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	General Comments		
481113	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Operations B Ø	0	
481114	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Operations A Ø	0	
481115	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
481116	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
481117	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
481118	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	General Comments		
481119	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
481120	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
481121	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
481122	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
481123	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
481124	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
481125	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
481126	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
481127	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
481128	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
481129	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
481130	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
481131	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
481132	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Follow-up Action Required?	n	
481133	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
481134	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
481135	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
481136	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
481137	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
481138	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
481139	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
481140	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
481141	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
481142	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
481143	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
481144	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Follow-up Action Required?	n	
481145	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Follow-up Action Required?	n	
481146	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Foundation Condition	Good	
481147	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	General Comments		
481148	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	General Comments		
481149	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Grounds in Place?	y	
481150	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
481151	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Maintenance Operations	0	
481152	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
481153	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Operations Counter AF	257	
481154	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Operations Counter AL	257	
481155	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
481156	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
481157	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
481158	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Operations This Read Vac	2	
481159	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Switching Operations	2	
481160	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Tank Paint Condition	Good	
481161	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Unknown Operations	0	
481162	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
481163	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
481164	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
481165	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	All Lights Functioning?	y	
481166	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
481167	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Tank Paint Condition	Good	
481168	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Moisture and Leak Free?	y	
481169	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Heaters (All) Functioning?	y	
481170	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Grounds in Place?	y	
481171	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	General Comments		
481172	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Foundation Condition	Good	
481173	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Operations B Ø	0	
481174	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Operations A Ø	0	
481175	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
481176	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
481177	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
481178	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Equipment Properly Labeled?	y	
481179	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Cabinet Paint Condition	Good	
481180	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
481181	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
481182	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
481183	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Bushings Connection/Risers	Good	
481184	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Bushing Condition	Good	
481185	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Amps C Ø	136.0	
481186	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
481187	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
481188	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
481189	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
481190	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
481191	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
481192	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
481193	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
481194	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
481195	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
481196	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
481197	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
481198	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
481199	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	Follow-up Action Required?	n	
481200	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
481201	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
481202	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
481203	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	2045	
481204	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	2045	
481205	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
481206	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
481207	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Unknown Operations	0	
481208	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Tank Paint Condition	Good	
481209	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
481210	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
481211	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
481212	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
481213	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
481214	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
481215	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
481216	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
481217	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
481218	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
481219	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
481220	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
481221	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
481222	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Tank Leaks	None	
481223	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
481224	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Regulator As Left Counter	115079	
481225	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
481226	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	General Comments		
481227	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
481228	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
481229	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
481230	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
481231	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
481232	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	LTCC000323	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
481233	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
481234	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
481235	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
481236	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
481237	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
481238	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
481239	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
481240	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
481241	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	General Comments		
481242	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
481243	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
481244	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
481245	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
481246	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
481247	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
481248	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
481249	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
481250	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
481251	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
481252	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
481253	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
481254	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
481255	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
481256	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
481257	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
481258	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
481259	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
481260	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
481261	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
481262	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
481263	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
481264	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
481265	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
481266	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
481267	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Operations Counter AF	239	
481268	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	BCH000591	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
481269	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Operations Counter AL	239	
481270	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Operations This Read Vac	0	
481271	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
481272	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
481273	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
481274	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
481275	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
481276	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
481277	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Bushing Condition	Good	
481278	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Amps C Ø	150.0	
481279	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Amps B Ø	130.0	
481280	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Amps A Ø	135.0	
481281	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
481282	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
481283	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Foundation Condition	Good	
481284	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
481285	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Foundation Condition	Good	
481286	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
481287	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	9 Month Operations	4	
481288	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	General Comments		
481289	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
481290	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
481291	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
481292	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Unknown Operations	0	
481293	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	General Comments		
481294	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Grounds in Place?	y	
481295	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Tank Paint Condition	Good	
481296	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Heaters (All) Functioning?	y	
481297	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Amps B Ø	160.0	
481298	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Amps A Ø	160.0	
481299	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	BCH000591	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
481300	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
481301	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Cabinet Paint Condition	Good	
481302	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Equipment Properly Labeled?	y	
481303	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	LTCC000323	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
481304	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	LTCC000323	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
481305	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
481306	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
481307	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
481308	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Operations A Ø	0	
481309	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Operations B Ø	0	
481310	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Operations C Ø	0	
481311	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
481312	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
481313	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
481314	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	9 Month Operations	5	
481315	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Operations Ground	0	
481316	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Follow-up Action Required?	n	
481317	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Follow-up Action Required?	n	
481318	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Foundation Condition	Good	
481319	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Bushing Condition	Good	
481320	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Bushings Connection/Risers	Good	
481321	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
481322	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
481323	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
481324	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Cabinet Paint Condition	Good	
481325	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Equipment Properly Labeled?	y	
481326	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
481327	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
481328	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
481329	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Operations A Ø	0	
481330	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Operations B Ø	0	
481331	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Operations C Ø	0	
481332	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Operations Ground	0	
481333	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Follow-up Action Required?	n	
481334	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Follow-up Action Required?	n	
481335	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	General Comments		
481336	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	General Comments		
481337	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Grounds in Place?	y	
481338	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Heaters (All) Functioning?	y	
481339	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Maintenance Operations	0	
481340	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
481341	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	6	
481342	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Moisture and Leak Free?	y	
481343	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	246	
481344	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	246	
481345	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	7	
481346	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
481347	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
481348	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
481349	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
481350	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	General Comments		
481351	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
481352	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
481353	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
481354	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
481355	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
481356	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
481357	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
481358	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
481359	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
481360	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
481361	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
481362	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
481363	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
481364	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
481365	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
481366	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
481367	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
481368	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
481369	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
481370	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
481371	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
481372	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
481373	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
481374	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Vegetation	None	
481375	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
481376	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
481377	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
481378	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Operations This Read Vac	5	
481379	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
481380	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	General Comments		
481381	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Maintenance Operations	0	
481382	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Moisture and Leak Free?	y	
481383	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Operations Counter AF	287	
481384	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Operations Counter AL	287	
481385	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Operations This Read Vac	0	
481386	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
481387	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Switching Operations	0	
481388	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Tank Paint Condition	Good	
481389	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Unknown Operations	0	
481390	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Operations Counter AL	96	
481391	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Operations Counter AF	96	
481392	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
481393	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Moisture and Leak Free?	y	
481394	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
481395	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
481396	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
481397	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
481398	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	Totalizer Meter Reading	.3456	
481399	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
481400	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
481401	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
481402	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	3L	
481403	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	Winding Temp Max	45	°C
481404	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	Winding Temp Present	45	°C
481405	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
481406	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
481407	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	4R	
481408	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	7L	
481409	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
481410	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
481411	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
481412	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Bushing Condition	Good	
481413	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Bushings Connection/Risers	Good	
481414	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
481415	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
481416	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
481417	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Cabinet Paint Condition	Good	
481418	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Equipment Properly Labeled?	y	
481419	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
481420	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
481421	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
481422	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Operations A Ø	0	
481423	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	849	
481424	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	849	
481425	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
481426	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
481427	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
481428	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
481429	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
481430	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
481431	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
481432	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
481433	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
481434	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
481435	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
481436	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
481437	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
481438	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
481439	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
481440	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
481441	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
481442	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
481443	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
481444	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
481445	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
481446	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
481447	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
481448	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
481449	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	278	
481450	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
481451	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
481452	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
481453	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
481454	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	General Comments		
481455	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	9 Month Operations	5	
481456	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
481457	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
481458	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
481459	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Amps A Ø	50.0	
481460	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
481461	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
481462	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Tank Leaks	None	
481463	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Switching Operations	4	
481464	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
481465	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
481466	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Operations This Read Vac	4	
481467	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
481468	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
481469	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
481470	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
481471	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
481472	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
481473	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Operations Counter AL	214	
481474	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Operations Counter AF	210	
481475	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Moisture and Leak Free?	y	
481476	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Maintenance Operations	0	
481477	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Grounds in Place?	y	
481478	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	General Comments		
481479	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	General Comments		
481480	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Foundation Condition	Good	
481481	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Follow-up Action Required?	n	
481482	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Follow-up Action Required?	n	
481483	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Operations Ground	0	
481484	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Operations C Ø	0	
481485	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Operations B Ø	0	
481486	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Operations A Ø	0	
481487	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
481488	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
481489	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
481490	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Equipment Properly Labeled?	y	
481491	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Cabinet Paint Condition	Good	
481492	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
481493	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
481494	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC Current Tap Position	1L	
481495	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC Max Tap Position	7R	
481496	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC Min Tap Position	4L	
481497	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC Operations Since Last Insp	717	
481498	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
481499	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
481500	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
481501	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
481502	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Bushings Connection/Risers	Good	
481503	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Bushing Condition	Good	
481504	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Amps C Ø	145.0	
481505	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
481506	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	9 Month Operations	5	
481507	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Unknown Operations	0	
481508	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Amps B Ø	135.0	
481509	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Amps A Ø	160.0	
481510	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
481511	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
481512	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
481513	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	9 Month Operations	16	
481514	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
481515	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
481516	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
481517	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Tank Paint Condition	Good	
481518	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Switching Operations	5	
481519	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
481520	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
481521	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
481522	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
481523	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
481524	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
481525	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
481526	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
481527	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
481528	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
481529	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
481530	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
481531	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
481532	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
481533	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
481534	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
481535	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	VRR Time Delay	30	Seconds
481536	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
481537	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
481538	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
481539	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
481540	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
481541	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	General Comments		
481542	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
481543	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
481544	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Foundation Condition	Good	
481545	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
481546	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
481547	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
481548	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
481549	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
481550	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
481551	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
481552	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
481553	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
481554	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
481555	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
481556	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
481557	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
481558	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Operations This Read Vac	5	
481559	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Operations Counter AL	225	
481560	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Operations Counter AF	225	
481561	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Moisture and Leak Free?	y	
481562	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Maintenance Operations	0	
481563	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Heaters (All) Functioning?	y	
481564	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
481565	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
481566	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
481567	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
481568	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
481569	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
481570	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
481571	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
481572	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Oil Temp Present	40	°C
481573	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Oil Temp Max	40	°C
481574	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
481575	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
481576	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
481577	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
481578	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
481579	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
481580	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
481581	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Maintenance Operations	0	
481582	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
481583	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
481584	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	LTC Totalizer Reading	2544.48	kw
481585	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
481586	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	General Comments		
481587	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
481588	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
481589	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
481590	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
481591	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	General Comments		
481592	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	General Comments		
481593	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Foundation Condition	Good	
481594	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Follow-up Action Required?	n	
481595	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Follow-up Action Required?	n	
481596	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Operations Ground	0	
481597	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Operations C Ø	0	
481598	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Operations B Ø	0	
481599	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Operations A Ø	0	
481600	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
481601	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
481602	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
481603	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
481604	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
481605	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
481606	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
481607	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
481608	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
481609	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Bushing Condition	Good	
481610	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Amps C Ø	500.0	
481611	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Regulator As Left Counter	22573	
481612	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
481613	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
481614	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
481615	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
481616	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
481617	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
481618	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
481619	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
481620	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Unknown Operations	0	
481621	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Tank Paint Condition	Good	
481622	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Switching Operations	1	
481623	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Operations This Read Vac	1	
481624	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Operations Counter AL	207	
481625	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Operations Counter AF	207	
481626	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
481627	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Maintenance Operations	0	
481628	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
481629	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Unknown Operations	0	
481630	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Tank Paint Condition	Good	
481631	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Switching Operations	0	
481632	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
481633	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Operations This Read Vac	0	
481634	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Operations Counter AL	53	
481635	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	General Comments		
481636	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
481637	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
481638	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
481639	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
481640	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
481641	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
481642	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
481643	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
481644	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
481645	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
481646	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
481647	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
481648	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
481649	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
481650	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
481651	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Positive DC Ground	22.0	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
481652	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Negative DC Ground	15.0	VDC
481653	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	General Comments		
481654	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
481655	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	General Comments		
481656	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	General Comments		
481657	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Unknown Operations	0	
481658	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Tank Paint Condition	Good	
481659	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
481660	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
481661	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
481662	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
481663	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
481664	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
481665	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
481666	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
481667	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
481668	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
481669	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Grounds in Place?	y	
481670	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	General Comments		
481671	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Totalizer Meter Reading	.3534	
481672	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
481673	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
481674	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Operations Counter AF	53	
481675	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
481676	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
481677	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Switching Operations	5	
481678	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
481679	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
481680	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
481681	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
481682	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
481683	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
481684	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
481685	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	All Connections OK?	y	
481686	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	Follow-up Action Required?	n	
481687	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	General Comments		
481688	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	LTC Operation Checked?	y	
481689	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
481690	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
481691	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
481692	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
481693	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
481694	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
481695	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
481696	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
481697	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
481698	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
481699	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
481700	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
481701	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Operations A Ø	0	
481702	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
481703	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
481704	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
481705	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
481706	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
481707	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
481708	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
481709	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
481710	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
481711	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
481712	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
481713	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
481714	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
481715	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
481716	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
481717	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
481718	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
481719	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
481720	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
481721	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	9 Month Operations	5	
481722	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
481723	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
481724	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
481725	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
481726	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
481727	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LTCC000839	LTCControl	BR-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
481728	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LTCC000839	LTCControl	BR-TRANS 2	LTC Control Insp	General Comments		
481729	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LTCC000839	LTCControl	BR-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
481730	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LTCC000838	LTCControl	BR-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
481731	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LTCC000838	LTCControl	BR-TRANS 1	LTC Control Insp	General Comments		
481732	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LTCC000838	LTCControl	BR-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
481733	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
481734	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
481735	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
481736	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
481737	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	LTC Operation Checked?	y	
481738	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	General Comments		
481739	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	Follow-up Action Required?	n	
481740	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
481741	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	All Connections OK?	y	
481742	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	BCH000591	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
481743	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	General Comments		
481744	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
481745	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
481746	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
481747	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
481748	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
481749	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
481750	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
481751	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
481752	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
481753	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Bushing Condition	Good	
481754	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	42946	
481755	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
481756	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	BCH000591	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
481757	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	BCH000591	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
481758	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
481759	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
481760	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
481761	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
481762	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	6	
481763	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
481764	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Amps A Ø	10.0	
481765	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Amps B Ø	10.0	
481766	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Amps C Ø	10.0	
481767	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Amps C Ø	160.0	
481768	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
481769	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
481770	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Follow-up Action Required?	n	
481771	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
481772	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
481773	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
481774	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Grounds in Place?	y	
481775	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	General Comments		
481776	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	General Comments		
481777	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Amps B Ø	500.0	
481778	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Amps A Ø	500.0	
481779	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
481780	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
481781	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
481782	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	9 Month Operations	6	
481783	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
481784	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	9 Month Operations	3	
481785	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
481786	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	9 Month Operations	4	
481787	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
481788	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
481789	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
481790	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Amps A Ø	10.0	
481791	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Amps B Ø	10.0	
481792	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Amps C Ø	10.0	
481793	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Bushing Condition	Good	
481794	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Bushings Connection/Risers	Good	
481795	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
481796	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
481797	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
481798	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
481799	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
481800	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Tank Leaks	None	
481801	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
481802	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
481803	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Amps A Ø	31.0	
481804	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Amps B Ø	31.0	
481805	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Amps C Ø	29.0	
481806	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
481807	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
481808	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	General Comments		
481809	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
481810	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	42946	
481811	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Grounds in Place?	y	
481812	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	General Comments		
481813	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	General Comments		
481814	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Foundation Condition	Good	
481815	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Follow-up Action Required?	n	
481816	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Follow-up Action Required?	n	
481817	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations Ground	0	
481818	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations C Ø	0	
481819	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations B Ø	0	
481820	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations A Ø	0	
481821	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
481822	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
481823	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
481824	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Equipment Properly Labeled?	y	
481825	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Cabinet Paint Condition	Good	
481826	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
481827	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
481828	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
481829	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Bushings Connection/Risers	Good	
481830	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Bushing Condition	Good	
481831	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Amps C Ø	120.0	
481832	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Amps B Ø	120.0	
481833	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Amps A Ø	120.0	
481834	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	General Comments		
481835	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
481836	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
481837	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Foundation Condition	Good	
481838	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Follow-up Action Required?	n	
481839	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Follow-up Action Required?	n	
481840	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Operations Ground	0	
481841	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Operations C Ø	0	
481842	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
481843	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
481844	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Operations B Ø	0	
481845	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
481846	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
481847	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
481848	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Heaters (All) Functioning?	y	
481849	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Maintenance Operations	0	
481850	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Moisture and Leak Free?	y	
481851	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Operations Counter AF	708	
481852	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Operations Counter AL	708	
481853	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Operations This Read Vac	5	
481854	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
481855	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Switching Operations	0	
481856	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Operations A Ø	0	
481857	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
481858	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
481859	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	2	
481860	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	772	
481861	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	772	
481862	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	5	
481863	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
481864	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
481865	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
481866	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
481867	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
481868	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
481869	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	General Comments		
481870	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
481871	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
481872	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
481873	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
481874	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
481875	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	General Comments		
481876	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
481877	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
481878	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
481879	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
481880	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
481881	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
481882	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
481883	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Moisture and Leak Free?	y	
481884	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Operations Counter AF	230	
481885	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Operations Counter AL	230	
481886	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Operations This Read Vac	1	
481887	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Switching Operations	1	
481888	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Tank Paint Condition	Good	
481889	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
481890	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
481891	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Unknown Operations	0	
481892	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
481893	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
481894	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
481895	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
481896	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
481897	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
481898	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
481899	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
481900	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
481901	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
481902	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
481903	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
481904	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
481905	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
481906	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	25.0	
481907	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	25.0	
481908	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	25.0	
481909	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
481910	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
481911	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
481912	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Equipment Properly Labeled?	y	
481913	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Cabinet Paint Condition	Good	
481914	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
481915	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
481916	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
481917	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Bushings Connection/Risers	Good	
481918	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Bushing Condition	Good	
481919	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
481920	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
481921	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Clear of Trash?	y	
481922	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
481923	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
481924	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
481925	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
481926	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
481927	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Amps B Ø	30.0	
481928	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCC000592	LTCControl	472-1	LTC Control Insp	VRR Time Delay	30	Seconds
481929	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCC000592	LTCControl	472-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
481930	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCC000592	LTCControl	472-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
481931	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Amps C Ø	50.0	
481932	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Bushing Condition	Good	
481933	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Bushings Connection/Risers	Good	
481934	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
481935	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	TC FILTER CHANGE LIGHT ON AND ALARM ISOLATED	
481936	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	General Comments		
481937	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
481938	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
481939	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCC000592	LTCControl	472-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
481940	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCC000592	LTCControl	472-1	LTC Control Insp	LTC Operation Checked?	y	
481941	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCC000592	LTCControl	472-1	LTC Control Insp	General Comments		
481942	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCC000592	LTCControl	472-1	LTC Control Insp	Follow-up Action Required?	n	
481943	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCC000592	LTCControl	472-1	LTC Control Insp	All Connections OK?	y	
481944	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
481945	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
481946	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
481947	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
481948	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
481949	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
481950	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Oil Temp Max	60	°C
481951	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
481952	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
481953	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	LTC Totalizer Reading	8820.00	kw
481954	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
481955	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	General Comments		
481956	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	General Comments		
481957	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
481958	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
481959	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
481960	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
481961	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Operations A Ø	5	
481962	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Operations B Ø	0	
481963	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Operations C Ø	0	
481964	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Operations Ground	0	
481965	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
481966	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
481967	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Cabinet Paint Condition	Good	
481968	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Equipment Properly Labeled?	y	
481969	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
481970	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
481971	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
481972	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Operations A Ø	0	
481973	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Operations B Ø	0	
481974	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Operations C Ø	0	
481975	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Operations Ground	0	
481976	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Follow-up Action Required?	n	
481977	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Follow-up Action Required?	n	
481978	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Foundation Condition	Good	
481979	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	General Comments		
481980	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	General Comments		
481981	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Grounds in Place?	y	
481982	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Heaters (All) Functioning?	y	
481983	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Maintenance Operations	0	
481984	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
481985	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
481986	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
481987	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
481988	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
481989	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
481990	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	2	
481991	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Follow-up Action Required?	n	
481992	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Follow-up Action Required?	n	
481993	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Foundation Condition	Good	
481994	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	General Comments		
481995	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	General Comments		
481996	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Grounds in Place?	y	
481997	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
481998	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
481999	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
482000	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
482001	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
482002	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
482003	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
482004	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
482005	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
482006	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
482007	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
482008	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
482009	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
482010	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	9 Month Operations	3	
482011	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
482012	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
482013	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
482014	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Amps A Ø	163.0	
482015	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
482016	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
482017	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Amps B Ø	157.0	
482018	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Amps C Ø	161.0	
482019	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
482020	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
482021	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
482022	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
482023	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Bushing Condition	Good	
482024	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Bushings Connection/Risers	Good	
482025	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
482026	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
482027	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
482028	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Cabinet Paint Condition	Good	
482029	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Equipment Properly Labeled?	y	
482030	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Adjusted Amps A Phase V	10.92	
482031	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
482032	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
482033	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Operations A Ø	2	
482034	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Operations B Ø	0	
482035	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Operations C Ø	0	
482036	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Operations Ground	0	
482037	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Follow-up Action Required?	n	
482038	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Follow-up Action Required?	n	
482039	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Foundation Condition	Good	
482040	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	General Comments		
482041	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
482042	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
482043	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
482044	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
482045	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
482046	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
482047	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	General Comments		
482048	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
482049	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Grounds in Place?	y	
482050	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Maintenance Operations	0	
482051	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Moisture and Leak Free?	y	
482052	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Operations Counter AF	168	
482053	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
482054	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
482055	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
482056	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
482057	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	2	
482058	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
482059	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Operations Counter AL	171	
482060	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Operations This Read Vac	2	
482061	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Switching Operations	0	
482062	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Tank Paint Condition	Good	
482063	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Unknown Operations	0	
482064	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
482065	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
482066	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
482067	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
482068	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
482069	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	BCH000586	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
482070	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	BCH000586	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
482071	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	BCH000586	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
482072	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	BCH000586	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
482073	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	BCH000586	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
482074	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
482075	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
482076	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
482077	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
482078	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Clear of Trash?	y	
482079	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
482080	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
482081	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Operations B Ø	0	
482082	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
482083	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
482084	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	General Comments		
482085	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
482086	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
482087	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
482088	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
482089	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Vegetation	None	
482090	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
482091	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Amps C Ø	310.0	
482092	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Cabinet Paint Condition	Good	
482093	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
482094	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
482095	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Equipment Properly Labeled?	y	
482096	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
482097	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
482098	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
482099	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
482100	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
482101	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
482102	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
482103	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
482104	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
482105	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
482106	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
482107	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
482108	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
482109	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	9 Month Operations	5	
482110	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
482111	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
482112	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
482113	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Amps A Ø	10.0	
482114	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
482115	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
482116	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
482117	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
482118	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	145.0	
482119	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	135.0	
482120	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	160.0	
482121	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
482122	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
482123	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
482124	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	1	
482125	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Amps B Ø	10.0	
482126	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Amps C Ø	10.0	
482127	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
482128	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
482129	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
482130	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
482131	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Bushing Condition	Good	
482132	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Bushings Connection/Risers	Good	
482133	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
482134	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
482135	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
482136	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
482137	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
482138	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
482139	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
482140	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	General Comments		
482141	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
482142	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
482143	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
482144	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
482145	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
482146	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
482147	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
482148	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
482149	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
482150	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
482151	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
482152	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
482153	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
482154	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
482155	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Follow-up Action Required?	n	
482156	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
482157	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
482158	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	General Comments		
482159	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
482160	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
482161	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
482162	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
482163	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
482164	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
482165	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
482166	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3690	
482167	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
482168	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
482169	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Switching Operations	0	
482170	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Tank Paint Condition	Good	
482171	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Unknown Operations	0	
482172	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Amps B Ø	120.0	
482173	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
482174	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
482175	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
482176	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
482177	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
482178	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Regulator As Left Counter	123685	
482179	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
482180	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Tank Leaks	None	
482181	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
482182	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
482183	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
482184	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
482185	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
482186	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
482187	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
482188	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
482189	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
482190	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Clear of Trash?	y	
482191	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
482192	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
482193	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
482194	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	150.0	
482195	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	180.0	
482196	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	200.0	
482197	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
482198	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Amps C Ø	140.0	
482199	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Bushing Condition	Good	
482200	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	General Comments		
482201	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
482202	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
482203	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
482204	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Bushings Connection/Risers	Good	
482205	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
482206	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
482207	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
482208	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
482209	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
482210	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
482211	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Clear of Trash?	y	
482212	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Cabinet Paint Condition	Good	
482213	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	LTCC000323	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
482214	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	LTCC000323	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
482215	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
482216	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Tank Leaks	None	
482217	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
482218	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
482219	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
482220	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	62	°F
482221	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
482222	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
482223	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	62	°F
482224	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
482225	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Regulator As Left Counter	45350	
482226	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
482227	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
482228	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
482229	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
482230	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
482231	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Min Tap Position	9L	
482232	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
482233	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Max Tap Position	1R	
482234	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
482235	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
482236	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
482237	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
482238	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
482239	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
482240	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
482241	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
482242	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
482243	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
482244	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
482245	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
482246	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
482247	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
482248	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
482249	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
482250	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
482251	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
482252	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
482253	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
482254	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
482255	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	9 Month Operations	0	
482256	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
482257	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
482258	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
482259	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	BCH000591	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
482260	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	9 Month Operations	5	
482261	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
482262	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
482263	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
482264	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
482265	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
482266	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
482267	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
482268	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
482269	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
482270	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
482271	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
482272	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
482273	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
482274	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
482275	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
482276	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
482277	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
482278	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
482279	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
482280	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
482281	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
482282	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
482283	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Winding Temp Max	50	°C
482284	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Totalizer Meter Reading	.4900	
482285	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
482286	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
482287	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
482288	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
482289	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
482290	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
482291	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
482292	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
482293	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Vegetation	None	
482294	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Amps A Ø	150.0	
482295	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3542.40	kw
482296	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
482297	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
482298	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
482299	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
482300	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
482301	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
482302	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
482303	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
482304	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
482305	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
482306	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
482307	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
482308	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
482309	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
482310	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
482311	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
482312	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
482313	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
482314	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
482315	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	General Comments		
482316	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
482317	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
482318	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
482319	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
482320	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Clear of Trash?	y	
482321	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Foundation Condition	Good	
482322	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
482323	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
482324	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
482325	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
482326	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
482327	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Ambient Temp	71	°F
482328	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
482329	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
482330	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	105.0	VDC
482331	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
482332	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
482333	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
482334	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
482335	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
482336	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
482337	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
482338	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
482339	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Bushing Condition	Good	
482340	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
482341	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
482342	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Operations C Ø	0	
482343	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Operations B Ø	0	
482344	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
482345	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
482346	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
482347	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
482348	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
482349	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
482350	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
482351	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
482352	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
482353	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
482354	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
482355	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
482356	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
482357	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
482358	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	General Comments		
482359	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
482360	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
482361	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Foundation Condition	Good	
482362	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
482363	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
482364	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
482365	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
482366	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
482367	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
482368	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	General Comments		
482369	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	General Comments		
482370	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC As Found Counter	70372	
482371	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC As Left Counter	70375	
482372	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
482373	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC Current Tap Position	3L	
482374	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
482375	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
482376	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
482377	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
482378	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
482379	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
482380	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
482381	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
482382	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
482383	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
482384	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
482385	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
482386	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
482387	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
482388	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
482389	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
482390	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
482391	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	24	
482392	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3R	
482393	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
482394	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	LTC As Left Counter	49555	
482395	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	LTC As Found Counter	49555	
482396	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
482397	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
482398	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
482399	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
482400	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
482401	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
482402	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
482403	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
482404	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
482405	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	LTCC000323	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
482406	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	LTCC000323	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
482407	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	LTCC000323	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
482408	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	Follow-up Action Required?	n	
482409	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
482410	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Equipment Properly Labeled?	y	
482411	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Adjusted Amps A Phase V	16.32	
482412	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
482413	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Maintenance Operations	0	
482414	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
482415	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
482416	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
482417	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
482418	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
482419	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
482420	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Heaters (All) Functioning?	y	
482421	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
482422	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Grounds in Place?	y	
482423	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
482424	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Vegetation	None	
482425	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
482426	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
482427	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	General Comments		
482428	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
482429	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
482430	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
482431	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
482432	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	General Comments		
482433	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
482434	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
482435	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
482436	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
482437	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
482438	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Regulator As Left Counter	99024	
482439	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
482440	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
482441	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Tank Leaks	None	
482442	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
482443	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
482444	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
482445	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
482446	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
482447	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
482448	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
482449	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
482450	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
482451	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	General Comments		
482452	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	General Comments		
482453	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	General Comments		
482454	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
482455	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Foundation Condition	Good	
482456	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Follow-up Action Required?	n	
482457	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Follow-up Action Required?	n	
482458	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
482459	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC As Left Counter	53417	
482460	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC As Found Counter	53417	
482461	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	General Comments		
482462	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Radiator Leaks	None	
482463	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
482464	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Grounds in Place?	y	
482465	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	General Comments	OK	
482466	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
482467	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	General Comments		
482468	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
482469	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	Follow-up Action Required?	n	
482470	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Operations Ground	0	
482471	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Current Tap Position	5L	
482472	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
482473	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
482474	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
482475	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
482476	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
482477	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Operations B Ø	0	
482478	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Operations A Ø	0	
482479	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
482480	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
482481	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
482482	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Equipment Properly Labeled?	y	
482483	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Cabinet Paint Condition	Good	
482484	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
482485	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
482486	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
482487	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Bushings Connection/Risers	Good	
482488	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Bushing Condition	Good	
482489	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Amps C Ø	30.0	
482490	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Amps B Ø	30.0	
482491	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
482492	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
482493	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
482494	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
482495	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
482496	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
482497	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
482498	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
482499	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
482500	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
482501	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
482502	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
482503	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
482504	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
482505	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
482506	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
482507	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
482508	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
482509	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
482510	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
482511	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
482512	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Amps A Ø	30.0	
482513	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
482514	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
482515	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
482516	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
482517	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Unknown Operations	0	
482518	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Tank Paint Condition	Good	
482519	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Switching Operations	0	
482520	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
482521	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Operations This Read Vac	0	
482522	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Operations Counter AL	216	
482523	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Operations Counter AF	216	
482524	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Moisture and Leak Free?	y	
482525	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Maintenance Operations	0	
482526	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Heaters (All) Functioning?	y	
482527	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Grounds in Place?	y	
482528	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	General Comments		
482529	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
482530	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
482531	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
482532	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
482533	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
482534	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
482535	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
482536	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
482537	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
482538	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
482539	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	9 Month Operations	3	
482540	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
482541	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
482542	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
482543	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Amps A Ø	272.0	
482544	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Amps B Ø	260.0	
482545	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Amps C Ø	262.0	
482546	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
482547	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
482548	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Follow-up Action Required?	n	
482549	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Follow-up Action Required?	n	
482550	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Operations Ground	0	
482551	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
482552	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Clear of Trash?	y	
482553	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
482554	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
482555	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Ambient Temp	6	°F
482556	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
482557	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
482558	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Follow-up Action Required?	n	
482559	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Operations C Ø	0	
482560	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Operations Ground	0	
482561	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Follow-up Action Required?	n	
482562	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
482563	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Bushings Connection/Risers	Good	
482564	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Bushing Condition	Good	
482565	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Amps C Ø	220.0	
482566	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Amps B Ø	220.0	
482567	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Follow-up Action Required?	n	
482568	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Operations Ground	0	
482569	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Operations C Ø	0	
482570	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Operations B Ø	0	
482571	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Amps A Ø	220.0	
482572	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
482573	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
482574	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
482575	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	9 Month Operations	11	
482576	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Operations Ground	0	
482577	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Follow-up Action Required?	n	
482578	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Follow-up Action Required?	n	
482579	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Foundation Condition	Good	
482580	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
482581	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
482582	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
482583	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
482584	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Operations A Ø	0	
482585	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
482586	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
482587	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
482588	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Equipment Properly Labeled?	y	
482589	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Cabinet Paint Condition	Good	
482590	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
482591	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
482592	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
482593	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Bushings Connection/Risers	Good	
482594	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
482595	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
482596	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
482597	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
482598	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
482599	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	General Comments		
482600	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	9 Month Operations	9	
482601	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
482602	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
482603	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
482604	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
482605	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
482606	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
482607	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
482608	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
482609	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
482610	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
482611	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	General Comments		
482612	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
482613	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Bushing Condition	Good	
482614	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Floor Swept?	y	
482615	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
482616	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Operations A Ø	0	
482617	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Operations B Ø	0	
482618	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
482619	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
482620	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
482621	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
482622	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
482623	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
482624	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Cabinet Paint Condition	Good	
482625	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
482626	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
482627	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
482628	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
482629	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
482630	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
482631	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
482632	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
482633	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
482634	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
482635	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
482636	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
482637	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	General Comments		
482638	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	General Comments		
482639	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Foundation Condition	Good	
482640	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
482641	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
482642	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
482643	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
482644	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
482645	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	9 Month Operations	1	
482646	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
482647	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	General Comments		
482648	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
482649	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
482650	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Floor Swept?	y	
482651	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
482652	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
482653	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Evidence of Insects	None	
482654	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
482655	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
482656	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
482657	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
482658	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
482659	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
482660	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
482661	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
482662	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
482663	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
482664	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
482665	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
482666	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
482667	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
482668	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
482669	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Operations Ground	0	
482670	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
482671	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
482672	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
482673	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	General Comments		
482674	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	General Comments	ok	
482675	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
482676	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
482677	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Maintenance Operations	0	
482678	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Tank Paint Condition	Good	
482679	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
482680	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Operations Counter AF	132	
482681	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Switching Operations	1	
482682	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Unknown Operations	0	
482683	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
482684	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
482685	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
482686	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
482687	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
482688	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
482689	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
482690	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Bushing Condition	Good	
482691	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Amps C Ø	400.0	
482692	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BCH000613	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
482693	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BCH000613	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.8	VDC
482694	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BCH000613	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.8	VDC
482695	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BCH000613	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
482696	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
482697	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	9 Month Operations	4	
482698	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
482699	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
482700	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
482701	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Amps A Ø	361.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
482702	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Amps B Ø	350.0	
482703	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Amps C Ø	359.0	
482704	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
482705	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
482706	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
482707	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
482708	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	BCH000576	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
482709	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	BCH000576	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
482710	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	BCH000576	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
482711	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	BCH000576	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
482712	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
482713	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
482714	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
482715	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
482716	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
482717	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
482718	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Unknown Operations	0	
482719	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
482720	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
482721	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
482722	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Panels Dusted?	y	
482723	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Amps B Ø	400.0	
482724	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Amps A Ø	400.0	
482725	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
482726	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Operations Counter AL	132	
482727	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Operations This Read Vac	0	
482728	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Switching Operations	0	
482729	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
482730	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Unknown Operations	0	
482731	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	LTC Totalizer Reading	4184.00	kw
482732	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
482733	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	General Comments		
482734	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
482735	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
482736	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
482737	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	BCH000576	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
482738	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Bushing Condition	Good	
482739	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Bushings Connection/Risers	Good	
482740	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
482741	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Operations B Ø	0	
482742	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Operations A Ø	0	
482743	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
482744	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
482745	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
482746	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
482747	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Equipment Properly Labeled?	y	
482748	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Cabinet Paint Condition	Good	
482749	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
482750	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
482751	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Vegetation	None	
482752	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
482753	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Operations This Read Vac	6	
482754	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Operations Counter AL	321	
482755	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Operations Counter AF	321	
482756	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Moisture and Leak Free?	y	
482757	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Maintenance Operations	0	
482758	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Heaters (All) Functioning?	y	
482759	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Grounds in Place?	y	
482760	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	General Comments		
482761	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	General Comments		
482762	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Foundation Condition	Good	
482763	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
482764	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	General Comments		
482765	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
482766	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
482767	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Tank Paint Condition	Good	
482768	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Operations This Read Vac	1	
482769	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Operations Counter AL	264	
482770	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Operations Counter AF	264	
482771	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Moisture and Leak Free?	y	
482772	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Maintenance Operations	0	
482773	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Heaters (All) Functioning?	y	
482774	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Grounds in Place?	y	
482775	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	General Comments		
482776	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
482777	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	240.0	
482778	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Switching Operations	6	
482779	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	240.0	
482780	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	240.0	
482781	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
482782	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
482783	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
482784	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
482785	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Maintenance Operations	0	
482786	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Heaters (All) Functioning?	y	
482787	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Grounds in Place?	y	
482788	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	General Comments		
482789	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	General Comments		
482790	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Foundation Condition	Good	
482791	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Follow-up Action Required?	n	
482792	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Follow-up Action Required?	n	
482793	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Operations Ground	0	
482794	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Operations C Ø	0	
482795	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
482796	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
482797	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
482798	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
482799	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
482800	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
482801	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
482802	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
482803	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
482804	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
482805	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Oil Temp Present	40	°C
482806	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Oil Temp Max	40	°C
482807	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
482808	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
482809	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
482810	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
482811	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
482812	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	General Comments		
482813	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
482814	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
482815	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	9 Month Operations	9	
482816	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
482817	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
482818	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
482819	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
482820	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	9 Month Operations	9	
482821	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
482822	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
482823	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
482824	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Totalizer Meter Reading	.8239	
482825	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Winding Temp Max	40	°C
482826	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Winding Temp Present	40	°C
482827	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
482828	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Amps A Ø	191.0	
482829	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Accumulated Fault Duty C Ph V	4.17	%
482830	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Accumulated Fault Duty B Ph V	5.37	%
482831	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Accumulated Fault Duty A Ph V	5.96	%
482832	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	9 Month Operations	3	
482833	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Amps A Ø	20.0	
482834	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
482835	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
482836	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
482837	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	2491	
482838	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC Min Tap Position	2R	
482839	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Amps B Ø	20.0	
482840	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Amps C Ø	20.0	
482841	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Bushing Condition	Good	
482842	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
482843	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Switching Operations	5	
482844	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Tank Paint Condition	Good	
482845	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Unknown Operations	0	
482846	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Signage Visible, and Proper?	y	
482847	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	General Comments		
482848	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Gate Locks Functioning ?	y	
482849	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
482850	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
482851	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
482852	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
482853	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
482854	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
482855	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
482856	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
482857	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Cabinet Paint Condition	Good	
482858	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Maintenance Operations	0	
482859	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Moisture and Leak Free?	y	
482860	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Operations Counter AF	298	
482861	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Operations Counter AL	298	
482862	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Operations This Read Vac	0	
482863	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
482864	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Switching Operations	0	
482865	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Tank Paint Condition	Good	
482866	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Unknown Operations	0	
482867	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Tank Leaks	None	
482868	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
482869	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
482870	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Amps A Ø	10.0	
482871	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Amps B Ø	10.0	
482872	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
482873	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
482874	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
482875	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Bushings Connection/Risers	Good	
482876	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Bushing Condition	Good	
482877	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Amps C Ø	194.0	
482878	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Amps B Ø	200.0	
482879	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Amps C Ø	10.0	
482880	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Bushing Condition	Good	
482881	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Bushings Connection/Risers	Good	
482882	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
482883	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
482884	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
482885	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
482886	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
482887	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
482888	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
482889	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	General Comments		
482890	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
482891	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
482892	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
482893	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
482894	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
482895	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
482896	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	7	
482897	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
482898	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	General Comments		
482899	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
482900	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
482901	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
482902	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
482903	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
482904	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1235	
482905	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1235	
482906	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
482907	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
482908	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
482909	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
482910	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
482911	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
482912	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
482913	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
482914	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
482915	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
482916	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
482917	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
482918	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
482919	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
482920	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
482921	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
482922	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
482923	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
482924	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
482925	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
482926	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
482927	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	General Comments		
482928	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
482929	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
482930	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
482931	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
482932	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
482933	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Operations A Ø	0	
482934	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
482935	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
482936	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Follow-up Action Required?	n	
482937	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Ties Intact?	y	
482938	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Posts Condition OK?	y	
482939	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Grounds in Place?	y	
482940	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Gates Aligned?	y	
482941	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
482942	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
482943	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
482944	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
482945	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Bushings Connection/Risers	Good	
482946	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3R	
482947	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3R	
482948	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
482949	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC As Left Counter	87671	
482950	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC As Found Counter	87671	
482951	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
482952	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
482953	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
482954	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Amps A Ø	360.0	
482955	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Amps B Ø	360.0	
482956	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Amps C Ø	360.0	
482957	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Bushing Condition	Good	
482958	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Bushings Connection/Risers	Good	
482959	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
482960	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
482961	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
482962	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Cabinet Paint Condition	Good	
482963	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Equipment Properly Labeled?	y	
482964	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
482965	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
482966	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
482967	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
482968	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
482969	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
482970	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	Follow-up Action Required?	n	
482971	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
482972	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
482973	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
482974	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
482975	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	General Comments		
482976	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
482977	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
482978	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
482979	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
482980	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Operations Ground	0	
482981	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
482982	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
482983	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
482984	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
482985	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
482986	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
482987	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Trash Emptied?	y	
482988	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Winding Temp Present	45	°C
482989	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Winding Temp Max	45	°C
482990	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Totalizer Meter Reading	.8886	
482991	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
482992	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Grounds in Place?	y	
482993	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
482994	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
482995	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	200.0	
482996	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Heaters (All) Functioning?	y	
482997	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Bushings Connection/Risers	Good	
482998	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Bushing Condition	Good	
482999	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Amps C Ø	71.0	
483000	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Unknown Operations	0	
483001	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
483002	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Switching Operations	0	
483003	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
483004	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Operations This Read Vac	0	
483005	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Operations Counter AL	169	
483006	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Operations Counter AF	169	
483007	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Moisture and Leak Free?	y	
483008	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Maintenance Operations	0	
483009	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Heaters (All) Functioning?	y	
483010	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Grounds in Place?	y	
483011	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	General Comments		
483012	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	General Comments		
483013	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Foundation Condition	Good	
483014	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Follow-up Action Required?	n	
483015	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Follow-up Action Required?	n	
483016	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Operations Ground	0	
483017	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	General Comments		
483018	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Panels Dusted?	y	
483019	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	9 Month Operations	9	
483020	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Bushing Condition	Good	
483021	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Amps C Ø	176.0	
483022	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Amps B Ø	177.0	
483023	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Amps A Ø	179.0	
483024	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Accumulated Fault Duty C Ph V	15.5	%
483025	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Accumulated Fault Duty B Ph V	41.14	%
483026	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Accumulated Fault Duty A Ph V	23.85	%
483027	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	9 Month Operations	2	
483028	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
483029	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
483030	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Follow-up Action Required?	n	
483031	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Foundation Condition	Good	
483032	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	General Comments		
483033	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	General Comments		
483034	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Grounds in Place?	y	
483035	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	General Comments		
483036	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Foundation Condition	Good	
483037	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Follow-up Action Required?	n	
483038	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Follow-up Action Required?	n	
483039	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Operations Ground	0	
483040	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Operations C Ø	0	
483041	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Operations B Ø	0	
483042	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Operations A Ø	0	
483043	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
483044	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
483045	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
483046	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Equipment Properly Labeled?	y	
483047	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Cabinet Paint Condition	Good	
483048	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
483049	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
483050	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
483051	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
483052	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
483053	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
483054	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
483055	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
483056	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
483057	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
483058	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
483059	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	General Comments		
483060	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
483061	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
483062	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
483063	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
483064	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
483065	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
483066	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	200.0	
483067	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	160.0	
483068	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
483069	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
483070	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
483071	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
483072	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
483073	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
483074	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
483075	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Regulator As Left Counter	34402	
483076	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
483077	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
483078	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
483079	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
483080	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
483081	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Heaters (All) Functioning?	y	
483082	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
483083	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
483084	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
483085	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
483086	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
483087	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
483088	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
483089	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
483090	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
483091	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
483092	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
483093	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Equipment Properly Labeled?	y	
483094	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Amps B Ø	72.0	
483095	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Amps A Ø	74.0	
483096	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
483097	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
483098	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
483099	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	9 Month Operations	2	
483100	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
483101	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Operations C Ø	0	
483102	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Operations B Ø	0	
483103	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Operations A Ø	0	
483104	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
483105	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
483106	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Maintenance Operations	0	
483107	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Moisture and Leak Free?	y	
483108	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Operations Counter AF	99992	
483109	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Operations Counter AL	9992	
483110	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
483111	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
483112	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	General Comments		
483113	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	General Comments	ok	
483114	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
483115	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Operations This Read Vac	5	
483116	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
483117	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
483118	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
483119	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Maintenance Operations	0	
483120	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
483121	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Operations Counter AF	169	
483122	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Operations Counter AL	169	
483123	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Operations This Read Vac	3	
483124	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Switching Operations	3	
483125	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
483126	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Unknown Operations	0	
483127	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
483128	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
483129	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
483130	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
483131	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
483132	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
483133	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Oil Temp Present	35	°C
483134	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Oil Temp Max	40	°C
483135	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
483136	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
483137	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	8530.56	kw
483138	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
483139	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
483140	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
483141	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
483142	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	General Comments		
483143	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
483144	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
483145	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
483146	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
483147	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
483148	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Follow-up Action Required?	n	
483149	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
483150	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
483151	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
483152	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	General Comments		
483153	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
483154	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
483155	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
483156	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
483157	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
483158	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
483159	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	7	
483160	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
483161	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	7	
483162	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	16	
483163	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	16	
483164	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
483165	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
483166	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
483167	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
483168	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
483169	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	General Comments		
483170	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
483171	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	LTC Totalizer Reading	7511.04	kw
483172	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
483173	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
483174	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Oil Temp Max	42	°C
483175	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Oil Temp Present	42	°C
483176	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
483177	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
483178	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
483179	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
483180	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
483181	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
483182	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
483183	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Oil Temp Present	42	°C
483184	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Tank Paint Condition	Good	
483185	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Switching Operations	5	
483186	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
483187	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
483188	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
483189	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
483190	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Ambient Temp	72	°F
483191	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
483192	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
483193	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
483194	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
483195	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	Oil Temp Present	45	°C
483196	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	General Comments		
483197	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	General Comments		
483198	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
483199	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	Follow-up Action Required?	n	
483200	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Oil Temp Present	32	°C
483201	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Oil Temp Max	32	°C
483202	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
483203	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
483204	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1915.20	kw
483205	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
483206	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Operations This Read Vac	5	
483207	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Operations Counter AL	467	
483208	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Operations Counter AF	467	
483209	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Moisture and Leak Free?	y	
483210	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
483211	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
483212	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
483213	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
483214	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
483215	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
483216	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	General Comments		
483217	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
483218	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1	psi
483219	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
483220	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
483221	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
483222	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
483223	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
483224	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
483225	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
483226	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Amps C Ø	10.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
483227	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Amps B Ø	10.0	
483228	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
483229	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
483230	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Totalizer Meter Reading	.7824	
483231	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
483232	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
483233	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Amps A Ø	10.0	
483234	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
483235	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
483236	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
483237	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	9 Month Operations	7	
483238	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Amps B Ø	40.0	
483239	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
483240	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	General Comments		
483241	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	LTC Operation Checked?	y	
483242	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
483243	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
483244	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Amps C Ø	40.0	
483245	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Bushing Condition	Good	
483246	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Bushings Connection/Risers	Good	
483247	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
483248	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Operations A Ø	0	
483249	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
483250	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
483251	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
483252	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
483253	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	VRR Time Delay	30	Seconds
483254	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
483255	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
483256	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	General Comments		
483257	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
483258	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
483259	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
483260	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
483261	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
483262	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
483263	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
483264	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
483265	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
483266	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
483267	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
483268	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Oil Temp Max	42	°C
483269	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
483270	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
483271	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
483272	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
483273	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
483274	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	9 Month Operations	9	
483275	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
483276	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
483277	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
483278	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Amps A Ø	40.0	
483279	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Maintenance Operations	0	
483280	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Heaters (All) Functioning?	y	
483281	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Grounds in Place?	y	
483282	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	General Comments		
483283	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	General Comments		
483284	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Foundation Condition	Good	
483285	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Follow-up Action Required?	n	
483286	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Follow-up Action Required?	n	
483287	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Operations Ground	0	
483288	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Operations C Ø	0	
483289	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Operations B Ø	0	
483290	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Operations A Ø	0	
483291	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
483292	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
483293	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
483294	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Equipment Properly Labeled?	y	
483295	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
483296	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Winding Temp Max	40	°C
483297	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Totalizer Meter Reading	.7300	
483298	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
483299	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	All Connections OK?	y	
483300	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	Follow-up Action Required?	n	
483301	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
483302	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	LTC Totalizer Reading	14830.20	kw
483303	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Cabinet Paint Condition	Good	
483304	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
483305	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
483306	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
483307	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
483308	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Bushings Connection/Risers	Good	
483309	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Bushing Condition	Good	
483310	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Evidence of Insects	None	
483311	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
483312	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
483313	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Amps A Ø	350.0	
483314	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Amps B Ø	350.0	
483315	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Amps C Ø	350.0	
483316	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Bushing Condition	Good	
483317	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
483318	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
483319	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
483320	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
483321	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
483322	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
483323	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
483324	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
483325	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
483326	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Operations A Ø	0	
483327	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Operations B Ø	0	
483328	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Operations C Ø	0	
483329	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Operations Ground	0	
483330	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Follow-up Action Required?	n	
483331	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Follow-up Action Required?	n	
483332	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Foundation Condition	Good	
483333	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	General Comments		
483334	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	General Comments		
483335	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Grounds in Place?	y	
483336	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Maintenance Operations	0	
483337	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
483338	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
483339	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
483340	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
483341	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
483342	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
483343	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	10.0	
483344	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	10.0	
483345	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	10.0	
483346	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
483347	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
483348	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
483349	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
483350	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
483351	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
483352	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
483353	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
483354	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
483355	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
483356	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
483357	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
483358	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
483359	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
483360	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
483361	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	General Comments		
483362	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
483363	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
483364	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Tank Paint Condition	Good	
483365	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Moisture and Leak Free?	y	
483366	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Heaters (All) Functioning?	y	
483367	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Grounds in Place?	y	
483368	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	General Comments		
483369	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Foundation Condition	Good	
483370	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Follow-up Action Required?	n	
483371	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Foundation Condition	Good	
483372	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
483373	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
483374	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
483375	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
483376	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
483377	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
483378	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
483379	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
483380	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
483381	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
483382	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	9 Month Operations	5	
483383	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
483384	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
483385	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	General Comments		
483386	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Grounds in Place?	y	
483387	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Heaters (All) Functioning?	y	
483388	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Maintenance Operations	0	
483389	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Moisture and Leak Free?	y	
483390	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Operations Counter AF	628	
483391	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
483392	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
483393	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Maintenance Operations	0	
483394	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
483395	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Grounds in Place?	y	
483396	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	General Comments		
483397	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	General Comments		
483398	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Foundation Condition	Good	
483399	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Follow-up Action Required?	n	
483400	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC Operations Since Last Insp	338	
483401	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Follow-up Action Required?	n	
483402	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
483403	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	245.00	
483404	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
483405	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
483406	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
483407	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
483408	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	VRR Time Delay	30	Seconds
483409	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
483410	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
483411	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
483412	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Operations Ground	0	
483413	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Operations C Ø	0	
483414	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Operations B Ø	0	
483415	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
483416	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC Min Tap Position	7L	
483417	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC Max Tap Position	6L	
483418	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC Current Tap Position	6L	
483419	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
483420	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Winding Temp Present	32	°C
483421	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Winding Temp Max	40	°C
483422	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2660	
483423	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
483424	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
483425	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
483426	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
483427	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
483428	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
483429	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
483430	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
483431	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC As Left Counter	84957	
483432	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC As Found Counter	84957	
483433	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
483434	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Unknown Operations	0	
483435	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
483436	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Operations Counter AF	185	
483437	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Operations Counter AL	185	
483438	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Operations This Read Vac	2	
483439	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Switching Operations	2	
483440	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Tank Paint Condition	Good	
483441	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Unknown Operations	0	
483442	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
483443	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
483444	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
483445	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
483446	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
483447	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
483448	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
483449	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Operations Counter AL	628	
483450	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Operations This Read Vac	5	
483451	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
483452	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
483453	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
483454	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
483455	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
483456	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
483457	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
483458	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Switching Operations	5	
483459	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
483460	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
483461	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
483462	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
483463	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	20.0	
483464	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	20.0	
483465	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	20.0	
483466	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Tank Paint Condition	Good	
483467	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Unknown Operations	0	
483468	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
483469	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
483470	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Unknown Operations	0	
483471	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Tank Paint Condition	Good	
483472	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Switching Operations	2	
483473	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Operations This Read Vac	2	
483474	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Operations Counter AL	157	
483475	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Operations Counter AF	155	
483476	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
483477	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Bushing Condition	Good	
483478	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
483479	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
483480	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
483481	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
483482	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
483483	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Regulator As Left Counter	7738	
483484	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
483485	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
483486	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Tank Leaks	None	
483487	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
483488	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
483489	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
483490	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
483491	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
483492	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
483493	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
483494	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
483495	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
483496	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
483497	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Equipment Properly Labeled?	y	
483498	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Cabinet Paint Condition	Good	
483499	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
483500	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
483501	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
483502	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
483503	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
483504	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
483505	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
483506	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Bushings Connection/Risers	Good	
483507	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
483508	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	13.0	VDC
483509	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	36.0	VDC
483510	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
483511	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
483512	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	78	°F
483513	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
483514	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
483515	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
483516	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
483517	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
483518	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
483519	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
483520	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
483521	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
483522	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Tank Leaks	None	
483523	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
483524	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
483525	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
483526	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
483527	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
483528	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
483529	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
483530	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
483531	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	General Comments		
483532	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	Follow-up Action Required?	n	
483533	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
483534	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	Battery Charger Current	10.1	amps
483535	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	As Left Float Voltage	52.1	VDC
483536	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	As Found Float Voltage	52.1	VDC
483537	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.710	millivolts
483538	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
483539	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
483540	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
483541	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	General Comments		
483542	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
483543	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
483544	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
483545	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
483546	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
483547	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
483548	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
483549	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Radiator Leaks	None	
483550	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
483551	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Grounds in Place?	y	
483552	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	General Comments		
483553	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
483554	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Foundation Condition	Good	
483555	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
483556	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
483557	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
483558	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
483559	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	74	°F
483560	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Grounds in Place?	y	
483561	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	General Comments		
483562	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	General Comments		
483563	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Foundation Condition	Good	
483564	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Follow-up Action Required?	n	
483565	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Follow-up Action Required?	n	
483566	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Operations Ground	0	
483567	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Operations C Ø	0	
483568	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Operations B Ø	0	
483569	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Operations A Ø	0	
483570	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	737	
483571	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
483572	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
483573	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
483574	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
483575	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
483576	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
483577	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
483578	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BCH000613	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
483579	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BCH000613	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
483580	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
483581	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
483582	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
483583	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
483584	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
483585	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
483586	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
483587	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
483588	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
483589	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
483590	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
483591	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
483592	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
483593	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
483594	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1486	
483595	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1486	
483596	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
483597	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
483598	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
483599	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
483600	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
483601	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
483602	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
483603	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
483604	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
483605	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
483606	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
483607	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
483608	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
483609	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
483610	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
483611	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
483612	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
483613	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
483614	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
483615	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
483616	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	VRR Time Delay	30	Seconds
483617	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
483618	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
483619	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
483620	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Unknown Operations	0	
483621	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Tank Paint Condition	Good	
483622	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	LTC Operation Checked?	y	
483623	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	General Comments		
483624	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	Follow-up Action Required?	n	
483625	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	All Connections OK?	y	
483626	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
483627	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
483628	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
483629	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
483630	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	737	
483631	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
483632	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
483633	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	General Comments		
483634	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
483635	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
483636	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
483637	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Switching Operations	0	
483638	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Operations This Read Vac	0	
483639	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Operations Counter AL	187	
483640	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Operations Counter AF	187	
483641	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
483642	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Maintenance Operations	0	
483643	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
483644	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
483645	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	VRR Time Delay	30	Seconds
483646	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
483647	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
483648	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
483649	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
483650	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
483651	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
483652	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
483653	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Regulator As Left Counter	7068	
483654	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
483655	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
483656	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Tank Leaks	None	
483657	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
483658	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
483659	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	9 Month Operations	5	
483660	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
483661	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
483662	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
483663	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
483664	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Follow-up Action Required?	n	
483665	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
483666	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
483667	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
483668	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
483669	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
483670	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Amps A Ø	175.0	
483671	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	All Connections OK?	y	
483672	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	Follow-up Action Required?	n	
483673	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	General Comments		
483674	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	LTC Operation Checked?	y	
483675	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
483676	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
483677	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
483678	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	VRR Time Delay	30	Seconds
483679	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Amps B Ø	145.0	
483680	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Amps C Ø	145.0	
483681	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Bushing Condition	Good	
483682	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Bushings Connection/Risers	Good	
483683	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
483684	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
483685	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
483686	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Cabinet Paint Condition	Good	
483687	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Equipment Properly Labeled?	y	
483688	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
483689	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
483690	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
483691	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
483692	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
483693	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
483694	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
483695	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
483696	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
483697	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
483698	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	LTC Operation Checked?	y	
483699	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	General Comments		
483700	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	Follow-up Action Required?	n	
483701	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	All Connections OK?	y	
483702	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
483703	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	General Comments		
483704	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	General Comments		
483705	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
483706	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Oil Temp Max	35	°C
483707	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
483708	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
483709	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	LTC Totalizer Reading	10512.00	kw
483710	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
483711	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	General Comments		
483712	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	General Comments		
483713	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
483714	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
483715	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	General Comments		
483716	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
483717	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
483718	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
483719	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
483720	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
483721	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	All Connections OK?	y	
483722	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	Follow-up Action Required?	n	
483723	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	General Comments		
483724	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	LTC Operation Checked?	y	
483725	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
483726	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
483727	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
483728	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
483729	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
483730	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
483731	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
483732	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
483733	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
483734	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
483735	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
483736	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
483737	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
483738	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
483739	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Regulator As Left Counter	6657	
483740	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Clear of Trash?	y	
483741	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
483742	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
483743	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Tank Leaks	None	
483744	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
483745	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
483746	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
483747	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
483748	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	999752	
483749	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	999752	
483750	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	3	
483751	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
483752	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
483753	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
483754	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
483755	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
483756	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BCH000879	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
483757	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BCH000879	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
483758	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
483759	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
483760	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
483761	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	General Comments		
483762	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
483763	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BCH000879	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
483764	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BCH000879	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
483765	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BCH000879	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
483766	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BCH000879	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
483767	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BCH000879	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
483768	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
483769	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
483770	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
483771	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
483772	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
483773	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Follow-up Action Required?	n	
483774	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
483775	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
483776	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
483777	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Totalizer Meter Reading	.5230	
483778	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
483779	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Cabinet Paint Condition	Good	
483780	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Equipment Properly Labeled?	y	
483781	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
483782	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
483783	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
483784	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
483785	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
483786	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
483787	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
483788	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Operations A Ø	0	
483789	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Operations B Ø	0	
483790	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Operations C Ø	0	
483791	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Unknown Operations	0	
483792	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Tank Paint Condition	Good	
483793	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Switching Operations	0	
483794	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Operations This Read Vac	0	
483795	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Operations Counter AL	230	
483796	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
483797	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Operations Counter AF	230	
483798	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Moisture and Leak Free?	y	
483799	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
483800	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
483801	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
483802	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
483803	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
483804	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
483805	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
483806	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
483807	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	General Comments		
483808	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
483809	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
483810	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
483811	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
483812	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
483813	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
483814	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
483815	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Equipment Properly Labeled?	y	
483816	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Cabinet Paint Condition	Good	
483817	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
483818	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
483819	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
483820	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
483821	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
483822	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
483823	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
483824	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
483825	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
483826	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
483827	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
483828	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
483829	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
483830	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
483831	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
483832	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	LTCC000252	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
483833	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	LTCC000252	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
483834	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	LTCC000252	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
483835	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	LTCC000252	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
483836	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	LTCC000252	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
483837	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	LTCC000252	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
483838	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	LTCC000252	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
483839	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	LTCC000252	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
483840	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
483841	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
483842	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
483843	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
483844	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
483845	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
483846	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
483847	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
483848	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Operations A Ø	0	
483849	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Operations B Ø	0	
483850	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Operations C Ø	0	
483851	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
483852	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
483853	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
483854	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
483855	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
483856	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
483857	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
483858	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
483859	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
483860	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
483861	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
483862	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
483863	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
483864	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
483865	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
483866	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
483867	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Totalizer Meter Reading	.5000	
483868	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Winding Temp Max	70	°C
483869	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Winding Temp Present	40	°C
483870	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
483871	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC Operations Since Last Insp	337	
483872	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC Min Tap Position	11L	
483873	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC Max Tap Position	3L	
483874	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
483875	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
483876	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
483877	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
483878	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
483879	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
483880	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Operations Ground	0	
483881	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Follow-up Action Required?	n	
483882	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Follow-up Action Required?	n	
483883	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Foundation Condition	Good	
483884	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	General Comments		
483885	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Amps A Ø	300.0	
483886	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
483887	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Follow-up Action Required?	n	
483888	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Operations Ground	0	
483889	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Operations C Ø	0	
483890	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Operations B Ø	0	
483891	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Operations A Ø	0	
483892	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
483893	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
483894	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
483895	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Equipment Properly Labeled?	y	
483896	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Cabinet Paint Condition	Good	
483897	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
483898	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
483899	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Operations Ground	0	
483900	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Operations C Ø	0	
483901	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
483902	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Operations A Ø	0	
483903	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
483904	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
483905	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
483906	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
483907	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
483908	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
483909	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
483910	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
483911	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
483912	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Bushing Condition	Good	
483913	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Amps C Ø	305.0	
483914	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Amps B Ø	280.0	
483915	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Amps A Ø	290.0	
483916	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
483917	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
483918	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
483919	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	9 Month Operations	2	
483920	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
483921	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
483922	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Grounds in Place?	y	
483923	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	General Comments		
483924	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	General Comments		
483925	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Foundation Condition	Good	
483926	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Follow-up Action Required?	n	
483927	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Follow-up Action Required?	n	
483928	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Operations This Read Vac	4	
483929	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Operations Counter AL	481	
483930	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
483931	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
483932	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
483933	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
483934	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Amps B Ø	300.0	
483935	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Operations Counter AF	481	
483936	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Moisture and Leak Free?	y	
483937	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Maintenance Operations	0	
483938	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
483939	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
483940	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Oil Temp Max	60	°C
483941	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Oil Temp Present	30	°C
483942	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
483943	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
483944	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
483945	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
483946	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
483947	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	PF000039	PowerFuse	BR-GND TR 1	Disconnect Powerfuse Inspection	General Comments	OK	
483948	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
483949	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
483950	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	PF000039	PowerFuse	BR-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
483951	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
483952	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
483953	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
483954	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
483955	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
483956	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
483957	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
483958	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
483959	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Operations Ground	0	
483960	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Operations C Ø	0	
483961	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Operations B Ø	0	
483962	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Operations A Ø	0	
483963	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
483964	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
483965	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
483966	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	General Comments		
483967	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Amps A Ø	120.0	
483968	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
483969	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
483970	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
483971	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
483972	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	9 Month Operations	9	
483973	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	General Comments		
483974	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Foundation Condition	Good	
483975	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Follow-up Action Required?	n	
483976	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC Max Tap Position	Neutral	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
483977	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC Min Tap Position	11L	
483978	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
483979	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
483980	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
483981	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
483982	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
483983	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
483984	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
483985	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
483986	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
483987	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
483988	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
483989	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Follow-up Action Required?	n	
483990	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Operations Ground	0	
483991	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Operations C Ø	0	
483992	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Operations B Ø	0	
483993	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Operations A Ø	0	
483994	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
483995	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
483996	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC Operations Since Last Insp	509	
483997	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
483998	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
483999	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
484000	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
484001	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
484002	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
484003	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Tank Paint Condition	Good	
484004	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
484005	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
484006	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
484007	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
484008	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
484009	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
484010	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
484011	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
484012	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
484013	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
484014	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
484015	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Unknown Operations	0	
484016	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
484017	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
484018	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
484019	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
484020	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
484021	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
484022	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
484023	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	355	
484024	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	9 Month Operations	7	
484025	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
484026	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
484027	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
484028	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Amps A Ø	10.0	
484029	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Amps B Ø	10.0	
484030	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Amps C Ø	10.0	
484031	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Bushing Condition	Good	
484032	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Bushings Connection/Risers	Good	
484033	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
484034	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
484035	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	3	
484036	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Heaters (All) Functioning?	y	
484037	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Grounds in Place?	y	
484038	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	VRR Time Delay	30	Seconds
484039	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
484040	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
484041	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
484042	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
484043	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
484044	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
484045	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
484046	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
484047	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Bushings Connection/Risers	Good	
484048	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC Operations Since Last Insp	667	
484049	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Bushing Condition	Good	
484050	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Amps C Ø	140.0	
484051	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Amps B Ø	130.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
484052	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
484053	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	PF000038	PowerFuse	BR-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
484054	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	PF000038	PowerFuse	BR-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
484055	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Amps A Ø	100.0	
484056	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
484057	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
484058	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	67	°F
484059	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
484060	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
484061	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
484062	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
484063	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
484064	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
484065	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
484066	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
484067	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
484068	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
484069	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
484070	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	9 Month Operations	4	
484071	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
484072	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
484073	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
484074	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
484075	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
484076	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
484077	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
484078	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
484079	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	General Comments		
484080	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
484081	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
484082	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
484083	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	General Comments		
484084	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
484085	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Unknown Operations	0	
484086	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
484087	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
484088	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Equipment Properly Labeled?	y	
484089	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Cabinet Paint Condition	Good	
484090	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
484091	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
484092	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
484093	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Bushings Connection/Risers	Good	
484094	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Bushing Condition	Good	
484095	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Amps C Ø	120.0	
484096	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Tank Paint Condition	Good	
484097	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Switching Operations	8	
484098	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Operations This Read Vac	8	
484099	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	Follow-up Action Required?	n	
484100	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Operations Counter AL	365	
484101	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Operations Counter AF	365	
484102	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Moisture and Leak Free?	y	
484103	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Maintenance Operations	0	
484104	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Heaters (All) Functioning?	y	
484105	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Grounds in Place?	y	
484106	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
484107	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	General Comments		
484108	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	General Comments		
484109	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC As Found Counter	34060	
484110	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Amps B Ø	120.0	
484111	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC As Left Counter	34060	
484112	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
484113	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC Current Tap Position	5L	
484114	4/9/2019 10:28	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
484115	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
484116	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Amps B Ø	140.0	
484117	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Amps A Ø	145.0	
484118	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	9 Month Operations	5	
484119	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Clear of Trash?	y	
484120	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
484121	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
484122	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
484123	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
484124	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
484125	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Amps A Ø	20.0	
484126	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Amps B Ø	20.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
484127	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Amps C Ø	20.0	
484128	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Bushing Condition	Good	
484129	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Bushings Connection/Risers	Good	
484130	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
484131	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
484132	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
484133	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
484134	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Cabinet Paint Condition	Good	
484135	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Equipment Properly Labeled?	y	
484136	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Accumulated Fault Duty C Ph V	3.58	%
484137	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
484138	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
484139	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
484140	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	General Comments		
484141	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
484142	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Accumulated Fault Duty B Ph V	5.37	%
484143	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Accumulated Fault Duty A Ph V	4.17	%
484144	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	9 Month Operations	10	
484145	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
484146	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
484147	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
484148	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Operations A Ø	0	
484149	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Operations B Ø	0	
484150	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Operations C Ø	0	
484151	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
484152	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
484153	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Operations Ground	0	
484154	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Follow-up Action Required?	n	
484155	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Follow-up Action Required?	n	
484156	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Foundation Condition	Good	
484157	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	General Comments		
484158	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	General Comments		
484159	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
484160	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
484161	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
484162	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
484163	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	69	°F
484164	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	10.0	
484165	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	10.0	
484166	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	10.0	
484167	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
484168	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
484169	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
484170	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
484171	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
484172	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
484173	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
484174	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
484175	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
484176	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
484177	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	General Comments		
484178	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
484179	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
484180	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Operations Counter	2329	
484181	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
484182	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
484183	4/9/2019 13:44	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
484184	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Unknown Operations	0	
484185	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Tank Paint Condition	Good	
484186	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Switching Operations	4	
484187	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
484188	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
484189	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
484190	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
484191	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
484192	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
484193	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
484194	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
484195	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Oil Status	Good	
484196	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
484197	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Operations This Read Vac	4	
484198	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Operations Counter AL	205	
484199	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Operations Counter AF	205	
484200	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Moisture and Leak Free?	y	
484201	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
484202	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Operations Counter AL	685	
484203	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	9 Month Operations	2	
484204	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
484205	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
484206	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
484207	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Amps A Ø	320.0	
484208	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Amps B Ø	320.0	
484209	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Operations A Ø	1	
484210	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Operations B Ø	0	
484211	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Operations C Ø	0	
484212	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Operations Ground	0	
484213	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Follow-up Action Required?	n	
484214	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Follow-up Action Required?	n	
484215	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Foundation Condition	Good	
484216	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	General Comments		
484217	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Amps C Ø	320.0	
484218	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Operations Counter AF	685	
484219	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Moisture and Leak Free?	y	
484220	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Bushing Condition	Good	
484221	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
484222	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
484223	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Maintenance Operations	0	
484224	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
484225	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Maintenance Operations	0	
484226	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Heaters (All) Functioning?	y	
484227	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
484228	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Grounds in Place?	y	
484229	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	General Comments		
484230	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	General Comments		
484231	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Foundation Condition	Good	
484232	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Follow-up Action Required?	n	
484233	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Follow-up Action Required?	n	
484234	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Operations Ground	0	
484235	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Operations C Ø	0	
484236	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Operations B Ø	0	
484237	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Operations A Ø	0	
484238	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
484239	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
484240	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
484241	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Equipment Properly Labeled?	y	
484242	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	General Comments		
484243	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Grounds in Place?	y	
484244	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Heaters (All) Functioning?	y	
484245	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Maintenance Operations	0	
484246	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Moisture and Leak Free?	y	
484247	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Operations Counter AF	271	
484248	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Operations Counter AL	271	
484249	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
484250	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
484251	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
484252	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Cabinet Paint Condition	Good	
484253	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
484254	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
484255	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
484256	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
484257	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
484258	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
484259	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	General Comments		
484260	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
484261	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
484262	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
484263	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
484264	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
484265	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
484266	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC As Found Counter	429902	
484267	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC As Left Counter	429904	
484268	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
484269	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC Current Tap Position	1L	
484270	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Unknown Operations	0	
484271	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Unknown Operations	0	
484272	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Tank Paint Condition	Good	
484273	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
484274	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
484275	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
484276	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
484277	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
484278	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Foundation Condition	Good	
484279	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
484280	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
484281	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	General Comments		
484282	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
484283	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
484284	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
484285	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
484286	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
484287	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
484288	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
484289	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
484290	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
484291	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
484292	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
484293	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
484294	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
484295	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
484296	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
484297	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
484298	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
484299	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Follow-up Action Required?	n	
484300	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
484301	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
484302	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	General Comments		
484303	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	General Comments		
484304	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Unknown Operations	0	
484305	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Tank Paint Condition	Good	
484306	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Switching Operations	4	
484307	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Switching Operations	1	
484308	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Operations This Read Vac	1	
484309	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Operations Counter AL	363	
484310	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Operations Counter AF	363	
484311	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Moisture and Leak Free?	y	
484312	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Maintenance Operations	0	
484313	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
484314	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
484315	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	LTC Totalizer Reading	9000.00	kw
484316	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
484317	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC Min Tap Position	8L	
484318	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC Operations Since Last Insp	582	
484319	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
484320	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Unknown Operations	0	
484321	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Tank Paint Condition	Good	
484322	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Switching Operations	2	
484323	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Operations This Read Vac	2	
484324	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Operations Counter AL	178	
484325	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Operations Counter AF	176	
484326	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
484327	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Maintenance Operations	0	
484328	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
484329	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Grounds in Place?	y	
484330	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	General Comments		
484331	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	General Comments		
484332	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Foundation Condition	Good	
484333	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Follow-up Action Required?	n	
484334	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Follow-up Action Required?	n	
484335	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
484336	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Heaters (All) Functioning?	y	
484337	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Grounds in Place?	y	
484338	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	General Comments		
484339	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	General Comments		
484340	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Foundation Condition	Good	
484341	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Follow-up Action Required?	n	
484342	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Bushings Connection/Risers	Good	
484343	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Bushing Condition	Good	
484344	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Amps C Ø	10.0	
484345	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Amps B Ø	10.0	
484346	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Amps A Ø	10.0	
484347	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
484348	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Grounds in Place?	y	
484349	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Heaters (All) Functioning?	y	
484350	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Maintenance Operations	0	
484351	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
484352	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Operations Counter AF	60	
484353	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Operations Counter AL	60	
484354	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Operations This Read Vac	5	
484355	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
484356	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Switching Operations	5	
484357	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Tank Paint Condition	Good	
484358	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Operations This Read Vac	4	
484359	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Operations Counter AL	487	
484360	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Operations Counter AF	487	
484361	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Moisture and Leak Free?	y	
484362	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Maintenance Operations	0	
484363	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Heaters (All) Functioning?	y	
484364	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Grounds in Place?	y	
484365	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
484366	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
484367	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
484368	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
484369	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
484370	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
484371	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
484372	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Follow-up Action Required?	n	
484373	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	General Comments		
484374	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	General Comments		
484375	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
484376	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
484377	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	9 Month Operations	4	
484378	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Unknown Operations	0	
484379	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
484380	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Foundation Condition	Good	
484381	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Follow-up Action Required?	n	
484382	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Follow-up Action Required?	n	
484383	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Operations Ground	0	
484384	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Operations C Ø	0	
484385	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Operations B Ø	0	
484386	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Operations A Ø	0	
484387	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
484388	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
484389	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
484390	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
484391	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Vegetation	None	
484392	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Operations This Read Vac	1	
484393	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
484394	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Switching Operations	0	
484395	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Tank Paint Condition	Good	
484396	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	PF000045	PowerFuse	BR-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
484397	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	PF000045	PowerFuse	BR-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
484398	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
484399	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
484400	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
484401	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
484402	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	PF000044	PowerFuse	BR-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
484403	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	PF000044	PowerFuse	BR-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
484404	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	PF000043	PowerFuse	BR-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
484405	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	PF000043	PowerFuse	BR-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
484406	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	PF000041	PowerFuse	BR-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
484407	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	PF000041	PowerFuse	BR-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
484408	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	PF000040	PowerFuse	BR-GND TR 2	Disconnect Powerfuse Inspection	General Comments	OK	
484409	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	PF000040	PowerFuse	BR-GND TR 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
484410	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
484411	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
484412	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
484413	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
484414	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	Follow-up Action Required?	n	
484415	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
484416	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	General Comments		
484417	4/9/2019 9:23	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	General Comments		
484418	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Maintenance Operations	0	
484419	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
484420	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
484421	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Heaters (All) Functioning?	y	
484422	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
484423	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	LTC Totalizer Reading	6220.80	kw
484424	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
484425	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	General Comments		
484426	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
484427	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
484428	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
484429	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Grounds in Place?	y	
484430	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	General Comments		
484431	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Operations Counter AL	271	
484432	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Operations This Read Vac	6	
484433	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Switching Operations	6	
484434	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Tank Paint Condition	Good	
484435	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Unknown Operations	0	
484436	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	General Comments		
484437	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
484438	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Oil Temp Max	40	°C
484439	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
484440	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Oil Temp Present	40	°C
484441	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
484442	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
484443	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
484444	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
484445	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
484446	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
484447	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
484448	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
484449	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
484450	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
484451	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Vegetation	None	
484452	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
484453	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
484454	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	General Comments		
484455	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
484456	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
484457	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
484458	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
484459	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
484460	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
484461	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Clear of Trash?	y	
484462	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
484463	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
484464	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Ambient Temp	74	°F
484465	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
484466	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
484467	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
484468	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	General Comments		
484469	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
484470	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
484471	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Foundation Condition	Good	
484472	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
484473	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
484474	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
484475	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
484476	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
484477	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
484478	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
484479	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
484480	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
484481	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
484482	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
484483	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
484484	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
484485	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
484486	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
484487	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
484488	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Totalizer Meter Reading	.7146	
484489	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Winding Temp Max	40	°C
484490	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Winding Temp Present	40	°C
484491	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
484492	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
484493	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Foundation Condition	Good	
484494	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Follow-up Action Required?	n	
484495	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Unknown Operations	0	
484496	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
484497	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
484498	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
484499	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
484500	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Clear of Trash?	y	
484501	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
484502	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Switching Operations	5	
484503	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
484504	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Operations This Read Vac	5	
484505	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	All Connections OK?	y	
484506	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
484507	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
484508	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
484509	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
484510	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
484511	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
484512	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
484513	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	General Comments		
484514	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
484515	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
484516	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	General Comments		
484517	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
484518	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	General Comments		
484519	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	General Comments		
484520	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
484521	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	LTC Totalizer Reading	12862.80	kw
484522	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
484523	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
484524	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Cabinet Paint Condition	Good	
484525	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Equipment Properly Labeled?	y	
484526	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
484527	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
484528	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Vegetation	None	
484529	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
484530	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	355	
484531	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
484532	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
484533	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
484534	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	51	
484535	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	52	
484536	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
484537	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Tank Leaks	None	
484538	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
484539	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
484540	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Regulator As Left Counter	666655	
484541	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
484542	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
484543	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
484544	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
484545	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Operations A Ø	0	
484546	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Operations B Ø	0	
484547	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Operations C Ø	0	
484548	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Operations Ground	0	
484549	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
484550	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Follow-up Action Required?	n	
484551	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Follow-up Action Required?	n	
484552	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Foundation Condition	Good	
484553	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	General Comments		
484554	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
484555	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	General Comments		
484556	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Grounds in Place?	y	
484557	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Heaters (All) Functioning?	y	
484558	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Maintenance Operations	0	
484559	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Moisture and Leak Free?	y	
484560	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Operations Counter AF	271	
484561	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
484562	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
484563	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Operations Counter AL	639	
484564	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Operations Counter AF	639	
484565	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
484566	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Foundation Condition	Good	
484567	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
484568	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
484569	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
484570	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
484571	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Moisture and Leak Free?	y	
484572	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
484573	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
484574	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
484575	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
484576	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
484577	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
484578	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
484579	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
484580	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
484581	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
484582	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Equipment Properly Labeled?	y	
484583	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Cabinet Paint Condition	Good	
484584	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
484585	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
484586	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
484587	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
484588	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
484589	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
484590	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
484591	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	General Comments		
484592	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
484593	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
484594	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
484595	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
484596	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
484597	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
484598	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Evidence of Insects	Yes_needs_sprayed	
484599	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
484600	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
484601	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Floor Swept?	y	
484602	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
484603	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
484604	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Bushings Connection/Risers	Good	
484605	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Bushing Condition	Good	
484606	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Amps C Ø	240.0	
484607	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Amps B Ø	221.0	
484608	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Amps A Ø	239.0	
484609	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
484610	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
484611	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Bushings Connection/Risers	Good	
484612	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Bushing Condition	Good	
484613	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Amps C Ø	100.0	
484614	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Amps B Ø	100.0	
484615	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Amps A Ø	100.0	
484616	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
484617	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
484618	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
484619	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	9 Month Operations	11	
484620	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
484621	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
484622	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
484623	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	9 Month Operations	2	
484624	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Foundation Condition	Good	
484625	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	General Comments		
484626	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
484627	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
484628	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Panels Dusted?	y	
484629	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
484630	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
484631	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
484632	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
484633	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
484634	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
484635	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
484636	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
484637	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
484638	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
484639	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
484640	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	General Comments		
484641	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
484642	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	General Comments		
484643	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Foundation Condition	Good	
484644	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Follow-up Action Required?	n	
484645	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Follow-up Action Required?	n	
484646	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Operations Ground	0	
484647	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Operations C Ø	0	
484648	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Operations B Ø	0	
484649	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Follow-up Action Required?	n	
484650	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
484651	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Max Tap Position	1L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
484652	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
484653	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	General Comments		
484654	4/9/2019 12:43	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
484655	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Operations Ground	0	
484656	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Operations C Ø	0	
484657	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Operations B Ø	0	
484658	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Operations A Ø	0	
484659	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
484660	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
484661	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
484662	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
484663	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
484664	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
484665	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
484666	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
484667	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
484668	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Follow-up Action Required?	n	
484669	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
484670	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
484671	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
484672	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
484673	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
484674	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
484675	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
484676	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
484677	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
484678	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
484679	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
484680	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
484681	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	General Comments		
484682	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	General Comments		
484683	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
484684	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
484685	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
484686	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
484687	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
484688	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Equipment Properly Labeled?	y	
484689	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Cabinet Paint Condition	Good	
484690	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
484691	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
484692	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
484693	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
484694	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
484695	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Follow-up Action Required?	n	
484696	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Follow-up Action Required?	n	
484697	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	LTC Totalizer Reading	1440.00	kw
484698	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
484699	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Oil Temp Max	45	°C
484700	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Oil Temp Present	40	°C
484701	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
484702	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
484703	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
484704	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
484705	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
484706	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
484707	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
484708	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
484709	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Totalizer Meter Reading	.0800	
484710	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Winding Temp Max	30	°C
484711	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Winding Temp Present	30	°C
484712	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
484713	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	General Comments		
484714	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
484715	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
484716	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
484717	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
484718	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
484719	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
484720	4/9/2019 14:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
484721	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Operations Ground	0	
484722	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Operations C Ø	0	
484723	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Operations B Ø	0	
484724	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Operations A Ø	0	
484725	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
484726	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	LTC Operation Checked?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
484727	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
484728	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
484729	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
484730	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
484731	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
484732	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Moisture and Leak Free?	y	
484733	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Maintenance Operations	0	
484734	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
484735	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
484736	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
484737	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	Follow-up Action Required?	n	
484738	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
484739	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
484740	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
484741	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
484742	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
484743	4/9/2019 16:16	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	General Comments		
484744	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
484745	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
484746	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
484747	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	General Comments		
484748	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Heaters (All) Functioning?	y	
484749	4/9/2019 9:56	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
484750	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Operations Counter AF	340	
484751	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
484752	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	General Comments		
484753	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Equipment Properly Labeled?	y	
484754	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Cabinet Paint Condition	Good	
484755	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
484756	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	Oil Temp Present	45	°C
484757	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	BCH000576	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
484758	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Operations Counter AL	340	
484759	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
484760	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Grounds in Place?	y	
484761	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	General Comments		
484762	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
484763	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	General Comments		
484764	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Foundation Condition	Good	
484765	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
484766	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC Current Tap Position	8L	
484767	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
484768	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC As Left Counter	115244	
484769	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC As Found Counter	115244	
484770	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	General Comments		
484771	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	General Comments		
484772	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
484773	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC As Left Counter	22230	
484774	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
484775	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Equipment Properly Labeled?	y	
484776	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Unknown Operations	0	
484777	4/10/2019 7:43	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Follow-up Action Required?	n	
484778	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
484779	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC As Found Counter	22228	
484780	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	General Comments		
484781	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	General Comments		
484782	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
484783	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	Follow-up Action Required?	n	
484784	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Current Tap Position	5L	
484785	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Follow-up Action Required?	n	
484786	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
484787	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Tank Paint Condition	Good	
484788	4/9/2019 11:32	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	Oil Temp Max	45	°C
484789	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Switching Operations	1	
484790	4/9/2019 6:40	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Operations This Read Vac	1	
484791	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Max Tap Position	2L	
484792	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Min Tap Position	10L	
484793	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Operations Since Last Insp	443	
484794	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
484795	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
484796	4/9/2019 10:13	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
484797	4/9/2019 17:18	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	Follow-up Action Required?	n	
484798	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
484799	4/9/2019 13:33	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
484800	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
484801	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
484802	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Replaced	
484803	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	y	
484804	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
484805	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	64	°F
484806	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
484807	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
484808	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	water last changed 1-7-2015	
484809	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
484810	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
484811	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
484812	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
484813	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
484814	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
484815	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	2	
484816	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	190.0	
484817	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	150.0	
484818	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
484819	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
484820	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
484821	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	30	
484822	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	244	
484823	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	244	
484824	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	150.0	
484825	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
484826	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
484827	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
484828	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	1	
484829	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	1	
484830	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
484831	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
484832	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
484833	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	A phase and B phase IOC targets	
484834	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
484835	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	230.0	
484836	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
484837	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
484838	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
484839	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
484840	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
484841	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
484842	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
484843	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
484844	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
484845	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
484846	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	152	
484847	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	152	
484848	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
484849	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
484850	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
484851	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	230.0	
484852	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	210.0	
484853	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
484854	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
484855	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
484856	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
484857	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
484858	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
484859	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
484860	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
484861	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	30.0	
484862	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
484863	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
484864	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	100.0	
484865	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
484866	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
484867	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
484868	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
484869	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
484870	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
484871	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
484872	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
484873	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
484874	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
484875	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
484876	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	203	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
484877	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	203	
484878	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
484879	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
484880	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
484881	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
484882	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
484883	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	10.0	
484884	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
484885	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
484886	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
484887	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
484888	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
484889	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
484890	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
484891	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
484892	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
484893	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
484894	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
484895	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
484896	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
484897	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
484898	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	86	
484899	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
484900	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	86	
484901	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
484902	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
484903	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
484904	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
484905	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
484906	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
484907	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
484908	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
484909	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
484910	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
484911	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
484912	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
484913	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
484914	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
484915	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
484916	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	54	
484917	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	54	
484918	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
484919	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
484920	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
484921	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
484922	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
484923	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
484924	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
484925	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
484926	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
484927	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
484928	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
484929	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
484930	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
484931	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
484932	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	50.0	
484933	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	30.0	
484934	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	40.0	
484935	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
484936	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
484937	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
484938	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
484939	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
484940	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
484941	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
484942	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	237	
484943	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	237	
484944	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
484945	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
484946	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
484947	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
484948	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
484949	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
484950	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
484951	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
484952	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
484953	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
484954	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
484955	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
484956	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
484957	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
484958	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
484959	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
484960	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
484961	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
484962	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
484963	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
484964	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
484965	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
484966	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
484967	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
484968	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	14	
484969	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
484970	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
484971	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	23	
484972	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	23	
484973	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
484974	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
484975	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
484976	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
484977	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
484978	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
484979	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
484980	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
484981	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
484982	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
484983	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
484984	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
484985	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
484986	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
484987	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
484988	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
484989	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
484990	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
484991	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
484992	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
484993	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
484994	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
484995	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
484996	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
484997	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	17	
484998	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
484999	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
485000	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
485001	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
485002	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	431	
485003	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	431	
485004	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
485005	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
485006	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	1	
485007	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
485008	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
485009	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
485010	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
485011	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	25.0	
485012	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	25.0	
485013	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	25.0	
485014	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	53	
485015	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
485016	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
485017	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	1	
485018	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	1	
485019	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
485020	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	100	
485021	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
485022	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
485023	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
485024	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	100	
485025	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	2	
485026	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
485027	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
485028	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
485029	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
485030	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
485031	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	A phasse and B phase Inst targets	
485032	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
485033	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
485034	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
485035	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
485036	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
485037	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	20.0	
485038	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
485039	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
485040	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
485041	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
485042	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	1	
485043	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
485044	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	6	
485045	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	346	
485046	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	346	
485047	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
485048	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
485049	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	c phase inst target	
485050	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
485051	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
485052	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	50.0	
485053	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	25.0	
485054	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
485055	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
485056	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
485057	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
485058	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
485059	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
485060	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
485061	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
485062	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
485063	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
485064	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
485065	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
485066	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
485067	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
485068	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
485069	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
485070	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	0	
485071	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	181	
485072	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
485073	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
485074	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
485075	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	30.0	
485076	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	20.0	
485077	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
485078	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
485079	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
485080	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	25.0	
485081	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
485082	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
485083	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
485084	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
485085	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
485086	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
485087	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
485088	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LTCC000116	LTCControl	SSC-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
485089	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LTCC000116	LTCControl	SSC-Offline-Distribution	LTC Control Insp	General Comments		
485090	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LTCC000116	LTCControl	SSC-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
485091	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LTCC000116	LTCControl	SSC-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
485092	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	6.64	%
485093	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
485094	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	101.0	
485095	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	9.3	%
485096	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
485097	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
485098	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	135.0	
485099	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	34	
485100	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	97.0	
485101	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	34	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
485102	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	137.0	
485103	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
485104	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
485105	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
485106	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
485107	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	General Comments		
485108	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
485109	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
485110	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
485111	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	General Comments	tap changer filter is in place but not plumbed in. Holes do not appear to be drilled on top of tap changer	
485112	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
485113	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
485114	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC Operations Since Last Insp	546	
485115	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1	psi
485116	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
485117	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
485118	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
485119	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	General Comments		
485120	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	General Comments	breer desath	
485121	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC As Found Counter	41032	
485122	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC As Left Counter	41035	
485123	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
485124	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC Current Tap Position	4L	
485125	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
485126	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
485127	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
485128	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	General Comments		
485129	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	LTC Operation Checked?	y	
485130	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
485131	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
485132	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
485133	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
485134	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
485135	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	50	
485136	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
485137	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
485138	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
485139	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	VRR Time Delay	30	Seconds
485140	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC Current Tap Position	6L	
485141	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
485142	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
485143	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
485144	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
485145	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
485146	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
485147	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
485148	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
485149	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
485150	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
485151	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
485152	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
485153	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
485154	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
485155	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
485156	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
485157	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
485158	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
485159	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
485160	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
485161	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
485162	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
485163	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
485164	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
485165	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
485166	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
485167	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
485168	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
485169	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
485170	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
485171	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0	%
485172	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
485173	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
485174	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
485175	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
485176	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
485177	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
485178	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
485179	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
485180	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
485181	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
485182	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
485183	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
485184	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
485185	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
485186	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
485187	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
485188	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	General Comments		
485189	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
485190	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
485191	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
485192	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
485193	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Clear of Trash?	y	
485194	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
485195	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
485196	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
485197	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
485198	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	General Comments		
485199	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
485200	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
485201	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
485202	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
485203	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
485204	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
485205	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
485206	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
485207	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
485208	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	General Comments		
485209	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
485210	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
485211	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
485212	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
485213	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
485214	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	
485215	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
485216	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
485217	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
485218	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
485219	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
485220	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
485221	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC As Left Counter	149870	
485222	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
485223	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC As Found Counter	149870	
485224	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
485225	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
485226	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
485227	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
485228	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
485229	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
485230	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC Max Tap Position	3L	
485231	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC Min Tap Position	9L	
485232	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
485233	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
485234	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	35	°C
485235	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	138	
485236	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC Operations Since Last Insp	990	
485237	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
485238	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
485239	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	VRR Time Delay	0	Seconds
485240	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	138	
485241	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
485242	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
485243	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
485244	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
485245	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
485246	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
485247	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
485248	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	General Comments		
485249	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	General Comments		
485250	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC Min Tap Position	8L	
485251	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC Max Tap Position	5R	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
485252	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
485253	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
485254	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
485255	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
485256	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	Follow-up Action Required?	n	
485257	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
485258	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
485259	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
485260	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
485261	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
485262	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Unknown Operations	0	
485263	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Tank Paint Condition	Good	
485264	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
485265	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
485266	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
485267	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
485268	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
485269	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
485270	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
485271	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
485272	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
485273	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
485274	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
485275	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Operations Counter AF	244	
485276	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
485277	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
485278	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
485279	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	40	°C
485280	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
485281	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	2.66	%
485282	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Operations This Read Vac	0	
485283	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Foundation Condition	Good	
485284	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
485285	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Switching Operations	0	
485286	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	6.64	%
485287	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
485288	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	1.33	%
485289	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
485290	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	145.0	
485291	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
485292	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	General Comments		
485293	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	LTC Operation Checked?	y	
485294	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	General Comments		
485295	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	Follow-up Action Required?	n	
485296	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
485297	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
485298	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	All Connections OK?	y	
485299	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
485300	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	General Comments	bottom string of barb wire is broken at corner next to white garage	
485301	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Foundation Condition	Good	
485302	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	LTC Output Voltage Level	122.0	VAC
485303	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
485304	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
485305	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
485306	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
485307	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
485308	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
485309	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	PF000115	PowerFuse	DA-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
485310	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
485311	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Operations Counter AL	244	
485312	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
485313	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
485314	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
485315	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
485316	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
485317	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
485318	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
485319	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
485320	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
485321	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
485322	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
485323	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
485324	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
485325	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Totalizer Meter Reading	.3592	
485326	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Winding Temp Max	25	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
485327	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
485328	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
485329	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
485330	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
485331	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
485332	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
485333	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
485334	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	950	
485335	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	950	
485336	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
485337	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
485338	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
485339	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	LTCC000278	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
485340	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
485341	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
485342	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Winding Temp Present	20	°C
485343	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
485344	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
485345	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
485346	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	50	
485347	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	General Comments		
485348	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
485349	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
485350	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
485351	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
485352	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
485353	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
485354	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
485355	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
485356	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
485357	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
485358	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
485359	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
485360	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
485361	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	PF000115	PowerFuse	DA-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
485362	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
485363	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
485364	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	1724.16	kw
485365	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
485366	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
485367	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
485368	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	9.3	%
485369	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
485370	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
485371	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0	%
485372	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0	%
485373	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
485374	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
485375	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
485376	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
485377	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
485378	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
485379	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
485380	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
485381	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	50	
485382	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	40	°C
485383	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
485384	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	40	°C
485385	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
485386	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
485387	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
485388	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Ambient Temp	66	°F
485389	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
485390	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
485391	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
485392	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
485393	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
485394	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	All Connections OK?	y	
485395	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	Follow-up Action Required?	n	
485396	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
485397	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
485398	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
485399	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
485400	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
485401	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
485402	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
485403	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
485404	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
485405	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
485406	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
485407	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
485408	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
485409	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	LTCC000278	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
485410	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	LTCC000278	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124	VAC
485411	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	LTCC000278	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124	VAC
485412	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	LTCC000278	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
485413	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	LTCC000278	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124	VAC
485414	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	LTCC000278	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
485415	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	LTCC000278	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
485416	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	LTCC000278	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
485417	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
485418	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
485419	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
485420	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
485421	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
485422	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
485423	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
485424	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
485425	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
485426	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
485427	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
485428	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
485429	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
485430	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
485431	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
485432	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	General Comments		
485433	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
485434	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
485435	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Foundation Condition	Good	
485436	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
485437	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
485438	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
485439	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
485440	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
485441	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
485442	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
485443	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
485444	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
485445	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
485446	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
485447	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Vegetation	None	
485448	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
485449	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
485450	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
485451	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	General Comments		
485452	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
485453	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
485454	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
485455	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
485456	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
485457	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
485458	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
485459	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	General Comments		
485460	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
485461	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
485462	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
485463	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
485464	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	493	
485465	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	493	
485466	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
485467	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
485468	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
485469	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
485470	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
485471	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
485472	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
485473	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
485474	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
485475	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
485476	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
485477	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
485478	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
485479	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
485480	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
485481	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
485482	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
485483	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	Oil Temp Present	26	°C
485484	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	Oil Temp Max	34	°C
485485	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
485486	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
485487	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
485488	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
485489	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
485490	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
485491	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
485492	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
485493	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
485494	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	General Comments		
485495	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	General Comments		
485496	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Clear of Trash?	y	
485497	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
485498	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
485499	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
485500	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
485501	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
485502	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
485503	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
485504	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
485505	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
485506	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
485507	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
485508	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
485509	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
485510	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
485511	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
485512	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
485513	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
485514	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
485515	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
485516	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	192.0	
485517	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	185.0	
485518	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	168.0	
485519	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
485520	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
485521	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
485522	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Tank Leaks	None	
485523	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
485524	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
485525	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Regulator As Left Counter	117415	
485526	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
485527	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
485528	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
485529	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
485530	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	PF000097	PowerFuse	DA-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
485531	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	PF000097	PowerFuse	DA-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
485532	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
485533	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
485534	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
485535	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
485536	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	General Comments		
485537	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
485538	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
485539	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
485540	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	Totalizer Meter Reading	.7020	
485541	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
485542	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
485543	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
485544	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
485545	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
485546	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
485547	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
485548	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
485549	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
485550	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
485551	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
485552	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
485553	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
485554	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
485555	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
485556	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
485557	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
485558	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
485559	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
485560	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
485561	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
485562	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
485563	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
485564	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
485565	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
485566	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
485567	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
485568	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
485569	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
485570	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
485571	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
485572	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
485573	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
485574	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
485575	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	466	
485576	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	466	
485577	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
485578	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
485579	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
485580	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
485581	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	528	
485582	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	538	
485583	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
485584	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
485585	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
485586	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
485587	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
485588	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
485589	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
485590	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
485591	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
485592	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
485593	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	General Comments		
485594	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
485595	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
485596	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
485597	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
485598	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
485599	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	35.00	
485600	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
485601	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
485602	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
485603	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
485604	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
485605	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
485606	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Totalizer Meter Reading	.5352	
485607	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
485608	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
485609	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
485610	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
485611	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
485612	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
485613	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
485614	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
485615	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
485616	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
485617	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
485618	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
485619	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
485620	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
485621	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
485622	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
485623	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
485624	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
485625	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
485626	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
485627	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
485628	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.8720	
485629	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
485630	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
485631	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
485632	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
485633	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
485634	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
485635	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
485636	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
485637	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	60	°C
485638	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
485639	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
485640	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	8371.20	kw
485641	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
485642	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
485643	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
485644	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
485645	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
485646	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
485647	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
485648	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
485649	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
485650	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
485651	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
485652	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
485653	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
485654	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
485655	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
485656	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
485657	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
485658	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
485659	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
485660	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
485661	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
485662	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC As Found Counter	236134	
485663	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	General Comments		
485664	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
485665	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
485666	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
485667	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
485668	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
485669	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
485670	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.7	psi
485671	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
485672	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
485673	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
485674	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	General Comments		
485675	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
485676	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
485677	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
485678	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
485679	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
485680	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
485681	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
485682	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
485683	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
485684	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	LTC Totalizer Reading	4212.00	kw
485685	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
485686	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
485687	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
485688	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
485689	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
485690	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
485691	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
485692	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
485693	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
485694	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
485695	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
485696	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
485697	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
485698	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
485699	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
485700	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
485701	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
485702	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
485703	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
485704	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
485705	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
485706	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
485707	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
485708	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
485709	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.3	psi
485710	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
485711	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
485712	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
485713	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
485714	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
485715	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
485716	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
485717	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
485718	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
485719	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
485720	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
485721	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
485722	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
485723	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
485724	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
485725	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
485726	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
485727	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
485728	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
485729	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
485730	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
485731	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC Operations Since Last Insp	277	
485732	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC Min Tap Position	8L	
485733	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC Max Tap Position	4L	
485734	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
485735	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
485736	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	Follow-up Action Required?	n	
485737	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
485738	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
485739	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	General Comments		
485740	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
485741	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
485742	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC Current Tap Position	8L	
485743	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC As Left Counter	236148	
485744	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	LTC Output Voltage Level	122.0	VAC
485745	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	LTC Operation Checked?	y	
485746	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	General Comments		
485747	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	Follow-up Action Required?	n	
485748	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	All Connections OK?	y	
485749	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
485750	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
485751	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	B0426	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
485752	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	B0426	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
485753	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	B0426	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
485754	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	B0426	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
485755	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	B0426	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.4	psi
485756	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	B0426	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
485757	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	B0426	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
485758	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	B0426	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
485759	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
485760	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
485761	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
485762	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
485763	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
485764	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
485765	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
485766	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	232	
485767	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	232	
485768	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	10	
485769	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
485770	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
485771	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
485772	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
485773	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	General Comments		
485774	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
485775	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
485776	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
485777	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
485778	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
485779	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
485780	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
485781	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
485782	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
485783	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
485784	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
485785	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
485786	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
485787	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
485788	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
485789	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
485790	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	9 Month Operations	2	
485791	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
485792	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
485793	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
485794	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Amps A Ø	120.0	
485795	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Amps B Ø	135.0	
485796	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Amps C Ø	140.0	
485797	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Bushing Condition	Good	
485798	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Bushings Connection/Risers	Good	
485799	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
485800	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
485801	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1547	
485802	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
485803	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
485804	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
485805	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	834	
485806	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	834101	
485807	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
485808	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	63	°F
485809	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
485810	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
485811	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
485812	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
485813	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
485814	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
485815	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
485816	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
485817	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
485818	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
485819	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
485820	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
485821	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
485822	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
485823	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	VRR Time Delay	30	Seconds
485824	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
485825	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
485826	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Operations Counter AL	181	
485827	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	4.200	millivolts
485828	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Operations This Read Vac	1	
485829	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Switching Operations	1	
485830	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Tank Paint Condition	Good	
485831	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Unknown Operations	0	
485832	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.1	VDC
485833	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.1	VDC
485834	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.7	amps
485835	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
485836	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
485837	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	General Comments		
485838	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
485839	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	LTCC000772	LTCControl	314-2	LTC Control Insp	VRR Time Delay	30	Seconds
485840	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	LTCC000772	LTCControl	314-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
485841	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	LTCC000772	LTCControl	314-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
485842	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	LTCC000772	LTCControl	314-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
485843	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	LTCC000772	LTCControl	314-2	LTC Control Insp	LTC Operation Checked?	y	
485844	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	LTCC000772	LTCControl	314-2	LTC Control Insp	General Comments		
485845	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	LTCC000772	LTCControl	314-2	LTC Control Insp	Follow-up Action Required?	n	
485846	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	LTCC000772	LTCControl	314-2	LTC Control Insp	All Connections OK?	y	
485847	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
485848	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
485849	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
485850	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
485851	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
485852	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
485853	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
485854	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
485855	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
485856	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
485857	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
485858	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
485859	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
485860	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
485861	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
485862	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
485863	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
485864	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
485865	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
485866	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
485867	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
485868	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	10.0	
485869	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	10.0	
485870	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	10.0	
485871	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	VRR Time Delay	30	Seconds
485872	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
485873	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
485874	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
485875	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
485876	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	LTC Operation Checked?	y	
485877	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	General Comments		
485878	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
485879	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Cabinet Paint Condition	Good	
485880	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Equipment Properly Labeled?	y	
485881	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
485882	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
485883	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
485884	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations A Ø	0	
485885	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	Follow-up Action Required?	n	
485886	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	All Connections OK?	y	
485887	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
485888	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
485889	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
485890	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
485891	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
485892	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10.0	
485893	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
485894	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
485895	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
485896	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations B Ø	0	
485897	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations C Ø	0	
485898	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations Ground	0	
485899	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Follow-up Action Required?	n	
485900	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Follow-up Action Required?	n	
485901	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Foundation Condition	Good	
485902	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	General Comments		
485903	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	General Comments		
485904	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Grounds in Place?	y	
485905	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Maintenance Operations	0	
485906	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Moisture and Leak Free?	y	
485907	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Operations Counter AF	181	
485908	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
485909	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
485910	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
485911	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	50.0	
485912	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
485913	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
485914	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
485915	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
485916	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
485917	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
485918	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	677	
485919	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
485920	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
485921	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
485922	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
485923	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
485924	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
485925	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
485926	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
485927	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
485928	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
485929	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
485930	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
485931	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
485932	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
485933	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
485934	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
485935	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Ambient Temp	61	°F
485936	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
485937	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Clear of Trash?	y	
485938	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
485939	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
485940	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
485941	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
485942	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
485943	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
485944	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	General Comments		
485945	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
485946	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
485947	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
485948	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Vegetation	None	
485949	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
485950	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
485951	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
485952	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
485953	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
485954	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
485955	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
485956	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
485957	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	PF000096	PowerFuse	DA-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
485958	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	PF000096	PowerFuse	DA-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
485959	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	PF000095	PowerFuse	DA-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
485960	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	PF000095	PowerFuse	DA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
485961	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	677	
485962	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
485963	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
485964	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
485965	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
485966	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
485967	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
485968	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
485969	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
485970	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
485971	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
485972	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
485973	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	33	
485974	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	33	
485975	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
485976	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
485977	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
485978	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
485979	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
485980	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
485981	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
485982	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.62	%
485983	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.62	%
485984	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.62	%
485985	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
485986	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
485987	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
485988	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
485989	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
485990	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
485991	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
485992	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
485993	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	10.0	
485994	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
485995	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
485996	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
485997	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
485998	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
485999	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
486000	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
486001	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
486002	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	95	
486003	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	95	
486004	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
486005	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
486006	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
486007	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
486008	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	LTCC000774	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
486009	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	LTCC000774	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
486010	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
486011	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	LTCC000774	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
486012	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	LTCC000774	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
486013	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	LTCC000774	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Operation Checked?	y	
486014	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	LTCC000774	LTCControl	932-Offline Distribution	LTC Control Insp	General Comments		
486015	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
486016	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	LTCC000774	LTCControl	932-Offline Distribution	LTC Control Insp	Follow-up Action Required?	n	
486017	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	LTCC000774	LTCControl	932-Offline Distribution	LTC Control Insp	All Connections OK?	y	
486018	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1547	
486019	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
486020	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
486021	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	7.97	%
486022	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	11.96	%
486023	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	9.3	%
486024	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	88.0	
486025	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	101.0	
486026	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	113.0	
486027	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
486028	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
486029	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
486030	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
486031	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
486032	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
486033	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
486034	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
486035	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	General Comments		
486036	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
486037	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
486038	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
486039	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
486040	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
486041	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
486042	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
486043	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
486044	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
486045	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
486046	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	Yes_sprayed	
486047	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
486048	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
486049	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
486050	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
486051	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
486052	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
486053	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
486054	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
486055	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
486056	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
486057	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
486058	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
486059	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
486060	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
486061	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
486062	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
486063	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
486064	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
486065	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	10.0	
486066	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	10.0	
486067	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
486068	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
486069	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
486070	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
486071	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
486072	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	General Comments		
486073	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
486074	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
486075	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	15.0	psi
486076	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
486077	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	40	°C
486078	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
486079	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	9 Month Operations	2	
486080	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
486081	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
486082	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
486083	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Amps A Ø	0.0	
486084	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Amps B Ø	0.0	
486085	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Amps C Ø	0.0	
486086	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
486087	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
486088	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Bushing Condition	Good	
486089	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
486090	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
486091	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
486092	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
486093	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
486094	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
486095	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
486096	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
486097	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
486098	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
486099	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
486100	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
486101	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
486102	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	2037	
486103	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	2037	
486104	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	10	
486105	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
486106	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
486107	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
486108	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
486109	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	General Comments		
486110	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3600.00	kw
486111	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
486112	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
486113	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
486114	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
486115	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
486116	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
486117	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	45	°C
486118	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	40	°C
486119	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	40	°C
486120	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	773	
486121	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
486122	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
486123	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
486124	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
486125	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
486126	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
486127	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
486128	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
486129	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
486130	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
486131	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
486132	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
486133	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
486134	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
486135	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
486136	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
486137	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
486138	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
486139	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
486140	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
486141	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3750	
486142	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
486143	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
486144	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
486145	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
486146	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
486147	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
486148	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
486149	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
486150	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
486151	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Oil Temp Max	35	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
486152	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
486153	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
486154	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
486155	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
486156	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	General Comments		
486157	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
486158	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
486159	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
486160	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
486161	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
486162	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
486163	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
486164	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Grounds in Place?	y	
486165	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	General Comments		
486166	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	General Comments		
486167	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Foundation Condition	Good	
486168	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Follow-up Action Required?	n	
486169	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Follow-up Action Required?	n	
486170	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Operations Ground	0	
486171	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
486172	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Operations C Ø	0	
486173	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Operations B Ø	0	
486174	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Operations A Ø	0	
486175	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
486176	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
486177	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
486178	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
486179	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
486180	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
486181	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
486182	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
486183	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Tank Leaks	None	
486184	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
486185	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
486186	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
486187	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Broom on Site?	y	
486188	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
486189	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
486190	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
486191	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
486192	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Evidence of Insects	None	
486193	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
486194	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
486195	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Operations C Ø	0	
486196	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Operations Ground	0	
486197	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
486198	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
486199	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
486200	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
486201	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
486202	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
486203	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
486204	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Follow-up Action Required?	n	
486205	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	General Comments		
486206	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Maintenance Operations	0	
486207	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Operations Counter AF	151	
486208	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Unknown Operations	0	
486209	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Tank Paint Condition	Good	
486210	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Operations Counter AL	151	
486211	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
486212	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
486213	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
486214	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
486215	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
486216	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Operations This Read Vac	0	
486217	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Switching Operations	0	
486218	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Unknown Operations	0	
486219	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Switching Operations	4	
486220	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
486221	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Operations This Read Vac	4	
486222	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Operations Counter AL	332	
486223	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Operations Counter AF	332	
486224	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Moisture and Leak Free?	y	
486225	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
486226	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
486227	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
486228	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
486229	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Maintenance Operations	0	
486230	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Heaters (All) Functioning?	y	
486231	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
486232	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
486233	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
486234	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
486235	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
486236	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
486237	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1644	
486238	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1644	
486239	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
486240	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
486241	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
486242	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
486243	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
486244	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
486245	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
486246	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
486247	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
486248	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
486249	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
486250	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
486251	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
486252	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
486253	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
486254	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
486255	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
486256	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
486257	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
486258	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	n	
486259	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
486260	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
486261	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
486262	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
486263	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
486264	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
486265	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
486266	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
486267	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
486268	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
486269	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
486270	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
486271	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
486272	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	General Comments		
486273	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	9 Month Operations	1	
486274	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
486275	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
486276	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
486277	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
486278	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
486279	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
486280	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
486281	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
486282	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
486283	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
486284	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
486285	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
486286	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
486287	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
486288	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
486289	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	5.0	
486290	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	10.0	
486291	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	5.0	
486292	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
486293	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
486294	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
486295	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	10.0	
486296	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	10.0	
486297	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	10.0	
486298	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
486299	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
486300	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
486301	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
486302	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
486303	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
486304	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
486305	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
486306	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
486307	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
486308	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
486309	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
486310	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
486311	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
486312	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
486313	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Readings	General Comments		
486314	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
486315	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
486316	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
486317	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments	Free breather	
486318	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
486319	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	80.0	
486320	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	90.0	
486321	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	90.0	
486322	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
486323	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
486324	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
486325	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
486326	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
486327	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
486328	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
486329	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	10	
486330	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	773	
486331	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
486332	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Tank Leaks	None	
486333	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
486334	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Regulator As Left Counter	116583	
486335	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
486336	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
486337	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
486338	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
486339	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
486340	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
486341	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
486342	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
486343	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	General Comments		
486344	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
486345	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
486346	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
486347	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
486348	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
486349	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
486350	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
486351	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
486352	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
486353	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
486354	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
486355	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
486356	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
486357	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
486358	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Accumulated Fault Duty C Ph V	.65	%
486359	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Amps A Ø	125.0	
486360	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Amps B Ø	86.0	
486361	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Amps C Ø	143.0	
486362	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
486363	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
486364	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
486365	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Operations A Ø	0	
486366	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Operations B Ø	0	
486367	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
486368	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
486369	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
486370	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
486371	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	General Comments		
486372	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	General Comments	1 fan has bad capacitor	
486373	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
486374	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
486375	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
486376	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
486377	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	Oil Temp Max	42	°C
486378	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
486379	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
486380	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
486381	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
486382	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Maintenance Operations	0	
486383	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
486384	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Grounds in Place?	y	
486385	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	General Comments		
486386	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	General Comments		
486387	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Foundation Condition	Good	
486388	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Follow-up Action Required?	n	
486389	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Follow-up Action Required?	n	
486390	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Operations Ground	0	
486391	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Operations C Ø	0	
486392	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Operations B Ø	0	
486393	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Operations A Ø	0	
486394	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
486395	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
486396	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
486397	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
486398	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
486399	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	General Comments		
486400	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
486401	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	General Comments		
486402	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
486403	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
486404	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
486405	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
486406	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
486407	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
486408	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
486409	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
486410	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
486411	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
486412	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
486413	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
486414	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
486415	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
486416	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Totalizer Meter Reading	.7020	
486417	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
486418	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
486419	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
486420	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	9 Month Operations	4	
486421	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
486422	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
486423	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
486424	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Amps A Ø	10.0	
486425	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Amps B Ø	10.0	
486426	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Amps C Ø	10.0	
486427	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Bushing Condition	Good	
486428	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Bushings Connection/Risers	Good	
486429	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
486430	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
486431	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
486432	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Cabinet Paint Condition	Good	
486433	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Equipment Properly Labeled?	y	
486434	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
486435	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
486436	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
486437	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Operations A Ø	0	
486438	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Operations B Ø	0	
486439	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Operations C Ø	0	
486440	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
486441	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
486442	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
486443	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
486444	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
486445	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
486446	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
486447	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
486448	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
486449	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
486450	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
486451	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
486452	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	Follow-up Action Required?	n	
486453	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
486454	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
486455	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	General Comments		
486456	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	General Comments		
486457	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
486458	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	LTC Totalizer Reading	4686.00	kw
486459	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
486460	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
486461	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	Oil Temp Max	50	°C
486462	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
486463	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
486464	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
486465	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
486466	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
486467	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
486468	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
486469	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
486470	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	Totalizer Meter Reading	.7810	
486471	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
486472	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
486473	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
486474	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Follow-up Action Required?	n	
486475	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
486476	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
486477	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
486478	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
486479	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
486480	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
486481	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
486482	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
486483	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
486484	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
486485	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
486486	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
486487	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
486488	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
486489	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
486490	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	General Comments		
486491	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
486492	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
486493	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
486494	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
486495	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
486496	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
486497	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
486498	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
486499	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
486500	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
486501	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	22	
486502	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	37.21	%
486503	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	26.58	%
486504	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	38.54	%
486505	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	90.0	
486506	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
486507	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	107.0	
486508	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
486509	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
486510	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	General Comments		
486511	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
486512	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	LTC Totalizer Reading	5137.92	kw
486513	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
486514	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
486515	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Oil Temp Max	35	°C
486516	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Oil Temp Present	35	°C
486517	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
486518	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
486519	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
486520	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
486521	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
486522	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Operations Ground	0	
486523	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Follow-up Action Required?	n	
486524	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Follow-up Action Required?	n	
486525	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Foundation Condition	Good	
486526	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
486527	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	General Comments		
486528	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Grounds in Place?	y	
486529	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Heaters (All) Functioning?	y	
486530	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Maintenance Operations	0	
486531	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Moisture and Leak Free?	y	
486532	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Operations Counter AF	193	
486533	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Operations Counter AL	193	
486534	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
486535	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
486536	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Operations This Read Vac	0	
486537	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
486538	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
486539	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
486540	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Switching Operations	0	
486541	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Tank Paint Condition	Good	
486542	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Unknown Operations	0	
486543	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
486544	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
486545	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
486546	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
486547	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
486548	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	General Comments		
486549	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
486550	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
486551	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
486552	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
486553	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
486554	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
486555	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
486556	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
486557	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
486558	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
486559	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
486560	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
486561	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
486562	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
486563	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
486564	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
486565	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
486566	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
486567	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
486568	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
486569	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
486570	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
486571	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
486572	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
486573	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	General Comments		
486574	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
486575	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
486576	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
486577	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
486578	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Max Tap Position	11L	
486579	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Min Tap Position	2L	
486580	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
486581	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
486582	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
486583	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
486584	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
486585	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
486586	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
486587	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Follow-up Action Required?	n	
486588	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
486589	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
486590	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	General Comments		
486591	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	General Comments		
486592	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
486593	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	LTC Totalizer Reading	6739.20	kw
486594	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
486595	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
486596	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Oil Temp Max	35	°C
486597	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Oil Temp Present	35	°C
486598	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
486599	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
486600	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
486601	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
486602	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
486603	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
486604	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
486605	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Floor Swept?	y	
486606	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
486607	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	General Comments		
486608	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
486609	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
486610	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Panels Dusted?	y	
486611	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
486612	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
486613	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
486614	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Trash Emptied?	y	
486615	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
486616	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
486617	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
486618	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
486619	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Equipment Properly Labeled?	y	
486620	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Cabinet Paint Condition	Good	
486621	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
486622	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
486623	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
486624	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Bushings Connection/Risers	Good	
486625	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Bushing Condition	Good	
486626	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Amps C Ø	120.0	
486627	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Amps B Ø	120.0	
486628	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Amps A Ø	120.0	
486629	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
486630	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
486631	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
486632	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	9 Month Operations	4	
486633	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
486634	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
486635	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Regulator As Left Counter	116816	
486636	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	.2	volts
486637	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
486638	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
486639	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
486640	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
486641	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
486642	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
486643	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
486644	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	General Comments		
486645	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
486646	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
486647	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
486648	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
486649	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
486650	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
486651	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
486652	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
486653	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
486654	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
486655	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
486656	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
486657	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	General Comments		
486658	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
486659	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
486660	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
486661	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
486662	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
486663	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
486664	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
486665	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
486666	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
486667	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
486668	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
486669	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
486670	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
486671	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
486672	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
486673	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
486674	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
486675	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
486676	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
486677	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
486678	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
486679	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
486680	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	852	
486681	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	852	
486682	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
486683	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
486684	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
486685	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
486686	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
486687	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
486688	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
486689	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
486690	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
486691	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
486692	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
486693	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
486694	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
486695	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
486696	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
486697	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
486698	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
486699	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
486700	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
486701	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
486702	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
486703	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
486704	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
486705	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	General Comments		
486706	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
486707	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Regulator As Left Counter	199683	
486708	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
486709	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
486710	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
486711	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
486712	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Tank Leaks	None	
486713	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
486714	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
486715	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
486716	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
486717	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	35.00	
486718	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
486719	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
486720	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
486721	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
486722	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
486723	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
486724	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
486725	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
486726	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
486727	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
486728	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
486729	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
486730	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
486731	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
486732	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	682	
486733	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	682	
486734	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
486735	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
486736	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
486737	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
486738	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
486739	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
486740	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
486741	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Operations A Ø	0	
486742	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
486743	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
486744	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
486745	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
486746	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
486747	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
486748	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
486749	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
486750	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
486751	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
486752	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
486753	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
486754	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
486755	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Amps C Ø	100.0	
486756	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Amps B Ø	140.0	
486757	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
486758	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
486759	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	General Comments	Barbed wire is rusty.	
486760	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
486761	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
486762	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
486763	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
486764	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
486765	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
486766	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
486767	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
486768	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
486769	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	80.0	
486770	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
486771	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	180	
486772	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	180	
486773	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
486774	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
486775	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
486776	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
486777	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
486778	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	General Comments		
486779	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
486780	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
486781	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
486782	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
486783	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
486784	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
486785	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
486786	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
486787	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	352	
486788	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	352	
486789	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
486790	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
486791	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
486792	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
486793	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
486794	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Clear of Trash?	y	
486795	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
486796	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
486797	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
486798	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
486799	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
486800	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
486801	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	General Comments		
486802	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
486803	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
486804	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Vegetation	None	
486805	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
486806	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	General Comments		
486807	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
486808	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
486809	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
486810	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	28.3	VDC
486811	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	28.3	VDC
486812	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	6.000	millivolts
486813	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
486814	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	General Comments		
486815	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
486816	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
486817	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
486818	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
486819	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
486820	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Amps A Ø	130.0	
486821	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
486822	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
486823	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
486824	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
486825	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
486826	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
486827	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	790	
486828	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Patrol Inspection	Follow-up Action Required?	n	
486829	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Operations Ground	0	
486830	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
486831	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
486832	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	9 Months Operations	0	
486833	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Operations C Ø	0	
486834	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Clear of Trash?	y	
486835	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
486836	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
486837	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Operations B Ø	0	
486838	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Operations A Ø	0	
486839	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
486840	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
486841	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
486842	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Ambient Temp	63	°F
486843	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
486844	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
486845	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
486846	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
486847	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
486848	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	General Comments		
486849	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
486850	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
486851	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
486852	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
486853	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
486854	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
486855	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	n	
486856	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	80.0	
486857	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	80.0	
486858	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Follow-up Action Required?	n	
486859	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Foundation Condition	Good	
486860	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	General Comments		
486861	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
486862	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Vegetation	None	
486863	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
486864	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
486865	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
486866	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
486867	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
486868	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
486869	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
486870	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
486871	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
486872	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
486873	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	General Comments		
486874	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
486875	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
486876	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
486877	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
486878	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	General Comments		
486879	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
486880	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
486881	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
486882	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
486883	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
486884	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
486885	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
486886	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
486887	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
486888	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
486889	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
486890	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
486891	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
486892	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
486893	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
486894	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
486895	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
486896	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
486897	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
486898	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
486899	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
486900	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Max Tap Position	11L	
486901	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
486902	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	General Comments		
486903	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
486904	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
486905	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
486906	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
486907	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
486908	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
486909	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
486910	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
486911	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
486912	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
486913	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
486914	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
486915	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
486916	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
486917	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
486918	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
486919	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
486920	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
486921	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
486922	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
486923	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
486924	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
486925	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
486926	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
486927	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
486928	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
486929	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	General Comments		
486930	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
486931	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
486932	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Patrol Inspection	General Comments		
486933	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
486934	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
486935	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
486936	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
486937	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	872	
486938	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	870	
486939	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
486940	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
486941	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
486942	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
486943	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
486944	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
486945	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
486946	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
486947	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
486948	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Operations C Ø	0	
486949	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
486950	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
486951	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
486952	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Operations B Ø	0	
486953	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
486954	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	883	
486955	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	883	
486956	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
486957	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
486958	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
486959	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
486960	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
486961	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
486962	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
486963	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
486964	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
486965	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
486966	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
486967	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
486968	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
486969	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
486970	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
486971	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Tank Leaks	None	
486972	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
486973	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Regulator As Left Counter	188774	
486974	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
486975	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Reg Operation Checked?	n	
486976	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
486977	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
486978	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
486979	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
486980	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	General Comments		
486981	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
486982	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
486983	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
486984	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
486985	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Min Tap Position	1L	
486986	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
486987	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
486988	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
486989	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
486990	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
486991	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
486992	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
486993	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
486994	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
486995	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
486996	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
486997	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
486998	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
486999	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
487000	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	121.0	
487001	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	106.0	
487002	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	122.0	
487003	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	14.62	%
487004	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	33.22	%
487005	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
487006	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
487007	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
487008	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
487009	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
487010	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Follow-up Action Required?	n	
487011	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	27.91	%
487012	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	14	
487013	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
487014	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
487015	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	B0270	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
487016	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	B0270	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
487017	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	B0270	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
487018	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
487019	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
487020	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
487021	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Cabinet Paint Condition	Good	
487022	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Equipment Properly Labeled?	y	
487023	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
487024	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
487025	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
487026	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
487027	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
487028	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
487029	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
487030	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
487031	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
487032	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
487033	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
487034	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
487035	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
487036	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
487037	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
487038	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
487039	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
487040	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
487041	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
487042	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
487043	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
487044	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
487045	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	MFD Breather green light	NotOK	
487046	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
487047	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
487048	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
487049	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
487050	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
487051	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
487052	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
487053	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
487054	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
487055	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
487056	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
487057	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
487058	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
487059	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
487060	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
487061	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
487062	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
487063	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
487064	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
487065	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
487066	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	40.0	
487067	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	40.0	
487068	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	40.0	
487069	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.46	%
487070	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.46	%
487071	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.46	%
487072	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
487073	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
487074	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
487075	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
487076	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
487077	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
487078	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
487079	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
487080	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
487081	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
487082	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
487083	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
487084	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
487085	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
487086	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
487087	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	General Comments		
487088	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
487089	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Max Tap Position	13L	
487090	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Min Tap Position	Neutral	
487091	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
487092	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
487093	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
487094	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
487095	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
487096	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Regulator As Left Counter	105905	
487097	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
487098	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
487099	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Tank Leaks	None	
487100	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
487101	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
487102	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
487103	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	50.0	
487104	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
487105	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Tank Leaks	None	
487106	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
487107	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
487108	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
487109	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Operations Counter	1823	
487110	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
487111	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
487112	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	General Comments		
487113	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
487114	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
487115	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
487116	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
487117	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
487118	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
487119	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
487120	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	General Comments		
487121	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
487122	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
487123	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
487124	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
487125	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
487126	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
487127	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
487128	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Readings	General Comments		
487129	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
487130	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
487131	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
487132	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
487133	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
487134	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
487135	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
487136	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
487137	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
487138	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
487139	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	General Comments		
487140	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
487141	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
487142	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
487143	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
487144	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
487145	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
487146	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
487147	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
487148	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Regulator As Left Counter	110889	
487149	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
487150	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
487151	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Tank Leaks	None	
487152	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
487153	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
487154	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
487155	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
487156	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
487157	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
487158	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
487159	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
487160	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
487161	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	67.0	
487162	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	61.0	
487163	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	5.32	%
487164	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	14.62	%
487165	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	2.66	%
487166	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
487167	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
487168	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
487169	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
487170	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
487171	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	356	
487172	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	356	
487173	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
487174	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
487175	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
487176	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
487177	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
487178	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
487179	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
487180	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
487181	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
487182	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
487183	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
487184	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
487185	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
487186	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
487187	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
487188	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
487189	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
487190	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
487191	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
487192	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
487193	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
487194	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
487195	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
487196	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
487197	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
487198	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
487199	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
487200	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
487201	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
487202	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
487203	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
487204	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
487205	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
487206	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
487207	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	General Comments		
487208	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
487209	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
487210	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
487211	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
487212	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
487213	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
487214	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
487215	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
487216	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
487217	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Amps C Ø	60.0	
487218	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
487219	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
487220	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
487221	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Amps C Ø	50.0	
487222	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
487223	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
487224	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
487225	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
487226	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
487227	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
487228	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
487229	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
487230	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Amps B Ø	60.0	
487231	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Amps A Ø	60.0	
487232	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
487233	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
487234	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
487235	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
487236	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
487237	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
487238	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	214	
487239	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
487240	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	218	
487241	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	4	
487242	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
487243	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
487244	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
487245	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
487246	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BCH000519	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
487247	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BCH000519	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
487248	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BCH000519	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
487249	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BCH000519	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
487250	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
487251	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
487252	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
487253	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
487254	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	Follow-up Action Required?	n	
487255	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
487256	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	General Comments		
487257	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	General Comments		
487258	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC As Found Counter	340	
487259	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
487260	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
487261	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
487262	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
487263	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Grounds in Place?	y	
487264	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Heaters (All) Functioning?	y	
487265	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Moisture and Leak Free?	y	
487266	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC As Left Counter	340	
487267	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
487268	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC Current Tap Position	4L	
487269	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
487270	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
487271	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
487272	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
487273	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	219	
487274	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1219	
487275	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
487276	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
487277	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
487278	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
487279	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
487280	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
487281	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
487282	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
487283	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
487284	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
487285	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
487286	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
487287	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	109.0	
487288	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
487289	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Vegetation	None	
487290	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
487291	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
487292	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
487293	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
487294	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Tank Leaks	None	
487295	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
487296	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Operations Counter	99	
487297	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
487298	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
487299	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	General Comments		
487300	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
487301	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
487302	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
487303	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
487304	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
487305	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
487306	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
487307	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
487308	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
487309	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
487310	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Amps C Ø	69.0	
487311	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Amps B Ø	52.0	
487312	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Amps A Ø	66.0	
487313	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
487314	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
487315	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
487316	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
487317	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
487318	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
487319	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
487320	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
487321	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
487322	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
487323	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
487324	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	65	
487325	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BCH000519	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
487326	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Winding Temp Max	35	°C
487327	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Totalizer Meter Reading	.371	
487328	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
487329	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
487330	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
487331	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BCH000519	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
487332	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
487333	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
487334	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
487335	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
487336	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
487337	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
487338	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
487339	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Tank Paint Condition	Good	
487340	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
487341	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
487342	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
487343	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.2	psi
487344	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
487345	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100	
487346	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100	
487347	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100	
487348	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	11.82	%
487349	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	5.46	%
487350	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	6.37	%
487351	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
487352	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	20.00	
487353	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
487354	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
487355	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
487356	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
487357	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	240.0	
487358	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	240.0	
487359	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	240.0	
487360	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
487361	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
487362	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
487363	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
487364	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
487365	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
487366	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
487367	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
487368	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
487369	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
487370	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
487371	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
487372	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
487373	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
487374	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
487375	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC Min Tap Position	5L	
487376	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
487377	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC Operations Since Last Insp	35	
487378	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
487379	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
487380	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
487381	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
487382	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Oil Temp Max	35	°C
487383	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
487384	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
487385	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	85.0	
487386	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	15.77	%
487387	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	18.2	%
487388	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	25.48	%
487389	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	38	
487390	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
487391	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
487392	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
487393	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
487394	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
487395	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
487396	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
487397	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
487398	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
487399	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
487400	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
487401	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
487402	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
487403	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
487404	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
487405	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
487406	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
487407	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
487408	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
487409	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	LTC Totalizer Reading	8904	kw
487410	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
487411	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	General Comments		
487412	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	General Comments		
487413	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
487414	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
487415	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Follow-up Action Required?	n	
487416	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
487417	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
487418	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.6	psi
487419	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
487420	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
487421	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
487422	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
487423	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
487424	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC Max Tap Position	2L	
487425	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC Min Tap Position	8L	
487426	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
487427	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
487428	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
487429	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
487430	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
487431	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC Operations Since Last Insp	376	
487432	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
487433	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
487434	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
487435	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
487436	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
487437	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
487438	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
487439	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	5.78	%
487440	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	5.78	%
487441	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	5.78	%
487442	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
487443	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
487444	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
487445	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
487446	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
487447	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	General Comments		
487448	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
487449	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
487450	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
487451	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
487452	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Unknown Operations	0	
487453	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Tank Paint Condition	Good	
487454	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Switching Operations	0	
487455	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Operations This Read Vac	0	
487456	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Operations Counter AL	210	
487457	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
487458	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Operations Counter AF	210	
487459	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Moisture and Leak Free?	y	
487460	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Maintenance Operations	0	
487461	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
487462	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
487463	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	Follow-up Action Required?	n	
487464	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
487465	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	General Comments		
487466	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	General Comments		
487467	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC As Found Counter	205028	
487468	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC As Left Counter	205028	
487469	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
487470	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Current Tap Position	8L	
487471	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Max Tap Position	2L	
487472	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Min Tap Position	11L	
487473	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Operations Since Last Insp	1035	
487474	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
487475	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
487476	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
487477	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
487478	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
487479	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
487480	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
487481	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
487482	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	General Comments		
487483	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
487484	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
487485	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
487486	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
487487	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Operations Counter	927	
487488	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
487489	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Tank Leaks	None	
487490	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
487491	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
487492	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	Follow-up Action Required?	n	
487493	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
487494	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	General Comments		
487495	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	General Comments		
487496	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC As Found Counter	18364	
487497	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	General Comments		
487498	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC As Left Counter	18364	
487499	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
487500	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
487501	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
487502	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
487503	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
487504	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC Current Tap Position	7L	
487505	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
487506	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
487507	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
487508	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
487509	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
487510	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	BCH000606	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
487511	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
487512	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
487513	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
487514	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
487515	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
487516	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	LTC Operation Checked?	y	
487517	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	General Comments		
487518	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	Follow-up Action Required?	n	
487519	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	All Connections OK?	y	
487520	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
487521	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
487522	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
487523	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
487524	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
487525	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
487526	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
487527	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
487528	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
487529	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
487530	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
487531	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
487532	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	General Comments		
487533	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	BCH000606	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
487534	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	BCH000606	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
487535	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	BCH000606	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
487536	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
487537	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	BCH000606	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
487538	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
487539	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	General Comments		
487540	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
487541	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
487542	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
487543	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
487544	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
487545	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
487546	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	BCH000606	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
487547	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
487548	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
487549	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	484	
487550	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Heaters (All) Functioning?	y	
487551	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Grounds in Place?	y	
487552	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
487553	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
487554	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
487555	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	476	
487556	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	476	
487557	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
487558	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	General Comments		
487559	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	General Comments		
487560	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
487561	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	486	
487562	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
487563	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
487564	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
487565	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
487566	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.62	%
487567	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.44	%
487568	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Foundation Condition	Good	
487569	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
487570	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
487571	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
487572	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
487573	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
487574	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
487575	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
487576	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	VRR Time Delay	30	Seconds

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
487577	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
487578	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
487579	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
487580	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Clear of Trash?	y	
487581	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
487582	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
487583	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
487584	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
487585	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
487586	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
487587	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	General Comments		
487588	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
487589	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
487590	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Vegetation	None	
487591	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
487592	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
487593	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
487594	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
487595	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
487596	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
487597	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
487598	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
487599	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
487600	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
487601	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
487602	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
487603	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
487604	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	804	
487605	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	804	
487606	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
487607	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
487608	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
487609	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
487610	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
487611	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
487612	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	50	
487613	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
487614	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	50	
487615	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
487616	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
487617	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
487618	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
487619	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
487620	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
487621	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0	%
487622	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	.91	%
487623	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
487624	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.91	%
487625	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
487626	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
487627	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
487628	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
487629	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
487630	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
487631	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
487632	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	59	°F
487633	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
487634	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
487635	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	50	
487636	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
487637	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
487638	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
487639	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
487640	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
487641	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
487642	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
487643	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
487644	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
487645	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
487646	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
487647	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
487648	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
487649	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
487650	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
487651	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
487652	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
487653	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
487654	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
487655	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
487656	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
487657	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
487658	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
487659	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2150	psi
487660	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
487661	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
487662	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
487663	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
487664	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
487665	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
487666	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
487667	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
487668	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
487669	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
487670	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
487671	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
487672	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
487673	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
487674	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
487675	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
487676	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
487677	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
487678	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
487679	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
487680	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	4.0	VDC
487681	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
487682	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
487683	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
487684	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
487685	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
487686	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
487687	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
487688	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
487689	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
487690	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
487691	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
487692	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
487693	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	LTC Operations Since Last Insp	453	
487694	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	LTC Min Tap Position	7L	
487695	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	LTC Max Tap Position	4L	
487696	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	LTC Current Tap Position	4L	
487697	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
487698	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	LTC As Left Counter	5253	
487699	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	LTC As Found Counter	5253	
487700	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	General Comments		
487701	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	General Comments		
487702	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
487703	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	Follow-up Action Required?	n	
487704	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
487705	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
487706	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
487707	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
487708	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
487709	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
487710	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
487711	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
487712	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
487713	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
487714	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
487715	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
487716	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1538	
487717	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1538	
487718	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
487719	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
487720	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
487721	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
487722	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
487723	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
487724	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
487725	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
487726	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
487727	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
487728	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
487729	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
487730	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
487731	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
487732	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
487733	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1226	
487734	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1226	
487735	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
487736	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
487737	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
487738	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
487739	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
487740	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Amps A Ø	80.0	
487741	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Amps B Ø	80.0	
487742	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Amps C Ø	80.0	
487743	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
487744	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
487745	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
487746	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
487747	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
487748	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
487749	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	General Comments		
487750	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
487751	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
487752	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
487753	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	5768	
487754	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	5768	
487755	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
487756	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	6L	
487757	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	6L	
487758	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	9L	
487759	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
487760	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	352	
487761	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
487762	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
487763	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
487764	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
487765	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
487766	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
487767	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
487768	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
487769	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
487770	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
487771	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
487772	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Maintenance Operations	0	
487773	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Operations Counter AF	323	
487774	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Operations Counter AL	323	
487775	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Operations This Read AM	0	
487776	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Switching Operations	0	
487777	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Unknown Operations	0	
487778	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Unknown Operations	0	
487779	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Switching Operations	0	
487780	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Amps B Ø	0.0	
487781	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Amps A Ø	0.0	
487782	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
487783	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
487784	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
487785	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	9 Month Operations	2	
487786	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Follow-up Action Required?	n	
487787	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Patrol Inspection	Follow-up Action Required?	n	
487788	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Operations Ground	0	
487789	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
487790	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
487791	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
487792	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
487793	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
487794	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
487795	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
487796	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
487797	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
487798	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
487799	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
487800	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	Follow-up Action Required?	n	
487801	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
487802	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	General Comments		
487803	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	General Comments		
487804	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC As Found Counter	3643	
487805	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC As Left Counter	3643	
487806	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
487807	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC Current Tap Position	3L	
487808	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
487809	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Min Tap Position	14L	
487810	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Max Tap Position	2L	
487811	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
487812	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	General Comments		
487813	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
487814	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
487815	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
487816	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
487817	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Current Tap Position	12L	
487818	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
487819	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
487820	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
487821	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
487822	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
487823	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
487824	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	open	
487825	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
487826	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
487827	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
487828	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
487829	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
487830	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
487831	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Operations A Ø	0	
487832	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Operations B Ø	0	
487833	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Operations C Ø	0	
487834	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
487835	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
487836	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	General Comments		
487837	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Operations Ground	0	
487838	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Patrol Inspection	Follow-up Action Required?	n	
487839	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Follow-up Action Required?	n	
487840	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Patrol Inspection	General Comments		
487841	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	General Comments		
487842	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Maintenance Operations	0	
487843	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
487844	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	General Comments		
487845	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Patrol Inspection	General Comments		
487846	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
487847	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
487848	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
487849	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
487850	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
487851	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
487852	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	General Comments		
487853	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
487854	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
487855	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
487856	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
487857	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
487858	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
487859	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
487860	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
487861	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
487862	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
487863	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
487864	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	General Comments		
487865	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	General Comments		
487866	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
487867	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
487868	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	140.04	kw
487869	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
487870	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
487871	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Oil Temp Max	40	°C
487872	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Oil Temp Present	25	°C
487873	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
487874	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
487875	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
487876	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
487877	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
487878	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
487879	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	2	
487880	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	2	
487881	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
487882	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
487883	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
487884	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
487885	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
487886	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
487887	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
487888	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
487889	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
487890	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Totalizer Meter Reading	.2334	
487891	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
487892	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
487893	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
487894	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC Max Tap Position	3L	
487895	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC Min Tap Position	7L	
487896	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC Operations Since Last Insp	261	
487897	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
487898	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
487899	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
487900	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Operations This Read AM	0	
487901	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Operations Counter AL	269	
487902	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Operations Counter AF	269	
487903	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Maintenance Operations	0	
487904	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
487905	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	General Comments		
487906	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
487907	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
487908	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
487909	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
487910	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
487911	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
487912	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
487913	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
487914	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
487915	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
487916	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
487917	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	Oil Temp Max	35	°C
487918	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
487919	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
487920	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
487921	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
487922	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
487923	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
487924	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
487925	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
487926	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
487927	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Tank Leaks	None	
487928	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
487929	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
487930	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Regulator As Left Counter	122747	
487931	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
487932	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
487933	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
487934	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
487935	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
487936	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
487937	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
487938	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
487939	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
487940	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
487941	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
487942	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
487943	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
487944	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Cabinet Paint Condition	Good	
487945	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Follow-up Action Required?	n	
487946	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Follow-up Action Required?	n	
487947	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Operations Ground	0	
487948	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
487949	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Equipment Properly Labeled?	y	
487950	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Amps C Ø	50.0	
487951	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
487952	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
487953	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
487954	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.62	%
487955	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
487956	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
487957	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
487958	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
487959	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
487960	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
487961	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
487962	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
487963	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
487964	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
487965	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
487966	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
487967	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
487968	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
487969	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
487970	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
487971	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
487972	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
487973	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
487974	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Regulator As Left Counter	156916	
487975	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
487976	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Tank Leaks	None	
487977	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	General Comments		
487978	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	General Comments		
487979	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
487980	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
487981	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
487982	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
487983	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
487984	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	open	
487985	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
487986	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	145	
487987	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	145	
487988	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
487989	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
487990	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
487991	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
487992	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
487993	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
487994	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
487995	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
487996	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
487997	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
487998	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
487999	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BCH000389	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
488000	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BCH000389	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
488001	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
488002	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
488003	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BCH000389	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
488004	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BCH000389	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
488005	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BCH000389	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
488006	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BCH000389	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
488007	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
488008	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
488009	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Foundation Condition	Good	
488010	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	9 Months Operations	0	
488011	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
488012	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
488013	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
488014	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
488015	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Amps A Ø	25.0	
488016	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Amps B Ø	100.0	
488017	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Bushing Condition	Good	
488018	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Bushings Connection/Risers	Good	
488019	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
488020	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
488021	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
488022	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
488023	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
488024	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
488025	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Bushings Connection/Risers	Good	
488026	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
488027	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Foundation Condition	Good	
488028	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	General Comments		
488029	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Grounds in Place?	y	
488030	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Heaters (All) Functioning?	y	
488031	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Moisture and Leak Free?	y	
488032	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
488033	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Tank Paint Condition	Good	
488034	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Bushing Condition	Good	
488035	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Amps C Ø	0.0	
488036	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
488037	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Tank Leaks	None	
488038	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BCH000386	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
488039	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BCH000386	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
488040	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BCH000386	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
488041	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BCH000386	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
488042	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BCH000386	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
488043	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
488044	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
488045	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
488046	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	BCH000386	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
488047	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
488048	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
488049	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
488050	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
488051	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
488052	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
488053	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
488054	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
488055	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
488056	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Switching Operations	0	
488057	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
488058	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
488059	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Regulator As Left Counter	24022	
488060	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
488061	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Operations This Read AM	0	
488062	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Operations Counter AL	316	
488063	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Operations Counter AF	316	
488064	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
488065	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
488066	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
488067	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
488068	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
488069	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Operations C Ø	0	
488070	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Operations B Ø	0	
488071	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	Oil Temp Max	31	°C
488072	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	Oil Temp Present	25	°C
488073	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
488074	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
488075	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
488076	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
488077	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
488078	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
488079	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
488080	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
488081	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	417	
488082	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Operations A Ø	0	
488083	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
488084	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
488085	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	417	
488086	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	73.0	
488087	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	81.0	
488088	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Bushing Condition	Good	
488089	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Bushings Connection/Risers	Good	
488090	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	69.0	
488091	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	23.05	%
488092	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	31.55	%
488093	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	29.12	%
488094	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	18	
488095	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
488096	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
488097	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
488098	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
488099	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
488100	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
488101	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
488102	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
488103	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
488104	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
488105	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Unknown Operations	0	
488106	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
488107	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Equipment Properly Labeled?	y	
488108	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Cabinet Paint Condition	Good	
488109	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
488110	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
488111	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Tank Paint Condition	Good	
488112	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Switching Operations	2	
488113	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
488114	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Operations This Read Vac	2	
488115	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
488116	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
488117	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Current Tap Position	14L	
488118	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
488119	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
488120	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
488121	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
488122	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	General Comments		
488123	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
488124	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Max Tap Position	6L	
488125	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Min Tap Position	15L	
488126	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
488127	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Operations Counter AL	180	
488128	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Operations Counter AF	180	
488129	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Moisture and Leak Free?	y	
488130	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Maintenance Operations	0	
488131	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
488132	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
488133	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
488134	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
488135	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
488136	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
488137	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
488138	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
488139	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
488140	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
488141	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Regulator As Left Counter	20212	
488142	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
488143	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
488144	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Tank Leaks	None	
488145	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
488146	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
488147	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	73	
488148	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
488149	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	7L	
488150	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
488151	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	3	
488152	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
488153	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
488154	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
488155	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
488156	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
488157	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
488158	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
488159	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
488160	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
488161	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
488162	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
488163	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
488164	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
488165	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
488166	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Tank Leaks	None	
488167	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
488168	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
488169	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
488170	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
488171	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
488172	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
488173	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
488174	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	General Comments		
488175	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	General Comments		
488176	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
488177	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
488178	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
488179	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
488180	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
488181	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
488182	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
488183	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
488184	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
488185	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	General Comments		
488186	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
488187	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC As Found Counter	132757	
488188	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
488189	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
488190	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
488191	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
488192	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
488193	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
488194	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
488195	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC As Left Counter	132757	
488196	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
488197	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
488198	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
488199	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
488200	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Unknown Operations	0	
488201	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	General Comments		
488202	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
488203	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Max Tap Position	1L	
488204	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Min Tap Position	13L	
488205	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
488206	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
488207	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
488208	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
488209	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
488210	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Regulator As Left Counter	26216	
488211	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
488212	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
488213	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Tank Leaks	None	
488214	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
488215	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
488216	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Vegetation	None	
488217	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
488218	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
488219	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
488220	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
488221	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
488222	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
488223	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	n	
488224	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
488225	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	General Comments		
488226	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	General Comments		
488227	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
488228	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	LTC Totalizer Reading	4578.00	kw
488229	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
488230	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	General Comments	saftey barrier cord is frayed and broken. 275 feet of new rope/chain is needed along with means to attach signs to rope/chain (ziptie)	
488231	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
488232	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
488233	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
488234	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
488235	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
488236	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	General Comments		
488237	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Grounds in Place?	y	
488238	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
488239	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	General Comments		
488240	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
488241	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
488242	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
488243	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
488244	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
488245	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
488246	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
488247	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
488248	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
488249	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
488250	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	789.12	kw
488251	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
488252	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
488253	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
488254	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
488255	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
488256	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
488257	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
488258	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
488259	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
488260	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
488261	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
488262	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	720	
488263	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
488264	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
488265	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
488266	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
488267	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
488268	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
488269	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
488270	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
488271	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
488272	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
488273	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
488274	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
488275	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
488276	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
488277	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
488278	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
488279	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
488280	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0960	
488281	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
488282	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
488283	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
488284	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
488285	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
488286	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Current Tap Position	12L	
488287	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
488288	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
488289	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
488290	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
488291	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
488292	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
488293	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
488294	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
488295	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
488296	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
488297	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
488298	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
488299	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
488300	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
488301	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
488302	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
488303	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
488304	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
488305	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
488306	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
488307	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
488308	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
488309	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
488310	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
488311	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
488312	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	General Comments		
488313	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
488314	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
488315	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
488316	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
488317	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC
488318	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
488319	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
488320	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
488321	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
488322	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
488323	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2L	
488324	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
488325	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
488326	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
488327	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
488328	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
488329	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
488330	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	2R	
488331	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
488332	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
488333	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
488334	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
488335	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
488336	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Maintenance Operations	0	
488337	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Grounds in Place?	y	
488338	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	General Comments		
488339	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	General Comments		
488340	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Foundation Condition	Good	
488341	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Follow-up Action Required?	n	
488342	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Follow-up Action Required?	n	
488343	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Operations Ground	0	
488344	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Operations C Ø	0	
488345	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Operations B Ø	0	
488346	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Operations A Ø	0	
488347	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
488348	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
488349	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
488350	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Equipment Properly Labeled?	y	
488351	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Cabinet Paint Condition	Good	
488352	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
488353	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Oil Temp Max	35	°C
488354	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Oil Temp Present	40	°C
488355	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
488356	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
488357	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
488358	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
488359	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
488360	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
488361	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
488362	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
488363	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
488364	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Winding Temp Max	40	°C
488365	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
488366	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
488367	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
488368	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Bushings Connection/Risers	Good	
488369	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
488370	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Bushing Condition	Good	
488371	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Amps C Ø	75.0	
488372	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Amps B Ø	68.0	
488373	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Amps A Ø	71.0	
488374	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Winding Temp Present	40	°C
488375	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
488376	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
488377	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
488378	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
488379	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	9 Month Operations	2	
488380	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
488381	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
488382	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
488383	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	General Comments		
488384	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
488385	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
488386	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
488387	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Vegetation	None	
488388	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
488389	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
488390	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
488391	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
488392	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
488393	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
488394	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
488395	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
488396	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
488397	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
488398	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
488399	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
488400	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
488401	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
488402	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
488403	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	General Comments		
488404	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
488405	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
488406	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
488407	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
488408	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
488409	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
488410	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
488411	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
488412	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	General Comments		
488413	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
488414	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
488415	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
488416	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
488417	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	88	
488418	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
488419	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
488420	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	63	
488421	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Amps C Ø	1.3	
488422	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Amps B Ø	6.8	
488423	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Amps A Ø	1.8	
488424	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Regulator As Left Counter	106489	
488425	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
488426	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
488427	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	366244	
488428	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
488429	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
488430	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
488431	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
488432	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
488433	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
488434	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
488435	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Clear of Trash?	y	
488436	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
488437	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
488438	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
488439	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
488440	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
488441	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
488442	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
488443	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
488444	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
488445	4/8/2019 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
488446	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Amps B Ø	100.0	
488447	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Amps A Ø	100.0	
488448	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
488449	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
488450	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Clear of Trash?	y	
488451	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
488452	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
488453	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
488454	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
488455	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
488456	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
488457	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
488458	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
488459	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
488460	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
488461	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
488462	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
488463	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
488464	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
488465	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
488466	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
488467	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	Follow-up Action Required?	n	
488468	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
488469	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
488470	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
488471	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Top Oil Temperature Present	35	°C
488472	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
488473	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
488474	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
488475	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
488476	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
488477	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
488478	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
488479	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
488480	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
488481	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
488482	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
488483	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
488484	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
488485	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Cabinet Paint Condition	Good	
488486	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
488487	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
488488	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
488489	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
488490	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
488491	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
488492	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
488493	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	270	
488494	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	270	
488495	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
488496	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
488497	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
488498	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
488499	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
488500	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
488501	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
488502	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
488503	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
488504	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
488505	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
488506	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Foundation Condition	Good	
488507	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
488508	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
488509	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	General Comments		
488510	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
488511	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
488512	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Bushings Connection/Risers	Good	
488513	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Bushing Condition	Good	
488514	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Amps C Ø	60.0	
488515	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Amps B Ø	60.0	
488516	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
488517	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
488518	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
488519	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
488520	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
488521	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
488522	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
488523	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
488524	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
488525	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
488526	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6140.16	kw
488527	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
488528	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
488529	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	General Comments		
488530	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	General Comments		
488531	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Foundation Condition	Good	
488532	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Follow-up Action Required?	n	
488533	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Follow-up Action Required?	n	
488534	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Operations Ground	0	
488535	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Operations C Ø	0	
488536	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	2.89	%
488537	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	367.0	
488538	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	370.0	
488539	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	375.0	
488540	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
488541	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
488542	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
488543	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
488544	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
488545	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
488546	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
488547	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
488548	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
488549	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
488550	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
488551	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
488552	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
488553	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
488554	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
488555	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
488556	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
488557	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	643	
488558	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Operations B Ø	0	
488559	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Operations A Ø	0	
488560	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Top Oil Temperature Max	35	°C
488561	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
488562	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
488563	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
488564	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
488565	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
488566	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
488567	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
488568	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	Follow-up Action Required?	n	
488569	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Vegetation	None	
488570	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
488571	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
488572	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
488573	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
488574	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
488575	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
488576	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
488577	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
488578	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
488579	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
488580	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
488581	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Ambient Temp	53	°F
488582	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
488583	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
488584	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Clear of Trash?	y	
488585	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
488586	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
488587	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
488588	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
488589	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
488590	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
488591	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
488592	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	600.0	
488593	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
488594	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	General Comments		
488595	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	600.0	
488596	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	600.0	
488597	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
488598	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
488599	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
488600	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC Max Tap Position	13L	
488601	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
488602	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	193	
488603	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
488604	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
488605	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
488606	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Amps A Ø	60.0	
488607	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
488608	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
488609	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
488610	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
488611	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
488612	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
488613	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
488614	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	9 Month Operations	4	
488615	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
488616	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Tank Leaks	None	
488617	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
488618	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Regulator As Left Counter	23958	
488619	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
488620	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
488621	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
488622	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
488623	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
488624	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
488625	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	643	
488626	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6396	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
488627	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
488628	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
488629	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
488630	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
488631	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
488632	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
488633	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
488634	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
488635	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
488636	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
488637	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
488638	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
488639	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
488640	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
488641	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
488642	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
488643	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
488644	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
488645	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
488646	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
488647	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	General Comments		
488648	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
488649	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
488650	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
488651	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Amps B Ø	170.0	
488652	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Amps A Ø	150.0	
488653	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
488654	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
488655	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
488656	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	9 Month Operations	2	
488657	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Foundation Condition	Good	
488658	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
488659	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Unknown Operations	0	
488660	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Tank Paint Condition	Good	
488661	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
488662	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
488663	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
488664	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
488665	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
488666	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	9 Months Operations	0	
488667	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
488668	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
488669	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
488670	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	838	
488671	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	840	
488672	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Switching Operations	0	
488673	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	General Comments		
488674	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Operations This Read Vac	0	
488675	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
488676	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
488677	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
488678	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
488679	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
488680	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	171	
488681	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
488682	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
488683	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
488684	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Vegetation	None	
488685	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
488686	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
488687	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	171	
488688	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
488689	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
488690	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
488691	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
488692	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
488693	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
488694	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
488695	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Operations Counter AL	266	
488696	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
488697	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
488698	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	4384	
488699	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	4384	
488700	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
488701	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	9L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
488702	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	9L	
488703	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	11L	
488704	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	376	
488705	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
488706	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
488707	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
488708	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	General Comments		
488709	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
488710	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	Oil Temp Max	60	°C
488711	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
488712	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
488713	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
488714	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
488715	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
488716	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
488717	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
488718	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
488719	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Foundation Condition	Good	
488720	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Follow-up Action Required?	n	
488721	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Follow-up Action Required?	n	
488722	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	Totalizer Meter Reading	.7630	
488723	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
488724	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Operations Ground	0	
488725	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Operations C Ø	0	
488726	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Operations B Ø	0	
488727	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Operations A Ø	0	
488728	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
488729	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
488730	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
488731	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Equipment Properly Labeled?	y	
488732	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Cabinet Paint Condition	Good	
488733	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
488734	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
488735	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
488736	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	General Comments		
488737	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
488738	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Bushings Connection/Risers	Good	
488739	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Bushing Condition	Good	
488740	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Amps C Ø	130.0	
488741	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
488742	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	560.0	
488743	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
488744	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
488745	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
488746	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	53	°F
488747	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
488748	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
488749	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
488750	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
488751	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
488752	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
488753	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
488754	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
488755	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	General Comments		
488756	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
488757	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
488758	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
488759	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
488760	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
488761	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
488762	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
488763	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
488764	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
488765	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
488766	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
488767	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
488768	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
488769	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
488770	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
488771	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	General Comments		
488772	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
488773	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
488774	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
488775	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
488776	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
488777	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
488778	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
488779	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
488780	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
488781	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
488782	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
488783	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
488784	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
488785	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
488786	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Operations Counter AF	266	
488787	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Moisture and Leak Free?	y	
488788	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Maintenance Operations	0	
488789	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
488790	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
488791	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
488792	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Heaters (All) Functioning?	y	
488793	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Grounds in Place?	y	
488794	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
488795	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
488796	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
488797	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
488798	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
488799	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
488800	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
488801	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
488802	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	General Comments		
488803	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
488804	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
488805	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
488806	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
488807	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
488808	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
488809	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
488810	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	BCH000903	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
488811	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	BCH000903	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
488812	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	BCH000903	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
488813	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	BCH000903	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
488814	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	BCH000903	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
488815	4/8/2019 15:42	Distribution	Columbia Quarterly Inspection	BCH000903	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
488816	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
488817	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
488818	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
488819	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
488820	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC As Found Counter	64994	
488821	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC As Left Counter	64994	
488822	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
488823	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
488824	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	550.0	
488825	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	575.0	
488826	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
488827	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
488828	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	2.89	%
488829	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	2.89	%
488830	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
488831	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
488832	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
488833	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
488834	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
488835	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
488836	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
488837	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
488838	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
488839	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
488840	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
488841	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
488842	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
488843	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
488844	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
488845	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
488846	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	General Comments		
488847	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
488848	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
488849	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Foundation Condition	Good	
488850	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
488851	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
488852	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
488853	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
488854	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
488855	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
488856	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
488857	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
488858	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
488859	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
488860	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Foundation Condition	Good	
488861	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
488862	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
488863	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	General Comments		
488864	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Clear of Trash?	y	
488865	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
488866	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
488867	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
488868	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
488869	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
488870	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
488871	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
488872	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
488873	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
488874	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
488875	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
488876	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
488877	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
488878	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	Oil Temp Max	70	°C
488879	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
488880	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
488881	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	LTC Totalizer Reading	7881.60	kw
488882	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
488883	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	General Comments		
488884	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	General Comments		
488885	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
488886	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	All Connections OK?	y	
488887	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
488888	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	Follow-up Action Required?	n	
488889	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	Follow-up Action Required?	n	
488890	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	General Comments		
488891	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	LTC Operation Checked?	y	
488892	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
488893	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
488894	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
488895	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	VRR Time Delay	30	Seconds
488896	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
488897	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
488898	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
488899	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
488900	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
488901	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	279	
488902	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	279	
488903	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
488904	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
488905	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
488906	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
488907	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	General Comments		
488908	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	12.0	
488909	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	7.0	
488910	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	9.0	
488911	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
488912	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
488913	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
488914	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
488915	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
488916	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
488917	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
488918	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
488919	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
488920	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	287.0	
488921	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
488922	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
488923	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
488924	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
488925	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
488926	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
488927	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
488928	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
488929	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	810	
488930	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	810	
488931	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	3	
488932	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	289.0	
488933	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	282.0	
488934	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
488935	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
488936	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
488937	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
488938	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
488939	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
488940	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
488941	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
488942	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
488943	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
488944	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
488945	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
488946	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
488947	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
488948	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	General Comments		
488949	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
488950	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Foundation Condition	Good	
488951	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
488952	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
488953	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
488954	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
488955	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
488956	4/8/2019 13:46	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
488957	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
488958	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
488959	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
488960	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	Totalizer Meter Reading	.8210	
488961	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
488962	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
488963	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
488964	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
488965	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
488966	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
488967	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
488968	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
488969	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
488970	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
488971	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
488972	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	3	
488973	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
488974	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	B0426	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
488975	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	B0426	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
488976	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	B0426	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
488977	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	B0426	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
488978	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
488979	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
488980	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
488981	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
488982	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
488983	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
488984	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
488985	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
488986	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
488987	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
488988	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
488989	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
488990	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
488991	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
488992	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
488993	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
488994	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
488995	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	300	
488996	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	200	
488997	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	300	
488998	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0	%
488999	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.2	%
489000	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0	%
489001	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
489002	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
489003	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
489004	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
489005	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
489006	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
489007	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	Temp guage is seeping very slightly	
489008	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
489009	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.4	psi
489010	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
489011	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
489012	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
489013	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
489014	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	Seeping	
489015	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
489016	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
489017	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
489018	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
489019	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
489020	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
489021	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
489022	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
489023	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
489024	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
489025	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
489026	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
489027	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
489028	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
489029	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
489030	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	General Comments	There is a washout where the driveway crosses the small creek and culvert.Road is washed out again	
489031	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
489032	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
489033	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
489034	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
489035	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
489036	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
489037	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
489038	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
489039	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
489040	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
489041	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
489042	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	5.0	VDC
489043	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	10.0	VDC
489044	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
489045	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
489046	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
489047	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
489048	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
489049	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
489050	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
489051	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
489052	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
489053	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
489054	4/8/2019 15:51	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
489055	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
489056	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
489057	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
489058	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
489059	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Vegetation	None	
489060	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
489061	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
489062	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
489063	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
489064	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	34.65	%
489065	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	34.65	%
489066	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	34.65	%
489067	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
489068	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	screw on filter	
489069	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
489070	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
489071	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
489072	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
489073	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
489074	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
489075	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
489076	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
489077	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
489078	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
489079	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	open	
489080	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
489081	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	790	
489082	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	n	
489083	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
489084	4/8/2019 16:46	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
489085	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC As Found Counter	418619	
489086	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC As Left Counter	418619	
489087	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
489088	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
489089	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	7L	
489090	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
489091	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
489092	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	139	
489093	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
489094	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
489095	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
489096	4/8/2019 10:53	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
489097	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
489098	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
489099	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
489100	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
489101	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
489102	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
489103	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
489104	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
489105	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
489106	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
489107	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
489108	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10.0	
489109	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
489110	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
489111	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
489112	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
489113	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
489114	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
489115	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
489116	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
489117	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
489118	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
489119	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
489120	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
489121	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
489122	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
489123	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
489124	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
489125	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
489126	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
489127	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
489128	4/8/2019 16:02	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
489129	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
489130	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
489131	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
489132	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
489133	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
489134	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
489135	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
489136	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
489137	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
489138	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
489139	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
489140	4/8/2019 16:01	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
489141	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	19.41	%
489142	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	16.99	%
489143	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
489144	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
489145	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
489146	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
489147	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Ambient Temp	59	°F
489148	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
489149	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
489150	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
489151	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
489152	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Unknown Operations	0	
489153	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
489154	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
489155	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
489156	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	General Comments		
489157	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	General Comments		
489158	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
489159	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
489160	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Follow-up Action Required?	n	
489161	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
489162	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
489163	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
489164	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
489165	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
489166	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
489167	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
489168	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
489169	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
489170	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
489171	4/9/2019 6:42	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
489172	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
489173	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
489174	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
489175	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
489176	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
489177	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
489178	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
489179	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
489180	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
489181	4/8/2019 10:05	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
489182	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
489183	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
489184	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
489185	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
489186	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
489187	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	6.07	%
489188	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
489189	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
489190	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
489191	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Moisture and Leak Free?	y	
489192	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Operations Counter AF	140	
489193	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
489194	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Operations Counter AL	140	
489195	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Operations This Read Vac	0	
489196	4/8/2019 15:32	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Switching Operations	0	
489197	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
489198	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
489199	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
489200	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
489201	4/8/2019 14:26	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
489202	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	B0270	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
489203	4/8/2019 16:16	Distribution	Pineville Substation Department Transform	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
489204	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	1L	
489205	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	10L	
489206	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
489207	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	359	
489208	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	9L	
489209	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	143852	
489210	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	143852	
489211	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	General Comments		
489212	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
489213	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
489214	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
489215	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
489216	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
489217	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
489218	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
489219	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
489220	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
489221	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
489222	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
489223	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
489224	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
489225	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
489226	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
489227	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	14	
489228	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
489229	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
489230	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
489231	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
489232	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
489233	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
489234	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
489235	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
489236	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
489237	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
489238	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
489239	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
489240	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	13	
489241	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	929	
489242	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	929	
489243	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
489244	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
489245	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	9	
489246	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
489247	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
489248	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
489249	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
489250	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
489251	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
489252	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
489253	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
489254	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
489255	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
489256	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
489257	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
489258	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
489259	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
489260	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
489261	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
489262	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
489263	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
489264	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	3	
489265	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
489266	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
489267	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
489268	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
489269	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	3	
489270	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
489271	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
489272	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
489273	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	825	
489274	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
489275	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
489276	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
489277	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	825	
489278	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
489279	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
489280	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
489281	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
489282	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
489283	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
489284	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
489285	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
489286	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
489287	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
489288	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
489289	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
489290	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
489291	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
489292	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
489293	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
489294	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
489295	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
489296	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
489297	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
489298	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
489299	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
489300	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
489301	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
489302	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
489303	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	412	
489304	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	412	
489305	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
489306	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
489307	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
489308	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
489309	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
489310	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
489311	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
489312	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
489313	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	110.0	
489314	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	110.0	
489315	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	110.0	
489316	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
489317	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
489318	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
489319	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
489320	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
489321	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
489322	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
489323	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
489324	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
489325	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
489326	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
489327	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
489328	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
489329	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
489330	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
489331	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
489332	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
489333	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
489334	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
489335	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
489336	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
489337	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
489338	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
489339	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
489340	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
489341	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
489342	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
489343	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	956	
489344	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
489345	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	956	
489346	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
489347	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
489348	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
489349	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
489350	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	50.0	
489351	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
489352	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	50.0	
489353	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	50.0	
489354	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
489355	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
489356	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
489357	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
489358	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
489359	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
489360	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
489361	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
489362	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
489363	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
489364	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
489365	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
489366	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
489367	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
489368	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
489369	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
489370	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
489371	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
489372	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
489373	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
489374	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
489375	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
489376	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
489377	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
489378	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
489379	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	259	
489380	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	400.0	
489381	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	400.0	
489382	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
489383	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
489384	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
489385	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
489386	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
489387	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
489388	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
489389	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
489390	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
489391	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	400.0	
489392	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
489393	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	259	
489394	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
489395	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
489396	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
489397	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
489398	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
489399	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
489400	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
489401	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
489402	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
489403	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
489404	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
489405	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
489406	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
489407	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
489408	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
489409	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
489410	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
489411	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
489412	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	BCH000407	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
489413	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	BCH000407	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
489414	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	BCH000407	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
489415	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	BCH000449	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
489416	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	BCH000449	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
489417	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	BCH000449	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
489418	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	BCH000449	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
489419	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	2.41	%
489420	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
489421	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
489422	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	4.82	%
489423	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
489424	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	492	
489425	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	492	
489426	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	2	
489427	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
489428	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
489429	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
489430	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
489431	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
489432	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	597	
489433	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	597	
489434	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
489435	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
489436	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
489437	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	25.0	
489438	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	25.0	
489439	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	4.82	%
489440	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
489441	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
489442	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
489443	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
489444	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
489445	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
489446	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
489447	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
489448	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
489449	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	1	
489450	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
489451	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
489452	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
489453	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
489454	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	2	
489455	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	2	
489456	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	972	
489457	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	972	
489458	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
489459	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
489460	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
489461	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	27.00	
489462	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	27.00	
489463	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	325.0	
489464	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	325.0	
489465	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	325.0	
489466	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
489467	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
489468	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
489469	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
489470	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
489471	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
489472	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	25.0	
489473	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	18.07	%
489474	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	18.07	%
489475	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	30.11	%
489476	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
489477	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
489478	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
489479	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	25.0	
489480	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	25.0	
489481	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
489482	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
489483	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
489484	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	50.0	
489485	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	50.0	
489486	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	50.0	
489487	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	25.0	
489488	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	6.02	%
489489	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	7.23	%
489490	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	10.84	%
489491	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	5	
489492	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	27.7	%
489493	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	31.32	%
489494	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	39	
489495	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
489496	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
489497	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	16	
489498	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	26.5	%
489499	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
489500	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
489501	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
489502	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
489503	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
489504	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
489505	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
489506	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	787	
489507	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	787	
489508	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
489509	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	OK	
489510	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
489511	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
489512	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
489513	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
489514	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	740	
489515	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
489516	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
489517	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	740	
489518	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
489519	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
489520	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
489521	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	50.0	
489522	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	50.0	
489523	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	A&B IOC	
489524	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
489525	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
489526	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	50.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
489527	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
489528	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	1	
489529	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
489530	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
489531	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
489532	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
489533	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
489534	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
489535	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
489536	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
489537	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
489538	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
489539	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
489540	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
489541	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
489542	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
489543	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
489544	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
489545	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	596529	
489546	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
489547	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	9R	
489548	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	5L	
489549	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
489550	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
489551	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	33.0	
489552	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	47.0	
489553	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
489554	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
489555	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	518	
489556	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
489557	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
489558	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
489559	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
489560	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
489561	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
489562	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
489563	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	60.0	
489564	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
489565	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
489566	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
489567	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
489568	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
489569	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1R	
489570	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
489571	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
489572	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
489573	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
489574	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
489575	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
489576	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	9R	
489577	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	2L	
489578	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
489579	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
489580	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
489581	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
489582	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	14169	
489583	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
489584	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
489585	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
489586	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
489587	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
489588	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
489589	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
489590	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
489591	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
489592	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
489593	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	82579	
489594	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
489595	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
489596	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
489597	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
489598	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
489599	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
489600	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
489601	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
489602	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
489603	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
489604	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	5L	
489605	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
489606	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	7R	
489607	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
489608	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
489609	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
489610	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
489611	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
489612	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Maintenance Operations	0	
489613	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
489614	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	General Comments	OPEN	
489615	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
489616	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	General Comments		
489617	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
489618	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
489619	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
489620	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
489621	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
489622	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Operations Ground	0	
489623	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Follow-up Action Required?	n	
489624	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Follow-up Action Required?	n	
489625	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
489626	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Foundation Condition	Good	
489627	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
489628	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	General Comments		
489629	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
489630	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Accumulated Fault Duty B Ph V	2.85	%
489631	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
489632	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
489633	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
489634	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Max Tap Position	8L	
489635	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
489636	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	9 Month Operations	7	
489637	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Accumulated Fault Duty A Ph V	1.98	%
489638	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
489639	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	455	
489640	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	455	
489641	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Accumulated Fault Duty C Ph V	2.85	%
489642	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
489643	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
489644	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
489645	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
489646	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
489647	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
489648	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
489649	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
489650	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
489651	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
489652	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
489653	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
489654	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
489655	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
489656	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
489657	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	General Comments		
489658	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
489659	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
489660	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Readings	Oil Temp Max	25	°C
489661	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
489662	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
489663	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
489664	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Follow-up Action Required?	n	
489665	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	General Comments		
489666	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
489667	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
489668	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Maintenance Operations	0	
489669	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Operations Counter AF	178	
489670	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Tank Leaks	None	
489671	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
489672	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
489673	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Follow-up Action Required?	n	
489674	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Operations Counter AL	187	
489675	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Operations This Read Vac	9	
489676	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Switching Operations	5	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
489677	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Unknown Operations	0	
489678	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Patrol Inspection	General Comments		
489679	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
489680	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
489681	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
489682	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
489683	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Oil Temp Max	40	°C
489684	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
489685	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
489686	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
489687	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Oil Temp Present	30	°C
489688	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
489689	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
489690	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
489691	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	LTC Operation Checked?	y	
489692	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
489693	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
489694	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	General Comments		
489695	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	Follow-up Action Required?	n	
489696	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
489697	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
489698	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
489699	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
489700	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Amps C Ø	32.0	
489701	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Amps B Ø	31.0	
489702	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Amps A Ø	34.0	
489703	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
489704	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
489705	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
489706	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
489707	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
489708	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	General Comments		
489709	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
489710	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
489711	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Foundation Condition	Good	
489712	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
489713	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
489714	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	240.0	
489715	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
489716	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
489717	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
489718	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
489719	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Accumulated Fault Duty A Ph V	2.85	%
489720	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
489721	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
489722	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Amps B Ø	50.0	
489723	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Amps A Ø	50.0	
489724	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
489725	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
489726	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
489727	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
489728	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
489729	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
489730	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
489731	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	BB0388	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	120.0	
489732	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	BB0388	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	120.0	
489733	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
489734	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
489735	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
489736	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
489737	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
489738	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	ST000353	Structure	662-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
489739	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	ST000353	Structure	662-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
489740	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	ST000353	Structure	662-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
489741	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
489742	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	BB0388	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	120.0	
489743	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
489744	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Operations Ground	0	
489745	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Operations C Ø	0	
489746	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
489747	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
489748	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Moisture and Leak Free?	y	
489749	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Maintenance Operations	0	
489750	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Heaters (All) Functioning?	y	
489751	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
489752	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Tank Leaks	None	
489753	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
489754	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
489755	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Foundation Condition	Good	
489756	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
489757	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
489758	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	General Comments		
489759	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
489760	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Accumulated Fault Duty B Ph V	3.95	%
489761	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Accumulated Fault Duty C Ph V	4.94	%
489762	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Amps A Ø	200.0	
489763	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Amps B Ø	120.0	
489764	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Amps C Ø	160.0	
489765	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
489766	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
489767	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
489768	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Amps A Ø	10.0	
489769	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Amps B Ø	13.0	
489770	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Amps C Ø	8.0	
489771	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
489772	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
489773	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
489774	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
489775	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
489776	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Operations B Ø	0	
489777	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
489778	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Operations A Ø	0	
489779	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
489780	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	General Comments		
489781	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
489782	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Grounds in Place?	y	
489783	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	General Comments		
489784	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
489785	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
489786	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	General Comments		
489787	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
489788	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
489789	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
489790	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
489791	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
489792	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
489793	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Readings	Winding Temp Max	25	°C
489794	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Readings	Totalizer Meter Reading	.6470	
489795	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
489796	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
489797	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
489798	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
489799	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
489800	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
489801	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
489802	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
489803	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
489804	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Unknown Operations	0	
489805	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Tank Paint Condition	Good	
489806	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Switching Operations	0	
489807	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
489808	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Operations This Read Vac	0	
489809	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
489810	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
489811	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
489812	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
489813	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
489814	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
489815	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
489816	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
489817	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
489818	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
489819	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
489820	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
489821	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	9 Months Operations	0	
489822	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
489823	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
489824	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1338	
489825	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1338	
489826	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
489827	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Operations Counter	782	
489828	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
489829	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Switching Operations	0	
489830	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
489831	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Operations This Read Vac	0	
489832	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Operations Counter AL	301	
489833	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	395	
489834	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
489835	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	395	
489836	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	3	
489837	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
489838	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
489839	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
489840	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	120.0	
489841	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	120.0	
489842	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	120.0	
489843	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Operations Counter AF	301	
489844	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Maintenance Operations	0	
489845	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	General Comments		
489846	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
489847	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
489848	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
489849	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	All Connections OK?	y	
489850	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Amps A Ø	0.0	
489851	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	General Comments		
489852	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Readings	General Comments		
489853	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
489854	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
489855	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
489856	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
489857	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Follow-up Action Required?	n	
489858	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	320.0	
489859	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
489860	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Regulator As Left Counter	71704	
489861	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Operations Counter AL	823	
489862	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Operations Counter AF	823	
489863	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
489864	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
489865	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
489866	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
489867	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
489868	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
489869	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
489870	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	LTC Totalizer Reading	11232.00	kw
489871	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Bushing Condition	Good	
489872	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
489873	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
489874	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
489875	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
489876	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
489877	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	FE000839	Fence	662-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
489878	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Bushings Connection/Risers	Good	
489879	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	FE000839	Fence	662-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
489880	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
489881	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	General Comments		
489882	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	General Comments		
489883	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
489884	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
489885	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Follow-up Action Required?	n	
489886	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
489887	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
489888	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
489889	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
489890	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
489891	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
489892	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
489893	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	FE000839	Fence	662-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
489894	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	FE000839	Fence	662-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
489895	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	FE000839	Fence	662-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
489896	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
489897	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Readings	LTC Totalizer Reading	9316.80	kw
489898	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
489899	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
489900	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
489901	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	FE000839	Fence	662-Fence	Fence Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
489902	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
489903	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Adjusted Amps A Phase V	17.75	
489904	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
489905	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
489906	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
489907	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	FE000839	Fence	662-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
489908	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
489909	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
489910	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
489911	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
489912	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
489913	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	General Comments		
489914	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
489915	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
489916	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
489917	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	General Comments		
489918	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
489919	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Max Tap Position	11L	
489920	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
489921	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
489922	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	General Comments		
489923	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
489924	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
489925	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
489926	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
489927	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
489928	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Switching Operations	0	
489929	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Unknown Operations	0	
489930	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	Follow-up Action Required?	n	
489931	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
489932	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	General Comments		
489933	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
489934	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Cabinet Paint Condition	Good	
489935	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Equipment Properly Labeled?	y	
489936	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
489937	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
489938	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	General Comments		
489939	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
489940	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Operations A Ø	0	
489941	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Operations B Ø	0	
489942	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Operations C Ø	0	
489943	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
489944	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
489945	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
489946	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
489947	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
489948	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
489949	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
489950	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
489951	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
489952	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	3	
489953	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
489954	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Readings	Follow-up Action Required?	n	
489955	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
489956	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
489957	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
489958	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	19.22	
489959	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
489960	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
489961	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
489962	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	FE000839	Fence	662-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
489963	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	80.0	
489964	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	80.0	
489965	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	80.0	
489966	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.43	%
489967	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	3.82	%
489968	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.87	%
489969	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
489970	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Tank Leaks	None	
489971	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
489972	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Operations Counter	28	
489973	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
489974	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
489975	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	General Comments		
489976	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
489977	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
489978	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
489979	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
489980	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
489981	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
489982	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	VRR Time Delay	30	Seconds
489983	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Amps A Ø	5.0	
489984	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Amps B Ø	5.0	
489985	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Amps C Ø	5.0	
489986	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
489987	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
489988	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
489989	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
489990	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
489991	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
489992	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Operations Counter AF	419	
489993	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
489994	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
489995	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Foundation Condition	Good	
489996	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
489997	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
489998	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
489999	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
490000	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
490001	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
490002	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	0	
490003	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	General Comments		
490004	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
490005	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
490006	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
490007	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
490008	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
490009	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
490010	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
490011	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Operations A Ø	4	
490012	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Operations B Ø	0	
490013	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
490014	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
490015	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
490016	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
490017	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
490018	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
490019	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
490020	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	General Comments		
490021	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
490022	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	General Comments		
490023	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
490024	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
490025	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
490026	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Operations Counter	291	
490027	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
490028	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
490029	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
490030	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Totalizer Meter Reading	.4680	
490031	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
490032	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
490033	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Operations C Ø	0	
490034	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Operations Ground	0	
490035	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
490036	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
490037	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
490038	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
490039	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
490040	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
490041	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	9 Month Operations	9	
490042	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
490043	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	16	
490044	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	8.44	%
490045	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	9.49	%
490046	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	8.44	%
490047	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	240.0	
490048	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
490049	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Winding Temp Max	40	°C
490050	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	240.0	
490051	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Winding Temp Present	30	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
490052	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
490053	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
490054	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
490055	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
490056	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Operations Ground	0	
490057	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Operations C Ø	0	
490058	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Operations B Ø	0	
490059	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
490060	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
490061	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Amps C Ø	0.0	
490062	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
490063	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Amps A Ø	5.0	
490064	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
490065	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
490066	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
490067	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Clear of Trash?	y	
490068	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
490069	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
490070	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Amps B Ø	0.0	
490071	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
490072	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
490073	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Vegetation	None	
490074	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
490075	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
490076	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
490077	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
490078	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Operations A Ø	0	
490079	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
490080	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
490081	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
490082	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	General Comments		
490083	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
490084	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
490085	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
490086	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
490087	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
490088	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
490089	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
490090	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
490091	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
490092	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
490093	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Operations This Read AM	0	
490094	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
490095	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
490096	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
490097	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
490098	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
490099	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	9 Month Operations	9	
490100	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Amps C Ø	50.0	
490101	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
490102	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
490103	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
490104	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Regulator As Left Counter	208338	
490105	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
490106	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
490107	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Operations Counter AL	419	
490108	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
490109	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
490110	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
490111	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
490112	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
490113	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
490114	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
490115	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
490116	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
490117	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
490118	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
490119	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
490120	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Regulator As Left Counter	67591	
490121	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
490122	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Tank Leaks	None	
490123	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
490124	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
490125	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	LTCMechanism	662-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
490126	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
490127	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
490128	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC Operations Since Last Insp	275	
490129	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC Min Tap Position	8L	
490130	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC Max Tap Position	Neutral	
490131	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC Current Tap Position	7L	
490132	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
490133	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC As Left Counter	34810	
490134	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Equipment Properly Labeled?	y	
490135	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
490136	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
490137	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Bushings Connection/Risers	Good	
490138	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Bushing Condition	Good	
490139	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Tank Paint Condition	Good	
490140	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Switching Operations	0	
490141	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
490142	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
490143	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
490144	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Operations This Read SF6	0	
490145	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Operations Counter AL	66	
490146	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Operations Counter AF	66	
490147	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Num Operations Last 9 Months	2	
490148	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
490149	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Maintenance Operations	0	
490150	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
490151	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Grounds in Place?	y	
490152	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	General Comments	y	
490153	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	General Comments		
490154	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
490155	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Foundation Condition	Good	
490156	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Follow-up Action Required?	n	
490157	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Follow-up Action Required?	n	
490158	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Fault Operations	0	
490159	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
490160	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Operations A Ø	0	
490161	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Readings	Amps C Ø	60.0	
490162	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
490163	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
490164	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Grounds in Place?	y	
490165	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	General Comments		
490166	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Foundation Condition	Good	
490167	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Follow-up Action Required?	n	
490168	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
490169	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
490170	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	General Comments		
490171	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
490172	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
490173	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1825	
490174	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1829	
490175	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	4	
490176	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
490177	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
490178	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
490179	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
490180	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
490181	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
490182	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
490183	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
490184	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
490185	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
490186	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
490187	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
490188	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	General Comments		
490189	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
490190	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
490191	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
490192	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
490193	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
490194	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
490195	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
490196	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
490197	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
490198	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
490199	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Bushings Connection/Risers	Good	
490200	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Bushing Condition	Good	
490201	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Amps C Ø	10.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
490202	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Amps B Ø	10.0	
490203	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
490204	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
490205	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
490206	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
490207	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
490208	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
490209	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
490210	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Amps C Ø	360.0	
490211	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Amps B Ø	360.0	
490212	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Amps A Ø	360.0	
490213	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
490214	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
490215	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
490216	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	9 Month Operations	1	
490217	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Unknown Operations	0	
490218	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Switching Operations	0	
490219	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Operations This Read AM	0	
490220	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Operations Counter AL	0	
490221	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Operations Counter AF	530	
490222	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Maintenance Operations	0	
490223	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	General Comments	open	
490224	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Follow-up Action Required?	n	
490225	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Operations Ground	0	
490226	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Operations C Ø	0	
490227	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Operations B Ø	0	
490228	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Operations A Ø	0	
490229	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
490230	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
490231	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
490232	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Operations This Read AM	0	
490233	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Operations Counter AL	618	
490234	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Operations Counter AF	618	
490235	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Maintenance Operations	0	
490236	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	General Comments		
490237	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Follow-up Action Required?	n	
490238	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Operations Ground	0	
490239	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Operations C Ø	0	
490240	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Operations B Ø	0	
490241	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Operations A Ø	0	
490242	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
490243	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
490244	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Amps A Ø	10.0	
490245	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Accumulated Fault Duty C Ph V	1.43	%
490246	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
490247	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Amps C Ø	100.0	
490248	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
490249	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	S0029	LTCMechanism	662-3	LTC Counter Readings	Follow-up Action Required?	n	
490250	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Amps B Ø	75.0	
490251	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Operations B Ø	0	
490252	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Operations C Ø	0	
490253	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Operations Ground	0	
490254	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Follow-up Action Required?	n	
490255	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Follow-up Action Required?	n	
490256	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Foundation Condition	Good	
490257	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	General Comments		
490258	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	General Comments		
490259	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Grounds in Place?	y	
490260	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
490261	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Heaters (All) Functioning?	y	
490262	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Maintenance Operations	0	
490263	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Moisture and Leak Free?	y	
490264	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Operations Counter AF	166	
490265	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Operations Counter AL	166	
490266	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Operations This Read Vac	0	
490267	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
490268	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Switching Operations	0	
490269	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Tank Paint Condition	Good	
490270	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Unknown Operations	0	
490271	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
490272	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC As Found Counter	34810	
490273	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	General Comments		
490274	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	S0029	LTCMechanism	662-3	LTC Counter Readings	General Comments		
490275	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
490276	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
490277	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
490278	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Ambient Temperature	53	°F
490279	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
490280	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	General Comments		
490281	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	General Comments		
490282	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
490283	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
490284	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Operations Ground	0	
490285	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Operations C Ø	0	
490286	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Operations B Ø	0	
490287	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Operations A Ø	0	
490288	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
490289	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
490290	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Unknown Operations	0	
490291	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Switching Operations	0	
490292	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
490293	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
490294	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
490295	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
490296	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
490297	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
490298	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
490299	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
490300	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	39	
490301	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	35	
490302	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Switching Operations	5	
490303	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Operations This Read Vac	5	
490304	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Operations Counter AL	298	
490305	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Operations Counter AF	298	
490306	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Moisture and Leak Free?	y	
490307	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Maintenance Operations	0	
490308	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Heaters (All) Functioning?	y	
490309	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Grounds in Place?	y	
490310	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	9 Month Operations	8	
490311	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Accumulated Fault Duty A Ph V	3.21	%
490312	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Accumulated Fault Duty B Ph V	3.33	%
490313	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Accumulated Fault Duty C Ph V	2.64	%
490314	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Amps A Ø	120.0	
490315	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Amps B Ø	120.0	
490316	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Amps C Ø	120.0	
490317	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
490318	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Switching Operations	0	
490319	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Tank Paint Condition	Good	
490320	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
490321	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
490322	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
490323	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
490324	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Operations A Ø	0	
490325	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Operations B Ø	0	
490326	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Operations C Ø	0	
490327	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Operations Ground	0	
490328	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Follow-up Action Required?	n	
490329	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	9 Month Operations	1	
490330	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Accumulated Fault Duty A Ph V	2.85	%
490331	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Accumulated Fault Duty B Ph V	2.63	%
490332	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Accumulated Fault Duty C Ph V	2.63	%
490333	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
490334	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Ambient Temp	61	°F
490335	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Amps A Ø	.6	
490336	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Amps B Ø	.5	
490337	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Amps C Ø	.5	
490338	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
490339	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
490340	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	9 Months Operations	0	
490341	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
490342	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
490343	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
490344	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	9 Month Operations	8	
490345	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Unknown Operations	0	
490346	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
490347	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Switching Operations	0	
490348	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
490349	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Operations This Read Vac	0	
490350	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Operations Counter AL	168	
490351	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Operations Counter AF	168	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
490352	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Unknown Operations	0	
490353	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Tank Paint Condition	Good	
490354	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
490355	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Maintenance Operations	0	
490356	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
490357	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
490358	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
490359	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
490360	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Clear of Trash?	y	
490361	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Ambient Temperature	53	°F
490362	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
490363	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
490364	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
490365	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
490366	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
490367	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
490368	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
490369	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Fault Operations	0	
490370	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Follow-up Action Required?	n	
490371	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Follow-up Action Required?	n	
490372	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Foundation Condition	Good	
490373	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
490374	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	General Comments		
490375	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	General Comments	y	
490376	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Grounds in Place?	y	
490377	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
490378	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Maintenance Operations	0	
490379	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
490380	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Num Operations Last 9 Months	1	
490381	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Operations Counter AF	46	
490382	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Operations Counter AL	46	
490383	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Operations This Read SF6	0	
490384	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
490385	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Amps A Ø	50.0	
490386	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Amps B Ø	50.0	
490387	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Amps C Ø	50.0	
490388	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Bushing Condition	Good	
490389	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Bushings Connection/Risers	Good	
490390	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
490391	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
490392	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
490393	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Cabinet Paint Condition	Good	
490394	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Equipment Properly Labeled?	y	
490395	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
490396	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
490397	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	General Comments		
490398	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	General Comments		
490399	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0025	BreakerVacuum	417-2134	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
490400	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0025	BreakerVacuum	417-2134	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
490401	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0025	BreakerVacuum	417-2134	VCB Readings	Accumulated Fault Duty A Ph V	.35	%
490402	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0025	BreakerVacuum	417-2134	VCB Readings	9 Month Operations	5	
490403	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Tank Paint Condition	Good	
490404	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Moisture and Leak Free?	y	
490405	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Heaters (All) Functioning?	y	
490406	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	120.0	
490407	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	60.0	
490408	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	60.0	
490409	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
490410	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
490411	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Foundation Condition	Good	
490412	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Follow-up Action Required?	n	
490413	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Follow-up Action Required?	n	
490414	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Operations Ground	0	
490415	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Operations C Ø	0	
490416	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Operations B Ø	0	
490417	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Operations A Ø	0	
490418	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
490419	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
490420	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
490421	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Equipment Properly Labeled?	y	
490422	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Cabinet Paint Condition	Good	
490423	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
490424	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Readings	9 Month Operations	2	
490425	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Readings	Accumulated Fault Duty A Ph V	.7	%
490426	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Readings	Accumulated Fault Duty B Ph V	1.75	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
490427	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Accumulated Fault Duty C Ph V	.35	%
490428	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Amps A Ø	60.0	
490429	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Amps B Ø	67.0	
490430	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
490431	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Operations A Ø	0	
490432	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Operations B Ø	0	
490433	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Operations C Ø	0	
490434	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Operations Ground	0	
490435	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Follow-up Action Required?	n	
490436	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	General Comments		
490437	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Maintenance Operations	0	
490438	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Operations Counter AF	216	
490439	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Operations Counter AL	216	
490440	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Operations This Read Vac	0	
490441	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	General Comments		
490442	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Maintenance Operations	0	
490443	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Operations Counter AF	193	
490444	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Operations Counter AL	193	
490445	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Operations This Read Vac	0	
490446	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Switching Operations	0	
490447	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Unknown Operations	0	
490448	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Switching Operations	0	
490449	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Unknown Operations	0	
490450	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
490451	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
490452	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
490453	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
490454	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
490455	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
490456	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
490457	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
490458	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
490459	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
490460	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
490461	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
490462	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
490463	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
490464	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
490465	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
490466	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
490467	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
490468	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
490469	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
490470	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
490471	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
490472	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Accumulated Fault Duty A Ph V	4.55	%
490473	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Accumulated Fault Duty B Ph V	1.82	%
490474	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Accumulated Fault Duty C Ph V	1.82	%
490475	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Unknown Operations	0	
490476	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	9 Months Operations	4	
490477	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Accumulated Fault Duty A Ph AM	3.64	%
490478	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
490479	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
490480	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
490481	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Accumulated Fault Duty B Ph AM	8.49	%
490482	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
490483	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Accumulated Fault Duty C Ph AM	8.49	%
490484	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Amps A Ø	75.0	
490485	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Amps B Ø	250.0	
490486	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Amps C Ø	260.0	
490487	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
490488	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
490489	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
490490	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Operations A Ø	0	
490491	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Amps B Ø	0.0	
490492	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Amps C Ø	0.0	
490493	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
490494	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
490495	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
490496	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Operations B Ø	0	
490497	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Operations C Ø	0	
490498	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Operations Ground	0	
490499	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Operations A Ø	0	
490500	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Follow-up Action Required?	n	
490501	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
490502	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Maintenance Operations	0	
490503	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Operations Counter AF	116	
490504	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
490505	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
490506	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
490507	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
490508	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
490509	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
490510	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
490511	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Operations A Ø	0	
490512	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Operations B Ø	0	
490513	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Operations C Ø	0	
490514	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Operations Ground	0	
490515	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
490516	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Operations Counter AL	116	
490517	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Operations This Read AM	0	
490518	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Switching Operations	0	
490519	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC Operations Since Last Insp	176	
490520	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC Min Tap Position	5L	
490521	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
490522	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC Current Tap Position	3L	
490523	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
490524	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC As Left Counter	524565	
490525	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC As Found Counter	524555	
490526	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	General Comments		
490527	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	General Comments		
490528	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
490529	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	Follow-up Action Required?	n	
490530	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	LTCC000395	LTCControl	587-1	LTC Control Insp	VRR Time Delay	30	Seconds
490531	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	LTCC000395	LTCControl	587-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
490532	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Operations Counter AL	152	
490533	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	LTCC000395	LTCControl	587-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
490534	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	LTCC000395	LTCControl	587-1	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
490535	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	LTCC000395	LTCControl	587-1	LTC Control Insp	LTC Operation Checked?	y	
490536	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	LTCC000395	LTCControl	587-1	LTC Control Insp	General Comments		
490537	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	LTCC000395	LTCControl	587-1	LTC Control Insp	Follow-up Action Required?	n	
490538	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	LTCC000395	LTCControl	587-1	LTC Control Insp	All Connections OK?	y	
490539	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Unknown Operations	0	
490540	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Tank Paint Condition	Good	
490541	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Switching Operations	2	
490542	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Operations This Read Vac	2	
490543	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Operations Counter AL	186	
490544	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Operations Counter AF	186	
490545	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Moisture and Leak Free?	y	
490546	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Maintenance Operations	0	
490547	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Heaters (All) Functioning?	y	
490548	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Grounds in Place?	y	
490549	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	General Comments		
490550	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	General Comments		
490551	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Foundation Condition	Good	
490552	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Follow-up Action Required?	n	
490553	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Follow-up Action Required?	n	
490554	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Operations Ground	0	
490555	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Operations C Ø	0	
490556	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Operations B Ø	0	
490557	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	9 Month Operations	4	
490558	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
490559	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
490560	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
490561	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Amps A Ø	0.0	
490562	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Operations This Read Vac	1	
490563	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Switching Operations	1	
490564	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Foundation Condition	Good	
490565	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	General Comments		
490566	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	General Comments		
490567	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Grounds in Place?	y	
490568	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
490569	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	0	
490570	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
490571	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
490572	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
490573	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
490574	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
490575	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
490576	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
490577	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	99982	
490578	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Bushings Connection/Risers	Good	
490579	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Bushing Condition	Good	
490580	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Amps C Ø	135.0	
490581	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Amps B Ø	145.0	
490582	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Amps A Ø	130.0	
490583	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
490584	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
490585	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
490586	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
490587	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
490588	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
490589	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
490590	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
490591	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
490592	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
490593	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
490594	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
490595	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
490596	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	99982	
490597	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Maintenance Operations	0	
490598	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
490599	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Operations Counter AF	164	
490600	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Operations Counter AL	164	
490601	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Operations This Read Vac	1	
490602	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Switching Operations	1	
490603	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Tank Paint Condition	Good	
490604	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Unknown Operations	0	
490605	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
490606	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
490607	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
490608	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	9 Month Operations	3	
490609	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Unknown Operations	0	
490610	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Follow-up Action Required?	n	
490611	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
490612	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	General Comments		
490613	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	General Comments		
490614	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
490615	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
490616	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Maintenance Operations	0	
490617	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
490618	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Operations Counter AF	186	
490619	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Operations Counter AL	186	
490620	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Operations This Read Vac	2	
490621	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Switching Operations	2	
490622	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
490623	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Unknown Operations	0	
490624	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
490625	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
490626	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
490627	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	9 Month Operations	3	
490628	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Equipment Properly Labeled?	y	
490629	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Cabinet Paint Condition	Good	
490630	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
490631	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
490632	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
490633	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
490634	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Amps A Ø	460.0	
490635	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Amps B Ø	545.0	
490636	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Amps C Ø	550.0	
490637	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Bushing Condition	Good	
490638	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
490639	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
490640	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
490641	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
490642	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
490643	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
490644	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
490645	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
490646	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
490647	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Operations A Ø	0	
490648	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Operations B Ø	0	
490649	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Operations C Ø	0	
490650	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Operations Ground	0	
490651	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
490652	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
490653	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Follow-up Action Required?	n	
490654	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Heaters (All) Functioning?	y	
490655	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Grounds in Place?	y	
490656	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	General Comments		
490657	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	General Comments		
490658	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Foundation Condition	Good	
490659	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Follow-up Action Required?	n	
490660	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Follow-up Action Required?	n	
490661	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Operations Ground	0	
490662	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Operations C Ø	0	
490663	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Operations B Ø	0	
490664	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Operations A Ø	0	
490665	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
490666	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
490667	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
490668	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Follow-up Action Required?	n	
490669	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Operations Ground	0	
490670	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Operations C Ø	0	
490671	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Operations B Ø	0	
490672	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Operations A Ø	0	
490673	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
490674	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
490675	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
490676	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Equipment Properly Labeled?	y	
490677	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Cabinet Paint Condition	Good	
490678	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
490679	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
490680	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
490681	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Operations A Ø	0	
490682	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Bushings Connection/Risers	Good	
490683	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Bushing Condition	Good	
490684	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Amps C Ø	70.0	
490685	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Amps B Ø	70.0	
490686	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Amps A Ø	75.0	
490687	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
490688	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
490689	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
490690	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	9 Month Operations	3	
490691	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Unknown Operations	0	
490692	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Tank Paint Condition	Good	
490693	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Switching Operations	2	
490694	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Operations This Read Vac	2	
490695	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Operations Counter AL	212	
490696	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Operations Counter AF	212	
490697	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Moisture and Leak Free?	y	
490698	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Maintenance Operations	0	
490699	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Amps C Ø	0.0	
490700	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Amps B Ø	0.0	
490701	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Amps A Ø	0.0	
490702	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
490703	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
490704	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Amps A Ø	150.0	
490705	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
490706	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
490707	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
490708	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Accumulated Fault Duty B Ph V	2.38	%
490709	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Accumulated Fault Duty A Ph V	2.85	%
490710	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	9 Month Operations	14	
490711	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	9 Months Operations	0	
490712	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
490713	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	9 Months Operations	0	
490714	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
490715	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
490716	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
490717	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	8012	
490718	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	8010	
490719	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
490720	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
490721	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
490722	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
490723	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
490724	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
490725	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
490726	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
490727	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
490728	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
490729	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	320.0	
490730	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	320.0	
490731	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	320.0	
490732	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
490733	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
490734	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
490735	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
490736	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Unknown Operations	0	
490737	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Tank Paint Condition	Good	
490738	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Switching Operations	2	
490739	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Operations This Read Vac	2	
490740	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Operations Counter AL	212	
490741	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Operations Counter AF	212	
490742	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Moisture and Leak Free?	y	
490743	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Maintenance Operations	0	
490744	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Amps B Ø	130.0	
490745	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Amps A Ø	130.0	
490746	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Accumulated Fault Duty C Ph V	2.38	%
490747	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Accumulated Fault Duty B Ph V	1.7	%
490748	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Accumulated Fault Duty A Ph V	2.04	%
490749	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	9 Month Operations	7	
490750	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	9 Month Operations	1	
490751	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
490752	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Bushings Connection/Risers	Good	
490753	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Bushing Condition	Good	
490754	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Amps C Ø	90.0	
490755	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Amps B Ø	95.0	
490756	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Amps A Ø	90.0	
490757	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
490758	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
490759	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
490760	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	9 Month Operations	3	
490761	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
490762	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
490763	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
490764	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	LTCC000814	LTCControl	662-2	LTC Control Insp	VRR Time Delay	30	Seconds
490765	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	LTCC000814	LTCControl	662-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
490766	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	LTCC000814	LTCControl	662-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
490767	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	LTCC000814	LTCControl	662-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
490768	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	LTCC000814	LTCControl	662-2	LTC Control Insp	LTC Operation Checked?	y	
490769	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	LTCC000814	LTCControl	662-2	LTC Control Insp	General Comments		
490770	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	LTCC000814	LTCControl	662-2	LTC Control Insp	Follow-up Action Required?	n	
490771	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	LTCC000814	LTCControl	662-2	LTC Control Insp	All Connections OK?	y	
490772	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Amps A Ø	0.0	
490773	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Amps B Ø	0.0	
490774	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Amps C Ø	0.0	
490775	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
490776	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
490777	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
490778	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Operations A Ø	0	
490779	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
490780	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
490781	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
490782	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Operations B Ø	0	
490783	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Operations C Ø	0	
490784	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Operations Ground	0	
490785	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Follow-up Action Required?	n	
490786	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	General Comments		
490787	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Maintenance Operations	0	
490788	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Operations Counter AF	152	
490789	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Heaters (All) Functioning?	y	
490790	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Grounds in Place?	y	
490791	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Operations B Ø	0	
490792	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
490793	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	General Comments		
490794	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	General Comments		
490795	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
490796	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
490797	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
490798	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
490799	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
490800	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
490801	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
490802	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
490803	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
490804	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
490805	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
490806	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	General Comments		
490807	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Foundation Condition	Good	
490808	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
490809	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
490810	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Operations C Ø	0	
490811	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Operations Ground	0	
490812	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Follow-up Action Required?	n	
490813	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Follow-up Action Required?	n	
490814	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Operations Ground	0	
490815	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Operations C Ø	0	
490816	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Operations B Ø	0	
490817	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Operations A Ø	0	
490818	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
490819	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
490820	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
490821	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Equipment Properly Labeled?	y	
490822	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Cabinet Paint Condition	Good	
490823	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Readings	Follow-up Action Required?	n	
490824	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Readings	General Comments		
490825	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Readings	Maintenance Operations	0	
490826	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Readings	Operations Counter AF	1637	
490827	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Readings	Operations Counter AL	1637	
490828	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Readings	Operations This Read Vac	0	
490829	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Readings	Switching Operations	0	
490830	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Readings	Unknown Operations	0	
490831	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Amps C Ø	130.0	
490832	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
490833	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
490834	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
490835	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
490836	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
490837	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
490838	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
490839	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
490840	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Operations A Ø	0	
490841	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Operations B Ø	0	
490842	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Operations C Ø	0	
490843	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
490844	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
490845	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Operations Ground	0	
490846	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
490847	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
490848	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
490849	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
490850	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
490851	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
490852	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
490853	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
490854	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
490855	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Follow-up Action Required?	n	
490856	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Follow-up Action Required?	n	
490857	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Foundation Condition	Good	
490858	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	General Comments		
490859	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	General Comments		
490860	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Grounds in Place?	y	
490861	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Heaters (All) Functioning?	y	
490862	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Maintenance Operations	0	
490863	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Moisture and Leak Free?	y	
490864	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Operations Counter AF	346	
490865	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Operations Counter AL	346	
490866	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Operations This Read Vac	0	
490867	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
490868	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
490869	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
490870	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	29.6	VDC
490871	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Switching Operations	0	
490872	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	26.5	VDC
490873	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
490874	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
490875	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
490876	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
490877	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
490878	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
490879	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
490880	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	6	
490881	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	215	
490882	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	0	
490883	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
490884	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
490885	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
490886	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
490887	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
490888	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
490889	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
490890	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
490891	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
490892	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
490893	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
490894	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Amps C Ø	0.0	
490895	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Amps B Ø	0.0	
490896	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
490897	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
490898	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
490899	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
490900	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
490901	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
490902	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
490903	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
490904	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
490905	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
490906	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
490907	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	General Comments	Station de-energized for customer outage	
490908	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	General Comments		
490909	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
490910	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
490911	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
490912	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
490913	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Foundation Condition	Good	
490914	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
490915	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
490916	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Cabinet Paint Condition	Good	
490917	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Equipment Properly Labeled?	y	
490918	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
490919	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	General Comments		
490920	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
490921	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
490922	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
490923	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ok	
490924	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
490925	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
490926	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
490927	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
490928	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
490929	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
490930	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
490931	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
490932	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
490933	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
490934	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
490935	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
490936	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
490937	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	200.0	
490938	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	200.0	
490939	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	200.0	
490940	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
490941	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
490942	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
490943	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
490944	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
490945	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
490946	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
490947	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
490948	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
490949	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
490950	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
490951	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
490952	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
490953	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
490954	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
490955	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
490956	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
490957	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
490958	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
490959	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
490960	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
490961	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
490962	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
490963	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	General Comments		
490964	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
490965	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
490966	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
490967	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	Oil Temp Max	35	°C
490968	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
490969	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Counter Readings	Follow-up Action Required?	n	
490970	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Tank Paint Condition	Good	
490971	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
490972	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Counter Readings	General Comments		
490973	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	General Comments		
490974	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC As Found Counter	824	
490975	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Unknown Operations	0	
490976	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC As Left Counter	824	
490977	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
490978	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
490979	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
490980	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
490981	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	219	
490982	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	4	
490983	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
490984	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
490985	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	9 Month Operations	43	
490986	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
490987	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
490988	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
490989	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps A Ø	315.0	
490990	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps B Ø	305.0	
490991	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps C Ø	302.0	
490992	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
490993	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
490994	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
490995	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
490996	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
490997	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
490998	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
490999	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Amps A Ø	0.0	
491000	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Accumulated Fault Duty C Ph V	28.56	%
491001	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Accumulated Fault Duty B Ph V	55.21	%
491002	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Accumulated Fault Duty A Ph V	53.31	%
491003	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	9 Month Operations	2	
491004	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
491005	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
491006	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
491007	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
491008	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
491009	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
491010	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	431	
491011	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	431	
491012	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
491013	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
491014	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
491015	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
491016	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
491017	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
491018	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
491019	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
491020	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
491021	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
491022	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
491023	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
491024	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
491025	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC Operations Since Last Insp	551	
491026	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
491027	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
491028	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
491029	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
491030	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
491031	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
491032	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
491033	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
491034	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
491035	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
491036	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Vegetation	None	
491037	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
491038	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
491039	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
491040	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
491041	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
491042	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
491043	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	General Comments		
491044	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
491045	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
491046	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
491047	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
491048	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
491049	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
491050	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
491051	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
491052	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
491053	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Ambient Temp	54	°F
491054	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
491055	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	9 Month Operations	27	
491056	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
491057	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
491058	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
491059	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
491060	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC Operations Since Last Insp	104	
491061	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC Min Tap Position	8L	
491062	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC Max Tap Position	11L	
491063	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC Current Tap Position	11L	
491064	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
491065	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC As Left Counter	200901	
491066	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BCH000605	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
491067	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BCH000605	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
491068	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BCH000605	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
491069	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BCH000605	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
491070	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BCH000605	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
491071	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BCH000605	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
491072	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BCH000605	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
491073	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC As Found Counter	200899	
491074	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	General Comments		
491075	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC As Found Counter	14811	
491076	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC As Left Counter	14811	
491077	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
491078	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC Current Tap Position	5L	
491079	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
491080	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC Max Tap Position	3R	
491081	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC Min Tap Position	8L	
491082	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
491083	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
491084	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	6	
491085	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	171	
491086	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	175	
491087	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
491088	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
491089	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
491090	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	4	
491091	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
491092	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
491093	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
491094	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
491095	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
491096	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
491097	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
491098	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
491099	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	205	
491100	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	201	
491101	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
491102	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
491103	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	Counter needs to be changed out	
491104	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
491105	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	4444	
491106	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	4444	
491107	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
491108	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
491109	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
491110	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Accumulated Fault Duty C Ph V	10	%
491111	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Amps A Ø	120.0	
491112	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Operations Counter AF	235	
491113	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Amps B Ø	120.0	
491114	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Amps C Ø	120.0	
491115	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Bushing Condition	Good	
491116	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Bushings Connection/Risers	Good	
491117	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
491118	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
491119	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
491120	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Counter Readings	Follow-up Action Required?	n	
491121	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	11.69	%
491122	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	11.69	%
491123	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Maintenance Operations	0	
491124	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	General Comments	ok	
491125	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Follow-up Action Required?	n	
491126	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Operations Ground	0	
491127	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Operations C Ø	0	
491128	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Operations B Ø	0	
491129	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
491130	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
491131	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
491132	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Operations A Ø	0	
491133	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
491134	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
491135	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
491136	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	ST000353	Structure	662-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
491137	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	ST000353	Structure	662-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
491138	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	ST000353	Structure	662-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
491139	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
491140	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
491141	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
491142	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
491143	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
491144	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
491145	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
491146	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
491147	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
491148	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
491149	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Amps A Ø	0.0	
491150	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Amps B Ø	0.0	
491151	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Amps C Ø	0.0	
491152	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
491153	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
491154	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
491155	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Operations A Ø	0	
491156	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Operations B Ø	0	
491157	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Operations C Ø	0	
491158	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
491159	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
491160	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
491161	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Operations Ground	0	
491162	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Follow-up Action Required?	n	
491163	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	General Comments		
491164	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Maintenance Operations	13	
491165	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	320.0	
491166	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Operations Counter AF	86	
491167	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Operations Counter AL	86	
491168	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Operations This Read Vac	13	
491169	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Switching Operations	0	
491170	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Unknown Operations	0	
491171	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
491172	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
491173	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	320.0	
491174	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
491175	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
491176	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
491177	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Switching Operations	0	
491178	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Operations This Read Vac	0	
491179	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Operations Counter AL	235	
491180	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
491181	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
491182	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
491183	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
491184	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	11.69	%
491185	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Counter Readings	General Comments		
491186	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
491187	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
491188	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
491189	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	9 Month Operations	9	
491190	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Accumulated Fault Duty A Ph V	6.37	%
491191	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Accumulated Fault Duty B Ph V	11.82	%
491192	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Amps A Ø	100.0	
491193	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
491194	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
491195	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	General Comments	ok	
491196	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
491197	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
491198	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
491199	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
491200	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
491201	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
491202	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
491203	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
491204	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
491205	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
491206	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
491207	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
491208	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	B0281	WithLTC	662-1	LTC Transformer Readings	Follow-up Action Required?	n	
491209	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Amps B Ø	152.0	
491210	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Amps C Ø	96.0	
491211	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
491212	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
491213	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
491214	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Operations A Ø	0	
491215	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Operations B Ø	0	
491216	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Operations C Ø	0	
491217	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Operations Ground	0	
491218	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Follow-up Action Required?	n	
491219	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	General Comments		
491220	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Maintenance Operations	1	
491221	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Operations Counter AF	169	
491222	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Operations Counter AL	170	
491223	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Operations This Read Vac	1	
491224	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Switching Operations	0	
491225	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Unknown Operations	0	
491226	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
491227	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	9 Month Operations	1	
491228	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
491229	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
491230	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
491231	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
491232	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
491233	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
491234	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
491235	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
491236	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Bushings Connection/Risers	Good	
491237	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Bushing Condition	Good	
491238	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Amps C Ø	84.0	
491239	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
491240	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
491241	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
491242	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
491243	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Amps B Ø	69.0	
491244	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Amps A Ø	75.0	
491245	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
491246	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
491247	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Operations Counter AL	384	
491248	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	B0281	WithLTC	662-1	LTC Transformer Readings	Oil Temp Max	45	°C
491249	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
491250	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
491251	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	B0281	WithLTC	662-1	LTC Transformer Readings	LTC Totalizer Reading	3955.20	kw

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
491252	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
491253	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Readings	General Comments		
491254	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	General Comments		
491255	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0025	BreakerVacuum	417-2134	VCB Readings	Operations Counter AF	384	
491256	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0025	BreakerVacuum	417-2134	VCB Readings	Maintenance Operations	0	
491257	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
491258	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
491259	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	9 Month Operations	2	
491260	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0025	BreakerVacuum	417-2134	VCB Readings	General Comments		
491261	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0025	BreakerVacuum	417-2134	VCB Readings	Follow-up Action Required?	n	
491262	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Operations Ground	0	
491263	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Operations C Ø	0	
491264	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Operations B Ø	0	
491265	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Operations A Ø	0	
491266	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
491267	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
491268	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
491269	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Accumulated Fault Duty A Ph V	.42	%
491270	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Accumulated Fault Duty B Ph V	.42	%
491271	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Accumulated Fault Duty C Ph V	.42	%
491272	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Amps A Ø	106.0	
491273	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
491274	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
491275	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
491276	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
491277	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
491278	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Foundation Condition	Good	
491279	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0025	BreakerVacuum	417-2134	VCB Readings	Amps C Ø	75.0	
491280	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0025	BreakerVacuum	417-2134	VCB Readings	Amps B Ø	120.0	
491281	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
491282	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Foundation Condition	Good	
491283	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
491284	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
491285	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Switching Operations	0	
491286	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Unknown Operations	0	
491287	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Unknown Operations	0	
491288	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Switching Operations	0	
491289	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Operations This Read AM	0	
491290	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Operations Counter AL	669	
491291	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Operations Counter AF	669	
491292	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Maintenance Operations	0	
491293	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	General Comments		
491294	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
491295	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
491296	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
491297	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
491298	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	LTCC000805	LTCControl	401-1	LTC Control Insp	VRR Time Delay	30	Seconds
491299	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	LTCC000805	LTCControl	401-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
491300	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	LTCC000805	LTCControl	401-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
491301	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	LTCC000805	LTCControl	401-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
491302	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
491303	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Vegetation	None	
491304	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
491305	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	LTCC000805	LTCControl	401-1	LTC Control Insp	LTC Operation Checked?	y	
491306	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	LTCC000805	LTCControl	401-1	LTC Control Insp	General Comments		
491307	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	LTCC000805	LTCControl	401-1	LTC Control Insp	Follow-up Action Required?	n	
491308	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	LTCC000805	LTCControl	401-1	LTC Control Insp	All Connections OK?	y	
491309	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
491310	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
491311	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
491312	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
491313	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	General Comments		
491314	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
491315	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Amps C Ø	300.0	
491316	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Amps B Ø	320.0	
491317	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Amps A Ø	340.0	
491318	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
491319	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
491320	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
491321	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
491322	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
491323	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
491324	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
491325	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
491326	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
491327	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
491328	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
491329	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	9 Month Operations	11	
491330	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
491331	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC Current Tap Position	6L	
491332	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC Max Tap Position	1R	
491333	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC Min Tap Position	7L	
491334	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
491335	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC Operations Since Last Insp	438	
491336	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
491337	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
491338	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
491339	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
491340	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
491341	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Amps A Ø	0.0	
491342	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Amps B Ø	0.0	
491343	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Amps C Ø	0.0	
491344	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
491345	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
491346	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
491347	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Operations A Ø	0	
491348	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Operations B Ø	0	
491349	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Operations C Ø	0	
491350	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Operations Ground	0	
491351	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Follow-up Action Required?	n	
491352	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	General Comments		
491353	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Maintenance Operations	0	
491354	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Operations Counter AF	21	
491355	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
491356	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
491357	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
491358	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
491359	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
491360	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	General Comments		
491361	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Maintenance Operations	0	
491362	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AF	332	
491363	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AL	332	
491364	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
491365	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Operations Counter AL	21	
491366	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Operations This Read Vac	0	
491367	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	General Comments		
491368	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Switching Operations	0	
491369	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Unknown Operations	0	
491370	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
491371	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
491372	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
491373	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
491374	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
491375	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
491376	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
491377	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
491378	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2121.12	kw
491379	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
491380	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
491381	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
491382	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
491383	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	General Comments		
491384	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	General Comments		
491385	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
491386	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
491387	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
491388	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
491389	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
491390	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
491391	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
491392	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
491393	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
491394	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
491395	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
491396	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
491397	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
491398	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
491399	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
491400	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
491401	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
491402	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
491403	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
491404	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
491405	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
491406	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
491407	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Ambient Temp	54	°F
491408	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
491409	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
491410	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Clear of Trash?	y	
491411	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
491412	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
491413	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
491414	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
491415	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
491416	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
491417	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
491418	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
491419	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
491420	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
491421	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
491422	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
491423	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
491424	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
491425	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
491426	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
491427	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
491428	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
491429	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	25	°C
491430	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
491431	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
491432	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
491433	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
491434	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
491435	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
491436	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
491437	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
491438	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
491439	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
491440	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
491441	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
491442	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
491443	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	General Comments	no 911 sign	
491444	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
491445	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	ST000353	Structure	662-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
491446	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	25	°C
491447	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8838	
491448	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
491449	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Top Oil Temperature Present	35	°C
491450	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Top Oil Temperature Max	35	°C
491451	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
491452	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
491453	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
491454	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
491455	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ok	
491456	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
491457	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	707	
491458	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	707	
491459	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
491460	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
491461	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
491462	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
491463	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ok	
491464	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
491465	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
491466	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	9 Month Operations	0	
491467	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Unknown Operations	0	
491468	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Tank Paint Condition	Good	
491469	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Switching Operations	0	
491470	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	3075	
491471	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	3075	
491472	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
491473	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
491474	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Operations This Read Vac	0	
491475	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Operations Counter AL	160	
491476	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Operations Counter AF	160	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
491477	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Moisture and Leak Free?	y	
491478	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Unknown Operations	0	
491479	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Switching Operations	1	
491480	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Operations This Read Vac	1	
491481	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Operations Counter AL	273	
491482	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Operations Counter AF	273	
491483	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Maintenance Operations	0	
491484	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	General Comments		
491485	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Maintenance Operations	0	
491486	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Heaters (All) Functioning?	y	
491487	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Grounds in Place?	y	
491488	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	General Comments		
491489	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	General Comments		
491490	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Foundation Condition	Good	
491491	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Follow-up Action Required?	n	
491492	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Follow-up Action Required?	n	
491493	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Operations Ground	0	
491494	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Operations C Ø	0	
491495	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Unknown Operations	0	
491496	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Switching Operations	5	
491497	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Operations This Read Vac	5	
491498	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Operations B Ø	0	
491499	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Operations A Ø	0	
491500	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
491501	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
491502	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
491503	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Equipment Properly Labeled?	y	
491504	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
491505	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
491506	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
491507	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	General Comments		
491508	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
491509	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Vegetation	None	
491510	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
491511	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Readings	Totalizer Meter Reading	.8240	
491512	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
491513	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
491514	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
491515	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
491516	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
491517	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
491518	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
491519	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
491520	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
491521	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
491522	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
491523	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
491524	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
491525	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
491526	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Unknown Operations	0	
491527	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Switching Operations	0	
491528	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Operations This Read Vac	0	
491529	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Operations Counter AL	237	
491530	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Operations Counter AF	237	
491531	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Maintenance Operations	0	
491532	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	General Comments		
491533	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Follow-up Action Required?	n	
491534	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Operations Ground	0	
491535	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Operations C Ø	0	
491536	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Operations B Ø	0	
491537	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Operations A Ø	0	
491538	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
491539	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
491540	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
491541	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
491542	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
491543	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
491544	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
491545	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
491546	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
491547	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Amps C Ø	0.0	
491548	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Amps B Ø	0.0	
491549	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Amps A Ø	0.0	
491550	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
491551	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Operations This Read AM	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
491552	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Operations Counter AL	65700	
491553	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Operations Counter AF	65700	
491554	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
491555	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	General Comments		
491556	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	General Comments		
491557	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
491558	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
491559	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	261.42	kw
491560	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
491561	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
491562	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Oil Temp Max	50	°C
491563	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Oil Temp Present	35	°C
491564	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
491565	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
491566	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Maintenance Operations	0	
491567	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	General Comments		
491568	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Follow-up Action Required?	n	
491569	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Operations Ground	0	
491570	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Operations C Ø	0	
491571	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Operations B Ø	0	
491572	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
491573	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
491574	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
491575	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
491576	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
491577	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	300	
491578	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Totalizer Meter Reading	.8714	
491579	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Operations A Ø	0	
491580	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
491581	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
491582	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Unknown Operations	0	
491583	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Switching Operations	0	
491584	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Operations This Read Vac	0	
491585	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Operations Counter AL	0	
491586	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Operations Counter AF	0	
491587	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Maintenance Operations	0	
491588	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	General Comments		
491589	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Follow-up Action Required?	n	
491590	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Operations Ground	0	
491591	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Operations C Ø	0	
491592	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
491593	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
491594	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
491595	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Operations A Ø	0	
491596	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Operations B Ø	0	
491597	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Operations C Ø	0	
491598	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Operations Ground	0	
491599	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Follow-up Action Required?	n	
491600	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	General Comments		
491601	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Maintenance Operations	0	
491602	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Operations Counter AF	122	
491603	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Operations Counter AL	122	
491604	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Operations This Read Vac	0	
491605	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Switching Operations	0	
491606	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Unknown Operations	0	
491607	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	8L	
491608	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	1L	
491609	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	5L	
491610	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
491611	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	18569	
491612	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	18560	
491613	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments		
491614	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
491615	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
491616	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
491617	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
491618	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
491619	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
491620	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
491621	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
491622	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
491623	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
491624	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
491625	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
491626	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.9	amps

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
491627	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
491628	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	General Comments		
491629	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
491630	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
491631	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Unknown Operations	0	
491632	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Switching Operations	0	
491633	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Accumulated Fault Duty B Ph V	3.56	%
491634	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Accumulated Fault Duty A Ph V	3.56	%
491635	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	9 Month Operations	5	
491636	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Follow-up Action Required?	n	
491637	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
491638	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
491639	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	General Comments		
491640	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	General Comments		
491641	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
491642	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	LTC Totalizer Reading	1596.16	kw
491643	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
491644	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
491645	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Oil Temp Max	35	°C
491646	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Oil Temp Present	35	°C
491647	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
491648	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
491649	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
491650	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
491651	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
491652	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
491653	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
491654	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
491655	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Amps A Ø	96.0	
491656	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Amps B Ø	108.0	
491657	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Totalizer Meter Reading	.4988	
491658	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
491659	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
491660	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0052	BreakerVacuum	662-0039	VCB Readings	9 Month Operations	11	
491661	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0052	BreakerVacuum	662-0039	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
491662	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0052	BreakerVacuum	662-0039	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
491663	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0052	BreakerVacuum	662-0039	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
491664	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0052	BreakerVacuum	662-0039	VCB Readings	Amps A Ø	240.0	
491665	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0052	BreakerVacuum	662-0039	VCB Readings	Amps B Ø	240.0	
491666	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0052	BreakerVacuum	662-0039	VCB Readings	Amps C Ø	240.0	
491667	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Bushing Condition	Good	
491668	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Bushings Connection/Risers	Good	
491669	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
491670	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
491671	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
491672	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Cabinet Paint Condition	Good	
491673	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Equipment Properly Labeled?	y	
491674	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Operations B Ø	0	
491675	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Operations A Ø	0	
491676	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
491677	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
491678	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Amps C Ø	260.0	
491679	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Amps B Ø	225.0	
491680	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Amps A Ø	210.0	
491681	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Accumulated Fault Duty C Ph AM	33.22	%
491682	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Accumulated Fault Duty B Ph AM	27.91	%
491683	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Accumulated Fault Duty A Ph AM	34.55	%
491684	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	9 Months Operations	1	
491685	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
491686	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
491687	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Amps C Ø	250.0	
491688	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000552	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
491689	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000552	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
491690	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000552	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
491691	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000552	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
491692	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000552	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
491693	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000552	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
491694	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000552	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
491695	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000552	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
491696	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000552	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
491697	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
491698	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
491699	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
491700	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
491701	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
491702	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
491703	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
491704	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
491705	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
491706	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
491707	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	9 Month Operations	4	
491708	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
491709	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
491710	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
491711	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Amps B Ø	270.0	
491712	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
491713	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
491714	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Amps A Ø	270.0	
491715	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Accumulated Fault Duty C Ph V	3.56	%
491716	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
491717	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	General Comments		
491718	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	General Comments		
491719	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
491720	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	LTC Totalizer Reading	15318.00	kw
491721	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
491722	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
491723	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Oil Temp Max	50	°C
491724	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
491725	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
491726	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
491727	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
491728	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
491729	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
491730	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
491731	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
491732	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
491733	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
491734	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Totalizer Meter Reading	.8510	
491735	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Winding Temp Max	55	°C
491736	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
491737	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
491738	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Unknown Operations	0	
491739	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Switching Operations	0	
491740	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Operations This Read Vac	0	
491741	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Operations Counter AL	228	
491742	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Operations Counter AF	228	
491743	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Maintenance Operations	0	
491744	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	General Comments		
491745	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Follow-up Action Required?	n	
491746	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Operations Ground	0	
491747	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Operations C Ø	0	
491748	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Operations B Ø	0	
491749	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Operations A Ø	0	
491750	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
491751	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
491752	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
491753	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Amps C Ø	70.0	
491754	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Amps B Ø	70.0	
491755	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Amps A Ø	70.0	
491756	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Accumulated Fault Duty C Ph V	2.27	%
491757	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Amps C Ø	120.0	
491758	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Amps B Ø	120.0	
491759	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Amps A Ø	100.0	
491760	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Accumulated Fault Duty C Ph V	5.49	%
491761	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Accumulated Fault Duty B Ph V	5.49	%
491762	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Accumulated Fault Duty A Ph V	10.99	%
491763	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	9 Month Operations	2	
491764	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
491765	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
491766	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
491767	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
491768	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
491769	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
491770	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
491771	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
491772	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
491773	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
491774	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
491775	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
491776	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
491777	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
491778	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Evidence of Insects	None	
491779	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
491780	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
491781	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Floor Swept?	y	
491782	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
491783	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
491784	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	General Comments		
491785	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
491786	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
491787	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Panels Dusted?	y	
491788	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
491789	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
491790	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
491791	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
491792	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	9 Month Operations	1	
491793	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
491794	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
491795	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
491796	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
491797	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Follow-up Action Required?	n	
491798	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
491799	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	16.0	VDC
491800	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
491801	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
491802	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
491803	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
491804	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
491805	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
491806	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
491807	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
491808	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
491809	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
491810	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
491811	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
491812	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
491813	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
491814	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
491815	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
491816	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
491817	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
491818	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
491819	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
491820	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
491821	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	General Comments		
491822	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
491823	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
491824	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
491825	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
491826	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
491827	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
491828	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	9 Month Operations	3	
491829	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
491830	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
491831	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
491832	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	431	
491833	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	9 Month Operations	2	
491834	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Accumulated Fault Duty A Ph V	2.63	%
491835	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Accumulated Fault Duty B Ph V	2.19	%
491836	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Accumulated Fault Duty C Ph V	1.53	%
491837	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Amps A Ø	120.0	
491838	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Amps B Ø	140.0	
491839	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Amps C Ø	100.0	
491840	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Accumulated Fault Duty B Ph V	5.68	%
491841	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
491842	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	9 Month Operations	3	
491843	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Unknown Operations	0	
491844	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Switching Operations	0	
491845	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Operations This Read Vac	0	
491846	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Operations Counter AL	224	
491847	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Operations Counter AF	224	
491848	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Maintenance Operations	0	
491849	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	General Comments		
491850	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Follow-up Action Required?	n	
491851	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
491852	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Operations C Ø	0	
491853	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Operations B Ø	0	
491854	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Operations A Ø	0	
491855	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
491856	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
491857	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
491858	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Amps C Ø	420.0	
491859	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Amps B Ø	420.0	
491860	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Amps A Ø	420.0	
491861	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Accumulated Fault Duty C Ph V	5.68	%
491862	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Accumulated Fault Duty B Ph V	5.68	%
491863	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
491864	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	General Comments		
491865	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
491866	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
491867	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
491868	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
491869	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
491870	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
491871	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
491872	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
491873	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
491874	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
491875	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
491876	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
491877	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
491878	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Accumulated Fault Duty A Ph V	5.68	%
491879	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
491880	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
491881	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	16.0	VDC
491882	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BCH001057	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
491883	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BCH001057	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
491884	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
491885	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
491886	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
491887	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
491888	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	General Comments		
491889	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Operations Counter AF	187	
491890	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Maintenance Operations	0	
491891	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	General Comments		
491892	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Follow-up Action Required?	n	
491893	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Operations Ground	0	
491894	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Operations C Ø	0	
491895	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Operations B Ø	0	
491896	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Operations A Ø	0	
491897	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
491898	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
491899	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
491900	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Amps C Ø	100.0	
491901	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Amps B Ø	100.0	
491902	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Amps A Ø	100.0	
491903	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Accumulated Fault Duty C Ph AM	8.43	%
491904	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Accumulated Fault Duty B Ph AM	22.89	%
491905	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Accumulated Fault Duty A Ph AM	19.27	%
491906	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	9 Months Operations	12	
491907	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
491908	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
491909	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.7	VDC
491910	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.4	VDC
491911	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
491912	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
491913	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
491914	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
491915	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
491916	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
491917	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
491918	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	63	°F
491919	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
491920	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Accumulated Fault Duty A Ph V	.99	%
491921	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	9 Month Operations	3	
491922	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Unknown Operations	0	
491923	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
491924	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
491925	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
491926	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
491927	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	General Comments		
491928	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
491929	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Amps C Ø	230.0	
491930	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Amps B Ø	200.0	
491931	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Amps A Ø	240.0	
491932	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
491933	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Accumulated Fault Duty C Ph V	3.95	%
491934	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Accumulated Fault Duty B Ph V	4.94	%
491935	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001093	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
491936	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001093	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
491937	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001093	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
491938	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001093	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
491939	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001093	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
491940	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Operations A Ø	0	
491941	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Operations B Ø	0	
491942	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Operations C Ø	0	
491943	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Operations Ground	0	
491944	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Follow-up Action Required?	n	
491945	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001093	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
491946	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001093	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
491947	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001093	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
491948	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001093	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
491949	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001093	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
491950	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001093	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
491951	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	General Comments		
491952	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Maintenance Operations	0	
491953	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Operations Counter AF	506	
491954	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Operations Counter AL	506	
491955	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Operations This Read AM	0	
491956	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Switching Operations	0	
491957	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Unknown Operations	0	
491958	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
491959	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
491960	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Operations Counter AL	187	
491961	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BCH001057	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	float was changed to 55	
491962	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BCH001057	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
491963	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BCH001057	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
491964	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BCH001057	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
491965	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Unknown Operations	0	
491966	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Switching Operations	2	
491967	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Operations This Read Vac	3	
491968	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Operations Counter AL	232	
491969	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Operations Counter AF	232	
491970	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Maintenance Operations	0	
491971	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	General Comments		
491972	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Follow-up Action Required?	n	
491973	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Operations Ground	0	
491974	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Operations C Ø	0	
491975	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Operations B Ø	0	
491976	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
491977	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
491978	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Oil Temp Present	25	°C
491979	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Oil Temp Max	25	°C
491980	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
491981	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Operations A Ø	1	
491982	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
491983	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
491984	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Adjusted Amps A Phase V	24.56	
491985	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Amps C Ø	277.0	
491986	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Amps B Ø	230.0	
491987	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Amps A Ø	278.0	
491988	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Accumulated Fault Duty C Ph V	7.32	%
491989	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Accumulated Fault Duty B Ph V	7.32	%
491990	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Accumulated Fault Duty A Ph V	7.32	%
491991	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	9 Month Operations	5	
491992	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	VRR Time Delay	30	Seconds
491993	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
491994	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
491995	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
491996	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	LTC Operation Checked?	y	
491997	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	General Comments		
491998	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	Follow-up Action Required?	n	
491999	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	All Connections OK?	y	
492000	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
492001	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
492002	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Totalizer Meter Reading	.4590	
492003	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
492004	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
492005	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
492006	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Switching Operations	4	
492007	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Operations This Read Vac	4	
492008	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Operations Counter AL	69	
492009	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Operations Counter AF	69	
492010	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Maintenance Operations	0	
492011	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
492012	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
492013	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	3.1	VDC
492014	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	3.1	VDC
492015	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
492016	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
492017	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
492018	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
492019	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
492020	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
492021	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
492022	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
492023	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
492024	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
492025	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Totalizer Meter Reading	.5900	
492026	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
492027	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	General Comments		
492028	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Follow-up Action Required?	n	
492029	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Operations Ground	0	
492030	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Operations C Ø	0	
492031	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Operations B Ø	0	
492032	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Operations A Ø	0	
492033	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
492034	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
492035	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
492036	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Amps C Ø	240.0	
492037	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Amps B Ø	240.0	
492038	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Amps A Ø	240.0	
492039	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Accumulated Fault Duty C Ph V	12.59	%
492040	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
492041	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
492042	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
492043	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
492044	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
492045	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Accumulated Fault Duty B Ph V	12.59	%
492046	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Accumulated Fault Duty A Ph V	3.6	%
492047	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	9 Month Operations	14	
492048	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Follow-up Action Required?	n	
492049	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	General Comments		
492050	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Maintenance Operations	0	
492051	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Operations Counter AF	796	
492052	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Operations Counter AL	796	
492053	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Operations This Read AM	0	
492054	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Switching Operations	0	
492055	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Unknown Operations	0	
492056	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0052	BreakerVacuum	662-0039	VCB Readings	Operations Counter AL	308	
492057	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
492058	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
492059	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0052	BreakerVacuum	662-0039	VCB Readings	Operations This Read Vac	4	
492060	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
492061	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0052	BreakerVacuum	662-0039	VCB Readings	Switching Operations	4	
492062	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Tank Paint Condition	Good	
492063	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0052	BreakerVacuum	662-0039	VCB Readings	Unknown Operations	0	
492064	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Operations A Ø	0	
492065	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Operations B Ø	0	
492066	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Operations C Ø	0	
492067	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Unknown Operations	0	
492068	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Switching Operations	1	
492069	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Heaters (All) Functioning?	y	
492070	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Grounds in Place?	y	
492071	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Operations This Read Vac	1	
492072	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0047	BreakerVacuum	662-0085	VCB Readings	General Comments		
492073	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	General Comments		
492074	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Foundation Condition	Good	
492075	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0047	BreakerVacuum	662-0085	VCB Readings	Follow-up Action Required?	n	
492076	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
492077	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Operations Ground	0	
492078	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Operations C Ø	0	
492079	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Operations B Ø	0	
492080	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Operations A Ø	0	
492081	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
492082	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
492083	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
492084	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Equipment Properly Labeled?	y	
492085	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Cabinet Paint Condition	Good	
492086	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
492087	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
492088	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Operations Counter AL	260	
492089	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
492090	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Unknown Operations	0	
492091	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Tank Paint Condition	Good	
492092	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Switching Operations	4	
492093	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
492094	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Operations This Read Vac	4	
492095	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Operations Counter AL	26	
492096	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Operations Counter AF	22	
492097	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Moisture and Leak Free?	y	
492098	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Maintenance Operations	0	
492099	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
492100	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
492101	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Operations A Ø	0	
492102	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Operations B Ø	0	
492103	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Operations C Ø	0	
492104	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Operations Ground	0	
492105	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Follow-up Action Required?	n	
492106	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	9 Months Operations	0	
492107	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Accumulated Fault Duty A Ph AM	10.63	%
492108	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Accumulated Fault Duty B Ph AM	9.3	%
492109	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
492110	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Amps C Ø	96.0	
492111	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
492112	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Follow-up Action Required?	n	
492113	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Foundation Condition	Good	
492114	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	General Comments		
492115	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	General Comments		
492116	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Grounds in Place?	y	
492117	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Heaters (All) Functioning?	y	
492118	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Maintenance Operations	0	
492119	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Moisture and Leak Free?	y	
492120	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Operations Counter AF	304	
492121	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Amps A Ø	450.0	
492122	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Amps B Ø	560.0	
492123	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Amps C Ø	420.0	
492124	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
492125	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
492126	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
492127	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Operations A Ø	0	
492128	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Operations B Ø	0	
492129	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Operations C Ø	0	
492130	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Operations Ground	0	
492131	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Switching Operations	0	
492132	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Unknown Operations	0	
492133	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Operations B Ø	0	
492134	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Operations A Ø	0	
492135	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
492136	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
492137	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
492138	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
492139	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
492140	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
492141	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
492142	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
492143	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
492144	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
492145	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Amps B Ø	320.0	
492146	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
492147	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
492148	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
492149	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
492150	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
492151	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
492152	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Switching Operations	8	
492153	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Operations This Read AM	8	
492154	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
492155	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
492156	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
492157	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
492158	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
492159	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	General Comments		
492160	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
492161	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
492162	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Amps C Ø	140.0	
492163	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
492164	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
492165	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
492166	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
492167	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
492168	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
492169	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001093	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
492170	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001093	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
492171	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001093	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
492172	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Operations Ground	0	
492173	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Follow-up Action Required?	n	
492174	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	General Comments		
492175	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Maintenance Operations	0	
492176	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Operations Counter AF	195	
492177	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Operations Counter AF	260	
492178	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Maintenance Operations	0	
492179	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	General Comments		
492180	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Follow-up Action Required?	n	
492181	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
492182	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Bushings Connection/Risers	Good	
492183	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Bushing Condition	Good	
492184	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Amps C Ø	40.0	
492185	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Amps B Ø	40.0	
492186	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Amps A Ø	40.0	
492187	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Operations Ground	0	
492188	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Operations C Ø	0	
492189	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
492190	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
492191	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
492192	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	9 Month Operations	4	
492193	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	9 Months Operations	0	
492194	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
492195	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
492196	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
492197	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Amps A Ø	130.0	
492198	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BCH000373	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
492199	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BCH000373	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
492200	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BCH000373	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
492201	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BCH000373	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.7	amps
492202	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
492203	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BCH000373	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
492204	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BCH000373	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
492205	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BCH000373	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
492206	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Operations Counter AL	195	
492207	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Operations This Read Vac	0	
492208	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	General Comments		
492209	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
492210	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
492211	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
492212	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
492213	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
492214	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
492215	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
492216	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
492217	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
492218	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
492219	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
492220	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
492221	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
492222	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
492223	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
492224	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
492225	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
492226	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4446	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
492227	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
492228	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
492229	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
492230	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
492231	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
492232	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
492233	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
492234	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
492235	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
492236	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
492237	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
492238	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
492239	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	10.52	%
492240	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	8.27	%
492241	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	15.03	%
492242	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	96.0	
492243	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
492244	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	96.0	
492245	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
492246	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
492247	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
492248	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
492249	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
492250	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
492251	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
492252	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
492253	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
492254	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
492255	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
492256	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
492257	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
492258	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	96.0	
492259	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	78.0	
492260	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	14.28	%
492261	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	21.79	%
492262	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	23.3	%
492263	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
492264	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
492265	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Foundation Condition	Good	
492266	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
492267	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
492268	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	General Comments		
492269	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
492270	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
492271	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
492272	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
492273	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
492274	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
492275	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Operations This Read Vac	1	
492276	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
492277	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Switching Operations	0	
492278	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Tank Paint Condition	Good	
492279	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Unknown Operations	0	
492280	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
492281	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
492282	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
492283	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
492284	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
492285	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
492286	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
492287	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
492288	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
492289	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
492290	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
492291	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
492292	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
492293	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Foundation Condition	Good	
492294	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
492295	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
492296	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	General Comments		
492297	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Adjusted Amps A Phase V	9.12	
492298	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
492299	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
492300	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Operations A Ø	2	
492301	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
492302	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Operations B Ø	0	
492303	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Operations C Ø	0	
492304	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Operations Ground	0	
492305	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Follow-up Action Required?	n	
492306	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	General Comments		
492307	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Maintenance Operations	0	
492308	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Operations Counter AF	193	
492309	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Operations Counter AL	193	
492310	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Operations This Read Vac	3	
492311	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Switching Operations	1	
492312	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Unknown Operations	0	
492313	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
492314	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Operations A Ø	0	
492315	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Operations B Ø	0	
492316	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Operations C Ø	0	
492317	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Operations Ground	0	
492318	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
492319	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
492320	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
492321	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
492322	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
492323	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	168	
492324	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	168	
492325	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Follow-up Action Required?	n	
492326	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
492327	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
492328	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
492329	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	9 Month Operations	3	
492330	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
492331	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
492332	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
492333	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Amps A Ø	575.0	
492334	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Amps B Ø	574.0	
492335	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Amps C Ø	565.0	
492336	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
492337	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
492338	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	191	
492339	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	10.00	
492340	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1067.04	kw
492341	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
492342	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
492343	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
492344	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	General Comments		
492345	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	General Comments		
492346	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
492347	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
492348	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
492349	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
492350	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
492351	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
492352	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
492353	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
492354	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
492355	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	191	
492356	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	8	
492357	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
492358	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
492359	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
492360	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
492361	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
492362	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
492363	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
492364	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
492365	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
492366	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
492367	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
492368	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
492369	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
492370	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
492371	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
492372	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	52	°F
492373	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	9 Month Operations	11	
492374	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Accumulated Fault Duty A Ph V	1.36	%
492375	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Accumulated Fault Duty B Ph V	.34	%
492376	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Accumulated Fault Duty C Ph V	1.36	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
492377	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Amps A Ø	25.0	
492378	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Amps B Ø	50.0	
492379	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Amps C Ø	70.0	
492380	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
492381	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
492382	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
492383	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Clear of Trash?	y	
492384	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
492385	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
492386	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
492387	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
492388	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
492389	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
492390	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	General Comments		
492391	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
492392	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
492393	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Vegetation	None	
492394	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
492395	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Amps A Ø	31.0	
492396	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Amps B Ø	29.0	
492397	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Amps C Ø	29.0	
492398	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
492399	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
492400	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
492401	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
492402	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
492403	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
492404	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
492405	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
492406	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
492407	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
492408	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	General Comments		
492409	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
492410	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
492411	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Operations Counter	57	
492412	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
492413	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Tank Leaks	None	
492414	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
492415	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	9 Month Operations	3	
492416	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Accumulated Fault Duty A Ph V	1.56	%
492417	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Accumulated Fault Duty B Ph V	1.56	%
492418	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Accumulated Fault Duty C Ph V	2.34	%
492419	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Amps A Ø	40.0	
492420	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Amps B Ø	40.0	
492421	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Operations B Ø	0	
492422	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Operations C Ø	0	
492423	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Operations Ground	0	
492424	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Follow-up Action Required?	n	
492425	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	General Comments		
492426	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Maintenance Operations	0	
492427	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Operations Counter AF	377	
492428	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Operations Counter AL	377	
492429	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Operations This Read AM	0	
492430	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Switching Operations	0	
492431	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Unknown Operations	0	
492432	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
492433	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
492434	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
492435	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
492436	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
492437	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
492438	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
492439	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
492440	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
492441	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
492442	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
492443	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
492444	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
492445	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
492446	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
492447	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	9 Month Operations	1	
492448	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
492449	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
492450	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
492451	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Amps A Ø	480.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
492452	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Amps B Ø	519.0	
492453	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Amps C Ø	450.0	
492454	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Bushing Condition	Good	
492455	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
492456	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
492457	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
492458	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
492459	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
492460	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
492461	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
492462	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
492463	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	General Comments		
492464	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
492465	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
492466	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Follow-up Action Required?	n	
492467	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
492468	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
492469	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
492470	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Foundation Condition	Good	
492471	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	General Comments		
492472	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	General Comments		
492473	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
492474	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
492475	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
492476	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
492477	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
492478	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
492479	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
492480	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
492481	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
492482	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	8	
492483	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	933	
492484	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	933	
492485	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
492486	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
492487	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
492488	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Grounds in Place?	y	
492489	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Heaters (All) Functioning?	y	
492490	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Maintenance Operations	1	
492491	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Moisture and Leak Free?	y	
492492	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Operations Counter AF	159	
492493	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Operations Counter AL	159	
492494	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
492495	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
492496	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
492497	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
492498	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
492499	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
492500	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
492501	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
492502	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
492503	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
492504	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Amps C Ø	40.0	
492505	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Bushing Condition	Good	
492506	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Bushings Connection/Risers	Good	
492507	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
492508	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
492509	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
492510	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Cabinet Paint Condition	Good	
492511	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Equipment Properly Labeled?	y	
492512	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
492513	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
492514	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
492515	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Operations A Ø	0	
492516	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Operations B Ø	0	
492517	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Operations C Ø	0	
492518	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Operations Ground	0	
492519	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Follow-up Action Required?	n	
492520	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Follow-up Action Required?	n	
492521	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
492522	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
492523	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Totalizer Meter Reading	.6852	
492524	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
492525	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
492526	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
492527	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
492528	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
492529	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
492530	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
492531	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
492532	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
492533	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
492534	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
492535	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
492536	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
492537	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
492538	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
492539	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Oil Temp Present	35	°C
492540	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Oil Temp Max	53	°C
492541	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
492542	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
492543	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	LTC Totalizer Reading	3288.96	kw
492544	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
492545	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	General Comments	H3 bushing's oil guage broke	
492546	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
492547	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
492548	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Cabinet Paint Condition	Good	
492549	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Equipment Properly Labeled?	y	
492550	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
492551	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
492552	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
492553	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Operations A Ø	0	
492554	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Operations B Ø	0	
492555	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Operations C Ø	0	
492556	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Operations Ground	0	
492557	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Follow-up Action Required?	n	
492558	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Follow-up Action Required?	n	
492559	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Foundation Condition	Good	
492560	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
492561	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
492562	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
492563	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
492564	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	10.0	
492565	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	25.0	
492566	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	10.0	
492567	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
492568	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
492569	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
492570	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	13	
492571	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	16.0	
492572	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	18.0	
492573	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	14.0	
492574	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	General Comments		
492575	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	General Comments		
492576	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Grounds in Place?	y	
492577	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
492578	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
492579	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
492580	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
492581	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
492582	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Unknown Operations	0	
492583	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Switching Operations	1	
492584	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Operations This Read Vac	1	
492585	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Operations Counter AL	169	
492586	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Operations Counter AF	169	
492587	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
492588	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
492589	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
492590	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
492591	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
492592	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	163	
492593	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	163	
492594	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
492595	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
492596	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
492597	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
492598	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
492599	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
492600	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
492601	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
492602	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
492603	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
492604	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
492605	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
492606	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
492607	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
492608	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
492609	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
492610	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	9 Month Operations	4	
492611	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Accumulated Fault Duty A Ph V	6.18	%
492612	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Accumulated Fault Duty B Ph V	1.9	%
492613	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Accumulated Fault Duty C Ph V	.48	%
492614	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Amps A Ø	10.0	
492615	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Amps B Ø	15.0	
492616	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Amps C Ø	10.0	
492617	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Bushing Condition	Good	
492618	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Bushings Connection/Risers	Good	
492619	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
492620	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
492621	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
492622	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
492623	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
492624	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
492625	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
492626	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
492627	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
492628	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
492629	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Operations This Read Vac	0	
492630	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Switching Operations	0	
492631	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Tank Paint Condition	Good	
492632	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Unknown Operations	0	
492633	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
492634	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	9 Month Operations	1	
492635	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Unknown Operations	0	
492636	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Switching Operations	0	
492637	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Operations This Read Vac	0	
492638	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Operations Counter AL	384	
492639	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Operations Counter AF	384	
492640	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Maintenance Operations	0	
492641	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	General Comments		
492642	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Follow-up Action Required?	n	
492643	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Operations Ground	0	
492644	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Operations C Ø	0	
492645	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Operations B Ø	0	
492646	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Operations A Ø	0	
492647	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
492648	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
492649	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
492650	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	Unknown Operations	0	
492651	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	Switching Operations	1	
492652	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	Operations This Read Vac	1	
492653	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	Operations Counter AL	188	
492654	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	Operations Counter AF	188	
492655	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	Maintenance Operations	0	
492656	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	General Comments		
492657	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	Follow-up Action Required?	n	
492658	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Operations Ground	0	
492659	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Operations C Ø	0	
492660	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Operations B Ø	0	
492661	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Operations A Ø	0	
492662	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
492663	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
492664	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
492665	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	Amps C Ø	39.0	
492666	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	Amps B Ø	32.0	
492667	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	Amps A Ø	43.0	
492668	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
492669	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
492670	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Maintenance Operations	0	
492671	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	General Comments		
492672	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Follow-up Action Required?	n	
492673	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
492674	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Steel Structures Rust Free?	y	
492675	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
492676	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Site Service Trans Condition	OK	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
492677	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
492678	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
492679	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
492680	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Operating Linkage OK?	y	
492681	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Fault Operations Ground	0	
492682	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Fault Operations C Ø	0	
492683	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Fault Operations B Ø	0	
492684	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Fault Operations A Ø	0	
492685	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
492686	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
492687	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
492688	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Amps C Ø	0.0	
492689	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Amps B Ø	0.0	
492690	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Amps A Ø	0.0	
492691	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
492692	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
492693	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Heaters (All) Functioning?	y	
492694	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Maintenance Operations	0	
492695	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
492696	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Linkage Grounds in Place?	y	
492697	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
492698	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
492699	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	General Comments		
492700	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
492701	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
492702	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Foundation Condition	Good	
492703	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
492704	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
492705	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
492706	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
492707	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
492708	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
492709	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Moisture and Leak Free?	y	
492710	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Operations Counter AF	99985	
492711	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Operations Counter AL	99985	
492712	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	General Comments		
492713	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	General Comments		
492714	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Grounds in Place?	y	
492715	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
492716	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Maintenance Operations	0	
492717	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
492718	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Operations Counter AF	186	
492719	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Operations Counter AL	186	
492720	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Operations This Read Vac	0	
492721	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Switching Operations	0	
492722	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Tank Paint Condition	Good	
492723	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Unknown Operations	0	
492724	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	B0417	WithLTC	662-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
492725	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	B0417	WithLTC	662-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
492726	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	B0417	WithLTC	662-2	LTC Transformer Readings	Winding Temp Max	40	°C
492727	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	B0417	WithLTC	662-2	LTC Transformer Readings	Totalizer Meter Reading	.6050	
492728	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	B0417	WithLTC	662-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
492729	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
492730	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
492731	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	YD000350	Yard	662-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
492732	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	YD000350	Yard	662-Yard	Yard Patrol Inspection	Vegetation	None	
492733	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	YD000350	Yard	662-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
492734	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	YD000350	Yard	662-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
492735	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	YD000350	Yard	662-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
492736	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	YD000350	Yard	662-Yard	Yard Patrol Inspection	General Comments		
492737	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	YD000350	Yard	662-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
492738	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
492739	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
492740	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
492741	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
492742	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
492743	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	YD000350	Yard	662-Yard	Yard Patrol Inspection	Clear of Trash?	y	
492744	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	YD000350	Yard	662-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
492745	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	YD000350	Yard	662-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
492746	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	YD000350	Yard	662-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
492747	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0053	BreakerVacuum	662-0179	VCB Readings	Unknown Operations	0	
492748	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Tank Paint Condition	Good	
492749	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0053	BreakerVacuum	662-0179	VCB Readings	Switching Operations	4	
492750	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
492751	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0053	BreakerVacuum	662-0179	VCB Readings	Operations This Read Vac	4	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
492752	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Operations Counter AL	222	
492753	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
492754	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Operations A Ø	0	
492755	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Operations B Ø	0	
492756	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Operations C Ø	0	
492757	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Operations Ground	0	
492758	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
492759	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
492760	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
492761	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
492762	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
492763	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
492764	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
492765	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Follow-up Action Required?	n	
492766	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	General Comments		
492767	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Maintenance Operations	0	
492768	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Operations Counter AF	203	
492769	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Operations Counter AL	203	
492770	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Operations This Read Vac	0	
492771	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Switching Operations	0	
492772	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Unknown Operations	0	
492773	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
492774	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
492775	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
492776	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
492777	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
492778	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
492779	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
492780	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
492781	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
492782	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
492783	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
492784	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
492785	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
492786	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
492787	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
492788	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
492789	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
492790	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
492791	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
492792	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	1	
492793	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Follow-up Action Required?	n	
492794	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Foundation Condition	Good	
492795	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
492796	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Readings	General Comments		
492797	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	General Comments		
492798	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
492799	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
492800	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Readings	Follow-up Action Required?	n	
492801	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
492802	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
492803	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
492804	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
492805	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
492806	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
492807	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
492808	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
492809	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	121	
492810	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	121	
492811	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
492812	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ok	
492813	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
492814	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
492815	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
492816	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
492817	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
492818	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
492819	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
492820	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
492821	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
492822	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
492823	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
492824	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
492825	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
492826	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
492827	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
492828	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
492829	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
492830	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
492831	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
492832	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
492833	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
492834	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
492835	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
492836	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Operations Counter AF	218	
492837	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Moisture and Leak Free?	y	
492838	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Maintenance Operations	0	
492839	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Heaters (All) Functioning?	y	
492840	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Grounds in Place?	y	
492841	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	General Comments		
492842	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	General Comments		
492843	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Foundation Condition	Good	
492844	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Follow-up Action Required?	n	
492845	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Follow-up Action Required?	n	
492846	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Operations Ground	0	
492847	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Operations C Ø	0	
492848	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Operations B Ø	0	
492849	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
492850	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
492851	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
492852	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Operations A Ø	0	
492853	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
492854	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
492855	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
492856	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Equipment Properly Labeled?	y	
492857	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Cabinet Paint Condition	Good	
492858	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
492859	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
492860	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
492861	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Bushings Connection/Risers	Good	
492862	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Bushing Condition	Good	
492863	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Amps C Ø	0.0	
492864	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Amps B Ø	0.0	
492865	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Amps A Ø	0.0	
492866	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
492867	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
492868	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
492869	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	9 Month Operations	4	
492870	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
492871	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
492872	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
492873	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
492874	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Readings	Oil Temp Max	45	°C
492875	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
492876	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
492877	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Readings	LTC Totalizer Reading	8712.00	kw
492878	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Operations Counter AL	292	
492879	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Operations Counter AF	292	
492880	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Maintenance Operations	0	
492881	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	General Comments		
492882	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Follow-up Action Required?	n	
492883	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Operations Ground	0	
492884	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Operations C Ø	0	
492885	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Operations B Ø	0	
492886	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Operations A Ø	0	
492887	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
492888	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
492889	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
492890	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Amps C Ø	390.0	
492891	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Amps B Ø	290.0	
492892	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Amps A Ø	280.0	
492893	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Accumulated Fault Duty C Ph AM	10.92	%
492894	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Accumulated Fault Duty B Ph AM	13.35	%
492895	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Accumulated Fault Duty A Ph AM	13.35	%
492896	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	9 Months Operations	7	
492897	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC As Left Counter	13897	
492898	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
492899	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
492900	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Unknown Operations	0	
492901	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Switching Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
492902	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Operations This Read AM	0	
492903	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Operations Counter AL	131	
492904	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Operations Counter AF	131	
492905	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Maintenance Operations	0	
492906	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	General Comments		
492907	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Follow-up Action Required?	n	
492908	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Operations Ground	0	
492909	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Operations C Ø	0	
492910	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Operations B Ø	0	
492911	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Operations A Ø	0	
492912	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
492913	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
492914	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
492915	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Amps C Ø	220.0	
492916	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Amps B Ø	210.0	
492917	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Amps A Ø	200.0	
492918	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Accumulated Fault Duty C Ph AM	10.92	%
492919	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations Ground	0	
492920	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Follow-up Action Required?	n	
492921	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	General Comments		
492922	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Maintenance Operations	0	
492923	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Operations Counter AF	34888	
492924	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Operations Counter AL	34888	
492925	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Operations This Read AM	0	
492926	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Switching Operations	0	
492927	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Unknown Operations	0	
492928	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
492929	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
492930	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
492931	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
492932	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Operations A Ø	0	
492933	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Operations B Ø	0	
492934	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Operations C Ø	0	
492935	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Operations Ground	0	
492936	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Follow-up Action Required?	n	
492937	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Follow-up Action Required?	n	
492938	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Foundation Condition	Good	
492939	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	General Comments		
492940	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	General Comments		
492941	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Grounds in Place?	y	
492942	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Heaters (All) Functioning?	y	
492943	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Maintenance Operations	0	
492944	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Moisture and Leak Free?	y	
492945	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Operations Counter AF	196	
492946	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Operations Counter AL	196	
492947	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Operations This Read Vac	0	
492948	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
492949	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Switching Operations	0	
492950	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Tank Paint Condition	Good	
492951	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Unknown Operations	0	
492952	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	Follow-up Action Required?	n	
492953	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
492954	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	General Comments		
492955	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	General Comments		
492956	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC As Found Counter	13897	
492957	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Unknown Operations	0	
492958	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Switching Operations	0	
492959	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Operations This Read AM	0	
492960	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Tank Leaks	None	
492961	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
492962	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Regulator As Left Counter	87116	
492963	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
492964	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
492965	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
492966	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
492967	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
492968	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
492969	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Max Tap Position	6L	
492970	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
492971	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	General Comments		
492972	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
492973	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
492974	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
492975	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
492976	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Current Tap Position	7L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
492977	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
492978	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
492979	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
492980	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
492981	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
492982	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
492983	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
492984	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
492985	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
492986	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
492987	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Unknown Operations	0	
492988	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Switching Operations	0	
492989	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Operations This Read AM	0	
492990	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Operations Counter AL	99768	
492991	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Operations Counter AF	99768	
492992	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Maintenance Operations	0	
492993	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	General Comments		
492994	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Unknown Operations	0	
492995	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Switching Operations	0	
492996	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Operations This Read Vac	0	
492997	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Operations Counter AL	212	
492998	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Operations Counter AF	212	
492999	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Maintenance Operations	0	
493000	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
493001	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Accumulated Fault Duty B Ph AM	15.77	%
493002	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Accumulated Fault Duty A Ph AM	12.13	%
493003	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	9 Months Operations	7	
493004	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
493005	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
493006	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC Min Tap Position	Neutral	
493007	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
493008	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC Operations Since Last Insp	0	
493009	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
493010	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
493011	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
493012	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
493013	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Tank Leaks	None	
493014	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
493015	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Regulator As Left Counter	80631	
493016	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
493017	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
493018	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
493019	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
493020	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
493021	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
493022	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
493023	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
493024	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	General Comments		
493025	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
493026	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
493027	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
493028	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
493029	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
493030	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
493031	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
493032	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
493033	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
493034	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
493035	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Switching Operations	0	
493036	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Tank Paint Condition	Good	
493037	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Unknown Operations	0	
493038	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
493039	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
493040	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
493041	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
493042	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
493043	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	General Comments		
493044	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
493045	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
493046	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations B Ø	4	
493047	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations C Ø	3	
493048	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
493049	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
493050	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	Follow-up Action Required?	n	
493051	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
493052	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	General Comments	B,C IOC	
493053	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Maintenance Operations	0	
493054	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AF	356	
493055	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AL	356	
493056	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations This Read Vac	7	
493057	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Switching Operations	0	
493058	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000571	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
493059	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000571	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
493060	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000571	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
493061	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000571	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
493062	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000571	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	n	
493063	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000571	LTCControl	Retired Distribution	LTC Control Insp	General Comments	out of service	
493064	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
493065	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
493066	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
493067	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
493068	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
493069	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
493070	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
493071	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
493072	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
493073	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
493074	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	320.0	
493075	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	320.0	
493076	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	320.0	
493077	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
493078	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
493079	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
493080	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
493081	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Unknown Operations	0	
493082	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	General Comments		
493083	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
493084	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
493085	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
493086	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
493087	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Tank Leaks	None	
493088	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
493089	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
493090	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Regulator As Left Counter	53946	
493091	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	120.0	volts
493092	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
493093	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
493094	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
493095	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
493096	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
493097	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
493098	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
493099	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	General Comments		
493100	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
493101	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
493102	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
493103	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
493104	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
493105	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
493106	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
493107	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
493108	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
493109	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
493110	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
493111	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	32.00	
493112	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	24.00	
493113	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
493114	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
493115	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
493116	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
493117	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
493118	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
493119	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
493120	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
493121	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
493122	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
493123	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
493124	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
493125	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
493126	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Accumulated Fault Duty B Ph V	3.59	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
493127	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
493128	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
493129	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
493130	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Amps C Ø	240.0	
493131	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Amps B Ø	260.0	
493132	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Amps A Ø	210.0	
493133	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
493134	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
493135	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
493136	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	9 Month Operations	7	
493137	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Accumulated Fault Duty C Ph V	3.59	%
493138	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Amps A Ø	60.0	
493139	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Amps B Ø	75.0	
493140	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Amps C Ø	90.0	
493141	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Bushing Condition	Good	
493142	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Bushings Connection/Risers	Good	
493143	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
493144	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
493145	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
493146	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Cabinet Paint Condition	Good	
493147	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Equipment Properly Labeled?	y	
493148	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
493149	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	54	°F
493150	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
493151	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
493152	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
493153	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Unknown Operations	0	
493154	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	9 Months Operations	18	
493155	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
493156	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
493157	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
493158	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Amps A Ø	100.0	
493159	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Amps B Ø	240.0	
493160	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Amps C Ø	180.0	
493161	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
493162	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
493163	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
493164	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations A Ø	0	
493165	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations B Ø	0	
493166	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations C Ø	0	
493167	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
493168	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
493169	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
493170	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	90	
493171	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6R	
493172	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	8R	
493173	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7R	
493174	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
493175	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC As Left Counter	330126	
493176	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC As Found Counter	330126	
493177	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
493178	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	General Comments		
493179	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
493180	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
493181	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	General Comments		
493182	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	LTC As Found Counter	255073	
493183	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000571	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
493184	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000571	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
493185	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	LTC As Left Counter	255073	
493186	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
493187	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	LTC Current Tap Position	8L	
493188	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	LTC Max Tap Position	Neutral	
493189	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	LTC Min Tap Position	9L	
493190	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
493191	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	LTC Operations Since Last Insp	436	
493192	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
493193	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
493194	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
493195	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Unknown Operations	0	
493196	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Switching Operations	5	
493197	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Operations This Read Vac	5	
493198	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Operations Counter AL	439	
493199	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Operations Counter AF	439	
493200	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Maintenance Operations	0	
493201	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
493202	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Follow-up Action Required?	n	
493203	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Operations Ground	0	
493204	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Operations C Ø	0	
493205	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Operations B Ø	0	
493206	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Operations A Ø	0	
493207	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	9 Month Operations	1	
493208	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Accumulated Fault Duty A Ph V	2.74	%
493209	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Amps C Ø	16.0	
493210	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
493211	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
493212	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
493213	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Operations A Ø	0	
493214	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Operations B Ø	0	
493215	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Operations C Ø	0	
493216	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Operations Ground	0	
493217	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Follow-up Action Required?	n	
493218	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	General Comments		
493219	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Maintenance Operations	0	
493220	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Operations Counter AF	54	
493221	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Operations Counter AL	54	
493222	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Operations This Read Vac	0	
493223	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Switching Operations	0	
493224	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Unknown Operations	0	
493225	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Unknown Operations	0	
493226	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Tank Paint Condition	Good	
493227	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Switching Operations	0	
493228	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
493229	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Operations This Read Vac	0	
493230	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Operations Counter AL	723	
493231	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Operations Counter AF	723	
493232	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
493233	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	General Comments		
493234	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
493235	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
493236	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
493237	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
493238	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
493239	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
493240	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
493241	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
493242	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Unknown Operations	0	
493243	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Switching Operations	0	
493244	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Operations This Read AM	0	
493245	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Operations Counter AL	99996	
493246	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Operations Counter AF	99996	
493247	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Maintenance Operations	0	
493248	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
493249	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
493250	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Operations Counter AF	94	
493251	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Operations Counter AL	94	
493252	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Operations This Read Vac	6	
493253	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Switching Operations	6	
493254	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Amps A Ø	5.0	
493255	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Amps B Ø	5.0	
493256	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Amps C Ø	3.0	
493257	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
493258	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
493259	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
493260	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Operations A Ø	0	
493261	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Operations B Ø	0	
493262	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Operations C Ø	0	
493263	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Operations Ground	0	
493264	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Follow-up Action Required?	n	
493265	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	General Comments		
493266	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Maintenance Operations	0	
493267	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Operations Counter AF	122	
493268	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Operations Counter AL	122	
493269	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Operations This Read Vac	0	
493270	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Switching Operations	0	
493271	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Unknown Operations	0	
493272	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
493273	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	General Comments		
493274	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	General Comments		
493275	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
493276	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
493277	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
493278	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
493279	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
493280	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
493281	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
493282	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
493283	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
493284	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
493285	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
493286	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	9 Month Operations	7	
493287	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Accumulated Fault Duty A Ph V	1.15	%
493288	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Accumulated Fault Duty B Ph V	.69	%
493289	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Accumulated Fault Duty C Ph V	1.84	%
493290	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Amps A Ø	22.0	
493291	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Amps B Ø	22.0	
493292	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
493293	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Amps B Ø	0.0	
493294	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Amps A Ø	0.0	
493295	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
493296	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
493297	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
493298	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Amps A Ø	0.0	
493299	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Amps B Ø	0.0	
493300	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Amps C Ø	0.0	
493301	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
493302	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
493303	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
493304	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Operations A Ø	0	
493305	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Operations B Ø	0	
493306	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Operations C Ø	0	
493307	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Operations Ground	0	
493308	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Follow-up Action Required?	n	
493309	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	General Comments	R&C	
493310	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
493311	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
493312	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
493313	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
493314	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
493315	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
493316	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
493317	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
493318	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
493319	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
493320	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
493321	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
493322	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
493323	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
493324	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
493325	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
493326	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
493327	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
493328	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
493329	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
493330	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
493331	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
493332	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
493333	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
493334	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
493335	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
493336	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
493337	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Maintenance Operations	0	
493338	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
493339	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Grounds in Place?	y	
493340	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	General Comments		
493341	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	General Comments		
493342	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Foundation Condition	Good	
493343	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Follow-up Action Required?	n	
493344	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Follow-up Action Required?	n	
493345	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Operations Ground	0	
493346	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Operations C Ø	0	
493347	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Operations B Ø	0	
493348	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Operations A Ø	0	
493349	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
493350	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
493351	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
493352	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
493353	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
493354	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
493355	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
493356	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
493357	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
493358	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Bushing Condition	Good	
493359	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Amps C Ø	0.0	
493360	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	9 Months Operations	0	
493361	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
493362	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
493363	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
493364	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
493365	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
493366	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
493367	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
493368	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
493369	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
493370	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
493371	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
493372	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
493373	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
493374	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	General Comments		
493375	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
493376	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
493377	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
493378	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
493379	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Totalizer Meter Reading	.5850	
493380	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Winding Temp Max	60	°C
493381	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Winding Temp Present	40	°C
493382	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
493383	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
493384	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
493385	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	30.0	
493386	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
493387	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
493388	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
493389	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
493390	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
493391	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
493392	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
493393	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
493394	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
493395	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
493396	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
493397	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
493398	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	Follow-up Action Required?	n	
493399	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
493400	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
493401	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	General Comments		
493402	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	General Comments	out of service	
493403	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
493404	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
493405	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
493406	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
493407	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	Oil Temp Max	25	°C
493408	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	Oil Temp Present	25	°C
493409	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
493410	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
493411	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
493412	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
493413	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
493414	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
493415	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
493416	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
493417	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
493418	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
493419	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
493420	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
493421	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
493422	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
493423	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Amps C Ø	750.0	
493424	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Amps B Ø	750.0	
493425	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Amps A Ø	600.0	
493426	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	2.89	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
493427	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	2.89	%
493428	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	2.89	%
493429	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	9 Months Operations	2	
493430	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
493431	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
493432	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
493433	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
493434	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
493435	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
493436	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
493437	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
493438	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
493439	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
493440	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
493441	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
493442	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
493443	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Follow-up Action Required?	n	
493444	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
493445	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
493446	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	General Comments		
493447	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	General Comments		
493448	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
493449	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	LTC Totalizer Reading	14040.00	kw
493450	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
493451	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
493452	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Oil Temp Max	40	°C
493453	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Oil Temp Present	30	°C
493454	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
493455	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
493456	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
493457	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
493458	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Operations A Ø	0	
493459	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
493460	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
493461	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
493462	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Amps C Ø	25.0	
493463	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Amps B Ø	30.0	
493464	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Amps A Ø	35.0	
493465	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Accumulated Fault Duty C Ph V	1.24	%
493466	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Accumulated Fault Duty B Ph V	.86	%
493467	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Accumulated Fault Duty A Ph V	.86	%
493468	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	9 Month Operations	1	
493469	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
493470	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
493471	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
493472	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
493473	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
493474	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
493475	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
493476	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
493477	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
493478	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2661.12	kw
493479	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
493480	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-2.0	psi
493481	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	9 Month Operations	13	
493482	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Accumulated Fault Duty A Ph V	3.45	%
493483	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Accumulated Fault Duty B Ph V	5.29	%
493484	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Accumulated Fault Duty C Ph V	3.45	%
493485	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	9 Month Operations	6	
493486	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
493487	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
493488	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
493489	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
493490	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
493491	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
493492	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Operations A Ø	0	
493493	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Operations B Ø	0	
493494	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Operations C Ø	0	
493495	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Operations Ground	0	
493496	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Follow-up Action Required?	n	
493497	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	General Comments		
493498	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Maintenance Operations	0	
493499	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
493500	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
493501	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
493502	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
493503	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	Winding Temp Max	15	°C
493504	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	Winding Temp Present	15	°C
493505	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
493506	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
493507	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	9 Month Operations	1	
493508	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	30.0	
493509	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	30.0	
493510	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	9 Month Operations	2	
493511	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Accumulated Fault Duty A Ph V	1.34	%
493512	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Accumulated Fault Duty B Ph V	.89	%
493513	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
493514	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Amps A Ø	137.0	
493515	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Amps B Ø	140.0	
493516	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Amps C Ø	134.0	
493517	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
493518	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
493519	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
493520	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Fault Operations A Ø	0	
493521	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Fault Operations B Ø	0	
493522	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Fault Operations C Ø	0	
493523	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Fault Operations Ground	0	
493524	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Follow-up Action Required?	n	
493525	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	General Comments		
493526	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Maintenance Operations	0	
493527	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Operations Counter AF	202	
493528	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Operations Counter AL	204	
493529	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Operations This Read Vac	2	
493530	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Switching Operations	2	
493531	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Unknown Operations	0	
493532	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5544	
493533	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
493534	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
493535	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	General Comments		
493536	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Follow-up Action Required?	n	
493537	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Operations Ground	0	
493538	4/5/2019 9:11	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
493539	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Operations C Ø	0	
493540	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Operations B Ø	0	
493541	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
493542	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
493543	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
493544	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
493545	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
493546	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Foundation Condition	Good	
493547	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
493548	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
493549	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	General Comments		
493550	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
493551	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
493552	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
493553	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
493554	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
493555	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
493556	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
493557	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
493558	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
493559	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
493560	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
493561	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
493562	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
493563	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
493564	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
493565	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
493566	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
493567	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
493568	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
493569	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
493570	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Unknown Operations	0	
493571	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Switching Operations	0	
493572	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Operations This Read Vac	0	
493573	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Operations Counter AL	185	
493574	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Operations Counter AF	185	
493575	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Maintenance Operations	0	
493576	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
493577	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Follow-up Action Required?	n	
493578	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Operations Ground	0	
493579	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
493580	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
493581	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
493582	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
493583	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
493584	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Follow-up Action Required?	n	
493585	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
493586	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
493587	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
493588	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
493589	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
493590	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
493591	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
493592	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
493593	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
493594	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
493595	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
493596	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
493597	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
493598	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
493599	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
493600	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
493601	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
493602	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
493603	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
493604	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
493605	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
493606	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Amps C Ø	360.0	
493607	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Amps B Ø	340.0	
493608	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Amps A Ø	350.0	
493609	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Accumulated Fault Duty C Ph AM	27.91	%
493610	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
493611	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
493612	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Readings	Follow-up Action Required?	n	
493613	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
493614	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
493615	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	General Comments		
493616	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Readings	General Comments		
493617	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
493618	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Readings	LTC Totalizer Reading	4541.76	kw
493619	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
493620	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
493621	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Readings	Oil Temp Max	60	°C
493622	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Readings	Oil Temp Present	35	°C
493623	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
493624	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
493625	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Unknown Operations	0	
493626	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Switching Operations	5	
493627	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Operations This Read Vac	5	
493628	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
493629	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
493630	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
493631	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Operations Counter AF	204	
493632	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Maintenance Operations	0	
493633	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	General Comments		
493634	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Follow-up Action Required?	n	
493635	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Operations Ground	0	
493636	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Operations C Ø	0	
493637	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Operations B Ø	0	
493638	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Operations A Ø	2	
493639	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
493640	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
493641	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Adjusted Amps A Phase V	26.50	
493642	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Amps C Ø	135.0	
493643	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Amps B Ø	109.0	
493644	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Amps A Ø	113.0	
493645	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Accumulated Fault Duty C Ph V	2.96	%
493646	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Operations A Ø	0	
493647	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
493648	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
493649	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
493650	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Equipment Properly Labeled?	y	
493651	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
493652	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
493653	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
493654	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
493655	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Bushings Connection/Risers	Good	
493656	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Accumulated Fault Duty B Ph V	2.96	%
493657	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Accumulated Fault Duty A Ph V	3.95	%
493658	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	9 Month Operations	8	
493659	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Bushing Condition	Good	
493660	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Amps C Ø	130.0	
493661	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Amps B Ø	110.0	
493662	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Amps A Ø	90.0	
493663	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Accumulated Fault Duty C Ph V	11.85	%
493664	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Accumulated Fault Duty B Ph V	11.85	%
493665	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Readings	Totalizer Meter Reading	.9462	
493666	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
493667	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
493668	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Operations C Ø	0	
493669	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Operations B Ø	0	
493670	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Operations A Ø	0	
493671	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
493672	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
493673	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
493674	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Amps C Ø	168.0	
493675	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Amps B Ø	140.0	
493676	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Amps A Ø	168.0	
493677	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
493678	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
493679	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
493680	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	9 Month Operations	2	
493681	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Accumulated Fault Duty B Ph AM	25.25	%
493682	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Unknown Operations	0	
493683	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Tank Paint Condition	Good	
493684	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Switching Operations	0	
493685	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
493686	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Operations This Read Vac	1	
493687	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Operations Counter AL	99936	
493688	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Operations Counter AF	99936	
493689	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Moisture and Leak Free?	y	
493690	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Maintenance Operations	1	
493691	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Heaters (All) Functioning?	y	
493692	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Grounds in Place?	y	
493693	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	General Comments		
493694	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	General Comments		
493695	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Foundation Condition	Good	
493696	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Follow-up Action Required?	n	
493697	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Follow-up Action Required?	n	
493698	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Operations Ground	0	
493699	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Operations C Ø	0	
493700	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Operations B Ø	0	
493701	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Accumulated Fault Duty A Ph AM	19.93	%
493702	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	9 Months Operations	16	
493703	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Unknown Operations	0	
493704	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Switching Operations	1	
493705	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Operations This Read Vac	3	
493706	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Operations Counter AL	204	
493707	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
493708	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
493709	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
493710	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
493711	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Foundation Condition	Good	
493712	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
493713	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	General Comments		
493714	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
493715	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
493716	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
493717	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
493718	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
493719	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
493720	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
493721	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
493722	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
493723	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
493724	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
493725	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
493726	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
493727	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
493728	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	9 Months Operations	3	
493729	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Accumulated Fault Duty A Ph AM	29.24	%
493730	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Accumulated Fault Duty B Ph AM	27.91	%
493731	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Accumulated Fault Duty C Ph AM	25.25	%
493732	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Amps A Ø	300.0	
493733	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Amps B Ø	325.0	
493734	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Amps C Ø	220.0	
493735	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
493736	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
493737	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
493738	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Operations A Ø	0	
493739	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Operations B Ø	0	
493740	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	General Comments		
493741	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	LTCC000251	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
493742	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	LTCC000251	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
493743	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	LTCC000251	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
493744	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	LTCC000251	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
493745	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	LTCC000251	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
493746	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	LTCC000251	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
493747	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
493748	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
493749	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
493750	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
493751	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
493752	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
493753	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Oil Temp Present	30	°C
493754	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Oil Temp Max	40	°C
493755	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
493756	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
493757	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	LTC Totalizer Reading	2203.20	kw
493758	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
493759	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	General Comments		
493760	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	General Comments		
493761	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
493762	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
493763	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Follow-up Action Required?	n	
493764	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
493765	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
493766	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
493767	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
493768	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
493769	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
493770	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
493771	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
493772	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
493773	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
493774	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
493775	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
493776	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	LTCC000665	LTCControl	662-1	LTC Control Insp	All Connections OK?	y	
493777	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	LTCC000665	LTCControl	662-1	LTC Control Insp	Follow-up Action Required?	n	
493778	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	LTCC000665	LTCControl	662-1	LTC Control Insp	General Comments		
493779	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	LTCC000665	LTCControl	662-1	LTC Control Insp	LTC Operation Checked?	y	
493780	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	LTCC000665	LTCControl	662-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
493781	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	LTCC000665	LTCControl	662-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
493782	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	LTCC000665	LTCControl	662-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
493783	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	LTCC000665	LTCControl	662-1	LTC Control Insp	VRR Time Delay	30	Seconds
493784	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
493785	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	LTC Totalizer Reading	5664.00	kw
493786	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
493787	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	General Comments		
493788	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
493789	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
493790	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
493791	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
493792	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
493793	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Switching Operations	0	
493794	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Operations This Read AM	0	
493795	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Operations Counter AL	871	
493796	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Operations Counter AF	871	
493797	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Maintenance Operations	0	
493798	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	General Comments		
493799	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Follow-up Action Required?	n	
493800	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
493801	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
493802	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
493803	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
493804	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
493805	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	25.0	
493806	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
493807	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
493808	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Operations Ground	0	
493809	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Operations C Ø	0	
493810	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Operations B Ø	0	
493811	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	10.0	
493812	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	25.0	
493813	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Clear of Trash?	y	
493814	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
493815	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
493816	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
493817	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
493818	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
493819	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
493820	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	General Comments		
493821	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
493822	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
493823	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Vegetation	None	
493824	4/5/2019 10:34	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
493825	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
493826	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	1.22	%
493827	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
493828	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	13	
493829	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Operations A Ø	0	
493830	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
493831	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
493832	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
493833	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Operations C Ø	0	
493834	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Operations Ground	0	
493835	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Follow-up Action Required?	n	
493836	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	General Comments		
493837	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Maintenance Operations	0	
493838	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Operations Counter AF	55	
493839	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Operations Counter AL	55	
493840	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Operations This Read AM	0	
493841	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Switching Operations	0	
493842	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Unknown Operations	0	
493843	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Unknown Operations	0	
493844	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	13	
493845	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
493846	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
493847	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	1.22	%
493848	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	25.0	
493849	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	10.0	
493850	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	25.0	
493851	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
493852	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
493853	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	LTCC000251	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
493854	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
493855	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
493856	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Clear of Trash?	y	
493857	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
493858	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
493859	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
493860	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
493861	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
493862	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
493863	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	General Comments		
493864	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
493865	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
493866	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Vegetation	None	
493867	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
493868	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	LTCC000251	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
493869	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	102	
493870	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	102	
493871	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
493872	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ok	
493873	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	50.0	
493874	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
493875	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
493876	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
493877	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	14	
493878	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Switching Operations	0	
493879	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Tank Paint Condition	Good	
493880	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Unknown Operations	0	
493881	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps B Ø	251.0	
493882	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
493883	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
493884	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
493885	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	527	
493886	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	527	
493887	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
493888	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
493889	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	General Comments		
493890	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
493891	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
493892	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
493893	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
493894	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
493895	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Clear of Trash?	y	
493896	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
493897	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
493898	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Ambient Temp	53	°F
493899	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
493900	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	General Comments		
493901	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
493902	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
493903	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
493904	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
493905	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
493906	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
493907	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
493908	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
493909	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
493910	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
493911	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
493912	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
493913	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
493914	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
493915	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	267	
493916	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	269	
493917	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	2	
493918	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	2	
493919	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
493920	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
493921	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Vegetation	None	
493922	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
493923	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
493924	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
493925	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
493926	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	General Comments		
493927	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
493928	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	General Comments		
493929	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
493930	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Max Tap Position	3R	
493931	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Min Tap Position	7L	
493932	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
493933	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
493934	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
493935	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.3	volts
493936	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Regulator As Left Counter	56408	
493937	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
493938	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
493939	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Tank Leaks	None	
493940	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
493941	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
493942	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
493943	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
493944	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps A Ø	263.0	
493945	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Maintenance Operations	0	
493946	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Moisture and Leak Free?	y	
493947	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Operations Counter AF	192	
493948	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Operations Counter AL	192	
493949	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Operations This Read Vac	0	
493950	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
493951	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
493952	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCC000246	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
493953	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
493954	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	80.0	
493955	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	20.0	
493956	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Oil Temp Present	45	°C
493957	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Oil Temp Max	60	°C
493958	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
493959	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
493960	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	LTC Totalizer Reading	2596.32	kw
493961	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
493962	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	General Comments		
493963	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	General Comments		
493964	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
493965	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
493966	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Follow-up Action Required?	n	
493967	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
493968	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
493969	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
493970	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
493971	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
493972	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
493973	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
493974	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
493975	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
493976	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
493977	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
493978	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
493979	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
493980	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
493981	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
493982	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
493983	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
493984	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	258	
493985	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	258	
493986	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
493987	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
493988	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
493989	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
493990	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
493991	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
493992	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
493993	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
493994	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
493995	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
493996	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
493997	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
493998	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
493999	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
494000	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
494001	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
494002	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
494003	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
494004	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
494005	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
494006	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Amps C Ø	370.0	
494007	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Amps B Ø	335.0	
494008	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Amps A Ø	350.0	
494009	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
494010	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
494011	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
494012	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	9 Months Operations	0	
494013	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
494014	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Totalizer Meter Reading	.3606	
494015	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
494016	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
494017	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
494018	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps C Ø	250.0	
494019	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Operations B Ø	0	
494020	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Operations C Ø	0	
494021	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Operations Ground	0	
494022	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Follow-up Action Required?	n	
494023	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Follow-up Action Required?	n	
494024	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Foundation Condition	Good	
494025	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	General Comments		
494026	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
494027	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Grounds in Place?	y	
494028	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Heaters (All) Functioning?	y	
494029	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Maintenance Operations	1	
494030	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Moisture and Leak Free?	y	
494031	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Operations Counter AF	153	
494032	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Operations Counter AL	153	
494033	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Operations This Read Vac	1	
494034	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
494035	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
494036	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
494037	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
494038	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
494039	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
494040	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
494041	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
494042	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
494043	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
494044	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
494045	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	9 Month Operations	5	
494046	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
494047	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
494048	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
494049	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	9 Month Operations	12	
494050	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Accumulated Fault Duty A Ph V	4.99	%
494051	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Accumulated Fault Duty B Ph V	4.49	%
494052	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Accumulated Fault Duty C Ph V	6.98	%
494053	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Amps A Ø	120.0	
494054	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Amps B Ø	240.0	
494055	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
494056	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
494057	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	9 Month Operations	2	
494058	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Accumulated Fault Duty A Ph V	.63	%
494059	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Accumulated Fault Duty B Ph V	.63	%
494060	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Accumulated Fault Duty C Ph V	.63	%
494061	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Amps A Ø	10.0	
494062	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Amps B Ø	10.0	
494063	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Amps C Ø	20.0	
494064	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Bushing Condition	Good	
494065	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Bushings Connection/Risers	Good	
494066	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
494067	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
494068	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
494069	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Cabinet Paint Condition	Good	
494070	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Equipment Properly Labeled?	y	
494071	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
494072	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
494073	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
494074	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Operations A Ø	0	
494075	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
494076	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
494077	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
494078	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
494079	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
494080	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Accumulated Fault Duty A Ph V	12.84	%
494081	4/5/2019 10:45	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	9 Month Operations	2	
494082	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
494083	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
494084	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
494085	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
494086	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
494087	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
494088	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Evidence of Insects	None	
494089	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
494090	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
494091	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Floor Swept?	y	
494092	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Operations Counter AL	309	
494093	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Operations Counter AF	304	
494094	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Maintenance Operations	0	
494095	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	General Comments		
494096	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Follow-up Action Required?	n	
494097	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Operations Ground	0	
494098	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Operations C Ø	0	
494099	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Operations B Ø	0	
494100	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Operations A Ø	0	
494101	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
494102	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
494103	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
494104	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Amps C Ø	170.0	
494105	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Amps B Ø	160.0	
494106	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Amps A Ø	140.0	
494107	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
494108	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
494109	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	General Comments		
494110	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
494111	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
494112	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Panels Dusted?	y	
494113	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
494114	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
494115	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
494116	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
494117	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
494118	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ok	
494119	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
494120	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	121	
494121	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	121	
494122	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	308	
494123	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	308	
494124	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
494125	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	OK	
494126	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
494127	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
494128	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
494129	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
494130	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	1	
494131	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
494132	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Operations Counter AL	111	
494133	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Operations Counter AF	111	
494134	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Maintenance Operations	0	
494135	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	General Comments		
494136	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
494137	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
494138	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
494139	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
494140	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
494141	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
494142	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Current Tap Position	5L	
494143	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
494144	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
494145	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
494146	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
494147	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	2	
494148	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	5.81	%
494149	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	5.81	%
494150	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	5.81	%
494151	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	171.0	
494152	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	157.0	
494153	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	131.0	
494154	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
494155	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
494156	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
494157	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
494158	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
494159	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
494160	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
494161	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
494162	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
494163	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
494164	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
494165	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
494166	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	General Comments		
494167	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
494168	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Amps C Ø	120.0	
494169	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Bushing Condition	Good	
494170	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Bushings Connection/Risers	Good	
494171	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
494172	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
494173	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
494174	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Cabinet Paint Condition	Good	
494175	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Equipment Properly Labeled?	y	
494176	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
494177	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
494178	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
494179	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Operations A Ø	0	
494180	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Operations B Ø	0	
494181	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Operations C Ø	0	
494182	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Operations Ground	0	
494183	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCC000246	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
494184	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCC000246	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
494185	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCC000246	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
494186	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCC000246	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
494187	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCC000246	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
494188	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCC000246	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
494189	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCC000246	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
494190	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	LTCC000246	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
494191	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Follow-up Action Required?	n	
494192	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Follow-up Action Required?	n	
494193	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Foundation Condition	Good	
494194	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	General Comments		
494195	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	General Comments	no end counter on last inspection	
494196	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
494197	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
494198	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
494199	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Grounds in Place?	y	
494200	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Heaters (All) Functioning?	y	
494201	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	9 Month Operations	18	
494202	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Unknown Operations	0	
494203	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Switching Operations	0	
494204	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Operations This Read AM	0	
494205	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
494206	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
494207	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
494208	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	9 Month Operations	7	
494209	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
494210	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
494211	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Operations C Ø	0	
494212	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Operations Ground	0	
494213	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	9 Month Operations	8	
494214	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
494215	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	9 Month Operations	48	
494216	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Follow-up Action Required?	n	
494217	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	General Comments		
494218	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Maintenance Operations	0	
494219	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Operations Counter AF	95	
494220	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Operations Counter AL	95	
494221	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Operations This Read Vac	0	
494222	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Switching Operations	0	
494223	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Unknown Operations	0	
494224	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
494225	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Clear of Trash?	y	
494226	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
494227	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	9 Month Operations	0	
494228	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
494229	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
494230	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
494231	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Amps A Ø	320.0	
494232	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Amps B Ø	320.0	
494233	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Amps C Ø	320.0	
494234	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Bushing Condition	Good	
494235	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
494236	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
494237	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
494238	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
494239	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
494240	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
494241	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
494242	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
494243	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
494244	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
494245	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Amps A Ø	112.0	
494246	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Amps B Ø	97.0	
494247	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Amps C Ø	94.0	
494248	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Bushing Condition	Good	
494249	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	5.0	
494250	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
494251	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
494252	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
494253	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
494254	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
494255	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
494256	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	255	
494257	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	255	
494258	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
494259	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ok	
494260	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
494261	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
494262	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
494263	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Readings	Fault Operations A Ø	0	
494264	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Readings	Fault Operations B Ø	0	
494265	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Readings	Fault Operations C Ø	0	
494266	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
494267	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
494268	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
494269	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
494270	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
494271	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
494272	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Accumulated Fault Duty B Ph AM	14.45	%
494273	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Accumulated Fault Duty C Ph AM	8.43	%
494274	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
494275	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	VRR Time Delay	30	Seconds
494276	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
494277	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
494278	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Amps A Ø	0.0	
494279	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Amps B Ø	0.0	
494280	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Amps C Ø	0.0	
494281	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
494282	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Amps C Ø	310.0	
494283	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
494284	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
494285	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
494286	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Operations A Ø	0	
494287	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Operations B Ø	0	
494288	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Operations C Ø	0	
494289	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Operations Ground	0	
494290	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Follow-up Action Required?	n	
494291	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	General Comments		
494292	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Maintenance Operations	0	
494293	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Operations Counter AF	144	
494294	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Operations Counter AL	144	
494295	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Operations This Read AM	0	
494296	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Switching Operations	0	
494297	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Unknown Operations	0	
494298	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Switching Operations	3	
494299	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Amps B Ø	310.0	
494300	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Amps A Ø	240.0	
494301	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	9 Month Operations	8	
494302	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Accumulated Fault Duty A Ph V	3.64	%
494303	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Accumulated Fault Duty B Ph V	3.64	%
494304	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
494305	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
494306	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
494307	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Operations This Read Vac	3	
494308	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Operations Counter AL	186	
494309	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Operations Counter AF	186	
494310	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Maintenance Operations	0	
494311	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	General Comments		
494312	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Follow-up Action Required?	n	
494313	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Operations Ground	0	
494314	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Operations C Ø	0	
494315	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Operations B Ø	0	
494316	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Operations A Ø	0	
494317	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
494318	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
494319	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
494320	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Amps C Ø	0.0	
494321	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Amps B Ø	0.0	
494322	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	9 Month Operations	2	
494323	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
494324	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
494325	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
494326	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Amps A Ø	28.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
494327	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Amps B Ø	29.0	
494328	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Amps C Ø	14.0	
494329	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
494330	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
494331	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
494332	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Operations A Ø	0	
494333	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Operations B Ø	0	
494334	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Amps A Ø	0.0	
494335	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Operations Counter AL	45	
494336	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Operations This Read SF6	3	
494337	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Switching Operations	0	
494338	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Maintenance Operations	0	
494339	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Moisture and Leak Free?	y	
494340	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Operations Counter AF	185	
494341	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
494342	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
494343	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
494344	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
494345	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
494346	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
494347	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Operations Counter AL	185	
494348	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Operations This Read Vac	0	
494349	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Switching Operations	0	
494350	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Tank Paint Condition	Good	
494351	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
494352	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
494353	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
494354	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
494355	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC Operations Since Last Insp	186	
494356	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Unknown Operations	0	
494357	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Switching Operations	3	
494358	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Operations This Read Vac	3	
494359	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Operations Counter AL	184	
494360	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Operations Counter AF	184	
494361	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC Min Tap Position	4L	
494362	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC Max Tap Position	6R	
494363	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC Current Tap Position	2L	
494364	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
494365	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC As Left Counter	48383	
494366	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC As Found Counter	48383	
494367	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	General Comments		
494368	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	General Comments		
494369	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Maintenance Operations	0	
494370	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	General Comments		
494371	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Follow-up Action Required?	n	
494372	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Operations Ground	0	
494373	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Operations C Ø	0	
494374	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Operations B Ø	0	
494375	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Operations A Ø	0	
494376	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
494377	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
494378	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
494379	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
494380	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Amps C Ø	130.0	
494381	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Amps B Ø	130.0	
494382	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Amps A Ø	130.0	
494383	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Accumulated Fault Duty C Ph V	.44	%
494384	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Accumulated Fault Duty B Ph V	.44	%
494385	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Accumulated Fault Duty A Ph V	.44	%
494386	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	9 Month Operations	3	
494387	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
494388	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
494389	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
494390	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	Follow-up Action Required?	n	
494391	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Amps A Ø	360.0	
494392	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Amps B Ø	360.0	
494393	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
494394	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
494395	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
494396	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
494397	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Foundation Condition	Good	
494398	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
494399	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
494400	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
494401	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	100.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
494402	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Unknown Operations	0	
494403	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Switching Operations	3	
494404	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Operations This Read Vac	3	
494405	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Operations Counter AL	140	
494406	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Operations Counter AF	140	
494407	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Maintenance Operations	0	
494408	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	General Comments		
494409	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Follow-up Action Required?	n	
494410	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Operations Ground	0	
494411	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Operations C Ø	0	
494412	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Operations B Ø	0	
494413	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Operations A Ø	0	
494414	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
494415	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
494416	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
494417	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
494418	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	107	
494419	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
494420	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
494421	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Bushings Connection/Risers	Good	
494422	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
494423	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
494424	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
494425	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Cabinet Paint Condition	Good	
494426	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Equipment Properly Labeled?	y	
494427	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
494428	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
494429	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
494430	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
494431	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
494432	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
494433	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Amps C Ø	100.0	
494434	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Amps B Ø	80.0	
494435	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Operations A Ø	0	
494436	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Operations B Ø	0	
494437	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Operations C Ø	0	
494438	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Amps A Ø	50.0	
494439	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
494440	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
494441	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
494442	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	9 Month Operations	3	
494443	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
494444	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	
494445	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
494446	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	1.22	%
494447	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	1.22	%
494448	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	14	
494449	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Fault Operations Ground	0	
494450	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Follow-up Action Required?	n	
494451	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Follow-up Action Required?	n	
494452	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Operations Ground	0	
494453	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Follow-up Action Required?	n	
494454	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Follow-up Action Required?	n	
494455	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Foundation Condition	Good	
494456	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	General Comments		
494457	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	General Comments		
494458	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Grounds in Place?	y	
494459	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Fault Operations	0	
494460	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Follow-up Action Required?	n	
494461	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	General Comments		
494462	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Maintenance Operations	3	
494463	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Num Operations Last 9 Months	3	
494464	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Operations Counter AF	45	
494465	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	1	
494466	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
494467	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Operations Counter AF	675	
494468	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Maintenance Operations	0	
494469	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
494470	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	General Comments		
494471	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Patrol Inspection	General Comments		
494472	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Follow-up Action Required?	n	
494473	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
494474	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Operations Ground	0	
494475	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Operations C Ø	0	
494476	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
494477	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	General Comments		
494478	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Maintenance Operations	1	
494479	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Operations Counter AF	170	
494480	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Operations Counter AL	171	
494481	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Operations This Read Vac	1	
494482	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Switching Operations	0	
494483	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Unknown Operations	0	
494484	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Operations A Ø	0	
494485	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
494486	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
494487	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC Operations Since Last Insp	400	
494488	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
494489	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
494490	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
494491	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
494492	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Foundation Condition	Good	
494493	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	All Connections OK?	y	
494494	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
494495	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
494496	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
494497	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
494498	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
494499	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Amps C Ø	160.0	
494500	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Amps B Ø	50.0	
494501	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Amps A Ø	50.0	
494502	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
494503	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
494504	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
494505	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	9 Months Operations	0	
494506	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	4.69	
494507	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
494508	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
494509	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	4.69	
494510	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
494511	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	Follow-up Action Required?	n	
494512	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	General Comments		
494513	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	LTC Operation Checked?	y	
494514	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Unknown Operations	0	
494515	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Switching Operations	1	
494516	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Operations This Read Vac	1	
494517	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	96.0	
494518	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Operations Counter AL	155	
494519	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Operations Counter AF	155	
494520	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Maintenance Operations	0	
494521	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	General Comments		
494522	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Follow-up Action Required?	n	
494523	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Operations Ground	0	
494524	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Operations C Ø	0	
494525	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Operations B Ø	0	
494526	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Operations A Ø	0	
494527	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
494528	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
494529	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
494530	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC Operations Since Last Insp	480	
494531	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
494532	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC Min Tap Position	9L	
494533	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC Max Tap Position	2R	
494534	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC Current Tap Position	5L	
494535	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
494536	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC As Left Counter	17964	
494537	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC As Found Counter	17960	
494538	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	General Comments		
494539	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	General Comments		
494540	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
494541	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	9 Month Operations	5	
494542	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Accumulated Fault Duty A Ph V	.22	%
494543	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Accumulated Fault Duty B Ph V	.22	%
494544	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Accumulated Fault Duty C Ph V	.3	%
494545	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Amps A Ø	30.0	
494546	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Amps B Ø	26.9	
494547	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Amps C Ø	22.0	
494548	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
494549	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
494550	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
494551	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
494552	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Operations B Ø	0	
494553	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Operations C Ø	0	
494554	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Operations Ground	0	
494555	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	Follow-up Action Required?	n	
494556	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
494557	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
494558	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
494559	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Clear of Trash?	y	
494560	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
494561	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
494562	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
494563	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
494564	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
494565	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
494566	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	General Comments		
494567	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
494568	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Vegetation	None	
494569	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
494570	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
494571	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
494572	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
494573	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Follow-up Action Required?	n	
494574	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
494575	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
494576	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
494577	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Unknown Operations	0	
494578	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Switching Operations	0	
494579	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Operations This Read AM	0	
494580	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Operations Counter AL	675	
494581	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
494582	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
494583	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
494584	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	General Comments		
494585	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
494586	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
494587	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Operations Counter	68	
494588	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
494589	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Tank Leaks	None	
494590	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
494591	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
494592	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
494593	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
494594	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	1	
494595	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Operations This Read Vac	0	
494596	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Operations Counter AL	171	
494597	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Operations Counter AF	171	
494598	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Maintenance Operations	0	
494599	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Operations Counter AL	138	
494600	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Operations Counter AF	138	
494601	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	General Comments		
494602	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Follow-up Action Required?	n	
494603	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Operations Ground	0	
494604	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Operations C Ø	0	
494605	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Maintenance Operations	0	
494606	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	General Comments		
494607	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Follow-up Action Required?	n	
494608	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Operations Ground	0	
494609	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Operations C Ø	0	
494610	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Operations B Ø	0	
494611	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Operations A Ø	0	
494612	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
494613	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Operations B Ø	0	
494614	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
494615	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
494616	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
494617	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
494618	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
494619	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Amps C Ø	130.0	
494620	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Amps B Ø	130.0	
494621	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Amps A Ø	130.0	
494622	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
494623	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
494624	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
494625	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	9 Month Operations	32	
494626	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
494627	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
494628	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
494629	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
494630	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
494631	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
494632	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
494633	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	General Comments		
494634	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
494635	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
494636	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
494637	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
494638	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
494639	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
494640	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
494641	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
494642	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	58	°F
494643	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
494644	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Operations A Ø	0	
494645	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
494646	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
494647	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
494648	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	All Connections OK?	y	
494649	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	Follow-up Action Required?	n	
494650	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
494651	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
494652	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	General Comments		
494653	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	LTC Operation Checked?	y	
494654	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
494655	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
494656	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	General Comments		
494657	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
494658	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	9 Months Operations	8	
494659	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Accumulated Fault Duty A Ph AM	10.84	%
494660	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Amps C Ø	160.0	
494661	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Amps B Ø	130.0	
494662	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Amps A Ø	110.0	
494663	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
494664	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
494665	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
494666	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	9 Month Operations	1	
494667	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
494668	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	108.0	
494669	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	96.0	
494670	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	20.29	%
494671	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	17.29	%
494672	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	13.53	%
494673	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
494674	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
494675	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	VRR Time Delay	30	Seconds
494676	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
494677	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
494678	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
494679	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
494680	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	74	
494681	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	74	
494682	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
494683	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
494684	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
494685	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
494686	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
494687	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
494688	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
494689	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
494690	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
494691	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
494692	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
494693	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
494694	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
494695	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
494696	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
494697	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
494698	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
494699	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Unknown Operations	0	
494700	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Unknown Operations	0	
494701	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Switching Operations	7	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
494702	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Operations This Read Vac	7	
494703	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Operations Counter AL	165	
494704	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Operations Counter AF	165	
494705	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Maintenance Operations	0	
494706	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	General Comments		
494707	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Follow-up Action Required?	n	
494708	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Operations Ground	0	
494709	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Operations C Ø	0	
494710	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Operations B Ø	0	
494711	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Operations A Ø	0	
494712	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
494713	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
494714	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
494715	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Amps C Ø	0.0	
494716	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Amps B Ø	0.0	
494717	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Amps A Ø	0.0	
494718	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
494719	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
494720	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
494721	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	9 Month Operations	10	
494722	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Unknown Operations	0	
494723	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Switching Operations	1	
494724	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Operations This Read Vac	1	
494725	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Switching Operations	0	
494726	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	General Comments	ok	
494727	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
494728	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
494729	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
494730	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
494731	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
494732	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
494733	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Clear of Trash?	y	
494734	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
494735	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
494736	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
494737	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Amps B Ø	0.0	
494738	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Amps C Ø	0.0	
494739	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
494740	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
494741	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
494742	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Operations A Ø	0	
494743	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Operations B Ø	0	
494744	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Operations C Ø	0	
494745	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Amps A Ø	62.0	
494746	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Amps B Ø	70.0	
494747	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Amps C Ø	57.0	
494748	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
494749	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	9 Month Operations	2	
494750	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Accumulated Fault Duty A Ph V	4.88	%
494751	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Accumulated Fault Duty B Ph V	.98	%
494752	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Accumulated Fault Duty C Ph V	.98	%
494753	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Amps A Ø	120.0	
494754	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
494755	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Amps B Ø	113.0	
494756	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Amps C Ø	108.0	
494757	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
494758	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
494759	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
494760	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
494761	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
494762	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
494763	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
494764	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
494765	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
494766	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
494767	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
494768	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
494769	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Switch Diagram Present/Current	y	
494770	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Panels Dusted?	y	
494771	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Panel Lights OK?	y	
494772	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments		
494773	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
494774	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
494775	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
494776	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
494777	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	General Comments		
494778	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
494779	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
494780	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Operations Counter	130	
494781	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
494782	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Tank Leaks	None	
494783	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Operations A Ø	0	
494784	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Operations B Ø	0	
494785	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Operations C Ø	0	
494786	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Operations Ground	0	
494787	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Follow-up Action Required?	n	
494788	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	General Comments		
494789	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Maintenance Operations	16	
494790	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Operations Counter AF	72	
494791	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Operations Counter AL	260	
494792	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Operations Counter AF	260	
494793	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Maintenance Operations	0	
494794	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	General Comments	A Phase gauge not showing amps	
494795	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Follow-up Action Required?	y	
494796	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Operations Ground	0	
494797	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Tank Leaks	None	
494798	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
494799	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Amps A Ø	129.0	
494800	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
494801	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Accumulated Fault Duty B Ph V	1.98	%
494802	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Accumulated Fault Duty A Ph V	1.98	%
494803	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	9 Month Operations	7	
494804	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Operations C Ø	0	
494805	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Operations B Ø	0	
494806	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Operations A Ø	0	
494807	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
494808	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Vegetation	None	
494809	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
494810	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
494811	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
494812	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
494813	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
494814	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
494815	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
494816	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
494817	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
494818	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
494819	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	9 Month Operations	33	
494820	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
494821	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Amps C Ø	260.0	
494822	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
494823	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
494824	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
494825	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Amps A Ø	0.0	
494826	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
494827	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Amps B Ø	200.0	
494828	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Amps A Ø	0.0	
494829	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Accumulated Fault Duty C Ph AM	11.96	%
494830	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Accumulated Fault Duty B Ph AM	15.95	%
494831	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Accumulated Fault Duty A Ph AM	10.63	%
494832	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	9 Months Operations	0	
494833	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
494834	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
494835	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
494836	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
494837	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
494838	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
494839	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
494840	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
494841	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
494842	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	General Comments		
494843	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
494844	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
494845	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
494846	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
494847	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
494848	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
494849	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
494850	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	120.0	volts
494851	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Regulator As Left Counter	53608	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
494852	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
494853	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
494854	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Tank Leaks	None	
494855	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
494856	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
494857	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	General Comments		
494858	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
494859	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
494860	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
494861	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
494862	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
494863	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
494864	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Vegetation	None	
494865	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
494866	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Operations Counter AF	296	
494867	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Maintenance Operations	0	
494868	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	General Comments		
494869	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Follow-up Action Required?	n	
494870	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Operations Ground	0	
494871	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Operations C Ø	0	
494872	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Operations B Ø	0	
494873	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Operations A Ø	0	
494874	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
494875	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
494876	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
494877	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
494878	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
494879	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
494880	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
494881	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Regulator As Left Counter	66313	
494882	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
494883	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
494884	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
494885	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
494886	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
494887	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
494888	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
494889	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Max Tap Position	10L	
494890	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
494891	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	General Comments		
494892	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
494893	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
494894	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
494895	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Current Tap Position	10L	
494896	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
494897	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
494898	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
494899	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
494900	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
494901	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
494902	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
494903	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
494904	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
494905	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
494906	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
494907	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
494908	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
494909	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
494910	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Amps C Ø	185.0	
494911	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Amps B Ø	175.0	
494912	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Amps A Ø	140.0	
494913	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
494914	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
494915	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
494916	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
494917	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
494918	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
494919	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Clear of Trash?	y	
494920	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
494921	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Operations Counter AL	72	
494922	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Operations This Read Vac	16	
494923	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Operations Ground	0	
494924	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Switching Operations	0	
494925	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Unknown Operations	0	
494926	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
494927	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
494928	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
494929	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC Operations Since Last Insp	132	
494930	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
494931	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC Min Tap Position	3L	
494932	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
494933	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Follow-up Action Required?	n	
494934	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	General Comments		
494935	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
494936	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
494937	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
494938	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
494939	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC Current Tap Position	3L	
494940	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
494941	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
494942	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
494943	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC As Left Counter	292703	
494944	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC As Found Counter	292694	
494945	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	General Comments		
494946	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	General Comments		
494947	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
494948	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	Follow-up Action Required?	n	
494949	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
494950	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Unknown Operations	0	
494951	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Switching Operations	0	
494952	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Maintenance Operations	0	
494953	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Operations Counter AF	227	
494954	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Operations Counter AL	229	
494955	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Operations This Read Vac	2	
494956	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
494957	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Tank Leaks	None	
494958	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
494959	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
494960	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Operations This Read AM	0	
494961	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Operations Counter AL	296	
494962	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
494963	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
494964	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
494965	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Clear of Trash?	y	
494966	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
494967	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
494968	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
494969	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
494970	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
494971	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
494972	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	General Comments		
494973	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
494974	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
494975	4/8/2019 8:06	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
494976	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Switching Operations	2	
494977	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Unknown Operations	0	
494978	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
494979	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Control Handle "Red Flagged"?	n	If Bkr is Closed
494980	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
494981	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
494982	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Vegetation	None	
494983	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	9 Months Operations	1	
494984	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
494985	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
494986	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	General Comments	VC change with no target drop	
494987	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Follow-up Action Required?	y	
494988	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Operations Ground	0	
494989	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Operations C Ø	0	
494990	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Switching Operations	0	
494991	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Unknown Operations	0	
494992	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Accumulated Fault Duty A Ph V	.41	%
494993	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	9 Month Operations	4	
494994	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Operations B Ø	0	
494995	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
494996	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
494997	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	General Comments		
494998	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
494999	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	9 Month Operations	2	
495000	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
495001	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
495002	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
495003	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Accumulated Fault Duty C Ph V	.78	%
495004	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Vegetation	None	
495005	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
495006	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Unknown Operations	0	
495007	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
495008	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
495009	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
495010	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
495011	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
495012	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
495013	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Foundation Condition	Good	
495014	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Operations A Ø	0	
495015	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
495016	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Amps A Ø	26.0	
495017	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Amps B Ø	24.0	
495018	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Follow-up Action Required?	n	
495019	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
495020	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
495021	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
495022	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.48	%
495023	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.48	%
495024	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Follow-up Action Required?	n	
495025	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Foundation Condition	Good	
495026	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	General Comments		
495027	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	General Comments		
495028	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.48	%
495029	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	320.0	
495030	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	320.0	
495031	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	320.0	
495032	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
495033	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	General Comments		
495034	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Readings	General Comments		
495035	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Grounds in Place?	y	
495036	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
495037	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
495038	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
495039	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
495040	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
495041	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
495042	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
495043	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Readings	Maintenance Operations	0	
495044	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
495045	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Readings	Operations Counter AF	120	
495046	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Grounds in Place?	y	
495047	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Heaters (All) Functioning?	y	
495048	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Maintenance Operations	0	
495049	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Moisture and Leak Free?	y	
495050	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Operations Counter AF	620	
495051	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	9 Months Operations	25	
495052	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Accumulated Fault Duty A Ph AM	3.99	%
495053	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Amps C Ø	360.0	
495054	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Bushing Condition	Good	
495055	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Bushings Connection/Risers	Good	
495056	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
495057	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
495058	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
495059	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Cabinet Paint Condition	Good	
495060	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Equipment Properly Labeled?	y	
495061	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
495062	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
495063	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
495064	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Operations A Ø	0	
495065	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Operations B Ø	0	
495066	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Operations C Ø	0	
495067	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
495068	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Operations Ground	0	
495069	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Unknown Operations	0	
495070	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Accumulated Fault Duty B Ph AM	3.99	%
495071	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Accumulated Fault Duty C Ph AM	3.99	%
495072	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Amps A Ø	440.0	
495073	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Amps B Ø	540.0	
495074	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Amps C Ø	420.0	
495075	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
495076	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
495077	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
495078	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Unknown Operations	0	
495079	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Switching Operations	0	
495080	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Unknown Operations	0	
495081	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Switching Operations	3	
495082	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Operations This Read Vac	3	
495083	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Operations Counter AL	176	
495084	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Operations Counter AF	176	
495085	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Maintenance Operations	0	
495086	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	General Comments		
495087	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Follow-up Action Required?	n	
495088	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Operations Ground	0	
495089	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Operations C Ø	0	
495090	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
495091	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Operations B Ø	0	
495092	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Operations A Ø	0	
495093	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
495094	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Operations This Read AM	0	
495095	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Operations Counter AL	309	
495096	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
495097	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
495098	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Operations A Ø	0	
495099	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Operations B Ø	0	
495100	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Operations C Ø	0	
495101	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Operations Ground	0	
495102	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Follow-up Action Required?	y	
495103	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	General Comments	VC change with no target drop	
495104	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Maintenance Operations	0	
495105	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Operations Counter AF	229	
495106	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
495107	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Amps C Ø	60.0	
495108	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Amps B Ø	60.0	
495109	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Amps A Ø	60.0	
495110	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Accumulated Fault Duty C Ph V	.41	%
495111	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Accumulated Fault Duty B Ph V	.41	%
495112	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Operations Counter AF	309	
495113	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Operations Counter AL	229	
495114	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Operations This Read AM	0	
495115	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Maintenance Operations	0	
495116	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
495117	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Unknown Operations	0	
495118	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Switching Operations	1	
495119	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Operations This Read Vac	4	
495120	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Operations Counter AL	202	
495121	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Operations Counter AF	202	
495122	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Maintenance Operations	0	
495123	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	General Comments		
495124	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Follow-up Action Required?	n	
495125	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Operations Ground	0	
495126	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Operations C Ø	0	
495127	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Operations B Ø	0	
495128	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Operations A Ø	3	
495129	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
495130	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
495131	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Adjusted Amps A Phase V	42.45	
495132	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Amps C Ø	211.0	
495133	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
495134	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
495135	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
495136	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
495137	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
495138	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Current Tap Position	9L	
495139	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
495140	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
495141	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
495142	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Amps B Ø	212.0	
495143	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Amps A Ø	226.0	
495144	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
495145	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Accumulated Fault Duty B Ph V	2.11	%
495146	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Accumulated Fault Duty A Ph V	7.38	%
495147	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	9 Month Operations	12	
495148	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Unknown Operations	0	
495149	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Switching Operations	0	
495150	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Operations This Read Vac	0	
495151	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Operations Counter AL	178	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
495152	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Operations Counter AF	178	
495153	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Maintenance Operations	0	
495154	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	General Comments		
495155	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Follow-up Action Required?	n	
495156	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Operations Ground	0	
495157	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Operations C Ø	0	
495158	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Operations B Ø	0	
495159	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Operations A Ø	0	
495160	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
495161	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
495162	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
495163	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Amps C Ø	118.0	
495164	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
495165	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Amps B Ø	124.0	
495166	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	General Comments		
495167	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
495168	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
495169	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
495170	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
495171	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
495172	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
495173	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
495174	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	120.0	volts
495175	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Regulator As Left Counter	47671	
495176	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
495177	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
495178	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Unknown Operations	0	
495179	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Switching Operations	0	
495180	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Operations This Read AM	0	
495181	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Readings	Operations Counter AL	120	
495182	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
495183	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
495184	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
495185	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	600	
495186	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	600	
495187	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
495188	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
495189	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
495190	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Amps C Ø	380.0	
495191	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Amps B Ø	300.0	
495192	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Operations Counter AL	620	
495193	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Amps C Ø	21.0	
495194	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Bushing Condition	Good	
495195	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Bushings Connection/Risers	Good	
495196	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
495197	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
495198	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
495199	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Cabinet Paint Condition	Good	
495200	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Equipment Properly Labeled?	y	
495201	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Amps A Ø	310.0	
495202	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Accumulated Fault Duty C Ph AM	51.83	%
495203	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Accumulated Fault Duty B Ph AM	21.26	%
495204	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Accumulated Fault Duty A Ph AM	21.26	%
495205	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
495206	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
495207	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
495208	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Operations A Ø	0	
495209	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Operations B Ø	0	
495210	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	9 Months Operations	24	
495211	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Operations C Ø	0	
495212	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Operations Ground	0	
495213	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Follow-up Action Required?	n	
495214	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Follow-up Action Required?	n	
495215	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Foundation Condition	Good	
495216	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	General Comments		
495217	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	General Comments		
495218	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
495219	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	General Comments		
495220	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
495221	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Readings	Operations This Read Vac	0	
495222	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
495223	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Grounds in Place?	y	
495224	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Maintenance Operations	0	
495225	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Moisture and Leak Free?	y	
495226	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Operations Counter AF	176	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
495227	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Operations Counter AL	176	
495228	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Operations This Read Vac	0	
495229	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Switching Operations	0	
495230	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
495231	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Switching Operations	0	
495232	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Tank Paint Condition	Good	
495233	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Unknown Operations	0	
495234	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
495235	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
495236	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
495237	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Tank Paint Condition	Good	
495238	4/4/2019 10:28	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Unknown Operations	0	
495239	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Operations This Read Vac	0	
495240	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
495241	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Switching Operations	0	
495242	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Tank Paint Condition	Good	
495243	4/5/2019 9:58	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Unknown Operations	0	
495244	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
495245	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
495246	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
495247	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Operations Ground	0	
495248	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Operations C Ø	0	
495249	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Operations B Ø	0	
495250	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
495251	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
495252	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Operations A Ø	0	
495253	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
495254	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
495255	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
495256	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Amps C Ø	240.0	
495257	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Amps B Ø	240.0	
495258	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Amps A Ø	240.0	
495259	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Accumulated Fault Duty C Ph V	2.04	%
495260	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Accumulated Fault Duty B Ph V	1.7	%
495261	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Accumulated Fault Duty A Ph V	1.7	%
495262	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	9 Month Operations	2	
495263	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
495264	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
495265	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
495266	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
495267	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
495268	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
495269	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
495270	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
495271	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Foundation Condition	Good	
495272	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
495273	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	General Comments		
495274	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
495275	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
495276	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
495277	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
495278	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
495279	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
495280	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
495281	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
495282	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ok	
495283	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
495284	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	143	
495285	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	143	
495286	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
495287	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
495288	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
495289	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
495290	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
495291	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
495292	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
495293	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
495294	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
495295	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
495296	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
495297	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
495298	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
495299	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
495300	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Reading	.3090	
495301	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
495302	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Readings	Switching Operations	4	
495303	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Tank Paint Condition	Good	
495304	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Readings	Unknown Operations	0	
495305	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
495306	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
495307	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	283.0	
495308	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	284.0	
495309	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	275.0	
495310	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
495311	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
495312	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
495313	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
495314	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
495315	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
495316	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
495317	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
495318	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ok	
495319	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
495320	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	745	
495321	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	745	
495322	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
495323	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
495324	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
495325	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
495326	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
495327	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	LTC Totalizer Reading	988.80	kw
495328	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
495329	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Equipment Properly Labeled?	y	
495330	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Cabinet Paint Condition	Good	
495331	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
495332	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
495333	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
495334	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Switching Operations	1	
495335	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Operations This Read SF6	1	
495336	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Operations Counter AL	64	
495337	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Operations Counter AF	64	
495338	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Num Operations Last 9 Months	2	
495339	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Maintenance Operations	0	
495340	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	General Comments		
495341	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Follow-up Action Required?	n	
495342	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Fault Operations	0	
495343	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
495344	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	55	°C
495345	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	35	°C
495346	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
495347	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Unknown Operations	0	
495348	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Switching Operations	0	
495349	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Operations This Read Vac	1	
495350	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Operations Counter AL	119	
495351	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Operations Counter AF	119	
495352	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Maintenance Operations	1	
495353	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	General Comments		
495354	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Follow-up Action Required?	n	
495355	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Amps A Ø	340.0	
495356	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Accumulated Fault Duty C Ph AM	5.32	%
495357	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
495358	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Operations Ground	0	
495359	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Operations C Ø	0	
495360	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Operations B Ø	0	
495361	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Operations A Ø	0	
495362	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
495363	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
495364	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
495365	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
495366	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Accumulated Fault Duty B Ph AM	13.29	%
495367	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
495368	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Accumulated Fault Duty A Ph AM	15.95	%
495369	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	9 Months Operations	12	
495370	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Amps C Ø	50.0	
495371	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Amps B Ø	50.0	
495372	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Amps A Ø	100.0	
495373	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
495374	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
495375	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
495376	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
495377	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Operations C Ø	0	
495378	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
495379	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
495380	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
495381	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
495382	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Trash Emptied?	n	
495383	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	9 Months Operations	0	
495384	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
495385	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
495386	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Panels Dusted?	y	
495387	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Panel Lights OK?	y	
495388	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
495389	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	General Comments		
495390	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
495391	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
495392	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Floor Swept?	y	
495393	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
495394	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
495395	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
495396	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
495397	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Door Alarms OK?	y	
495398	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
495399	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Operations B Ø	0	
495400	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Operations A Ø	0	
495401	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
495402	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Broom on Site?	y	
495403	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
495404	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
495405	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Unknown Operations	0	
495406	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Switching Operations	0	
495407	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Operations This Read Vac	0	
495408	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Operations Counter AL	160	
495409	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
495410	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
495411	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Operations Counter AL	410	
495412	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
495413	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Operations Counter AF	410	
495414	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
495415	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
495416	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Maintenance Operations	0	
495417	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
495418	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	General Comments		
495419	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Patrol Inspection	General Comments		
495420	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Follow-up Action Required?	n	
495421	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Unknown Operations	0	
495422	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Switching Operations	0	
495423	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Operations This Read AM	0	
495424	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Operations Counter AL	952	
495425	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Operations Counter AF	952	
495426	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Maintenance Operations	0	
495427	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	General Comments		
495428	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Follow-up Action Required?	n	
495429	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Operations Ground	0	
495430	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Operations C Ø	0	
495431	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Operations B Ø	0	
495432	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Operations A Ø	0	
495433	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
495434	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
495435	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
495436	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
495437	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Bushings Connection/Risers	Good	
495438	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Bushing Condition	Good	
495439	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Amps C Ø	.6	
495440	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Amps B Ø	.5	
495441	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Amps A Ø	.7	
495442	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Accumulated Fault Duty C Ph V	.84	%
495443	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Accumulated Fault Duty B Ph V	.63	%
495444	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Accumulated Fault Duty A Ph V	.63	%
495445	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	9 Month Operations	3	
495446	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
495447	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
495448	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
495449	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
495450	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
495451	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
495452	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
495453	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
495454	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	106	
495455	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	106	
495456	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
495457	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
495458	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
495459	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
495460	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
495461	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
495462	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Amps C Ø	310.0	
495463	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Amps B Ø	330.0	
495464	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
495465	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Tank Leaks	None	
495466	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
495467	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
495468	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
495469	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Unknown Operations	0	
495470	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Tank Paint Condition	Good	
495471	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Switching Operations	0	
495472	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
495473	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Operations This Read Vac	0	
495474	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Operations Counter AL	147	
495475	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Operations Counter AF	147	
495476	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Moisture and Leak Free?	y	
495477	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Maintenance Operations	0	
495478	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Heaters (All) Functioning?	y	
495479	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Grounds in Place?	y	
495480	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	General Comments		
495481	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	General Comments		
495482	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Operations Counter	253	
495483	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
495484	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
495485	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	23	
495486	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	23	
495487	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Unknown Operations	0	
495488	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Switching Operations	0	
495489	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Operations This Read AM	0	
495490	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Operations Counter AL	31	
495491	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Operations Counter AF	31	
495492	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
495493	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	General Comments		
495494	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Maintenance Operations	0	
495495	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	General Comments		
495496	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Follow-up Action Required?	n	
495497	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
495498	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
495499	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ok	
495500	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
495501	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
495502	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Readings	Amps A Ø	160.0	
495503	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Readings	Amps B Ø	160.0	
495504	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Readings	Amps C Ø	160.0	
495505	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Bushing Condition	Good	
495506	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
495507	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
495508	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
495509	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
495510	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
495511	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
495512	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
495513	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
495514	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
495515	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Amps C Ø	37.0	
495516	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Amps B Ø	33.0	
495517	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
495518	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Operations A Ø	0	
495519	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
495520	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
495521	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
495522	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Amps C Ø	125.0	
495523	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Amps B Ø	140.0	
495524	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Amps A Ø	130.0	
495525	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
495526	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
495527	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
495528	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	9 Months Operations	1	
495529	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	4	
495530	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	4	
495531	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	121	
495532	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	121	
495533	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
495534	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ok	
495535	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
495536	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
495537	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
495538	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
495539	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
495540	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
495541	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
495542	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
495543	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
495544	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
495545	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
495546	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	23.38	%
495547	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	26.3	%
495548	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
495549	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	5.57	%
495550	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	5.88	%
495551	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	4.95	%
495552	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
495553	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
495554	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
495555	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
495556	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
495557	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	3.86	
495558	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
495559	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
495560	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	2	
495561	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
495562	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
495563	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
495564	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	1	
495565	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	99946	
495566	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	99948	
495567	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	3	
495568	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
495569	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
495570	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	9 Month Operations	6	
495571	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
495572	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
495573	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
495574	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
495575	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
495576	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
495577	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
495578	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Unknown Operations	0	
495579	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Switching Operations	0	
495580	4/5/2019 12:47	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Operations This Read AM	0	
495581	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
495582	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
495583	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
495584	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
495585	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Follow-up Action Required?	n	
495586	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Foundation Condition	Good	
495587	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	General Comments		
495588	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	General Comments		
495589	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Grounds in Place?	y	
495590	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Heaters (All) Functioning?	y	
495591	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
495592	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
495593	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
495594	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
495595	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
495596	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
495597	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
495598	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
495599	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Maintenance Operations	0	
495600	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Moisture and Leak Free?	y	
495601	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Operations Counter AF	99774	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
495602	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
495603	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
495604	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
495605	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
495606	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
495607	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
495608	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
495609	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
495610	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
495611	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
495612	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
495613	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
495614	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
495615	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
495616	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
495617	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Foundation Condition	Good	
495618	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Follow-up Action Required?	n	
495619	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Follow-up Action Required?	n	
495620	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Operations Ground	0	
495621	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Operations C Ø	0	
495622	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Operations B Ø	0	
495623	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Operations A Ø	0	
495624	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
495625	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Readings	Operations Counter AL	99778	
495626	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Readings	Operations This Read Vac	6	
495627	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
495628	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Bushings Connection/Risers	Good	
495629	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
495630	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
495631	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
495632	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Cabinet Paint Condition	Good	
495633	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Equipment Properly Labeled?	y	
495634	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Adjusted Amps A Phase V	6.41	
495635	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Adjusted Amps B Phase V	6.41	
495636	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
495637	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Operations A Ø	1	
495638	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Operations B Ø	1	
495639	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Operations C Ø	0	
495640	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
495641	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
495642	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	
495643	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
495644	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
495645	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
495646	4/5/2019 10:07	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
495647	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Switching Operations	1	
495648	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
495649	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
495650	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Operations Counter	89	
495651	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
495652	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
495653	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	General Comments		
495654	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
495655	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
495656	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
495657	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
495658	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
495659	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
495660	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
495661	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
495662	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Amps A Ø	33.0	
495663	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Operations This Read SF6	1	
495664	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Operations Counter AL	69	
495665	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Operations Counter AF	69	
495666	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Num Operations Last 9 Months	1	
495667	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Maintenance Operations	0	
495668	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	General Comments		
495669	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Follow-up Action Required?	n	
495670	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Fault Operations	0	
495671	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Amps C Ø	60.0	
495672	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Amps B Ø	62.0	
495673	4/5/2019 9:38	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Amps A Ø	60.0	
495674	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Operations Ground	0	
495675	4/5/2019 14:14	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Follow-up Action Required?	n	
495676	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	65	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
495677	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
495678	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
495679	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
495680	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
495681	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
495682	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
495683	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	9 Months Operations	9	
495684	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Accumulated Fault Duty A Ph AM	14.45	%
495685	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
495686	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Amps C Ø	210.0	
495687	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Operations This Read AM	0	
495688	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Amps C Ø	180.0	
495689	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Maintenance Operations	0	
495690	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
495691	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
495692	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Operations Counter AF	393	
495693	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
495694	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	9 Months Operations	4	
495695	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Operations Counter AF	160	
495696	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Maintenance Operations	0	
495697	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	General Comments		
495698	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Follow-up Action Required?	n	
495699	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Operations Ground	0	
495700	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Operations C Ø	0	
495701	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Operations B Ø	0	
495702	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Operations Counter AL	393	
495703	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Operations A Ø	0	
495704	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
495705	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
495706	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations A Ø	0	
495707	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Switching Operations	0	
495708	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Unknown Operations	0	
495709	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
495710	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Amps C Ø	400.0	
495711	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Amps B Ø	240.0	
495712	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Amps A Ø	200.0	
495713	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Accumulated Fault Duty C Ph V	5.4	%
495714	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Accumulated Fault Duty B Ph V	5.4	%
495715	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
495716	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	9 Month Operations	10	
495717	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Amps B Ø	400.0	
495718	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Amps A Ø	400.0	
495719	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Operations A Ø	1	
495720	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
495721	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	Breaker needs paint.	
495722	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
495723	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	General Comments		
495724	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	General Comments		
495725	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
495726	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	Follow-up Action Required?	n	
495727	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
495728	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
495729	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
495730	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
495731	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
495732	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Fault Operations	0	
495733	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Follow-up Action Required?	n	
495734	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	General Comments		
495735	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	General Comments		
495736	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Maintenance Operations	2	
495737	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Num Operations Last 9 Months	2	
495738	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Operations Counter AF	62	
495739	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Operations Counter AL	62	
495740	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Operations This Read SF6	2	
495741	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Switching Operations	0	
495742	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Maintenance Operations	0	
495743	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Operations Counter AF	49	
495744	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Operations Counter AL	49	
495745	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	9 Months Operations	0	
495746	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
495747	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
495748	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Unknown Operations	0	
495749	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Switching Operations	4	
495750	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Operations This Read Vac	4	
495751	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Operations Counter AL	486	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
495752	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
495753	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Amps A Ø	140.0	
495754	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Operations Counter AF	486	
495755	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Maintenance Operations	0	
495756	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	General Comments		
495757	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Follow-up Action Required?	n	
495758	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Operations Ground	0	
495759	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Operations C Ø	0	
495760	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Operations B Ø	0	
495761	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Operations A Ø	0	
495762	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
495763	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
495764	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Amps B Ø	160.0	
495765	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Clear of Trash?	y	
495766	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
495767	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
495768	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
495769	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
495770	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
495771	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
495772	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
495773	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
495774	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
495775	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations C Ø	0	
495776	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations Ground	0	
495777	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Operations This Read AM	2	
495778	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Follow-up Action Required?	n	
495779	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	General Comments		
495780	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Maintenance Operations	0	
495781	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Operations Counter AF	1301	
495782	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	General Comments		
495783	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
495784	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
495785	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.39	%
495786	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.91	%
495787	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.91	%
495788	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
495789	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
495790	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
495791	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Follow-up Action Required?	n	
495792	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Operations Ground	0	
495793	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Operations C Ø	0	
495794	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
495795	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
495796	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
495797	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
495798	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
495799	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	General Comments		
495800	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
495801	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Vegetation	None	
495802	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Unknown Operations	0	
495803	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Switching Operations	1	
495804	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Operations B Ø	0	
495805	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
495806	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Operations A Ø	0	
495807	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	102	
495808	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	102	
495809	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
495810	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations B Ø	0	
495811	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	26.3	%
495812	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	5	
495813	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
495814	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	11	
495815	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
495816	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
495817	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	9 Month Operations	6	
495818	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
495819	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	9	
495820	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
495821	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Accumulated Fault Duty B Ph AM	12.05	%
495822	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Accumulated Fault Duty C Ph AM	10.84	%
495823	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
495824	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
495825	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	142	
495826	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	142	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
495827	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
495828	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Amps A Ø	100.0	
495829	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Amps B Ø	100.0	
495830	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Amps C Ø	100.0	
495831	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
495832	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Unknown Operations	0	
495833	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Switching Operations	0	
495834	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Operations This Read AM	0	
495835	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Operations Counter AL	1301	
495836	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
495837	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
495838	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
495839	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
495840	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Amps A Ø	75.0	
495841	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Amps B Ø	75.0	
495842	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Amps C Ø	75.0	
495843	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
495844	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
495845	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
495846	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Ambient Temp	56	°F
495847	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
495848	4/5/2019 11:30	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
495849	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	2.6	%
495850	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Accumulated Fault Duty A Ph V	4.73	%
495851	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Accumulated Fault Duty B Ph V	4.97	%
495852	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Accumulated Fault Duty C Ph V	4.73	%
495853	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
495854	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
495855	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
495856	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
495857	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Amps A Ø	34.0	
495858	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Amps B Ø	38.0	
495859	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
495860	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
495861	4/5/2019 12:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
495862	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
495863	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	9 Months Operations	2	
495864	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	2.6	%
495865	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
495866	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
495867	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Amps C Ø	100.0	
495868	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Amps B Ø	100.0	
495869	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Amps A Ø	180.0	
495870	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Accumulated Fault Duty C Ph AM	1.33	%
495871	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
495872	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	13	
495873	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	9 Months Operations	2	
495874	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
495875	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
495876	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
495877	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
495878	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
495879	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
495880	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
495881	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	General Comments		
495882	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
495883	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Amps C Ø	27.0	
495884	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
495885	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
495886	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
495887	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
495888	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
495889	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Operations A Ø	0	
495890	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
495891	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Operations B Ø	0	
495892	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC Min Tap Position	7L	
495893	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
495894	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
495895	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Maintenance Operations	0	
495896	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	General Comments		
495897	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Operations C Ø	0	
495898	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Operations Ground	0	
495899	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Follow-up Action Required?	n	
495900	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC As Found Counter	48978	
495901	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC As Left Counter	48978	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
495902	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
495903	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
495904	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC Current Tap Position	6L	
495905	4/5/2019 11:45	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC Max Tap Position	4R	
495906	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Operations B Ø	0	
495907	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Amps C Ø	30.0	
495908	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Operations C Ø	0	
495909	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Maintenance Operations	0	
495910	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Operations Counter AF	326	
495911	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Operations Counter AL	326	
495912	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Operations This Read AM	0	
495913	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
495914	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
495915	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
495916	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
495917	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
495918	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
495919	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Amps B Ø	31.0	
495920	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	General Comments	A PHASE IOC	
495921	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Follow-up Action Required?	n	
495922	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Operations Ground	0	
495923	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Unknown Operations	0	
495924	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Switching Operations	0	
495925	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
495926	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	2.6	%
495927	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Amps A Ø	275.0	
495928	4/5/2019 10:36	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
495929	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Operations Counter AF	198	
495930	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Amps B Ø	275.0	
495931	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Amps C Ø	275.0	
495932	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Operations Counter AL	198	
495933	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
495934	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
495935	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	9 Month Operations	8	
495936	4/5/2019 10:13	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Amps A Ø	43.0	
495937	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Operations This Read Vac	0	
495938	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Switching Operations	0	
495939	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Unknown Operations	0	
495940	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	BCH000845	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
495941	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	BCH000845	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
495942	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	BCH000845	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.8	VDC
495943	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
495944	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Negative DC Ground	68.9	VDC
495945	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	General Comments		
495946	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
495947	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Positive DC Ground	67.4	VDC
495948	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
495949	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
495950	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
495951	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
495952	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
495953	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	General Comments		
495954	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
495955	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
495956	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
495957	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	General Comments	Circuit 1530 low side arrestor C phase blown in station and on pole	
495958	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
495959	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
495960	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
495961	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Foundation Condition	Good	
495962	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Ties Intact?	y	
495963	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
495964	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
495965	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	64	°F
495966	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
495967	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Posts Condition OK?	y	
495968	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
495969	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Grounds in Place?	y	
495970	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Gates Aligned?	y	
495971	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
495972	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
495973	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
495974	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
495975	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
495976	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
495977	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
495978	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
495979	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
495980	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
495981	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC As Left Counter	124546	
495982	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC As Found Counter	124535	
495983	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
495984	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC Current Tap Position	8L	
495985	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC Max Tap Position	3R	
495986	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC Min Tap Position	9L	
495987	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC Operations Since Last Insp	82	
495988	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
495989	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
495990	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
495991	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	General Comments		
495992	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	General Comments		
495993	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
495994	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	Follow-up Action Required?	n	
495995	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
495996	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
495997	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
495998	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
495999	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
496000	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	General Comments		
496001	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
496002	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
496003	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
496004	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
496005	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
496006	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
496007	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
496008	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
496009	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	General Comments		
496010	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
496011	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
496012	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
496013	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
496014	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
496015	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
496016	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
496017	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
496018	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
496019	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
496020	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LTCC000016	LTCControl	KE-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
496021	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LTCC000016	LTCControl	KE-TRANS 1	LTC Control Insp	General Comments		
496022	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LTCC000016	LTCControl	KE-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
496023	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
496024	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
496025	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
496026	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
496027	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
496028	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
496029	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
496030	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
496031	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
496032	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
496033	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
496034	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
496035	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
496036	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
496037	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
496038	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
496039	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
496040	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
496041	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
496042	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
496043	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
496044	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
496045	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
496046	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
496047	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
496048	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
496049	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
496050	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
496051	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
496052	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
496053	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
496054	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
496055	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
496056	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
496057	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
496058	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
496059	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	General Comments		
496060	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
496061	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
496062	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5L	
496063	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
496064	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	227	
496065	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
496066	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
496067	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
496068	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
496069	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
496070	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
496071	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
496072	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
496073	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
496074	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
496075	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	General Comments		
496076	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
496077	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
496078	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
496079	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
496080	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
496081	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
496082	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
496083	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
496084	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
496085	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
496086	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
496087	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
496088	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
496089	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Vegetation	None	
496090	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	General Comments		
496091	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
496092	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
496093	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
496094	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drive/Lot Drainage	Good	
496095	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
496096	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Clear of Trash?	y	
496097	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Clear of Obstacles?	y	
496098	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
496099	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
496100	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
496101	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
496102	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
496103	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
496104	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
496105	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
496106	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
496107	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
496108	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC As Left Counter	193629	
496109	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
496110	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
496111	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
496112	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
496113	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
496114	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
496115	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Oil Temp Present	25	°C
496116	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Oil Temp Max	25	°C
496117	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
496118	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
496119	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	LTC Totalizer Reading	4020.48	kw
496120	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
496121	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	General Comments		
496122	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	General Comments		
496123	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
496124	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
496125	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Follow-up Action Required?	n	
496126	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
496127	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
496128	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
496129	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
496130	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
496131	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
496132	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
496133	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
496134	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
496135	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
496136	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
496137	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
496138	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
496139	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
496140	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
496141	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
496142	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
496143	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
496144	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
496145	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
496146	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
496147	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Totalizer Meter Reading	.4188	
496148	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Winding Temp Max	38	°C
496149	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Winding Temp Present	28	°C
496150	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
496151	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
496152	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
496153	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
496154	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Vegetation	None	
496155	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
496156	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
496157	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
496158	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
496159	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
496160	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	Follow-up Action Required?	n	
496161	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
496162	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
496163	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
496164	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
496165	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
496166	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
496167	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
496168	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
496169	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
496170	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
496171	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	General Comments		
496172	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Follow-up Action Required?	n	
496173	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
496174	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
496175	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
496176	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
496177	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
496178	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
496179	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
496180	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
496181	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
496182	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Clear of Trash?	y	
496183	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
496184	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
496185	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
496186	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	45	°C
496187	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
496188	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
496189	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Ambient Temp	54	°F
496190	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
496191	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
496192	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
496193	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
496194	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
496195	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
496196	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
496197	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
496198	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
496199	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
496200	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
496201	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
496202	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Signage Visible, and Proper?	y	
496203	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	General Comments		
496204	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Gate Locks Functioning ?	y	
496205	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
496206	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
496207	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
496208	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
496209	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Totalizer Meter Reading	.7086	
496210	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
496211	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
496212	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
496213	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
496214	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
496215	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
496216	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
496217	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
496218	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
496219	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
496220	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
496221	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
496222	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
496223	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
496224	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
496225	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Oil Temp Present	40	°C
496226	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Oil Temp Max	40	°C
496227	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
496228	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.000	millivolts
496229	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
496230	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	LTC Totalizer Reading	1700.64	kw
496231	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
496232	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
496233	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	General Comments		
496234	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	General Comments		
496235	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
496236	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
496237	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
496238	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
496239	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
496240	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	Follow-up Action Required?	n	
496241	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
496242	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
496243	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	General Comments		
496244	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	General Comments		
496245	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
496246	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
496247	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
496248	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	40	°C
496249	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
496250	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	35	°C
496251	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	Oil Temp Max	47	°C
496252	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	Oil Temp Present	30	°C
496253	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
496254	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
496255	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
496256	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
496257	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
496258	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
496259	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
496260	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
496261	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
496262	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	General Comments		
496263	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
496264	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
496265	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
496266	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
496267	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
496268	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
496269	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
496270	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
496271	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
496272	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Bushings Connection/Risers	Good	
496273	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Bushing Condition	Good	
496274	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	General Comments		
496275	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Follow-up Action Required?	n	
496276	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
496277	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
496278	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
496279	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drive/Lot Drainage	Good	
496280	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
496281	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
496282	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
496283	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Clear of Trash?	y	
496284	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
496285	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
496286	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
496287	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	General Comments		
496288	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
496289	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
496290	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
496291	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
496292	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
496293	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
496294	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	61	
496295	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
496296	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Clear of Obstacles?	y	
496297	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
496298	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	56	°F
496299	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
496300	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
496301	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
496302	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
496303	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
496304	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
496305	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
496306	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
496307	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Moisture and Leak Free?	y	
496308	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Heaters (All) Functioning?	y	
496309	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Grounds in Place?	y	
496310	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	General Comments		
496311	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Foundation Condition	Good	
496312	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Follow-up Action Required?	n	
496313	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Equipment Properly Labeled?	y	
496314	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Cabinet Paint Condition	Good	
496315	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
496316	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
496317	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
496318	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Tank Paint Condition	Good	
496319	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Surge Arrester Condition	Good	
496320	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Steel Structures Rust Free?	y	
496321	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Signage Visible, and Proper?	y	
496322	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
496323	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
496324	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
496325	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
496326	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Operating Linkage OK?	y	
496327	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Live Parts Good Condition?	y	
496328	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Linkage Grounds in Place?	y	
496329	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Yard Lights Working?	y	
496330	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Vegetation	None	
496331	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Insulators In Good Condition?	y	
496332	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Ground Connections Intact?	y	
496333	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
496334	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
496335	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
496336	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	General Comments		
496337	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Free of Audible Arcing?	y	
496338	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Foundation Condition	Good	
496339	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Follow-up Action Required?	n	
496340	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Equipment Properly Labeled?	y	
496341	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Contacts Engaged Properly?	y	
496342	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Conductors and Connectors OK?	y	
496343	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
496344	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	All Identified and Legible?	y	
496345	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
496346	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
496347	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
496348	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
496349	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Tank Leaks	None	
496350	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
496351	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
496352	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
496353	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
496354	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	PF000046	PowerFuse	BR-12KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
496355	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
496356	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	PF000046	PowerFuse	BR-12KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
496357	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	PF000049	PowerFuse	BR-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
496358	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	PF000049	PowerFuse	BR-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
496359	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC Operations Since Last Insp	60	
496360	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
496361	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
496362	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
496363	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC As Left Counter	119251	
496364	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC As Found Counter	119241	
496365	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	General Comments		
496366	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
496367	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	General Comments		
496368	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
496369	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	Follow-up Action Required?	n	
496370	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
496371	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
496372	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
496373	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
496374	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	General Comments		
496375	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
496376	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
496377	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
496378	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
496379	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
496380	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
496381	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
496382	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6L	
496383	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
496384	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
496385	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
496386	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
496387	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
496388	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
496389	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
496390	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Vegetation	None	
496391	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
496392	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
496393	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	General Comments		
496394	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
496395	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
496396	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
496397	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
496398	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
496399	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
496400	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Clear of Trash?	y	
496401	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
496402	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	General Comments		
496403	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Negative DC Ground	.3	VDC
496404	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
496405	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
496406	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Positive DC Ground	.6	VDC
496407	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
496408	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
496409	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
496410	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
496411	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	General Comments		
496412	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
496413	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC As Found Counter	397871	
496414	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Ambient Temp	66	°F
496415	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
496416	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	Oil Temp Max	35	°C
496417	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
496418	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC As Left Counter	397871	
496419	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
496420	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
496421	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Max Tap Position	8L	
496422	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC Operations Since Last Insp	150	
496423	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC Min Tap Position	8L	
496424	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC Max Tap Position	2L	
496425	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11R	
496426	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
496427	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
496428	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	1.5	VDC
496429	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	1.4	VDC
496430	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
496431	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
496432	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
496433	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
496434	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC Current Tap Position	5L	
496435	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
496436	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
496437	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	492	
496438	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	PF000189	PowerFuse	KE-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
496439	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	PF000189	PowerFuse	KE-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
496440	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
496441	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
496442	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
496443	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC As Found Counter	73077	
496444	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC As Left Counter	73088	
496445	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
496446	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC Current Tap Position	Neutral	
496447	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC Max Tap Position	4R	
496448	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
496449	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC Min Tap Position	3L	
496450	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Floor Swept?	y	
496451	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
496452	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
496453	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	56	°F
496454	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
496455	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
496456	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Evidence of Insects	None	
496457	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
496458	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
496459	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
496460	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
496461	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
496462	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
496463	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
496464	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
496465	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
496466	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
496467	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
496468	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
496469	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
496470	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
496471	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
496472	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
496473	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
496474	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	8.2	VDC
496475	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
496476	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Patrol Inspection	Follow-up Action Required?	n	
496477	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Patrol Inspection	General Comments		
496478	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	8.2	VDC
496479	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
496480	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LTCC000016	LTCControl	KE-TRANS 1	LTC Control Insp	All Connections OK?	y	
496481	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
496482	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
496483	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
496484	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
496485	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
496486	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
496487	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Bushing Condition	Good	
496488	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Bushings Connection/Risers	Good	
496489	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LTCC000015	LTCControl	KE-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelND	Position
496490	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LTCC000015	LTCControl	KE-TRANS 2	LTC Control Insp	General Comments		
496491	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LTCC000015	LTCControl	KE-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
496492	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
496493	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
496494	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
496495	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
496496	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LTCC000015	LTCControl	KE-TRANS 2	LTC Control Insp	All Connections OK?	y	
496497	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
496498	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
496499	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
496500	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
496501	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
496502	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
496503	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
496504	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
496505	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
496506	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	6.0	amps
496507	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	General Comments		
496508	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
496509	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
496510	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
496511	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
496512	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
496513	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
496514	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
496515	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Follow-up Action Required?	n	
496516	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Operations Ground	0	
496517	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
496518	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
496519	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Operations C Ø	0	
496520	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Operations B Ø	0	
496521	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Operations A Ø	0	
496522	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
496523	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
496524	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
496525	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	General Comments		
496526	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
496527	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
496528	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
496529	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
496530	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
496531	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
496532	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	General Comments		
496533	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Foundation Condition	Good	
496534	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
496535	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
496536	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
496537	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
496538	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
496539	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
496540	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Panels Dusted?	y	
496541	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
496542	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
496543	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	General Comments		
496544	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
496545	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
496546	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Heaters (All) Functioning?	y	
496547	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Moisture and Leak Free?	y	
496548	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
496549	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Tank Leaks	None	
496550	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
496551	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
496552	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
496553	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
496554	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
496555	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
496556	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
496557	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Bushing Condition	Good	
496558	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
496559	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
496560	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
496561	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
496562	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Patrol Inspection	General Comments		
496563	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Patrol Inspection	Follow-up Action Required?	n	
496564	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Patrol Inspection	Equipment Properly Labeled?	y	
496565	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
496566	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
496567	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Foundation Condition	Good	
496568	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
496569	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
496570	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	General Comments		
496571	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
496572	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
496573	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
496574	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
496575	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
496576	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
496577	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
496578	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
496579	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
496580	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Amps C Ø	90.0	
496581	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Amps B Ø	110.0	
496582	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Amps A Ø	92.0	
496583	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
496584	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
496585	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Tank Paint Condition	Good	
496586	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
496587	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
496588	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
496589	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
496590	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
496591	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
496592	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
496593	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	9 Month Operations	4	
496594	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
496595	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
496596	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Patrol Inspection	Follow-up Action Required?	n	
496597	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
496598	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
496599	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
496600	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
496601	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Cabinet Paint Condition	Good	
496602	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
496603	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
496604	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	General Comments		
496605	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	General Comments		
496606	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
496607	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Patrol Inspection	General Comments		
496608	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	64	°F
496609	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
496610	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
496611	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
496612	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
496613	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC As Found Counter	75378	
496614	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC As Left Counter	75378	
496615	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
496616	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Foundation Condition	Good	
496617	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
496618	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	General Comments		
496619	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
496620	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
496621	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
496622	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
496623	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
496624	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
496625	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
496626	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
496627	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
496628	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
496629	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
496630	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
496631	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	General Comments		
496632	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
496633	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
496634	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
496635	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
496636	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
496637	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Equipment Properly Labeled?	y	
496638	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Follow-up Action Required?	n	
496639	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Foundation Condition	Good	
496640	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	General Comments		
496641	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Grounds in Place?	y	
496642	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
496643	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Amps A Ø	220.0	
496644	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Amps B Ø	220.0	
496645	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Amps C Ø	240.0	
496646	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Bushing Condition	Good	
496647	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
496648	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
496649	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
496650	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
496651	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
496652	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Ambient Temperature	54	°F
496653	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
496654	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
496655	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
496656	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
496657	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
496658	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
496659	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
496660	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
496661	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
496662	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
496663	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
496664	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
496665	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Operations A Ø	0	
496666	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.600	millivolts
496667	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	27.1	VDC
496668	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	27.1	VDC
496669	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
496670	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
496671	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
496672	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Operations B Ø	0	
496673	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Operations C Ø	0	
496674	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Operations Ground	0	
496675	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Follow-up Action Required?	n	
496676	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Follow-up Action Required?	n	
496677	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Foundation Condition	Good	
496678	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	General Comments		
496679	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	General Comments		
496680	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Grounds in Place?	y	
496681	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Maintenance Operations	0	
496682	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
496683	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
496684	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
496685	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
496686	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
496687	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
496688	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
496689	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
496690	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
496691	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	General Comments		
496692	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC As Found Counter	270594	
496693	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC As Left Counter	270601	
496694	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
496695	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC Current Tap Position	7L	
496696	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC Max Tap Position	5L	
496697	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC Min Tap Position	9L	
496698	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
496699	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC Operations Since Last Insp	83	
496700	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
496701	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
496702	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
496703	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
496704	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
496705	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
496706	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
496707	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Tank Paint Condition	Good	
496708	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
496709	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	SF6 Pressure	68	psi
496710	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	SF6 Bushing Condition	Good	
496711	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Moisture and Leak Free?	y	
496712	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Heaters (All) Functioning?	y	
496713	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Grounds in Place?	y	
496714	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	General Comments		
496715	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Gauge(s) Condition	Good	
496716	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Foundation Condition	Good	
496717	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Follow-up Action Required?	n	
496718	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Equipment Properly Labeled?	y	
496719	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Cabinet Paint Condition	Good	
496720	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
496721	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	9 Month Operations	4	
496722	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
496723	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
496724	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	7.0	
496725	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	3.3	
496726	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	3.1	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
496727	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
496728	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
496729	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
496730	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
496731	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
496732	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	General Comments		
496733	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	General Comments		
496734	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
496735	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
496736	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
496737	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
496738	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	Oil Temp Max	30	°C
496739	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	Oil Temp Present	30	°C
496740	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
496741	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
496742	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BCH000310	Charger	421-Battery Charger	Battery Charger Patrol Insp	General Comments		
496743	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BCH000310	Charger	421-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
496744	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BCH000310	Charger	421-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.8	VDC
496745	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Bushing Condition	Good	
496746	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Bushings Connection/Risers	Good	
496747	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
496748	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
496749	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
496750	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
496751	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
496752	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
496753	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
496754	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	General Comments		
496755	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
496756	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Cabinet Paint Condition	Good	
496757	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Equipment Properly Labeled?	y	
496758	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Follow-up Action Required?	n	
496759	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
496760	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
496761	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
496762	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
496763	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
496764	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
496765	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Operations Counter AF	174	
496766	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Operations Counter AL	174	
496767	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Operations This Read Vac	0	
496768	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
496769	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Switching Operations	0	
496770	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Tank Paint Condition	Good	
496771	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Unknown Operations	0	
496772	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
496773	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
496774	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
496775	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
496776	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
496777	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
496778	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Foundation Condition	Good	
496779	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
496780	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
496781	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	General Comments	Only 1 Spare 125 E S&C fuse at station	
496782	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
496783	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
496784	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
496785	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
496786	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
496787	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
496788	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
496789	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
496790	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
496791	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
496792	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
496793	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
496794	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
496795	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
496796	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
496797	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
496798	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
496799	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
496800	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
496801	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
496802	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
496803	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
496804	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
496805	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
496806	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
496807	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Switching Operations	0	
496808	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Operations This Read Vac	0	
496809	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Operations Counter AL	155	
496810	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Operations Counter AF	155	
496811	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Moisture and Leak Free?	y	
496812	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Maintenance Operations	0	
496813	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Grounds in Place?	y	
496814	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	General Comments		
496815	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Foundation Condition	Good	
496816	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Follow-up Action Required?	n	
496817	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Equipment Properly Labeled?	y	
496818	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Cabinet Paint Condition	Good	
496819	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
496820	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	General Comments		
496821	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	General Comments		
496822	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	45	°C
496823	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
496824	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
496825	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
496826	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
496827	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
496828	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
496829	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
496830	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Bushings Connection/Risers	Good	
496831	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Bushing Condition	Good	
496832	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
496833	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
496834	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
496835	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
496836	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
496837	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
496838	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
496839	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
496840	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
496841	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	Oil Temp Present	45	°C
496842	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	Oil Temp Max	65	°C
496843	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
496844	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
496845	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Foundation Condition	Good	
496846	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Follow-up Action Required?	n	
496847	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Follow-up Action Required?	n	
496848	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	9 Month Operations	5	
496849	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
496850	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
496851	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
496852	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
496853	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	12	
496854	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1948	
496855	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1948	
496856	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
496857	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
496858	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
496859	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
496860	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
496861	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	PF000047	PowerFuse	BR-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
496862	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	PF000047	PowerFuse	BR-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
496863	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	PF000048	PowerFuse	BR-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
496864	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	PF000048	PowerFuse	BR-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
496865	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
496866	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
496867	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
496868	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
496869	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
496870	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
496871	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
496872	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
496873	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
496874	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
496875	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
496876	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
496877	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
496878	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
496879	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
496880	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
496881	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
496882	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
496883	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
496884	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	General Comments	all of fence is getting rusty	
496885	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
496886	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
496887	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Unknown Operations	0	
496888	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Tank Paint Condition	Good	
496889	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
496890	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
496891	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
496892	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
496893	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
496894	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Clear of Trash?	y	
496895	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
496896	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
496897	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
496898	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Equipment Properly Labeled?	y	
496899	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Cabinet Paint Condition	Good	
496900	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
496901	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
496902	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Ambient Temp	77	°F
496903	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
496904	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Bushings Connection/Risers	Good	
496905	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Bushing Condition	Good	
496906	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Amps C Ø	27.0	
496907	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Amps B Ø	51.0	
496908	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Amps A Ø	32.0	
496909	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
496910	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
496911	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
496912	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	9 Month Operations	1	
496913	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
496914	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
496915	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	General Comments		
496916	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
496917	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	Follow-up Action Required?	n	
496918	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
496919	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	General Comments		
496920	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
496921	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
496922	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
496923	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
496924	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
496925	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
496926	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Foundation Condition	Good	
496927	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
496928	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
496929	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	General Comments		
496930	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Operations Ground	0	
496931	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
496932	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	General Comments		
496933	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
496934	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
496935	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
496936	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
496937	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
496938	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
496939	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
496940	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
496941	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
496942	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
496943	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
496944	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
496945	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
496946	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
496947	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
496948	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
496949	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Bushing Condition	Good	
496950	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Bushings Connection/Risers	Good	
496951	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
496952	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
496953	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
496954	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Cabinet Paint Condition	Good	
496955	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Equipment Properly Labeled?	y	
496956	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Follow-up Action Required?	n	
496957	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Foundation Condition	Good	
496958	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	General Comments		
496959	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Grounds in Place?	y	
496960	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Heaters (All) Functioning?	y	
496961	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Moisture and Leak Free?	y	
496962	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
496963	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Tank Paint Condition	Good	
496964	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Operations C Ø	0	
496965	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Operations B Ø	0	
496966	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Operations A Ø	0	
496967	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
496968	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
496969	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Vegetation	None	
496970	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
496971	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	General Comments		
496972	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
496973	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
496974	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Tank Leaks	None	
496975	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
496976	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
496977	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Regulator As Left Counter	5564	
496978	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
496979	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
496980	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
496981	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
496982	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
496983	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
496984	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	PF000192	PowerFuse	KE-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
496985	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
496986	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
496987	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
496988	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
496989	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
496990	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
496991	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
496992	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
496993	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
496994	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
496995	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
496996	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	54	°F
496997	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
496998	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
496999	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
497000	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
497001	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
497002	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
497003	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	General Comments		
497004	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
497005	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
497006	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
497007	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
497008	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
497009	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
497010	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
497011	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
497012	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
497013	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
497014	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	General Comments		
497015	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
497016	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
497017	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
497018	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
497019	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
497020	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
497021	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
497022	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
497023	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	PF000191	PowerFuse	KE-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
497024	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
497025	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	General Comments		
497026	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	PF000192	PowerFuse	KE-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
497027	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
497028	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Tank Leaks	None	
497029	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
497030	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
497031	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Regulator As Left Counter	5347	
497032	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
497033	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
497034	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
497035	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
497036	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
497037	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
497038	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
497039	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
497040	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
497041	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
497042	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
497043	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
497044	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	General Comments		
497045	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
497046	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
497047	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
497048	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
497049	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
497050	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
497051	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
497052	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
497053	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
497054	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
497055	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
497056	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
497057	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
497058	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
497059	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	64	
497060	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	64	
497061	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
497062	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
497063	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
497064	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
497065	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
497066	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	General Comments		
497067	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	General Comments		
497068	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
497069	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
497070	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
497071	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
497072	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
497073	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
497074	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
497075	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
497076	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
497077	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
497078	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
497079	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
497080	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
497081	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
497082	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	55	°C
497083	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	55	°C
497084	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	55	°C
497085	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	54	°C
497086	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	55	°C
497087	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
497088	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
497089	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
497090	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
497091	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
497092	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
497093	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
497094	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
497095	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
497096	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
497097	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
497098	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
497099	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.2	VDC
497100	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.4	VDC
497101	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
497102	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
497103	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	846.72	kw
497104	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
497105	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
497106	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	Oil Temp Max	52	°C
497107	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
497108	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
497109	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
497110	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
497111	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
497112	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
497113	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	Oil Temp Present	38	°C
497114	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
497115	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
497116	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
497117	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
497118	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Tank Leaks	None	
497119	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
497120	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
497121	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Regulator As Left Counter	4456	
497122	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
497123	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
497124	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
497125	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
497126	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
497127	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
497128	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
497129	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
497130	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	General Comments		
497131	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
497132	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
497133	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
497134	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
497135	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
497136	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
497137	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
497138	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
497139	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	Oil Temp Max	30	°C
497140	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	Oil Temp Present	30	°C
497141	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
497142	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
497143	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
497144	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
497145	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Tank Paint Condition	Good	
497146	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
497147	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
497148	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
497149	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
497150	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
497151	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
497152	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
497153	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
497154	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
497155	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
497156	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
497157	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
497158	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	General Comments		
497159	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	General Comments		
497160	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
497161	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
497162	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
497163	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Patrol Inspection	General Comments		
497164	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Patrol Inspection	Follow-up Action Required?	n	
497165	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Patrol Inspection	Equipment Properly Labeled?	y	
497166	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
497167	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	Oil Temp Max	30	°C
497168	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	Oil Temp Present	30	°C
497169	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
497170	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
497171	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
497172	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
497173	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
497174	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
497175	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
497176	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
497177	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
497178	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Foundation Condition	Good	
497179	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	General Comments		
497180	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Grounds in Place?	y	
497181	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Heaters (All) Functioning?	y	
497182	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Moisture and Leak Free?	y	
497183	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
497184	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
497185	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
497186	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
497187	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
497188	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
497189	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
497190	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
497191	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
497192	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
497193	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
497194	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
497195	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
497196	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
497197	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
497198	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
497199	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
497200	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
497201	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	General Comments		
497202	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
497203	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
497204	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
497205	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
497206	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
497207	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
497208	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
497209	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
497210	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
497211	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
497212	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
497213	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
497214	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
497215	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	General Comments		
497216	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	General Comments		
497217	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
497218	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
497219	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
497220	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
497221	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
497222	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
497223	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
497224	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
497225	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
497226	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
497227	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
497228	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
497229	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
497230	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
497231	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
497232	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
497233	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
497234	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
497235	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
497236	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
497237	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Clear of Trash?	y	
497238	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
497239	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
497240	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
497241	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
497242	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
497243	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	General Comments		
497244	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
497245	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Vegetation	None	
497246	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
497247	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	53	°C
497248	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
497249	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
497250	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
497251	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	PF000191	PowerFuse	KE-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
497252	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
497253	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
497254	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
497255	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
497256	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
497257	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
497258	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Foundation Condition	Good	
497259	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
497260	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
497261	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
497262	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
497263	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
497264	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2646	
497265	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
497266	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
497267	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
497268	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
497269	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
497270	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
497271	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
497272	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
497273	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Evidence of Insects	None	
497274	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
497275	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	6L	
497276	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
497277	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
497278	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
497279	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
497280	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments	Non working counter	
497281	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
497282	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	3R	
497283	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
497284	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
497285	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
497286	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
497287	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
497288	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
497289	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	14294	
497290	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
497291	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
497292	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
497293	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
497294	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Floor Swept?	y	
497295	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
497296	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
497297	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	General Comments		
497298	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
497299	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Panels Dusted?	y	
497300	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Trash Emptied?	n	
497301	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
497302	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
497303	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
497304	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
497305	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
497306	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
497307	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
497308	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
497309	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
497310	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
497311	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Foundation Condition	Good	
497312	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
497313	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
497314	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	General Comments		
497315	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
497316	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
497317	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
497318	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
497319	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
497320	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
497321	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
497322	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
497323	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
497324	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
497325	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
497326	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
497327	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
497328	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Operations This Read Vac	0	
497329	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
497330	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
497331	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
497332	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	Yes_sprayed	
497333	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
497334	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
497335	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
497336	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
497337	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
497338	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
497339	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC Operations Since Last Insp	925	
497340	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
497341	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
497342	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
497343	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
497344	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
497345	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
497346	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
497347	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
497348	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
497349	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
497350	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
497351	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
497352	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
497353	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Follow-up Action Required?	n	
497354	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
497355	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
497356	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	General Comments		
497357	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	General Comments		
497358	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Unknown Operations	0	
497359	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Tank Paint Condition	Good	
497360	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Switching Operations	0	
497361	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
497362	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Vegetation	None	
497363	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
497364	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
497365	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	General Comments		
497366	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
497367	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Bushing Condition	Good	
497368	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Bushings Connection/Risers	Good	
497369	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
497370	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
497371	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
497372	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Cabinet Paint Condition	Good	
497373	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Equipment Properly Labeled?	y	
497374	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Follow-up Action Required?	n	
497375	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Foundation Condition	Good	
497376	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	General Comments		
497377	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Grounds in Place?	y	
497378	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
497379	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
497380	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
497381	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
497382	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
497383	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Clear of Trash?	y	
497384	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
497385	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
497386	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	Seeping	
497387	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
497388	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
497389	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
497390	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Ambient Temp	56	°F
497391	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
497392	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
497393	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Clear of Trash?	y	
497394	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
497395	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
497396	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
497397	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
497398	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
497399	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
497400	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	General Comments	ok	
497401	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
497402	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Vegetation	None	
497403	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
497404	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
497405	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
497406	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
497407	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
497408	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	50	°C
497409	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	50	°C
497410	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	50	°C
497411	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	50	°C
497412	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	55	°C
497413	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	55	°C
497414	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
497415	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
497416	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
497417	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Heaters (All) Functioning?	y	
497418	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Moisture and Leak Free?	y	
497419	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
497420	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Tank Paint Condition	Good	
497421	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Totalizer Meter Multiplier	2800	
497422	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Totalizer Meter Reading	.0448	
497423	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
497424	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
497425	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
497426	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC Min Tap Position	10L	
497427	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC Max Tap Position	6R	
497428	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC Current Tap Position	3L	
497429	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
497430	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC As Left Counter	249816	
497431	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC As Found Counter	249805	
497432	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	General Comments		
497433	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	General Comments		
497434	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
497435	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	Follow-up Action Required?	n	
497436	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
497437	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
497438	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
497439	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
497440	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
497441	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Clear of Trash?	y	
497442	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
497443	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
497444	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
497445	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
497446	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
497447	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
497448	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	General Comments		
497449	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Exp Boom Needs Corr	
497450	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Vegetation	None	
497451	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
497452	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
497453	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	LTC Totalizer Reading	125.44	kw
497454	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
497455	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
497456	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Oil Temp Max	45	°C
497457	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Oil Temp Present	26	°C
497458	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
497459	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
497460	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Adequate	
497461	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
497462	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
497463	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
497464	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	Oil Temp Max	50	°C
497465	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	Oil Temp Present	50	°C
497466	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
497467	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
497468	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
497469	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
497470	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
497471	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
497472	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
497473	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	Follow-up Action Required?	n	
497474	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
497475	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	General Comments		
497476	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
497477	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC As Found Counter	168567	
497478	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Adequate	
497479	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC As Left Counter	168573	
497480	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
497481	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Winding Temp Present	52	°C
497482	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC Current Tap Position	5L	
497483	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC Max Tap Position	4L	
497484	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC Min Tap Position	10L	
497485	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC Operations Since Last Insp	229	
497486	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
497487	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
497488	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
497489	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Amps A Ø	10.0	
497490	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Amps B Ø	11.0	
497491	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Amps C Ø	13.0	
497492	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
497493	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
497494	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Patrol Inspection	Equipment Properly Labeled?	y	
497495	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Patrol Inspection	Follow-up Action Required?	n	
497496	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Patrol Inspection	General Comments		
497497	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
497498	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
497499	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
497500	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	General Comments		
497501	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
497502	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Operations Counter	299	
497503	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
497504	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
497505	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	All Connections OK?	y	
497506	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
497507	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
497508	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC As Found Counter	193629	
497509	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
497510	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	General Comments		
497511	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
497512	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
497513	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	All Connections OK?	y	
497514	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	Follow-up Action Required?	n	
497515	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	General Comments		
497516	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	LTC Operation Checked?	y	
497517	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	LTC Output Voltage Level	113.6	VAC
497518	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
497519	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	VRR Base Voltage AF	112.0	VAC
497520	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	VRR Base Voltage AL	112.0	VAC
497521	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	VRR Time Delay	45	Seconds
497522	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	All Connections OK?	y	
497523	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	Follow-up Action Required?	n	
497524	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	General Comments		
497525	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	LTC Operation Checked?	y	
497526	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	LTC Output Voltage Level	113.0	VAC
497527	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
497528	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	VRR Base Voltage AF	112.0	VAC
497529	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	VRR Base Voltage AL	112.0	VAC
497530	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	VRR Time Delay	45	Seconds
497531	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	All Connections OK?	y	
497532	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	Follow-up Action Required?	n	
497533	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	General Comments		
497534	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	LTC Operation Checked?	y	
497535	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	LTC Output Voltage Level	113.0	VAC
497536	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
497537	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	VRR Base Voltage AF	112.0	VAC
497538	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	VRR Base Voltage AL	112.0	VAC
497539	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	VRR Time Delay	45	Seconds
497540	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
497541	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
497542	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
497543	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
497544	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
497545	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
497546	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
497547	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
497548	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments		
497549	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
497550	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
497551	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
497552	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
497553	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
497554	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
497555	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
497556	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
497557	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
497558	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
497559	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
497560	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
497561	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
497562	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
497563	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
497564	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
497565	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
497566	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	VRR Time Delay	30	Seconds
497567	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	All Connections OK?	y	
497568	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	Follow-up Action Required?	n	
497569	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	General Comments		
497570	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	LTC Operation Checked?	y	
497571	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	LTC Output Voltage Level	112.7	VAC
497572	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	VRR Base Voltage AF	112.0	VAC
497573	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	VRR Base Voltage AL	112.0	VAC
497574	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	VRR Time Delay	30	Seconds
497575	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
497576	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
497577	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
497578	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
497579	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
497580	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
497581	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
497582	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
497583	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
497584	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
497585	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
497586	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
497587	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
497588	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
497589	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
497590	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
497591	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
497592	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
497593	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
497594	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
497595	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Winding Temp Max	60	°C
497596	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Top Oil Temperature Present	50	°C
497597	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Top Oil Temperature Max	50	°C
497598	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
497599	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
497600	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
497601	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
497602	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
497603	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
497604	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
497605	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
497606	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
497607	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
497608	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
497609	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
497610	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
497611	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
497612	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
497613	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
497614	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	General Comments		
497615	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	General Comments	slight leak coming from radiators	
497616	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
497617	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
497618	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
497619	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
497620	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
497621	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2050	psi
497622	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
497623	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
497624	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
497625	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	General Comments		
497626	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
497627	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
497628	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	Follow-up Action Required?	n	
497629	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	General Comments		
497630	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	LTC Operation Checked?	y	
497631	4/4/2019 10:22	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
497632	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	General Comments		
497633	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	General Comments		
497634	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
497635	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
497636	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Follow-up Action Required?	n	
497637	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
497638	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
497639	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
497640	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
497641	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
497642	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
497643	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
497644	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
497645	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
497646	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
497647	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
497648	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
497649	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
497650	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
497651	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
497652	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
497653	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
497654	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	General Comments		
497655	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	PF000051	PowerFuse	BR-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
497656	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	PF000051	PowerFuse	BR-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
497657	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	BCH000262	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.600	millivolts
497658	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	BCH000262	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
497659	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	BCH000262	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
497660	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	BCH000262	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
497661	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	BCH000262	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
497662	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	BCH000262	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
497663	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	BCH000262	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
497664	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
497665	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
497666	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
497667	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
497668	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
497669	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
497670	4/4/2019 13:14	Distribution	Beargrass Quarterly Inspection	PF000017	PowerFuse	BG-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
497671	4/4/2019 13:14	Distribution	Beargrass Quarterly Inspection	PF000017	PowerFuse	BG-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
497672	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	PF000050	PowerFuse	BR-12KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
497673	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
497674	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
497675	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
497676	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
497677	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
497678	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
497679	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
497680	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
497681	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
497682	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
497683	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
497684	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
497685	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
497686	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
497687	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
497688	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
497689	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
497690	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
497691	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
497692	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
497693	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
497694	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	General Comments		
497695	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
497696	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
497697	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
497698	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
497699	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
497700	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Winding Temp Present	40	°C
497701	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Winding Temp Max	40	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
497702	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
497703	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
497704	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
497705	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
497706	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
497707	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
497708	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
497709	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Oil Temp Present	50	°C
497710	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Oil Temp Max	55	°C
497711	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
497712	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
497713	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
497714	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	60.0	
497715	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
497716	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Vegetation	None	
497717	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
497718	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	General Comments	No Spill KIt	
497719	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
497720	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
497721	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
497722	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
497723	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
497724	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
497725	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Clear of Trash?	y	
497726	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
497727	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
497728	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
497729	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	General Comments		
497730	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
497731	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
497732	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
497733	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
497734	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
497735	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
497736	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	45	°C
497737	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	65	°C
497738	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	45	°C
497739	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	65	°C
497740	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	45	°C
497741	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
497742	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
497743	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
497744	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
497745	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
497746	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
497747	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
497748	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
497749	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
497750	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
497751	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
497752	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
497753	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
497754	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	General Comments		
497755	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	PF000050	PowerFuse	BR-12KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
497756	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Operations Counter AL	183	
497757	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Operations Counter AF	183	
497758	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Moisture and Leak Free?	y	
497759	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Maintenance Operations	0	
497760	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Grounds in Place?	y	
497761	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	General Comments		
497762	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	General Comments		
497763	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Foundation Condition	Good	
497764	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Follow-up Action Required?	n	
497765	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Follow-up Action Required?	n	
497766	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Operations Ground	0	
497767	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Operations C Ø	0	
497768	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Operations B Ø	0	
497769	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Operations A Ø	0	
497770	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
497771	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
497772	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
497773	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Equipment Properly Labeled?	y	
497774	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
497775	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
497776	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
497777	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
497778	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
497779	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
497780	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
497781	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Cabinet Paint Condition	Good	
497782	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
497783	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
497784	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
497785	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Bushings Connection/Risers	Good	
497786	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Bushing Condition	Good	
497787	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Amps C Ø	180.0	
497788	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Amps B Ø	180.0	
497789	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Amps A Ø	180.0	
497790	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Tank Paint Condition	Good	
497791	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
497792	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Moisture and Leak Free?	y	
497793	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Heaters (All) Functioning?	y	
497794	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Grounds in Place?	y	
497795	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	60.0	
497796	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	100.0	
497797	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.3	VDC
497798	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.3	VDC
497799	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
497800	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
497801	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
497802	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
497803	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
497804	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	Oil Temp Max	58	°C
497805	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	Oil Temp Present	36	°C
497806	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
497807	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
497808	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
497809	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
497810	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
497811	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Unknown Operations	0	
497812	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Tank Paint Condition	Good	
497813	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	46	°C
497814	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	46	°C
497815	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
497816	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
497817	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Switching Operations	0	
497818	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
497819	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Operations This Read Vac	0	
497820	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Operations Counter AL	225	
497821	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	46	°C
497822	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	46	°C
497823	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	4646	°C
497824	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	46	°C
497825	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
497826	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
497827	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
497828	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
497829	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
497830	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
497831	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
497832	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
497833	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Operations Counter AF	225	
497834	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
497835	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Maintenance Operations	0	
497836	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
497837	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Patrol Inspection	Follow-up Action Required?	n	
497838	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
497839	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
497840	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
497841	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
497842	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
497843	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
497844	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
497845	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
497846	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
497847	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
497848	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
497849	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
497850	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
497851	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
497852	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
497853	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	General Comments		
497854	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
497855	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
497856	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
497857	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
497858	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
497859	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
497860	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
497861	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
497862	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
497863	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
497864	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
497865	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
497866	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
497867	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
497868	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
497869	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
497870	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
497871	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
497872	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	General Comments		
497873	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
497874	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
497875	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	BCH000448	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.6	VDC
497876	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	BCH000448	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
497877	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	BCH000448	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
497878	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
497879	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
497880	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
497881	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
497882	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
497883	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
497884	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
497885	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
497886	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
497887	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	Oil Temp Max	57	°C
497888	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	Oil Temp Present	38	°C
497889	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
497890	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
497891	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
497892	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
497893	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
497894	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
497895	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
497896	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	1.2	VDC
497897	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	1.4	VDC
497898	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
497899	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
497900	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
497901	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
497902	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
497903	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
497904	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	Oil Temp Present	46	°C
497905	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	Oil Temp Max	46	°C
497906	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	500	psi
497907	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
497908	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
497909	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
497910	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
497911	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
497912	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	72	°F
497913	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
497914	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
497915	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
497916	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	General Comments		
497917	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
497918	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
497919	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	General Comments		
497920	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
497921	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Patrol Inspection	General Comments		
497922	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	General Comments		
497923	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	General Comments		
497924	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	
497925	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Follow-up Action Required?	n	
497926	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
497927	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Operations Ground	0	
497928	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Operations C Ø	0	
497929	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Operations B Ø	0	
497930	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Operations A Ø	0	
497931	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
497932	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
497933	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
497934	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
497935	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
497936	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
497937	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
497938	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
497939	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
497940	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Bushing Condition	Good	
497941	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Amps C Ø	0.0	
497942	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Amps B Ø	0.0	
497943	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Amps A Ø	0.0	
497944	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
497945	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
497946	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
497947	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	9 Month Operations	10	
497948	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
497949	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
497950	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
497951	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
497952	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
497953	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
497954	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
497955	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
497956	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
497957	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
497958	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	General Comments		
497959	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
497960	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
497961	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
497962	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
497963	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
497964	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
497965	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
497966	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
497967	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Moisture and Leak Free?	y	
497968	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Maintenance Operations	0	
497969	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Heaters (All) Functioning?	y	
497970	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Grounds in Place?	y	
497971	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	General Comments		
497972	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	General Comments		
497973	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Foundation Condition	Good	
497974	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Follow-up Action Required?	n	
497975	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Follow-up Action Required?	n	
497976	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Operations Ground	0	
497977	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Operations C Ø	0	
497978	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Operations B Ø	0	
497979	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Operations A Ø	0	
497980	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
497981	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
497982	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
497983	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
497984	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
497985	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
497986	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
497987	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
497988	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
497989	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
497990	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
497991	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
497992	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
497993	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
497994	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Equipment Properly Labeled?	y	
497995	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Cabinet Paint Condition	Good	
497996	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
497997	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
497998	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
497999	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
498000	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
498001	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
498002	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
498003	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
498004	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
498005	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
498006	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Bushings Connection/Risers	Good	
498007	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Bushing Condition	Good	
498008	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Amps C Ø	180.0	
498009	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Amps B Ø	140.0	
498010	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Amps A Ø	160.0	
498011	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
498012	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
498013	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
498014	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	9 Month Operations	3	
498015	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
498016	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
498017	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
498018	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
498019	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Tank Leaks	None	
498020	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
498021	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
498022	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Regulator As Left Counter	41778	
498023	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
498024	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
498025	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
498026	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
498027	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
498028	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
498029	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Tank Leaks	None	
498030	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
498031	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Regulator As Left Counter	41142	
498032	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.1	volts
498033	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
498034	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
498035	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
498036	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
498037	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
498038	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
498039	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
498040	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	General Comments		
498041	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
498042	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
498043	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
498044	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
498045	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
498046	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
498047	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
498048	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
498049	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
498050	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
498051	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
498052	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
498053	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Min Tap Position	7L	
498054	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Max Tap Position	3L	
498055	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
498056	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	General Comments		
498057	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
498058	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
498059	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
498060	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
498061	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Current Tap Position	4L	
498062	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
498063	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
498064	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
498065	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
498066	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
498067	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Unknown Operations	0	
498068	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Tank Paint Condition	Good	
498069	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Switching Operations	0	
498070	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Operations This Read Vac	0	
498071	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Operations Counter AL	20	
498072	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Operations Counter AF	20	
498073	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
498074	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
498075	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
498076	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
498077	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
498078	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
498079	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
498080	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	General Comments		
498081	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
498082	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
498083	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
498084	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
498085	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
498086	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
498087	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
498088	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
498089	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
498090	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
498091	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
498092	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
498093	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
498094	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
498095	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Bushing Condition	Good	
498096	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Bushings Connection/Risers	Good	
498097	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
498098	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
498099	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
498100	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Cabinet Paint Condition	Good	
498101	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Equipment Properly Labeled?	y	
498102	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Follow-up Action Required?	n	
498103	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Foundation Condition	Good	
498104	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	General Comments		
498105	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Grounds in Place?	y	
498106	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Heaters (All) Functioning?	y	
498107	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Moisture and Leak Free?	y	
498108	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
498109	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Tank Paint Condition	Good	
498110	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
498111	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
498112	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Foundation Condition	Good	
498113	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
498114	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	General Comments		
498115	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
498116	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
498117	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
498118	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
498119	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
498120	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
498121	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
498122	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
498123	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
498124	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
498125	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
498126	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
498127	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1737.60	kw
498128	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
498129	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LTCC000475	LTCControl	BR-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
498130	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
498131	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
498132	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
498133	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LTCC000475	LTCControl	BR-TRANS 3	LTC Control Insp	General Comments		
498134	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LTCC000475	LTCControl	BR-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
498135	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Bushing Condition	Good	
498136	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Bushings Connection/Risers	Good	
498137	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
498138	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
498139	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
498140	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Cabinet Paint Condition	Good	
498141	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Equipment Properly Labeled?	y	
498142	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Follow-up Action Required?	n	
498143	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Foundation Condition	Good	
498144	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	General Comments		
498145	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Grounds in Place?	y	
498146	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Unknown Operations	0	
498147	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
498148	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
498149	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	37.50	
498150	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
498151	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Oil Temp Max	45	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
498152	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
498153	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
498154	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
498155	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Tank Leaks	None	
498156	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
498157	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
498158	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
498159	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
498160	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Heaters (All) Functioning?	y	
498161	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Moisture and Leak Free?	y	
498162	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
498163	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Tank Paint Condition	Good	
498164	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
498165	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
498166	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
498167	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
498168	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
498169	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
498170	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
498171	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
498172	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
498173	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
498174	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
498175	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
498176	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
498177	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
498178	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
498179	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
498180	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
498181	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
498182	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Tank Leaks	None	
498183	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
498184	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
498185	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Regulator As Left Counter	44206	
498186	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
498187	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
498188	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
498189	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
498190	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
498191	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Min Tap Position	5L	
498192	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
498193	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
498194	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	General Comments		
498195	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
498196	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
498197	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
498198	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
498199	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
498200	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
498201	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
498202	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
498203	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
498204	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
498205	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
498206	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
498207	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
498208	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
498209	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
498210	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
498211	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
498212	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
498213	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
498214	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
498215	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
498216	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
498217	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
498218	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
498219	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	General Comments		
498220	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
498221	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
498222	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
498223	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
498224	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
498225	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
498226	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
498227	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Min Tap Position	7L	
498228	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Max Tap Position	3L	
498229	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
498230	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
498231	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
498232	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
498233	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	General Comments		
498234	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
498235	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
498236	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
498237	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
498238	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Current Tap Position	5L	
498239	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
498240	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
498241	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
498242	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
498243	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
498244	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
498245	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
498246	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
498247	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
498248	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
498249	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
498250	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
498251	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	General Comments		
498252	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
498253	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
498254	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
498255	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	General Comments		
498256	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
498257	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	1252.80	kw
498258	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
498259	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
498260	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
498261	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
498262	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
498263	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
498264	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
498265	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
498266	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
498267	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
498268	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Max	58	°C
498269	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Present	25	°C
498270	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
498271	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
498272	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Adequate	
498273	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
498274	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
498275	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
498276	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
498277	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
498278	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
498279	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Amps A Ø	60.0	
498280	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Amps B Ø	60.0	
498281	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Amps C Ø	60.0	
498282	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Bushing Condition	Good	
498283	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Bushings Connection/Risers	Good	
498284	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
498285	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
498286	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	9 Month Operations	5	
498287	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
498288	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
498289	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
498290	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Cabinet Paint Condition	Good	
498291	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Equipment Properly Labeled?	y	
498292	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
498293	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
498294	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
498295	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Operations A Ø	0	
498296	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Operations B Ø	0	
498297	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Operations C Ø	0	
498298	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
498299	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
498300	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Follow-up Action Required?	n	
498301	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
498302	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	General Comments		
498303	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Grounds in Place?	y	
498304	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
498305	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Moisture and Leak Free?	y	
498306	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
498307	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Tank Paint Condition	Good	
498308	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Operations Ground	0	
498309	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Follow-up Action Required?	n	
498310	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Follow-up Action Required?	n	
498311	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Foundation Condition	Good	
498312	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	General Comments		
498313	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
498314	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
498315	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
498316	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	Yes_sprayed	
498317	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Amps A Ø	50.0	
498318	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Amps B Ø	45.0	
498319	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Amps C Ø	45.0	
498320	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
498321	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
498322	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
498323	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
498324	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
498325	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
498326	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
498327	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
498328	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
498329	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
498330	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
498331	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
498332	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
498333	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
498334	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
498335	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
498336	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
498337	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
498338	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
498339	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
498340	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	General Comments		
498341	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
498342	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
498343	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Operations Counter	6	
498344	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
498345	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Tank Leaks	None	
498346	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
498347	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	All Connections OK?	y	
498348	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	Follow-up Action Required?	n	
498349	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	General Comments		
498350	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	LTC Operation Checked?	n	
498351	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
498352	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
498353	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
498354	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
498355	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	VRR Time Delay	60	Seconds
498356	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
498357	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Tank Leaks	None	
498358	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
498359	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
498360	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Follow-up Action Required?	n	
498361	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Follow-up Action Required?	n	
498362	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Operations Ground	0	
498363	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Operations C Ø	0	
498364	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Operations B Ø	0	
498365	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Operations A Ø	0	
498366	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
498367	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
498368	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
498369	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
498370	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
498371	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
498372	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
498373	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
498374	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
498375	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Equipment Properly Labeled?	y	
498376	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
498377	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
498378	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
498379	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
498380	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
498381	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Amps C Ø	60.0	
498382	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Amps B Ø	80.0	
498383	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
498384	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Amps A Ø	70.0	
498385	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
498386	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
498387	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
498388	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
498389	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
498390	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
498391	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
498392	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
498393	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
498394	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
498395	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
498396	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
498397	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
498398	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	General Comments		
498399	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
498400	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
498401	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
498402	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	Oil Temp Max	35	°C
498403	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
498404	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
498405	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
498406	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
498407	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
498408	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
498409	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	9 Month Operations	7	
498410	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Bushing Condition	Good	
498411	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
498412	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
498413	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
498414	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
498415	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
498416	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
498417	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Bushings Connection/Risers	Good	
498418	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
498419	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
498420	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
498421	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Maintenance Operations	0	
498422	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Operations Counter AF	556	
498423	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Operations Counter AL	556	
498424	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Operations This Read AM	0	
498425	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Switching Operations	0	
498426	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Unknown Operations	0	
498427	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Bushings Connection/Risers	Good	
498428	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Bushing Condition	Good	
498429	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Amps C Ø	59.0	
498430	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Amps B Ø	58.0	
498431	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Amps A Ø	60.0	
498432	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
498433	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	9 Month Operations	6	
498434	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
498435	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
498436	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
498437	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
498438	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
498439	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
498440	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
498441	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	General Comments		
498442	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
498443	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
498444	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
498445	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
498446	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
498447	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
498448	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
498449	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
498450	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
498451	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
498452	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
498453	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	General Comments		
498454	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
498455	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
498456	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Operations Counter	945	
498457	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
498458	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
498459	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
498460	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
498461	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Grounds in Place?	y	
498462	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Maintenance Operations	0	
498463	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Moisture and Leak Free?	y	
498464	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Operations Counter AF	318	
498465	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Tank Leaks	None	
498466	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
498467	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Regulator As Left Counter	474917	
498468	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
498469	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
498470	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Operations Counter AL	318	
498471	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Operations This Read Vac	0	
498472	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
498473	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Switching Operations	0	
498474	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Tank Paint Condition	Good	
498475	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Unknown Operations	0	
498476	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
498477	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
498478	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
498479	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
498480	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
498481	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
498482	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
498483	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
498484	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
498485	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	General Comments		
498486	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	General Comments		
498487	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
498488	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	General Comments		
498489	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
498490	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
498491	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
498492	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
498493	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
498494	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
498495	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
498496	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
498497	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
498498	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
498499	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
498500	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
498501	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
498502	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
498503	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
498504	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
498505	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
498506	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
498507	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
498508	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
498509	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
498510	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
498511	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Tank Leaks	None	
498512	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
498513	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
498514	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Regulator As Left Counter	31440	
498515	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
498516	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
498517	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Regulator As Left Counter	88727	
498518	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
498519	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
498520	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
498521	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
498522	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
498523	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
498524	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	0985	NonLTC	351-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
498525	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	0985	NonLTC	351-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
498526	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	0985	NonLTC	351-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
498527	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
498528	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	269.28	kw
498529	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
498530	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
498531	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
498532	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Readings	General Comments		
498533	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	General Comments		
498534	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
498535	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
498536	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
498537	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
498538	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	32.0	
498539	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	37.4	
498540	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	25.9	
498541	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
498542	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
498543	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
498544	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
498545	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
498546	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
498547	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
498548	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	296	
498549	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC Min Tap Position	15L	
498550	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC Max Tap Position	9L	
498551	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC Current Tap Position	12L	
498552	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
498553	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
498554	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
498555	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
498556	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC As Left Counter	174854	
498557	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC As Found Counter	174854	
498558	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
498559	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	General Comments		
498560	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
498561	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
498562	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
498563	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
498564	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
498565	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
498566	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
498567	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
498568	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
498569	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
498570	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC Operations Since Last Insp	167	
498571	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
498572	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC Min Tap Position	10L	
498573	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC Max Tap Position	8L	
498574	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC Current Tap Position	8L	
498575	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
498576	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC As Left Counter	140295	
498577	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC As Found Counter	140292	
498578	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
498579	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	General Comments		
498580	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	General Comments		
498581	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
498582	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	Follow-up Action Required?	n	
498583	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
498584	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	General Comments		
498585	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
498586	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
498587	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
498588	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
498589	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
498590	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
498591	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
498592	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
498593	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
498594	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
498595	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
498596	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
498597	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
498598	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
498599	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
498600	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
498601	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
498602	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6876	
498603	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
498604	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
498605	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
498606	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
498607	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
498608	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
498609	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
498610	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
498611	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
498612	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Oil Temp Max	65	°C
498613	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
498614	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
498615	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2475.36	kw
498616	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
498617	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	6.5	psi
498618	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
498619	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	General Comments		
498620	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	General Comments		
498621	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
498622	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
498623	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
498624	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
498625	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
498626	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
498627	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
498628	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
498629	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
498630	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
498631	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
498632	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Patrol Inspection	General Comments		
498633	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Patrol Inspection	Follow-up Action Required?	n	
498634	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
498635	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
498636	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
498637	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
498638	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
498639	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
498640	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
498641	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
498642	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
498643	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
498644	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
498645	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
498646	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
498647	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
498648	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
498649	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
498650	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
498651	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
498652	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
498653	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	General Comments		
498654	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	General Comments		
498655	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
498656	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
498657	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
498658	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	1599.84	kw
498659	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
498660	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
498661	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
498662	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
498663	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Oil Temp Max	51	°C
498664	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Oil Temp Present	38	°C
498665	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
498666	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
498667	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
498668	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
498669	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
498670	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	General Comments	tower foundation near battery house is crumbling	
498671	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
498672	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
498673	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Foundation Condition	Good	
498674	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
498675	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
498676	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
498677	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
498678	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
498679	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
498680	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
498681	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	General Comments		
498682	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
498683	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
498684	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
498685	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
498686	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
498687	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
498688	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
498689	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
498690	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
498691	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
498692	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
498693	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
498694	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
498695	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
498696	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Ambient Temperature	54	°F
498697	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
498698	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
498699	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
498700	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Tank Leaks	None	
498701	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
498702	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
498703	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Regulator As Left Counter	8156	
498704	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
498705	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
498706	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
498707	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
498708	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
498709	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
498710	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	General Comments		
498711	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
498712	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
498713	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
498714	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
498715	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
498716	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
498717	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
498718	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
498719	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	General Comments		
498720	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
498721	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
498722	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
498723	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
498724	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
498725	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
498726	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
498727	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
498728	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
498729	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
498730	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
498731	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
498732	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
498733	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
498734	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Tank Leaks	None	
498735	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
498736	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
498737	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Regulator As Left Counter	8498	
498738	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
498739	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
498740	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
498741	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
498742	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
498743	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
498744	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Max Tap Position	6L	
498745	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
498746	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	General Comments		
498747	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
498748	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
498749	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
498750	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
498751	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Current Tap Position	8L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
498752	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
498753	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
498754	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
498755	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
498756	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
498757	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
498758	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
498759	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
498760	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
498761	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	General Comments	Fence/barbwire in plans to be replaced	
498762	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
498763	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
498764	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
498765	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Operations Counter	31	
498766	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
498767	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	General Comments		
498768	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
498769	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
498770	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
498771	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
498772	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
498773	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Amps C Ø	12.0	
498774	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Amps B Ø	13.0	
498775	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Amps A Ø	14.0	
498776	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Amps A Ø	27.0	
498777	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Amps B Ø	25.0	
498778	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Amps C Ø	29.0	
498779	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
498780	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
498781	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
498782	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
498783	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
498784	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
498785	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
498786	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
498787	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
498788	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
498789	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Vegetation	None	
498790	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Exp Boom Corrected	
498791	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	General Comments		
498792	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
498793	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
498794	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
498795	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
498796	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
498797	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
498798	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
498799	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
498800	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
498801	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
498802	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
498803	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
498804	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
498805	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
498806	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
498807	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
498808	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
498809	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
498810	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
498811	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Clear of Trash?	y	
498812	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
498813	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
498814	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
498815	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
498816	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
498817	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
498818	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	General Comments		
498819	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
498820	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5430	
498821	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
498822	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
498823	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
498824	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
498825	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Operations Counter	109	
498826	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
498827	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
498828	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
498829	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
498830	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
498831	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
498832	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
498833	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
498834	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
498835	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
498836	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
498837	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
498838	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Signage Visible, and Proper?	y	
498839	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	General Comments		
498840	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Gate Locks Functioning ?	y	
498841	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
498842	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
498843	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
498844	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
498845	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
498846	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
498847	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
498848	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Fault Operations	0	
498849	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
498850	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
498851	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
498852	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
498853	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
498854	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
498855	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Follow-up Action Required?	n	
498856	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Ties Intact?	y	
498857	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Posts Condition OK?	y	
498858	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Grounds in Place?	y	
498859	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Gates Aligned?	y	
498860	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
498861	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
498862	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
498863	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
498864	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
498865	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Bushing Condition	Good	
498866	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Amps C Ø	60.0	
498867	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Amps B Ø	70.0	
498868	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Amps A Ø	60.0	
498869	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
498870	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
498871	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	Follow-up Action Required?	n	
498872	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
498873	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	General Comments		
498874	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	General Comments		
498875	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC As Found Counter	407686	
498876	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC As Left Counter	407686	
498877	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
498878	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC Current Tap Position	9L	
498879	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC Max Tap Position	1L	
498880	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC Min Tap Position	16L	
498881	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
498882	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
498883	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
498884	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Adequate	
498885	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
498886	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
498887	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
498888	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Totalizer Meter Reading	.6666	
498889	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
498890	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
498891	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
498892	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	Follow-up Action Required?	n	
498893	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
498894	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	General Comments		
498895	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	General Comments		
498896	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC As Found Counter	152359	
498897	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC As Left Counter	152365	
498898	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
498899	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC Current Tap Position	5L	
498900	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
498901	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
498902	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
498903	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
498904	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC Max Tap Position	3L	
498905	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC Min Tap Position	10L	
498906	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC Operations Since Last Insp	294	
498907	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
498908	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
498909	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
498910	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
498911	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Top Oil Temperature Present	27	°C
498912	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
498913	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Totalizer Meter Reading	1.0170	
498914	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
498915	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
498916	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Ambient Temp	56	°F
498917	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
498918	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
498919	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Clear of Trash?	y	
498920	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
498921	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
498922	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
498923	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
498924	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
498925	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
498926	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	General Comments		
498927	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
498928	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
498929	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
498930	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
498931	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
498932	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
498933	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Vegetation	None	
498934	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
498935	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
498936	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
498937	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
498938	4/4/2019 15:23	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
498939	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
498940	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	385	
498941	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC Min Tap Position	12L	
498942	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC Max Tap Position	8L	
498943	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC Current Tap Position	9L	
498944	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
498945	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC As Left Counter	171210	
498946	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC As Found Counter	171210	
498947	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
498948	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	General Comments		
498949	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
498950	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
498951	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
498952	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
498953	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
498954	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	285	
498955	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
498956	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC Min Tap Position	14L	
498957	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC Max Tap Position	9L	
498958	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC Current Tap Position	11L	
498959	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
498960	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Tank Leaks	None	
498961	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
498962	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
498963	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Regulator As Left Counter	146222	
498964	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
498965	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
498966	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
498967	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
498968	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
498969	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Min Tap Position	10L	
498970	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Max Tap Position	6R	
498971	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
498972	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	General Comments		
498973	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
498974	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
498975	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
498976	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
498977	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
498978	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
498979	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Current Tap Position	6L	
498980	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
498981	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
498982	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
498983	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
498984	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
498985	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
498986	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
498987	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
498988	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC As Left Counter	162725	
498989	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC As Found Counter	162725	
498990	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Follow-up Action Required?	n	
498991	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Max Tap Position	1L	
498992	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
498993	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	General Comments		
498994	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
498995	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
498996	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
498997	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
498998	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Current Tap Position	3L	
498999	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
499000	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
499001	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
499002	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
499003	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
499004	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
499005	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
499006	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	General Comments		
499007	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
499008	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Vegetation	None	
499009	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
499010	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
499011	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
499012	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
499013	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
499014	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	General Comments		
499015	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
499016	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
499017	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
499018	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Clear of Trash?	y	
499019	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
499020	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
499021	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	General Comments		
499022	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
499023	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	LTC Totalizer Reading	2440.80	kw
499024	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
499025	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
499026	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	General Comments		
499027	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
499028	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
499029	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
499030	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
499031	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
499032	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
499033	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
499034	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
499035	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
499036	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
499037	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
499038	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
499039	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
499040	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
499041	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
499042	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
499043	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
499044	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
499045	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
499046	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
499047	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
499048	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
499049	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
499050	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
499051	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
499052	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
499053	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
499054	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
499055	4/4/2019 10:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	1.0440	
499056	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
499057	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Patrol Inspection	General Comments		
499058	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
499059	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
499060	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	General Comments		
499061	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
499062	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
499063	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
499064	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
499065	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
499066	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
499067	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
499068	4/4/2019 12:33	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Top Oil Temperature Max	65	°C
499069	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Winding Temp Present	8	°C
499070	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
499071	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
499072	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Number of Ops last 9 Months	19	
499073	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
499074	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Maintenance Operations	0	
499075	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
499076	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Winding Temp Present	25	°C
499077	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Winding Temp Max	33	°C
499078	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Totalizer Meter Reading	.6906	
499079	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
499080	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
499081	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
499082	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
499083	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
499084	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Grounds in Place?	y	
499085	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
499086	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
499087	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
499088	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Oil Temp Present	30	°C
499089	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Oil Temp Max	30	°C
499090	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
499091	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	General Comments		
499092	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	General Comments		
499093	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
499094	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Foundation Condition	Good	
499095	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Follow-up Action Required?	n	
499096	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
499097	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	LTC Totalizer Reading	6629.76	kw
499098	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
499099	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	General Comments		
499100	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	General Comments		
499101	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
499102	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
499103	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Follow-up Action Required?	n	
499104	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
499105	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Tank Paint Condition	Good	
499106	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
499107	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	SF6 Pressure	68	psi
499108	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
499109	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
499110	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
499111	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
499112	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
499113	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
499114	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
499115	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
499116	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
499117	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
499118	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
499119	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
499120	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
499121	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
499122	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Grounds in Place?	y	
499123	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	General Comments		
499124	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
499125	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Foundation Condition	Good	
499126	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
499127	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
499128	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Tank Leaks	None	
499129	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
499130	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
499131	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Regulator As Left Counter	6143	
499132	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
499133	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
499134	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
499135	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
499136	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
499137	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
499138	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
499139	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
499140	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	General Comments		
499141	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
499142	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
499143	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
499144	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
499145	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
499146	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
499147	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
499148	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	General Comments	has a desicant on one side , but it has a free breather on the other	
499149	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	General Comments		
499150	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
499151	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
499152	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
499153	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
499154	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
499155	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
499156	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
499157	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
499158	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
499159	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
499160	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Switching Operations	0	
499161	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Operations This Read Oil	0	
499162	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Operations Counter AL	2033	
499163	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Operations Counter AF	2033	
499164	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
499165	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
499166	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
499167	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Operations Since Last Insp	99	
499168	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Min Tap Position	9L	
499169	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Max Tap Position	7L	
499170	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Current Tap Position	7L	
499171	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
499172	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
499173	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
499174	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC As Left Counter	34575	
499175	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC As Found Counter	34558	
499176	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	General Comments		
499177	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	General Comments		
499178	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
499179	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	Follow-up Action Required?	n	
499180	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	BCH001258	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
499181	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	BCH001258	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
499182	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	BCH001258	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
499183	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LTCC000496	LTCControl	BR-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
499184	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LTCC000496	LTCControl	BR-TRANS 4	LTC Control Insp	General Comments		
499185	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LTCC000496	LTCControl	BR-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
499186	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	BCH001258	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
499187	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	BCH001258	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
499188	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	BCH001258	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
499189	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	General Comments		
499190	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
499191	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
499192	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
499193	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	As Left Float Voltage	134.2	VDC
499194	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	As Found Float Voltage	134.2	VDC
499195	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
499196	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
499197	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
499198	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
499199	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
499200	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
499201	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
499202	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
499203	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
499204	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
499205	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
499206	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
499207	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
499208	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
499209	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Follow-up Action Required?	n	
499210	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
499211	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
499212	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	General Comments		
499213	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	General Comments		
499214	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
499215	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
499216	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
499217	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Oil Temp Max	20	°C
499218	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Oil Temp Present	17	°C
499219	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
499220	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
499221	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
499222	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
499223	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
499224	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
499225	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
499226	4/4/2019 15:14	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Winding Temp Max	15	°C
499227	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
499228	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
499229	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
499230	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Trash Emptied?	y	
499231	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
499232	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
499233	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
499234	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Panels Dusted?	y	
499235	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
499236	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
499237	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	General Comments		
499238	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
499239	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
499240	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
499241	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
499242	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
499243	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
499244	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
499245	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
499246	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Floor Swept?	y	
499247	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
499248	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
499249	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Evidence of Insects	None	
499250	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
499251	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
499252	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
499253	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
499254	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Broom on Site?	y	
499255	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
499256	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
499257	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
499258	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
499259	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
499260	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
499261	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
499262	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
499263	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
499264	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
499265	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
499266	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
499267	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
499268	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
499269	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
499270	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Vegetation	None	
499271	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
499272	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
499273	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
499274	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
499275	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	General Comments		
499276	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
499277	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
499278	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
499279	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
499280	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
499281	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
499282	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
499283	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
499284	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
499285	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
499286	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
499287	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
499288	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
499289	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	22	
499290	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
499291	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
499292	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
499293	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
499294	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
499295	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	72.0	
499296	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
499297	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
499298	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
499299	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
499300	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
499301	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
499302	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
499303	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Winding Temp Max	30	°C
499304	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Winding Temp Present	30	°C
499305	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
499306	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
499307	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
499308	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
499309	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
499310	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
499311	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
499312	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
499313	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
499314	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Operations Counter	162	
499315	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
499316	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
499317	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
499318	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	General Comments		
499319	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
499320	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
499321	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
499322	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
499323	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
499324	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Amps C Ø	16.0	
499325	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Amps B Ø	14.0	
499326	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Amps A Ø	14.0	
499327	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
499328	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
499329	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Tank Leaks	None	
499330	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
499331	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
499332	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Regulator As Left Counter	152124	
499333	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
499334	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
499335	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
499336	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
499337	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
499338	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
499339	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
499340	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
499341	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
499342	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
499343	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
499344	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
499345	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
499346	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Min Tap Position	3L	
499347	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
499348	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
499349	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	General Comments		
499350	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
499351	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
499352	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
499353	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
499354	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
499355	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
499356	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
499357	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
499358	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
499359	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
499360	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
499361	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
499362	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
499363	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
499364	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
499365	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
499366	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
499367	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
499368	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
499369	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
499370	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
499371	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
499372	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
499373	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
499374	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
499375	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
499376	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	130	
499377	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	130	
499378	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
499379	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
499380	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
499381	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
499382	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
499383	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Operations Ground	0	
499384	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Operations C Ø	0	
499385	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Operations B Ø	0	
499386	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Operations A Ø	0	
499387	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
499388	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
499389	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
499390	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
499391	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
499392	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
499393	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
499394	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
499395	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
499396	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
499397	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	General Comments		
499398	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	General Comments		
499399	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
499400	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
499401	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
499402	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
499403	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
499404	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
499405	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Foundation Condition	Good	
499406	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
499407	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
499408	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	General Comments		
499409	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
499410	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
499411	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
499412	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
499413	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
499414	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
499415	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
499416	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
499417	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	Follow-up Action Required?	n	
499418	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
499419	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Equipment Properly Labeled?	y	
499420	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
499421	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
499422	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
499423	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
499424	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
499425	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
499426	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
499427	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
499428	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
499429	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
499430	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Bushings Connection/Risers	Good	
499431	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Bushing Condition	Good	
499432	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
499433	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Tank Leaks	None	
499434	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
499435	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
499436	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Regulator As Left Counter	154171	
499437	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
499438	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
499439	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
499440	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
499441	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
499442	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
499443	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
499444	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
499445	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
499446	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
499447	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
499448	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Unknown Operations	0	
499449	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
499450	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
499451	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
499452	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
499453	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
499454	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
499455	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
499456	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
499457	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
499458	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
499459	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
499460	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Tank Paint Condition	Good	
499461	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
499462	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
499463	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
499464	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Switching Operations	0	
499465	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Operations This Read Vac	0	
499466	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Operations Counter AL	269	
499467	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Operations Counter AF	269	
499468	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Moisture and Leak Free?	y	
499469	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Maintenance Operations	0	
499470	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Heaters (All) Functioning?	y	
499471	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Grounds in Place?	y	
499472	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	General Comments		
499473	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	General Comments		
499474	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Foundation Condition	Good	
499475	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
499476	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Follow-up Action Required?	n	
499477	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Follow-up Action Required?	n	
499478	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
499479	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
499480	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
499481	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
499482	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
499483	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
499484	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
499485	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
499486	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
499487	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	General Comments		
499488	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
499489	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
499490	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Ambient Temp	74	°F
499491	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
499492	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	225.00	
499493	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
499494	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
499495	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Clear of Trash?	y	
499496	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
499497	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
499498	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
499499	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
499500	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
499501	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
499502	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	General Comments		
499503	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
499504	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
499505	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
499506	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
499507	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
499508	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Vegetation	None	
499509	4/4/2019 14:47	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
499510	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
499511	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
499512	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	General Comments		
499513	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
499514	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Operations Counter	431	
499515	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
499516	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Patrol Inspection	General Comments		
499517	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Patrol Inspection	Follow-up Action Required?	n	
499518	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Patrol Inspection	Equipment Properly Labeled?	y	
499519	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Tank Paint Condition	Good	
499520	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Unknown Operations	0	
499521	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
499522	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
499523	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
499524	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
499525	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
499526	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
499527	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
499528	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
499529	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	General Comments		
499530	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
499531	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
499532	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
499533	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
499534	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
499535	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
499536	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
499537	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.9	volts
499538	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Regulator As Left Counter	21419	
499539	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
499540	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Tank Leaks	None	
499541	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
499542	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
499543	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
499544	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
499545	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
499546	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
499547	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
499548	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
499549	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
499550	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
499551	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
499552	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
499553	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1004	Regulator	351-1 A	Regulator Patrol Inspection	General Comments		
499554	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
499555	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
499556	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
499557	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
499558	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
499559	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
499560	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
499561	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
499562	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
499563	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
499564	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
499565	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
499566	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
499567	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
499568	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
499569	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
499570	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
499571	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
499572	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1006	Regulator	351-1 C	Regulator Patrol Inspection	General Comments		
499573	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
499574	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
499575	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
499576	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
499577	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
499578	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
499579	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
499580	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Follow-up Action Required?	n	
499581	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Foundation Condition	Good	
499582	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	General Comments		
499583	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	General Comments		
499584	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
499585	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
499586	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
499587	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
499588	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
499589	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
499590	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
499591	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
499592	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
499593	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
499594	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
499595	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
499596	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
499597	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
499598	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
499599	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
499600	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	569.88	kw
499601	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
499602	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
499603	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
499604	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	General Comments	UNable to read Gauges. Need replacing	
499605	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	General Comments		
499606	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
499607	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
499608	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
499609	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
499610	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
499611	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
499612	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
499613	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
499614	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
499615	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
499616	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
499617	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
499618	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
499619	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9498	
499620	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
499621	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Tank Leaks	None	
499622	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
499623	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
499624	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
499625	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
499626	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Amps A Ø	27.0	
499627	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Amps B Ø	30.0	
499628	4/4/2019 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
499629	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Regulator As Left Counter	342452	
499630	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
499631	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
499632	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
499633	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
499634	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
499635	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
499636	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
499637	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
499638	4/4/2019 11:39	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
499639	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Grounds in Place?	y	
499640	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Maintenance Operations	0	
499641	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
499642	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Operations Counter AF	223	
499643	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Operations Counter AL	233	
499644	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Operations This Read Vac	0	
499645	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
499646	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Switching Operations	0	
499647	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Amps C Ø	33.0	
499648	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
499649	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
499650	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
499651	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
499652	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
499653	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
499654	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	112612	
499655	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
499656	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
499657	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
499658	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
499659	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
499660	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	5L	
499661	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	4R	
499662	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
499663	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
499664	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
499665	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
499666	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
499667	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
499668	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Follow-up Action Required?	n	
499669	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
499670	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
499671	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	General Comments		
499672	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	General Comments		
499673	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
499674	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
499675	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
499676	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
499677	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
499678	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
499679	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
499680	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
499681	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
499682	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
499683	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
499684	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
499685	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
499686	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
499687	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	LTC Totalizer Reading	1512.96	kw
499688	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
499689	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	Top Oil Temperature Present	40	°C
499690	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	Top Oil Temperature Max	40	°C
499691	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
499692	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
499693	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LTCC000529	LTCControl	BR-TRANS 5	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
499694	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LTCC000529	LTCControl	BR-TRANS 5	LTC Control Insp	General Comments		
499695	4/9/2019 10:20	Distribution	Breckenridge Quarterly Inspection	LTCC000529	LTCControl	BR-TRANS 5	LTC Control Insp	Follow-up Action Required?	n	
499696	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
499697	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
499698	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
499699	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
499700	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
499701	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
499702	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
499703	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
499704	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
499705	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
499706	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
499707	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
499708	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	General Comments		
499709	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	General Comments		
499710	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
499711	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
499712	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
499713	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
499714	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
499715	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
499716	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
499717	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
499718	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
499719	4/4/2019 15:56	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
499720	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
499721	4/4/2019 7:39	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
499722	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectir	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
499723	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectir	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Regulator As Left Counter	303216	
499724	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectir	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
499725	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectir	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
499726	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectir	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Tank Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
499727	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
499728	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	15	
499729	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
499730	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
499731	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
499732	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	168.0	
499733	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	168.0	
499734	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	168.0	
499735	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
499736	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
499737	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
499738	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
499739	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
499740	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
499741	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
499742	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
499743	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	29.63	
499744	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
499745	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
499746	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
499747	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
499748	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
499749	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
499750	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
499751	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
499752	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
499753	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
499754	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
499755	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
499756	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
499757	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
499758	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	General Comments		
499759	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
499760	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
499761	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
499762	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
499763	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
499764	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
499765	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
499766	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.3	volts
499767	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Regulator As Left Counter	26967	
499768	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
499769	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Tank Leaks	None	
499770	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
499771	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
499772	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
499773	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	6	
499774	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
499775	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
499776	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
499777	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
499778	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
499779	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
499780	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
499781	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
499782	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
499783	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
499784	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
499785	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	103	
499786	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	103	
499787	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	6	
499788	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
499789	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
499790	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
499791	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
499792	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
499793	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Bushing Condition	Good	
499794	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
499795	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Bushings Connection/Risers	Good	
499796	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
499797	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
499798	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
499799	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Cabinet Paint Condition	Good	
499800	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Equipment Properly Labeled?	y	
499801	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
499802	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Foundation Condition	Good	
499803	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
499804	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	General Comments		
499805	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
499806	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
499807	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
499808	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	General Comments	SEL Bad Display screen. Have notified and will be repairing..	
499809	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Grounds in Place?	y	
499810	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
499811	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
499812	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
499813	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Tank Leaks	None	
499814	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
499815	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
499816	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Regulator As Left Counter	143559	
499817	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
499818	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
499819	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
499820	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
499821	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
499822	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Min Tap Position	10L	
499823	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Max Tap Position	3R	
499824	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
499825	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
499826	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	General Comments		
499827	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
499828	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
499829	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Oil Temp Present	40	°C
499830	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Oil Temp Max	40	°C
499831	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
499832	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	General Comments		
499833	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Grounds in Place?	y	
499834	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Maintenance Operations	0	
499835	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Moisture and Leak Free?	y	
499836	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
499837	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
499838	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Operations This Read Vac	0	
499839	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Operations Counter AF	218	
499840	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
499841	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Operations Counter AL	218	
499842	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
499843	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	General Comments		
499844	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
499845	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
499846	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
499847	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
499848	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Current Tap Position	6L	
499849	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
499850	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	Oil Temp Max	35	°C
499851	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
499852	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
499853	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
499854	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
499855	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
499856	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
499857	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
499858	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
499859	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
499860	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	0985	NonLTC	351-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
499861	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	General Comments		
499862	4/4/2019 14:57	Distribution	Virginia City Distribution Quarterly Inspectio	0985	NonLTC	351-1	NonLTC Transformer Readings	Totalizer Meter Reading	.1122	
499863	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Patrol Inspection	General Comments		
499864	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
499865	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
499866	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
499867	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
499868	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
499869	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
499870	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
499871	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
499872	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
499873	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
499874	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
499875	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Current Tap Position	7L	
499876	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
499877	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Unknown Operations	0	
499878	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
499879	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
499880	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
499881	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
499882	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
499883	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
499884	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
499885	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Amps C Ø	310.0	
499886	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Amps B Ø	285.0	
499887	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Amps A Ø	301.0	
499888	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
499889	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
499890	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
499891	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
499892	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Heaters (All) Functioning?	y	
499893	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Moisture and Leak Free?	y	
499894	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
499895	4/4/2019 13:24	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Tank Paint Condition	Good	
499896	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	9 Months Operations	15	
499897	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
499898	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
499899	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
499900	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
499901	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
499902	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
499903	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
499904	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	General Comments		
499905	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
499906	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Max Tap Position	2R	
499907	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Min Tap Position	16L	
499908	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
499909	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
499910	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
499911	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
499912	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
499913	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	General Comments		
499914	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
499915	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Foundation Condition	Good	
499916	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
499917	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
499918	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
499919	4/4/2019 12:55	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
499920	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
499921	4/4/2019 13:46	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
499922	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
499923	4/4/2019 13:12	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Switching Operations	0	
499924	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
499925	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
499926	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
499927	4/4/2019 14:44	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Totalizer Meter Reading	.4728	
499928	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
499929	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
499930	4/4/2019 11:11	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
499931	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
499932	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
499933	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	OK	
499934	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
499935	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
499936	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	OK	
499937	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
499938	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
499939	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	OK	
499940	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	OK	
499941	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
499942	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
499943	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	OK	
499944	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
499945	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
499946	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
499947	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
499948	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
499949	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
499950	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
499951	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
499952	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Bushing Condition	Good	
499953	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
499954	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
499955	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
499956	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
499957	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
499958	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
499959	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
499960	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
499961	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
499962	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
499963	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
499964	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
499965	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
499966	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
499967	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Foundation Condition	Good	
499968	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
499969	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Follow-up Action Required?	n	
499970	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Equipment Properly Labeled?	y	
499971	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
499972	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Cabinet Paint Condition	Good	
499973	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC As Found Counter	92863	
499974	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
499975	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
499976	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Patrol Inspection	General Comments		
499977	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Patrol Inspection	Follow-up Action Required?	n	
499978	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
499979	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
499980	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Cabinet Paint Condition	Good	
499981	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Equipment Properly Labeled?	y	
499982	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Follow-up Action Required?	n	
499983	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Foundation Condition	Good	
499984	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
499985	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
499986	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Bushing Condition	Good	
499987	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Bushings Connection/Risers	Good	
499988	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
499989	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
499990	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Bushings Connection/Risers	Good	
499991	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
499992	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC As Left Counter	92863	
499993	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
499994	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
499995	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
499996	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
499997	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
499998	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
499999	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Winding Temp Present	26	°C
500000	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	General Comments		
500001	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
500002	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
500003	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
500004	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
500005	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
500006	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
500007	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
500008	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	Yes_sprayed	
500009	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
500010	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
500011	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
500012	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
500013	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
500014	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
500015	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
500016	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
500017	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	General Comments	fans changed to bank 1 for 2019	
500018	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	General Comments	ok	
500019	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
500020	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
500021	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
500022	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
500023	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
500024	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
500025	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
500026	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
500027	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
500028	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
500029	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
500030	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
500031	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
500032	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Tank Paint Condition	Good	
500033	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
500034	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Moisture and Leak Free?	y	
500035	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Heaters (All) Functioning?	y	
500036	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Grounds in Place?	y	
500037	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	General Comments		
500038	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Foundation Condition	Good	
500039	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Follow-up Action Required?	n	
500040	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Equipment Properly Labeled?	y	
500041	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Cabinet Paint Condition	Good	
500042	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
500043	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
500044	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
500045	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Bushings Connection/Risers	Good	
500046	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Bushing Condition	Good	
500047	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
500048	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
500049	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
500050	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
500051	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
500052	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
500053	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Foundation Condition	Good	
500054	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
500055	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
500056	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	General Comments		
500057	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
500058	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
500059	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
500060	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
500061	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
500062	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
500063	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
500064	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
500065	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
500066	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Foundation Condition	Good	
500067	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
500068	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
500069	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	General Comments		
500070	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
500071	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
500072	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
500073	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
500074	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
500075	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
500076	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
500077	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
500078	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
500079	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
500080	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
500081	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
500082	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	General Comments		
500083	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Grounds in Place?	y	
500084	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Moisture and Leak Free?	y	
500085	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Tank Paint Condition	Good	
500086	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
500087	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
500088	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
500089	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Vegetation	None	
500090	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
500091	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
500092	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
500093	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
500094	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
500095	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	General Comments		
500096	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
500097	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
500098	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
500099	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
500100	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
500101	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	657	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
500102	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC Min Tap Position	14L	
500103	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC Max Tap Position	9L	
500104	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC Current Tap Position	12L	
500105	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
500106	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC As Left Counter	183719	
500107	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC As Found Counter	183719	
500108	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
500109	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
500110	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	General Comments		
500111	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
500112	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
500113	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
500114	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
500115	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
500116	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
500117	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
500118	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
500119	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	General Comments		
500120	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
500121	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
500122	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
500123	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
500124	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
500125	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
500126	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
500127	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
500128	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
500129	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Percent Thermal Load A Ø Max	-60	%
500130	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
500131	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Percent Thermal Load C Ø Max	-60	%
500132	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
500133	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
500134	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
500135	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
500136	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
500137	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
500138	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	General Comments		
500139	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
500140	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
500141	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
500142	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
500143	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
500144	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
500145	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
500146	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
500147	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
500148	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
500149	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
500150	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Follow-up Action Required?	n	
500151	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
500152	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
500153	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	General Comments		
500154	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	General Comments		
500155	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	General Comments		
500156	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
500157	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
500158	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
500159	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
500160	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Panels Dusted?	y	
500161	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
500162	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
500163	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	General Comments		
500164	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
500165	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
500166	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Floor Swept?	y	
500167	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
500168	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
500169	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Evidence of Insects	None	
500170	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
500171	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
500172	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
500173	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
500174	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Broom on Site?	y	
500175	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
500176	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
500177	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LTCC000334	LTCControl	SW-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
500178	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LTCC000334	LTCControl	SW-TRANS 1	LTC Control Insp	General Comments		
500179	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LTCC000334	LTCControl	SW-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
500180	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LTCC000334	LTCControl	SW-TRANS 1	LTC Control Insp	All Connections OK?	y	
500181	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LTCC000333	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
500182	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LTCC000333	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
500183	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LTCC000333	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
500184	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LTCC000333	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
500185	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
500186	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	LTC Totalizer Reading	8530.56	kw
500187	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
500188	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
500189	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Oil Temp Max	38	°C
500190	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Oil Temp Present	28	°C
500191	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
500192	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
500193	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
500194	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	40	°C
500195	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	37	°C
500196	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	40	°C
500197	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
500198	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	40	°C
500199	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	37	°C
500200	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
500201	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
500202	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
500203	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
500204	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
500205	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
500206	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
500207	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Clear of Trash?	y	
500208	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
500209	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
500210	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
500211	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
500212	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
500213	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
500214	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
500215	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
500216	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
500217	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
500218	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
500219	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
500220	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
500221	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	General Comments		
500222	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
500223	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
500224	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
500225	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	BCH000395	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
500226	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
500227	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
500228	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
500229	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
500230	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
500231	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
500232	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
500233	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
500234	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
500235	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
500236	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
500237	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	BCH000395	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
500238	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	BCH000395	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
500239	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
500240	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
500241	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
500242	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
500243	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	BCH000395	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
500244	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	BCH000395	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
500245	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
500246	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
500247	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
500248	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
500249	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
500250	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
500251	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	BCH000395	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
S00252	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	BCH000395	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
S00253	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
S00254	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
S00255	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
S00256	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
S00257	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
S00258	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
S00259	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
S00260	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Totalizer Meter Reading	.8886	
S00261	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Winding Temp Max	38	°C
S00262	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	LTC Operation Checked?	y	
S00263	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	General Comments		
S00264	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	Follow-up Action Required?	n	
S00265	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	All Connections OK?	y	
S00266	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
S00267	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
S00268	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
S00269	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
S00270	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
S00271	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
S00272	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
S00273	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
S00274	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
S00275	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
S00276	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
S00277	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
S00278	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
S00279	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
S00280	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
S00281	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
S00282	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5180	
S00283	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Winding Temp Max	30	°C
S00284	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Winding Temp Present	25	°C
S00285	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
S00286	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
S00287	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
S00288	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
S00289	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
S00290	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	General Comments		
S00291	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
S00292	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
S00293	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Operations Counter	0	
S00294	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
S00295	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
S00296	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
S00297	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
S00298	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
S00299	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
S00300	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
S00301	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments	OK	
S00302	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
S00303	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
S00304	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
S00305	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
S00306	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
S00307	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
S00308	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
S00309	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
S00310	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
S00311	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
S00312	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	27	
S00313	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.5	psi
S00314	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
S00315	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC Max Tap Position	7L	
S00316	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Tank Paint Condition	Good	
S00317	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
S00318	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Moisture and Leak Free?	y	
S00319	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Heaters (All) Functioning?	y	
S00320	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Grounds in Place?	y	
S00321	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	General Comments		
S00322	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
S00323	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
S00324	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
S00325	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
S00326	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
500327	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	General Comments	ok	
500328	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
500329	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
500330	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
500331	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
500332	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	PF000169	PowerFuse	HC-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
500333	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	PF000169	PowerFuse	HC-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
500334	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
500335	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Vegetation	None	
500336	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
500337	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
500338	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
500339	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
500340	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
500341	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
500342	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
500343	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.800	millivolts
500344	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
500345	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
500346	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	PF000168	PowerFuse	HC-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
500347	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	PF000168	PowerFuse	HC-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
500348	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.8	amps
500349	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
500350	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
500351	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
500352	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
500353	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
500354	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
500355	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
500356	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	PF000166	PowerFuse	HC-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
500357	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	PF000166	PowerFuse	HC-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
500358	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
500359	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
500360	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
500361	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
500362	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	General Comments		
500363	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
500364	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
500365	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
500366	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
500367	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
500368	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
500369	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
500370	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
500371	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
500372	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
500373	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
500374	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2486.40	kw
500375	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
500376	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
500377	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Oil Temp Max	25	°C
500378	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Amps A Ø	1.0	
500379	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Amps B Ø	1.0	
500380	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
500381	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
500382	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	LTCC000678	LTCControl	417-1	LTC Control Insp	VRR Time Delay	30	Seconds
500383	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	LTCC000678	LTCControl	417-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
500384	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	LTCC000678	LTCControl	417-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
500385	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	LTCC000678	LTCControl	417-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
500386	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
500387	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
500388	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
500389	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Patrol Inspection	Follow-up Action Required?	n	
500390	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Patrol Inspection	General Comments		
500391	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	VRR Time Delay	30	Seconds
500392	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
500393	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
500394	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
500395	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	LTC Operation Checked?	y	
500396	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	General Comments		
500397	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	Follow-up Action Required?	n	
500398	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	All Connections OK?	y	
500399	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
500400	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.8	VDC
500401	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
500402	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
500403	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
500404	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
500405	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	General Comments		
500406	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
500407	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
500408	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
500409	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
500410	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
500411	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
500412	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
500413	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
500414	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
500415	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
500416	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
500417	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
500418	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
500419	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
500420	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
500421	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
500422	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
500423	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
500424	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	11764.80	kw
500425	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
500426	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
500427	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Tank Leaks	None	
500428	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
500429	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
500430	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Regulator As Left Counter	374477	
500431	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
500432	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	45	°C
500433	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	40	°C
500434	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
500435	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Operational?	y	
500436	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
500437	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
500438	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
500439	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
500440	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
500441	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
500442	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
500443	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
500444	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.8170	
500445	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	Winding Temp Max	70	°C
500446	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	Winding Temp Present	30	°C
500447	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
500448	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
500449	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
500450	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
500451	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Evidence of Insects	None	
500452	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Doors and Locks Secure?	y	
500453	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
500454	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Control House Lighting OK?	y	
500455	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Broom on Site?	y	
500456	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
500457	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
500458	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
500459	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
500460	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Bushing Condition	Good	
500461	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
500462	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
500463	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
500464	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
500465	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
500466	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
500467	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	General Comments		
500468	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
500469	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
500470	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Foundation Condition	Good	
500471	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
500472	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
500473	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
500474	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
500475	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
500476	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
500477	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Vegetation	None	
500478	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
500479	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
500480	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
500481	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
500482	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	General Comments		
500483	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Bushing Condition	Good	
500484	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Bushings Connection/Risers	Good	
500485	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
500486	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
500487	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
500488	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Cabinet Paint Condition	Good	
500489	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Equipment Properly Labeled?	y	
500490	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Follow-up Action Required?	n	
500491	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Foundation Condition	Good	
500492	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	General Comments		
500493	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Grounds in Place?	y	
500494	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Moisture and Leak Free?	y	
500495	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Tank Paint Condition	Good	
500496	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
500497	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
500498	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
500499	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
500500	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
500501	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
500502	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
500503	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	General Comments		
500504	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
500505	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
500506	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
500507	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
500508	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
500509	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
500510	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
500511	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
500512	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Patrol Inspection	Follow-up Action Required?	n	
500513	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Patrol Inspection	General Comments	ok	
500514	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
500515	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
500516	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Min Tap Position	1L	
500517	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
500518	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
500519	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
500520	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
500521	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
500522	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
500523	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
500524	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
500525	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	General Comments		
500526	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
500527	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
500528	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	General Comments		
500529	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
500530	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
500531	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
500532	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
500533	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
500534	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
500535	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
500536	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Regulator As Left Counter	100487	
500537	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
500538	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
500539	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Tank Leaks	None	
500540	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
500541	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
500542	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Foundation Condition	Good	
500543	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
500544	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
500545	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
500546	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	General Comments		
500547	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
500548	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
500549	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
500550	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
500551	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
500552	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
500553	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
500554	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
500555	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
500556	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Vegetation	None	
500557	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
500558	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Patrol Inspection	General Comments		
500559	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Patrol Inspection	Follow-up Action Required?	n	
500560	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
500561	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
500562	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
500563	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
500564	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
500565	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
500566	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
500567	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
500568	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
500569	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
500570	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
500571	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
500572	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
500573	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
500574	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
500575	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
500576	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
500577	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Clear of Trash?	y	
500578	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
500579	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
500580	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
500581	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	LTCMechanism	417-1	LTC Counter Readings	Follow-up Action Required?	n	
500582	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
500583	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	LTCMechanism	417-1	LTC Counter Readings	General Comments		
500584	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	General Comments		
500585	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
500586	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
500587	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	General Comments		
500588	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
500589	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
500590	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Min Tap Position	1L	
500591	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
500592	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
500593	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
500594	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
500595	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.4	volts
500596	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Regulator As Left Counter	91800	
500597	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
500598	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
500599	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Tank Leaks	None	
500600	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
500601	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
500602	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
500603	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
500604	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
500605	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
500606	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	LTCMechanism	417-1	LTC Counter Readings	LTC As Found Counter	6450	
500607	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	LTCMechanism	417-1	LTC Counter Readings	LTC As Left Counter	6450	
500608	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
500609	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	LTCMechanism	417-1	LTC Counter Readings	LTC Current Tap Position	6L	
500610	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	LTCMechanism	417-1	LTC Counter Readings	LTC Max Tap Position	3L	
500611	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	LTCMechanism	417-1	LTC Counter Readings	LTC Min Tap Position	6L	
500612	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
500613	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
500614	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
500615	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
500616	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
500617	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Patrol Inspection	General Comments		
500618	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
500619	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
500620	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
500621	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
500622	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
500623	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
500624	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
500625	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	LTCMechanism	417-1	LTC Counter Readings	LTC Operations Since Last Insp	313	
500626	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
500627	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
500628	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
500629	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
500630	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Vegetation	None	
500631	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
500632	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
500633	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
500634	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
500635	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
500636	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	General Comments		
500637	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
500638	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
500639	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
500640	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
500641	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
500642	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Clear of Trash?	y	
500643	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
500644	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Ambient Temp	56	°F
500645	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
500646	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
500647	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
500648	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
500649	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
500650	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
500651	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
500652	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
500653	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
500654	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
500655	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	General Comments		
500656	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
500657	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
500658	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
500659	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
500660	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
500661	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
500662	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Clear of Trash?	y	
500663	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
500664	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Ambient Temp	54	°F
500665	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
500666	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
500667	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
500668	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
500669	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
500670	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
500671	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
500672	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	40	°C
500673	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
500674	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	45	°C
500675	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	45	°C
500676	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	45	°C
500677	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
500678	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	General Comments	Temperature gauge glass cloudy	
500679	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
500680	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
500681	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
500682	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1130.40	kw
500683	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
500684	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
500685	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
500686	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
500687	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
500688	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
500689	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
500690	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
500691	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
500692	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
500693	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
500694	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
500695	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
500696	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	Yes_sprayed	
500697	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
500698	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
500699	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
500700	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
500701	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
500702	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
500703	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
500704	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
500705	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
500706	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
500707	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
500708	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	400	psi
500709	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
500710	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
500711	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
500712	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
500713	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
500714	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
500715	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
500716	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
500717	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
500718	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
500719	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Unreadable	
500720	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	General Comments		
500721	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
500722	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Tank Paint Condition	Good	
500723	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
500724	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Moisture and Leak Free?	y	
500725	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Heaters (All) Functioning?	y	
500726	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Grounds in Place?	y	
500727	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	General Comments		
500728	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Foundation Condition	Good	
500729	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Follow-up Action Required?	n	
500730	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Equipment Properly Labeled?	y	
500731	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Cabinet Paint Condition	Good	
500732	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
500733	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
500734	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
500735	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Bushings Connection/Risers	Good	
500736	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Bushing Condition	Good	
500737	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
500738	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
500739	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
500740	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
500741	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Vegetation	None	
500742	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
500743	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
500744	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
500745	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
500746	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
500747	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
500748	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
500749	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Clear of Trash?	y	
500750	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
500751	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
500752	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
500753	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
500754	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
500755	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
500756	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
500757	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
500758	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
500759	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
500760	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
500761	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
500762	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
500763	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
500764	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
500765	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
500766	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9420	
500767	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
500768	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
500769	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
500770	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
500771	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
500772	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
500773	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Trash Emptied?	y	
500774	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Moisture and Leak Free?	y	
500775	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	General Comments		
500776	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
500777	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Follow-up Action Required?	n	
500778	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Floor Swept?	y	
500779	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
500780	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
500781	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	General Comments		
500782	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
500783	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
500784	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
500785	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
500786	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
500787	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
500788	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
500789	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
500790	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
500791	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
500792	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
500793	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
500794	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
500795	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
500796	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
500797	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
500798	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
500799	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
500800	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
500801	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
500802	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
500803	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
500804	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Foundation Condition	Good	
500805	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Follow-up Action Required?	n	
500806	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
500807	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Tank Paint Condition	Good	
500808	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Moisture and Leak Free?	y	
500809	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
500810	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
500811	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
500812	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Heaters (All) Functioning?	y	
500813	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Grounds in Place?	y	
500814	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	General Comments		
500815	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Foundation Condition	Good	
500816	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Follow-up Action Required?	n	
500817	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Equipment Properly Labeled?	y	
500818	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Cabinet Paint Condition	Good	
500819	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
500820	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
500821	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Bushings Connection/Risers	Good	
500822	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Bushing Condition	Good	
500823	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
500824	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
500825	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
500826	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	LTCC000453	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
500827	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	LTCC000453	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
500828	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	LTCC000453	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
500829	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	LTCC000453	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
500830	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	LTCC000453	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
500831	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	LTCC000453	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
500832	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
500833	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
500834	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
500835	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
500836	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
500837	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
500838	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
500839	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	LTCC000453	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
500840	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	LTCC000453	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
500841	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	LTCC000453	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
500842	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Tank Paint Condition	Good	
500843	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
500844	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
500845	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Grounds in Place?	y	
500846	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
500847	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
500848	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
500849	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
500850	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
500851	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
500852	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
500853	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
500854	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	Foundation Condition	Good	
500855	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
500856	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
500857	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	General Comments		
500858	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
500859	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
500860	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
500861	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
500862	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
500863	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
500864	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
500865	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
500866	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
500867	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Amps A Ø	34.0	
500868	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Amps B Ø	46.0	
500869	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Amps C Ø	21.0	
500870	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
500871	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
500872	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
500873	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
500874	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
500875	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Patrol Inspection	General Comments		
500876	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
500877	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
500878	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
500879	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
500880	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
500881	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
500882	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
500883	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
500884	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
500885	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
500886	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
500887	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	General Comments		
500888	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
500889	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
500890	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
500891	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
500892	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Readings	Totalizer Meter Reading	.7770	
500893	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
500894	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
500895	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
500896	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
500897	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
500898	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Patrol Inspection	General Comments		
500899	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Patrol Inspection	Follow-up Action Required?	n	
500900	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
500901	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
500902	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
500903	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
500904	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
500905	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
500906	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
500907	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
500908	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
500909	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
500910	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
500911	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Vegetation	None	
500912	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
500913	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	General Comments		
500914	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
500915	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
500916	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Operations Counter	29	
500917	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
500918	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Tank Leaks	None	
500919	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
500920	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Bushing Condition	Good	
500921	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
500922	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
500923	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
500924	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
500925	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	All Connections OK?	y	
500926	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	54	°F

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
500927	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Battery Bank Amps	2.5	AMPS
500928	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
500929	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	LTCC000143	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
500930	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	LTCC000143	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
500931	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
500932	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Follow-up Action Required?	n	
500933	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Foundation Condition	Good	
500934	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	General Comments		
500935	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Grounds in Place?	y	
500936	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
500937	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
500938	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Tank Paint Condition	Good	
500939	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	PF000031	PowerFuse	AB-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
500940	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	PF000031	PowerFuse	AB-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
500941	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Patrol Inspection	General Comments	ok	
500942	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
500943	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
500944	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Patrol Inspection	Follow-up Action Required?	n	
500945	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	PF000167	PowerFuse	HC-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
500946	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	PF000167	PowerFuse	HC-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
500947	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Patrol Inspection	General Comments		
500948	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	LTCC000143	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
500949	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Battery Bank Volts	53.0	VDC
500950	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
500951	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
500952	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
500953	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
500954	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
500955	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
500956	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
500957	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	General Comments		
500958	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
500959	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
500960	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
500961	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
500962	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	LTCC000143	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
500963	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
500964	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	LTCC000155	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
500965	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	LTCC000155	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
500966	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	LTCC000155	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
500967	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	LTCC000155	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
500968	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	LTCC000155	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
500969	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	LTCC000155	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
500970	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	LTCC000155	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
500971	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	LTCC000155	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
500972	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
500973	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
500974	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
500975	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
500976	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
500977	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	General Comments		
500978	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
500979	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
500980	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
500981	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
500982	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
500983	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
500984	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
500985	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Readings	Oil Temp Present	35	°C
500986	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Readings	Oil Temp Max	45	°C
500987	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
500988	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
500989	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Readings	LTC Totalizer Reading	7459.20	kw
500990	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
500991	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Readings	General Comments		
500992	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	General Comments		
500993	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
500994	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
500995	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Readings	Follow-up Action Required?	n	
500996	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
500997	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
500998	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
500999	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
501000	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
501001	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
501002	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
501003	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments	OK	
501004	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
501005	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
501006	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
501007	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
501008	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
501009	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
501010	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
501011	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
501012	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
501013	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Tank Paint Condition	Good	
501014	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
501015	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
501016	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
501017	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
501018	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
501019	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
501020	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
501021	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
501022	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
501023	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
501024	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
501025	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
501026	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
501027	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
501028	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
501029	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
501030	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
501031	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
501032	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
501033	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
501034	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
501035	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
501036	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
501037	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
501038	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
501039	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
501040	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
501041	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
501042	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
501043	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
501044	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
501045	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
501046	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
501047	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
501048	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
501049	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Clear of Trash?	y	
501050	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
501051	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
501052	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
501053	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Operational?	y	
501054	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
501055	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	11.0	
501056	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	11.0	
501057	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	12.0	
501058	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
501059	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
501060	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
501061	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
501062	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
501063	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
501064	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
501065	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Tank Leaks	None	
501066	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Regulator As Left Counter	10332	
501067	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	0.0	volts
501068	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Reg Operation Checked?	n	
501069	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
501070	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
501071	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
501072	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	General Comments		
501073	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
501074	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
501075	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
501076	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
501077	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
501078	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	General Comments		
501079	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
501080	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
501081	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Operations Counter	0	
501082	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
501083	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
501084	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	30	°C
501085	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	30	°C
501086	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
501087	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Bushings Connection/Risers	Good	
501088	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
501089	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
501090	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Cabinet Paint Condition	Good	
501091	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Equipment Properly Labeled?	y	
501092	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Follow-up Action Required?	n	
501093	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Foundation Condition	Good	
501094	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	General Comments		
501095	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Grounds in Place?	y	
501096	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Heaters (All) Functioning?	y	
501097	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Moisture and Leak Free?	y	
501098	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Tank Paint Condition	Good	
501099	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
501100	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
501101	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
501102	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
501103	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
501104	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
501105	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	LV Winding Temp Max	38	°C
501106	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
501107	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
501108	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
501109	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
501110	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	HV Winding Temp Present	28	°C
501111	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	HV Winding Temp Max	40	°C
501112	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
501113	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	General Comments		
501114	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Patrol Inspection	Follow-up Action Required?	n	
501115	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
501116	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	General Comments		
501117	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
501118	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
501119	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
501120	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
501121	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
501122	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	General Comments		
501123	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
501124	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
501125	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
501126	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
501127	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
501128	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
501129	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
501130	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
501131	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
501132	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Vegetation	None	
501133	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
501134	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
501135	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
501136	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
501137	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
501138	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
501139	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
501140	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
501141	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
501142	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
501143	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
501144	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
501145	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
501146	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
501147	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
501148	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
501149	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
501150	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
501151	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
501152	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
501153	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
501154	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
501155	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
501156	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	Follow-up Action Required?	n	
501157	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
501158	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
501159	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
501160	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
501161	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
501162	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
501163	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	LV Winding Temp Present	27	°C
501164	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
501165	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
501166	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
501167	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
501168	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1450	psi
501169	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	Oil Temp Max	35	°C
501170	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	Oil Temp Present	27	°C
501171	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
501172	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
501173	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
501174	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
501175	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
501176	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
501177	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
501178	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	TV Winding Temp Max	37	°C
501179	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	TV Winding Temp Present	26	°C
501180	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
501181	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
501182	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
501183	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Patrol Inspection	Follow-up Action Required?	n	
501184	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Patrol Inspection	General Comments	ok	
501185	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
501186	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
501187	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	General Comments		
501188	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
501189	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Patrol Inspection	General Comments		
501190	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Amps A Ø	.2	
501191	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Amps B Ø	.2	
501192	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
501193	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
501194	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
501195	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
501196	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Patrol Inspection	General Comments		
501197	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC As Found Counter	72240	
501198	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC As Left Counter	72240	
501199	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
501200	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Patrol Inspection	Follow-up Action Required?	n	
501201	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
501202	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
501203	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
501204	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
501205	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
501206	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
501207	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Clear of Trash?	y	
501208	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
501209	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
501210	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
501211	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
501212	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
501213	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
501214	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
501215	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	332	
501216	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
501217	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
501218	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	52.9	VDC
501219	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	52.9	VDC
501220	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
501221	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
501222	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
501223	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	General Comments		
501224	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
501225	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Bushing Condition	Good	
501226	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
501227	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
501228	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
501229	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Vegetation	None	
501230	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
501231	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
501232	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
501233	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	General Comments		
501234	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
501235	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
501236	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
501237	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
501238	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
501239	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
501240	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Clear of Trash?	y	
501241	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
501242	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
501243	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Ambient Temp	51	°F
501244	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
501245	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
501246	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
501247	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
501248	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
501249	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
501250	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
501251	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
501252	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
501253	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
501254	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
501255	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
501256	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
501257	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
501258	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
501259	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
501260	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
501261	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
501262	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
501263	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
501264	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
501265	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Follow-up Action Required?	n	
501266	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Foundation Condition	Good	
501267	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	General Comments		
501268	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Grounds in Place?	y	
501269	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
501270	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	LTCC000143	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
501271	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	LTCC000143	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
501272	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	LTCC000143	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
501273	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	LTCC000143	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
501274	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
501275	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
501276	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
501277	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
501278	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
501279	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
501280	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
501281	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
501282	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
501283	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
501284	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
501285	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LTCC000226	LTCControl	AB-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
501286	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LTCC000226	LTCControl	AB-TRANS 2	LTC Control Insp	General Comments		
501287	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LTCC000226	LTCControl	AB-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
501288	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
501289	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PF000348	PowerFuse	SW-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
501290	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PF000348	PowerFuse	SW-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
501291	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PF000349	PowerFuse	SW-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
501292	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PF000349	PowerFuse	SW-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
501293	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
501294	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
501295	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
501296	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
501297	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	122071	
501298	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	122071	
501299	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
501300	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	10L	
501301	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	2L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
501302	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	13L	
501303	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	396	
501304	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
501305	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
501306	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
501307	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
501308	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
501309	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
501310	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
501311	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
501312	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
501313	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
501314	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
501315	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	General Comments		
501316	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
501317	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
501318	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Operations Counter	0	
501319	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
501320	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
501321	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X3 Winding Temp Present	35	°C
501322	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X3 Winding Temp Max	35	°C
501323	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X2 Winding Temp Present	35	°C
501324	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X2 Winding Temp Max	35	°C
501325	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Present	35	°C
501326	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Max	40	°C
501327	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
501328	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
501329	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
501330	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Bushing Condition	Good	
501331	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
501332	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
501333	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
501334	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Bushings Connection/Risers	Good	
501335	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Bushing Condition	Good	
501336	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
501337	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
501338	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
501339	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
501340	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Patrol Inspection	General Comments		
501341	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
501342	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
501343	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
501344	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
501345	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
501346	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
501347	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
501348	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
501349	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
501350	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
501351	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
501352	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
501353	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
501354	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
501355	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	General Comments		
501356	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
501357	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
501358	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
501359	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
501360	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
501361	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
501362	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
501363	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
501364	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
501365	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
501366	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
501367	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
501368	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
501369	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
501370	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
501371	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
501372	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
501373	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
501374	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
501375	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
501376	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
501377	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
501378	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
501379	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
501380	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
501381	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
501382	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
501383	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	40	°C
501384	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
501385	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
501386	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
501387	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
501388	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	40	°C
501389	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.8	psi
501390	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
501391	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
501392	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	8L	
501393	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
501394	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	122266	
501395	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	122266	
501396	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments	LEVEL ON HIGH. TRANSFORMER IS A LITTLE LOW	
501397	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
501398	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
501399	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
501400	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
501401	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
501402	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
501403	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BCH000973	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
501404	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BCH000973	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
501405	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BCH000973	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
501406	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BCH000973	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
501407	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BCH000973	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	134.4	VDC
501408	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BCH000973	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	134.4	VDC
501409	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
501410	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
501411	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
501412	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
501413	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	General Comments		
501414	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
501415	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
501416	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
501417	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
501418	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
501419	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
501420	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
501421	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
501422	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Regulator As Left Counter	27752	
501423	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
501424	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
501425	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Tank Leaks	None	
501426	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
501427	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
501428	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
501429	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
501430	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Tank Paint Condition	Good	
501431	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
501432	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Moisture and Leak Free?	y	
501433	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Heaters (All) Functioning?	y	
501434	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Grounds in Place?	y	
501435	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	General Comments		
501436	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Foundation Condition	Good	
501437	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Follow-up Action Required?	n	
501438	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Equipment Properly Labeled?	y	
501439	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
501440	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
501441	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
501442	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
501443	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Cabinet Paint Condition	Good	
501444	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
501445	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
501446	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
501447	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
501448	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
501449	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
501450	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
501451	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
501452	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
501453	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
501454	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
501455	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
501456	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
501457	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
501458	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
501459	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
501460	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
501461	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
501462	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
501463	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
501464	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
501465	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
501466	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
501467	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
501468	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
501469	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
501470	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
501471	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
501472	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
501473	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
501474	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
501475	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
501476	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
501477	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
501478	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
501479	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
501480	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
501481	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
501482	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
501483	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
501484	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
501485	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	General Comments		
501486	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
501487	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
501488	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
501489	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
501490	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
501491	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
501492	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
501493	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
501494	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
501495	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
501496	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
501497	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
501498	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PF000347	PowerFuse	SW-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
501499	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PF000347	PowerFuse	SW-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
501500	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PF000346	PowerFuse	SW-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
501501	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PF000346	PowerFuse	SW-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
501502	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
501503	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	General Comments	ok	
501504	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
501505	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
501506	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
501507	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
501508	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
501509	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
501510	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
501511	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
501512	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
501513	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments	OK	
501514	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
501515	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
501516	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
501517	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
501518	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
501519	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
501520	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
501521	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	General Comments		
501522	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
501523	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
501524	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
501525	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
501526	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
501527	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
501528	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
501529	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
501530	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
501531	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
501532	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
501533	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
501534	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
501535	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
501536	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Foundation Condition	Good	
501537	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
501538	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
501539	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
501540	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
501541	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
501542	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
501543	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
501544	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
501545	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
501546	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	General Comments		
501547	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
501548	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Foundation Condition	Good	
501549	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
501550	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
501551	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Trash Emptied?	y	
501552	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
501553	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
501554	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
501555	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
501556	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
501557	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
501558	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
501559	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.030	millivolts
501560	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	27.1	VDC
501561	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	27.1	VDC
501562	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
501563	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
501564	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
501565	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	General Comments		
501566	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
501567	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
501568	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
501569	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
501570	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
501571	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
501572	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
501573	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
501574	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
501575	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
501576	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Foundation Condition	Good	
501577	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
501578	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	General Comments	ok	
501579	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
501580	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
501581	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
501582	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
501583	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
501584	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
501585	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
501586	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
501587	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
501588	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
501589	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
501590	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
501591	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
501592	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
501593	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
501594	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	754	
501595	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
501596	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
501597	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
501598	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
501599	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
501600	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
501601	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
501602	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
501603	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC As Left Counter	457669	
501604	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC As Found Counter	457669	
501605	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
501606	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
501607	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
501608	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	Vegetation	None	
501609	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
501610	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
501611	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
501612	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
501613	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
501614	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
501615	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
501616	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
501617	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	General Comments		
501618	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
501619	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
501620	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
501621	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
501622	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
501623	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
501624	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	Clear of Trash?	y	
501625	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
501626	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
501627	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	General Comments		
501628	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
501629	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
501630	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
501631	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
501632	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	379	
501633	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	11L	
501634	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	4L	
501635	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	9L	
501636	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
501637	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	134711	
501638	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	134711	
501639	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments	OK	
501640	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
501641	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
501642	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
501643	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	FE000450	Fence	417-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
501644	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	FE000450	Fence	417-Fence	Fence Patrol Inspection	General Comments		
501645	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	FE000450	Fence	417-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
501646	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	FE000450	Fence	417-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
501647	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	FE000450	Fence	417-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
501648	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	FE000450	Fence	417-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
501649	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	FE000450	Fence	417-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
501650	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
501651	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
501652	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
501653	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
501654	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
501655	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
501656	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
501657	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
501658	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	FE000450	Fence	417-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
501659	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
501660	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
501661	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	Follow-up Action Required?	n	
501662	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
501663	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	General Comments		
501664	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	General Comments		
501665	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC As Found Counter	61808	
501666	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC As Left Counter	61815	
501667	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
501668	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC Current Tap Position	2L	
501669	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC Max Tap Position	2R	
501670	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC Min Tap Position	4L	
501671	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC Operations Since Last Insp	75	
501672	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
501673	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
501674	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
501675	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LTCC000433	LTCControl	HC-TRANS 2	LTC Control Insp	All Connections OK?	y	
501676	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LTCC000433	LTCControl	HC-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
501677	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
501678	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
501679	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
501680	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
501681	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
501682	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
501683	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
501684	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	Winding Temp Max	85	°C
501685	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.8700	
501686	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
501687	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
501688	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
501689	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
501690	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
501691	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
501692	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
501693	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
501694	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Operational?	y	
501695	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
501696	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	55	°C
501697	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
501698	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
501699	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	12528.00	kw
501700	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
501701	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
501702	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
501703	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
501704	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
501705	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
501706	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
501707	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
501708	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
501709	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
501710	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
501711	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
501712	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
501713	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
501714	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
501715	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
501716	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
501717	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
501718	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
501719	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Patrol Inspection	General Comments	ok	
501720	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Patrol Inspection	Follow-up Action Required?	n	
501721	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
501722	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
501723	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
501724	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
501725	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
501726	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
501727	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
501728	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
501729	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
501730	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	General Comments	ok	
501731	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
501732	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
501733	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
501734	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
501735	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
501736	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
501737	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
501738	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	High	
501739	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	55	
501740	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	8L	
501741	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	6L	
501742	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
501743	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
501744	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Ambient Temp	51	°F
501745	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
501746	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
501747	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
501748	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	General Comments		
501749	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	General Comments	ok	
501750	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	ok	
501751	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC As Found Counter	88605	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
501752	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
501753	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
501754	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
501755	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
501756	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
501757	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	General Comments		
501758	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
501759	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
501760	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC As Left Counter	88605	
501761	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
501762	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
501763	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
501764	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
501765	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
501766	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	808	
501767	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
501768	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
501769	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
501770	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
501771	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
501772	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC As Left Counter	459120	
501773	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC As Found Counter	459120	
501774	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
501775	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	General Comments		
501776	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
501777	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
501778	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC Current Tap Position	12L	
501779	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
501780	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
501781	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	Winding Temp Present	40	°C
501782	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6L	
501783	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC Min Tap Position	16L	
501784	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Patrol Inspection	General Comments	ok	
501785	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Patrol Inspection	Follow-up Action Required?	n	
501786	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
501787	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
501788	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	545	
501789	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
501790	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
501791	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
501792	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
501793	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LTCC000433	LTCControl	HC-TRANS 2	LTC Control Insp	General Comments	ok	
501794	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LTCC000433	LTCControl	HC-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
501795	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PF001153	PowerFuse	SW-B 14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
501796	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	PF001153	PowerFuse	SW-B 14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
501797	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
501798	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
501799	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Patrol Inspection	General Comments		
501800	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
501801	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
501802	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
501803	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
501804	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
501805	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
501806	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
501807	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
501808	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
501809	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	General Comments		
501810	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
501811	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
501812	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
501813	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
501814	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Tank Leaks	None	
501815	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
501816	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
501817	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
501818	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
501819	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
501820	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
501821	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Reg Operation Checked?	n	
501822	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	0.0	volts
501823	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Regulator As Left Counter	424080	
501824	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Tank Leaks	None	
501825	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
501826	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
501827	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
501828	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
501829	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
501830	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Patrol Inspection	Follow-up Action Required?	n	
501831	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
501832	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
501833	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
501834	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
501835	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
501836	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Bushing Condition	Good	
501837	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Bushings Connection/Risers	Good	
501838	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
501839	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
501840	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
501841	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
501842	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
501843	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
501844	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
501845	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
501846	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
501847	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
501848	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
501849	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
501850	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
501851	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
501852	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
501853	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	689	
501854	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
501855	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
501856	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
501857	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
501858	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
501859	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
501860	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
501861	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
501862	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
501863	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
501864	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
501865	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
501866	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	General Comments		
501867	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
501868	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
501869	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Evidence of Insects	None	
501870	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
501871	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
501872	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Totalizer Meter Reading	.4692	
501873	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Winding Temp Max	32	°C
501874	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Winding Temp Present	22	°C
501875	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
501876	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
501877	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
501878	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
501879	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
501880	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Broom on Site?	y	
501881	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
501882	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
501883	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
501884	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
501885	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
501886	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	General Comments		
501887	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
501888	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	Follow-up Action Required?	n	
501889	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
501890	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Regulator As Left Counter	10121	
501891	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
501892	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
501893	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Tank Leaks	None	
501894	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
501895	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
501896	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
501897	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
501898	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
501899	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	36	
501900	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	2.0	
501901	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	1.2	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
501902	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	20.9	
501903	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	39	
501904	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
501905	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
501906	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
501907	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
501908	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Clear of Trash?	y	
501909	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
501910	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
501911	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
501912	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
501913	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
501914	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
501915	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
501916	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
501917	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
501918	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
501919	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
501920	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
501921	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	62	
501922	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
501923	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
501924	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
501925	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
501926	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
501927	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
501928	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
501929	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
501930	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
501931	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
501932	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Cabinet Paint Condition	Good	
501933	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Equipment Properly Labeled?	y	
501934	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Follow-up Action Required?	n	
501935	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Foundation Condition	Good	
501936	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	General Comments		
501937	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Grounds in Place?	y	
501938	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Moisture and Leak Free?	y	
501939	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
501940	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Tank Paint Condition	Good	
501941	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
501942	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
501943	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Current Tap Position	11L	
501944	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
501945	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
501946	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC Operations Since Last Insp	241	
501947	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
501948	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC Min Tap Position	8L	
501949	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC Max Tap Position	4L	
501950	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC Current Tap Position	6L	
501951	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
501952	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments		
501953	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
501954	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
501955	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
501956	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
501957	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
501958	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	General Comments		
501959	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
501960	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
501961	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Min Tap Position	2L	
501962	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
501963	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC As Left Counter	46488	
501964	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC As Found Counter	46488	
501965	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	General Comments		
501966	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
501967	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Oil Temp Max	32	°C
501968	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
501969	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
501970	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
501971	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
501972	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	General Comments		
501973	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
501974	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
501975	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
501976	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
501977	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
501978	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
501979	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
501980	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
501981	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	186	
501982	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	12L	
501983	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	2L	
501984	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	10L	
501985	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
501986	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
501987	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
501988	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
501989	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
501990	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
501991	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	General Comments		
501992	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
501993	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
501994	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
501995	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
501996	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	114612	
501997	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	114612	
501998	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
501999	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
502000	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
502001	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
502002	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
502003	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
502004	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Follow-up Action Required?	y	
502005	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Foundation Condition	Crumbling	
502006	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
502007	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	General Comments		
502008	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
502009	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
502010	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
502011	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
502012	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
502013	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
502014	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Regulator As Left Counter	85445	
502015	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
502016	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
502017	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
502018	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
502019	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
502020	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
502021	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
502022	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
502023	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
502024	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
502025	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
502026	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
502027	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
502028	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
502029	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
502030	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
502031	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
502032	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
502033	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
502034	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
502035	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
502036	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
502037	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
502038	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
502039	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
502040	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
502041	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
502042	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
502043	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
502044	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	LTC Totalizer Reading	4504.32	kw
502045	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
502046	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
502047	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
502048	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
502049	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
502050	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
502051	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
502052	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
502053	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Oil Temp Present	22	°C
502054	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
502055	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
502056	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
502057	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
502058	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
502059	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Trash Emptied?	y	
502060	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
502061	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
502062	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
502063	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
502064	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
502065	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
502066	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
502067	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
502068	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
502069	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
502070	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
502071	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
502072	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
502073	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Panels Dusted?	y	
502074	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
502075	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
502076	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
502077	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	General Comments	ok	
502078	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
502079	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
502080	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
502081	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
502082	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
502083	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	6.0	amps
502084	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
502085	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
502086	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.800	millivolts
502087	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
502088	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Floor Swept?	y	
502089	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
502090	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	General Comments	Distribution pads crumbling on 660	
502091	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
502092	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
502093	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
502094	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
502095	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
502096	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
502097	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
502098	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
502099	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
502100	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
502101	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
502102	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
502103	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
502104	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
502105	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
502106	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
502107	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
502108	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
502109	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
502110	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
502111	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
502112	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
502113	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
502114	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
502115	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Tank Leaks	None	
502116	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
502117	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
502118	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Regulator As Left Counter	28364	
502119	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Foundation Condition	Good	
502120	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	General Comments		
502121	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Grounds in Place?	y	
502122	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
502123	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
502124	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
502125	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Tank Paint Condition	Good	
502126	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
502127	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
502128	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
502129	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
502130	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
502131	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Bushing Condition	Good	
502132	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Bushings Connection/Risers	Good	
502133	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
502134	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
502135	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
502136	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Cabinet Paint Condition	Good	
502137	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Equipment Properly Labeled?	y	
502138	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Follow-up Action Required?	n	
502139	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Foundation Condition	Good	
502140	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	General Comments		
502141	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Bushings Connection/Risers	Good	
502142	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
502143	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
502144	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
502145	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Cabinet Paint Condition	Good	
502146	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	n	If no, which cells in comments
502147	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
502148	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
502149	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Grounds in Place?	y	
502150	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Moisture and Leak Free?	y	
502151	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Equipment Properly Labeled?	y	
502152	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Follow-up Action Required?	n	
502153	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Foundation Condition	Good	
502154	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	General Comments		
502155	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	51	°F
502156	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
502157	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
502158	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Tank Paint Condition	Good	
502159	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
502160	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
502161	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
502162	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
502163	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
502164	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Grounds in Place?	y	
502165	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Heaters (All) Functioning?	y	
502166	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
502167	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
502168	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
502169	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
502170	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
502171	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	Follow-up Action Required?	n	
502172	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
502173	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
502174	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	multiple cells have bad post. batteries have a workorder to be replaced	
502175	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
502176	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC Max Tap Position	2L	
502177	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
502178	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
502179	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
502180	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
502181	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
502182	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	General Comments		
502183	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
502184	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
502185	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
502186	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
502187	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Vegetation	None	
502188	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
502189	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
502190	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	172	
502191	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
502192	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
502193	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
502194	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
502195	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
502196	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC Current Tap Position	5L	
502197	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
502198	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
502199	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
502200	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
502201	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
502202	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	Oil Temp Max	36	°C
502203	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
502204	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
502205	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
502206	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
502207	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
502208	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BCH000551	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
502209	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BCH000551	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
502210	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LTCC000401	LTCControl	AB-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
502211	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LTCC000401	LTCControl	AB-TRANS 1	LTC Control Insp	General Comments		
502212	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LTCC000401	LTCControl	AB-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
502213	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
502214	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC As Left Counter	74105	
502215	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC As Found Counter	74101	
502216	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
502217	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
502218	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
502219	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
502220	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
502221	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
502222	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
502223	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
502224	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
502225	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
502226	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
502227	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
502228	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	50	°C
502229	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
502230	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	38	°C
502231	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
502232	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
502233	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
502234	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
502235	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	65	°C
502236	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
502237	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
502238	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	55	°C
502239	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	55	°C
502240	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
502241	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	General Comments		
502242	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
502243	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
502244	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
502245	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
502246	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
502247	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	General Comments		
502248	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
502249	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
502250	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
502251	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	42	°C
502252	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	42	°C
502253	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	42	°C
502254	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
502255	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
502256	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	General Comments	ok	
502257	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
502258	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	General Comments	shanged fans to bank2 for2019	
502259	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
502260	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Moisture and Leak Free?	y	
502261	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
502262	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Tank Paint Condition	Good	
502263	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	General Comments		
502264	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
502265	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Foundation Condition	Good	
502266	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
502267	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
502268	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
502269	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
502270	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
502271	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
502272	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
502273	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	Oil Temp Max	42	°C
502274	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	24	°C
502275	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	36	°C
502276	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	26	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
502277	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	38	°C
502278	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	Oil Temp Present	38	°C
502279	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
502280	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	26	°C
502281	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
502282	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
502283	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
502284	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
502285	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
502286	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
502287	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
502288	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC As Left Counter	66474	
502289	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC As Found Counter	66474	
502290	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	ok	
502291	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	General Comments	ok	
502292	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
502293	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
502294	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
502295	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
502296	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	General Comments		
502297	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
502298	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
502299	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
502300	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
502301	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
502302	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
502303	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
502304	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
502305	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Vegetation	None	
502306	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
502307	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
502308	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
502309	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
502310	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
502311	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
502312	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
502313	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
502314	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
502315	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
502316	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
502317	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
502318	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
502319	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
502320	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Amps A Ø	13.0	
502321	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Amps B Ø	13.0	
502322	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Amps C Ø	16.0	
502323	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
502324	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
502325	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
502326	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
502327	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
502328	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
502329	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	General Comments		
502330	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
502331	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
502332	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
502333	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
502334	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
502335	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
502336	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
502337	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
502338	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
502339	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
502340	4/3/2019 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
502341	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
502342	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
502343	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	General Comments		
502344	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
502345	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
502346	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Vegetation	None	
502347	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
502348	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
502349	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BCH000551	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
502350	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BCH000551	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
502351	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
502352	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
502353	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
502354	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
502355	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
502356	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Good	
502357	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BCH000551	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
502358	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BCH000551	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.5	amps
502359	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
502360	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
502361	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
502362	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	General Comments		
502363	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
502364	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
502365	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
502366	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
502367	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
502368	4/3/2019 15:08	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
502369	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
502370	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
502371	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
502372	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Clear of Trash?	y	
502373	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
502374	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
502375	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
502376	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
502377	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
502378	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
502379	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
502380	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
502381	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
502382	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
502383	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
502384	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
502385	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
502386	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
502387	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
502388	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
502389	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	General Comments		
502390	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
502391	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
502392	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
502393	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
502394	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Tank Leaks	None	
502395	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
502396	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Regulator As Left Counter	848902	
502397	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	0.0	volts
502398	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Reg Operation Checked?	n	
502399	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
502400	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC Operations Since Last Insp	462	
502401	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
502402	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
502403	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
502404	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
502405	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
502406	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
502407	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Clear of Trash?	y	
502408	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC Min Tap Position	9L	
502409	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
502410	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
502411	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
502412	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
502413	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	General Comments		
502414	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
502415	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
502416	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
502417	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
502418	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
502419	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
502420	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
502421	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
502422	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Foundation Condition	Good	
502423	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
502424	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
502425	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
502426	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
502427	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
502428	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
502429	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
502430	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	42	°C
502431	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	42	°C
502432	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	42	°C
502433	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
502434	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
502435	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
502436	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
502437	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	General Comments		
502438	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
502439	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
502440	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
502441	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
502442	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
502443	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
502444	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
502445	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
502446	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
502447	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
502448	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
502449	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
502450	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
502451	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
502452	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
502453	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
502454	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
502455	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Clear of Trash?	y	
502456	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
502457	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
502458	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
502459	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Bushing Condition	Good	
502460	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	General Comments		
502461	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
502462	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
502463	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
502464	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
502465	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
502466	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
502467	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
502468	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
502469	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
502470	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
502471	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
502472	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
502473	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
502474	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
502475	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
502476	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
502477	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
502478	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
502479	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
502480	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
502481	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
502482	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
502483	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
502484	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
502485	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	General Comments		
502486	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
502487	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
502488	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
502489	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	General Comments		
502490	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
502491	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
502492	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	Oil Temp Max	68	°C
502493	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	Oil Temp Present	38	°C
502494	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
502495	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
502496	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
502497	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
502498	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
502499	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
502500	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
502501	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
502502	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
502503	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
502504	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
502505	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
502506	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
502507	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
502508	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
502509	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
502510	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
502511	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
502512	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
502513	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
502514	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
502515	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
502516	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
502517	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
502518	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
502519	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
502520	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
502521	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Oil Temp Present	34	°C
502522	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
502523	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
502524	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	115.00	
502525	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
502526	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	68	°C
502527	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	38	°C
502528	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
502529	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
502530	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
502531	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
502532	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
502533	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
502534	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
502535	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
502536	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
502537	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	General Comments		
502538	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	51	°F
502539	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspectior	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
502540	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	General Comments		
502541	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Follow-up Action Required?	n	
502542	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Evidence of Insects	None	
502543	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
502544	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
502545	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
502546	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
502547	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
502548	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
502549	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
502550	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
502551	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
502552	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
502553	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Patrol Inspection	General Comments		
502554	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
502555	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
502556	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
502557	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
502558	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
502559	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
502560	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2963.52	kw
502561	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
502562	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
502563	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Oil Temp Max	38	°C
502564	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
502565	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Oil Temp Present	28	°C
502566	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
502567	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
502568	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
502569	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
502570	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Oil Temp Present	35	°C
502571	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
502572	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
502573	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Oil Temp Max	60	°C
502574	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
502575	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
502576	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
502577	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
502578	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
502579	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
502580	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
502581	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
502582	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
502583	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
502584	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
502585	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
502586	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
502587	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
502588	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
502589	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
502590	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
502591	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
502592	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
502593	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
502594	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
502595	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
502596	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
502597	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
502598	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
502599	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Follow-up Action Required?	n	
502600	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
502601	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
502602	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	General Comments		
502603	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	General Comments		
502604	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
502605	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	LTC Totalizer Reading	6614.40	kw
502606	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Patrol Inspection	Equipment Properly Labeled?	y	
502607	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
502608	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Patrol Inspection	Follow-up Action Required?	n	
502609	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Patrol Inspection	General Comments	ok	
502610	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
502611	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
502612	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
502613	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
502614	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
502615	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
502616	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
502617	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	General Comments		
502618	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
502619	4/3/2019 10:13	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
502620	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
502621	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
502622	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Broom on Site?	y	
502623	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
502624	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
502625	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
502626	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
502627	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
502628	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	ok	
502629	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
502630	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
502631	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
502632	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
502633	4/3/2019 15:08	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
502634	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
502635	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Patrol Inspection	General Comments		
502636	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Patrol Inspection	Follow-up Action Required?	n	
502637	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
502638	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
502639	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
502640	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Tank Leaks	None	
502641	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
502642	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
502643	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Regulator As Left Counter	86058	
502644	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
502645	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
502646	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
502647	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
502648	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
502649	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
502650	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
502651	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
502652	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
502653	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
502654	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
502655	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
502656	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.2348	
502657	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
502658	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
502659	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
502660	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
502661	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
502662	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
502663	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
502664	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
502665	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
502666	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
502667	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
502668	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
502669	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
502670	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	General Comments		
502671	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
502672	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
502673	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
502674	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
502675	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
502676	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
502677	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
502678	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
502679	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
502680	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
502681	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	LTCC000816	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
502682	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	LTCC000816	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
502683	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	LTCC000816	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
502684	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
502685	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
502686	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
502687	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
502688	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
502689	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	LTCC000816	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
502690	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	LTCC000816	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Operation Checked?	y	
502691	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LTCC000520	LTCControl	HC-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
502692	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
502693	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
502694	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
502695	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
502696	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
502697	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
502698	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LTCC000520	LTCControl	HC-TRANS 1	LTC Control Insp	General Comments	ok	
502699	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
502700	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	LTCC000816	LTCControl	932-Offline Distribution	LTC Control Insp	General Comments		
502701	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
502702	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
502703	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
502704	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Tank Leaks	None	
502705	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
502706	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
502707	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Tank Leaks	None	
502708	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
502709	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
502710	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Regulator As Left Counter	116935	
502711	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
502712	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
502713	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
502714	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
502715	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
502716	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
502717	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
502718	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
502719	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	General Comments		
502720	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
502721	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
502722	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
502723	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Operations Counter	6	
502724	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
502725	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
502726	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
502727	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
502728	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
502729	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
502730	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
502731	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Bushing Condition	Good	
502732	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
502733	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
502734	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
502735	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
502736	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
502737	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
502738	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
502739	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
502740	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
502741	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
502742	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
502743	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
502744	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Patrol Inspection	General Comments		
502745	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
502746	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
502747	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
502748	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
502749	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
502750	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
502751	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
502752	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
502753	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
502754	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
502755	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
502756	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
502757	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
502758	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
502759	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	LTCC000816	LTCControl	932-Offline Distribution	LTC Control Insp	Follow-up Action Required?	n	
502760	4/3/2019 11:10	Distribution	Wilson Downing Quarterly Inspection	LTCC000816	LTCControl	932-Offline Distribution	LTC Control Insp	All Connections OK?	y	
502761	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Amps A Ø	68.0	
502762	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Amps B Ø	65.0	
502763	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Amps C Ø	70.0	
502764	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
502765	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
502766	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
502767	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
502768	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
502769	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
502770	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
502771	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
502772	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
502773	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
502774	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	General Comments		
502775	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
502776	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
502777	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
502778	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
502779	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
502780	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
502781	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
502782	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
502783	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
502784	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
502785	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	LTCC000456	LTCControl	977-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
502786	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
502787	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
502788	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
502789	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
502790	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
502791	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
502792	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
502793	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	LTCC000456	LTCControl	977-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	117.0	VAC
502794	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	LTCC000456	LTCControl	977-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
502795	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
502796	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	LTCC000456	LTCControl	977-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
502797	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	LTCC000456	LTCControl	977-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
502798	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
502799	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Bushings Connection/Risers	Good	
502800	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Patrol Inspection	General Comments		
502801	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Panel Lights OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
502802	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
502803	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Bushing Condition	Good	
502804	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
502805	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	PF000030	PowerFuse	AB-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
502806	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	PF000030	PowerFuse	AB-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
502807	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	General Comments	restroom out of order	
502808	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
502809	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	PF000029	PowerFuse	AB-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
502810	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	PF000029	PowerFuse	AB-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
502811	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	General Comments		
502812	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC Min Tap Position	16L	
502813	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
502814	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	General Comments		
502815	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	General Comments	added nitrogen	
502816	4/3/2019 15:08	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
502817	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
502818	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
502819	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Floor Swept?	y	
502820	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
502821	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
502822	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Broom on Site?	y	
502823	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
502824	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
502825	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
502826	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
502827	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
502828	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
502829	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
502830	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	PF000028	PowerFuse	AB-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
502831	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	PF000028	PowerFuse	AB-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
502832	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
502833	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	General Comments		
502834	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
502835	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
502836	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
502837	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
502838	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
502839	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
502840	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
502841	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
502842	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
502843	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Grounds in Place?	y	
502844	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
502845	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
502846	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	General Comments		
502847	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Foundation Condition	Good	
502848	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
502849	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	General Comments		
502850	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Follow-up Action Required?	n	
502851	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Equipment Properly Labeled?	y	
502852	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
502853	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
502854	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
502855	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
502856	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
502857	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC Max Tap Position	3L	
502858	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
502859	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
502860	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
502861	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
502862	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
502863	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Trash Emptied?	y	
502864	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Heaters (All) Functioning?	y	
502865	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
502866	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
502867	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Moisture and Leak Free?	y	
502868	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
502869	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
502870	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
502871	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Tank Paint Condition	Good	
502872	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC Current Tap Position	7L	
502873	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
502874	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC As Left Counter	85761	
502875	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC As Found Counter	85755	
502876	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
502877	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
502878	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
502879	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
502880	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	General Comments		
502881	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	General Comments		
502882	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
502883	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
502884	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
502885	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
502886	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	LTCC000456	LTCControl	977-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
502887	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	LTCC000456	LTCControl	977-Offline-Distribution	LTC Control Insp	General Comments		
502888	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	LTCC000456	LTCControl	977-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
502889	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	Follow-up Action Required?	n	
502890	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Cabinet Paint Condition	Good	
502891	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
502892	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LTCC000520	LTCControl	HC-TRANS 1	LTC Control Insp	All Connections OK?	y	
502893	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LTCC000520	LTCControl	HC-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
502894	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Restroom Clean & OK?	n	
502895	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Panels Dusted?	y	
502896	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
502897	4/3/2019 9:52	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
502898	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
502899	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	General Comments		
502900	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
502901	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
502902	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Follow-up Action Required?	n	
502903	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
502904	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
502905	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
502906	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
502907	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Totalizer Meter Reading	.6890	
502908	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
502909	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
502910	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Panels Dusted?	y	
502911	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
502912	4/3/2019 10:59	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
502913	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
502914	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
502915	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
502916	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
502917	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
502918	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
502919	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Floor Swept?	y	
502920	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
502921	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
502922	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
502923	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
502924	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
502925	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	General Comments		
502926	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
502927	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Trash Emptied?	y	
502928	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
502929	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	General Comments		
502930	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
502931	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
502932	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Evidence of Insects	None	
502933	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
502934	4/3/2019 9:02	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
502935	4/3/2019 11:30	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
502936	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC Operations Since Last Insp	885	
502937	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
502938	4/3/2019 14:54	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
502939	4/3/2019 10:58	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
502940	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
502941	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
502942	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
502943	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
502944	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Moisture and Leak Free?	y	
502945	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
502946	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	110.0	
502947	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Heaters (All) Functioning?	y	
502948	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	
502949	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0	%
502950	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Grounds in Place?	y	
502951	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
502952	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	General Comments		
502953	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
502954	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
502955	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
502956	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0	%
502957	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	General Comments		
502958	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
502959	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Unknown Operations	0	
502960	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0	%
502961	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	15	
502962	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
502963	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
502964	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Oil Temp Max	50	°C
502965	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Unknown Operations	0	
502966	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Switching Operations	3	
502967	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
502968	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Oil Temp Present	30	°C
502969	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Operations This Read Vac	3	
502970	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Operations Counter AL	48	
502971	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Operations Counter AF	48	
502972	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Switching Operations	0	
502973	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Operations This Read Oil	0	
502974	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Foundation Condition	Good	
502975	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
502976	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
502977	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Follow-up Action Required?	n	
502978	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
502979	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Operations Counter AL	0	
502980	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
502981	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	General Comments		
502982	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	General Comments		
502983	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Amps C Ø	480.0	
502984	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
502985	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Amps B Ø	460.0	
502986	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
502987	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
502988	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
502989	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Follow-up Action Required?	n	
502990	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Amps A Ø	420.0	
502991	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
502992	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Accumulated Fault Duty C Ph AM	6.18	%
502993	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Accumulated Fault Duty B Ph AM	6.18	%
502994	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	VRR Base Voltage AF	125	VAC
502995	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
502996	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
502997	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC As Found Counter	18731	
502998	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC As Left Counter	18731	
502999	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
503000	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Accumulated Fault Duty A Ph AM	5.56	%
503001	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
503002	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3R	
503003	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
503004	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.1	psi
503005	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	9 Months Operations	5	
503006	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	LTC Totalizer Reading	512	kw
503007	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
503008	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
503009	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	394	
503010	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Patrol Inspection	General Comments		
503011	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
503012	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
503013	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
503014	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
503015	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
503016	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
503017	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
503018	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	100.0	
503019	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Patrol Inspection	Follow-up Action Required?	n	
503020	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Patrol Inspection	Equipment Properly Labeled?	y	
503021	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
503022	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	PF000022	PowerFuse	AS-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
503023	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
503024	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	PF000022	PowerFuse	AS-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
503025	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Tank Paint Condition	Good	
503026	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
503027	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Bushing Condition	Good	
503028	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
503029	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
503030	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
503031	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Accumulated Fault Duty B Ph V	.8	%
503032	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	9 Months Operations	2	
503033	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ok	
503034	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Maintenance Operations	0	
503035	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
503036	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	General Comments	ok	
503037	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
503038	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
503039	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Follow-up Action Required?	n	
503040	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
503041	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Number of Ops last 9 Months	0	
503042	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Fault Operations	0	
503043	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Follow-up Action Required?	n	
503044	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	General Comments	couldn't find	
503045	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Maintenance Operations	0	
503046	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
503047	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Amps C Ø	100.0	
503048	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Amps B Ø	100.0	
503049	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Amps A Ø	100.0	
503050	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
503051	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
503052	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
503053	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
503054	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
503055	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	9 Month Operations	20	
503056	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Accumulated Fault Duty A Ph V	0	%
503057	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Bushings Connection/Risers	Good	
503058	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
503059	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Accumulated Fault Duty B Ph AM	0	%
503060	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Operations Ground	0	
503061	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	General Comments	Nitro cyl at 0 PSI needs gas. Changed fans to bank 1 for 2019.	
503062	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Operations C Ø	0	
503063	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
503064	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
503065	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Operations B Ø	0	
503066	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Operations A Ø	0	
503067	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
503068	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
503069	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Accumulated Fault Duty A Ph AM	0	%
503070	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
503071	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
503072	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Amps C Ø	200.0	
503073	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Amps B Ø	190.0	
503074	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
503075	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Amps A Ø	160.0	
503076	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
503077	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
503078	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Equipment Properly Labeled?	y	
503079	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Cabinet Paint Condition	Good	
503080	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Operations Counter AF	0	
503081	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Operations A Ø	0	
503082	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Operations B Ø	0	
503083	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Operations C Ø	0	
503084	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
503085	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
503086	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Operations Ground	0	
503087	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Follow-up Action Required?	n	
503088	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	General Comments	ok	
503089	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Maintenance Operations	0	
503090	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Operations Counter AF	919	
503091	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
503092	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	General Comments		
503093	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
503094	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
503095	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
503096	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
503097	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
503098	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
503099	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
503100	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
503101	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
503102	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Operations A Ø	0	
503103	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Operations B Ø	0	
503104	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Operations C Ø	0	
503105	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Operations Ground	0	
503106	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Follow-up Action Required?	n	
503107	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
503108	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
503109	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	General Comments	ok	
503110	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Maintenance Operations	0	
503111	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Operations Counter AF	570	
503112	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Operations Counter AL	570	
503113	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Operations This Read AM	0	
503114	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Switching Operations	0	
503115	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
503116	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
503117	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
503118	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Unknown Operations	0	
503119	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
503120	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
503121	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Amps A Ø	0.0	
503122	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
503123	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
503124	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Amps B Ø	0.0	
503125	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Amps C Ø	0.0	
503126	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
503127	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
503128	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Operations Counter AL	919	
503129	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Operations This Read AM	0	
503130	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Switching Operations	0	
503131	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Unknown Operations	0	
503132	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
503133	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Accumulated Fault Duty B Ph AM	1.23	%
503134	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Accumulated Fault Duty A Ph AM	1.23	%
503135	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	9 Months Operations	0	
503136	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
503137	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
503138	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
503139	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
503140	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
503141	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
503142	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
503143	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
503144	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
503145	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
503146	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
503147	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
503148	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
503149	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
503150	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
503151	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
503152	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
503153	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	9 Month Operations	42	
503154	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	51	
503155	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	51	
503156	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
503157	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	VRR Time Delay	30	Seconds
503158	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
503159	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
503160	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
503161	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	°C
503162	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	45	°C
503163	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	37	°C
503164	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
503165	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	General Comments		
503166	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
503167	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
503168	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
503169	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
503170	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
503171	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
503172	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
503173	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
503174	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
503175	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Amps A Ø	25.0	
503176	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
503177	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Amps B Ø	25.0	
503178	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
503179	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
503180	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
503181	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
503182	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
503183	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
503184	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
503185	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Operations Counter AF	697	
503186	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Maintenance Operations	0	
503187	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	General Comments	open	
503188	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
503189	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
503190	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
503191	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Operations This Read AM	0	
503192	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Operations Counter AL	870	
503193	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
503194	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Switching Operations	0	
503195	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
503196	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
503197	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
503198	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
503199	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
503200	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Operations Counter AF	870	
503201	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Maintenance Operations	0	
503202	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	General Comments	ok	
503203	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Follow-up Action Required?	n	
503204	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Operations Ground	0	
503205	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Operations C Ø	0	
503206	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Operations B Ø	0	
503207	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Operations A Ø	0	
503208	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
503209	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
503210	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
503211	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Amps C Ø	50.0	
503212	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Amps B Ø	50.0	
503213	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Amps A Ø	50.0	
503214	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
503215	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
503216	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Follow-up Action Required?	n	
503217	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
503218	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Operations Ground	0	
503219	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	VRR Base Voltage AL	125	VAC
503220	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Operations C Ø	0	
503221	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Operations B Ø	0	
503222	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Operations A Ø	0	
503223	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
503224	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
503225	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
503226	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Amps C Ø	0.0	
503227	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Amps B Ø	0.0	
503228	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Amps A Ø	0.0	
503229	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Unknown Operations	0	
503230	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
503231	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
503232	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
503233	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
503234	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
503235	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Accumulated Fault Duty C Ph AM	1.23	%
503236	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
503237	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Patrol Inspection	Follow-up Action Required?	n	
503238	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Patrol Inspection	General Comments		
503239	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
503240	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	9 Months Operations	6	
503241	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Operations Counter AL	697	
503242	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
503243	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
503244	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	112	
503245	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	LTC Current Tap Position	5R	
503246	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
503247	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	LTC As Left Counter	56761	
503248	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
503249	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
503250	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
503251	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Operations This Read Vac	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
503252	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	LTC As Found Counter	56761	
503253	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Operations Counter AL	29	
503254	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
503255	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
503256	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
503257	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
503258	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
503259	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
503260	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
503261	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
503262	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
503263	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
503264	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Operations Counter AF	29	
503265	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Maintenance Operations	0	
503266	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	General Comments	ok	
503267	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
503268	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
503269	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
503270	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
503271	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	General Comments		
503272	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
503273	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
503274	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
503275	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
503276	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
503277	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1224	
503278	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
503279	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
503280	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
503281	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
503282	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	PF001203	PowerFuse	CF-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
503283	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
503284	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	PF001203	PowerFuse	CF-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	ok	
503285	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Totalizer Meter Reading	.16	
503286	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
503287	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
503288	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
503289	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
503290	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
503291	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
503292	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
503293	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
503294	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
503295	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
503296	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
503297	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
503298	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
503299	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
503300	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Amps C Ø	25.0	
503301	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
503302	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
503303	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
503304	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
503305	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
503306	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Operations A Ø	0	
503307	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Operations B Ø	0	
503308	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Operations C Ø	0	
503309	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Operations Ground	0	
503310	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Follow-up Action Required?	n	
503311	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	General Comments	ok	
503312	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Maintenance Operations	0	
503313	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Operations Counter AF	45	
503314	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Operations Counter AL	45	
503315	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Operations This Read Vac	0	
503316	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Switching Operations	0	
503317	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Unknown Operations	0	
503318	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
503319	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
503320	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
503321	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
503322	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
503323	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1224	
503324	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	42	°C
503325	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
503326	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	45	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
503327	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
503328	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Unknown Operations	0	
503329	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Switching Operations	0	
503330	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
503331	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
503332	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
503333	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
503334	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
503335	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
503336	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
503337	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
503338	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
503339	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
503340	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
503341	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
503342	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
503343	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
503344	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
503345	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
503346	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
503347	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
503348	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
503349	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
503350	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
503351	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
503352	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
503353	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
503354	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
503355	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
503356	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
503357	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
503358	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Amps A Ø	250.0	
503359	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
503360	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
503361	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
503362	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Accumulated Fault Duty C Ph AM	0	%
503363	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	PF000108	PowerFuse	CF-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
503364	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	PF000108	PowerFuse	CF-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
503365	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Accumulated Fault Duty B Ph AM	0	%
503366	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
503367	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
503368	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
503369	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
503370	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
503371	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
503372	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
503373	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
503374	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
503375	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	16	
503376	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	PF000107	PowerFuse	CF-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
503377	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	PF000107	PowerFuse	CF-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
503378	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
503379	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
503380	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
503381	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
503382	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	10.0	
503383	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	10.0	
503384	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	10.0	
503385	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
503386	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
503387	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Patrol Inspection	Follow-up Action Required?	n	
503388	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Patrol Inspection	General Comments		
503389	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	PF000024	PowerFuse	AS-GND TR 3	Disconnect Powerfuse Inspection	General Comments	ok	
503390	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	PF000024	PowerFuse	AS-GND TR 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
503391	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Accumulated Fault Duty A Ph AM	0	%
503392	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	9 Months Operations	14	
503393	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
503394	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
503395	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
503396	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
503397	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
503398	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
503399	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
503400	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
503401	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
503402	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
503403	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
503404	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
503405	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
503406	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
503407	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Clear of Trash?	y	
503408	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
503409	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
503410	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
503411	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Operations A Ø	0	
503412	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Operations B Ø	0	
503413	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Operations C Ø	0	
503414	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Operations A Ø	0	
503415	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
503416	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	General Comments	OK	
503417	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC As Found Counter	192382	
503418	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC As Left Counter	192382	
503419	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Current Tap Position	11L	
503420	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Max Tap Position	9L	
503421	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Min Tap Position	15L	
503422	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	369	
503423	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
503424	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
503425	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
503426	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LTCC000419	LTCControl	AS-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
503427	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Operations Ground	0	
503428	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
503429	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
503430	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
503431	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
503432	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
503433	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
503434	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	General Comments		
503435	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
503436	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
503437	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
503438	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
503439	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
503440	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
503441	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
503442	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
503443	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
503444	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
503445	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
503446	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Amps C Ø	200.0	
503447	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Amps B Ø	220.0	
503448	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	General Comments		
503449	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
503450	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
503451	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Unknown Operations	0	
503452	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Patrol Inspection	General Comments		
503453	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	10	
503454	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
503455	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
503456	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
503457	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Unknown Operations	0	
503458	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	10.0	
503459	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	10.0	
503460	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	10.0	
503461	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
503462	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
503463	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
503464	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
503465	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Patrol Inspection	Follow-up Action Required?	n	
503466	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Operations This Read Vac	3	
503467	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Switching Operations	0	
503468	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
503469	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
503470	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
503471	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Operations This Read AM	0	
503472	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
503473	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
503474	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
503475	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
503476	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
503477	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ok	
503478	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
503479	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1556	
503480	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1556	
503481	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	2	
503482	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	2	
503483	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
503484	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
503485	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
503486	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Unknown Operations	0	
503487	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Switching Operations	2	
503488	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Operations This Read AM	2	
503489	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Operations Counter AL	685	
503490	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Operations Counter AF	685	
503491	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Operations Counter AL	286	
503492	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Operations Counter AF	286	
503493	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Maintenance Operations	0	
503494	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	General Comments	ok	
503495	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Follow-up Action Required?	n	
503496	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Operations Ground	0	
503497	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Operations C Ø	0	
503498	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
503499	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
503500	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
503501	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
503502	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
503503	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
503504	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
503505	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
503506	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
503507	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
503508	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
503509	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
503510	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
503511	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
503512	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
503513	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
503514	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
503515	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
503516	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
503517	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Readings	General Comments		
503518	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Patrol Inspection	General Comments		
503519	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
503520	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
503521	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
503522	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
503523	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
503524	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
503525	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
503526	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
503527	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
503528	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Patrol Inspection	General Comments		
503529	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Patrol Inspection	Follow-up Action Required?	n	
503530	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Follow-up Action Required?	y	
503531	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	General Comments	the charge indicator is fall off . will send pic	
503532	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Maintenance Operations	0	
503533	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AF	42	
503534	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AL	42	
503535	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
503536	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
503537	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC Operations Since Last Insp	332	
503538	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC Min Tap Position	7L	
503539	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC Max Tap Position	3R	
503540	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC Current Tap Position	5L	
503541	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
503542	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC As Left Counter	270481	
503543	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC As Found Counter	270481	
503544	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	General Comments		
503545	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	General Comments		
503546	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
503547	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Unknown Operations	0	
503548	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
503549	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	9 Months Operations	0	
503550	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
503551	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
503552	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
503553	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
503554	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	9 Month Operations	19	
503555	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
503556	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
503557	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
503558	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Patrol Inspection	General Comments		
503559	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	General Comments		
503560	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
503561	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
503562	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
503563	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
503564	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
503565	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Patrol Inspection	General Comments		
503566	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Patrol Inspection	Follow-up Action Required?	n	
503567	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Patrol Inspection	Equipment Properly Labeled?	y	
503568	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
503569	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Bushing Condition	Good	
503570	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
503571	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
503572	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
503573	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
503574	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
503575	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
503576	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
503577	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Amps A Ø	0.0	
503578	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Amps B Ø	0.0	
503579	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
503580	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Amps C Ø	0.0	
503581	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
503582	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
503583	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
503584	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Unknown Operations	0	
503585	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Switching Operations	2	
503586	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Operations This Read AM	2	
503587	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Operations Counter AL	844	
503588	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Operations Counter AF	844	
503589	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
503590	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
503591	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
503592	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Maintenance Operations	0	
503593	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations B Ø	0	
503594	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
503595	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Foundation Condition	Good	
503596	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
503597	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	General Comments		
503598	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
503599	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
503600	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
503601	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
503602	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
503603	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Patrol Inspection	Follow-up Action Required?	n	
503604	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Patrol Inspection	General Comments		
503605	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
503606	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
503607	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
503608	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
503609	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
503610	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
503611	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
503612	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	General Comments		
503613	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
503614	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC As Found Counter	14914	
503615	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC As Left Counter	14914	
503616	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
503617	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC Current Tap Position	19R	
503618	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC Max Tap Position	21R	
503619	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC Min Tap Position	17R	
503620	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	19	
503621	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
503622	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
503623	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
503624	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations A Ø	0	
503625	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations C Ø	0	
503626	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
503627	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Follow-up Action Required?	n	
503628	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	General Comments	open	
503629	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Maintenance Operations	0	
503630	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Operations Counter AF	299	
503631	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
503632	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Operations Counter AL	299	
503633	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Operations This Read AM	0	
503634	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Switching Operations	0	
503635	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
503636	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
503637	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Amps C Ø	0.0	
503638	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Amps B Ø	0.0	
503639	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Amps A Ø	0.0	
503640	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
503641	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Follow-up Action Required?	n	
503642	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Operations Ground	0	
503643	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Operations C Ø	0	
503644	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Operations B Ø	0	
503645	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Operations A Ø	0	
503646	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
503647	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
503648	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
503649	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
503650	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
503651	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
503652	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
503653	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
503654	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
503655	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
503656	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Amps C Ø	0.0	
503657	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Amps B Ø	0.0	
503658	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Amps A Ø	0.0	
503659	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
503660	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Accumulated Fault Duty C Ph V	10.36	%
503661	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Accumulated Fault Duty B Ph V	10.36	%
503662	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Accumulated Fault Duty A Ph V	10.36	%
503663	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
503664	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
503665	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
503666	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
503667	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
503668	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
503669	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
503670	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
503671	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
503672	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
503673	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
503674	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	General Comments		
503675	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
503676	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	9 Month Operations	24	
503677	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
503678	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
503679	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
503680	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
503681	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
503682	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Operations Ground	0	
503683	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Operations C Ø	0	
503684	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
503685	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Operations B Ø	0	
503686	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
503687	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
503688	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	General Comments	ok	
503689	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
503690	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
503691	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
503692	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Vegetation	None	
503693	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1609	
503694	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1609	
503695	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
503696	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Unknown Operations	0	
503697	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Switching Operations	0	
503698	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Operations This Read Vac	0	
503699	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Operations Counter AL	44	
503700	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Operations Counter AF	44	
503701	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
503702	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	General Comments	ok	
503703	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Follow-up Action Required?	n	
503704	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations Ground	0	
503705	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ok	
503706	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
503707	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
503708	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
503709	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	General Comments		
503710	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
503711	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
503712	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations C Ø	0	
503713	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations B Ø	0	
503714	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations A Ø	0	
503715	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
503716	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
503717	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
503718	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Amps C Ø	120.0	
503719	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Amps B Ø	120.0	
503720	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Amps A Ø	150.0	
503721	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
503722	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
503723	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
503724	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	9 Month Operations	22	
503725	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	140	
503726	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	100	
503727	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	160	
503728	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Unknown Operations	0	
503729	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Follow-up Action Required?	n	
503730	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Switching Operations	0	
503731	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Operations This Read Vac	0	
503732	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Operations Counter AL	13	
503733	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Operations Counter AF	13	
503734	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Maintenance Operations	0	
503735	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	General Comments	open	
503736	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
503737	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	9 Months Operations	15	
503738	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Accumulated Fault Duty A Ph AM	4.94	%
503739	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Accumulated Fault Duty B Ph AM	4.94	%
503740	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
503741	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Accumulated Fault Duty C Ph AM	4.94	%
503742	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ok	
503743	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
503744	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
503745	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
503746	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Amps A Ø	140.0	
503747	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	PF000025	PowerFuse	AS-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
503748	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	PF000025	PowerFuse	AS-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
503749	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
503750	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
503751	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
503752	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
503753	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
503754	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
503755	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Amps B Ø	120.0	
503756	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	9 Months Operations	2	
503757	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1461	
503758	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1461	
503759	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Amps C Ø	140.0	
503760	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	2	
503761	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
503762	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	2	
503763	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
503764	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
503765	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
503766	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
503767	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
503768	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
503769	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
503770	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
503771	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
503772	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Operations A Ø	0	
503773	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
503774	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
503775	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
503776	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
503777	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
503778	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
503779	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
503780	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Operations B Ø	0	
503781	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Operations C Ø	0	
503782	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Operations Ground	0	
503783	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Follow-up Action Required?	n	
503784	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations A Ø	0	
503785	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations B Ø	0	
503786	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations C Ø	0	
503787	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations Ground	0	
503788	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Follow-up Action Required?	n	
503789	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
503790	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
503791	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
503792	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Accumulated Fault Duty A Ph AM	3.38	%
503793	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Accumulated Fault Duty B Ph AM	3.38	%
503794	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LTCC000473	LTCControl	AS-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
503795	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
503796	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
503797	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
503798	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
503799	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
503800	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
503801	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LTCC000473	LTCControl	AS-TRANS 4	LTC Control Insp	General Comments		
503802	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Maintenance Operations	0	
503803	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Operations Counter AF	597	
503804	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Operations Counter AL	597	
503805	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
503806	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
503807	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LTCC000473	LTCControl	AS-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
503808	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
503809	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
503810	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
503811	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
503812	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	9 Month Operations	12	
503813	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
503814	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
503815	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
503816	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Amps A Ø	300.0	
503817	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Amps B Ø	300.0	
503818	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Amps C Ø	300.0	
503819	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	7	
503820	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
503821	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
503822	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
503823	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	10.0	
503824	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	10.0	
503825	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	10.0	
503826	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	LTC Operation Checked?	y	
503827	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
503828	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Operations This Read AM	0	
503829	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Switching Operations	0	
503830	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
503831	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
503832	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	General Comments		
503833	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Unknown Operations	0	
503834	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	5	
503835	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	PF000026	PowerFuse	AS-14KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
503836	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	PF000026	PowerFuse	AS-14KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
503837	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	PF000027	PowerFuse	AS-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
503838	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Unknown Operations	0	
503839	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	PF000027	PowerFuse	AS-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
503840	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
503841	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
503842	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	Follow-up Action Required?	n	
503843	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	All Connections OK?	y	
503844	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
503845	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
503846	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
503847	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
503848	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
503849	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
503850	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
503851	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
503852	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
503853	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
503854	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Foundation Condition	Good	
503855	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
503856	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
503857	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
503858	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Amps C Ø	375.0	
503859	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Amps B Ø	400.0	
503860	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Amps A Ø	400.0	
503861	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
503862	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
503863	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
503864	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	9 Months Operations	9	
503865	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Accumulated Fault Duty A Ph AM	1.11	%
503866	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	9 Months Operations	0	
503867	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Unknown Operations	0	
503868	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Grounds in Place?	y	
503869	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
503870	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ok	
503871	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
503872	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
503873	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
503874	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
503875	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments	Low air alarm that will not reset. Pressure at 150 (norm)	
503876	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
503877	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LTCC000419	LTCControl	AS-TRANS 3	LTC Control Insp	General Comments		
503878	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LTCC000419	LTCControl	AS-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
503879	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
503880	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Tank Leaks	None	
503881	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
503882	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
503883	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1876	
503884	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1876	
503885	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	5	
503886	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	General Comments		
503887	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
503888	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
503889	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
503890	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
503891	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
503892	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	Follow-up Action Required?	n	
503893	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LTCC000536	LTCControl	CF-TRANS 1	LTC Control Insp	General Comments		
503894	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
503895	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
503896	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
503897	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
503898	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
503899	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LTCC000536	LTCControl	CF-TRANS 1	LTC Control Insp	All Connections OK?	y	
503900	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
503901	4/2/2019 12:26	Distribution	Centerfield Quarterly Inspection	LTCC000536	LTCControl	CF-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
503902	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Accumulated Fault Duty C Ph AM	3.38	%
503903	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Amps A Ø	556.0	
503904	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Amps B Ø	589.0	
503905	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Amps C Ø	612.0	
503906	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	General Comments	ok	
503907	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
503908	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Operations B Ø	0	
503909	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
503910	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
503911	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Operations A Ø	0	
503912	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
503913	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
503914	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Switching Operations	1	
503915	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Maintenance Operations	0	
503916	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Operations This Read AM	1	
503917	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
503918	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Amps C Ø	0.0	
503919	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Amps B Ø	0.0	
503920	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Amps A Ø	0.0	
503921	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Accumulated Fault Duty C Ph AM	1.11	%
503922	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Accumulated Fault Duty B Ph AM	1.11	%
503923	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Switching Operations	3	
503924	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Switching Operations	0	
503925	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Operations This Read AM	0	
503926	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
503927	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Operations Counter AL	297	
503928	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Operations Counter AF	297	
503929	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Operations C Ø	0	
503930	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Operations Ground	0	
503931	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Maintenance Operations	0	
503932	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	General Comments	ok	
503933	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Follow-up Action Required?	n	
503934	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	General Comments	ok	
503935	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
503936	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
503937	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
503938	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
503939	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
503940	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
503941	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
503942	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
503943	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
503944	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
503945	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
503946	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
503947	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
503948	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	y	
503949	4/2/2019 12:01	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
503950	4/2/2019 15:04	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
503951	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
503952	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
503953	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	25	°C
503954	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
503955	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	45	°C
503956	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	5433.60	kw
503957	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.5660	
503958	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
503959	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
503960	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
503961	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
503962	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
503963	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
503964	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
503965	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
503966	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
503967	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
503968	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
503969	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
503970	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
503971	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
503972	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
503973	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
503974	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
503975	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
503976	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
503977	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
503978	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
503979	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
503980	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
503981	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
503982	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
503983	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
503984	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
503985	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
503986	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
503987	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCC000203	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
503988	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
503989	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCC000203	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
503990	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCC000203	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
503991	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCC000203	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
503992	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCC000203	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
503993	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Equipment Properly Labeled?	y	
503994	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCC000203	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
503995	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCC000203	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
503996	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
503997	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCC000203	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
503998	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCC000203	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
503999	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
504000	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
504001	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
504002	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
504003	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Clear of Trash?	y	
504004	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
504005	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
504006	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
504007	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
504008	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
504009	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
504010	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
504011	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
504012	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
504013	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
504014	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
504015	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
504016	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
504017	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
504018	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
504019	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
504020	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
504021	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
504022	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
504023	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
504024	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
504025	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
504026	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	General Comments		
504027	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
504028	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Grounds in Place?	y	
504029	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	General Comments		
504030	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	General Comments		
504031	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Cabinet Paint Condition	Good	
504032	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
504033	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Foundation Condition	Good	
504034	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	General Comments		
504035	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
504036	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
504037	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Bushings Connection/Risers	Good	
504038	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Bushing Condition	Good	
504039	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Grounds in Place?	y	
504040	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Moisture and Leak Free?	y	
504041	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Tank Paint Condition	Good	
504042	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
504043	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
504044	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
504045	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Vegetation	None	
504046	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
504047	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
504048	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
504049	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
504050	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
504051	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
504052	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	General Comments		
504053	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
504054	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
504055	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
504056	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Clear of Trash?	y	
504057	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
504058	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
504059	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
504060	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Moisture and Leak Free?	y	
504061	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Heaters (All) Functioning?	y	
504062	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Grounds in Place?	y	
504063	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	LTC Totalizer Reading	3945.60	kw
504064	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
504065	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	General Comments		
504066	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	General Comments		
504067	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
504068	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
504069	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
504070	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Tank Paint Condition	Good	
504071	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Moisture and Leak Free?	y	
504072	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Grounds in Place?	y	
504073	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	General Comments		
504074	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Foundation Condition	Good	
504075	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Follow-up Action Required?	n	
504076	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
504077	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Cabinet Paint Condition	Good	
504078	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
504079	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
504080	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
504081	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
504082	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	General Comments		
504083	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
504084	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
504085	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
504086	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
504087	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
504088	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
504089	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
504090	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Bushings Connection/Risers	Good	
504091	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Bushing Condition	Good	
504092	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
504093	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
504094	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	General Comments		
504095	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
504096	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
504097	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Cabinet Paint Condition	Good	
504098	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
504099	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
504100	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
504101	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
504102	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
504103	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
504104	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
504105	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
504106	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
504107	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Oil Temp Present	20	°C
504108	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Oil Temp Max	25	°C
504109	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
504110	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
504111	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
504112	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Tank Paint Condition	Good	
504113	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
504114	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Moisture and Leak Free?	y	
504115	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Heaters (All) Functioning?	y	
504116	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
504117	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
504118	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
504119	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
504120	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Vegetation	None	
504121	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
504122	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
504123	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Tank Paint Condition	Good	
504124	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
504125	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
504126	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
504127	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
504128	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
504129	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
504130	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
504131	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
504132	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Bushing Condition	Good	
504133	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
504134	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
504135	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
504136	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	General Comments		
504137	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
504138	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
504139	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Foundation Condition	Good	
504140	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Bushings Connection/Risers	Good	
504141	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
504142	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
504143	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
504144	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
504145	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
504146	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
504147	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
504148	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Tank Paint Condition	Good	
504149	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
504150	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
504151	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
504152	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
504153	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
504154	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
504155	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
504156	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Tank Paint Condition	Good	
504157	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
504158	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
504159	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
504160	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
504161	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
504162	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
504163	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
504164	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
504165	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
504166	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
504167	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
504168	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
504169	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
504170	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
504171	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Equipment Properly Labeled?	y	
504172	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Follow-up Action Required?	n	
504173	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
504174	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
504175	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
504176	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
504177	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
504178	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
504179	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
504180	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
504181	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
504182	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
504183	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
504184	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
504185	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	General Comments		
504186	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
504187	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
504188	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
504189	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
504190	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
504191	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
504192	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
504193	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Grounds in Place?	y	
504194	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	General Comments		
504195	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC As Left Counter	7614	
504196	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC As Found Counter	7614	
504197	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Foundation Condition	Good	
504198	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Follow-up Action Required?	n	
504199	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
504200	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
504201	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
504202	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Follow-up Action Required?	n	
504203	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
504204	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
504205	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	General Comments		
504206	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Foundation Condition	Good	
504207	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Follow-up Action Required?	n	
504208	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Equipment Properly Labeled?	y	
504209	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
504210	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Cabinet Paint Condition	Good	
504211	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
504212	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
504213	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
504214	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
504215	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
504216	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
504217	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
504218	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
504219	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Bushing Condition	Good	
504220	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Bushings Connection/Risers	Good	
504221	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
504222	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
504223	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
504224	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Cabinet Paint Condition	Good	
504225	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Equipment Properly Labeled?	y	
504226	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
504227	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Foundation Condition	Good	
504228	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	General Comments		
504229	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Grounds in Place?	y	
504230	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Heaters (All) Functioning?	y	
504231	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Moisture and Leak Free?	y	
504232	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
504233	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
504234	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
504235	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
504236	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
504237	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
504238	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Foundation Condition	Good	
504239	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
504240	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
504241	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	General Comments		
504242	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
504243	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
504244	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
504245	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
504246	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Tank Paint Condition	Good	
504247	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
504248	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
504249	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
504250	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
504251	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
504252	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
504253	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
504254	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
504255	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Cabinet Paint Condition	Good	
504256	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Equipment Properly Labeled?	y	
504257	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Follow-up Action Required?	n	
504258	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Foundation Condition	Good	
504259	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	General Comments		
504260	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Grounds in Place?	y	
504261	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Moisture and Leak Free?	y	
504262	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Tank Paint Condition	Good	
504263	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Bushing Condition	Good	
504264	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	Follow-up Action Required?	n	
504265	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
504266	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	General Comments		
504267	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	General Comments		
504268	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Bushings Connection/Risers	Good	
504269	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
504270	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC As Found Counter	4407	
504271	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
504272	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC As Left Counter	4407	
504273	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
504274	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC Current Tap Position	5L	
504275	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
504276	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
504277	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
504278	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
504279	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
504280	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC Min Tap Position	7L	
504281	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC Operations Since Last Insp	292	
504282	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
504283	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
504284	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
504285	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
504286	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
504287	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
504288	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
504289	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
504290	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
504291	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
504292	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
504293	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
504294	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
504295	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
504296	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	General Comments		
504297	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
504298	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
504299	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
504300	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
504301	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
504302	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
504303	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Cabinet Paint Condition	Good	
504304	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
504305	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
504306	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Equipment Properly Labeled?	y	
504307	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Follow-up Action Required?	n	
504308	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Foundation Condition	Good	
504309	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	General Comments		
504310	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Grounds in Place?	y	
504311	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Moisture and Leak Free?	y	
504312	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Tank Paint Condition	Good	
504313	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
504314	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
504315	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Grounds in Place?	y	
504316	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Moisture and Leak Free?	y	
504317	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Tank Paint Condition	Good	
504318	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Bushing Condition	Good	
504319	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
504320	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Bushings Connection/Risers	Good	
504321	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
504322	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
504323	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
504324	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
504325	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
504326	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Totalizer Meter Reading	.9096	
504327	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
504328	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
504329	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
504330	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
504331	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
504332	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Tank Paint Condition	Good	
504333	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
504334	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Bushing Condition	Good	
504335	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
504336	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
504337	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
504338	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
504339	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Moisture and Leak Free?	y	
504340	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Heaters (All) Functioning?	y	
504341	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Grounds in Place?	y	
504342	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
504343	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
504344	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Follow-up Action Required?	n	
504345	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Foundation Condition	Good	
504346	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	General Comments		
504347	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	General Comments		
504348	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	General Comments		
504349	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Foundation Condition	Good	
504350	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Follow-up Action Required?	n	
504351	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Equipment Properly Labeled?	y	
504352	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Cabinet Paint Condition	Good	
504353	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
504354	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
504355	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
504356	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
504357	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
504358	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
504359	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
504360	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
504361	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
504362	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
504363	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
504364	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
504365	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
504366	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Bushing Condition	Good	
504367	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Bushings Connection/Risers	Good	
504368	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
504369	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
504370	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
504371	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Cabinet Paint Condition	Good	
504372	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Equipment Properly Labeled?	y	
504373	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Follow-up Action Required?	n	
504374	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Foundation Condition	Good	
504375	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	Follow-up Action Required?	n	
504376	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
504377	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	General Comments		
504378	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
504379	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
504380	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
504381	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
504382	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
504383	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Oil Temp Present	30	°C
504384	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Oil Temp Max	55	°C
504385	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Bushing Condition	Good	
504386	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	General Comments		
504387	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	General Comments		
504388	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	General Comments		
504389	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC As Found Counter	148255	
504390	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC As Left Counter	148255	
504391	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
504392	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC Current Tap Position	2L	
504393	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC Max Tap Position	2R	
504394	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC Min Tap Position	6L	
504395	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC Operations Since Last Insp	360	
504396	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
504397	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
504398	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
504399	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	Follow-up Action Required?	n	
504400	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Bushing Condition	Good	
504401	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Bushings Connection/Risers	Good	
504402	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Bushings Connection/Risers	Good	
504403	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Grounds in Place?	y	
504404	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
504405	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Bushing Condition	Good	
504406	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Cabinet Paint Condition	Good	
504407	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Bushings Connection/Risers	Good	
504408	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Equipment Properly Labeled?	y	
504409	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
504410	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
504411	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
504412	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
504413	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
504414	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
504415	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
504416	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
504417	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
504418	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
504419	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
504420	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Vegetation	None	
504421	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
504422	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
504423	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
504424	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
504425	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
504426	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
504427	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
504428	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
504429	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
504430	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
504431	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	General Comments		
504432	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
504433	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
504434	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
504435	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
504436	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
504437	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
504438	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
504439	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Follow-up Action Required?	n	
504440	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Foundation Condition	Good	
504441	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	General Comments		
504442	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Grounds in Place?	y	
504443	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Heaters (All) Functioning?	y	
504444	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
504445	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
504446	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
504447	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
504448	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	General Comments		
504449	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Bushing Condition	Good	
504450	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
504451	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
504452	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
504453	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Cabinet Paint Condition	Good	
504454	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Equipment Properly Labeled?	y	
504455	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Follow-up Action Required?	n	
504456	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Foundation Condition	Good	
504457	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	General Comments		
504458	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
504459	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
504460	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
504461	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
504462	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Grounds in Place?	y	
504463	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Heaters (All) Functioning?	y	
504464	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Moisture and Leak Free?	y	
504465	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
504466	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
504467	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
504468	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
504469	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Follow-up Action Required?	n	
504470	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Foundation Condition	Good	
504471	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	General Comments		
504472	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
504473	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
504474	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
504475	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
504476	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Moisture and Leak Free?	y	
504477	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
504478	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
504479	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Tank Paint Condition	Good	
504480	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
504481	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
504482	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
504483	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
504484	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
504485	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
504486	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
504487	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
504488	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
504489	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
504490	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
504491	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
504492	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
504493	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
504494	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
504495	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
504496	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Follow-up Action Required?	n	
504497	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
504498	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
504499	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	General Comments		
504500	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
504501	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
504502	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	General Comments		
504503	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
504504	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Foundation Condition	Good	
504505	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
504506	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	General Comments		
504507	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
504508	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	LTC Totalizer Reading	14616.00	kw
504509	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
504510	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Cabinet Paint Condition	Good	
504511	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
504512	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Oil Temp Max	60	°C
504513	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Oil Temp Present	55	°C
504514	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
504515	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
504516	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
504517	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
504518	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
504519	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
504520	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Equipment Properly Labeled?	y	
504521	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Follow-up Action Required?	n	
504522	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Foundation Condition	Good	
504523	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	General Comments		
504524	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Grounds in Place?	y	
504525	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Heaters (All) Functioning?	y	
504526	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
504527	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
504528	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
504529	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
504530	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Totalizer Meter Reading	.8120	
504531	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Winding Temp Max	75	°C
504532	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Winding Temp Present	55	°C
504533	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
504534	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
504535	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
504536	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
504537	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Moisture and Leak Free?	y	
504538	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
504539	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
504540	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
504541	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
504542	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Tank Paint Condition	Good	
504543	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Bushings Connection/Risers	Good	
504544	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Bushing Condition	Good	
504545	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
504546	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
504547	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Bushing Condition	Good	
504548	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
504549	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
504550	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	LTC Totalizer Reading	4366.08	kw
504551	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
504552	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Bushings Connection/Risers	Good	
504553	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
504554	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
504555	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	General Comments		
504556	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	General Comments		
504557	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
504558	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
504559	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Follow-up Action Required?	n	
504560	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
504561	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
504562	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
504563	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
504564	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
504565	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	General Comments		
504566	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
504567	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
504568	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
504569	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
504570	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
504571	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
504572	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	General Comments		
504573	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Grounds in Place?	y	
504574	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
504575	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	General Comments		
504576	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
504577	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
504578	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Moisture and Leak Free?	y	
504579	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Foundation Condition	Good	
504580	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
504581	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Tank Paint Condition	Good	
504582	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
504583	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	General Comments		
504584	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
504585	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
504586	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
504587	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
504588	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
504589	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
504590	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
504591	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
504592	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
504593	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
504594	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
504595	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	General Comments		
504596	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC Operations Since Last Insp	532	
504597	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC Min Tap Position	12L	
504598	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC Max Tap Position	3L	
504599	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC Current Tap Position	6L	
504600	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
504601	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC As Left Counter	117455	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
504602	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC As Found Counter	117455	
504603	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	General Comments		
504604	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	General Comments		
504605	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
504606	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	Follow-up Action Required?	n	
504607	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
504608	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
504609	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
504610	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
504611	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
504612	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
504613	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
504614	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
504615	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
504616	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
504617	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	General Comments		
504618	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
504619	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
504620	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
504621	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
504622	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
504623	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
504624	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
504625	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
504626	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
504627	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
504628	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
504629	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	General Comments		
504630	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
504631	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
504632	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Tank Paint Condition	Good	
504633	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
504634	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Bushing Condition	Good	
504635	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Moisture and Leak Free?	y	
504636	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Heaters (All) Functioning?	y	
504637	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Grounds in Place?	y	
504638	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	General Comments		
504639	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
504640	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
504641	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Vegetation	None	
504642	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Foundation Condition	Good	
504643	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Follow-up Action Required?	n	
504644	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Equipment Properly Labeled?	y	
504645	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Cabinet Paint Condition	Good	
504646	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
504647	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
504648	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
504649	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Bushings Connection/Risers	Good	
504650	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Bushing Condition	Good	
504651	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
504652	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
504653	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
504654	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
504655	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
504656	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
504657	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Bushing Condition	Good	
504658	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Bushings Connection/Risers	Good	
504659	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
504660	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
504661	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
504662	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
504663	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Bushings Connection/Risers	Good	
504664	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
504665	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Cabinet Paint Condition	Good	
504666	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Bushing Condition	Good	
504667	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Equipment Properly Labeled?	y	
504668	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Follow-up Action Required?	n	
504669	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Foundation Condition	Good	
504670	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
504671	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
504672	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
504673	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
504674	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
504675	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
504676	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
504677	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
504678	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
504679	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
504680	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
504681	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
504682	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
504683	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
504684	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
504685	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
504686	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
504687	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
504688	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Follow-up Action Required?	n	
504689	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
504690	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
504691	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Tank Paint Condition	Good	
504692	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	General Comments		
504693	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	General Comments		
504694	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
504695	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	LTC Totalizer Reading	16920.00	kw
504696	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
504697	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
504698	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Oil Temp Max	60	°C
504699	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
504700	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
504701	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
504702	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
504703	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
504704	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
504705	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
504706	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
504707	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
504708	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
504709	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
504710	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
504711	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
504712	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
504713	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
504714	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
504715	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
504716	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Grounds in Place?	y	
504717	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	General Comments	y	
504718	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
504719	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Foundation Condition	Good	
504720	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Follow-up Action Required?	n	
504721	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
504722	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	General Comments		
504723	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
504724	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
504725	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
504726	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
504727	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Ambient Temperature	47	°F
504728	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	General Comments		
504729	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
504730	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	Follow-up Action Required?	n	
504731	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Totalizer Meter Reading	.9400	
504732	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Winding Temp Max	70	°C
504733	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
504734	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
504735	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
504736	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
504737	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
504738	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
504739	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
504740	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	°F
504741	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
504742	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
504743	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
504744	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
504745	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
504746	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
504747	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
504748	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
504749	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
504750	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
504751	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
504752	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC Operations Since Last Insp	280	
504753	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC Min Tap Position	7L	
504754	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC Max Tap Position	4R	
504755	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC Current Tap Position	4L	
504756	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
504757	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC As Left Counter	53759	
504758	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC As Found Counter	53759	
504759	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
504760	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
504761	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
504762	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
504763	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
504764	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
504765	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
504766	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
504767	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
504768	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
504769	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
504770	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
504771	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
504772	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
504773	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
504774	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
504775	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
504776	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
504777	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
504778	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
504779	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	General Comments		
504780	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
504781	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
504782	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Foundation Condition	Good	
504783	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
504784	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
504785	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
504786	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
504787	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
504788	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
504789	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
504790	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
504791	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
504792	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	PF001214	PowerFuse	060-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	ok	
504793	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
504794	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
504795	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	Follow-up Action Required?	n	
504796	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
504797	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Tank Paint Condition	Good	
504798	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
504799	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
504800	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
504801	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
504802	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Moisture and Leak Free?	y	
504803	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
504804	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
504805	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
504806	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
504807	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
504808	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
504809	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
504810	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
504811	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
504812	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
504813	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
504814	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
504815	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Heaters (All) Functioning?	y	
504816	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
504817	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
504818	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
504819	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
504820	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Follow-up Action Required?	n	
504821	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
504822	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
504823	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	General Comments		
504824	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	General Comments		
504825	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
504826	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	LTC Totalizer Reading	5552.00	kw

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
504827	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
504828	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
504829	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Oil Temp Max	40	°C
504830	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Oil Temp Present	30	°C
504831	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
504832	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
504833	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
504834	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
504835	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
504836	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
504837	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	All Connections OK?	y	
504838	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	Follow-up Action Required?	n	
504839	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	General Comments		
504840	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
504841	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
504842	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Totalizer Meter Reading	.6940	
504843	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
504844	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
504845	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	General Comments	drag hands wont reset	
504846	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	General Comments	Drag hands wont reset oil level getting low	
504847	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC As Found Counter	45203	
504848	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC As Left Counter	45203	
504849	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC Min Tap Position	8L	
504850	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC Operations Since Last Insp	348	
504851	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
504852	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
504853	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
504854	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Tank Paint Condition	Good	
504855	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
504856	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Grounds in Place?	y	
504857	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	General Comments		
504858	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Foundation Condition	Good	
504859	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
504860	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC Current Tap Position	5L	
504861	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
504862	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC As Left Counter	109593	
504863	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC As Found Counter	109593	
504864	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	General Comments		
504865	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	General Comments		
504866	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
504867	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	Follow-up Action Required?	n	
504868	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	Follow-up Action Required?	n	
504869	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
504870	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Follow-up Action Required?	n	
504871	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
504872	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
504873	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
504874	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
504875	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
504876	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
504877	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Bushing Condition	Good	
504878	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	General Comments		
504879	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	General Comments		
504880	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC As Found Counter	153373	
504881	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC As Left Counter	153373	
504882	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
504883	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC Current Tap Position	8L	
504884	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
504885	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC Min Tap Position	13L	
504886	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC Operations Since Last Insp	305	
504887	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
504888	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
504889	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Tank Paint Condition	Good	
504890	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Moisture and Leak Free?	y	
504891	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Grounds in Place?	y	
504892	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	General Comments		
504893	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Foundation Condition	Good	
504894	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Follow-up Action Required?	n	
504895	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Equipment Properly Labeled?	y	
504896	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Cabinet Paint Condition	Good	
504897	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
504898	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
504899	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
504900	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Bushings Connection/Risers	Good	
504901	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
504902	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
504903	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	PF001213	PowerFuse	060-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
504904	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	PF001213	PowerFuse	060-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
504905	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	PF001214	PowerFuse	060-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
504906	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
504907	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
504908	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
504909	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
504910	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
504911	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Tank Paint Condition	Good	
504912	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Moisture and Leak Free?	y	
504913	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Heaters (All) Functioning?	y	
504914	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
504915	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
504916	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
504917	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
504918	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
504919	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
504920	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
504921	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
504922	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
504923	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
504924	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Grounds in Place?	y	
504925	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	General Comments		
504926	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
504927	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
504928	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
504929	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
504930	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
504931	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
504932	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Tank Paint Condition	Good	
504933	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	All Connections OK?	y	
504934	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	Follow-up Action Required?	n	
504935	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
504936	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
504937	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
504938	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	General Comments		
504939	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	LTC Operation Checked?	y	
504940	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
504941	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
504942	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
504943	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	VRR Time Delay	30	Seconds
504944	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
504945	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
504946	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Foundation Condition	Good	
504947	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
504948	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Heaters (All) Functioning?	y	
504949	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Follow-up Action Required?	n	
504950	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Grounds in Place?	y	
504951	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	General Comments		
504952	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Foundation Condition	Good	
504953	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Follow-up Action Required?	n	
504954	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
504955	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
504956	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Equipment Properly Labeled?	y	
504957	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Cabinet Paint Condition	Good	
504958	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
504959	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
504960	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
504961	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Clear of Trash?	y	
504962	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
504963	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	General Comments		
504964	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
504965	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
504966	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
504967	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
504968	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
504969	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	LTC Operation Checked?	y	
504970	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
504971	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
504972	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
504973	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC Current Tap Position	7L	
504974	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
504975	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	VRR Time Delay	30	Seconds
504976	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
504977	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	LTCC000513	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
504978	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	General Comments		
504979	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	LTCC000513	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
504980	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	LTCC000513	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
504981	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	LTCC000513	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
504982	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	LTCC000513	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
504983	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	LTCC000513	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
504984	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	LTCC000513	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
504985	4/1/2019 12:59	Distribution	Haley Quarterly Inspection	LTCC000513	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
504986	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Grounds in Place?	y	
504987	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	General Comments		
504988	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC Max Tap Position	3L	
504989	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC Min Tap Position	8L	
504990	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC Operations Since Last Insp	414	
504991	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
504992	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
504993	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
504994	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	VRR Time Delay	30	Seconds
504995	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
504996	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
504997	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
504998	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	LTC Operation Checked?	y	
504999	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	General Comments		
505000	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	Follow-up Action Required?	n	
505001	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	All Connections OK?	y	
505002	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Foundation Condition	Good	
505003	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Follow-up Action Required?	n	
505004	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Equipment Properly Labeled?	y	
505005	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Cabinet Paint Condition	Good	
505006	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
505007	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
505008	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
505009	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	VRR Time Delay	30	Seconds
505010	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
505011	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
505012	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
505013	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Bushings Connection/Risers	Good	
505014	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Bushing Condition	Good	
505015	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
505016	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	LTC Operation Checked?	y	
505017	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	General Comments		
505018	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	Follow-up Action Required?	n	
505019	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	All Connections OK?	y	
505020	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
505021	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
505022	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
505023	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
505024	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	VRR Time Delay	30	Seconds
505025	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
505026	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
505027	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
505028	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
505029	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Follow-up Action Required?	n	
505030	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
505031	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
505032	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
505033	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
505034	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
505035	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
505036	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	General Comments		
505037	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
505038	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
505039	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Panels Dusted?	y	
505040	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
505041	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
505042	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	General Comments		
505043	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
505044	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
505045	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
505046	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Floor Swept?	y	
505047	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
505048	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
505049	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
505050	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Evidence of Insects	None	
505051	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
505052	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
505053	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Oil Temp Max	25	°C
505054	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
505055	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
505056	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Oil Temp Max	50	°C
505057	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	General Comments		
505058	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
505059	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Oil Temp Present	20	°C
505060	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
505061	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
505062	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
505063	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
505064	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
505065	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
505066	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	General Comments		
505067	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
505068	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
505069	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
505070	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
505071	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
505072	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
505073	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
505074	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
505075	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
505076	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
505077	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
505078	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Clear of Trash?	y	
505079	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
505080	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
505081	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
505082	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Oil Temp Present	25	°C
505083	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
505084	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
505085	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
505086	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
505087	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
505088	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
505089	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
505090	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
505091	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	LTC Totalizer Reading	3732.00	kw
505092	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
505093	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
505094	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
505095	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
505096	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
505097	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
505098	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC Operations Since Last Insp	386	
505099	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC Min Tap Position	6L	
505100	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC Max Tap Position	1L	
505101	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
505102	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
505103	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
505104	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
505105	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	All Connections OK?	y	
505106	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	Follow-up Action Required?	n	
505107	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	General Comments		
505108	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	LTC Operation Checked?	y	
505109	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	General Comments		
505110	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC As Found Counter	4552	
505111	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC As Left Counter	4552	
505112	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
505113	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC Current Tap Position	6L	
505114	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC Max Tap Position	2L	
505115	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC Min Tap Position	6L	
505116	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
505117	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
505118	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	15	°C
505119	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC Operations Since Last Insp	323	
505120	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
505121	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
505122	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
505123	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
505124	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
505125	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
505126	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
505127	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
505128	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
505129	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
505130	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
505131	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
505132	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	All Connections OK?	y	
505133	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	Follow-up Action Required?	n	
505134	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	General Comments		
505135	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	LTC Operation Checked?	y	
505136	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
505137	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Oil Temp Max	65	°C
505138	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
505139	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
505140	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	LTC Totalizer Reading	10843.20	kw
505141	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
505142	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
505143	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
505144	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	VRR Time Delay	30	Seconds
505145	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
505146	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
505147	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
505148	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
505149	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
505150	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
505151	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
505152	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
505153	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Tank Paint Condition	Good	
505154	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
505155	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Moisture and Leak Free?	y	
505156	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Heaters (All) Functioning?	y	
505157	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Grounds in Place?	y	
505158	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	General Comments		
505159	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Foundation Condition	Good	
505160	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Follow-up Action Required?	n	
505161	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Equipment Properly Labeled?	y	
505162	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Cabinet Paint Condition	Good	
505163	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
505164	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
505165	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
505166	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Bushings Connection/Risers	Good	
505167	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
505168	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
505169	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
505170	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
505171	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
505172	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Totalizer Meter Reading	.6220	
505173	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
505174	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
505175	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
505176	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
505177	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
505178	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
505179	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
505180	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
505181	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
505182	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
505183	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
505184	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
505185	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
505186	4/1/2019 13:56	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Bushing Condition	Good	
505187	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
505188	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Follow-up Action Required?	n	
505189	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
505190	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
505191	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	LTC Totalizer Reading	21024.00	kw
505192	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	Follow-up Action Required?	n	
505193	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
505194	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	General Comments		
505195	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	General Comments		
505196	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	General Comments		
505197	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Winding Temp Present	20	°C
505198	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
505199	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Totalizer Meter Reading	.7530	
505200	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
505201	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	LTC Operation Checked?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
505202	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
505203	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
505204	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
505205	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC Current Tap Position	6L	
505206	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
505207	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
505208	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
505209	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
505210	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
505211	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
505212	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	General Comments		
505213	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	Follow-up Action Required?	n	
505214	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	All Connections OK?	y	
505215	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
505216	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
505217	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
505218	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
505219	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
505220	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
505221	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
505222	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
505223	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
505224	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
505225	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Oil Temp Present	35	°C
505226	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
505227	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
505228	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
505229	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
505230	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
505231	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
505232	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Ambient Temperature	47	°F
505233	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
505234	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
505235	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
505236	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
505237	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
505238	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Follow-up Action Required?	n	
505239	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Foundation Condition	Good	
505240	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
505241	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	General Comments	y	
505242	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Grounds in Place?	y	
505243	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
505244	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
505245	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
505246	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
505247	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
505248	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Foundation Condition	Good	
505249	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Follow-up Action Required?	n	
505250	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Equipment Properly Labeled?	y	
505251	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Cabinet Paint Condition	Good	
505252	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
505253	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
505254	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
505255	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
505256	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Tank Paint Condition	Good	
505257	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Bushing Condition	Good	
505258	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Bushings Connection/Risers	Good	
505259	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
505260	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Tank Paint Condition	Good	
505261	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
505262	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
505263	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
505264	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
505265	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
505266	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Winding Temp Present	35	°C
505267	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
505268	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Moisture and Leak Free?	y	
505269	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
505270	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Grounds in Place?	y	
505271	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
505272	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	General Comments		
505273	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Winding Temp Present	30	°C
505274	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	General Comments		
505275	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Winding Temp Max	30	°C
505276	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Winding Temp Max	45	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
505277	4/1/2019 13:11	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
505278	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Totalizer Meter Reading	1.4600	
505279	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
505280	4/1/2019 14:50	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	General Comments	Varmint gaurd disc off of Cph line side	
505281	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
505282	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
505283	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
505284	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
505285	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
505286	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
505287	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Totalizer Meter Reading	.2740	
505288	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Follow-up Action Required?	n	
505289	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
505290	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
505291	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	VRR Time Delay	30	Seconds
505292	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
505293	4/1/2019 11:54	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
505294	4/1/2019 8:52	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Winding Temp Max	30	°C
505295	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
505296	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
505297	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	5.0	
505298	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
505299	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	5.0	
505300	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	5.0	
505301	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
505302	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	0	
505303	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
505304	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
505305	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
505306	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
505307	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	162	
505308	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
505309	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
505310	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
505311	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	230.0	
505312	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Bushing Condition	Good	
505313	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Amps C Ø	401.0	
505314	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Amps B Ø	439.0	
505315	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Amps A Ø	395.0	
505316	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
505317	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
505318	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
505319	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
505320	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
505321	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
505322	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
505323	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	General Comments	.	
505324	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
505325	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
505326	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
505327	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
505328	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
505329	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0	amps
505330	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
505331	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
505332	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
505333	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
505334	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.92	%
505335	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
505336	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
505337	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations A Ø	0	
505338	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations B Ø	0	
505339	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations C Ø	0	
505340	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
505341	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Amps A Ø	120.0	
505342	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
505343	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
505344	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Amps B Ø	180.0	
505345	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Amps C Ø	240.0	
505346	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
505347	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	9 Months Operations	1	
505348	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
505349	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
505350	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations A Ø	0	
505351	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
505352	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
505353	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations C Ø	0	
505354	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations Ground	0	
505355	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
505356	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
505357	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Follow-up Action Required?	n	
505358	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
505359	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
505360	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
505361	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
505362	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	LTC Totalizer Reading	18165.60	kw
505363	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
505364	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
505365	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	60	°C
505366	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
505367	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
505368	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
505369	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	General Comments		
505370	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Maintenance Operations	0	
505371	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Operations Counter AF	300	
505372	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Operations Counter AL	300	
505373	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Switching Operations	0	
505374	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Unknown Operations	0	
505375	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
505376	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
505377	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
505378	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
505379	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
505380	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Operational?	y	
505381	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
505382	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
505383	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
505384	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
505385	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	9 Month Operations	0	
505386	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
505387	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
505388	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	12	
505389	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	7.69	%
505390	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	4.80	%
505391	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
505392	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.96	%
505393	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	190.0	
505394	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
505395	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
505396	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
505397	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
505398	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
505399	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
505400	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
505401	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
505402	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
505403	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
505404	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
505405	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
505406	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
505407	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
505408	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
505409	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
505410	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
505411	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
505412	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
505413	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
505414	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
505415	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	272	
505416	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	277	
505417	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
505418	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
505419	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
505420	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	160.0	
505421	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
505422	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	140.0	
505423	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	140.0	
505424	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	General Comments		
505425	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
505426	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
505427	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
505428	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
505429	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
505430	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
505431	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
505432	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
505433	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
505434	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
505435	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
505436	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
505437	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
505438	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
505439	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
505440	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	12	
505441	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	7	
505442	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
505443	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	9	
505444	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
505445	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
505446	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
505447	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
505448	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Readings	General Comments		
505449	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
505450	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
505451	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Foundation Condition	Good	
505452	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
505453	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
505454	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
505455	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
505456	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
505457	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
505458	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
505459	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Reading	1.0092	
505460	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations Ground	0	
505461	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Follow-up Action Required?	n	
505462	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	3.85	%
505463	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	40.0	
505464	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
505465	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Follow-up Action Required?	n	
505466	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	40.0	
505467	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	40.0	
505468	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
505469	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Foundation Condition	Good	
505470	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
505471	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
505472	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
505473	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
505474	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
505475	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	General Comments		
505476	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	General Comments		
505477	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Grounds in Place?	y	
505478	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Maintenance Operations	0	
505479	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
505480	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
505481	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
505482	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
505483	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
505484	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Operations Counter AF	145	
505485	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Operations Counter AL	145	
505486	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Switching Operations	0	
505487	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Clear of Trash?	y	
505488	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
505489	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
505490	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
505491	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
505492	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
505493	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
505494	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	General Comments		
505495	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
505496	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Tank Paint Condition	Good	
505497	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Unknown Operations	0	
505498	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
505499	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
505500	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Winding Temp Max	50	°C
505501	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
505502	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
505503	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
505504	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
505505	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
505506	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
505507	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Vegetation	None	
505508	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
505509	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	General Comments		
505510	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
505511	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
505512	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
505513	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
505514	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
505515	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
505516	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
505517	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
505518	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
505519	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
505520	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
505521	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
505522	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
505523	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
505524	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
505525	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
505526	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
505527	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
505528	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
505529	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
505530	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
505531	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
505532	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
505533	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
505534	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
505535	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
505536	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	General Comments		
505537	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
505538	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
505539	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
505540	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
505541	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
505542	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
505543	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
505544	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
505545	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
505546	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	8.0	amps
505547	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
505548	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
505549	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
505550	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	4	
505551	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
505552	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	334	
505553	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	330	
505554	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
505555	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
505556	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
505557	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
505558	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
505559	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
505560	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
505561	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
505562	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
505563	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
505564	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
505565	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
505566	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
505567	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
505568	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
505569	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
505570	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	General Comments		
505571	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
505572	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
505573	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
505574	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
505575	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
505576	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	200.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
505577	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
505578	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
505579	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
505580	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
505581	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
505582	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	VRR Time Delay	30	Seconds
505583	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
505584	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
505585	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
505586	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	2791	
505587	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
505588	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
505589	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
505590	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	LTC Output Voltage Level	53.0	VAC
505591	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
505592	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	LTC Operation Checked?	y	
505593	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	General Comments		
505594	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
505595	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	Follow-up Action Required?	n	
505596	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	All Connections OK?	y	
505597	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	2791	
505598	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
505599	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
505600	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
505601	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	7L	
505602	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	1L	
505603	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	11L	
505604	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
505605	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
505606	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
505607	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
505608	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	705	
505609	3/27/2019 8:17	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	General Comments		
505610	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
505611	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
505612	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
505613	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
505614	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
505615	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
505616	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
505617	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
505618	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
505619	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
505620	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
505621	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	LTC Totalizer Reading	6635.52	kw
505622	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
505623	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
505624	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
505625	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
505626	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Winding Temp Present	18	°C
505627	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
505628	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Winding Temp Max	28	°C
505629	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
505630	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	General Comments		
505631	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
505632	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	General Comments		
505633	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
505634	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	18000	
505635	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Totalizer Meter Reading	.1164	
505636	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
505637	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
505638	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Follow-up Action Required?	n	
505639	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
505640	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
505641	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
505642	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations Ground	0	
505643	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Follow-up Action Required?	n	
505644	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
505645	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0542	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
505646	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0542	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
505647	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Follow-up Action Required?	n	
505648	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0542	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
505649	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0542	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
505650	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Foundation Condition	Good	
505651	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
505652	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	General Comments		
505653	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Grounds in Place?	y	
505654	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Maintenance Operations	0	
505655	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
505656	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
505657	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
505658	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
505659	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Operations Since Last Insp	516	
505660	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Amps A Ø	9.0	
505661	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Amps B Ø	9.0	
505662	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
505663	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
505664	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
505665	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
505666	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	General Comments		
505667	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	General Comments		
505668	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
505669	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
505670	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
505671	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
505672	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
505673	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
505674	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
505675	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	100	psi
505676	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	100.00	
505677	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	2095.20	kw
505678	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
505679	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
505680	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Oil Temp Max	30	°C
505681	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Oil Temp Present	20	°C
505682	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
505683	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Vegetation	None	
505684	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
505685	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
505686	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	General Comments		
505687	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
505688	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
505689	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
505690	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
505691	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
505692	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
505693	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Clear of Trash?	y	
505694	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
505695	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
505696	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
505697	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Accumulated Fault Duty B Ph V	.47	%
505698	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Accumulated Fault Duty C Ph V	.47	%
505699	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Equipment Properly Labeled?	y	
505700	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations C Ø	0	
505701	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
505702	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
505703	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
505704	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCC000550	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
505705	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations Ground	0	
505706	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCC000550	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
505707	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCC000550	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
505708	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCC000550	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
505709	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCC000550	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
505710	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCC000550	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
505711	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
505712	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCC000550	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
505713	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
505714	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
505715	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
505716	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
505717	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
505718	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	General Comments		
505719	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0542	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	55103	
505720	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
505721	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0542	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
505722	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Paint Condition	Good	
505723	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
505724	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
505725	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
505726	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
505727	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
505728	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
505729	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Amps C Ø	9.0	
505730	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
505731	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
505732	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
505733	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Totalizer Meter Reading	.5484	
505734	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Oil Temp Max	40	°C
505735	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
505736	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
505737	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
505738	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
505739	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
505740	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
505741	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
505742	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
505743	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Operations Counter AF	234	
505744	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Operations Counter AL	234	
505745	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
505746	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Switching Operations	3	
505747	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
505748	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
505749	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
505750	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
505751	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
505752	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
505753	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
505754	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
505755	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Totalizer Meter Reading	.6912	
505756	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
505757	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
505758	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Equipment Properly Labeled?	y	
505759	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
505760	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCC000550	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
505761	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCC000151	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
505762	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCC000151	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
505763	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
505764	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	9 Month Operations	15	
505765	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Accumulated Fault Duty A Ph V	.47	%
505766	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
505767	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
505768	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
505769	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Tank Paint Condition	Good	
505770	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Unknown Operations	0	
505771	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
505772	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Accumulated Fault Duty C Ph V	1.42	%
505773	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	50360	
505774	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	50360	
505775	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
505776	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Counter Readings	General Comments		
505777	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
505778	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
505779	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
505780	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Follow-up Action Required?	n	
505781	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
505782	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
505783	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
505784	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
505785	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	General Comments		
505786	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
505787	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
505788	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
505789	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
505790	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
505791	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
505792	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
505793	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
505794	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
505795	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
505796	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
505797	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
505798	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
505799	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
505800	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
505801	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
505802	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
505803	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
505804	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
505805	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
505806	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Foundation Condition	Good	
505807	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
505808	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
505809	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	General Comments		
505810	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
505811	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
505812	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
505813	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
505814	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
505815	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
505816	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
505817	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
505818	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
505819	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
505820	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
505821	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations A Ø	0	
505822	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
505823	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
505824	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
505825	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
505826	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	LTC Totalizer Reading	7914.24	kw
505827	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
505828	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
505829	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	Follow-up Action Required?	n	
505830	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
505831	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	General Comments		
505832	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
505833	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
505834	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
505835	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	General Comments		
505836	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC As Found Counter	34887	
505837	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC As Left Counter	34887	
505838	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
505839	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
505840	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Current Tap Position	2R	
505841	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
505842	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
505843	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	0	
505844	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	Neutral	
505845	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
505846	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
505847	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
505848	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Max Tap Position	2R	
505849	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
505850	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
505851	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Min Tap Position	8R	
505852	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
505853	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Tank Leaks	None	
505854	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
505855	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	General Comments		
505856	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Bushings Connection/Risers	Good	
505857	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations B Ø	0	
505858	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Bushing Condition	Good	
505859	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Amps C Ø	60.0	
505860	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
505861	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
505862	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Amps B Ø	60.0	
505863	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	General Comments		
505864	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
505865	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
505866	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
505867	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
505868	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Regulator As Left Counter	44176	
505869	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.0	volts
505870	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
505871	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
505872	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
505873	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
505874	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
505875	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Amps A Ø	60.0	
505876	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Regulator As Left Counter	12730	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
505877	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
505878	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
505879	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
505880	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
505881	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
505882	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
505883	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
505884	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
505885	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
505886	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
505887	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Amps A Ø	12.0	
505888	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
505889	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Min Tap Position	7L	
505890	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Max Tap Position	3R	
505891	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
505892	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	General Comments		
505893	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Accumulated Fault Duty C Ph V	10.48	%
505894	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Accumulated Fault Duty B Ph V	13.62	%
505895	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Accumulated Fault Duty A Ph V	11.18	%
505896	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	9 Month Operations	5	
505897	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
505898	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
505899	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
505900	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
505901	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
505902	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	39	°F
505903	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
505904	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	General Comments		
505905	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Current Tap Position	2L	
505906	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
505907	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
505908	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	General Comments		
505909	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
505910	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
505911	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
505912	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
505913	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	1754.88	kw
505914	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
505915	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
505916	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
505917	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Oil Temp Max	50	°C
505918	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Oil Temp Present	30	°C
505919	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
505920	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
505921	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
505922	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
505923	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
505924	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations A Ø	0	
505925	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations B Ø	0	
505926	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
505927	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations C Ø	0	
505928	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
505929	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
505930	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
505931	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
505932	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
505933	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
505934	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
505935	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
505936	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
505937	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
505938	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	General Comments		
505939	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
505940	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
505941	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Foundation Condition	Good	
505942	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
505943	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
505944	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
505945	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
505946	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
505947	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
505948	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
505949	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
505950	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
505951	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
505952	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
505953	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
505954	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
505955	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
505956	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
505957	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
505958	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Tank Leaks	None	
505959	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
505960	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
505961	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
505962	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
505963	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Bushing Condition	Good	
505964	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Amps C Ø	12.0	
505965	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Amps B Ø	12.0	
505966	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
505967	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
505968	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
505969	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
505970	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
505971	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
505972	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
505973	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
505974	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
505975	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
505976	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
505977	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
505978	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
505979	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
505980	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
505981	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
505982	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
505983	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
505984	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
505985	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
505986	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
505987	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
505988	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	General Comments		
505989	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
505990	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
505991	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
505992	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
505993	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations Ground	0	
505994	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	9 Month Operations	8	
505995	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
505996	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
505997	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations C Ø	0	
505998	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations B Ø	0	
505999	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations A Ø	0	
506000	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
506001	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
506002	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
506003	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
506004	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
506005	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
506006	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
506007	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
506008	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
506009	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
506010	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
506011	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Equipment Properly Labeled?	y	
506012	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Paint Condition	Good	
506013	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
506014	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
506015	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
506016	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Bushings Connection/Risers	Good	
506017	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Bushing Condition	Good	
506018	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
506019	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Amps C Ø	60.0	
506020	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Amps B Ø	60.0	
506021	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Amps A Ø	70.0	
506022	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
506023	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
506024	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
506025	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Totalizer Meter Reading	.8634	
506026	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
506027	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
506028	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
506029	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
506030	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
506031	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
506032	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
506033	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Bushings Connection/Risers	Good	
506034	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Bushing Condition	Good	
506035	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Operations Since Last Insp	145	
506036	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
506037	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Amps C Ø	120.0	
506038	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Amps B Ø	120.0	
506039	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
506040	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0541	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
506041	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0541	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Low	
506042	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0541	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
506043	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0541	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
506044	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Unknown Operations	0	
506045	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
506046	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0541	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	4L	
506047	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0541	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	2R	
506048	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0541	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
506049	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0541	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
506050	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0541	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
506051	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0541	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
506052	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0541	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
506053	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0541	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
506054	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0541	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
506055	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0541	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
506056	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0541	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
506057	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Tank Paint Condition	Good	
506058	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Switching Operations	2	
506059	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Operations Counter AL	190	
506060	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Operations Counter AF	188	
506061	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Moisture and Leak Free?	y	
506062	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Maintenance Operations	0	
506063	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Grounds in Place?	y	
506064	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	General Comments		
506065	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	General Comments		
506066	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Foundation Condition	Good	
506067	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Follow-up Action Required?	n	
506068	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0541	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
506069	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0541	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
506070	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0541	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
506071	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Follow-up Action Required?	n	
506072	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
506073	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	General Comments		
506074	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Amps A Ø	120.0	
506075	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
506076	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
506077	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
506078	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
506079	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Tank Leaks	None	
506080	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
506081	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
506082	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Regulator As Left Counter	47892	
506083	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.0	volts
506084	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Follow-up Action Required?	n	
506085	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Oil Temp Max	40	°C
506086	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
506087	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
506088	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	LTC Totalizer Reading	4144.32	kw
506089	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
506090	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
506091	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
506092	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6810	
506093	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Operations Counter	87	
506094	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
506095	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Tank Leaks	None	
506096	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	General Comments		
506097	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	General Comments		
506098	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
506099	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
506100	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	General Comments		
506101	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
506102	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Follow-up Action Required?	n	
506103	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
506104	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
506105	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
506106	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
506107	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
506108	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
506109	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
506110	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
506111	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Follow-up Action Required?	n	
506112	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
506113	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
506114	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
506115	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
506116	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
506117	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
506118	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	General Comments		
506119	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC As Found Counter	35942	
506120	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
506121	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
506122	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
506123	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
506124	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC As Left Counter	35492	
506125	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
506126	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Current Tap Position	4L	
506127	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
506128	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
506129	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
506130	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
506131	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Amps C Ø	17.0	
506132	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Max Tap Position	2L	
506133	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Min Tap Position	8L	
506134	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Amps B Ø	33.0	
506135	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Amps A Ø	19.0	
506136	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	9 Month Operations	2	
506137	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	General Comments		
506138	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	General Comments		
506139	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
506140	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
506141	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Tank Leaks	None	
506142	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
506143	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Operations Counter	15	
506144	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
506145	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
506146	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-2.0	psi
506147	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	100.00	
506148	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
506149	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	General Comments		
506150	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
506151	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6537.60	kw
506152	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
506153	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
506154	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
506155	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
506156	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
506157	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
506158	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
506159	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
506160	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	121.0	volts
506161	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Regulator As Left Counter	46389	
506162	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
506163	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
506164	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Tank Leaks	None	
506165	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
506166	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	General Comments		
506167	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
506168	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
506169	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
506170	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Grounds in Place?	y	
506171	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	General Comments		
506172	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	General Comments		
506173	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
506174	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
506175	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
506176	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
506177	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Foundation Condition	Good	
506178	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
506179	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
506180	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
506181	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
506182	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
506183	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
506184	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
506185	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
506186	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
506187	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
506188	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCC000151	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
506189	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCC000151	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
506190	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
506191	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Unknown Operations	0	
506192	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Accumulated Fault Duty B Ph V	2.61	%
506193	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Accumulated Fault Duty A Ph V	2.37	%
506194	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	9 Month Operations	13	
506195	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	10.0	
506196	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	10.0	
506197	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
506198	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
506199	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Tank Paint Condition	Good	
506200	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Switching Operations	4	
506201	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
506202	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Operations Counter AL	358	
506203	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Operations Counter AF	354	
506204	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Moisture and Leak Free?	y	
506205	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Maintenance Operations	0	
506206	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Heaters (All) Functioning?	y	
506207	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
506208	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
506209	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Bushings Connection/Risers	Good	
506210	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Grounds in Place?	y	
506211	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	General Comments		
506212	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	General Comments		
506213	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Foundation Condition	Good	
506214	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Follow-up Action Required?	n	
506215	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Follow-up Action Required?	n	
506216	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0542	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
506217	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0542	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
506218	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0542	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
506219	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	General Comments		
506220	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
506221	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
506222	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	44	°F
506223	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
506224	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
506225	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Operations Counter	4	
506226	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
506227	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
506228	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
506229	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
506230	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
506231	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations Ground	0	
506232	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations C Ø	0	
506233	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
506234	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
506235	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
506236	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
506237	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
506238	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
506239	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
506240	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
506241	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
506242	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
506243	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Moisture and Leak Free?	y	
506244	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Maintenance Operations	0	
506245	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Heaters (All) Functioning?	y	
506246	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Trip-energy Supply Verified	y	LED lights?
506247	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
506248	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
506249	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
506250	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
506251	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
506252	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
506253	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
506254	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Paint Condition	Good	
506255	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
506256	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
506257	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
506258	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
506259	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
506260	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
506261	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
506262	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
506263	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Amps A Ø	30.0	
506264	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
506265	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
506266	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
506267	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
506268	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
506269	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
506270	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Amps B Ø	30.0	
506271	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Amps C Ø	30.0	
506272	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Bushing Condition	Good	
506273	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
506274	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
506275	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
506276	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCC000151	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
506277	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCC000151	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
506278	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
506279	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
506280	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
506281	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
506282	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	10.0	
506283	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0542	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
506284	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCC000151	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
506285	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0542	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Low	
506286	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0542	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
506287	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0542	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
506288	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCC000151	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
506289	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0542	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	3L	
506290	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0542	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	5R	
506291	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0542	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
506292	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
506293	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
506294	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
506295	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
506296	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
506297	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
506298	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
506299	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
506300	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	General Comments		
506301	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
506302	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
506303	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
506304	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
506305	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
506306	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
506307	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Clear of Trash?	y	
506308	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
506309	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
506310	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
506311	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
506312	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
506313	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0541	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
506314	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0541	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	44066	
506315	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0541	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
506316	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
506317	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
506318	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
506319	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
506320	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
506321	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
506322	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
506323	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
506324	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
506325	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
506326	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
506327	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
506328	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	General Comments		
506329	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
506330	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
506331	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2021-03-26 00:00:00.000000	
506332	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Vegetation	None	
506333	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
506334	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
506335	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations B Ø	0	
506336	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations A Ø	0	
506337	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
506338	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
506339	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
506340	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Equipment Properly Labeled?	y	
506341	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Paint Condition	Good	
506342	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
506343	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
506344	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
506345	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
506346	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
506347	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
506348	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	General Comments		
506349	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
506350	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
506351	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
506352	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0542	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
506353	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0542	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
506354	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0542	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
506355	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0542	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
506356	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
506357	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
506358	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
506359	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
506360	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Readings	General Comments		
506361	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0542	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
506362	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0542	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
506363	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0542	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
506364	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0542	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
506365	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0541	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
506366	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0541	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
506367	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
506368	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
506369	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
506370	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
506371	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
506372	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
506373	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	663	
506374	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	667	
506375	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
506376	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
506377	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
506378	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
506379	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
506380	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
506381	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
506382	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
506383	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0541	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
506384	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	Follow-up Action Required?	n	
506385	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Amps A Ø	41.0	
506386	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Amps B Ø	55.0	
506387	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Amps C Ø	50.0	
506388	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
506389	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
506390	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
506391	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
506392	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
506393	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
506394	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
506395	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
506396	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
506397	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
506398	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Paint Condition	Good	
506399	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Equipment Properly Labeled?	y	
506400	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
506401	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
506402	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
506403	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
506404	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
506405	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
506406	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
506407	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
506408	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
506409	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
506410	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
506411	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
506412	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
506413	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
506414	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
506415	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations A Ø	0	
506416	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations B Ø	0	
506417	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations C Ø	0	
506418	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
506419	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
506420	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations Ground	0	
506421	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Follow-up Action Required?	n	
506422	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
506423	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
506424	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
506425	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
506426	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
506427	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	586	
506428	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	590	
506429	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
506430	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Follow-up Action Required?	n	
506431	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Foundation Condition	Good	
506432	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	General Comments		
506433	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	General Comments		
506434	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Grounds in Place?	y	
506435	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Heaters (All) Functioning?	y	
506436	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Maintenance Operations	0	
506437	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Moisture and Leak Free?	y	
506438	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Operations Counter AF	904	
506439	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Operations Counter AL	908	
506440	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
506441	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
506442	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
506443	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Unknown Operations	0	
506444	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Tank Paint Condition	Good	
506445	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Switching Operations	2	
506446	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
506447	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Switching Operations	4	
506448	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations B Ø	0	
506449	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations A Ø	0	
506450	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	General Comments		
506451	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
506452	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	Follow-up Action Required?	n	
506453	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
506454	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
506455	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
506456	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
506457	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
506458	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
506459	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
506460	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations A Ø	0	
506461	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations B Ø	0	
506462	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Amps C Ø	120.0	
506463	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Bushing Condition	Good	
506464	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Bushings Connection/Risers	Good	
506465	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
506466	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
506467	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
506468	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Paint Condition	Good	
506469	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Equipment Properly Labeled?	y	
506470	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
506471	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
506472	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Switching Operations	4	
506473	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Tank Paint Condition	Good	
506474	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Unknown Operations	0	
506475	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
506476	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
506477	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	General Comments		
506478	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC As Found Counter	71151	
506479	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC As Left Counter	71151	
506480	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	16	
506481	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
506482	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
506483	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.50	%
506484	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
506485	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	70.0	
506486	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	70.0	
506487	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	70.0	
506488	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Current Tap Position	2L	
506489	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
506490	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Min Tap Position	7L	
506491	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Operations Since Last Insp	133	
506492	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
506493	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
506494	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
506495	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
506496	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	9 Month Operations	12	
506497	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Accumulated Fault Duty A Ph V	.71	%
506498	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Accumulated Fault Duty B Ph V	.95	%
506499	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
506500	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
506501	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
506502	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Unknown Operations	0	
506503	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Tank Paint Condition	Good	
506504	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Accumulated Fault Duty C Ph V	.95	%
506505	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Switching Operations	4	
506506	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
506507	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Operations Counter AL	30	
506508	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Operations Counter AF	25	
506509	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Moisture and Leak Free?	y	
506510	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Maintenance Operations	0	
506511	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Heaters (All) Functioning?	y	
506512	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Grounds in Place?	y	
506513	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
506514	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	General Comments		
506515	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	General Comments		
506516	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Foundation Condition	Good	
506517	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Follow-up Action Required?	n	
506518	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Follow-up Action Required?	n	
506519	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations Ground	0	
506520	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations C Ø	0	
506521	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Amps A Ø	30.0	
506522	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Amps B Ø	30.0	
506523	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Amps C Ø	30.0	
506524	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Bushing Condition	Good	
506525	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Bushings Connection/Risers	Good	
506526	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
506527	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
506528	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Operations C Ø	1	
506529	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Operations B Ø	0	
506530	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Operations A Ø	0	
506531	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Adjusted Amps C Phase V	4.69	
506532	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
506533	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
506534	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Equipment Properly Labeled?	y	
506535	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Cabinet Paint Condition	Good	
506536	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
506537	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
506538	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
506539	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Bushings Connection/Risers	Good	
506540	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Bushing Condition	Good	
506541	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Amps C Ø	154.0	
506542	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Amps B Ø	214.0	
506543	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Amps A Ø	194.0	
506544	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Accumulated Fault Duty C Ph V	1.05	%
506545	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
506546	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
506547	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	9 Month Operations	13	
506548	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
506549	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
506550	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
506551	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
506552	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
506553	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Tank Leaks	None	
506554	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
506555	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.4	volts
506556	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
506557	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
506558	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
506559	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
506560	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Min Tap Position	2R	
506561	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Max Tap Position	2R	
506562	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
506563	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	General Comments		
506564	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
506565	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
506566	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
506567	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
506568	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Current Tap Position	2R	
506569	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
506570	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
506571	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
506572	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
506573	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
506574	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
506575	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
506576	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
506577	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	General Comments		
506578	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	General Comments		
506579	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
506580	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
506581	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
506582	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
506583	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
506584	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	Oil Temp Max	30	°C
506585	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	Oil Temp Present	20	°C
506586	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Unknown Operations	0	
506587	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Tank Paint Condition	Good	
506588	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Switching Operations	0	
506589	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Operations Counter AL	38	
506590	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Operations Counter AF	38	
506591	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
506592	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Maintenance Operations	0	
506593	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Grounds in Place?	y	
506594	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Operations Counter AL	174	
506595	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Operations Counter AF	172	
506596	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations C Ø	0	
506597	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations Ground	0	
506598	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Follow-up Action Required?	n	
506599	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Follow-up Action Required?	n	
506600	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Foundation Condition	Good	
506601	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	General Comments		
506602	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	General Comments		
506603	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Grounds in Place?	y	
506604	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Heaters (All) Functioning?	y	
506605	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Maintenance Operations	0	
506606	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Moisture and Leak Free?	y	
506607	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Operations Counter AF	258	
506608	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Operations Counter AL	262	
506609	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
506610	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Moisture and Leak Free?	y	
506611	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Maintenance Operations	0	
506612	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Heaters (All) Functioning?	y	
506613	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Grounds in Place?	y	
506614	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	General Comments		
506615	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	General Comments		
506616	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Foundation Condition	Good	
506617	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Follow-up Action Required?	n	
506618	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Follow-up Action Required?	n	
506619	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations Ground	0	
506620	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations C Ø	0	
506621	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations B Ø	0	
506622	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations A Ø	0	
506623	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
506624	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
506625	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
506626	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
506627	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Paint Condition	Good	
506628	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Switching Operations	4	
506629	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Tank Paint Condition	Good	
506630	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
506631	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
506632	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
506633	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Unknown Operations	0	
506634	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Tank Paint Condition	Good	
506635	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Unknown Operations	0	
506636	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Bushings Connection/Risers	Good	
506637	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Bushing Condition	Good	
506638	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Amps C Ø	94.0	
506639	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Amps B Ø	131.0	
506640	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Amps A Ø	141.0	
506641	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Accumulated Fault Duty C Ph V	.70	%
506642	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Accumulated Fault Duty B Ph V	2.45	%
506643	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Accumulated Fault Duty A Ph V	1.75	%
506644	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	9 Month Operations	9	
506645	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Unknown Operations	0	
506646	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Tank Paint Condition	Good	
506647	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Switching Operations	2	
506648	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Operations Counter AL	173	
506649	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Operations Counter AF	170	
506650	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Moisture and Leak Free?	y	
506651	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Maintenance Operations	0	
506652	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Heaters (All) Functioning?	y	
506653	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Grounds in Place?	y	
506654	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	General Comments		
506655	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	General Comments		
506656	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Foundation Condition	Good	
506657	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Follow-up Action Required?	n	
506658	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Follow-up Action Required?	n	
506659	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Operations Ground	0	
506660	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
506661	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
506662	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Operations Counter AF	355	
506663	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Operations Counter AL	359	
506664	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
506665	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Adjusted Amps B Phase V	4.19	
506666	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Switching Operations	4	
506667	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Adjusted Amps A Phase V	4.19	
506668	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Equipment Properly Labeled?	y	
506669	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Paint Condition	Good	
506670	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
506671	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
506672	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
506673	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Bushings Connection/Risers	Good	
506674	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Bushing Condition	Good	
506675	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Amps C Ø	60.0	
506676	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Amps B Ø	60.0	
506677	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Bushings Connection/Risers	Good	
506678	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Bushing Condition	Good	
506679	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
506680	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
506681	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Bushing Condition	Good	
506682	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Amps C Ø	0.0	
506683	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Amps B Ø	0.0	
506684	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Amps A Ø	0.0	
506685	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
506686	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
506687	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Tank Paint Condition	Good	
506688	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Unknown Operations	0	
506689	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
506690	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	9 Month Operations	13	
506691	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Unknown Operations	0	
506692	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank Paint Condition	Good	
506693	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank Leaks	None	
506694	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
506695	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
506696	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
506697	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Switching Operations	0	
506698	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Amps A Ø	60.0	
506699	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Accumulated Fault Duty C Ph V	.94	%
506700	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Accumulated Fault Duty B Ph V	.94	%
506701	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Spring Compression Ind.	springcharged	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
506702	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
506703	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2019-03-26 00:00:00.000000	
506704	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Accumulated Fault Duty A Ph V	.94	%
506705	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	9 Month Operations	12	
506706	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Operations Counter AL	1091	
506707	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Operations Counter AF	1091	
506708	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Number of Ops last 9 Months	18	
506709	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Operations Counter AF	286	
506710	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
506711	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Maintenance Operations	0	
506712	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Amps C Ø	90.0	
506713	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Amps B Ø	44.0	
506714	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Amps A Ø	64.0	
506715	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Accumulated Fault Duty C Ph V	.35	%
506716	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Accumulated Fault Duty B Ph V	1.05	%
506717	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
506718	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	9 Month Operations	6	
506719	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Heaters (All) Functioning?	y	
506720	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Grounds in Place?	y	
506721	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	General Comments		
506722	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	General Comments		
506723	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
506724	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Foundation Condition	Good	
506725	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
506726	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations A Ø	0	
506727	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
506728	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations B Ø	0	
506729	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
506730	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations C Ø	0	
506731	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations Ground	0	
506732	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
506733	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	
506734	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
506735	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
506736	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
506737	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
506738	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Follow-up Action Required?	n	
506739	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	
506740	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	General Comments		
506741	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	General Comments		
506742	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations Ground	0	
506743	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Follow-up Action Required?	n	
506744	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Follow-up Action Required?	n	
506745	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Foundation Condition	Good	
506746	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	General Comments		
506747	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Grounds in Place?	y	
506748	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Heaters (All) Functioning?	y	
506749	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	General Comments		
506750	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	General Comments		
506751	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Foundation Condition	Good	
506752	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Maintenance Operations	0	
506753	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Moisture and Leak Free?	y	
506754	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
506755	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	General Comments		
506756	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Grounds in Place?	y	
506757	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Heaters (All) Functioning?	y	
506758	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Maintenance Operations	0	
506759	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Follow-up Action Required?	n	
506760	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Moisture and Leak Free?	y	
506761	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Operations Counter AF	243	
506762	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations C Ø	0	
506763	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations B Ø	0	
506764	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Operations Counter AL	245	
506765	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Switching Operations	2	
506766	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Tank Paint Condition	Good	
506767	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Unknown Operations	0	
506768	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations A Ø	0	
506769	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
506770	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
506771	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
506772	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Equipment Properly Labeled?	y	
506773	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Cabinet Paint Condition	Good	
506774	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
506775	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Maintenance Operations	0	
506776	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
506777	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Operations Counter AF	368	
506778	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Operations Counter AL	372	
506779	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
506780	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
506781	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
506782	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
506783	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
506784	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Follow-up Action Required?	n	
506785	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations Ground	1	
506786	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations C Ø	0	
506787	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations B Ø	0	
506788	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations A Ø	0	
506789	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Adjusted Amps C Phase V	4.19	
506790	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
506791	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Follow-up Action Required?	n	
506792	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
506793	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
506794	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
506795	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Bushings Connection/Risers	Good	
506796	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations Ground	0	
506797	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations C Ø	0	
506798	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
506799	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
506800	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
506801	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
506802	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
506803	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
506804	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
506805	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
506806	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
506807	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	General Comments		
506808	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Bushing Condition	Good	
506809	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Amps C Ø	144.0	
506810	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Amps B Ø	136.0	
506811	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Amps A Ø	155.0	
506812	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
506813	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Accumulated Fault Duty B Ph V	.35	%
506814	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations B Ø	0	
506815	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations A Ø	0	
506816	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
506817	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
506818	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
506819	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Equipment Properly Labeled?	y	
506820	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Paint Condition	Good	
506821	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
506822	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
506823	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
506824	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Bushings Connection/Risers	Good	
506825	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Bushing Condition	Good	
506826	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Amps C Ø	150.0	
506827	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Amps B Ø	120.0	
506828	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Amps A Ø	150.0	
506829	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
506830	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
506831	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
506832	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	9 Month Operations	6	
506833	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	General Comments		
506834	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
506835	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
506836	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
506837	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	9 Month Operations	9	
506838	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
506839	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
506840	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
506841	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
506842	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
506843	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	39	°F
506844	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
506845	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
506846	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
506847	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
506848	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
506849	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
506850	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Operations Counter AL	290	
506851	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	9 Month Operations	8	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
506852	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Accumulated Fault Duty A Ph V	.77	%
506853	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Accumulated Fault Duty B Ph V	.77	%
506854	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
506855	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Amps A Ø	120.0	
506856	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Amps B Ø	120.0	
506857	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Unknown Operations	0	
506858	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Tank Paint Condition	Good	
506859	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Follow-up Action Required?	n	
506860	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Follow-up Action Required?	n	
506861	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Fault Operations	0	
506862	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
506863	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
506864	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
506865	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
506866	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
506867	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
506868	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Bushing Oil Level	Good	
506869	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Bushing Condition	Good	
506870	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
506871	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
506872	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Pressure OK?	y	
506873	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Leaks	None	
506874	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
506875	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
506876	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Switching Operations	2	
506877	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Operations Counter AL	162	
506878	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Operations Counter AF	160	
506879	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Moisture and Leak Free?	y	
506880	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Maintenance Operations	0	
506881	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Heaters (All) Functioning?	y	
506882	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
506883	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Switching Operations	4	
506884	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Tank Paint Condition	Good	
506885	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Unknown Operations	0	
506886	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
506887	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	Oil Temp Present	20	°C
506888	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	Oil Temp Max	30	°C
506889	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	30.00	
506890	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	35.00	
506891	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
506892	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
506893	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
506894	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Grounds in Place?	y	
506895	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	General Comments		
506896	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	General Comments		
506897	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Foundation Condition	Good	
506898	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Unknown Operations	0	
506899	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Tank Paint Condition	Good	
506900	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Switching Operations	4	
506901	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
506902	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Operations Counter AL	233	
506903	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Operations Counter AF	229	
506904	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Follow-up Action Required?	n	
506905	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Follow-up Action Required?	n	
506906	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations Ground	0	
506907	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations C Ø	0	
506908	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations B Ø	0	
506909	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations A Ø	0	
506910	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
506911	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Moisture and Leak Free?	y	
506912	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Maintenance Operations	0	
506913	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
506914	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
506915	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Equipment Properly Labeled?	y	
506916	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Paint Condition	Good	
506917	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Heaters (All) Functioning?	y	
506918	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Grounds in Place?	y	
506919	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	General Comments		
506920	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	General Comments		
506921	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Foundation Condition	Good	
506922	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Follow-up Action Required?	n	
506923	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
506924	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
506925	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Min Tap Position	8L	
506926	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
506927	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
506928	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
506929	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Panels Dusted?	y	
506930	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
506931	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
506932	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
506933	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
506934	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Tank Leaks	None	
506935	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
506936	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
506937	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
506938	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
506939	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
506940	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
506941	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Min Tap Position	2L	
506942	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Max Tap Position	6R	
506943	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
506944	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	General Comments		
506945	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
506946	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
506947	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
506948	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
506949	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Current Tap Position	1R	
506950	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Max Tap Position	1L	
506951	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
506952	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	General Comments		
506953	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
506954	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
506955	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
506956	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
506957	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Current Tap Position	3L	
506958	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
506959	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
506960	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
506961	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
506962	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
506963	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
506964	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
506965	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
506966	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
506967	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
506968	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
506969	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
506970	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
506971	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
506972	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
506973	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
506974	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
506975	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
506976	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
506977	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
506978	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
506979	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
506980	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
506981	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
506982	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
506983	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
506984	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
506985	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
506986	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
506987	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
506988	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
506989	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
506990	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
506991	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
506992	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
506993	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
506994	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
506995	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
506996	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
506997	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
506998	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
506999	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
507000	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Evidence of Insects	None	
507001	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
507002	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
507003	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Floor Swept?	y	
507004	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
507005	3/26/2019 14:52	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
507006	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
507007	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Tank Leaks	None	
507008	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
507009	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
507010	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
507011	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
507012	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
507013	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
507014	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Min Tap Position	2L	
507015	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Max Tap Position	6R	
507016	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
507017	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	General Comments		
507018	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
507019	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
507020	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
507021	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
507022	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Current Tap Position	2R	
507023	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
507024	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
507025	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
507026	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
507027	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
507028	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
507029	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
507030	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
507031	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
507032	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
507033	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
507034	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
507035	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
507036	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	General Comments		
507037	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
507038	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
507039	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
507040	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
507041	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
507042	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
507043	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Tank Leaks	None	
507044	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
507045	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
507046	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Regulator As Left Counter	10025	
507047	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
507048	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
507049	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
507050	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
507051	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
507052	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Min Tap Position	3L	
507053	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Max Tap Position	1R	
507054	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0543	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
507055	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0543	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
507056	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0543	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
507057	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0543	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
507058	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0543	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	43562	
507059	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0543	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
507060	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0543	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
507061	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
507062	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	General Comments		
507063	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
507064	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
507065	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Totalizer Meter Reading	.8244	
507066	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
507067	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
507068	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
507069	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
507070	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
507071	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
507072	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
507073	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
507074	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Oil Temp Present	40	°C
507075	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
507076	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
507077	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
507078	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
507079	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
507080	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
507081	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Current Tap Position	3L	
507082	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
507083	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
507084	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
507085	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
507086	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
507087	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
507088	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
507089	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
507090	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0543	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
507091	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0543	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
507092	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0543	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
507093	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0543	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
507094	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
507095	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
507096	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
507097	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
507098	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
507099	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0543	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Low	
507100	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
507101	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Oil Temp Max	40	°C
507102	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0543	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
507103	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0543	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	5L	
507104	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0543	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
507105	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0543	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
507106	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0543	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
507107	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0543	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
507108	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0543	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
507109	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0543	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
507110	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0543	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	1R	
507111	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0543	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	5L	
507112	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0543	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
507113	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	R0543	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
507114	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
507115	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
507116	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	General Comments		
507117	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
507118	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Foundation Condition	Good	
507119	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
507120	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
507121	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
507122	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
507123	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
507124	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
507125	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
507126	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
507127	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
507128	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Ambient Temp	41	°F
507129	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
507130	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Clear of Trash?	n	
507131	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
507132	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
507133	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
507134	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Amps B Ø	8.0	
507135	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
507136	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
507137	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
507138	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
507139	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	General Comments	.	
507140	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
507141	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
507142	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Vegetation	None	
507143	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
507144	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
507145	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
507146	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
507147	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
507148	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
507149	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
507150	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
507151	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
507152	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
507153	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
507154	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
507155	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	General Comments		
507156	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
507157	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
507158	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
507159	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
507160	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
507161	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
507162	3/26/2019 11:39	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
507163	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
507164	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
507165	3/26/2019 11:27	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
507166	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Operations Counter	31	
507167	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
507168	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Tank Leaks	None	
507169	3/26/2019 12:55	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
507170	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
507171	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Tank Leaks	None	
507172	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
507173	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
507174	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Regulator As Left Counter	11114	
507175	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
507176	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
507177	3/26/2019 15:15	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
507178	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Oil Temp Max	30	°C
507179	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Oil Temp Present	20	°C
507180	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
507181	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
507182	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
507183	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
507184	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	General Comments		
507185	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	General Comments		
507186	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
507187	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
507188	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Totalizer Meter Reading	.3642	
507189	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
507190	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	9 Month Operations	0	
507191	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
507192	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Bushing Condition	Good	
507193	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Amps C Ø	12.0	
507194	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Amps B Ø	12.0	
507195	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Accumulated Fault Duty A Ph V	.70	%
507196	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
507197	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
507198	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
507199	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
507200	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
507201	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
507202	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
507203	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
507204	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations A Ø	0	
507205	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations B Ø	0	
507206	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations C Ø	0	
507207	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations Ground	0	
507208	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Follow-up Action Required?	n	
507209	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Follow-up Action Required?	n	
507210	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Foundation Condition	Good	
507211	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
507212	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	General Comments		
507213	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	General Comments		
507214	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
507215	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
507216	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
507217	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
507218	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Amps A Ø	12.0	
507219	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
507220	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
507221	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
507222	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
507223	3/26/2019 15:16	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	291.36	kw
507224	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
507225	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
507226	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
507227	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
507228	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
507229	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
507230	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
507231	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
507232	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
507233	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
507234	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
507235	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
507236	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
507237	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
507238	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
507239	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
507240	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
507241	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
507242	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
507243	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
507244	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Unknown Operations	0	
507245	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	General Comments		
507246	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
507247	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC As Left Counter	70127	
507248	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
507249	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC As Found Counter	70127	
507250	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	General Comments		
507251	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
507252	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	General Comments		
507253	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
507254	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
507255	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	11.07	%
507256	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	13.15	%
507257	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	13.14	%
507258	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	130.0	
507259	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
507260	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	125.0	
507261	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
507262	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Maintenance Operations	0	
507263	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
507264	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Operations Counter AF	158	
507265	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Operations Counter AL	158	
507266	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
507267	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Tank Paint Condition	Good	
507268	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
507269	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
507270	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
507271	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
507272	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
507273	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
507274	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
507275	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC As Left Counter	165931	
507276	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
507277	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0216	NonLTC	363-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
507278	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0216	NonLTC	363-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
507279	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0216	NonLTC	363-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
507280	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0216	NonLTC	363-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
507281	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0216	NonLTC	363-1 C	NonLTC Transformer Patrol Inspection	General Comments		
507282	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0216	NonLTC	363-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
507283	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
507284	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
507285	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
507286	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
507287	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	62	
507288	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
507289	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
507290	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
507291	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
507292	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
507293	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
507294	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
507295	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
507296	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
507297	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
507298	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
507299	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
507300	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
507301	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
507302	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Switching Operations	0	
507303	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Tank Paint Condition	Good	
507304	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Min Tap Position	8L	
507305	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	General Comments		
507306	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
507307	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
507308	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
507309	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
507310	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
507311	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
507312	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
507313	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
507314	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
507315	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
507316	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
507317	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	BAT000161	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
507318	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	BAT000161	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	66	°F
507319	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	BAT000161	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
507320	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
507321	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
507322	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
507323	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
507324	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations A Ø	0	
507325	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
507326	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
507327	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
507328	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Equipment Properly Labeled?	y	
507329	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Paint Condition	Good	
507330	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
507331	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
507332	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
507333	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
507334	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3L	
507335	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
507336	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
507337	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
507338	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
507339	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Follow-up Action Required?	n	
507340	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
507341	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
507342	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	General Comments		
507343	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	General Comments		
507344	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
507345	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	LTC Totalizer Reading	2467.20	kw
507346	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
507347	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
507348	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	Follow-up Action Required?	n	
507349	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
507350	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
507351	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
507352	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
507353	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
507354	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
507355	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
507356	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
507357	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
507358	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations Ground	0	
507359	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Unknown Operations	0	
507360	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
507361	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
507362	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Follow-up Action Required?	n	
507363	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Follow-up Action Required?	n	
507364	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Foundation Condition	Good	
507365	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
507366	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC As Found Counter	211803	
507367	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Foundation Condition	Good	
507368	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Follow-up Action Required?	n	
507369	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Follow-up Action Required?	n	
507370	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations Ground	0	
507371	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	BAT000161	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
507372	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
507373	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	BAT000161	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
507374	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	BAT000161	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
507375	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	BAT000161	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
507376	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	BAT000161	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
507377	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	BAT000161	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
507378	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	BAT000161	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
507379	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	BAT000161	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
507380	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	BAT000161	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
507381	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	BAT000161	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
507382	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
507383	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
507384	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
507385	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
507386	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	BAT000161	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
507387	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations C Ø	0	
507388	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations B Ø	0	
507389	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC As Left Counter	211803	
507390	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
507391	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Operations Since Last Insp	896	
507392	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	General Comments		
507393	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
507394	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Foundation Condition	Good	
507395	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
507396	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
507397	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
507398	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
507399	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Operations Since Last Insp	837	
507400	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
507401	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
507402	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
507403	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
507404	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Paint Condition	Good	
507405	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Equipment Properly Labeled?	y	
507406	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
507407	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Follow-up Action Required?	n	
507408	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
507409	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
507410	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
507411	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	General Comments		
507412	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	LTC Totalizer Reading	5433.60	kw
507413	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
507414	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	9 Month Operations	0	
507415	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
507416	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
507417	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Oil Temp Max	35	°C
507418	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Oil Temp Present	35	°C
507419	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
507420	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Totalizer Meter Reading	.5660	
507421	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
507422	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
507423	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
507424	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
507425	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
507426	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
507427	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	316	
507428	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Swept?	y	
507429	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
507430	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
507431	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
507432	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Amps A Ø	480.0	
507433	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Amps B Ø	480.0	
507434	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Amps C Ø	480.0	
507435	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Bushing Condition	Good	
507436	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
507437	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Paint Condition	Good	
507438	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Equipment Properly Labeled?	y	
507439	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
507440	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
507441	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
507442	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations A Ø	0	
507443	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations B Ø	0	
507444	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations C Ø	0	
507445	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations Ground	0	
507446	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Follow-up Action Required?	n	
507447	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Follow-up Action Required?	n	
507448	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Foundation Condition	Good	
507449	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	General Comments		
507450	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	General Comments		
507451	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
507452	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Heaters (All) Functioning?	y	
507453	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Amps C Ø	120.0	
507454	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Bushing Condition	Good	
507455	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Bushings Connection/Risers	Good	
507456	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
507457	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
507458	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
507459	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
507460	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
507461	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
507462	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
507463	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
507464	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
507465	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
507466	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
507467	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
507468	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
507469	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
507470	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
507471	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
507472	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
507473	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
507474	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
507475	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
507476	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
507477	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
507478	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
507479	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
507480	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	General Comments		
507481	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
507482	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
507483	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
507484	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
507485	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
507486	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	244	
507487	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	244	
507488	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
507489	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Min Tap Position	9L	
507490	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Max Tap Position	3R	
507491	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
507492	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
507493	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	General Comments		
507494	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
507495	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
507496	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
507497	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Current Tap Position	2L	
507498	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
507499	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
507500	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
507501	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
507502	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
507503	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
507504	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
507505	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
507506	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Operations A Ø	0	
507507	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Operations B Ø	0	
507508	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
507509	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
507510	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	General Comments		
507511	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
507512	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC As Found Counter	165931	
507513	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
507514	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Panels Dusted?	y	
507515	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Switch Diagram Present/Current	y	
507516	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
507517	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
507518	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Operations C Ø	0	
507519	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Operations Ground	0	
507520	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Follow-up Action Required?	n	
507521	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Follow-up Action Required?	n	
507522	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Foundation Condition	Good	
507523	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	General Comments		
507524	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	General Comments		
507525	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Grounds in Place?	y	
507526	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	316	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
507527	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
507528	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Maintenance Operations	0	
507529	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Moisture and Leak Free?	y	
507530	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Operations Counter AF	372	
507531	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Operations Counter AL	376	
507532	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
507533	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
507534	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
507535	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
507536	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
507537	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
507538	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
507539	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
507540	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
507541	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
507542	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
507543	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
507544	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
507545	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
507546	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
507547	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
507548	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
507549	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
507550	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
507551	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
507552	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
507553	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Switching Operations	4	
507554	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
507555	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
507556	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments		
507557	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
507558	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations A Ø	0	
507559	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations B Ø	0	
507560	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations C Ø	0	
507561	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
507562	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
507563	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
507564	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
507565	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
507566	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	General Comments		
507567	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
507568	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
507569	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
507570	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
507571	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
507572	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Tank Paint Condition	Good	
507573	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PF001197	PowerFuse	WP-33KV TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
507574	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PF001197	PowerFuse	WP-33KV TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
507575	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Unknown Operations	0	
507576	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
507577	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
507578	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
507579	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
507580	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
507581	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
507582	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
507583	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
507584	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
507585	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
507586	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	20	
507587	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	9 Month Operations	10	
507588	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
507589	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
507590	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
507591	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
507592	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	General Comments		
507593	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
507594	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
507595	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
507596	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
507597	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
507598	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
507599	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
507600	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
507601	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
507602	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
507603	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
507604	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
507605	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
507606	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
507607	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
507608	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
507609	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
507610	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
507611	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	General Comments		
507612	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
507613	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	LTC Totalizer Reading	13610.88	kw
507614	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
507615	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
507616	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Oil Temp Max	55	°C
507617	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
507618	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Oil Temp Present	50	°C
507619	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
507620	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
507621	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Accumulated Fault Duty C Ph V	2.95	%
507622	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
507623	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
507624	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	386	
507625	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	386	
507626	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
507627	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
507628	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
507629	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
507630	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Maintenance Operations	0	
507631	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Moisture and Leak Free?	y	
507632	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Operations Counter AF	376	
507633	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Operations Counter AL	376	
507634	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
507635	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
507636	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Accumulated Fault Duty A Ph V	3.93	%
507637	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
507638	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
507639	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Switching Operations	0	
507640	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
507641	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
507642	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	BCH000211	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
507643	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	BCH000211	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
507644	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	BCH000211	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
507645	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	BCH000211	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
507646	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
507647	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
507648	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
507649	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
507650	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
507651	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
507652	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	20	
507653	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
507654	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
507655	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
507656	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
507657	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
507658	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	3.67	
507659	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
507660	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
507661	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	2	
507662	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
507663	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
507664	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
507665	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
507666	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
507667	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
507668	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
507669	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
507670	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
507671	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
507672	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
507673	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
507674	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
507675	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
507676	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
507677	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
507678	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
507679	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
507680	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
507681	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
507682	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
507683	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
507684	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
507685	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
507686	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
507687	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	General Comments		
507688	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
507689	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
507690	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
507691	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
507692	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
507693	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
507694	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
507695	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	General Comments		
507696	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
507697	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
507698	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
507699	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	.50	MegaVars
507700	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	-.21	MegaVars
507701	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	5.54	MegaWatts
507702	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	.14	MegaWatts
507703	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
507704	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	General Comments	T.C filter will not start. Run hours at 75681.7	
507705	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
507706	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
507707	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
507708	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	Oil Temp Max	30	°C
507709	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
507710	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
507711	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
507712	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
507713	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Adequate	
507714	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
507715	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
507716	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
507717	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
507718	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
507719	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
507720	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
507721	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
507722	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
507723	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
507724	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
507725	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
507726	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	Oil Temp Max	30	°C
507727	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
507728	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
507729	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
507730	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
507731	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
507732	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
507733	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
507734	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
507735	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
507736	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
507737	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
507738	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
507739	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
507740	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
507741	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
507742	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
507743	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
507744	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
507745	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
507746	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Clear of Trash?	y	
507747	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
507748	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
507749	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
507750	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
507751	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
507752	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
507753	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	General Comments	no spill kit	
507754	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
507755	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	180.0	
507756	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	180.0	
507757	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
507758	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
507759	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
507760	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Clear of Trash?	y	
507761	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
507762	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
507763	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
507764	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
507765	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
507766	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
507767	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	General Comments		
507768	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	180.0	
507769	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
507770	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
507771	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
507772	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Grounds in Place?	y	
507773	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Heaters (All) Functioning?	y	
507774	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
507775	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Vegetation	None	
507776	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
507777	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Operations Counter AL	270	
507778	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
507779	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
507780	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
507781	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
507782	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
507783	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
507784	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
507785	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Oil Temp Max	30	°C
507786	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	74	
507787	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Oil Temp Present	30	°C
507788	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
507789	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
507790	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
507791	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
507792	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
507793	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
507794	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
507795	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
507796	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
507797	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Totalizer Meter Reading	.5140	
507798	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
507799	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
507800	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
507801	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
507802	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
507803	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Tank Paint Condition	Good	
507804	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Switching Operations	4	
507805	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Max Tap Position	4R	
507806	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Current Tap Position	1L	
507807	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
507808	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC As Left Counter	123067	
507809	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC As Found Counter	123067	
507810	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	General Comments		
507811	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	General Comments		
507812	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
507813	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	Follow-up Action Required?	n	
507814	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
507815	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
507816	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
507817	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Unknown Operations	0	
507818	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
507819	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
507820	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Winding Temp Present	50	°C
507821	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Winding Temp Max	55	°C
507822	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Totalizer Meter Reading	1.4178	
507823	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
507824	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
507825	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
507826	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Tank Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
507827	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
507828	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
507829	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	
507830	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	33.69	%
507831	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	38.28	%
507832	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	21.44	%
507833	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
507834	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
507835	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
507836	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
507837	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
507838	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
507839	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
507840	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
507841	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Follow-up Action Required?	n	
507842	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Bushings Connection/Risers	Good	
507843	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Bushing Condition	Good	
507844	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
507845	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
507846	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Maintenance Operations	0	
507847	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Heaters (All) Functioning?	y	
507848	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Grounds in Place?	y	
507849	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	General Comments		
507850	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	General Comments		
507851	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Accumulated Fault Duty B Ph V	3.46	%
507852	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Accumulated Fault Duty A Ph V	3.46	%
507853	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	9 Month Operations	4	
507854	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	BCH000211	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.360	millivolts
507855	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	BCH000211	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
507856	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
507857	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
507858	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	BCH000211	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
507859	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
507860	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
507861	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
507862	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
507863	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
507864	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
507865	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	General Comments		
507866	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Amps C Ø	120.0	
507867	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Amps B Ø	120.0	
507868	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Amps A Ø	120.0	
507869	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	General Comments		
507870	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
507871	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
507872	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
507873	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
507874	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
507875	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
507876	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Vegetation	None	
507877	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
507878	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
507879	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
507880	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
507881	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Foundation Condition	Good	
507882	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
507883	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
507884	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
507885	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
507886	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
507887	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
507888	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
507889	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
507890	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	All Connections OK?	y	
507891	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	Follow-up Action Required?	n	
507892	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Amps B Ø	80.0	
507893	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	General Comments		
507894	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	LTC Operation Checked?	y	
507895	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
507896	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
507897	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
507898	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	VRR Time Delay	30	Seconds
507899	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Amps A Ø	80.0	
507900	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Operations Counter AF	266	
507901	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
507902	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
507903	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
507904	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
507905	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	General Comments		
507906	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
507907	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
507908	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
507909	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
507910	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
507911	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Accumulated Fault Duty C Ph V	4.15	%
507912	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
507913	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
507914	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Top Oil Temperature Present	50	°C
507915	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Top Oil Temperature Max	50	°C
507916	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
507917	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0237	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
507918	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0237	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
507919	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
507920	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
507921	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Current Tap Position	5L	
507922	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
507923	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC As Left Counter	94199	
507924	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
507925	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	1	
507926	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	1	
507927	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
507928	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	4.92	%
507929	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.97	%
507930	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
507931	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
507932	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
507933	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
507934	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	120.0	
507935	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	120.0	
507936	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	120.0	
507937	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.59	%
507938	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
507939	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
507940	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	6	
507941	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
507942	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
507943	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
507944	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
507945	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
507946	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	446	
507947	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
507948	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
507949	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
507950	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
507951	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
507952	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
507953	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	9 Month Operations	0	
507954	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
507955	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
507956	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	All Connections OK?	y	
507957	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	6	
507958	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
507959	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	Follow-up Action Required?	n	
507960	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
507961	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
507962	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	General Comments		
507963	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Follow-up Action Required?	n	
507964	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
507965	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Amps A Ø	640.0	
507966	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Amps B Ø	640.0	
507967	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Amps C Ø	640.0	
507968	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Bushing Condition	Good	
507969	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
507970	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
507971	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
507972	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
507973	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
507974	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
507975	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
507976	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
507977	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
507978	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	446	
507979	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Vegetation	None	
507980	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
507981	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
507982	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
507983	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
507984	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
507985	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
507986	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
507987	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
507988	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
507989	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
507990	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	General Comments	No berm or spill kit.	
507991	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
507992	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
507993	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
507994	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
507995	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
507996	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
507997	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
507998	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
507999	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
508000	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
508001	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
508002	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
508003	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
508004	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
508005	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Winding Temp Present	55	°C
508006	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
508007	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	4.92	%
508008	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
508009	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	120.0	
508010	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	General Comments		
508011	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
508012	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
508013	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
508014	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
508015	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
508016	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
508017	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Operations Since Last Insp	403	
508018	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Min Tap Position	13L	
508019	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0237	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
508020	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0237	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
508021	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
508022	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
508023	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0237	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
508024	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Winding Temp Max	55	°C
508025	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Totalizer Meter Reading	.7330	
508026	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0237	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
508027	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
508028	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
508029	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	Follow-up Action Required?	n	
508030	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
508031	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	General Comments		
508032	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	General Comments		
508033	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
508034	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
508035	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Follow-up Action Required?	n	
508036	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
508037	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
508038	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
508039	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
508040	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
508041	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Operations A Ø	0	
508042	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Operations B Ø	0	
508043	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Operations C Ø	0	
508044	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Unknown Operations	0	
508045	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Tank Paint Condition	Good	
508046	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Switching Operations	0	
508047	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
508048	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
508049	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
508050	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Operations Counter AL	200	
508051	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Operations Counter AF	200	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
508052	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
508053	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Maintenance Operations	0	
508054	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
508055	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Operations Ground	0	
508056	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
508057	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
508058	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
508059	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
508060	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
508061	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
508062	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	General Comments		
508063	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
508064	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
508065	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
508066	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
508067	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
508068	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
508069	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
508070	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Grounds in Place?	y	
508071	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	General Comments		
508072	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	General Comments		
508073	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Foundation Condition	Good	
508074	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
508075	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
508076	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
508077	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Follow-up Action Required?	n	
508078	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
508079	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
508080	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Poor	
508081	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
508082	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
508083	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Clear of Trash?	y	
508084	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
508085	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	6.13	
508086	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	6.13	
508087	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
508088	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
508089	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
508090	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	General Comments		
508091	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
508092	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
508093	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
508094	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
508095	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
508096	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
508097	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
508098	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	LTC Operation Checked?	y	
508099	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	LTCC000642	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
508100	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	LTCC000642	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
508101	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
508102	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
508103	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	LTCC000642	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
508104	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
508105	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	LTCC000642	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
508106	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	LTCC000642	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
508107	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	LTCC000642	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
508108	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	LTCC000642	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
508109	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
508110	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	LTCC000642	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
508111	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	LTCC000642	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
508112	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
508113	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
508114	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Operations Since Last Insp	2336	
508115	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Min Tap Position	13L	
508116	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Max Tap Position	2L	
508117	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
508118	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	VRR Time Delay	30	Seconds
508119	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	51.6	VDC
508120	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	51.7	VDC
508121	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.700	millivolts
508122	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
508123	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
508124	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
508125	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
508126	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
508127	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
508128	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
508129	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
508130	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
508131	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
508132	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
508133	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
508134	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
508135	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
508136	3/25/2019 11:40	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
508137	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Current Tap Position	8L	
508138	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
508139	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC As Left Counter	120907	
508140	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC As Found Counter	120907	
508141	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	General Comments		
508142	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	General Comments		
508143	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
508144	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
508145	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	7	
508146	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
508147	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
508148	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	General Comments		
508149	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
508150	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	60.0	
508151	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	60.0	
508152	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	60.0	
508153	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
508154	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
508155	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
508156	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
508157	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
508158	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
508159	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
508160	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
508161	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
508162	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	Follow-up Action Required?	n	
508163	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
508164	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	General Comments		
508165	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	General Comments		
508166	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC As Found Counter	94195	
508167	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
508168	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
508169	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Clear of Trash?	y	
508170	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
508171	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
508172	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
508173	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
508174	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
508175	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
508176	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
508177	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
508178	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
508179	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	PF000254	PowerFuse	MU-33KV TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
508180	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	PF000254	PowerFuse	MU-33KV TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
508181	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
508182	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
508183	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
508184	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
508185	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
508186	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
508187	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
508188	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
508189	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
508190	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
508191	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
508192	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
508193	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
508194	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
508195	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
508196	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
508197	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
508198	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
508199	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
508200	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
508201	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
508202	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
508203	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
508204	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
508205	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
508206	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
508207	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
508208	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
508209	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
508210	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
508211	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	General Comments		
508212	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
508213	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
508214	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
508215	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Very Low	
508216	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
508217	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
508218	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
508219	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
508220	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Bushings Connection/Risers	Good	
508221	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Bushing Condition	Good	
508222	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Amps C Ø	320.0	
508223	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Amps B Ø	320.0	
508224	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Amps A Ø	320.0	
508225	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Accumulated Fault Duty C Ph V	1.83	%
508226	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	560	
508227	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	556	
508228	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
508229	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	4	
508230	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
508231	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
508232	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
508233	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
508234	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
508235	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
508236	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
508237	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
508238	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
508239	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
508240	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
508241	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
508242	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
508243	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
508244	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
508245	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
508246	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Vegetation	None	
508247	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
508248	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
508249	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
508250	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
508251	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
508252	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
508253	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
508254	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	LTC Totalizer Reading	10555.20	kw
508255	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
508256	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
508257	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
508258	3/25/2019 10:46	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
508259	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	14	
508260	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	14	
508261	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
508262	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
508263	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
508264	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
508265	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
508266	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
508267	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
508268	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
508269	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
508270	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
508271	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
508272	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
508273	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
508274	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
508275	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
508276	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
508277	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
508278	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
508279	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
508280	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
508281	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
508282	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
508283	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
508284	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
508285	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
508286	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	9 Month Operations	8	
508287	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
508288	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	120.0	
508289	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	120.0	
508290	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
508291	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
508292	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
508293	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
508294	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
508295	3/25/2019 14:34	Distribution	Big Stone Gap Storeroom Spare Transforme	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Very Low	
508296	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Accumulated Fault Duty A Ph V	1.37	%
508297	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
508298	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
508299	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
508300	3/25/2019 15:25	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
508301	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
508302	3/25/2019 14:22	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Accumulated Fault Duty B Ph V	.46	%
508303	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BCH000476	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
508304	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BCH000476	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
508305	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BCH000476	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
508306	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BCH000476	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
508307	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BCH000476	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
508308	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BCH000476	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
508309	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
508310	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	11.62	%
508311	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	5.81	%
508312	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	6.70	%
508313	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
508314	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
508315	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
508316	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Grounds in Place?	y	
508317	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
508318	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
508319	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
508320	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
508321	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations A Ø	0	
508322	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations B Ø	0	
508323	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations C Ø	0	
508324	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations Ground	0	
508325	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
508326	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Follow-up Action Required?	n	
508327	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Follow-up Action Required?	n	
508328	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
508329	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
508330	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
508331	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	LTCC000243	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
508332	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
508333	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
508334	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
508335	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
508336	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
508337	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
508338	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
508339	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
508340	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
508341	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	General Comments		
508342	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
508343	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1516	
508344	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	13	
508345	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1510	
508346	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
508347	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	LTCC000243	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
508348	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
508349	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
508350	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
508351	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	LTCC000047	LTCControl	427-1 C	LTC Control Insp	VRR Time Delay	30	Seconds

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
508352	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	LTCC000047	LTCControl	427-1 C	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
508353	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	LTCC000047	LTCControl	427-1 C	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
508354	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
508355	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
508356	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Maintenance Operations	0	
508357	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
508358	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
508359	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Readings	General Comments		
508360	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
508361	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Foundation Condition	Good	
508362	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
508363	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
508364	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
508365	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
508366	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
508367	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
508368	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
508369	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
508370	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
508371	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
508372	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	9 Month Operations	0	
508373	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
508374	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
508375	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
508376	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Amps A Ø	280.0	
508377	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Amps B Ø	280.0	
508378	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
508379	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	30	°C
508380	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Amps C Ø	240.0	
508381	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Operations Counter AF	225	
508382	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Operations Counter AL	225	
508383	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Switching Operations	0	
508384	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
508385	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
508386	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
508387	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Bushing Condition	Good	
508388	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
508389	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
508390	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
508391	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
508392	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
508393	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
508394	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
508395	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Tank Paint Condition	Good	
508396	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Unknown Operations	0	
508397	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
508398	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
508399	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
508400	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
508401	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	6	
508402	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
508403	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
508404	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
508405	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
508406	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	General Comments		
508407	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
508408	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
508409	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
508410	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
508411	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	200	psi
508412	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
508413	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
508414	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Oil Temp Max	40	°C
508415	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
508416	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
508417	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
508418	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
508419	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
508420	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
508421	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
508422	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
508423	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Totalizer Meter Reading	.4422	
508424	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
508425	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
508426	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
508427	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
508428	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
508429	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
508430	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
508431	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	90.0	
508432	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
508433	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Patrol Inspection	Follow-up Action Required?	n	
508434	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	50.0	
508435	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	50.0	
508436	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
508437	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	PF000089	PowerFuse	CL-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
508438	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	PF000089	PowerFuse	CL-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
508439	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
508440	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Patrol Inspection	Follow-up Action Required?	n	
508441	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Patrol Inspection	General Comments	ok	
508442	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
508443	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	PF000090	PowerFuse	CL-12KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
508444	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	PF000090	PowerFuse	CL-12KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
508445	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
508446	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
508447	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Patrol Inspection	Follow-up Action Required?	n	
508448	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
508449	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
508450	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
508451	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
508452	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
508453	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments		
508454	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
508455	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
508456	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
508457	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
508458	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
508459	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
508460	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
508461	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
508462	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
508463	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
508464	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
508465	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
508466	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
508467	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Follow-up Action Required?	n	
508468	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
508469	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
508470	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	General Comments		
508471	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	General Comments		
508472	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
508473	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
508474	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	14130	
508475	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1409	
508476	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	PF000088	PowerFuse	CL-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
508477	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
508478	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	49.03	%
508479	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	49.03	%
508480	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	49.03	%
508481	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
508482	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
508483	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
508484	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
508485	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
508486	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
508487	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
508488	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
508489	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
508490	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
508491	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
508492	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
508493	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
508494	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
508495	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	PF000088	PowerFuse	CL-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
508496	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	6.73	%
508497	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	6.73	%
508498	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	9.61	%
508499	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
508500	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Equipment Properly Labeled?	y	
508501	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
508502	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
508503	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Patrol Inspection	General Comments	ok	
508504	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	15	
508505	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
508506	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
508507	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
508508	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
508509	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
508510	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Readings	General Comments		
508511	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
508512	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
508513	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
508514	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
508515	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
508516	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
508517	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
508518	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	LTC Totalizer Reading	1415.04	kw
508519	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	General Comments	ok	
508520	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
508521	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	40	°C
508522	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
508523	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
508524	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	43	°F
508525	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
508526	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
508527	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
508528	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
508529	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
508530	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Moisture and Leak Free?	y	
508531	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Operations Counter AF	305	
508532	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Operations Counter AL	309	
508533	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
508534	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
508535	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
508536	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	General Comments		
508537	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
508538	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
508539	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
508540	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
508541	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
508542	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
508543	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
508544	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
508545	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
508546	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
508547	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
508548	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
508549	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
508550	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Switching Operations	4	
508551	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Tank Paint Condition	Good	
508552	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
508553	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
508554	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
508555	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
508556	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
508557	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
508558	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
508559	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
508560	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
508561	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
508562	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	LTCC000047	LTCControl	427-1 C	LTC Control Insp	All Connections OK?	y	
508563	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	LTCC000047	LTCControl	427-1 C	LTC Control Insp	Follow-up Action Required?	n	
508564	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	LTCC000047	LTCControl	427-1 C	LTC Control Insp	General Comments		
508565	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	LTCC000047	LTCControl	427-1 C	LTC Control Insp	LTC Operation Checked?	y	
508566	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
508567	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
508568	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
508569	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
508570	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	LTCC000047	LTCControl	427-1 C	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
508571	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	General Comments		
508572	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
508573	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
508574	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
508575	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
508576	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
508577	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
508578	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
508579	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
508580	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
508581	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
508582	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
508583	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
508584	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
508585	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
508586	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
508587	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	99763	
508588	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	99767	
508589	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
508590	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
508591	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
508592	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Operations A Ø	0	
508593	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Operations B Ø	0	
508594	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Operations C Ø	0	
508595	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Operations Ground	0	
508596	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Follow-up Action Required?	n	
508597	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Follow-up Action Required?	n	
508598	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Foundation Condition	Good	
508599	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	General Comments		
508600	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	General Comments		
508601	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Grounds in Place?	y	
508602	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Heaters (All) Functioning?	y	
508603	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Maintenance Operations	0	
508604	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
508605	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
508606	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
508607	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
508608	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
508609	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
508610	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
508611	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
508612	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
508613	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
508614	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
508615	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
508616	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
508617	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
508618	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
508619	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
508620	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
508621	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
508622	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
508623	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
508624	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
508625	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	General Comments	6 pack needs filled	
508626	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC As Found Counter	109727	
508627	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC As Left Counter	109727	
508628	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Vegetation	None	
508629	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
508630	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Current Tap Position	1L	
508631	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Max Tap Position	4R	
508632	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Min Tap Position	7L	
508633	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
508634	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
508635	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
508636	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	General Comments		
508637	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
508638	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Patrol Inspection	Follow-up Action Required?	n	
508639	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Patrol Inspection	General Comments	ok	
508640	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
508641	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
508642	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
508643	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
508644	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
508645	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
508646	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
508647	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	35	°C
508648	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	35	°C
508649	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
508650	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
508651	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	LTC Totalizer Reading	5961.60	kw

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
508652	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	54	°F
508653	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
508654	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Operations Since Last Insp	707	
508655	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
508656	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
508657	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
508658	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
508659	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
508660	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
508661	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
508662	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
508663	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
508664	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
508665	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
508666	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
508667	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
508668	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
508669	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
508670	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
508671	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
508672	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Clear of Trash?	y	
508673	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
508674	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
508675	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Ambient Temp	47	°F
508676	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
508677	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	General Comments		
508678	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
508679	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
508680	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
508681	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
508682	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
508683	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
508684	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
508685	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
508686	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
508687	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
508688	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
508689	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
508690	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
508691	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
508692	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
508693	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
508694	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
508695	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
508696	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
508697	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
508698	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
508699	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
508700	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
508701	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	PF000087	PowerFuse	CL-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
508702	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	PF000087	PowerFuse	CL-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
508703	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	LTC Operation Checked?	y	
508704	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
508705	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
508706	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
508707	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
508708	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	VRR Time Delay	30	Seconds
508709	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
508710	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
508711	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
508712	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
508713	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
508714	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
508715	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
508716	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
508717	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	24	
508718	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	24	
508719	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
508720	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
508721	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
508722	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
508723	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
508724	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
508725	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
508726	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
508727	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
508728	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
508729	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
508730	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	General Comments		
508731	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
508732	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
508733	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Foundation Condition	Good	
508734	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	General Comments		
508735	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	General Comments		
508736	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC As Found Counter	15461	
508737	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	Follow-up Action Required?	n	
508738	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
508739	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
508740	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
508741	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
508742	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
508743	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
508744	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
508745	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
508746	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	ok	
508747	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
508748	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
508749	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	General Comments		
508750	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	General Comments		
508751	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
508752	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
508753	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
508754	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Patrol Inspection	Equipment Properly Labeled?	y	
508755	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
508756	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
508757	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Clear of Trash?	y	
508758	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
508759	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
508760	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	LTCC000243	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
508761	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	LTCC000243	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
508762	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	LTCC000243	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
508763	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Patrol Inspection	General Comments	ok	
508764	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
508765	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Patrol Inspection	Follow-up Action Required?	n	
508766	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
508767	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	LTCC000243	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
508768	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	LTCC000243	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
508769	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	LTCC000243	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
508770	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
508771	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
508772	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	LTCC000243	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
508773	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Patrol Inspection	Follow-up Action Required?	n	
508774	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
508775	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
508776	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
508777	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	9 Month Operations	9	
508778	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
508779	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
508780	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Patrol Inspection	General Comments	ok	
508781	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
508782	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	General Comments		
508783	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
508784	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
508785	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
508786	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Vegetation	None	
508787	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
508788	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
508789	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
508790	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
508791	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
508792	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
508793	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
508794	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	General Comments		
508795	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
508796	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
508797	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
508798	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
508799	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
508800	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
508801	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
508802	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
508803	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
508804	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
508805	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
508806	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
508807	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
508808	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
508809	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
508810	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
508811	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	General Comments	ok	
508812	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
508813	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
508814	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
508815	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
508816	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
508817	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
508818	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
508819	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
508820	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
508821	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
508822	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
508823	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
508824	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Patrol Inspection	Equipment Properly Labeled?	y	
508825	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Patrol Inspection	Follow-up Action Required?	n	
508826	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Patrol Inspection	General Comments	ok	
508827	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
508828	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
508829	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
508830	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
508831	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
508832	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
508833	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
508834	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
508835	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
508836	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
508837	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
508838	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
508839	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
508840	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
508841	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
508842	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
508843	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
508844	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
508845	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
508846	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	320.0	
508847	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	320.0	
508848	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	320.0	
508849	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
508850	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.54	%
508851	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.54	%
508852	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.54	%
508853	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
508854	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	General Comments		
508855	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
508856	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
508857	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
508858	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
508859	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
508860	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
508861	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
508862	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
508863	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
508864	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
508865	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
508866	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
508867	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
508868	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
508869	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
508870	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
508871	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
508872	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
508873	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
508874	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC As Left Counter	15461	
508875	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Unknown Operations	0	
508876	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
508877	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Current Tap Position	8L	
508878	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Max Tap Position	2L	
508879	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Min Tap Position	12L	
508880	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Operations Since Last Insp	523	
508881	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
508882	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
508883	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
508884	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
508885	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
508886	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
508887	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
508888	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
508889	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.95	%
508890	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
508891	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
508892	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
508893	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
508894	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
508895	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	2	
508896	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
508897	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Patrol Inspection	Follow-up Action Required?	y	
508898	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Patrol Inspection	General Comments	owhy is there a pre charge check on a air breaker	
508899	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Patrol Inspection	Pre-Charge Pressure Correct?	y	
508900	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
508901	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Patrol Inspection	General Comments	ok	
508902	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
508903	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
508904	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
508905	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
508906	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
508907	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
508908	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
508909	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
508910	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
508911	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	40	°C
508912	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	40	°C
508913	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
508914	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Operations Since Last Insp	479	
508915	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Min Tap Position	8L	
508916	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	35	°C
508917	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	45	°C
508918	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	30	°C
508919	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	45	°C
508920	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	VRR Time Delay	30	Seconds
508921	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
508922	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
508923	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
508924	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
508925	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
508926	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
508927	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Max Tap Position	3L	
508928	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Current Tap Position	3L	
508929	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
508930	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
508931	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
508932	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
508933	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
508934	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
508935	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
508936	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
508937	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
508938	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
508939	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC As Left Counter	219857	
508940	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	LTC Operation Checked?	y	
508941	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	General Comments		
508942	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	Follow-up Action Required?	n	
508943	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	All Connections OK?	y	
508944	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
508945	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
508946	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
508947	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
508948	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
508949	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
508950	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
508951	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
508952	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Patrol Inspection	General Comments	ok	
508953	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
508954	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Patrol Inspection	General Comments	ok	
508955	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Patrol Inspection	Follow-up Action Required?	n	
508956	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
508957	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
508958	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
508959	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
508960	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
508961	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
508962	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
508963	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
508964	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
508965	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
508966	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
508967	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
508968	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
508969	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
508970	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
508971	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
508972	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
508973	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
508974	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
508975	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
508976	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
508977	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
508978	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
508979	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
508980	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
508981	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	n	
508982	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
508983	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
508984	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	y	
508985	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
508986	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
508987	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
508988	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Patrol Inspection	General Comments	ok	
508989	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Patrol Inspection	Follow-up Action Required?	n	
508990	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
508991	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
508992	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
508993	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
508994	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
508995	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	11.99	
508996	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
508997	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
508998	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
508999	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
509000	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
509001	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	General Comments	ok	
509002	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	General Comments	ok	
509003	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCC000540	LTCControl	CL-TRANS 5	LTC Control Insp	Follow-up Action Required?	n	
509004	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCC000540	LTCControl	CL-TRANS 5	LTC Control Insp	General Comments	ok	
509005	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCC000541	LTCControl	CL-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
509006	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCC000541	LTCControl	CL-TRANS 2	LTC Control Insp	General Comments	ok	
509007	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCC000541	LTCControl	CL-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
509008	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
509009	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
509010	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	Oil Temp Max	45	°C
509011	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	Oil Temp Present	30	°C
509012	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
509013	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
509014	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
509015	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
509016	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	General Comments	ok	
509017	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
509018	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
509019	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	239	
509020	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
509021	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	General Comments		
509022	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
509023	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
509024	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
509025	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
509026	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
509027	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
509028	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
509029	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
509030	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
509031	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
509032	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
509033	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
509034	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
509035	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
509036	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
509037	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
509038	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	VRR Time Delay	30	Seconds
509039	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
509040	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
509041	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Vegetation	None	
509042	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
509043	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
509044	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
509045	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
509046	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
509047	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
509048	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	General Comments		
509049	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	162	
509050	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	166	
509051	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
509052	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
509053	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
509054	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
509055	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
509056	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
509057	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
509058	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
509059	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	General Comments		
509060	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Reading	1.2420	
509061	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
509062	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
509063	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	Follow-up Action Required?	n	
509064	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
509065	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
509066	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
509067	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
509068	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
509069	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
509070	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
509071	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
509072	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	All Connections OK?	y	
509073	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	Follow-up Action Required?	n	
509074	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	General Comments		
509075	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
509076	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
509077	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Clear of Trash?	y	
509078	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
509079	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
509080	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
509081	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
509082	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	203	
509083	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	207	
509084	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
509085	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
509086	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
509087	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
509088	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	General Comments	ONLY HAS 5 FENCE GROUNDS ON IT. BARB WIRE ON RIGHT SIDE OF GATE IS NOT GROUNDED AT ALL.	
509089	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
509090	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
509091	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
509092	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	General Comments		
509093	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
509094	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
509095	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	All Connections OK?	y	
509096	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	Follow-up Action Required?	n	
509097	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	General Comments		
509098	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
509099	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	LTC Operation Checked?	y	
509100	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
509101	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
509102	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
509103	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC As Found Counter	219857	
509104	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	General Comments		
509105	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	General Comments		
509106	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
509107	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	Follow-up Action Required?	n	
509108	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
509109	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
509110	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
509111	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
509112	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
509113	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
509114	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
509115	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
509116	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
509117	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
509118	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
509119	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
509120	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
509121	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
509122	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
509123	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
509124	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
509125	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	110.0	
509126	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	50.0	
509127	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	90.0	
509128	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
509129	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
509130	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
509131	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
509132	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
509133	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
509134	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
509135	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
509136	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
509137	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
509138	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
509139	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	235	
509140	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
509141	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
509142	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
509143	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
509144	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
509145	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
509146	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
509147	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Paint Condition	Good	
509148	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
509149	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
509150	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
509151	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
509152	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
509153	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Equipment Properly Labeled?	y	
509154	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
509155	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
509156	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
509157	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
509158	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	General Comments	ok	
509159	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	ok	
509160	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC As Found Counter	25618	
509161	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
509162	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
509163	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
509164	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
509165	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations A Ø	0	
509166	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations B Ø	0	
509167	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations C Ø	0	
509168	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations Ground	0	
509169	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Follow-up Action Required?	n	
509170	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Follow-up Action Required?	n	
509171	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	313	
509172	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	317	
509173	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
509174	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
509175	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
509176	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
509177	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC As Left Counter	25618	
509178	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
509179	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	2R	
509180	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2R	
509181	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
509182	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Patrol Inspection	Follow-up Action Required?	n	
509183	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Patrol Inspection	General Comments	ok	
509184	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations Ground	0	
509185	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	9 Month Operations	11	
509186	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Follow-up Action Required?	n	
509187	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Accumulated Fault Duty A Ph V	5.94	%
509188	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Accumulated Fault Duty B Ph V	3.20	%
509189	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Accumulated Fault Duty C Ph V	5.48	%
509190	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Amps A Ø	175.0	
509191	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Amps B Ø	200.0	
509192	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Follow-up Action Required?	n	
509193	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Foundation Condition	Good	
509194	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	General Comments		
509195	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	General Comments		
509196	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	2R	
509197	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	38	
509198	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
509199	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Foundation Condition	Good	
509200	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	General Comments		
509201	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	General Comments		
509202	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Grounds in Place?	y	
509203	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Heaters (All) Functioning?	y	
509204	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Maintenance Operations	0	
509205	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Moisture and Leak Free?	y	
509206	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Operations Counter AF	190	
509207	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
509208	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
509209	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Foundation Condition	Good	
509210	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	General Comments		
509211	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	General Comments		
509212	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Grounds in Place?	y	
509213	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Maintenance Operations	0	
509214	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
509215	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	General Comments		
509216	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Moisture and Leak Free?	y	
509217	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Operations Counter AF	221	
509218	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Operations Counter AL	223	
509219	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
509220	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
509221	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
509222	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
509223	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
509224	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
509225	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
509226	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
509227	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	Oil Temp Max	57	°C
509228	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
509229	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
509230	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
509231	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
509232	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
509233	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
509234	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
509235	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations C Ø	0	
509236	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Switching Operations	2	
509237	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Tank Paint Condition	Good	
509238	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Unknown Operations	0	
509239	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
509240	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
509241	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
509242	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
509243	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
509244	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
509245	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
509246	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
509247	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
509248	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
509249	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
509250	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Linkage Grounds in Place?	y	
509251	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
509252	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Operating Linkage OK?	y	
509253	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
509254	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
509255	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
509256	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	9 Month Operations	11	
509257	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
509258	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Site Service Trans Condition	OK	
509259	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
509260	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Steel Structures Rust Free?	y	
509261	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
509262	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
509263	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Amps A Ø	115.0	
509264	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Amps B Ø	100.0	
509265	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
509266	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Amps C Ø	75.0	
509267	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Bushing Condition	Good	
509268	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Bushings Connection/Risers	Good	
509269	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
509270	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
509271	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
509272	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	General Comments		
509273	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
509274	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
509275	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Foundation Condition	Good	
509276	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
509277	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
509278	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
509279	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Heaters (All) Functioning?	y	
509280	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Maintenance Operations	0	
509281	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Moisture and Leak Free?	y	
509282	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Operations Counter AF	312	
509283	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Operations Counter AL	316	
509284	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
509285	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Switching Operations	4	
509286	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	Oil Temp Present	40	°C
509287	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
509288	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
509289	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
509290	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
509291	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
509292	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Winding Temp Present	40	°C
509293	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Winding Temp Max	80	°C
509294	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Totalizer Meter Reading	.7398	
509295	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
509296	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
509297	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
509298	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
509299	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
509300	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
509301	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
509302	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
509303	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
509304	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
509305	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Clear of Trash?	y	
509306	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
509307	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
509308	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
509309	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
509310	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
509311	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Tank Paint Condition	Good	
509312	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Unknown Operations	0	
509313	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	General Comments		
509314	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
509315	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
509316	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
509317	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
509318	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
509319	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
509320	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
509321	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
509322	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
509323	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	General Comments		
509324	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
509325	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
509326	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Vegetation	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
509327	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
509328	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
509329	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
509330	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
509331	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Totalizer Meter Reading	1.1772	
509332	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
509333	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Operations Counter AL	192	
509334	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Switching Operations	2	
509335	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Tank Paint Condition	Good	
509336	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Unknown Operations	0	
509337	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
509338	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
509339	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
509340	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
509341	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
509342	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
509343	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCC000489	LTCControl	CL-TRANS 1	LTC Control Insp	General Comments	ok	
509344	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCC000489	LTCControl	CL-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
509345	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
509346	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
509347	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
509348	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
509349	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
509350	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
509351	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Grounds in Place?	y	
509352	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
509353	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
509354	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
509355	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
509356	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
509357	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
509358	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
509359	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
509360	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	y	
509361	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
509362	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
509363	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
509364	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
509365	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
509366	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	General Comments	parts from old fpe in switch gear need someone with a crate or 55 gallon drum to come and pick up with state body	
509367	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
509368	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
509369	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
509370	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
509371	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	General Comments		
509372	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
509373	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
509374	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
509375	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
509376	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
509377	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
509378	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Foundation Condition	Good	
509379	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
509380	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Amps C Ø	170.0	
509381	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Bushing Condition	Good	
509382	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Bushings Connection/Risers	Good	
509383	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
509384	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
509385	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
509386	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
509387	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
509388	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
509389	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
509390	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
509391	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
509392	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
509393	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
509394	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
509395	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
509396	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	.65	%
509397	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
509398	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
509399	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.65	%
509400	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	9	
509401	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
509402	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
509403	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
509404	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
509405	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
509406	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
509407	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
509408	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
509409	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
509410	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
509411	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
509412	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
509413	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	9 Month Operations	12	
509414	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Accumulated Fault Duty A Ph V	.88	%
509415	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	BCH000617	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
509416	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Operations Since Last Insp	737	
509417	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
509418	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
509419	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
509420	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
509421	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	BCH000617	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
509422	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	BCH000617	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
509423	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	BCH000617	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.3	VDC
509424	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	BCH000617	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.3	VDC
509425	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	General Comments		
509426	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
509427	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	BCH000617	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
509428	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
509429	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Vegetation	None	
509430	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
509431	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
509432	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	General Comments		
509433	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
509434	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
509435	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
509436	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
509437	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
509438	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
509439	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Accumulated Fault Duty B Ph V	.66	%
509440	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
509441	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Accumulated Fault Duty C Ph V	1.31	%
509442	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Amps A Ø	60.0	
509443	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	4295	
509444	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
509445	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	General Comments		
509446	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
509447	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
509448	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
509449	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
509450	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
509451	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Clear of Trash?	y	
509452	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
509453	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
509454	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
509455	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Amps B Ø	80.0	
509456	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Amps C Ø	100.0	
509457	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Bushing Condition	Good	
509458	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	11.99	
509459	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
509460	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
509461	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
509462	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
509463	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
509464	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
509465	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	General Comments	ok	
509466	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
509467	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
509468	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
509469	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
509470	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
509471	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
509472	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
509473	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
509474	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	160.0	
509475	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
509476	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
509477	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
509478	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	160.0	
509479	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
509480	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
509481	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	160.0	
509482	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
509483	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
509484	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	Follow-up Action Required?	n	
509485	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
509486	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	General Comments		
509487	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	General Comments		
509488	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC As Found Counter	5695	
509489	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC As Left Counter	5695	
509490	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
509491	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Current Tap Position	6L	
509492	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Max Tap Position	1L	
509493	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Min Tap Position	11L	
509494	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
509495	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
509496	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
509497	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	180	
509498	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	10L	
509499	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
509500	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
509501	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	2R	
509502	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
509503	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
509504	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Vegetation	None	
509505	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
509506	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
509507	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
509508	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Amps A Ø	120.0	
509509	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Amps B Ø	120.0	
509510	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	200.0	
509511	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	240.0	
509512	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Amps C Ø	120.0	
509513	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	General Comments		
509514	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	6L	
509515	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
509516	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	4299	
509517	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
509518	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.23	%
509519	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
509520	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	240.0	
509521	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
509522	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
509523	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank 1 Oil Level	Good	
509524	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank 2 Oil level	Good	
509525	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank 3 Oil Level	Good	
509526	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank Leaks	None	
509527	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank Oil Level	Good	
509528	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank Paint Condition	Good	
509529	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
509530	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
509531	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations A Ø	0	
509532	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
509533	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
509534	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
509535	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
509536	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
509537	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
509538	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
509539	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
509540	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
509541	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
509542	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
509543	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
509544	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
509545	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
509546	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
509547	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
509548	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	General Comments		
509549	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations A Ø	0	
509550	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations B Ø	0	
509551	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
509552	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
509553	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
509554	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations Ground	0	
509555	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Follow-up Action Required?	n	
509556	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Follow-up Action Required?	n	
509557	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
509558	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Foundation Condition	Good	
509559	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
509560	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
509561	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
509562	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
509563	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
509564	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
509565	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
509566	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
509567	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
509568	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	15	
509569	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.47	%
509570	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
509571	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.94	%
509572	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
509573	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	General Comments	ok	
509574	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	General Comments	ok	
509575	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	80.0	
509576	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	80.0	
509577	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	PF000085	PowerFuse	CL-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
509578	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	PF000085	PowerFuse	CL-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
509579	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	80.0	
509580	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
509581	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations B Ø	0	
509582	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
509583	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
509584	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Foundation Condition	Good	
509585	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
509586	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
509587	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	2	
509588	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Clear of Trash?	y	
509589	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
509590	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
509591	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Ambient Temp	54	°F
509592	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Bushings Connection/Risers	Good	
509593	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
509594	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
509595	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
509596	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Patrol Inspection	Follow-up Action Required?	n	
509597	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Patrol Inspection	General Comments	ok	
509598	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
509599	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
509600	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
509601	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
509602	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
509603	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
509604	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Bushing Condition	Good	
509605	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
509606	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
509607	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Bushings Connection/Risers	Good	
509608	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
509609	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
509610	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
509611	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Bushing Condition	Good	
509612	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Paint Condition	Good	
509613	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Equipment Properly Labeled?	y	
509614	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
509615	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
509616	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
509617	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
509618	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
509619	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
509620	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
509621	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	General Comments		
509622	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
509623	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
509624	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
509625	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
509626	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
509627	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
509628	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
509629	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
509630	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
509631	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
509632	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
509633	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Paint Condition	Good	
509634	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Equipment Properly Labeled?	y	
509635	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
509636	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
509637	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Bushings Connection/Risers	Good	
509638	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
509639	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
509640	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
509641	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Paint Condition	Good	
509642	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
509643	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Follow-up Action Required?	n	
509644	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Foundation Condition	Good	
509645	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	General Comments	ok	
509646	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Grounds in Place?	y	
509647	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Moisture and Leak Free?	y	
509648	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	General Comments		
509649	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	General Comments		
509650	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Grounds in Place?	y	
509651	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Heaters (All) Functioning?	y	
509652	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
509653	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
509654	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
509655	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
509656	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
509657	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
509658	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
509659	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
509660	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
509661	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
509662	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
509663	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
509664	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
509665	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
509666	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
509667	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
509668	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
509669	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	5326	
509670	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	5322	
509671	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
509672	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
509673	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Follow-up Action Required?	n	
509674	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
509675	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
509676	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
509677	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Readings	General Comments		
509678	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
509679	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
509680	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
509681	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
509682	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
509683	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
509684	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
509685	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Maintenance Operations	0	
509686	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Moisture and Leak Free?	y	
509687	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCC000658	LTCControl	CL-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
509688	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCC000658	LTCControl	CL-TRANS 3	LTC Control Insp	General Comments	ok	
509689	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCC000658	LTCControl	CL-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
509690	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Operations Counter AF	345	
509691	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Operations Counter AL	352	
509692	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
509693	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
509694	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	General Comments		
509695	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Switching Operations	7	
509696	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	General Comments		
509697	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
509698	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	LTC Totalizer Reading	13305.60	kw
509699	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
509700	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
509701	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Oil Temp Max	40	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
509702	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Oil Temp Present	30	°C
509703	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
509704	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
509705	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
509706	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
509707	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
509708	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
509709	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
509710	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
509711	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
509712	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
509713	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Totalizer Meter Reading	.9240	
509714	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Winding Temp Max	45	°C
509715	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Winding Temp Present	35	°C
509716	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Tank Paint Condition	Good	
509717	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Unknown Operations	0	
509718	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
509719	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
509720	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
509721	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
509722	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
509723	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	100.0	
509724	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
509725	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
509726	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
509727	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Accumulated Fault Duty A Ph V	.46	%
509728	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Accumulated Fault Duty B Ph V	.46	%
509729	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Patrol Inspection	Equipment Properly Labeled?	y	
509730	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Patrol Inspection	Follow-up Action Required?	n	
509731	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Patrol Inspection	General Comments	ok	
509732	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
509733	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Follow-up Action Required?	n	
509734	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
509735	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
509736	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
509737	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
509738	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
509739	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
509740	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
509741	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
509742	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
509743	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
509744	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
509745	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
509746	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Amps A Ø	60.0	
509747	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	45	°C
509748	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
509749	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
509750	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
509751	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
509752	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
509753	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
509754	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
509755	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
509756	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
509757	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
509758	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
509759	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
509760	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
509761	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
509762	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
509763	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
509764	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
509765	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
509766	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
509767	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
509768	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
509769	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
509770	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	235	
509771	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	0	
509772	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	30	
509773	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
509774	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
509775	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Amps B Ø	60.0	
509776	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Amps C Ø	60.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
509777	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Bushing Condition	Good	
509778	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
509779	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Bushings Connection/Risers	Good	
509780	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
509781	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
509782	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Equipment Properly Labeled?	y	
509783	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
509784	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
509785	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	47	°F
509786	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
509787	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
509788	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
509789	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
509790	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
509791	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
509792	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Cabinet Paint Condition	Good	
509793	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations A Ø	0	
509794	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations B Ø	0	
509795	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations C Ø	0	
509796	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations Ground	0	
509797	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Follow-up Action Required?	n	
509798	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BCH000481	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
509799	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BCH000481	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
509800	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BCH000481	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
509801	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BCH000481	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
509802	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BCH000481	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
509803	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BCH000481	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
509804	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Follow-up Action Required?	n	
509805	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Foundation Condition	Good	
509806	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
509807	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
509808	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
509809	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
509810	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
509811	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	General Comments	ok	
509812	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	General Comments	nitro bottle empty	
509813	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
509814	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
509815	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
509816	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
509817	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
509818	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
509819	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
509820	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
509821	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
509822	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
509823	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
509824	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
509825	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
509826	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
509827	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
509828	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
509829	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
509830	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
509831	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
509832	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
509833	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
509834	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	160	
509835	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	155	
509836	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
509837	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
509838	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
509839	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
509840	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
509841	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
509842	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
509843	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
509844	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
509845	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
509846	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
509847	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
509848	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
509849	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
509850	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
509851	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
509852	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
509853	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
509854	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
509855	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
509856	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	General Comments		
509857	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
509858	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
509859	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
509860	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
509861	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
509862	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
509863	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
509864	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
509865	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	PF000086	PowerFuse	CL-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
509866	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	PF000086	PowerFuse	CL-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
509867	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
509868	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
509869	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
509870	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
509871	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
509872	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
509873	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
509874	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
509875	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
509876	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
509877	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
509878	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
509879	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
509880	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
509881	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
509882	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
509883	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
509884	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
509885	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
509886	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
509887	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
509888	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Patrol Inspection	Equipment Properly Labeled?	y	
509889	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Patrol Inspection	Follow-up Action Required?	n	
509890	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Patrol Inspection	General Comments	ok	
509891	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
509892	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
509893	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
509894	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	100.0	
509895	3/22/2019 11:42	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	100.0	
509896	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
509897	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Foundation Condition	Good	
509898	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
509899	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
509900	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
509901	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	General Comments	ok	
509902	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	General Comments	ok	
509903	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC As Found Counter	202232	
509904	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC As Left Counter	202232	
509905	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
509906	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Current Tap Position	13L	
509907	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
509908	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
509909	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
509910	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
509911	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
509912	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	1050	
509913	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	21	°C
509914	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
509915	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
509916	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Min Tap Position	5L	
509917	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Max Tap Position	12R	
509918	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Current Tap Position	3R	
509919	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
509920	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC As Left Counter	26598	
509921	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC As Found Counter	26598	
509922	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	General Comments	ok	
509923	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	General Comments	ok	
509924	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Max Tap Position	11L	
509925	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Min Tap Position	15L	
509926	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	480	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
509927	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
509928	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
509929	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
509930	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	45	°C
509931	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	60	°C
509932	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
509933	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	50	°C
509934	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
509935	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
509936	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
509937	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
509938	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
509939	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
509940	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
509941	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	40	°C
509942	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
509943	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
509944	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
509945	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
509946	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
509947	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
509948	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
509949	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	General Comments		
509950	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
509951	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
509952	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
509953	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
509954	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
509955	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
509956	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
509957	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
509958	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
509959	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
509960	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
509961	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
509962	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
509963	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
509964	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	Oil Temp Present	45	°C
509965	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
509966	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
509967	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Oil Temp Max	50	°C
509968	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
509969	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
509970	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
509971	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
509972	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
509973	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	LTC Totalizer Reading	8475.84	kw
509974	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
509975	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	General Comments		
509976	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	General Comments		
509977	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
509978	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	ok	
509979	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
509980	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
509981	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
509982	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	33	
509983	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.65	%
509984	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.31	%
509985	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.65	%
509986	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	240.0	
509987	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	240.0	
509988	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	240.0	
509989	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
509990	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
509991	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
509992	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
509993	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
509994	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
509995	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
509996	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
509997	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
509998	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
509999	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Follow-up Action Required?	n	
510000	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
510001	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Fans Operational?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
510002	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	242	
510003	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
510004	3/25/2019 6:43	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
510005	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
510006	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
510007	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
510008	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
510009	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
510010	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	54.0	VDC
510011	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
510012	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
510013	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
510014	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
510015	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
510016	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
510017	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
510018	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
510019	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
510020	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
510021	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
510022	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
510023	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
510024	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
510025	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
510026	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Paint Condition	Good	
510027	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
510028	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
510029	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
510030	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
510031	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Oil Temp Present	35	°C
510032	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Oil Temp Max	60	°C
510033	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
510034	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
510035	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	LTC Totalizer Reading	10653.12	kw
510036	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	5	
510037	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
510038	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	General Comments		
510039	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	General Comments		
510040	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	PF000082	PowerFuse	CL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
510041	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	PF000082	PowerFuse	CL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
510042	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
510043	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	General Comments		
510044	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
510045	3/22/2019 15:47	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
510046	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
510047	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
510048	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
510049	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
510050	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
510051	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
510052	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	PF000083	PowerFuse	CL-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
510053	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	PF000083	PowerFuse	CL-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
510054	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	PF000081	PowerFuse	CL-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
510055	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	General Comments	ok	
510056	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
510057	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	65	°C
510058	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
510059	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
510060	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
510061	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
510062	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
510063	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
510064	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
510065	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
510066	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
510067	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
510068	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
510069	3/22/2019 13:49	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	9 Month Operations	8	
510070	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
510071	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Patrol Inspection	Follow-up Action Required?	n	
510072	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Patrol Inspection	General Comments	ok	
510073	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	45	°C
510074	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	PF000084	PowerFuse	CL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
510075	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	PF000084	PowerFuse	CL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
510076	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	64	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
510077	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	45	°C
510078	3/22/2019 10:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	242	
510079	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	64	°C
510080	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
510081	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
510082	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
510083	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	PF000081	PowerFuse	CL-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
510084	3/22/2019 21:02	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
510085	3/22/2019 9:55	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
510086	3/22/2019 10:55	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
510087	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	BCH000503	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
510088	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	BCH000503	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
510089	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	BCH000503	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
510090	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	BCH000503	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
510091	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	BCH000503	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
510092	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	BCH000503	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
510093	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
510094	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
510095	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
510096	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
510097	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
510098	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
510099	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
510100	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations C Ø	0	
510101	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations Ground	0	
510102	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Follow-up Action Required?	n	
510103	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Follow-up Action Required?	n	
510104	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
510105	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
510106	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Foundation Condition	Good	
510107	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
510108	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
510109	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
510110	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	General Comments		
510111	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
510112	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	General Comments		
510113	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	303	
510114	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
510115	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Grounds in Place?	y	
510116	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Heaters (All) Functioning?	y	
510117	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
510118	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Maintenance Operations	0	
510119	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Moisture and Leak Free?	y	
510120	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Operations Counter AF	273	
510121	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Operations Counter AL	277	
510122	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
510123	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
510124	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
510125	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
510126	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Switching Operations	4	
510127	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Tank Paint Condition	Good	
510128	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Unknown Operations	0	
510129	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
510130	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	160.0	
510131	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	160.0	
510132	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	160.0	
510133	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
510134	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	165	
510135	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
510136	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
510137	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
510138	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
510139	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
510140	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
510141	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
510142	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
510143	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
510144	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
510145	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
510146	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
510147	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
510148	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
510149	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
510150	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
510151	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
510152	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
510153	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
510154	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
510155	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
510156	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
510157	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
510158	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
510159	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
510160	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
510161	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
510162	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
510163	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	General Comments		
510164	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	Oil Temp Present	22	°C
510165	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
510166	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
510167	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
510168	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
510169	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
510170	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
510171	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
510172	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
510173	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
510174	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
510175	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
510176	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
510177	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
510178	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
510179	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
510180	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
510181	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
510182	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
510183	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
510184	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
510185	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
510186	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
510187	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
510188	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
510189	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	134	
510190	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	139	
510191	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Vegetation	None	
510192	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
510193	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
510194	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
510195	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
510196	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
510197	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
510198	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
510199	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
510200	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	General Comments		
510201	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
510202	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	General Comments		
510203	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
510204	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
510205	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
510206	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
510207	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations B Ø	0	
510208	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations A Ø	0	
510209	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
510210	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
510211	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
510212	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.77	%
510213	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
510214	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	13	
510215	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
510216	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Present	10	°C
510217	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
510218	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
510219	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
510220	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
510221	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
510222	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
510223	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
510224	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Max	25	°C
510225	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
510226	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
510227	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
510228	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
510229	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
510230	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
510231	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
510232	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Clear of Trash?	y	
510233	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
510234	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	Follow-up Action Required?	n	
510235	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
510236	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
510237	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	General Comments		
510238	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	General Comments		
510239	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
510240	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
510241	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
510242	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
510243	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
510244	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
510245	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
510246	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	221.67	
510247	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
510248	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
510249	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	289	
510250	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
510251	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	Oil Temp Max	36	°C
510252	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
510253	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
510254	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
510255	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
510256	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
510257	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
510258	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Evidence of Insects	None	
510259	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
510260	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
510261	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
510262	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
510263	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
510264	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
510265	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
510266	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
510267	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
510268	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
510269	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
510270	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
510271	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
510272	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
510273	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
510274	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
510275	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
510276	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
510277	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
510278	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
510279	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
510280	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
510281	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
510282	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
510283	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	General Comments		
510284	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
510285	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
510286	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
510287	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
510288	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
510289	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
510290	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
510291	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
510292	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
510293	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
510294	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
510295	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
510296	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
510297	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
510298	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Totalizer Meter Reading	1.0152	
510299	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
510300	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
510301	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
510302	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
510303	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
510304	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
510305	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
510306	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
510307	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
510308	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
510309	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
510310	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
510311	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.38	%
510312	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.38	%
510313	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.38	%
510314	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
510315	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
510316	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
510317	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
510318	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0326	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
510319	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
510320	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
510321	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
510322	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
510323	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
510324	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
510325	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
510326	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
510327	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Panels Dusted?	y	
510328	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
510329	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
510330	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	General Comments		
510331	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
510332	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
510333	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
510334	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	161	
510335	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
510336	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
510337	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Floor Swept?	y	
510338	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
510339	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
510340	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
510341	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
510342	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
510343	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
510344	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
510345	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
510346	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
510347	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
510348	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
510349	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
510350	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
510351	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
510352	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Oil Temp Present	40	°C
510353	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Oil Temp Max	45	°C
510354	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
510355	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	General Comments		
510356	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
510357	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
510358	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
510359	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
510360	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
510361	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
510362	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
510363	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
510364	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0321	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
510365	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
510366	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
510367	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Foundation Condition	Good	
510368	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
510369	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
510370	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
510371	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
510372	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
510373	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
510374	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
510375	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
510376	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	LTC Totalizer Reading	9745.92	kw

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
510377	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
510378	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	General Comments		
510379	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
510380	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
510381	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
510382	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	General Comments		
510383	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
510384	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
510385	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
510386	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
510387	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
510388	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
510389	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
510390	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
510391	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
510392	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
510393	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
510394	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
510395	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
510396	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
510397	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Follow-up Action Required?	n	
510398	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
510399	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
510400	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
510401	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
510402	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
510403	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
510404	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
510405	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Operations Since Last Insp	2200	
510406	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Min Tap Position	16L	
510407	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Max Tap Position	2L	
510408	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Current Tap Position	8L	
510409	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
510410	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC As Left Counter	10	
510411	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC As Found Counter	68485	
510412	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	General Comments		
510413	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
510414	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
510415	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
510416	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
510417	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	General Comments		
510418	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
510419	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	Follow-up Action Required?	n	
510420	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
510421	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
510422	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
510423	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
510424	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
510425	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
510426	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
510427	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
510428	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
510429	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
510430	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
510431	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
510432	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Bushings Connection/Risers	Good	
510433	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Bushing Condition	Good	
510434	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Amps C Ø	40.0	
510435	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Amps B Ø	40.0	
510436	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Amps A Ø	40.0	
510437	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
510438	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Accumulated Fault Duty B Ph V	.40	%
510439	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
510440	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	9 Month Operations	8	
510441	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
510442	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
510443	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
510444	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	General Comments		
510445	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
510446	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
510447	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Operations Counter AL	291	
510448	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Operations Counter AF	287	
510449	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Moisture and Leak Free?	y	
510450	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
510451	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
510452	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
510453	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
510454	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
510455	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
510456	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
510457	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
510458	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
510459	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
510460	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
510461	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
510462	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
510463	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
510464	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
510465	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
510466	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
510467	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
510468	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
510469	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	General Comments		
510470	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
510471	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
510472	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Min Tap Position	14L	
510473	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
510474	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Heaters (All) Functioning?	y	
510475	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
510476	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
510477	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
510478	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Grounds in Place?	y	
510479	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3724.80	kw
510480	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Foundation Condition	Good	
510481	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	General Comments		
510482	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
510483	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
510484	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
510485	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
510486	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	General Comments	temp gauge is bad and needs replaced	
510487	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	General Comments		
510488	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
510489	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
510490	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
510491	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	Follow-up Action Required?	y	
510492	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
510493	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
510494	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
510495	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
510496	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
510497	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	General Comments		
510498	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
510499	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
510500	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
510501	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
510502	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
510503	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
510504	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
510505	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
510506	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
510507	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
510508	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Tank Leaks	None	
510509	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
510510	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
510511	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Regulator As Left Counter	37357	
510512	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
510513	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
510514	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
510515	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
510516	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
510517	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
510518	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
510519	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
510520	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
510521	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
510522	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
510523	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
510524	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
510525	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
510526	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Min Tap Position	11L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
510527	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Unknown Operations	0	
510528	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Tank Paint Condition	Good	
510529	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Switching Operations	4	
510530	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	General Comments		
510531	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
510532	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
510533	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	General Comments		
510534	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
510535	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
510536	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	Follow-up Action Required?	n	
510537	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
510538	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
510539	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
510540	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
510541	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	9 Month Operations	11	
510542	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
510543	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
510544	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
510545	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Accumulated Fault Duty C Ph V	1.19	%
510546	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Amps A Ø	60.0	
510547	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
510548	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Amps B Ø	60.0	
510549	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Amps C Ø	60.0	
510550	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
510551	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
510552	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	General Comments		
510553	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
510554	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
510555	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Foundation Condition	Good	
510556	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
510557	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
510558	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
510559	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
510560	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
510561	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
510562	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
510563	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Equipment Properly Labeled?	y	
510564	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Paint Condition	Good	
510565	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
510566	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
510567	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
510568	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
510569	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
510570	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
510571	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
510572	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
510573	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
510574	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
510575	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
510576	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Bushing Condition	Good	
510577	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Bushings Connection/Risers	Good	
510578	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
510579	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
510580	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
510581	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
510582	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
510583	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Regulator As Left Counter	32819	
510584	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
510585	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
510586	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
510587	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	General Comments		
510588	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Maintenance Operations	0	
510589	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Moisture and Leak Free?	y	
510590	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	General Comments		
510591	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	General Comments		
510592	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	General Comments		
510593	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Operations Counter AF	242	
510594	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Operations Counter AL	246	
510595	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
510596	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Switching Operations	4	
510597	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Tank Paint Condition	Good	
510598	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Unknown Operations	0	
510599	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
510600	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Tank Leaks	None	
510601	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
510602	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
510603	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
510604	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
510605	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
510606	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
510607	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
510608	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
510609	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
510610	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
510611	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
510612	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
510613	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
510614	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
510615	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
510616	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
510617	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
510618	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
510619	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
510620	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
510621	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
510622	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
510623	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
510624	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
510625	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
510626	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
510627	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
510628	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
510629	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
510630	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
510631	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
510632	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
510633	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
510634	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
510635	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
510636	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Foundation Condition	Good	
510637	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Follow-up Action Required?	n	
510638	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
510639	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
510640	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Follow-up Action Required?	n	
510641	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations Ground	0	
510642	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
510643	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
510644	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
510645	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
510646	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Regulator As Left Counter	34893	
510647	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
510648	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
510649	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Tank Leaks	None	
510650	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
510651	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	Oil Temp Present	24	°C
510652	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	Oil Temp Max	0	°C
510653	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
510654	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
510655	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BCH000982	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
510656	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations C Ø	0	
510657	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BCH000982	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
510658	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BCH000982	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
510659	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BCH000982	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
510660	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations B Ø	0	
510661	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
510662	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
510663	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
510664	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	80.00	
510665	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	75.00	
510666	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations A Ø	0	
510667	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
510668	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
510669	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
510670	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
510671	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
510672	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
510673	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
510674	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
510675	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
510676	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
510677	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
510678	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
510679	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
510680	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
510681	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Amps A Ø	120.0	
510682	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
510683	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
510684	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BCH000982	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
510685	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Heaters (All) Functioning?	y	
510686	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Grounds in Place?	y	
510687	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
510688	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
510689	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
510690	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BCH000982	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
510691	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	9 Month Operations	8	
510692	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BCH000982	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
510693	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	General Comments		
510694	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	General Comments		
510695	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
510696	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
510697	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
510698	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
510699	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
510700	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
510701	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
510702	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
510703	3/21/2019 15:36	Distribution	Mount Sterling Quarterly Inspection	BB0322	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
510704	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
510705	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
510706	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
510707	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
510708	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
510709	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
510710	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
510711	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
510712	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
510713	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
510714	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
510715	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
510716	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
510717	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
510718	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
510719	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
510720	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
510721	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
510722	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
510723	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
510724	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	General Comments		
510725	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
510726	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
510727	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	General Comments		
510728	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
510729	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
510730	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Max Tap Position	5L	
510731	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
510732	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Paint Condition	Good	
510733	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
510734	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Follow-up Action Required?	n	
510735	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
510736	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Ambient Temp	51	°F
510737	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
510738	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
510739	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
510740	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Clear of Trash?	y	
510741	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Winding Temp Max	30	°C
510742	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
510743	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
510744	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
510745	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Vegetation	None	
510746	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
510747	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
510748	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
510749	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	General Comments		
510750	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
510751	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
510752	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
510753	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
510754	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
510755	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
510756	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	Oil Temp Max	36	°C
510757	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	Oil Temp Present	26	°C
510758	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
510759	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	General Comments		
510760	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Equipment Properly Labeled?	y	
510761	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
510762	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3880	
510763	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
510764	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
510765	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
510766	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
510767	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
510768	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
510769	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
510770	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
510771	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
510772	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
510773	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations Ground	0	
510774	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations C Ø	0	
510775	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations B Ø	0	
510776	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations A Ø	0	
510777	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Amps B Ø	120.0	
510778	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Amps C Ø	120.0	
510779	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Bushing Condition	Good	
510780	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Bushings Connection/Risers	Good	
510781	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
510782	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
510783	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
510784	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
510785	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
510786	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
510787	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
510788	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
510789	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
510790	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Vegetation	None	
510791	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
510792	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Follow-up Action Required?	n	
510793	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
510794	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
510795	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
510796	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
510797	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Paint Condition	Good	
510798	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Equipment Properly Labeled?	y	
510799	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
510800	3/21/2019 15:50	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
510801	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
510802	3/21/2019 9:45	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
510803	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Amps B Ø	75.0	
510804	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
510805	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Amps C Ø	50.0	
510806	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
510807	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
510808	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
510809	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
510810	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
510811	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Totalizer Meter Reading	.6880	
510812	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
510813	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations Ground	0	
510814	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations C Ø	0	
510815	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations B Ø	0	
510816	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations A Ø	0	
510817	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	General Comments		
510818	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
510819	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Maintenance Operations	0	
510820	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
510821	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
510822	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
510823	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	General Comments		
510824	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
510825	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
510826	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
510827	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
510828	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
510829	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	General Comments		
510830	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Follow-up Action Required?	n	
510831	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
510832	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
510833	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
510834	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
510835	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Oil Temp Present	28	°C
510836	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Oil Temp Max	37	°C
510837	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
510838	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
510839	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	LTC Totalizer Reading	6604.80	kw
510840	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
510841	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	General Comments		
510842	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	General Comments		
510843	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
510844	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
510845	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Follow-up Action Required?	n	
510846	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
510847	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
510848	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
510849	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
510850	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
510851	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
510852	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
510853	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
510854	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
510855	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
510856	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	General Comments		
510857	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
510858	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
510859	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
510860	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
510861	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
510862	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
510863	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
510864	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
510865	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
510866	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
510867	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	Yes_sprayed	
510868	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
510869	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
510870	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
510871	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
510872	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
510873	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations Ground	0	
510874	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations C Ø	0	
510875	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations B Ø	0	
510876	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
510877	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
510878	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
510879	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	The SWGR is grounded from the Trans side, does not need another ground, Per Tom Goodner & Jim Johnson	
510880	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
510881	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
510882	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
510883	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
510884	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
510885	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
510886	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
510887	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
510888	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
510889	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
510890	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
510891	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations A Ø	0	
510892	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
510893	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
510894	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
510895	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
510896	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
510897	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
510898	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
510899	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
510900	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
510901	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
510902	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
510903	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
510904	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
510905	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
510906	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
510907	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
510908	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
510909	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
510910	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
510911	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	684	
510912	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	General Comments		
510913	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
510914	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
510915	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
510916	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Tank Leaks	None	
510917	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
510918	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
510919	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
510920	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	7.13	%
510921	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
510922	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	9 Months Operations	16	
510923	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
510924	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Follow-up Action Required?	n	
510925	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
510926	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
510927	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Amps A Ø	50.0	
510928	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
510929	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
510930	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	684	
510931	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Switching Operations	0	
510932	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Operations Counter AL	533	
510933	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Operations Counter AF	533	
510934	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations A Ø	0	
510935	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
510936	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
510937	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
510938	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Equipment Properly Labeled?	y	
510939	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Paint Condition	Good	
510940	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
510941	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
510942	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
510943	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
510944	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Bushings Connection/Risers	Good	
510945	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
510946	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Bushing Condition	Good	
510947	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
510948	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
510949	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
510950	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
510951	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
510952	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
510953	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
510954	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
510955	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
510956	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
510957	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
510958	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
510959	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
510960	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
510961	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
510962	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
510963	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
510964	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
510965	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
510966	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
510967	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
510968	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	140.0	
510969	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	190.0	
510970	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Ambient Temp	57	°F
510971	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
510972	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
510973	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Clear of Trash?	y	
510974	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
510975	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Amps C Ø	101.0	
510976	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Amps B Ø	87.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
510977	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Amps A Ø	75.0	
510978	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	9.51	%
510979	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
510980	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
510981	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
510982	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
510983	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
510984	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
510985	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
510986	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
510987	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
510988	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
510989	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
510990	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
510991	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
510992	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
510993	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
510994	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
510995	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	General Comments		
510996	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Accumulated Fault Duty C Ph V	.78	%
510997	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Accumulated Fault Duty B Ph V	.65	%
510998	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Accumulated Fault Duty A Ph V	.13	%
510999	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	9 Month Operations	2	
511000	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
511001	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
511002	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
511003	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
511004	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
511005	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
511006	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
511007	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
511008	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
511009	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
511010	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
511011	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
511012	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
511013	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
511014	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
511015	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
511016	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
511017	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
511018	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
511019	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Amps C Ø	200.0	
511020	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Amps B Ø	120.0	
511021	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
511022	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
511023	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
511024	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	Oil Temp Max	30	°C
511025	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
511026	3/20/2019 14:41	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
511027	3/20/2019 14:41	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
511028	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
511029	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
511030	3/20/2019 14:41	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
511031	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
511032	3/20/2019 14:41	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
511033	3/20/2019 14:41	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
511034	3/20/2019 14:41	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
511035	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	General Comments		
511036	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
511037	3/20/2019 14:41	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
511038	3/20/2019 14:41	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
511039	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
511040	3/20/2019 14:41	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
511041	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
511042	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
511043	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
511044	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
511045	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
511046	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
511047	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Unknown Operations	0	
511048	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Tank Paint Condition	Good	
511049	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Switching Operations	0	
511050	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Operations Counter AL	178	
511051	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Operations Counter AF	178	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
511052	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Moisture and Leak Free?	y	
511053	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Maintenance Operations	0	
511054	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Amps A Ø	210.0	
511055	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
511056	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
511057	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
511058	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	9 Months Operations	0	
511059	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Grounds in Place?	y	
511060	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	General Comments		
511061	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	General Comments		
511062	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Foundation Condition	Good	
511063	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Follow-up Action Required?	n	
511064	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Follow-up Action Required?	n	
511065	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations Ground	0	
511066	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations C Ø	0	
511067	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations B Ø	0	
511068	3/20/2019 14:41	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
511069	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
511070	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
511071	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
511072	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
511073	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	General Comments		
511074	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	30	°C
511075	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	25	°C
511076	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H3 Winding Temp Max	25	°C
511077	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H3 Winding Temp Present	30	°C
511078	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	LTCC000190	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
511079	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	LTCC000190	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
511080	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	LTCC000190	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
511081	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	LTCC000190	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
511082	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	LTCC000190	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
511083	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	LTCC000190	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
511084	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	LTCC000190	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
511085	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	General Comments		
511086	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Follow-up Action Required?	n	
511087	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	LTCC000139	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
511088	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	LTCC000139	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
511089	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	LTCC000139	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
511090	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	LTCC000139	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
511091	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	LTCC000139	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
511092	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	LTCC000190	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
511093	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
511094	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
511095	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
511096	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
511097	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
511098	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
511099	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
511100	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
511101	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
511102	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
511103	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
511104	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
511105	3/20/2019 14:41	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
511106	3/20/2019 14:41	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
511107	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
511108	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
511109	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
511110	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
511111	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations A Ø	0	
511112	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
511113	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
511114	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
511115	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
511116	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
511117	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Equipment Properly Labeled?	y	
511118	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Paint Condition	Good	
511119	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
511120	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
511121	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
511122	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
511123	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
511124	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Bushings Connection/Risers	Good	
511125	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Bushing Condition	Good	
511126	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Amps C Ø	22.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
511127	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
511128	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Amps B Ø	25.0	
511129	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Amps A Ø	24.0	
511130	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
511131	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
511132	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
511133	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
511134	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	9 Month Operations	1	
511135	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
511136	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
511137	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
511138	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Totalizer Meter Reading	.7398	
511139	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
511140	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
511141	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
511142	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
511143	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
511144	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
511145	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
511146	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	General Comments		
511147	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
511148	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
511149	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Vegetation	None	
511150	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
511151	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
511152	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
511153	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
511154	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Unknown Operations	0	
511155	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Switching Operations	0	
511156	3/20/2019 14:41	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
511157	3/20/2019 14:41	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	General Comments		
511158	3/20/2019 14:41	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
511159	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Operations Counter AL	418	
511160	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
511161	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
511162	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
511163	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Oil Temp Present	30	°C
511164	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Oil Temp Max	55	°C
511165	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
511166	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
511167	3/20/2019 14:41	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
511168	3/20/2019 14:41	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
511169	3/20/2019 14:41	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
511170	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	LTC Totalizer Reading	7102.08	kw
511171	3/20/2019 14:41	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
511172	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
511173	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	General Comments		
511174	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Operations Counter AF	418	
511175	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Unknown Operations	0	
511176	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	LTCC000139	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
511177	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	LTCC000139	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
511178	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	LTCC000139	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
511179	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Tank Paint Condition	Good	
511180	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Switching Operations	0	
511181	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Operations Counter AL	167	
511182	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
511183	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Operations Counter AF	167	
511184	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Moisture and Leak Free?	y	
511185	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Maintenance Operations	0	
511186	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Grounds in Place?	y	
511187	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	General Comments		
511188	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	General Comments		
511189	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Foundation Condition	Good	
511190	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Follow-up Action Required?	n	
511191	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Follow-up Action Required?	n	
511192	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H1 Winding Temp Max	30	°C
511193	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H1 Winding Temp Present	25	°C
511194	3/20/2019 14:41	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
511195	3/20/2019 14:41	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
511196	3/20/2019 14:41	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
511197	3/20/2019 14:41	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
511198	3/20/2019 14:41	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
511199	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations Ground	0	
511200	3/20/2019 14:41	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
511201	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
511202	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations B Ø	0	
511203	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	LTCC000139	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
511204	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Maintenance Operations	0	
511205	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
511206	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	General Comments		
511207	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
511208	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
511209	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
511210	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
511211	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
511212	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
511213	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
511214	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
511215	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
511216	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
511217	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
511218	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
511219	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC As Found Counter	11982	
511220	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC As Left Counter	11982	
511221	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
511222	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
511223	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
511224	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
511225	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	General Comments		
511226	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
511227	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
511228	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
511229	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
511230	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	514	
511231	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
511232	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
511233	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
511234	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
511235	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
511236	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
511237	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
511238	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Floor Swept?	y	
511239	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
511240	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
511241	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
511242	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
511243	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
511244	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Evidence of Insects	None	
511245	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
511246	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
511247	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
511248	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
511249	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
511250	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
511251	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
511252	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
511253	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
511254	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
511255	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
511256	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Broom on Site?	y	
511257	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
511258	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
511259	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
511260	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
511261	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
511262	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
511263	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
511264	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
511265	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
511266	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
511267	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
511268	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
511269	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
511270	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
511271	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
511272	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
511273	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
511274	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
511275	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
511276	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
511277	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
511278	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
511279	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
511280	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
511281	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
511282	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
511283	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	9 Months Operations	1	
511284	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.700	millivolts
511285	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
511286	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
511287	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
511288	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
511289	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
511290	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
511291	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
511292	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
511293	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
511294	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
511295	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
511296	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	9 Months Operations	0	
511297	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
511298	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Amps A Ø	0.0	
511299	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Amps B Ø	0.0	
511300	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
511301	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
511302	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
511303	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Trash Emptied?	n	
511304	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
511305	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
511306	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Panels Dusted?	y	
511307	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Amps C Ø	0.0	
511308	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	BCH000236	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
511309	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	BCH000236	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
511310	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	BCH000236	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
511311	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	BCH000236	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.9	VDC
511312	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	BCH000236	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.9	VDC
511313	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
511314	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
511315	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
511316	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
511317	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Operations A Ø	0	
511318	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
511319	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	General Comments		
511320	3/20/2019 14:41	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
511321	3/20/2019 14:41	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.5	VDC
511322	3/20/2019 14:41	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.5	VDC
511323	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
511324	3/20/2019 14:41	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
511325	3/20/2019 14:41	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
511326	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	General Comments	fence is rusty. large gap beneath fenced,but has barb wire spanning it. One fence post washed out andis loose	
511327	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
511328	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
511329	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
511330	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
511331	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
511332	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
511333	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
511334	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
511335	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
511336	3/20/2019 14:41	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
511337	3/20/2019 14:41	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	General Comments		
511338	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
511339	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
511340	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
511341	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
511342	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
511343	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
511344	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
511345	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Amps C Ø	25.0	
511346	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Amps B Ø	25.0	
511347	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Amps A Ø	25.0	
511348	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
511349	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
511350	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
511351	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	12.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
511352	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	12.0	
511353	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	9 Months Operations	8	
511354	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Operations B Ø	0	
511355	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Operations C Ø	0	
511356	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Operations Ground	0	
511357	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
511358	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Follow-up Action Required?	n	
511359	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	General Comments		
511360	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	General Comments		
511361	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
511362	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Maintenance Operations	0	
511363	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Operations Counter AF	99950	
511364	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Operations Counter AL	99950	
511365	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Switching Operations	0	
511366	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Unknown Operations	0	
511367	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.94	%
511368	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	.94	%
511369	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
511370	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
511371	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
511372	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
511373	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
511374	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
511375	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
511376	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
511377	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
511378	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
511379	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
511380	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
511381	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	510	
511382	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
511383	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.94	%
511384	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
511385	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
511386	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
511387	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
511388	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
511389	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
511390	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Totalizer Meter Reading	.8670	
511391	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
511392	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
511393	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
511394	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
511395	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
511396	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
511397	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
511398	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
511399	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
511400	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
511401	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
511402	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
511403	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Follow-up Action Required?	n	
511404	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
511405	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
511406	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	General Comments		
511407	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	General Comments		
511408	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
511409	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	LTC Totalizer Reading	8323.20	kw
511410	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
511411	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
511412	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Oil Temp Max	32	°C
511413	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Oil Temp Present	25	°C
511414	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
511415	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
511416	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Amps A Ø	45.0	
511417	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
511418	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Amps B Ø	40.0	
511419	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
511420	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Amps C Ø	83.0	
511421	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
511422	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
511423	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
511424	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
511425	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
511426	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
511427	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Unknown Operations	0	
511428	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
511429	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Switching Operations	0	
511430	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Operations Counter AL	1006	
511431	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
511432	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
511433	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
511434	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
511435	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
511436	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	General Comments		
511437	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
511438	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
511439	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Operations Counter	1	
511440	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
511441	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
511442	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
511443	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
511444	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Operations Counter AF	1006	
511445	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Maintenance Operations	0	
511446	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
511447	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	General Comments		
511448	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	General Comments		
511449	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Follow-up Action Required?	n	
511450	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	Follow-up Action Required?	n	
511451	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations Ground	0	
511452	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations C Ø	0	
511453	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations B Ø	0	
511454	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations A Ø	0	
511455	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
511456	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
511457	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
511458	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
511459	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
511460	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
511461	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
511462	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	General Comments		
511463	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
511464	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC As Found Counter	233639	
511465	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC As Left Counter	233639	
511466	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
511467	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
511468	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
511469	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
511470	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
511471	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
511472	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
511473	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
511474	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
511475	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
511476	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	3.76	%
511477	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
511478	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	General Comments		
511479	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
511480	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
511481	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
511482	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
511483	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
511484	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Accumulated Fault Duty A Ph AM	2.13	%
511485	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	9 Months Operations	10	
511486	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
511487	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
511488	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Unknown Operations	0	
511489	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Switching Operations	0	
511490	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	Follow-up Action Required?	n	
511491	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
511492	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	General Comments		
511493	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	General Comments		
511494	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Unknown Operations	0	
511495	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Switching Operations	0	
511496	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
511497	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Operations Counter AL	384	
511498	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Operations Counter AF	384	
511499	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Maintenance Operations	0	
511500	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
511501	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
511502	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	General Comments		
511503	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Follow-up Action Required?	n	
511504	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
511505	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations Ground	0	
511506	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations C Ø	0	
511507	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations B Ø	0	
511508	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
511509	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
511510	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	General Comments		
511511	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
511512	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations A Ø	0	
511513	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
511514	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
511515	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
511516	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
511517	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Amps C Ø	90.0	
511518	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Amps B Ø	100.0	
511519	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
511520	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
511521	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
511522	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
511523	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
511524	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
511525	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
511526	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
511527	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	9 Months Operations	0	
511528	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
511529	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
511530	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
511531	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Amps A Ø	75.0	
511532	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Amps B Ø	25.0	
511533	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Amps C Ø	50.0	
511534	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
511535	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
511536	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
511537	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
511538	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations A Ø	0	
511539	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations B Ø	0	
511540	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations C Ø	0	
511541	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations Ground	0	
511542	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
511543	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Follow-up Action Required?	n	
511544	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	General Comments		
511545	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	BCH001235	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
511546	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	BCH001235	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
511547	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	BCH001235	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
511548	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	General Comments		
511549	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
511550	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Maintenance Operations	0	
511551	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
511552	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Operations Counter AF	430	
511553	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
511554	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
511555	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	0.00	MegaVars
511556	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	-.20	MegaVars
511557	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	3.60	MegaWatts
511558	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	2.00	MegaWatts
511559	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
511560	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
511561	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
511562	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
511563	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
511564	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
511565	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
511566	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
511567	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
511568	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
511569	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
511570	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
511571	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
511572	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Swept?	y	
511573	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
511574	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
511575	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
511576	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
511577	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
511578	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
511579	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
511580	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
511581	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
511582	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
511583	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
511584	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
511585	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments		
511586	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
511587	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Unknown Operations	0	
511588	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
511589	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Trash Emptied?	n	
511590	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
511591	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
511592	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Unknown Operations	0	
511593	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Switching Operations	0	
511594	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Operations Counter AL	479	
511595	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Operations Counter AF	479	
511596	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Maintenance Operations	0	
511597	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
511598	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	General Comments		
511599	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Patrol Inspection	General Comments		
511600	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Follow-up Action Required?	n	
511601	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
511602	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations Ground	0	
511603	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations C Ø	0	
511604	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations B Ø	0	
511605	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations A Ø	0	
511606	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
511607	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
511608	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
511609	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
511610	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
511611	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
511612	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Operations Since Last Insp	766	
511613	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Min Tap Position	6L	
511614	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Max Tap Position	4R	
511615	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Current Tap Position	1R	
511616	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
511617	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC As Left Counter	91550	
511618	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
511619	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Amps C Ø	100.0	
511620	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Amps B Ø	160.0	
511621	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Amps A Ø	50.0	
511622	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
511623	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
511624	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
511625	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Unknown Operations	0	
511626	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	9 Months Operations	0	
511627	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
511628	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
511629	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
511630	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
511631	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
511632	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	BCH001235	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
511633	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	BCH001235	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
511634	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	BCH001235	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.4	VDC
511635	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	BCH001235	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.4	VDC
511636	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	BCH001235	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.600	millivolts
511637	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
511638	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
511639	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
511640	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
511641	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
511642	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
511643	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
511644	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
511645	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
511646	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
511647	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
511648	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
511649	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
511650	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
511651	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
511652	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
511653	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	General Comments		
511654	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
511655	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
511656	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Foundation Condition	Good	
511657	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
511658	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
511659	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
511660	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
511661	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
511662	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
511663	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
511664	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
511665	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
511666	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
511667	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.2	VDC
511668	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.2	VDC
511669	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.300	millivolts
511670	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
511671	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
511672	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
511673	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	Follow-up Action Required?	n	
511674	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
511675	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	General Comments		
511676	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	General Comments		
511677	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC As Found Counter	189552	
511678	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC As Left Counter	189565	
511679	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
511680	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Current Tap Position	8L	
511681	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Max Tap Position	1L	
511682	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Min Tap Position	14L	
511683	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Operations Since Last Insp	1456	
511684	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
511685	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
511686	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
511687	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
511688	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
511689	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC As Found Counter	91541	
511690	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	General Comments		
511691	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
511692	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
511693	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
511694	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
511695	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
511696	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
511697	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
511698	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
511699	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
511700	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Operations Counter AL	430	
511701	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
511702	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
511703	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
511704	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
511705	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
511706	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Oil Temp Max	30	°C
511707	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
511708	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
511709	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
511710	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	General Comments		
511711	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
511712	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
511713	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
511714	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
511715	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Operations Counter AL	308	
511716	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Operations Counter AF	308	
511717	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Maintenance Operations	0	
511718	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
511719	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	General Comments		
511720	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
511721	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
511722	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
511723	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
511724	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
511725	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
511726	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
511727	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
511728	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Amps A Ø	120.0	
511729	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	5.34	%
511730	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	4.27	%
511731	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	General Comments		
511732	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Follow-up Action Required?	n	
511733	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
511734	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations Ground	0	
511735	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations C Ø	0	
511736	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations B Ø	0	
511737	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations A Ø	0	
511738	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
511739	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
511740	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
511741	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
511742	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Amps C Ø	150.0	
511743	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Amps B Ø	100.0	
511744	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Amps A Ø	200.0	
511745	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
511746	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	7.47	%
511747	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
511748	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	Oil Temp Max	30	°C
511749	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
511750	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
511751	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
511752	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
511753	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
511754	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Switching Operations	0	
511755	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
511756	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
511757	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
511758	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
511759	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
511760	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
511761	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
511762	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
511763	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
511764	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
511765	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Amps A Ø	140.0	
511766	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Amps B Ø	130.0	
511767	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Amps C Ø	80.0	
511768	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations C Ø	0	
511769	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations Ground	0	
511770	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Follow-up Action Required?	n	
511771	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
511772	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
511773	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
511774	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
511775	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
511776	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
511777	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
511778	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
511779	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
511780	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
511781	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
511782	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Follow-up Action Required?	n	
511783	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
511784	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
511785	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
511786	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
511787	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
511788	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Foundation Condition	Good	
511789	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	General Comments		
511790	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
511791	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations A Ø	0	
511792	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Amps A Ø	50.0	
511793	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Amps B Ø	50.0	
511794	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations B Ø	0	
511795	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations C Ø	0	
511796	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Amps C Ø	50.0	
511797	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
511798	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
511799	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations Ground	0	
511800	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
511801	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
511802	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
511803	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
511804	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations A Ø	0	
511805	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations B Ø	0	
511806	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations C Ø	0	
511807	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations Ground	0	
511808	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
511809	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Follow-up Action Required?	n	
511810	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Follow-up Action Required?	n	
511811	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	General Comments		
511812	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	General Comments		
511813	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
511814	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	General Comments		
511815	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
511816	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Maintenance Operations	0	
511817	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Operations Counter AF	612	
511818	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations A Ø	0	
511819	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations B Ø	0	
511820	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations C Ø	0	
511821	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Operations Counter AL	612	
511822	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Switching Operations	0	
511823	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Unknown Operations	0	
511824	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
511825	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Adjusted Amps B Phase V	4.69	
511826	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
511827	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations A Ø	0	
511828	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations B Ø	1	
511829	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
511830	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
511831	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
511832	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
511833	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
511834	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
511835	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
511836	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
511837	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
511838	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
511839	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
511840	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
511841	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
511842	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
511843	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	9 Month Operations	3	
511844	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
511845	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Accumulated Fault Duty B Ph V	.35	%
511846	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	9 Month Operations	3	
511847	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
511848	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
511849	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
511850	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Amps A Ø	320.0	
511851	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Amps B Ø	320.0	
511852	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Amps C Ø	320.0	
511853	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Bushing Condition	Good	
511854	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Accumulated Fault Duty C Ph V	.35	%
511855	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Amps A Ø	25.0	
511856	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Amps B Ø	23.0	
511857	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Amps C Ø	28.0	
511858	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Bushing Condition	Good	
511859	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
511860	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
511861	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
511862	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
511863	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
511864	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
511865	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
511866	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
511867	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
511868	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
511869	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	Follow-up Action Required?	n	
511870	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
511871	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	General Comments		
511872	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations A Ø	0	
511873	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Bushings Connection/Risers	Good	
511874	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
511875	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
511876	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
511877	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Paint Condition	Good	
511878	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Accumulated Fault Duty C Ph V	6.58	%
511879	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	9 Months Operations	18	
511880	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Equipment Properly Labeled?	y	
511881	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations B Ø	0	
511882	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	.1	AMPS
511883	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	26.6	VDC
511884	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
511885	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
511886	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
511887	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
511888	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	General Comments		
511889	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
511890	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
511891	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	9 Months Operations	0	
511892	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
511893	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
511894	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Switching Operations	0	
511895	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Operations Counter AL	411	
511896	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	All Connections OK?	y	
511897	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Operations Counter AF	411	
511898	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	Follow-up Action Required?	n	
511899	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	General Comments		
511900	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	LTC Operation Checked?	y	
511901	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
511902	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
511903	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
511904	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	VRR Time Delay	30	Seconds
511905	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Maintenance Operations	0	
511906	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
511907	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
511908	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Bushings Connection/Risers	Good	
511909	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Bushing Condition	Good	
511910	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Amps C Ø	185.0	
511911	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Amps B Ø	210.0	
511912	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Amps A Ø	216.0	
511913	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Accumulated Fault Duty C Ph V	1.10	%
511914	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Accumulated Fault Duty B Ph V	2.95	%
511915	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Accumulated Fault Duty A Ph V	1.10	%
511916	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	9 Month Operations	5	
511917	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
511918	3/20/2019 14:41	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	General Comments		
511919	3/20/2019 14:41	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
511920	3/20/2019 14:41	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
511921	3/20/2019 14:41	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
511922	3/20/2019 14:41	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
511923	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	247	
511924	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
511925	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
511926	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	General Comments		
511927	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	Follow-up Action Required?	n	
511928	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
511929	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	General Comments		
511930	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	General Comments		
511931	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC As Found Counter	154081	
511932	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC As Left Counter	154096	
511933	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
511934	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Current Tap Position	6L	
511935	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Max Tap Position	1R	
511936	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Min Tap Position	11L	
511937	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Operations Since Last Insp	2121	
511938	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
511939	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
511940	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
511941	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
511942	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
511943	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
511944	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
511945	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
511946	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Unknown Operations	0	
511947	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
511948	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
511949	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
511950	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
511951	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
511952	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	45.0	
511953	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Unknown Operations	0	
511954	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	General Comments		
511955	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	General Comments		
511956	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Grounds in Place?	y	
511957	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Maintenance Operations	0	
511958	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	45.0	
511959	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
511960	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
511961	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
511962	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations C Ø	0	
511963	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
511964	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
511965	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations Ground	0	
511966	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Follow-up Action Required?	n	
511967	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
511968	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
511969	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Follow-up Action Required?	n	
511970	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Foundation Condition	Good	
511971	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	General Comments		
511972	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations Ground	0	
511973	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Follow-up Action Required?	n	
511974	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	General Comments		
511975	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Unknown Operations	0	
511976	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Follow-up Action Required?	n	
511977	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Totalizer Meter Reading	.7392	
511978	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Winding Temp Max	38	°C
511979	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Winding Temp Present	29	°C
511980	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
511981	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Foundation Condition	Good	
511982	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Tank Paint Condition	Good	
511983	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Switching Operations	0	
511984	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Operations Counter AL	239	
511985	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Operations Counter AF	239	
511986	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Moisture and Leak Free?	y	
511987	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Maintenance Operations	0	
511988	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Grounds in Place?	y	
511989	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	General Comments		
511990	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	General Comments		
511991	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Foundation Condition	Good	
511992	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Follow-up Action Required?	n	
511993	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Follow-up Action Required?	n	
511994	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations Ground	0	
511995	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations C Ø	0	
511996	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations B Ø	0	
511997	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Grounds in Place?	y	
511998	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Maintenance Operations	0	
511999	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Moisture and Leak Free?	y	
512000	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	General Comments		
512001	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
512002	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Maintenance Operations	0	
512003	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Operations Counter AF	175	
512004	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Operations Counter AL	175	
512005	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Switching Operations	0	
512006	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Tank Paint Condition	Good	
512007	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations A Ø	0	
512008	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
512009	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Operations Counter AF	456	
512010	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Operations Counter AL	456	
512011	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
512012	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Switching Operations	0	
512013	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Accumulated Fault Duty B Ph V	4.39	%
512014	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
512015	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
512016	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Equipment Properly Labeled?	y	
512017	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Paint Condition	Good	
512018	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Accumulated Fault Duty A Ph V	5.12	%
512019	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	LTC Totalizer Reading	10644.48	kw
512020	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
512021	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	9 Month Operations	7	
512022	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Unknown Operations	0	
512023	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
512024	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Unknown Operations	0	
512025	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
512026	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
512027	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Top Oil Temperature Present	32	°C
512028	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
512029	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Totalizer Meter Reading	.9906	
512030	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
512031	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
512032	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
512033	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
512034	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
512035	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
512036	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
512037	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
512038	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
512039	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations A Ø	0	
512040	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations B Ø	0	
512041	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations C Ø	0	
512042	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
512043	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Vegetation	None	
512044	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
512045	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
512046	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
512047	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
512048	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	General Comments		
512049	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Amps B Ø	130.0	
512050	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Amps A Ø	140.0	
512051	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
512052	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
512053	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
512054	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
512055	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
512056	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
512057	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
512058	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
512059	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
512060	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
512061	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	257	
512062	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations Ground	0	
512063	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	Follow-up Action Required?	n	
512064	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
512065	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	257	
512066	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
512067	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
512068	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
512069	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
512070	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
512071	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
512072	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
512073	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
512074	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
512075	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
512076	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
512077	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
512078	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Follow-up Action Required?	n	
512079	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	General Comments		
512080	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	General Comments		
512081	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
512082	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
512083	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
512084	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
512085	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
512086	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
512087	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
512088	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
512089	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
512090	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Adjusted Amps A Phase AM	9.55	
512091	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Adjusted Amps B Phase AM	9.55	
512092	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
512093	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Adjusted Amps C Phase AM	9.55	
512094	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Operations A Ø	1	
512095	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Operations B Ø	1	
512096	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	9 Months Operations	33	
512097	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
512098	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
512099	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
512100	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Operations C Ø	1	
512101	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
512102	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
512103	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
512104	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Bushings Connection/Risers	Good	
512105	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Bushing Condition	Good	
512106	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Amps C Ø	130.0	
512107	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
512108	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Follow-up Action Required?	n	
512109	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Patrol Inspection	General Comments		
512110	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	General Comments	ABC Phase IOC	
512111	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
512112	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Maintenance Operations	0	
512113	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Operations Counter AF	451	
512114	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Operations Counter AL	451	
512115	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Switching Operations	0	
512116	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Unknown Operations	0	
512117	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
512118	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
512119	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Amps A Ø	50.0	
512120	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Amps B Ø	75.0	
512121	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Amps C Ø	50.0	
512122	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
512123	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
512124	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
512125	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Follow-up Action Required?	n	
512126	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
512127	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
512128	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	General Comments		
512129	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	General Comments		
512130	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
512131	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	LTC Totalizer Reading	4754.88	kw
512132	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
512133	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
512134	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
512135	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
512136	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
512137	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
512138	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
512139	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
512140	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
512141	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Top Oil Temperature Max	58	°C
512142	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
512143	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
512144	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
512145	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
512146	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	180.0	
512147	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	180.0	
512148	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
512149	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
512150	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
512151	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
512152	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
512153	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
512154	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
512155	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
512156	3/20/2019 14:41	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
512157	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
512158	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
512159	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
512160	3/20/2019 14:41	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
512161	3/20/2019 14:41	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
512162	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
512163	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
512164	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
512165	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	9 Months Operations	8	
512166	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	12L	
512167	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
512168	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC As Left Counter	423817	
512169	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
512170	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	291	
512171	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	291	
512172	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
512173	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
512174	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC As Found Counter	423817	
512175	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
512176	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
512177	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
512178	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
512179	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Top Oil Temperature Max	64	°C
512180	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	General Comments		
512181	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
512182	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
512183	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
512184	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
512185	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Amps C Ø	90.0	
512186	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Amps B Ø	80.0	
512187	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Amps A Ø	100.0	
512188	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Accumulated Fault Duty C Ph AM	6.41	%
512189	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Accumulated Fault Duty B Ph AM	6.41	%
512190	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Accumulated Fault Duty A Ph AM	7.47	%
512191	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	9 Months Operations	10	
512192	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
512193	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
512194	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
512195	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
512196	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
512197	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
512198	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
512199	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
512200	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
512201	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
512202	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
512203	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
512204	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
512205	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
512206	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
512207	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
512208	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
512209	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
512210	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
512211	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
512212	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
512213	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
512214	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
512215	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
512216	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
512217	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
512218	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
512219	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
512220	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	248	
512221	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
512222	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
512223	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
512224	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Clear of Trash?	y	
512225	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
512226	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
512227	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
512228	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	LTCC000045	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	45	Seconds
512229	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	LTCC000045	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
512230	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	LTCC000045	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
512231	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
512232	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	General Comments		
512233	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	LTCC000045	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
512234	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	LTCC000045	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
512235	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	LTCC000045	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
512236	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	LTCC000045	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
512237	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	LTCC000045	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
512238	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Amps A Ø	160.0	
512239	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Maintenance Operations	0	
512240	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Operations Counter AF	421	
512241	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Operations Counter AL	421	
512242	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Switching Operations	0	
512243	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
512244	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Amps B Ø	75.0	
512245	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Amps C Ø	100.0	
512246	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
512247	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
512248	3/20/2019 14:41	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
512249	3/20/2019 14:41	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
512250	3/20/2019 14:41	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
512251	3/20/2019 14:41	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
512252	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
512253	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
512254	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	248	
512255	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
512256	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
512257	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
512258	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
512259	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
512260	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Top Oil Temperature Present	42	°C
512261	3/20/2019 14:41	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
512262	3/20/2019 14:41	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
512263	3/20/2019 14:41	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
512264	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	General Comments		
512265	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
512266	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Paint Condition	Good	
512267	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Equipment Properly Labeled?	y	
512268	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
512269	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
512270	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
512271	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
512272	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
512273	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
512274	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	298	
512275	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
512276	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
512277	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	14L	
512278	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	10L	
512279	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
512280	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC As Found Counter	217823	
512281	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC As Left Counter	217823	
512282	3/20/2019 14:41	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Unknown Operations	0	
512283	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
512284	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
512285	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5L	
512286	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
512287	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Foundation Condition	Good	
512288	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
512289	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
512290	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
512291	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Operations Since Last Insp	1200	
512292	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Min Tap Position	4L	
512293	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Max Tap Position	7R	
512294	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Current Tap Position	1R	
512295	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Min	-.60	MegaVars
512296	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Max	-.20	MegaVars
512297	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
512298	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC As Left Counter	396109	
512299	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
512300	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
512301	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
512302	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
512303	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	28.51	%
512304	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
512305	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
512306	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC As Found Counter	396097	
512307	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	General Comments		
512308	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	General Comments		
512309	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
512310	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
512311	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
512312	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
512313	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
512314	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
512315	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	General Comments		
512316	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
512317	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
512318	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
512319	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
512320	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
512321	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
512322	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
512323	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
512324	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
512325	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
512326	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
512327	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
512328	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
512329	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
512330	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
512331	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
512332	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
512333	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
512334	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
512335	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
512336	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
512337	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	37	°F
512338	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
512339	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	Follow-up Action Required?	n	
512340	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
512341	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
512342	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
512343	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
512344	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
512345	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
512346	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
512347	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
512348	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
512349	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
512350	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
512351	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
512352	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
512353	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Amps B Ø	0.0	
512354	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Amps A Ø	0.0	
512355	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	9 Months Operations	0	
512356	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
512357	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Vegetation	None	
512358	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
512359	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
512360	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	General Comments		
512361	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
512362	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
512363	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	General Comments		
512364	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
512365	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Panels Dusted?	y	
512366	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
512367	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
512368	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
512369	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
512370	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
512371	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	General Comments	Swept pad & picked up trash	
512372	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
512373	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
512374	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
512375	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
512376	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
512377	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
512378	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
512379	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
512380	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
512381	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
512382	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
512383	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
512384	3/20/2019 11:02	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
512385	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
512386	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
512387	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Grounds in Place?	y	
512388	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Maintenance Operations	0	
512389	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Moisture and Leak Free?	y	
512390	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
512391	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
512392	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6L	
512393	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
512394	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
512395	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC As Left Counter	314559	
512396	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC As Found Counter	314559	
512397	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
512398	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	General Comments		
512399	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
512400	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
512401	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Operations Counter AF	131	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
512402	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Operations Counter AL	131	
512403	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
512404	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Switching Operations	0	
512405	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Tank Paint Condition	Good	
512406	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Unknown Operations	0	
512407	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
512408	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
512409	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
512410	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
512411	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
512412	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
512413	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
512414	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
512415	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
512416	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	General Comments		
512417	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
512418	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
512419	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
512420	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
512421	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Foundation Condition	Good	
512422	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
512423	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
512424	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
512425	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
512426	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
512427	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
512428	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
512429	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
512430	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
512431	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
512432	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
512433	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
512434	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Vegetation	None	
512435	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
512436	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
512437	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	General Comments		
512438	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
512439	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
512440	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
512441	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
512442	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
512443	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
512444	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
512445	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Clear of Trash?	y	
512446	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
512447	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
512448	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
512449	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
512450	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
512451	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	General Comments		
512452	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	General Comments		
512453	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Follow-up Action Required?	n	
512454	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
512455	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations Ground	0	
512456	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations C Ø	0	
512457	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
512458	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
512459	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations B Ø	0	
512460	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations A Ø	0	
512461	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	General Comments	trees are getting large around station	
512462	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
512463	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	General Comments		
512464	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
512465	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
512466	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	320	
512467	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	320	
512468	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
512469	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
512470	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
512471	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
512472	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
512473	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
512474	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
512475	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
512476	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
512477	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
512478	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
512479	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
512480	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
512481	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
512482	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
512483	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
512484	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
512485	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
512486	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
512487	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
512488	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
512489	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
512490	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
512491	3/20/2019 14:41	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
512492	3/20/2019 14:41	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
512493	3/20/2019 14:41	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Vegetation	None	
512494	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Vegetation	None	
512495	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
512496	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	General Comments		
512497	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
512498	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
512499	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
512500	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
512501	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
512502	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
512503	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
512504	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
512505	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
512506	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
512507	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Clear of Trash?	y	
512508	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
512509	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
512510	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
512511	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
512512	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
512513	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
512514	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
512515	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
512516	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
512517	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
512518	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
512519	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
512520	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
512521	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
512522	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
512523	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
512524	3/20/2019 14:41	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
512525	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
512526	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
512527	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
512528	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
512529	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BCH000976	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
512530	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BCH000976	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
512531	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BCH000976	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
512532	3/20/2019 14:41	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
512533	3/20/2019 14:41	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
512534	3/20/2019 14:41	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
512535	3/20/2019 14:41	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
512536	3/20/2019 14:41	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
512537	3/20/2019 14:41	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
512538	3/20/2019 14:41	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	General Comments		
512539	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BCH000976	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
512540	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BCH000976	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
512541	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
512542	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
512543	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
512544	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
512545	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BCH000976	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
512546	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
512547	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
512548	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BCH000976	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.000	millivolts
512549	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
512550	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
512551	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
512552	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
512553	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	General Comments		
512554	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
512555	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
512556	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
512557	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
512558	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
512559	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
512560	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
512561	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
512562	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
512563	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
512564	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
512565	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
512566	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
512567	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
512568	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
512569	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC As Left Counter	86266	
512570	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC As Found Counter	86254	
512571	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	General Comments		
512572	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
512573	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
512574	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	General Comments		
512575	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
512576	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
512577	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	General Comments		
512578	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	General Comments		
512579	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Follow-up Action Required?	n	
512580	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
512581	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Operations Ground	0	
512582	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Operations C Ø	0	
512583	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Operations B Ø	0	
512584	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Operations A Ø	0	
512585	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
512586	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
512587	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
512588	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
512589	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	Oil Temp Present	45	°C
512590	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
512591	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
512592	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
512593	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
512594	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
512595	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
512596	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
512597	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
512598	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
512599	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
512600	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Operations Counter AL	161	
512601	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
512602	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
512603	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
512604	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
512605	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
512606	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
512607	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
512608	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
512609	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Current Tap Position	6L	
512610	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Max Tap Position	1R	
512611	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
512612	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
512613	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Min Tap Position	10L	
512614	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Unknown Operations	0	
512615	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
512616	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	LTCC000650	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
512617	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
512618	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
512619	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Operations Since Last Insp	933	
512620	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
512621	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
512622	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
512623	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
512624	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	LTCC000650	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
512625	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	LTCC000650	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
512626	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	LTCC000650	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.3	VAC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
512627	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	LTCC000650	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
512628	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Switching Operations	0	
512629	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	General Comments		
512630	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
512631	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
512632	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
512633	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
512634	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
512635	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Tank Paint Condition	Good	
512636	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Switching Operations	0	
512637	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
512638	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
512639	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
512640	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
512641	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Operations Counter AL	18463	
512642	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Operations Counter AF	18463	
512643	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Maintenance Operations	0	
512644	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	LTCC000650	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
512645	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	LTCC000650	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
512646	3/20/2019 9:57	Distribution	East Bernstadt Quarterly Inspection	LTCC000650	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
512647	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Vegetation	None	
512648	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
512649	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
512650	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
512651	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
512652	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Foundation Condition	Good	
512653	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
512654	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
512655	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
512656	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
512657	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
512658	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Max	.60	MegaWatts
512659	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Min	.40	MegaWatts
512660	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
512661	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
512662	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
512663	3/20/2019 14:41	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
512664	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	212	
512665	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
512666	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
512667	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Operations Counter AF	161	
512668	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
512669	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
512670	3/20/2019 13:58	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
512671	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
512672	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
512673	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Follow-up Action Required?	n	
512674	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Amps C Ø	0.0	
512675	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
512676	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Evidence of Insects	None	
512677	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
512678	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
512679	3/21/2019 14:35	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
512680	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
512681	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
512682	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
512683	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
512684	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Floor Swept?	y	
512685	3/20/2019 12:36	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
512686	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	General Comments		
512687	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	General Comments		
512688	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
512689	3/20/2019 11:59	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
512690	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
512691	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Amps C Ø	137.0	
512692	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Clear of Trash?	n	
512693	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
512694	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Tank Paint Condition	Good	
512695	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Switching Operations	1	
512696	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
512697	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
512698	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Follow-up Action Required?	n	
512699	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
512700	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	General Comments	2 blown LA on A and B phase....one structure leg foundation is crumbling and another is starting to	
512701	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Fans Operational?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
512702	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
512703	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
512704	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Follow-up Action Required?	n	
512705	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Foundation Condition	Good	
512706	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	9 Month Operations	4	
512707	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
512708	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Vegetation	None	
512709	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
512710	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
512711	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
512712	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
512713	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Foundation Condition	Good	
512714	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
512715	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
512716	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
512717	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
512718	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	General Comments		
512719	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	General Comments	BFTC	
512720	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Grounds in Place?	y	
512721	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
512722	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Adjusted Amps C Phase AM	9.55	
512723	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Operations A Ø	0	
512724	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Oil Temp Max	42	°C
512725	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
512726	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
512727	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Operations Ground	0	
512728	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Unknown Operations	0	
512729	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
512730	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Accumulated Fault Duty B Ph V	.31	%
512731	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
512732	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Amps A Ø	138.0	
512733	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
512734	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Operations B Ø	0	
512735	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Operations C Ø	1	
512736	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Maintenance Operations	0	
512737	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Amps B Ø	146.0	
512738	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Moisture and Leak Free?	y	
512739	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Operations Counter AF	180	
512740	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
512741	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
512742	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Operations Counter AL	180	
512743	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
512744	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
512745	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
512746	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
512747	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
512748	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
512749	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
512750	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
512751	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
512752	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
512753	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
512754	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
512755	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
512756	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations A Ø	0	
512757	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
512758	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
512759	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
512760	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
512761	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
512762	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	LTC Totalizer Reading	5352.48	kw
512763	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	General Comments		
512764	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	General Comments		
512765	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Totalizer Meter Reading	.7434	
512766	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Oil Temp Present	36	°C
512767	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
512768	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations B Ø	0	
512769	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations C Ø	0	
512770	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations Ground	0	
512771	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
512772	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
512773	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
512774	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
512775	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC As Left Counter	271477	
512776	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
512777	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
512778	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
512779	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
512780	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
512781	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6L	
512782	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
512783	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
512784	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
512785	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
512786	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Follow-up Action Required?	n	
512787	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
512788	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
512789	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
512790	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Equipment Properly Labeled?	y	
512791	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
512792	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	87	
512793	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	9 Months Operations	2	
512794	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Accumulated Fault Duty A Ph AM	4.27	%
512795	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Accumulated Fault Duty B Ph AM	3.20	%
512796	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Accumulated Fault Duty C Ph AM	2.14	%
512797	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	General Comments	Pile of branches and debris in front of station	
512798	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
512799	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
512800	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
512801	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
512802	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
512803	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
512804	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
512805	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
512806	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
512807	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Vegetation	None	
512808	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Paint Condition	Good	
512809	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
512810	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
512811	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
512812	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Amps A Ø	100.0	
512813	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Amps B Ø	130.0	
512814	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Amps C Ø	150.0	
512815	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
512816	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
512817	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
512818	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Bushings Connection/Risers	Good	
512819	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC As Found Counter	271477	
512820	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
512821	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	General Comments		
512822	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
512823	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
512824	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Bushing Condition	Good	
512825	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	General Comments		
512826	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	General Comments		
512827	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
512828	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
512829	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Follow-up Action Required?	n	
512830	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
512831	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Vegetation	None	
512832	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
512833	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Switching Operations	0	
512834	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
512835	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
512836	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
512837	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
512838	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
512839	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
512840	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
512841	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
512842	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
512843	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
512844	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Operations Counter AL	377	
512845	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
512846	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
512847	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
512848	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
512849	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
512850	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
512851	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
512852	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
512853	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
512854	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Operations Counter AF	377	
512855	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Maintenance Operations	0	
512856	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
512857	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
512858	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
512859	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
512860	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
512861	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
512862	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
512863	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
512864	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
512865	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
512866	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
512867	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
512868	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
512869	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Totalizer Meter Reading	.9630	
512870	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
512871	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
512872	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
512873	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
512874	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Totalizer Meter Multiplier	72009	
512875	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
512876	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
512877	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
512878	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
512879	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Top Oil Temperature Present	39	°C
512880	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Top Oil Temperature Max	52	°C
512881	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
512882	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
512883	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
512884	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
512885	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
512886	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
512887	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
512888	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
512889	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
512890	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
512891	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Unknown Operations	0	
512892	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
512893	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	General Comments		
512894	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
512895	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
512896	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
512897	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
512898	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
512899	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
512900	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
512901	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
512902	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
512903	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
512904	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
512905	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
512906	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	LTC Totalizer Reading	69344.67	kw
512907	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
512908	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	General Comments		
512909	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
512910	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
512911	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Foundation Condition	Good	
512912	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
512913	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
512914	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
512915	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	General Comments		
512916	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
512917	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
512918	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
512919	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
512920	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
512921	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
512922	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
512923	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
512924	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
512925	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
512926	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
512927	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
512928	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
512929	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
512930	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Current Tap Position	1L	
512931	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Max Tap Position	5R	
512932	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Min Tap Position	8L	
512933	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Operations Since Last Insp	826	
512934	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
512935	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
512936	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
512937	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
512938	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
512939	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
512940	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
512941	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	General Comments		
512942	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
512943	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
512944	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
512945	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
512946	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
512947	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
512948	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
512949	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
512950	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
512951	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
512952	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
512953	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	Follow-up Action Required?	n	
512954	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
512955	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	General Comments		
512956	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	General Comments		
512957	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC As Found Counter	2541	
512958	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC As Left Counter	2550	
512959	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
512960	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
512961	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Clear of Trash?	y	
512962	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
512963	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Ambient Temp	42	°F
512964	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
512965	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
512966	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
512967	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	General Comments	top rail is getting rusty	
512968	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	General Comments	C Phase IOC	
512969	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
512970	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
512971	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	General Comments	A couple of trees are starting to have some limbs to grow over the top of the fence line at the back of the station.	
512972	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
512973	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Ambient Temp	53	°F
512974	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
512975	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Patrol Inspection	General Comments		
512976	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Follow-up Action Required?	n	
512977	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
512978	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
512979	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
512980	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
512981	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
512982	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
512983	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Clear of Trash?	y	
512984	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
512985	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
512986	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
512987	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
512988	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
512989	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
512990	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
512991	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
512992	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.080	millivolts
512993	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	12.9	VDC
512994	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	27.8	VDC
512995	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
512996	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	General Comments		
512997	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	General Comments		
512998	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC As Found Counter	189630	
512999	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC As Left Counter	189642	
513000	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
513001	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
513002	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
513003	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
513004	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	General Comments		
513005	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
513006	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
513007	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
513008	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
513009	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
513010	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	All Connections OK?	y	
513011	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	Follow-up Action Required?	n	
513012	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	General Comments		
513013	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
513014	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
513015	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
513016	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
513017	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
513018	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
513019	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
513020	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
513021	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
513022	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Maintenance Operations	0	
513023	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
513024	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	General Comments		
513025	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Patrol Inspection	General Comments		
513026	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Follow-up Action Required?	n	
513027	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
513028	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Operations Ground	0	
513029	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
513030	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
513031	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
513032	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
513033	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
513034	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	LTC Operation Checked?	y	
513035	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
513036	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
513037	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
513038	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
513039	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	40.0	
513040	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Operations C Ø	0	
513041	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	VRR Time Delay	60	Seconds
513042	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Operations B Ø	1	
513043	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Operations A Ø	0	
513044	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
513045	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
513046	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
513047	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Unknown Operations	0	
513048	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Switching Operations	0	
513049	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
513050	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
513051	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Operations Counter AL	454	
513052	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Operations Counter AF	454	
513053	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	BAT000202	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
513054	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	BAT000202	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
513055	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	BAT000202	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
513056	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	BAT000202	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
513057	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	BAT000202	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	n	If no, which cells in comments
513058	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	BAT000202	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	n	If no, which cells in comments
513059	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	BAT000202	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
513060	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	BAT000202	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
513061	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	BAT000202	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
513062	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	BAT000202	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
513063	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	BAT000202	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
513064	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	BAT000202	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
513065	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	BAT000202	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
513066	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	BAT000202	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
513067	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Operations Ground	0	
513068	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Panels Dusted?	y	
513069	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
513070	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	General Comments		
513071	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
513072	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
513073	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Floor Swept?	y	
513074	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
513075	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
513076	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
513077	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Evidence of Insects	None	
513078	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
513079	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Follow-up Action Required?	n	
513080	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Patrol Inspection	General Comments		
513081	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	General Comments		
513082	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
513083	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	BCH001060	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
513084	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	BCH001060	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
513085	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	BCH001060	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
513086	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	BCH001060	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
513087	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	BCH001060	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
513088	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	BCH001060	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
513089	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	BCH001060	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.700	millivolts
513090	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Maintenance Operations	0	
513091	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Operations Counter AF	308	
513092	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Operations Counter AL	308	
513093	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Switching Operations	0	
513094	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Unknown Operations	0	
513095	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
513096	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
513097	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
513098	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
513099	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
513100	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	Follow-up Action Required?	n	
513101	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
513102	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
513103	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	General Comments		
513104	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
513105	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
513106	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
513107	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	9 Months Operations	0	
513108	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
513109	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
513110	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
513111	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
513112	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
513113	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
513114	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
513115	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
513116	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
513117	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
513118	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
513119	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
513120	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	BFTC	
513121	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
513122	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
513123	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
513124	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
513125	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
513126	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
513127	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
513128	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
513129	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1106	
513130	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1106	
513131	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
513132	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
513133	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
513134	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Panels Dusted?	n	
513135	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
513136	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Amps A Ø	25.0	
513137	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Amps B Ø	25.0	
513138	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Amps C Ø	75.0	
513139	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
513140	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
513141	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Accumulated Fault Duty B Ph AM	5.34	%
513142	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Accumulated Fault Duty A Ph AM	2.14	%
513143	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
513144	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
513145	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	9 Months Operations	3	
513146	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Operations C Ø	0	
513147	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Operations B Ø	0	
513148	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
513149	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
513150	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
513151	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
513152	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
513153	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Operations A Ø	0	
513154	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
513155	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
513156	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	40.0	
513157	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	15.05	%
513158	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	21.39	%
513159	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	16.63	%
513160	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
513161	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
513162	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
513163	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Adjusted Amps B Phase AM	9.55	
513164	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
513165	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
513166	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Current Tap Position	7L	
513167	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Max Tap Position	1R	
513168	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Min Tap Position	12L	
513169	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
513170	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
513171	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Percent Thermal Load C Ø Max	-60	%
513172	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Operations Since Last Insp	1100	
513173	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
513174	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	35.64	%
513175	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	35.64	%
513176	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Amps C Ø	150.0	
513177	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Amps B Ø	130.0	
513178	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Amps A Ø	170.0	
513179	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
513180	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	35.64	%
513181	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
513182	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Percent Thermal Load A Ø Max	-60	%
513183	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
513184	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Oil Temp Max	30	°C
513185	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
513186	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
513187	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	0.00	MegaWatts
513188	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	2.50	MegaWatts
513189	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	.10	MegaVars
513190	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
513191	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
513192	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
513193	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
513194	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
513195	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
513196	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
513197	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
513198	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
513199	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	.35	MegaVars
513200	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
513201	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
513202	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
513203	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
513204	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
513205	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
513206	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
513207	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
513208	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
513209	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
513210	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0104	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
513211	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	General Comments		
513212	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
513213	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
513214	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
513215	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
513216	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
513217	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
513218	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	15	
513219	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	15	
513220	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
513221	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Floor Swept?	y	
513222	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Unknown Operations	0	
513223	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Tank Paint Condition	Good	
513224	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
513225	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
513226	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
513227	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	BFTC	
513228	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
513229	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
513230	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
513231	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Switching Operations	1	
513232	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Operations Counter AL	163	
513233	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Operations Counter AF	163	
513234	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Moisture and Leak Free?	y	
513235	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Maintenance Operations	0	
513236	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Grounds in Place?	y	
513237	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	General Comments	Blown arrestors	
513238	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	General Comments	BFTC	
513239	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
513240	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
513241	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	9 Month Operations	17	
513242	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Accumulated Fault Duty A Ph V	1.87	%
513243	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Accumulated Fault Duty B Ph V	1.25	%
513244	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Foundation Condition	Good	
513245	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
513246	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Amps A Ø	106.0	
513247	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
513248	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Follow-up Action Required?	n	
513249	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
513250	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
513251	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
513252	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
513253	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
513254	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Follow-up Action Required?	n	
513255	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
513256	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations Ground	0	
513257	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
513258	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
513259	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
513260	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
513261	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
513262	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations C Ø	0	
513263	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations B Ø	0	
513264	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
513265	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations A Ø	0	
513266	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
513267	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
513268	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
513269	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Amps B Ø	113.0	
513270	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
513271	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
513272	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Equipment Properly Labeled?	y	
513273	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Amps C Ø	99.0	
513274	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Bushing Condition	Good	
513275	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Paint Condition	Good	
513276	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
513277	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Bushings Connection/Risers	Good	
513278	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
513279	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
513280	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	General Comments		
513281	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
513282	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
513283	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	All Connections OK?	y	
513284	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
513285	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
513286	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	Follow-up Action Required?	n	
513287	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	General Comments		
513288	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
513289	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	42.500	millivolts
513290	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
513291	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	LTC Operation Checked?	y	
513292	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
513293	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
513294	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
513295	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
513296	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
513297	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
513298	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
513299	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
513300	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	VRR Time Delay	45	Seconds
513301	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
513302	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
513303	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
513304	3/19/2019 12:52	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
513305	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Evidence of Insects	Yes_needs_sprayed	
513306	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
513307	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
513308	3/19/2019 11:38	Distribution	Ferguson South Quarterly Inspection	MB0111	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
513309	3/19/2019 13:14	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
513310	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
513311	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
513312	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
513313	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
513314	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
513315	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
513316	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
513317	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
513318	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
513319	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	335	
513320	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
513321	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
513322	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
513323	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
513324	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
513325	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
513326	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	331	
513327	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
513328	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
513329	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
513330	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
513331	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	Follow-up Action Required?	n	
513332	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	General Comments		
513333	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC Operations Since Last Insp	631	
513334	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
513335	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC Min Tap Position	14L	
513336	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC As Found Counter	86958	
513337	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC As Left Counter	86958	
513338	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC Current Tap Position	10L	
513339	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC Max Tap Position	3L	
513340	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
513341	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
513342	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
513343	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Totalizer Meter Reading	1.4118	
513344	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Follow-up Action Required?	n	
513345	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	General Comments		
513346	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	LTC Totalizer Reading	13553.28	kw
513347	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Oil Temp Max	45	°C
513348	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Oil Temp Present	35	°C
513349	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
513350	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
513351	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
513352	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
513353	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
513354	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
513355	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	150.0	
513356	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
513357	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
513358	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
513359	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
513360	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
513361	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	6	
513362	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	320	
513363	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	391	
513364	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	23	
513365	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	33	
513366	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	4.50	%
513367	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	4.50	%
513368	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	6.11	%
513369	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
513370	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
513371	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
513372	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
513373	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
513374	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
513375	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
513376	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
513377	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
513378	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
513379	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
513380	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
513381	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
513382	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
513383	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
513384	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
513385	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
513386	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
513387	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
513388	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
513389	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
513390	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
513391	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
513392	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
513393	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
513394	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
513395	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
513396	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
513397	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
513398	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
513399	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
513400	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
513401	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
513402	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	General Comments		
513403	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
513404	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
513405	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
513406	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
513407	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
513408	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
513409	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
513410	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
513411	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
513412	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
513413	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
513414	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
513415	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
513416	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
513417	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
513418	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
513419	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
513420	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
513421	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
513422	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
513423	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
513424	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
513425	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
513426	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	General Comments		
513427	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
513428	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
513429	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
513430	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
513431	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Accumulated Fault Duty B Ph V	.96	%
513432	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Accumulated Fault Duty A Ph V	.96	%
513433	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	9 Month Operations	4	
513434	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
513435	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Accumulated Fault Duty C Ph V	.96	%
513436	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
513437	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
513438	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
513439	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
513440	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
513441	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
513442	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
513443	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
513444	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	8933.76	kw
513445	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
513446	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations Ground	0	
513447	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
513448	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Amps A Ø	100.0	
513449	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
513450	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
513451	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
513452	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
513453	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
513454	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Amps B Ø	100.0	
513455	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations C Ø	0	
513456	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations B Ø	0	
513457	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC Operations Since Last Insp	674	
513458	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Amps C Ø	100.0	
513459	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC Min Tap Position	16L	
513460	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations A Ø	0	
513461	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
513462	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
513463	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
513464	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	General Comments		
513465	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Follow-up Action Required?	n	
513466	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	General Comments		
513467	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Unknown Operations	0	
513468	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Switching Operations	0	
513469	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
513470	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
513471	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
513472	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Amps C Ø	50.0	
513473	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Amps B Ø	75.0	
513474	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Amps A Ø	25.0	
513475	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Accumulated Fault Duty C Ph AM	2.13	%
513476	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Operations Counter AL	511	
513477	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Operations Counter AF	511	
513478	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Maintenance Operations	0	
513479	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	General Comments		
513480	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Accumulated Fault Duty B Ph AM	2.13	%
513481	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Accumulated Fault Duty A Ph AM	2.13	%
513482	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	9 Months Operations	12	
513483	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
513484	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
513485	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
513486	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
513487	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
513488	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
513489	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
513490	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
513491	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Bushings Connection/Risers	Good	
513492	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
513493	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
513494	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
513495	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Clear of Trash?	y	
513496	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Equipment Properly Labeled?	y	
513497	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Cabinet Paint Condition	Good	
513498	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
513499	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
513500	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	25	°C
513501	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	30	°C
513502	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
513503	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	General Comments	lightening arrestor has come loose at the chance clamp.	
513504	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	General Comments		
513505	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Foundation Condition	Good	
513506	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
513507	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	General Comments		
513508	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
513509	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Follow-up Action Required?	n	
513510	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Follow-up Action Required?	n	
513511	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	General Comments		
513512	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
513513	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Unknown Operations	0	
513514	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations Ground	0	
513515	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	25	°C
513516	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	30	°C
513517	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
513518	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
513519	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
513520	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
513521	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
513522	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
513523	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
513524	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
513525	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
513526	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	Oil Temp Max	30	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
513527	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
513528	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
513529	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	.50	MegaWatts
513530	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	.90	MegaWatts
513531	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	0.00	MegaVars
513532	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	.20	MegaVars
513533	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
513534	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	General Comments		
513535	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
513536	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Tank Leaks	None	
513537	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
513538	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
513539	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Regulator As Left Counter	135748	
513540	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
513541	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
513542	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
513543	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
513544	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
513545	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
513546	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
513547	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
513548	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	General Comments		
513549	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
513550	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
513551	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
513552	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
513553	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
513554	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
513555	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
513556	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
513557	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
513558	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
513559	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
513560	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
513561	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
513562	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Bushings Connection/Risers	Good	
513563	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
513564	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
513565	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Bushing Condition	Good	
513566	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
513567	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Follow-up Action Required?	n	
513568	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Switching Operations	0	
513569	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	LTCC000590	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
513570	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	LTCC000590	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
513571	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Current Tap Position	10L	
513572	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Max Tap Position	6L	
513573	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Min Tap Position	16L	
513574	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	General Comments		
513575	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC As Found Counter	1374	
513576	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC As Left Counter	1374	
513577	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
513578	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC Current Tap Position	6L	
513579	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC Max Tap Position	6L	
513580	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
513581	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	99	
513582	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
513583	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Winding Temp Present	54	°C
513584	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	LTCC000590	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
513585	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	LTCC000590	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
513586	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	LTCC000590	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
513587	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	LTCC000590	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
513588	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
513589	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
513590	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	General Comments		
513591	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
513592	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Winding Temp Max	55	°C
513593	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
513594	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
513595	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
513596	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
513597	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	General Comments		
513598	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
513599	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
513600	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Amps A Ø	75.0	
513601	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Amps B Ø	75.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
513602	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Follow-up Action Required?	n	
513603	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9306	
513604	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
513605	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations Ground	0	
513606	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
513607	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
513608	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
513609	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
513610	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Amps B Ø	0.0	
513611	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Amps C Ø	0.0	
513612	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
513613	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
513614	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
513615	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Operations Since Last Insp	716	
513616	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
513617	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
513618	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
513619	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
513620	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
513621	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations C Ø	0	
513622	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations B Ø	0	
513623	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations A Ø	0	
513624	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
513625	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
513626	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
513627	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
513628	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Amps C Ø	75.0	
513629	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
513630	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
513631	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
513632	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
513633	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
513634	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
513635	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations C Ø	0	
513636	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations B Ø	0	
513637	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations A Ø	0	
513638	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Unknown Operations	0	
513639	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
513640	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
513641	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
513642	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
513643	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	9 Months Operations	8	
513644	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
513645	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
513646	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
513647	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	Follow-up Action Required?	n	
513648	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Bushing Condition	Good	
513649	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
513650	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Amps C Ø	12.0	
513651	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Amps B Ø	12.0	
513652	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
513653	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
513654	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations Ground	0	
513655	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	9 Months Operations	0	
513656	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	14.94	%
513657	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	14.94	%
513658	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	14.94	%
513659	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Amps A Ø	0.0	
513660	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
513661	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Oil Temp Max	48	°C
513662	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
513663	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
513664	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
513665	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	General Comments		
513666	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
513667	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Oil Temp Present	46	°C
513668	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
513669	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	General Comments		
513670	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
513671	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations C Ø	0	
513672	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations B Ø	0	
513673	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations A Ø	0	
513674	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
513675	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
513676	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
513677	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
513678	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
513679	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	Follow-up Action Required?	n	
513680	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
513681	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	General Comments		
513682	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Maintenance Operations	0	
513683	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Operations Counter AF	321	
513684	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	General Comments		
513685	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC As Found Counter	24704	
513686	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC As Left Counter	24704	
513687	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Paint Condition	Good	
513688	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
513689	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Equipment Properly Labeled?	y	
513690	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
513691	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
513692	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
513693	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Vegetation	None	
513694	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
513695	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
513696	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
513697	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
513698	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	General Comments		
513699	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
513700	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
513701	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
513702	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	LTCC000590	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
513703	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	LTCC000590	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
513704	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
513705	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
513706	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
513707	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	LTCC000590	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
513708	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
513709	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
513710	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
513711	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Operations Counter AL	321	
513712	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Regulator As Left Counter	88180	
513713	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
513714	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
513715	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Tank Leaks	None	
513716	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
513717	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
513718	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
513719	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
513720	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
513721	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
513722	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	General Comments		
513723	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
513724	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
513725	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
513726	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
513727	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
513728	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
513729	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
513730	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
513731	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
513732	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
513733	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
513734	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Bushing Condition	Good	
513735	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
513736	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
513737	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
513738	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BCH000480	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
513739	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BCH000480	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
513740	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BCH000480	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
513741	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
513742	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
513743	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
513744	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
513745	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
513746	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Amps A Ø	30.0	
513747	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
513748	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
513749	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
513750	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
513751	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
513752	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
513753	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
513754	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
513755	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
513756	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
513757	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
513758	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations A Ø	0	
513759	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
513760	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Amps C Ø	50.0	
513761	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Amps B Ø	50.0	
513762	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations B Ø	0	
513763	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	37	°F
513764	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
513765	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
513766	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
513767	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
513768	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
513769	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
513770	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations A Ø	0	
513771	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
513772	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
513773	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations A Ø	0	
513774	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
513775	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
513776	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
513777	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
513778	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
513779	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Equipment Properly Labeled?	y	
513780	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Paint Condition	Good	
513781	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
513782	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
513783	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
513784	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Vegetation	None	
513785	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
513786	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
513787	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
513788	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	BCH000282	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
513789	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
513790	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
513791	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	BCH000282	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
513792	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
513793	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
513794	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
513795	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BCH000480	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
513796	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BCH000480	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
513797	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	605	
513798	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	601	
513799	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
513800	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
513801	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
513802	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
513803	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
513804	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
513805	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
513806	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
513807	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
513808	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
513809	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Bushings Connection/Risers	Good	
513810	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Bushing Condition	Good	
513811	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Amps C Ø	30.0	
513812	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Amps B Ø	30.0	
513813	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
513814	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BCH000480	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
513815	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
513816	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
513817	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
513818	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
513819	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
513820	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
513821	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
513822	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
513823	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
513824	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
513825	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	BCH000282	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
513826	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	BCH000282	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
513827	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	BCH000282	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
513828	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
513829	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	General Comments		
513830	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
513831	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
513832	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Floor Swept?	y	
513833	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
513834	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
513835	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Evidence of Insects	None	
513836	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
513837	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
513838	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
513839	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Accumulated Fault Duty C Ph V	.79	%
513840	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Accumulated Fault Duty B Ph V	1.19	%
513841	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
513842	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
513843	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
513844	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
513845	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
513846	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
513847	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
513848	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
513849	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
513850	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
513851	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	9 Months Operations	1	
513852	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Ambient Temp	44	°F
513853	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
513854	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
513855	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Clear of Trash?	y	
513856	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
513857	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
513858	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
513859	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
513860	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
513861	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
513862	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	General Comments		
513863	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
513864	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
513865	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
513866	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Switch Stick and Container OK?	y	
513867	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Vegetation	None	
513868	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
513869	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
513870	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	General Comments		
513871	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
513872	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
513873	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	Oil Temp Max	35	°C
513874	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
513875	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
513876	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Min	0.00	MegaWatts
513877	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Max	.10	MegaWatts
513878	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Min	-.20	MegaVars
513879	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Max	0.00	MegaVars
513880	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
513881	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	General Comments		
513882	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
513883	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
513884	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
513885	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
513886	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	160.0	
513887	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	160.0	
513888	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
513889	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
513890	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
513891	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	160.0	
513892	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	20.95	%
513893	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	17.54	%
513894	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	27.44	%
513895	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	13	
513896	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations C Ø	0	
513897	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations Ground	0	
513898	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Follow-up Action Required?	n	
513899	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Follow-up Action Required?	n	
513900	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Foundation Condition	Good	
513901	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
513902	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	General Comments		
513903	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
513904	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
513905	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
513906	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
513907	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Grounds in Place?	y	
513908	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
513909	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Amps A Ø	50.0	
513910	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
513911	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
513912	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
513913	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Maintenance Operations	0	
513914	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
513915	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
513916	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Operations Counter AF	168	
513917	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Operations Counter AL	168	
513918	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Switching Operations	0	
513919	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Tank Paint Condition	Good	
513920	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Unknown Operations	0	
513921	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
513922	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Tank Leaks	None	
513923	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
513924	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
513925	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Regulator As Left Counter	93386	
513926	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
513927	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Clear of Trash?	y	
513928	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
513929	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
513930	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
513931	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
513932	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
513933	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Trash Emptied?	n	
513934	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
513935	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
513936	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
513937	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
513938	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
513939	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
513940	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
513941	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
513942	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
513943	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	General Comments		
513944	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
513945	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
513946	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
513947	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
513948	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
513949	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
513950	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
513951	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	9 Months Operations	4	
513952	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
513953	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
513954	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
513955	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
513956	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
513957	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	General Comments		
513958	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
513959	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
513960	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
513961	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
513962	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
513963	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
513964	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
513965	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
513966	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
513967	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
513968	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
513969	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
513970	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Switching Operations	0	
513971	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Operations Counter AL	375	
513972	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Operations Counter AF	375	
513973	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Maintenance Operations	0	
513974	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
513975	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	44	°F
513976	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
513977	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
513978	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
513979	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
513980	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
513981	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
513982	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
513983	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
513984	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	General Comments		
513985	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	General Comments		
513986	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
513987	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
513988	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
513989	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Follow-up Action Required?	n	
513990	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
513991	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Switching Operations	0	
513992	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Tank Paint Condition	Good	
513993	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Unknown Operations	0	
513994	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
513995	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
513996	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
513997	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
513998	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	General Comments		
513999	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
514000	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
514001	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
514002	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
514003	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
514004	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
514005	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
514006	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Operations A Ø	0	
514007	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Operations B Ø	0	
514008	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Operations C Ø	0	
514009	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Operations Ground	0	
514010	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Follow-up Action Required?	n	
514011	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Follow-up Action Required?	n	
514012	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Foundation Condition	Good	
514013	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	General Comments		
514014	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Grounds in Place?	y	
514015	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Heaters (All) Functioning?	y	
514016	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Maintenance Operations	0	
514017	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	General Comments		
514018	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Moisture and Leak Free?	y	
514019	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Operations Counter AF	280	
514020	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Operations Counter AL	280	
514021	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
514022	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
514023	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	General Comments		
514024	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	All Connections OK?	y	
514025	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	Follow-up Action Required?	n	
514026	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	General Comments		
514027	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	LTC Operation Checked?	y	
514028	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
514029	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
514030	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC As Found Counter	96568	
514031	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Grounds in Place?	y	
514032	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC As Left Counter	96568	
514033	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
514034	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11L	
514035	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Max Tap Position	9L	
514036	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
514037	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
514038	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1069	
514039	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
514040	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
514041	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
514042	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
514043	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
514044	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
514045	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	VRR Time Delay	30	Seconds
514046	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Heaters (All) Functioning?	y	
514047	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Maintenance Operations	0	
514048	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Moisture and Leak Free?	y	
514049	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Operations Counter AF	186	
514050	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Operations Counter AL	188	
514051	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
514052	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Switching Operations	2	
514053	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Tank Paint Condition	Good	
514054	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Unknown Operations	0	
514055	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
514056	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
514057	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
514058	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
514059	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
514060	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
514061	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	General Comments		
514062	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Follow-up Action Required?	n	
514063	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	9 Month Operations	0	
514064	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
514065	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
514066	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Unknown Operations	0	
514067	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Switching Operations	0	
514068	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
514069	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Amps A Ø	330.0	
514070	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Amps B Ø	330.0	
514071	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Amps C Ø	330.0	
514072	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
514073	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
514074	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
514075	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
514076	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
514077	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
514078	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
514079	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
514080	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
514081	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
514082	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
514083	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
514084	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
514085	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
514086	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
514087	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
514088	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Operations Counter AL	293	
514089	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Operations Counter AF	293	
514090	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Maintenance Operations	0	
514091	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
514092	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
514093	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	General Comments		
514094	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	General Comments		
514095	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Follow-up Action Required?	n	
514096	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
514097	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
514098	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
514099	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
514100	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations Ground	0	
514101	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations C Ø	0	
514102	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
514103	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
514104	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
514105	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
514106	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
514107	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	9 Month Operations	4	
514108	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Accumulated Fault Duty A Ph V	.79	%
514109	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
514110	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	General Comments		
514111	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
514112	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
514113	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
514114	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
514115	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
514116	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations B Ø	0	
514117	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
514118	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
514119	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
514120	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
514121	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
514122	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
514123	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
514124	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
514125	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
514126	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
514127	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
514128	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	General Comments		
514129	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
514130	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
514131	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
514132	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
514133	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Follow-up Action Required?	n	
514134	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Eyewash Solution	Good	
514135	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
514136	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
514137	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
514138	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
514139	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
514140	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
514141	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
514142	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
514143	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
514144	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Foundation Condition	Good	
514145	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
514146	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
514147	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	General Comments		
514148	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
514149	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
514150	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
514151	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
514152	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
514153	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
514154	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
514155	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
514156	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
514157	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
514158	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
514159	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
514160	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
514161	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
514162	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
514163	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
514164	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Foundation Condition	Good	
514165	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
514166	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
514167	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	General Comments	lightening arrestor has come loose at the chance clamp.	
514168	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
514169	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
514170	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Overall Condition	Good	
514171	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Bank Volts	26.7	VDC
514172	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Bank Amps	0.0	AMPS
514173	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
514174	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
514175	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
514176	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
514177	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Ground Lights	None	
514178	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	187	
514179	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
514180	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
514181	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
514182	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
514183	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
514184	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Unknown Operations	0	
514185	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
514186	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Switching Operations	0	
514187	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
514188	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Amps A Ø	72.0	
514189	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
514190	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
514191	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
514192	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
514193	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
514194	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
514195	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
514196	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
514197	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
514198	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
514199	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
514200	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
514201	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	120.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
514202	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	120.0	
514203	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	120.0	
514204	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
514205	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Oil Temp Present	30	°C
514206	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	183	
514207	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
514208	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
514209	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
514210	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
514211	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
514212	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
514213	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
514214	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
514215	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Oil Temp Max	30	°C
514216	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
514217	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
514218	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
514219	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
514220	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
514221	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	434	
514222	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	438	
514223	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
514224	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	General Comments		
514225	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
514226	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
514227	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
514228	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
514229	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	9 Month Operations	4	
514230	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
514231	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
514232	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
514233	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
514234	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
514235	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
514236	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
514237	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
514238	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
514239	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
514240	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
514241	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	General Comments		
514242	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
514243	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
514244	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
514245	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
514246	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
514247	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	230	
514248	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	234	
514249	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
514250	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
514251	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
514252	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
514253	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
514254	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	4	
514255	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
514256	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
514257	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Winding Temp Max	40	°C
514258	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Totalizer Meter Reading	.6816	
514259	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
514260	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
514261	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
514262	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
514263	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
514264	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations Ground	0	
514265	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
514266	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
514267	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
514268	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
514269	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	General Comments		
514270	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
514271	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
514272	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
514273	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
514274	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	5.0	psi
514275	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations A Ø	0	
514276	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
514277	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations C Ø	0	
514278	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
514279	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
514280	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
514281	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
514282	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations Ground	0	
514283	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
514284	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
514285	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
514286	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	LTC Totalizer Reading	12268.80	kw
514287	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
514288	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
514289	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
514290	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
514291	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
514292	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
514293	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	General Comments		
514294	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	BCH000011	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
514295	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	BCH000011	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
514296	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
514297	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Follow-up Action Required?	n	
514298	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	General Comments		
514299	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
514300	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	BCH000011	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
514301	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	BCH000011	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
514302	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	BCH000011	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
514303	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
514304	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	BCH000011	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
514305	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
514306	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
514307	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
514308	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
514309	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
514310	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
514311	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
514312	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
514313	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Amps B Ø	60.0	
514314	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Amps C Ø	96.0	
514315	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
514316	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
514317	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	9 Months Operations	15	
514318	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
514319	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
514320	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
514321	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Amps A Ø	50.0	
514322	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Amps B Ø	50.0	
514323	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Amps C Ø	50.0	
514324	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
514325	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
514326	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
514327	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
514328	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
514329	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
514330	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
514331	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
514332	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
514333	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
514334	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
514335	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
514336	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
514337	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
514338	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Vegetation	None	
514339	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
514340	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
514341	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations A Ø	0	
514342	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
514343	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
514344	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
514345	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations B Ø	0	
514346	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations C Ø	0	
514347	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
514348	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
514349	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Oil Temp Present	30	°C
514350	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Oil Temp Max	0	°C
514351	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
514352	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
514353	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	LTC Totalizer Reading	7977.60	kw
514354	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
514355	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	General Comments		
514356	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	General Comments		
514357	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
514358	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
514359	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
514360	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
514361	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	9 Months Operations	0	
514362	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
514363	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Vegetation	None	
514364	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
514365	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
514366	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
514367	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Follow-up Action Required?	n	
514368	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
514369	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
514370	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
514371	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	General Comments		
514372	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
514373	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
514374	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
514375	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Winding Temp Present	30	°C
514376	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
514377	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
514378	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
514379	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
514380	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
514381	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
514382	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
514383	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
514384	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
514385	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
514386	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
514387	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
514388	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
514389	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
514390	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
514391	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
514392	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
514393	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
514394	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	30.0	
514395	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
514396	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
514397	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
514398	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Amps C Ø	100.0	
514399	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
514400	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
514401	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
514402	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
514403	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
514404	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	37	°F
514405	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
514406	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
514407	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations A Ø	0	
514408	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	LTCC000280	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
514409	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	30.0	
514410	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	30.0	
514411	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Amps B Ø	100.0	
514412	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Amps A Ø	100.0	
514413	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
514414	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
514415	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	LTCC000280	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
514416	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	LTCC000280	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
514417	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	LTCC000280	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
514418	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	LTCC000280	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
514419	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	LTCC000280	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
514420	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	LTCC000280	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
514421	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	LTCC000280	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
514422	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	LTCC000280	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
514423	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
514424	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
514425	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Totalizer Meter Reading	.8310	
514426	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
514427	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
514428	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
514429	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
514430	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
514431	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
514432	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
514433	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
514434	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
514435	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
514436	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	12	
514437	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.32	%
514438	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	.32	%
514439	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.96	%
514440	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	60.0	
514441	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	60.0	
514442	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	60.0	
514443	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
514444	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
514445	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
514446	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
514447	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
514448	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
514449	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
514450	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
514451	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
514452	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
514453	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
514454	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
514455	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
514456	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
514457	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
514458	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
514459	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
514460	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
514461	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
514462	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
514463	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
514464	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
514465	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
514466	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
514467	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
514468	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
514469	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
514470	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
514471	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
514472	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
514473	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
514474	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
514475	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
514476	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
514477	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
514478	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
514479	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
514480	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Clear of Trash?	y	
514481	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
514482	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
514483	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
514484	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	y	
514485	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
514486	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	General Comments	Taps seem to be changing but no LTC counter operations.	
514487	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC As Found Counter	5825	
514488	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
514489	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
514490	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Foundation Condition	Good	
514491	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
514492	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
514493	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	General Comments		
514494	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
514495	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
514496	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC As Left Counter	5825	
514497	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
514498	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
514499	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6L	
514500	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
514501	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	9 Month Operations	8	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
514502	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Accumulated Fault Duty A Ph V	.36	%
514503	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Accumulated Fault Duty B Ph V	.72	%
514504	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Accumulated Fault Duty C Ph V	.36	%
514505	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
514506	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
514507	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
514508	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
514509	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	0	
514510	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
514511	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
514512	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
514513	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
514514	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
514515	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
514516	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
514517	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
514518	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
514519	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1072	
514520	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1068	
514521	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	15	
514522	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
514523	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
514524	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
514525	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
514526	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
514527	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
514528	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Heaters (All) Functioning?	y	
514529	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Amps A Ø	12.0	
514530	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Maintenance Operations	0	
514531	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Moisture and Leak Free?	y	
514532	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Operations Counter AF	251	
514533	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
514534	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
514535	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations B Ø	0	
514536	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
514537	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	General Comments		
514538	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
514539	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC As Found Counter	256515	
514540	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC As Left Counter	256515	
514541	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
514542	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Operations Counter AF	276	
514543	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Panel Lights OK?	y	
514544	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
514545	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	General Comments		
514546	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
514547	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
514548	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
514549	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Operations Counter AL	276	
514550	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
514551	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
514552	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Max Tap Position	8L	
514553	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
514554	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
514555	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
514556	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
514557	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
514558	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
514559	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	General Comments		
514560	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Operations Counter AL	253	
514561	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	General Comments		
514562	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
514563	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
514564	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Switching Operations	2	
514565	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
514566	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
514567	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
514568	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
514569	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
514570	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
514571	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
514572	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Maintenance Operations	0	
514573	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	General Comments		
514574	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
514575	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
514576	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
514577	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Unknown Operations	0	
514578	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
514579	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
514580	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
514581	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
514582	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
514583	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	160.0	
514584	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	160.0	
514585	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	13.84	%
514586	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
514587	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	13.15	%
514588	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
514589	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
514590	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
514591	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps B Ø	360.0	
514592	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps C Ø	360.0	
514593	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
514594	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	160.0	
514595	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
514596	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
514597	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
514598	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
514599	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
514600	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps A Ø	300.0	
514601	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
514602	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations B Ø	0	
514603	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations C Ø	0	
514604	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
514605	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations Ground	0	
514606	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
514607	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
514608	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	9 Month Operations	27	
514609	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
514610	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
514611	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations C Ø	0	
514612	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations Ground	0	
514613	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Follow-up Action Required?	n	
514614	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Follow-up Action Required?	n	
514615	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Foundation Condition	Good	
514616	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	General Comments		
514617	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
514618	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	General Comments		
514619	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Grounds in Place?	y	
514620	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
514621	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
514622	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
514623	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
514624	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
514625	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
514626	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
514627	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	36	°F
514628	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
514629	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	82	°F
514630	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
514631	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations A Ø	0	
514632	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
514633	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
514634	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
514635	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
514636	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
514637	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
514638	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Amps C Ø	50.0	
514639	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Amps B Ø	50.0	
514640	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Amps A Ø	50.0	
514641	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
514642	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
514643	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
514644	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
514645	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
514646	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
514647	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
514648	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
514649	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
514650	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
514651	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
514652	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
514653	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
514654	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
514655	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
514656	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
514657	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
514658	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
514659	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
514660	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
514661	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
514662	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
514663	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	13.15	%
514664	3/18/2019 16:04	Distribution	Camargo Quarterly Inspection	BB0244	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	14	
514665	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
514666	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
514667	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
514668	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
514669	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Switching Operations	4	
514670	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Follow-up Action Required?	n	
514671	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	General Comments		
514672	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Maintenance Operations	0	
514673	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Operations Counter AF	251	
514674	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
514675	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
514676	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	General Comments		
514677	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Unknown Operations	0	
514678	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Switching Operations	0	
514679	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Operations Counter AL	251	
514680	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	General Comments		
514681	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
514682	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Operations Counter AL	252	
514683	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
514684	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Operations Counter AF	252	
514685	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
514686	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Maintenance Operations	0	
514687	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
514688	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Maintenance Operations	0	
514689	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Operations Counter AF	2	
514690	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
514691	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	General Comments		
514692	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
514693	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
514694	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
514695	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
514696	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
514697	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
514698	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Unknown Operations	0	
514699	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
514700	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Switching Operations	0	
514701	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Operations Counter AL	418	
514702	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Operations Counter AF	418	
514703	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Maintenance Operations	0	
514704	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
514705	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Unknown Operations	0	
514706	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Follow-up Action Required?	n	
514707	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
514708	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
514709	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
514710	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations Counter AF	251	
514711	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations Counter AL	251	
514712	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BCH000484	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
514713	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
514714	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Operations Counter AL	2	
514715	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BCH000484	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
514716	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BCH000484	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
514717	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BCH000484	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
514718	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Switching Operations	0	
514719	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BCH000484	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
514720	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Unknown Operations	0	
514721	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	General Comments		
514722	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BCH000484	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
514723	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	General Comments		
514724	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Follow-up Action Required?	n	
514725	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
514726	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
514727	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
514728	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
514729	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
514730	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations Ground	0	
514731	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations C Ø	0	
514732	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations B Ø	0	
514733	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
514734	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
514735	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
514736	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
514737	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
514738	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
514739	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
514740	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	General Comments		
514741	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
514742	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
514743	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
514744	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
514745	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
514746	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
514747	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
514748	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
514749	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
514750	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
514751	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
514752	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
514753	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
514754	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
514755	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
514756	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
514757	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
514758	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
514759	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
514760	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
514761	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
514762	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
514763	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
514764	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
514765	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
514766	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Amps A Ø	0.0	
514767	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
514768	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Amps B Ø	0.0	
514769	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	General Comments		
514770	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
514771	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Clear of Trash?	y	
514772	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
514773	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
514774	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
514775	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
514776	3/18/2019 13:58	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
514777	3/18/2019 12:56	Distribution	Southern Baptist Seminary Quarterly Inspe	BCH000011	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
514778	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
514779	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
514780	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
514781	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
514782	3/18/2019 11:29	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
514783	3/18/2019 13:44	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Amps C Ø	0.0	
514784	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	50.0	
514785	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	35.0	
514786	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	35.0	
514787	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	5.40	%
514788	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	11.57	%
514789	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	10.03	%
514790	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
514791	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
514792	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
514793	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
514794	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
514795	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
514796	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
514797	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
514798	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	209	
514799	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	209	
514800	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
514801	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
514802	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
514803	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
514804	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
514805	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
514806	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
514807	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
514808	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
514809	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
514810	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
514811	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
514812	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
514813	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
514814	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
514815	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
514816	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
514817	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
514818	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
514819	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
514820	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
514821	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
514822	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
514823	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
514824	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
514825	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
514826	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
514827	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
514828	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
514829	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
514830	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
514831	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
514832	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
514833	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	31.0	VDC
514834	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
514835	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
514836	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
514837	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
514838	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
514839	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
514840	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
514841	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	369	
514842	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
514843	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
514844	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
514845	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
514846	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
514847	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	32.0	VDC
514848	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
514849	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Max Tap Position	8L	
514850	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
514851	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
514852	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
514853	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
514854	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
514855	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
514856	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
514857	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
514858	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
514859	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
514860	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
514861	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
514862	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
514863	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
514864	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
514865	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
514866	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Trash?	y	
514867	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
514868	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
514869	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
514870	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
514871	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
514872	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
514873	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
514874	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	General Comments		
514875	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
514876	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
514877	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
514878	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Vegetation	None	
514879	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
514880	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Ambient Temp	47	°F
514881	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
514882	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
514883	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Accumulated Fault Duty C Ph V	4.41	%
514884	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Trash?	y	
514885	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
514886	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
514887	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
514888	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
514889	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
514890	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
514891	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
514892	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	General Comments		
514893	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
514894	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
514895	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
514896	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
514897	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
514898	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
514899	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2021-03-15 00:00:00.000000	
514900	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
514901	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Vegetation	None	
514902	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
514903	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
514904	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
514905	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
514906	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
514907	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
514908	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
514909	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
514910	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	General Comments		
514911	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
514912	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
514913	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
514914	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	General Comments		
514915	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
514916	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
514917	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
514918	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
514919	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	9 Month Operations	0	
514920	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Accumulated Fault Duty A Ph V	4.41	%
514921	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Accumulated Fault Duty B Ph V	4.41	%
514922	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
514923	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
514924	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
514925	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
514926	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
514927	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
514928	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
514929	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
514930	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
514931	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
514932	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Tank Leaks	None	
514933	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
514934	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	9 Month Operations	13	
514935	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Accumulated Fault Duty A Ph V	65.51	%
514936	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Accumulated Fault Duty B Ph V	68.02	%
514937	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Accumulated Fault Duty C Ph V	64.67	%
514938	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Amps A Ø	0.0	
514939	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Amps B Ø	0.0	
514940	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Amps C Ø	0.0	
514941	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Bushing Condition	Good	
514942	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Bushings Connection/Risers	Good	
514943	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
514944	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
514945	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Ambient Temp	47	°F
514946	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
514947	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
514948	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
514949	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
514950	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
514951	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
514952	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations A Ø	0	
514953	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations B Ø	0	
514954	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations C Ø	0	
514955	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations Ground	0	
514956	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
514957	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
514958	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
514959	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Follow-up Action Required?	n	
514960	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Follow-up Action Required?	n	
514961	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Foundation Condition	Good	
514962	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
514963	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
514964	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	General Comments		
514965	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	General Comments		
514966	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Grounds in Place?	y	
514967	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Totalizer Meter Reading	.7512	
514968	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
514969	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
514970	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
514971	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Amps C Ø	120.0	
514972	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
514973	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
514974	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
514975	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Amps B Ø	120.0	
514976	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
514977	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
514978	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Amps A Ø	150.0	
514979	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
514980	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
514981	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
514982	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
514983	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
514984	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
514985	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
514986	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
514987	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
514988	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
514989	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
514990	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
514991	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	General Comments	Northwest tower leg foundation starting to crumble	
514992	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
514993	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
514994	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
514995	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
514996	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
514997	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
514998	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
514999	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
515000	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
515001	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Follow-up Action Required?	n	
515002	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
515003	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Amps A Ø	512.0	
515004	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
515005	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	General Comments		
515006	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	General Comments		
515007	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
515008	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
515009	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
515010	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	LTC Totalizer Reading	7211.52	kw
515011	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
515012	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Foundation Condition	Crumbling	
515013	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
515014	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
515015	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Oil Temp Max	40	°C
515016	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Oil Temp Present	35	°C
515017	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
515018	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Amps B Ø	512.0	
515019	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Amps C Ø	480.0	
515020	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
515021	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
515022	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Bushing Condition	Good	
515023	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
515024	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
515025	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
515026	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
515027	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
515028	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
515029	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
515030	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
515031	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	12.58	
515032	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Operations Ground	0	
515033	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
515034	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
515035	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
515036	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
515037	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
515038	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	General Comments		
515039	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Clear of Trash?	y	
515040	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
515041	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
515042	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
515043	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
515044	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
515045	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
515046	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
515047	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
515048	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
515049	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
515050	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
515051	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	General Comments		
515052	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
515053	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
515054	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Operations Counter	2018	
515055	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
515056	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Tank Leaks	None	
515057	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
515058	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	General Comments		
515059	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
515060	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Vegetation	None	
515061	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
515062	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
515063	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	108.0	
515064	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	84.0	
515065	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	17.48	%
515066	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	VRR Time Delay	30	Seconds
515067	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
515068	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
515069	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
515070	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Operations C Ø	0	
515071	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Operations B Ø	0	
515072	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Operations A Ø	0	
515073	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
515074	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	LTC Operation Checked?	y	
515075	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	General Comments		
515076	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	Follow-up Action Required?	n	
515077	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	All Connections OK?	y	
515078	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
515079	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Amps A Ø	200.0	
515080	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Amps B Ø	350.0	
515081	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Amps C Ø	300.0	
515082	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
515083	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
515084	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
515085	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
515086	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
515087	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
515088	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
515089	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	LTCC000176	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
515090	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	LTCC000176	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
515091	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	LTCC000176	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
515092	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	LTCC000176	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	122.8	VAC
515093	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	LTCC000176	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
515094	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	LTCC000176	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
515095	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	LTCC000176	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
515096	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
515097	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
515098	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Adjusted Amps A Phase AM	33.54	
515099	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
515100	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Amps C Ø	230.0	
515101	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Amps B Ø	330.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
515102	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
515103	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Amps A Ø	190.0	
515104	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Patrol Inspection	General Comments		
515105	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Follow-up Action Required?	n	
515106	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
515107	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Patrol Inspection	Follow-up Action Required?	n	
515108	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Operations Since Last Insp	855	
515109	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
515110	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Min Tap Position	6L	
515111	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Max Tap Position	3R	
515112	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Current Tap Position	3L	
515113	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
515114	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
515115	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC As Left Counter	17291	
515116	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	9 Months Operations	16	
515117	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
515118	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	8.0	VDC
515119	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	8.0	VDC
515120	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC As Found Counter	17288	
515121	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	General Comments		
515122	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
515123	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	General Comments		
515124	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
515125	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	Follow-up Action Required?	n	
515126	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Ambient Temp	56	°F
515127	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
515128	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Amps A Ø	20.0	
515129	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Amps B Ø	22.0	
515130	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
515131	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
515132	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
515133	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
515134	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
515135	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Amps C Ø	19.0	
515136	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
515137	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
515138	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
515139	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
515140	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Accumulated Fault Duty B Ph AM	3.64	%
515141	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Accumulated Fault Duty A Ph AM	3.64	%
515142	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	9 Months Operations	23	
515143	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	3	
515144	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
515145	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
515146	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
515147	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
515148	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
515149	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
515150	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
515151	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	5	
515152	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Amps C Ø	.2	
515153	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Amps B Ø	.5	
515154	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	General Comments		
515155	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	General Comments		
515156	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Grounds in Place?	y	
515157	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Heaters (All) Functioning?	y	
515158	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Maintenance Operations	0	
515159	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
515160	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
515161	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Moisture and Leak Free?	y	
515162	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
515163	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
515164	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Operations Counter AF	706	
515165	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Operations Counter AL	706	
515166	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
515167	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Switching Operations	0	
515168	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Tank Paint Condition	Good	
515169	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Unknown Operations	1	
515170	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
515171	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
515172	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Floor Swept?	y	
515173	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
515174	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
515175	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Evidence of Insects	None	
515176	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
515177	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
515178	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	25	°C
515179	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	37	°C
515180	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	25	°C
515181	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	37	°C
515182	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	24	°C
515183	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	36	°C
515184	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Current Tap Position	11L	
515185	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
515186	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC As Left Counter	221218	
515187	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC As Found Counter	221218	
515188	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
515189	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
515190	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
515191	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	59	
515192	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
515193	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
515194	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
515195	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	General Comments		
515196	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
515197	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
515198	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Clear of Trash?	y	
515199	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
515200	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
515201	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
515202	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
515203	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
515204	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
515205	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	General Comments		
515206	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
515207	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Vegetation	None	
515208	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
515209	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
515210	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Amps A Ø	3.8	
515211	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
515212	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
515213	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
515214	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Patrol Inspection	General Comments		
515215	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	General Comments	High Set Inst. Phase A and Phase B	
515216	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Maintenance Operations	0	
515217	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Operations Counter AF	145	
515218	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Operations Counter AL	145	
515219	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Switching Operations	2	
515220	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Unknown Operations	0	
515221	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	20.84	%
515222	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	24.20	%
515223	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	41	
515224	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
515225	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
515226	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	General Comments		
515227	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
515228	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
515229	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	General Comments		
515230	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
515231	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
515232	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
515233	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
515234	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
515235	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
515236	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
515237	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
515238	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
515239	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
515240	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
515241	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
515242	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
515243	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
515244	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
515245	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
515246	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
515247	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
515248	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
515249	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
515250	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
515251	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
515252	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
515253	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
515254	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
515255	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
515256	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
515257	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	General Comments		
515258	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
515259	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
515260	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
515261	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	68	
515262	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
515263	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
515264	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
515265	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
515266	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
515267	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
515268	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
515269	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
515270	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
515271	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Trash Emptied?	y	
515272	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Tank Paint Condition	Good	
515273	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Unknown Operations	0	
515274	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations C Ø	0	
515275	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations Ground	0	
515276	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
515277	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
515278	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Follow-up Action Required?	n	
515279	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
515280	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
515281	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
515282	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
515283	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
515284	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
515285	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
515286	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
515287	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
515288	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
515289	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Clear of Trash?	y	
515290	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
515291	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
515292	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
515293	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
515294	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
515295	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
515296	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
515297	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
515298	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
515299	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
515300	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
515301	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
515302	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
515303	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
515304	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	General Comments		
515305	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
515306	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
515307	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Foundation Condition	Good	
515308	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	General Comments		
515309	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
515310	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
515311	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
515312	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
515313	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
515314	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
515315	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
515316	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
515317	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Foundation Condition	Good	
515318	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
515319	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
515320	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
515321	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
515322	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
515323	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
515324	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
515325	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
515326	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
515327	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
515328	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
515329	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
515330	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
515331	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
515332	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
515333	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
515334	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
515335	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
515336	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
515337	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
515338	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
515339	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
515340	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
515341	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	9 Months Operations	32	
515342	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
515343	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
515344	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
515345	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
515346	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	General Comments		
515347	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
515348	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
515349	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Foundation Condition	Good	
515350	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
515351	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
515352	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
515353	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
515354	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
515355	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
515356	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
515357	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
515358	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
515359	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
515360	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
515361	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
515362	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
515363	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
515364	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	n	
515365	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
515366	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
515367	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
515368	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Paint Condition	Good	
515369	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Equipment Properly Labeled?	y	
515370	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Adjusted Amps A Phase V	2.62	
515371	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Adjusted Amps B Phase V	2.62	
515372	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Adjusted Amps C Phase V	2.62	
515373	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations A Ø	0	
515374	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
515375	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations B Ø	0	
515376	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
515377	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Maintenance Operations	0	
515378	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
515379	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Operations Counter AF	166	
515380	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Operations Counter AL	166	
515381	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
515382	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
515383	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Vegetation	None	
515384	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
515385	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
515386	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	General Comments		
515387	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
515388	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
515389	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
515390	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
515391	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
515392	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Switching Operations	0	
515393	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
515394	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
515395	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	47	°F
515396	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	Oil Temp Present	24	°C
515397	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
515398	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
515399	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
515400	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
515401	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
515402	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
515403	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
515404	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
515405	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
515406	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Unknown Operations	0	
515407	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Switching Operations	0	
515408	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Operations Counter AL	418	
515409	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Operations Counter AF	418	
515410	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Maintenance Operations	0	
515411	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	General Comments	IOC Phase A and B	
515412	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Patrol Inspection	General Comments		
515413	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Follow-up Action Required?	n	
515414	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
515415	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	12.58	
515416	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	12.58	
515417	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
515418	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
515419	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
515420	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
515421	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
515422	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
515423	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
515424	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Patrol Inspection	Follow-up Action Required?	n	
515425	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations Ground	0	
515426	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations C Ø	0	
515427	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations B Ø	3	
515428	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations A Ø	3	
515429	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
515430	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
515431	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
515432	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1659	
515433	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1651	
515434	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
515435	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
515436	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
515437	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
515438	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
515439	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
515440	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
515441	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
515442	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
515443	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
515444	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Unknown Operations	0	
515445	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Switching Operations	1	
515446	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Operations Counter AL	99	
515447	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Operations Counter AF	99	
515448	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Maintenance Operations	0	
515449	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	General Comments		
515450	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
515451	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
515452	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Adjusted Amps B Phase AM	33.54	
515453	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	LTCC000176	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
515454	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
515455	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
515456	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
515457	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
515458	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
515459	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
515460	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
515461	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
515462	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	All Connections OK?	y	
515463	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	Follow-up Action Required?	n	
515464	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	General Comments		
515465	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	LTC Operation Checked?	y	
515466	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
515467	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
515468	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
515469	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	VRR Time Delay	30	Seconds
515470	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
515471	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	General Comments		
515472	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
515473	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
515474	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
515475	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Foundation Condition	Good	
515476	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
515477	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
515478	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
515479	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
515480	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
515481	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
515482	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
515483	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
515484	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
515485	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
515486	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
515487	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
515488	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.9	VDC
515489	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.9	VDC
515490	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
515491	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
515492	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
515493	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
515494	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Follow-up Action Required?	n	
515495	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Foundation Condition	Good	
515496	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	General Comments		
515497	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
515498	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	VRR Time Delay	45	Seconds
515499	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
515500	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
515501	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
515502	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	LTC Operation Checked?	y	
515503	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	General Comments		
515504	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	Follow-up Action Required?	n	
515505	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	All Connections OK?	y	
515506	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
515507	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	General Comments		
515508	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	General Comments	nitrogen bottle needs refilled, Strip heaters do not work, changed fuse for HTR and still not working	
515509	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
515510	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
515511	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
515512	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
515513	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	Oil Temp Max	36	°C
515514	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
515515	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
515516	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
515517	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Clear of Trash?	y	
515518	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Amps C Ø	49.0	
515519	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
515520	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
515521	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
515522	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
515523	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
515524	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
515525	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Amps B Ø	52.0	
515526	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
515527	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
515528	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
515529	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	General Comments		
515530	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
515531	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
515532	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
515533	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
515534	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
515535	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
515536	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
515537	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
515538	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
515539	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
515540	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
515541	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
515542	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
515543	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
515544	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Operations Since Last Insp	1217	
515545	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
515546	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
515547	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
515548	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
515549	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Amps A Ø	61.0	
515550	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
515551	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	250.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
515552	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	245.00	
515553	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	Oil Temp Max	22	°C
515554	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	Oil Temp Present	15	°C
515555	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
515556	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Accumulated Fault Duty B Ph V	1.10	%
515557	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Accumulated Fault Duty C Ph V	1.10	%
515558	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Amps A Ø	160.0	
515559	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Amps B Ø	320.0	
515560	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Amps C Ø	320.0	
515561	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Bushing Condition	Good	
515562	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Bushings Connection/Risers	Good	
515563	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
515564	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
515565	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
515566	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Paint Condition	Good	
515567	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Equipment Properly Labeled?	y	
515568	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
515569	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.8	psi
515570	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Oil Temp Max	38	°C
515571	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Oil Temp Present	36	°C
515572	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
515573	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
515574	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
515575	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
515576	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
515577	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
515578	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
515579	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
515580	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
515581	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
515582	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
515583	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
515584	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Unknown Operations	0	
515585	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
515586	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
515587	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
515588	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations A Ø	0	
515589	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations B Ø	0	
515590	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
515591	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
515592	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
515593	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
515594	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Clear of Trash?	y	
515595	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
515596	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
515597	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
515598	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
515599	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
515600	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
515601	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	General Comments		
515602	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
515603	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
515604	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
515605	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
515606	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Vegetation	None	
515607	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
515608	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
515609	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
515610	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
515611	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
515612	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
515613	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
515614	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
515615	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Vegetation	None	
515616	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
515617	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
515618	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
515619	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
515620	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
515621	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
515622	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Foundation Condition	Good	
515623	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
515624	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
515625	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
515626	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
515627	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
515628	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
515629	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
515630	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Foundation Condition	Good	
515631	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
515632	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
515633	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
515634	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2021-03-15 00:00:00.000000	
515635	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	General Comments		
515636	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
515637	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
515638	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
515639	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
515640	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
515641	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
515642	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
515643	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
515644	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	General Comments		
515645	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
515646	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
515647	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
515648	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
515649	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
515650	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
515651	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
515652	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
515653	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
515654	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
515655	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
515656	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
515657	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
515658	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
515659	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
515660	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
515661	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
515662	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Current Tap Position	4R	
515663	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Max Tap Position	6R	
515664	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Min Tap Position	10L	
515665	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
515666	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Follow-up Action Required?	n	
515667	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
515668	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
515669	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
515670	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
515671	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
515672	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
515673	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
515674	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
515675	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
515676	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
515677	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
515678	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
515679	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
515680	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
515681	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
515682	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
515683	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	146	
515684	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
515685	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	General Comments		
515686	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	General Comments		
515687	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
515688	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Clear of Trash?	y	
515689	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
515690	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
515691	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
515692	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
515693	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
515694	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
515695	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	LTC Totalizer Reading	10724.40	kw
515696	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	General Comments		
515697	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
515698	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
515699	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
515700	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
515701	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Totalizer Meter Reading	.3558	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
515702	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
515703	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
515704	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
515705	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Foundation Condition	Good	
515706	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
515707	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
515708	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	146	
515709	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
515710	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
515711	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
515712	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
515713	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
515714	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
515715	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
515716	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
515717	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
515718	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
515719	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
515720	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
515721	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
515722	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
515723	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
515724	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
515725	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
515726	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
515727	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
515728	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
515729	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
515730	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
515731	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
515732	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
515733	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
515734	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
515735	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	General Comments	69kv 603 switch has all three arcing horns broke off. Line arrestor circuit 756 has blown and needs replaced	
515736	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
515737	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
515738	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Foundation Condition	Good	
515739	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
515740	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations C Ø	0	
515741	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations Ground	0	
515742	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Follow-up Action Required?	n	
515743	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Follow-up Action Required?	n	
515744	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Foundation Condition	Good	
515745	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
515746	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
515747	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
515748	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
515749	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
515750	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
515751	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	31	
515752	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	16.81	%
515753	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	6.72	%
515754	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	General Comments		
515755	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	General Comments		
515756	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Grounds in Place?	y	
515757	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Heaters (All) Functioning?	y	
515758	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Maintenance Operations	0	
515759	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Moisture and Leak Free?	y	
515760	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Operations Counter AF	19	
515761	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Operations Counter AL	19	
515762	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
515763	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Switching Operations	0	
515764	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
515765	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
515766	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	General Comments		
515767	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
515768	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
515769	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
515770	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
515771	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
515772	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Tank Paint Condition	Good	
515773	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Unknown Operations	0	
515774	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
515775	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
515776	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
515777	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
515778	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	14.12	%
515779	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	108.0	
515780	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	72.0	
515781	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	84.0	
515782	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
515783	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
515784	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
515785	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
515786	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
515787	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
515788	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
515789	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
515790	3/15/2019 9:40	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
515791	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
515792	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
515793	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
515794	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
515795	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
515796	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
515797	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
515798	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
515799	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	General Comments		
515800	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
515801	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
515802	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
515803	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
515804	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
515805	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
515806	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
515807	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
515808	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
515809	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
515810	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
515811	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
515812	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
515813	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
515814	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
515815	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Winding Temp Max	60	°C
515816	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
515817	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
515818	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
515819	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
515820	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Operations Since Last Insp	686	
515821	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Min Tap Position	10L	
515822	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Max Tap Position	1R	
515823	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Current Tap Position	6L	
515824	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
515825	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Winding Temp Present	45	°C
515826	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
515827	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
515828	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC As Left Counter	11775	
515829	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC As Found Counter	11771	
515830	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
515831	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
515832	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
515833	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	General Comments		
515834	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	General Comments		
515835	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
515836	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
515837	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	Follow-up Action Required?	n	
515838	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
515839	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
515840	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
515841	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
515842	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
515843	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
515844	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
515845	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
515846	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
515847	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	16	
515848	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
515849	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	General Comments		
515850	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	General Comments		
515851	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
515852	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	Follow-up Action Required?	n	
515853	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
515854	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
515855	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
515856	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
515857	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
515858	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
515859	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
515860	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
515861	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
515862	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
515863	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
515864	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
515865	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
515866	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
515867	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
515868	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
515869	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
515870	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
515871	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
515872	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
515873	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	BCH001267	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
515874	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	BCH001267	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
515875	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	BCH001267	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
515876	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	81	
515877	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	BCH001267	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
515878	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	81	
515879	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
515880	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
515881	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
515882	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Tank Leaks	None	
515883	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
515884	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Regulator As Left Counter	64803	
515885	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
515886	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
515887	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
515888	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
515889	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
515890	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Unknown Operations	0	
515891	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Tank Paint Condition	Good	
515892	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Switching Operations	4	
515893	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
515894	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Operations Counter AL	470	
515895	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Operations Counter AF	470	
515896	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Moisture and Leak Free?	y	
515897	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Maintenance Operations	0	
515898	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Grounds in Place?	y	
515899	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	General Comments		
515900	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Grounds in Place?	y	
515901	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Moisture and Leak Free?	y	
515902	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
515903	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
515904	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Tank Paint Condition	Good	
515905	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	General Comments		
515906	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Foundation Condition	Good	
515907	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Follow-up Action Required?	n	
515908	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Equipment Properly Labeled?	y	
515909	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Paint Condition	Good	
515910	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
515911	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
515912	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
515913	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Bushings Connection/Risers	Good	
515914	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Bushing Condition	Good	
515915	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Tank Leaks	None	
515916	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
515917	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
515918	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
515919	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
515920	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
515921	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
515922	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
515923	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
515924	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
515925	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
515926	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
515927	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
515928	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
515929	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	General Comments		
515930	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	General Comments		
515931	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
515932	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
515933	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
515934	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Operations Counter	45	
515935	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	LTC Totalizer Reading	11847.60	kw
515936	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
515937	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
515938	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
515939	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
515940	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	General Comments		
515941	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	General Comments		
515942	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Foundation Condition	Good	
515943	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
515944	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Follow-up Action Required?	n	
515945	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Oil Temp Max	55	°C
515946	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Oil Temp Present	40	°C
515947	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
515948	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Follow-up Action Required?	n	
515949	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Operations Ground	0	
515950	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	4.300	millivolts
515951	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
515952	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
515953	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.4	amps
515954	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
515955	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
515956	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	General Comments		
515957	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
515958	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
515959	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
515960	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
515961	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
515962	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
515963	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
515964	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Totalizer Meter Reading	.6582	
515965	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	PF000334	PowerFuse	SP-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
515966	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	PF000334	PowerFuse	SP-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
515967	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Bushing Condition	Good	
515968	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Amps C Ø	100.0	
515969	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	PF000333	PowerFuse	SP-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
515970	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
515971	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Follow-up Action Required?	n	
515972	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
515973	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
515974	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	General Comments		
515975	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	General Comments		
515976	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
515977	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	LTC Totalizer Reading	3415.68	kw
515978	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
515979	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	PF000333	PowerFuse	SP-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
515980	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Amps B Ø	110.0	
515981	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	BCH000553	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
515982	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	BCH000553	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	51.9	VDC
515983	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Amps A Ø	90.0	
515984	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	BCH001267	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
515985	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
515986	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	80	°F
515987	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
515988	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
515989	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
515990	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
515991	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
515992	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
515993	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
515994	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
515995	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
515996	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	9 Month Operations	0	
515997	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Accumulated Fault Duty A Ph V	1.10	%
515998	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Accumulated Fault Duty C Ph V	22.38	%
515999	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	BCH000553	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	50.8	VDC
516000	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	BCH000553	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
516001	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	BCH000553	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
516002	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	BCH000553	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	y	
516003	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	BCH000553	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	work order for new charger	
516004	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Accumulated Fault Duty B Ph V	37.81	%
516005	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Accumulated Fault Duty A Ph V	32.41	%
516006	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	9 Month Operations	22	
516007	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
516008	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
516009	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
516010	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Operations Since Last Insp	945	
516011	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
516012	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
516013	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
516014	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
516015	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
516016	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
516017	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Tank Leaks	None	
516018	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
516019	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	Follow-up Action Required?	n	
516020	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
516021	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	General Comments		
516022	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	General Comments		
516023	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC As Found Counter	57219	
516024	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC As Left Counter	57219	
516025	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Regulator As Left Counter	63276	
516026	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
516027	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
516028	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Vegetation	None	
516029	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
516030	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
516031	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
516032	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	General Comments		
516033	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
516034	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
516035	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
516036	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
516037	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
516038	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
516039	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
516040	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
516041	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
516042	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
516043	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	General Comments		
516044	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
516045	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
516046	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
516047	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
516048	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
516049	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
516050	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
516051	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Amps A Ø	22.0	
516052	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Amps A Ø	160.0	
516053	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Amps B Ø	130.0	
516054	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Amps C Ø	140.0	
516055	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
516056	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
516057	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
516058	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
516059	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations A Ø	0	
516060	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations B Ø	0	
516061	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations C Ø	0	
516062	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations Ground	0	
516063	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Patrol Inspection	Follow-up Action Required?	n	
516064	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Follow-up Action Required?	n	
516065	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
516066	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
516067	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
516068	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
516069	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
516070	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
516071	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
516072	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
516073	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Operations C Ø	0	
516074	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Operations B Ø	0	
516075	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
516076	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
516077	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	General Comments		
516078	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Maintenance Operations	0	
516079	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Operations Counter AF	240	
516080	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Operations Counter AL	240	
516081	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Switching Operations	1	
516082	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Unknown Operations	0	
516083	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Amps B Ø	20.3	
516084	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Operations A Ø	0	
516085	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
516086	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Amps C Ø	22.5	
516087	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
516088	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
516089	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
516090	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	793	
516091	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
516092	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
516093	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
516094	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	General Comments	Cannot read A or B counters	
516095	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
516096	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
516097	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
516098	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
516099	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
516100	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Equipment Properly Labeled?	y	
516101	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Paint Condition	Good	
516102	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
516103	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
516104	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
516105	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
516106	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
516107	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
516108	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
516109	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
516110	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
516111	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
516112	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
516113	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
516114	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Bushings Connection/Risers	Good	
516115	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
516116	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	3172	
516117	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
516118	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
516119	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
516120	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
516121	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
516122	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
516123	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
516124	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
516125	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
516126	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
516127	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
516128	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
516129	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
516130	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
516131	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
516132	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
516133	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
516134	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
516135	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
516136	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
516137	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
516138	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	°F
516139	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
516140	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
516141	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
516142	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
516143	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
516144	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
516145	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
516146	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	General Comments		
516147	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
516148	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
516149	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
516150	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
516151	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Oil Temp Present	25	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
516152	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
516153	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
516154	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
516155	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
516156	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5400	
516157	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
516158	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
516159	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Oil Temp Max	30	°C
516160	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
516161	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
516162	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
516163	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
516164	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
516165	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
516166	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
516167	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
516168	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
516169	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
516170	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	General Comments		
516171	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
516172	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
516173	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
516174	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
516175	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
516176	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
516177	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
516178	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
516179	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
516180	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	LTC Totalizer Reading	8758.80	kw
516181	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
516182	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	General Comments		
516183	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	General Comments		
516184	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
516185	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
516186	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Follow-up Action Required?	n	
516187	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
516188	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
516189	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Clear of Trash?	y	
516190	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
516191	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Foundation Condition	Good	
516192	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
516193	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
516194	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
516195	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
516196	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	General Comments		
516197	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
516198	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
516199	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
516200	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
516201	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
516202	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Winding Temp Present	30	°C
516203	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Winding Temp Max	35	°C
516204	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Totalizer Meter Reading	.4866	
516205	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
516206	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	General Comments		
516207	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
516208	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
516209	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
516210	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
516211	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC Operations Since Last Insp	574	
516212	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC Min Tap Position	8L	
516213	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC Max Tap Position	16R	
516214	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC Current Tap Position	4L	
516215	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
516216	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC As Left Counter	81489	
516217	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC As Found Counter	81484	
516218	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	General Comments		
516219	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	General Comments		
516220	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
516221	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	Follow-up Action Required?	n	
516222	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
516223	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
516224	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
516225	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
516226	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
516227	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
516228	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
516229	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Amps A Ø	274.0	
516230	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Accumulated Fault Duty C Ph V	1.05	%
516231	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Accumulated Fault Duty B Ph V	1.05	%
516232	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Accumulated Fault Duty A Ph V	1.05	%
516233	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	9 Month Operations	0	
516234	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
516235	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
516236	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	n	
516237	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
516238	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
516239	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
516240	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
516241	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
516242	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
516243	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	Bad Ballast on 8ft Bulb.	
516244	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
516245	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	y	
516246	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
516247	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
516248	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
516249	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
516250	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
516251	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
516252	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	2L	
516253	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	12L	
516254	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
516255	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
516256	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
516257	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
516258	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
516259	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
516260	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
516261	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
516262	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
516263	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
516264	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
516265	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
516266	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
516267	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
516268	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
516269	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
516270	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
516271	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	General Comments		
516272	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	General Comments		
516273	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
516274	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.7	psi
516275	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
516276	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	647.64	kw
516277	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
516278	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
516279	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
516280	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Oil Temp Present	37	°C
516281	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
516282	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
516283	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
516284	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
516285	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
516286	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
516287	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
516288	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
516289	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
516290	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
516291	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
516292	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
516293	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5397	
516294	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
516295	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
516296	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
516297	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
516298	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
516299	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Current Tap Position	10L	
516300	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
516301	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
516302	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
516303	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
516304	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	General Comments		
516305	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
516306	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Max Tap Position	5L	
516307	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Min Tap Position	15L	
516308	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
516309	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
516310	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
516311	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
516312	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
516313	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Regulator As Left Counter	6038	
516314	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
516315	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
516316	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
516317	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
516318	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
516319	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
516320	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
516321	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
516322	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
516323	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
516324	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
516325	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	General Comments		
516326	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
516327	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
516328	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
516329	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
516330	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
516331	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
516332	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
516333	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
516334	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
516335	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
516336	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LTCC000567	LTCControl	SP-TRANS 2	LTC Control Insp	General Comments	ok	
516337	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LTCC000567	LTCControl	SP-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
516338	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
516339	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	General Comments		
516340	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
516341	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
516342	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
516343	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
516344	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
516345	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
516346	3/15/2019 15:29	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
516347	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	BCH000272	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
516348	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	BCH000272	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
516349	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	BCH000272	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
516350	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
516351	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
516352	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
516353	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
516354	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
516355	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
516356	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
516357	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
516358	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
516359	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
516360	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
516361	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
516362	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Regulator As Left Counter	705	
516363	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
516364	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
516365	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Tank Leaks	None	
516366	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
516367	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
516368	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
516369	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
516370	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	VRR Time Delay	30	Seconds
516371	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
516372	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
516373	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
516374	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	LTC Operation Checked?	y	
516375	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	General Comments		
516376	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
516377	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	All Connections OK?	y	
516378	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
516379	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
516380	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
516381	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
516382	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	BCH000272	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
516383	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
516384	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	General Comments		
516385	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
516386	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
516387	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
516388	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
516389	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
516390	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
516391	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
516392	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
516393	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
516394	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
516395	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	BCH000272	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
516396	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
516397	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
516398	3/15/2019 12:41	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
516399	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
516400	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
516401	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
516402	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
516403	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
516404	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
516405	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
516406	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
516407	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
516408	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
516409	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
516410	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
516411	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
516412	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
516413	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
516414	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
516415	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
516416	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
516417	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
516418	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
516419	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Patrol Inspection	General Comments		
516420	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Follow-up Action Required?	n	
516421	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
516422	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Patrol Inspection	Follow-up Action Required?	n	
516423	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Operations Ground	0	
516424	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Operations C Ø	0	
516425	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Operations B Ø	1	
516426	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
516427	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
516428	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
516429	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
516430	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
516431	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Follow-up Action Required?	n	
516432	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
516433	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
516434	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	General Comments		
516435	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	General Comments	Added nitrogen	
516436	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
516437	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	LTC Totalizer Reading	10290.24	kw
516438	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Operations A Ø	1	
516439	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	BAT000197	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
516440	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	BAT000197	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
516441	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	BAT000197	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
516442	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	BAT000197	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
516443	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	BAT000197	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
516444	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	BAT000197	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
516445	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	BAT000197	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
516446	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
516447	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
516448	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC As Left Counter	114300	
516449	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Oil Temp Max	59	°C
516450	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Oil Temp Present	42	°C
516451	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	BAT000197	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
516452	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	7L	
516453	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	BAT000197	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
516454	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	BAT000197	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
516455	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	BAT000197	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
516456	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
516457	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
516458	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
516459	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
516460	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	BAT000197	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
516461	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
516462	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC As Found Counter	114300	
516463	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	General Comments		
516464	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	General Comments		
516465	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
516466	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	Follow-up Action Required?	n	
516467	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Unknown Operations	0	
516468	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Tank Paint Condition	Good	
516469	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Switching Operations	0	
516470	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Operations Counter AL	205	
516471	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Operations Counter AF	205	
516472	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
516473	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
516474	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
516475	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Totalizer Meter Reading	1.4292	
516476	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
516477	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
516478	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
516479	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
516480	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
516481	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
516482	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
516483	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
516484	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
516485	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
516486	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
516487	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
516488	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	General Comments		
516489	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
516490	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	n	
516491	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
516492	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
516493	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
516494	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
516495	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
516496	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
516497	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Switching Operations	0	
516498	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Operations Counter AL	2466	
516499	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Operations Counter AF	2466	
516500	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Maintenance Operations	0	
516501	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
516502	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
516503	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	General Comments	IOC Phase A and B	
516504	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
516505	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
516506	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
516507	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Oil Temp Max	30	°C
516508	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
516509	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Min Tap Position	6L	
516510	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Max Tap Position	11R	
516511	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Oil Temp Present	28	°C
516512	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
516513	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
516514	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
516515	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
516516	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
516517	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
516518	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
516519	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
516520	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
516521	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
516522	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Operations Since Last Insp	1046	
516523	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Min Tap Position	9L	
516524	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
516525	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Totalizer Meter Reading	.5958	
516526	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Winding Temp Max	30	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
516527	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Winding Temp Present	30	°C
516528	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
516529	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
516530	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Current Tap Position	10R	
516531	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
516532	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC As Left Counter	153123	
516533	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC As Found Counter	153123	
516534	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	General Comments		
516535	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	General Comments		
516536	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
516537	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	Follow-up Action Required?	n	
516538	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
516539	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	General Comments		
516540	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
516541	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
516542	3/15/2019 15:30	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
516543	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
516544	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
516545	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
516546	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
516547	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
516548	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Current Tap Position	6L	
516549	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
516550	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
516551	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
516552	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
516553	3/15/2019 9:27	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
516554	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
516555	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
516556	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
516557	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Tank Leaks	None	
516558	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
516559	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
516560	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
516561	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
516562	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
516563	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
516564	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
516565	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
516566	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
516567	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
516568	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
516569	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
516570	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	9 Months Operations	16	
516571	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Accumulated Fault Duty A Ph AM	1.21	%
516572	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Accumulated Fault Duty B Ph AM	1.21	%
516573	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
516574	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
516575	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
516576	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	9 Months Operations	13	
516577	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Amps A Ø	220.0	
516578	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
516579	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
516580	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	864.00	kw
516581	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
516582	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
516583	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
516584	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
516585	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Amps B Ø	244.0	
516586	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
516587	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Amps C Ø	259.0	
516588	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
516589	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
516590	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
516591	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
516592	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
516593	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
516594	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
516595	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
516596	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
516597	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
516598	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
516599	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
516600	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
516601	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Oil Temp Max	45	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
516602	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Bushing Condition	Good	
516603	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
516604	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
516605	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
516606	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Amps C Ø	190.0	
516607	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Amps B Ø	160.0	
516608	3/15/2019 10:18	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
516609	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
516610	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
516611	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	General Comments	added nitrogen	
516612	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
516613	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Regulator As Left Counter	62694	
516614	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
516615	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
516616	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
516617	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
516618	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
516619	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	BAT000197	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
516620	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	BAT000197	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
516621	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
516622	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
516623	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
516624	3/22/2019 10:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	General Comments		
516625	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	General Comments		
516626	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
516627	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
516628	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
516629	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
516630	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Maintenance Operations	0	
516631	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Grounds in Place?	y	
516632	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	General Comments		
516633	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	General Comments		
516634	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Foundation Condition	Good	
516635	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Follow-up Action Required?	n	
516636	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Follow-up Action Required?	n	
516637	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations Ground	0	
516638	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations C Ø	0	
516639	3/15/2019 9:42	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
516640	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations B Ø	0	
516641	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations A Ø	0	
516642	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
516643	3/15/2019 11:30	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
516644	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
516645	3/15/2019 12:13	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Vegetation	None	
516646	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
516647	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
516648	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
516649	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
516650	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
516651	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
516652	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
516653	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
516654	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
516655	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
516656	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
516657	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
516658	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
516659	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
516660	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Radiator Leaks	Seeping	
516661	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
516662	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
516663	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	82.50	
516664	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
516665	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
516666	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	General Comments		
516667	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
516668	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
516669	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
516670	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
516671	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	General Comments	Heaters not plugged in. Only one leg is being used on heaters. Trips GFI rec.	
516672	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
516673	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
516674	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	n	
516675	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
516676	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
516677	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
516678	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
516679	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
516680	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	9 Month Operations	0	
516681	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Accumulated Fault Duty A Ph V	.90	%
516682	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Accumulated Fault Duty B Ph V	.90	%
516683	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Accumulated Fault Duty C Ph V	.90	%
516684	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Unknown Operations	0	
516685	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Switching Operations	0	
516686	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Operations C Ø	0	
516687	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Maintenance Operations	0	
516688	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Operations Counter AF	60	
516689	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Operations Counter AL	60	
516690	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC As Found Counter	15026	
516691	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC As Left Counter	15036	
516692	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
516693	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
516694	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
516695	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
516696	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
516697	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Operations A Ø	0	
516698	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
516699	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
516700	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
516701	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
516702	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Operations A Ø	0	
516703	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Operations B Ø	0	
516704	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
516705	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Current Tap Position	3L	
516706	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Amps C Ø	0.0	
516707	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Amps B Ø	0.0	
516708	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Amps A Ø	0.0	
516709	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Tank Leaks	None	
516710	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
516711	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Warning Signs OK?	y	
516712	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	39	°C
516713	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	9 Month Operations	1	
516714	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Follow-up Action Required?	n	
516715	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Foundation Condition	Good	
516716	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
516717	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
516718	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	General Comments		
516719	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
516720	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Grounds in Place?	y	
516721	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Operations Ground	0	
516722	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Patrol Inspection	Follow-up Action Required?	n	
516723	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Follow-up Action Required?	n	
516724	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Patrol Inspection	General Comments	ok	
516725	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
516726	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	General Comments	ok	
516727	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
516728	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
516729	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Operations Ground	0	
516730	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	General Comments	ok	
516731	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Maintenance Operations	0	
516732	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Operations Counter AF	174	
516733	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Operations Counter AL	174	
516734	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Switching Operations	0	
516735	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Patrol Inspection	General Comments	ok	
516736	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Follow-up Action Required?	n	
516737	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Patrol Inspection	Follow-up Action Required?	n	
516738	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Operations Ground	0	
516739	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
516740	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
516741	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Amps A Ø	122.0	
516742	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Amps B Ø	126.0	
516743	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Operations C Ø	0	
516744	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
516745	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Maintenance Operations	0	
516746	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
516747	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
516748	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	43	°C
516749	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Amps C Ø	125.0	
516750	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	General Comments	ok	
516751	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Patrol Inspection	General Comments	ok	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
516752	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
516753	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
516754	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
516755	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	General Comments		
516756	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
516757	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
516758	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Max Tap Position	4R	
516759	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Min Tap Position	9L	
516760	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Operations B Ø	0	
516761	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Unknown Operations	0	
516762	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Switching Operations	0	
516763	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Operations Counter AL	146	
516764	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Operations Counter AF	146	
516765	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Maintenance Operations	0	
516766	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Unknown Operations	0	
516767	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	General Comments	ok	
516768	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Patrol Inspection	General Comments		
516769	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Follow-up Action Required?	n	
516770	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Patrol Inspection	Follow-up Action Required?	n	
516771	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Operations Since Last Insp	1667	
516772	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Operations Ground	0	
516773	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	All Connections OK?	y	
516774	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
516775	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
516776	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
516777	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
516778	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Bushing Condition	Good	
516779	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
516780	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
516781	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Condition	Good	
516782	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Operations C Ø	0	
516783	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
516784	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
516785	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Unknown Operations	0	
516786	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	General Comments		
516787	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
516788	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
516789	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	Follow-up Action Required?	n	
516790	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Switching Operations	1	
516791	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
516792	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
516793	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Operations Counter AL	181	
516794	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Operations Counter AF	181	
516795	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
516796	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	42	°C
516797	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
516798	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	General Comments	The battery that is used to electrically start the motor used for the outriggers is dead. It will not start electrically.	
516799	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
516800	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
516801	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
516802	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
516803	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
516804	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
516805	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
516806	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Amps A Ø	138.0	
516807	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Amps B Ø	137.0	
516808	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Amps C Ø	137.0	
516809	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Unknown Operations	0	
516810	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Switching Operations	0	
516811	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
516812	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Operations Counter AL	189	
516813	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Operations Counter AF	189	
516814	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
516815	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
516816	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
516817	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
516818	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
516819	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
516820	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
516821	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
516822	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
516823	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
516824	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
516825	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Maintenance Operations	0	
516826	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
516827	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
516828	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
516829	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Foundation Condition	Crumbling	
516830	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
516831	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
516832	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	General Comments	tower leg foundations crumbling, as well as transformer	
516833	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
516834	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
516835	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
516836	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
516837	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
516838	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
516839	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
516840	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
516841	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
516842	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
516843	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
516844	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
516845	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
516846	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
516847	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
516848	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
516849	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
516850	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
516851	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.2724	
516852	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Winding Temp Max	30	°C
516853	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Winding Temp Present	30	°C
516854	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	All Connections OK?	y	
516855	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	Follow-up Action Required?	n	
516856	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	General Comments		
516857	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	LTC Operation Checked?	y	
516858	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
516859	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
516860	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
516861	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
516862	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	VRR Time Delay	30	Seconds
516863	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
516864	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
516865	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
516866	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Clear of Trash?	y	
516867	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
516868	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
516869	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
516870	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
516871	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	9 Month Operations	0	
516872	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
516873	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
516874	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
516875	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
516876	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
516877	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	General Comments		
516878	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
516879	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
516880	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
516881	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
516882	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
516883	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
516884	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
516885	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
516886	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Vegetation	None	
516887	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
516888	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
516889	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
516890	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
516891	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
516892	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
516893	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
516894	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
516895	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
516896	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
516897	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
516898	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	General Comments	ok	
516899	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Operations Ground	0	
516900	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Operations C Ø	0	
516901	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
516902	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Patrol Inspection	General Comments		
516903	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Follow-up Action Required?	n	
516904	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Patrol Inspection	Follow-up Action Required?	n	
516905	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Operations Ground	0	
516906	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Operations C Ø	0	
516907	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Operations B Ø	0	
516908	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Operations A Ø	0	
516909	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
516910	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
516911	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Amps C Ø	0.0	
516912	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Amps B Ø	0.0	
516913	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Amps A Ø	0.0	
516914	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
516915	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
516916	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
516917	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Operations A Ø	0	
516918	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
516919	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
516920	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
516921	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
516922	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
516923	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
516924	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Amps C Ø	138.0	
516925	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Amps B Ø	135.0	
516926	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Amps A Ø	138.0	
516927	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
516928	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
516929	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
516930	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	9 Month Operations	0	
516931	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	9 Month Operations	1	
516932	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
516933	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
516934	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
516935	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
516936	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
516937	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
516938	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
516939	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
516940	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	General Comments		
516941	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
516942	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
516943	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
516944	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
516945	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
516946	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
516947	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
516948	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
516949	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
516950	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Vegetation	None	
516951	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
516952	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	General Comments		
516953	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
516954	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
516955	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
516956	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
516957	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
516958	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Clear of Trash?	y	
516959	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
516960	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
516961	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
516962	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
516963	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	n	
516964	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	General Comments	fence and barb wire rusty, gaps under fence more than 4 inches	
516965	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
516966	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
516967	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
516968	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
516969	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
516970	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
516971	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
516972	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
516973	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
516974	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
516975	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
516976	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
516977	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
516978	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
516979	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Patrol Inspection	General Comments		
516980	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
516981	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Trash Emptied?	n	
516982	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
516983	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
516984	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	General Comments	turned heater down	
516985	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
516986	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
516987	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Floor Swept?	n	
516988	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
516989	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
516990	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
516991	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
516992	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Evidence of Insects	None	
516993	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
516994	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
516995	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
516996	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
516997	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
516998	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	General Comments	ok	
516999	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Follow-up Action Required?	n	
517000	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
517001	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
517002	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Overall Condition	Good	
517003	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	General Comments		
517004	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Follow-up Action Required?	n	
517005	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
517006	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
517007	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Overall Condition	Good	
517008	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	9 Month Operations	0	
517009	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
517010	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
517011	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
517012	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Amps A Ø	115.0	
517013	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Amps B Ø	115.0	
517014	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Amps C Ø	114.0	
517015	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
517016	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
517017	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
517018	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
517019	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
517020	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Operations Since Last Insp	1162	
517021	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Min Tap Position	12L	
517022	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Operations B Ø	0	
517023	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Operations A Ø	0	
517024	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
517025	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
517026	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
517027	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
517028	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Amps C Ø	108.0	
517029	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Amps B Ø	105.0	
517030	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Amps A Ø	105.0	
517031	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
517032	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
517033	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
517034	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	9 Month Operations	0	
517035	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
517036	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
517037	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
517038	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
517039	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
517040	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Amps C Ø	608.0	
517041	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Amps B Ø	614.0	
517042	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Amps A Ø	613.0	
517043	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
517044	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
517045	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
517046	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
517047	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
517048	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.500	millivolts
517049	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
517050	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
517051	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	9 Month Operations	4	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
517052	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
517053	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
517054	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
517055	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
517056	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
517057	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	General Comments		
517058	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
517059	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
517060	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
517061	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
517062	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
517063	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
517064	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
517065	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
517066	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
517067	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
517068	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
517069	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
517070	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
517071	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
517072	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
517073	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
517074	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
517075	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
517076	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
517077	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
517078	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
517079	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
517080	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
517081	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
517082	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Unknown Operations	0	
517083	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Switching Operations	0	
517084	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Operations Counter AL	119	
517085	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Operations Counter AF	119	
517086	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Maintenance Operations	0	
517087	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	General Comments	ok	
517088	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Patrol Inspection	General Comments		
517089	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Follow-up Action Required?	n	
517090	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Patrol Inspection	Follow-up Action Required?	n	
517091	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
517092	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
517093	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	526	
517094	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	526	
517095	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
517096	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
517097	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	General Comments		
517098	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	General Comments	added 1 lb nitrogen	
517099	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
517100	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
517101	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
517102	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
517103	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3053.76	kw
517104	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
517105	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
517106	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Oil Temp Max	25	°C
517107	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
517108	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
517109	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
517110	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
517111	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
517112	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Max Tap Position	2L	
517113	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Current Tap Position	6L	
517114	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
517115	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC As Left Counter	50448	
517116	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC As Found Counter	50448	
517117	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	General Comments		
517118	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	General Comments		
517119	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
517120	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	Follow-up Action Required?	n	
517121	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
517122	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
517123	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
517124	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
517125	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
517126	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
517127	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Operations B Ø	0	
517128	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Operations C Ø	0	
517129	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Operations Ground	0	
517130	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Patrol Inspection	Follow-up Action Required?	n	
517131	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Follow-up Action Required?	n	
517132	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Patrol Inspection	General Comments		
517133	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
517134	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	General Comments	ok	
517135	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Maintenance Operations	0	
517136	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Operations Counter AF	143	
517137	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Operations Counter AL	143	
517138	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Switching Operations	0	
517139	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Unknown Operations	0	
517140	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
517141	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
517142	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
517143	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
517144	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
517145	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.35	%
517146	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	4.24	%
517147	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	3.30	%
517148	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
517149	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
517150	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
517151	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
517152	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
517153	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
517154	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
517155	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
517156	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
517157	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
517158	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Amps C Ø	0.0	
517159	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
517160	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
517161	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
517162	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
517163	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations A Ø	0	
517164	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations B Ø	0	
517165	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Bushing Condition	Good	
517166	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
517167	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
517168	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
517169	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
517170	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
517171	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
517172	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
517173	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
517174	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
517175	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations C Ø	0	
517176	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations Ground	0	
517177	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Patrol Inspection	Follow-up Action Required?	n	
517178	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Follow-up Action Required?	n	
517179	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Patrol Inspection	General Comments	ok	
517180	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	General Comments	open	
517181	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Maintenance Operations	0	
517182	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Operations Counter AF	49	
517183	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
517184	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
517185	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
517186	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
517187	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Unknown Operations	0	
517188	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
517189	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
517190	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
517191	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
517192	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	General Comments		
517193	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
517194	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
517195	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
517196	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	9 Month Operations	0	
517197	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
517198	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
517199	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
517200	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
517201	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
517202	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
517203	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
517204	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Follow-up Action Required?	n	
517205	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Foundation Condition	Good	
517206	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
517207	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
517208	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
517209	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
517210	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
517211	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
517212	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
517213	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
517214	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
517215	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
517216	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
517217	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
517218	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations B Ø	0	
517219	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations A Ø	0	
517220	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
517221	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
517222	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
517223	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Operations A Ø	0	
517224	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Operations B Ø	0	
517225	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Operations C Ø	0	
517226	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Operations Ground	0	
517227	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Patrol Inspection	Follow-up Action Required?	n	
517228	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Follow-up Action Required?	n	
517229	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Patrol Inspection	General Comments		
517230	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	General Comments	open	
517231	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Maintenance Operations	0	
517232	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	9 Months Operations	1	
517233	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
517234	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
517235	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
517236	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Amps A Ø	160.0	
517237	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Amps B Ø	240.0	
517238	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Amps C Ø	150.0	
517239	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
517240	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
517241	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
517242	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
517243	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
517244	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
517245	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
517246	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
517247	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
517248	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
517249	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
517250	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
517251	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
517252	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
517253	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
517254	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations A Ø	0	
517255	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations B Ø	0	
517256	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations C Ø	0	
517257	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations Ground	0	
517258	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
517259	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Follow-up Action Required?	n	
517260	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
517261	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
517262	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
517263	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
517264	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
517265	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	163	
517266	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	163	
517267	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
517268	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
517269	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
517270	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
517271	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	General Comments		
517272	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	9 Month Operations	0	
517273	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Accumulated Fault Duty A Ph V	.90	%
517274	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Accumulated Fault Duty B Ph V	.90	%
517275	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Accumulated Fault Duty C Ph V	.90	%
517276	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Amps A Ø	0.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
517277	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Amps B Ø	0.0	
517278	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
517279	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Amps C Ø	0.0	
517280	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Amps B Ø	0.0	
517281	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
517282	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Amps A Ø	0.0	
517283	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
517284	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
517285	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
517286	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	9 Month Operations	0	
517287	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Unknown Operations	0	
517288	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Switching Operations	0	
517289	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Operations Counter AL	158	
517290	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Operations Counter AF	158	
517291	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Maintenance Operations	0	
517292	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	General Comments	open	
517293	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Patrol Inspection	General Comments	ok	
517294	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Follow-up Action Required?	n	
517295	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Patrol Inspection	Follow-up Action Required?	n	
517296	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Operations Ground	0	
517297	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Operations C Ø	0	
517298	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Unknown Operations	0	
517299	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Switching Operations	0	
517300	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Operations Counter AL	106	
517301	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Operations Counter AF	106	
517302	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Maintenance Operations	0	
517303	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
517304	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
517305	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
517306	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
517307	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
517308	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	General Comments	ok	
517309	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Patrol Inspection	General Comments	ok	
517310	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Follow-up Action Required?	n	
517311	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Patrol Inspection	Follow-up Action Required?	n	
517312	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations Ground	0	
517313	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations C Ø	0	
517314	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations B Ø	0	
517315	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations A Ø	0	
517316	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
517317	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
517318	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
517319	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
517320	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Amps C Ø	104.0	
517321	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Amps B Ø	105.0	
517322	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Amps A Ø	102.0	
517323	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
517324	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
517325	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
517326	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	9 Month Operations	2	
517327	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
517328	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
517329	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Totalizer Meter Reading	.6186	
517330	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
517331	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
517332	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
517333	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
517334	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
517335	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
517336	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
517337	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
517338	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
517339	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	11.76	%
517340	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	13.86	%
517341	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	General Comments		
517342	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
517343	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Amps C Ø	0.0	
517344	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Amps B Ø	0.0	
517345	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Amps A Ø	0.0	
517346	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
517347	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
517348	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Operations Counter AL	49	
517349	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Switching Operations	0	
517350	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Unknown Operations	0	
517351	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	16.80	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
517352	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
517353	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
517354	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	9 Month Operations	0	
517355	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Operations Counter AF	175	
517356	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Operations Counter AL	175	
517357	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Switching Operations	0	
517358	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Unknown Operations	0	
517359	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
517360	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
517361	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
517362	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Bushing Condition	Good	
517363	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Grounds in Place?	y	
517364	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
517365	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Switching Operations	0	
517366	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Operations Counter AL	188	
517367	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Operations Counter AF	188	
517368	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Maintenance Operations	0	
517369	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	General Comments	ok	
517370	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
517371	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Tank Paint Condition	Good	
517372	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Patrol Inspection	General Comments		
517373	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Follow-up Action Required?	n	
517374	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Patrol Inspection	Follow-up Action Required?	n	
517375	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Operations Ground	0	
517376	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Operations C Ø	0	
517377	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Operations B Ø	0	
517378	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Operations A Ø	0	
517379	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
517380	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
517381	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
517382	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
517383	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Amps C Ø	40.0	
517384	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Amps B Ø	36.0	
517385	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Amps A Ø	36.0	
517386	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
517387	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
517388	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
517389	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	9 Month Operations	0	
517390	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Patrol Inspection	Follow-up Action Required?	n	
517391	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Operations Ground	0	
517392	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Operations C Ø	0	
517393	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Operations B Ø	0	
517394	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Operations A Ø	0	
517395	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
517396	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
517397	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
517398	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Unknown Operations	0	
517399	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations A Ø	0	
517400	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
517401	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
517402	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
517403	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
517404	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Amps C Ø	0.0	
517405	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Amps B Ø	0.0	
517406	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Amps A Ø	0.0	
517407	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
517408	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
517409	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
517410	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	9 Month Operations	0	
517411	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
517412	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
517413	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
517414	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
517415	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
517416	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
517417	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
517418	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
517419	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
517420	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
517421	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
517422	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
517423	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	General Comments		
517424	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
517425	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
517426	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	9 Month Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
517427	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
517428	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
517429	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
517430	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
517431	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
517432	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
517433	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
517434	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Operations Counter AL	223	
517435	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Switching Operations	0	
517436	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Unknown Operations	0	
517437	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
517438	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
517439	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Amps A Ø	0.0	
517440	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Amps B Ø	0.0	
517441	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Amps C Ø	0.0	
517442	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Accumulated Fault Duty A Ph V	3.80	%
517443	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Accumulated Fault Duty B Ph V	3.80	%
517444	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Accumulated Fault Duty C Ph V	5.07	%
517445	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Amps A Ø	60.0	
517446	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Amps B Ø	60.0	
517447	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Amps C Ø	60.0	
517448	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Bushing Condition	Good	
517449	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Bushings Connection/Risers	Good	
517450	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
517451	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
517452	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
517453	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
517454	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
517455	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
517456	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations A Ø	0	
517457	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
517458	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
517459	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
517460	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	Oil Temp Present	37	°C
517461	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
517462	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
517463	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
517464	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
517465	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
517466	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
517467	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Amps A Ø	0.0	
517468	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
517469	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
517470	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
517471	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
517472	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
517473	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
517474	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	General Comments	ok	
517475	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	General Comments	ok	
517476	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
517477	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
517478	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
517479	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
517480	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
517481	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
517482	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Operations Counter	105	
517483	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Operations Counter AF	223	
517484	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
517485	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	9 Month Operations	25	
517486	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Amps B Ø	0.0	
517487	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	42	°C
517488	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	39	°C
517489	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Amps C Ø	0.0	
517490	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	42	°C
517491	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
517492	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
517493	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
517494	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
517495	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Operations A Ø	0	
517496	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Operations B Ø	0	
517497	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Operations C Ø	0	
517498	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	39	°C
517499	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	42	°C
517500	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	39	°C
517501	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
517502	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Patrol Inspection	Follow-up Action Required?	n	
517503	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Follow-up Action Required?	n	
517504	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Patrol Inspection	General Comments		
517505	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	General Comments	open	
517506	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Maintenance Operations	0	
517507	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	General Comments	ok	
517508	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Patrol Inspection	General Comments	ok	
517509	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Follow-up Action Required?	n	
517510	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Patrol Inspection	Follow-up Action Required?	n	
517511	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations Ground	0	
517512	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations C Ø	0	
517513	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations B Ø	0	
517514	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Maintenance Operations	0	
517515	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Operations Counter AF	174	
517516	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Operations Counter AL	174	
517517	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Switching Operations	0	
517518	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
517519	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
517520	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
517521	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
517522	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
517523	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
517524	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
517525	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
517526	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
517527	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	General Comments	Gap under fence in back right corner. Barb wire and some of the posts and rails have some rust.	
517528	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
517529	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
517530	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	BAT000174	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
517531	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Unknown Operations	0	
517532	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Switching Operations	0	
517533	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	BAT000174	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
517534	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	BAT000174	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	25.0	VDC
517535	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	BAT000174	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	24.0	VDC
517536	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	BAT000174	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	turned heater down	
517537	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	BAT000174	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
517538	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	BAT000174	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
517539	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	BAT000174	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
517540	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	BAT000174	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
517541	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	BAT000174	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
517542	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Operations Counter AL	66	
517543	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Operations Counter AF	66	
517544	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	BAT000174	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
517545	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Maintenance Operations	0	
517546	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	General Comments	open	
517547	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	BAT000174	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
517548	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	BAT000174	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	90	°F
517549	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	BAT000174	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
517550	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
517551	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
517552	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Tank Leaks	None	
517553	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
517554	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Radiator Leaks	None	
517555	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
517556	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
517557	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	General Comments		
517558	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Amps A Ø	0.0	
517559	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Amps B Ø	0.0	
517560	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Patrol Inspection	General Comments	ok	
517561	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Follow-up Action Required?	n	
517562	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Amps C Ø	0.0	
517563	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
517564	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
517565	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
517566	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
517567	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Unknown Operations	0	
517568	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Switching Operations	0	
517569	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Operations Counter AL	150	
517570	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Operations Counter AF	150	
517571	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Maintenance Operations	0	
517572	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	General Comments	open	
517573	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Patrol Inspection	General Comments		
517574	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Follow-up Action Required?	n	
517575	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Patrol Inspection	Follow-up Action Required?	n	
517576	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
517577	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations C Ø	0	
517578	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Amps C Ø	66.0	
517579	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Amps B Ø	44.0	
517580	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Amps A Ø	46.0	
517581	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations B Ø	0	
517582	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations C Ø	0	
517583	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
517584	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
517585	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
517586	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
517587	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
517588	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
517589	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
517590	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
517591	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
517592	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
517593	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
517594	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
517595	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
517596	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
517597	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
517598	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations Ground	0	
517599	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Patrol Inspection	Follow-up Action Required?	n	
517600	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Follow-up Action Required?	n	
517601	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Patrol Inspection	General Comments		
517602	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	General Comments	open	
517603	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Maintenance Operations	0	
517604	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Operations Counter AF	229	
517605	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Operations Counter AL	229	
517606	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Switching Operations	0	
517607	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Unknown Operations	0	
517608	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
517609	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Paint Condition	Good	
517610	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Equipment Properly Labeled?	y	
517611	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
517612	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
517613	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
517614	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations A Ø	0	
517615	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations B Ø	0	
517616	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations C Ø	0	
517617	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations Ground	0	
517618	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Follow-up Action Required?	n	
517619	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Follow-up Action Required?	n	
517620	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Foundation Condition	Good	
517621	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	General Comments		
517622	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	General Comments		
517623	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Grounds in Place?	y	
517624	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Maintenance Operations	0	
517625	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Moisture and Leak Free?	y	
517626	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Operations Counter AF	476	
517627	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Operations Counter AL	476	
517628	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
517629	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Switching Operations	0	
517630	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Tank Paint Condition	Good	
517631	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Unknown Operations	0	
517632	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	9 Month Operations	0	
517633	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
517634	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
517635	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
517636	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
517637	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
517638	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	All Connections OK?	y	
517639	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	Follow-up Action Required?	n	
517640	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	General Comments		
517641	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	LTC Operation Checked?	y	
517642	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
517643	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
517644	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
517645	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
517646	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Patrol Inspection	Follow-up Action Required?	n	
517647	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Operations Ground	0	
517648	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Operations C Ø	0	
517649	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Operations B Ø	0	
517650	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Operations A Ø	0	
517651	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
517652	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	VRR Time Delay	30	Seconds
517653	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
517654	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	8.94	%
517655	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	10.83	%
517656	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	11.77	%
517657	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
517658	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
517659	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
517660	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
517661	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Operations A Ø	0	
517662	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Operations B Ø	0	
517663	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Operations C Ø	0	
517664	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Operations Ground	0	
517665	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Patrol Inspection	Follow-up Action Required?	n	
517666	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Follow-up Action Required?	n	
517667	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
517668	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
517669	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
517670	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
517671	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
517672	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	General Comments	fault x	
517673	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Patrol Inspection	General Comments	ok	
517674	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Maintenance Operations	0	
517675	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Operations Counter AF	72	
517676	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Operations Counter AL	72	
517677	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Switching Operations	0	
517678	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Unknown Operations	1	
517679	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
517680	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
517681	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
517682	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
517683	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
517684	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
517685	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
517686	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
517687	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
517688	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
517689	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
517690	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
517691	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
517692	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
517693	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
517694	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
517695	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Follow-up Action Required?	n	
517696	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
517697	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
517698	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	General Comments	ok	
517699	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Patrol Inspection	General Comments		
517700	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Follow-up Action Required?	n	
517701	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Patrol Inspection	Follow-up Action Required?	n	
517702	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Operations Ground	0	
517703	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Unknown Operations	0	
517704	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Operations C Ø	0	
517705	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Operations B Ø	0	
517706	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Operations A Ø	0	
517707	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
517708	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
517709	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
517710	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
517711	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
517712	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
517713	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Amps C Ø	133.0	
517714	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Amps B Ø	131.0	
517715	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Amps A Ø	134.0	
517716	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Accumulated Fault Duty C Ph V	1.79	%
517717	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Accumulated Fault Duty B Ph V	1.79	%
517718	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Accumulated Fault Duty A Ph V	1.79	%
517719	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	9 Month Operations	1	
517720	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Switching Operations	0	
517721	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Operations Counter AL	74	
517722	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Patrol Inspection	General Comments	ok	
517723	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	General Comments	open	
517724	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Maintenance Operations	0	
517725	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Operations Counter AF	88	
517726	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Operations Counter AL	88	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
517727	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Switching Operations	0	
517728	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Unknown Operations	0	
517729	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
517730	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Operations Counter AF	74	
517731	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Maintenance Operations	0	
517732	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	General Comments	ok	
517733	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Patrol Inspection	General Comments	ok	
517734	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Follow-up Action Required?	n	
517735	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Patrol Inspection	Follow-up Action Required?	n	
517736	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations Ground	0	
517737	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations C Ø	0	
517738	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations B Ø	0	
517739	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
517740	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations A Ø	0	
517741	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
517742	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
517743	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
517744	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Unknown Operations	0	
517745	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
517746	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Amps C Ø	76.0	
517747	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Amps B Ø	78.0	
517748	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Amps A Ø	77.0	
517749	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
517750	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
517751	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Switching Operations	0	
517752	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Operations Counter AL	125	
517753	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Operations Counter AF	125	
517754	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Maintenance Operations	0	
517755	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	General Comments	open	
517756	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Patrol Inspection	General Comments		
517757	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Follow-up Action Required?	n	
517758	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
517759	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
517760	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
517761	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
517762	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	General Comments		
517763	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Unknown Operations	0	
517764	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Switching Operations	0	
517765	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Operations Counter AL	99	
517766	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
517767	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Maintenance Operations	0	
517768	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Operations Counter AF	386	
517769	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Operations Counter AL	386	
517770	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Switching Operations	0	
517771	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Unknown Operations	0	
517772	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Operations Counter AF	99	
517773	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Maintenance Operations	0	
517774	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	General Comments	ok	
517775	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Patrol Inspection	General Comments		
517776	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
517777	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
517778	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
517779	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
517780	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	54	
517781	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	54	
517782	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
517783	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
517784	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Follow-up Action Required?	n	
517785	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Patrol Inspection	Follow-up Action Required?	n	
517786	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations Ground	0	
517787	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations C Ø	0	
517788	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations B Ø	0	
517789	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations A Ø	0	
517790	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
517791	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
517792	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
517793	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
517794	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Amps C Ø	54.0	
517795	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Amps B Ø	54.0	
517796	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Amps A Ø	55.0	
517797	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
517798	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
517799	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
517800	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
517801	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
517802	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
517803	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
517804	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
517805	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
517806	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
517807	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	General Comments	ok	
517808	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	General Comments	ok	
517809	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
517810	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
517811	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
517812	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
517813	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	Oil Temp Max	40	°C
517814	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	Oil Temp Present	37	°C
517815	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
517816	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
517817	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	9 Month Operations	0	
517818	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	9 Month Operations	0	
517819	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
517820	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
517821	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
517822	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	General Comments		
517823	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	General Comments		
517824	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
517825	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	LTC Totalizer Reading	9508.32	kw
517826	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
517827	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
517828	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Oil Temp Max	40	°C
517829	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Oil Temp Present	40	°C
517830	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
517831	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
517832	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Amps A Ø	0.0	
517833	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
517834	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
517835	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
517836	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Amps B Ø	0.0	
517837	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Amps C Ø	0.0	
517838	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Patrol Inspection	Equipment Properly Labeled?	y	
517839	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
517840	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
517841	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
517842	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
517843	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
517844	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
517845	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
517846	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
517847	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
517848	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Operations A Ø	0	
517849	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Operations B Ø	0	
517850	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Operations C Ø	0	
517851	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Operations Ground	0	
517852	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Patrol Inspection	Follow-up Action Required?	n	
517853	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Follow-up Action Required?	n	
517854	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Patrol Inspection	General Comments	ok	
517855	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	General Comments	open	
517856	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
517857	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
517858	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Maintenance Operations	0	
517859	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Operations Counter AF	161	
517860	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Operations Counter AL	0	
517861	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Switching Operations	0	
517862	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Totalizer Meter Reading	1.3206	
517863	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
517864	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
517865	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Unknown Operations	0	
517866	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Unknown Operations	0	
517867	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Switching Operations	0	
517868	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Operations Counter AL	158	
517869	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
517870	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
517871	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
517872	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
517873	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
517874	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
517875	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
517876	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	9 Month Operations	2	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
517877	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
517878	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Follow-up Action Required?	n	
517879	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
517880	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
517881	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
517882	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
517883	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
517884	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Amps B Ø	0.0	
517885	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Amps A Ø	0.0	
517886	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
517887	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
517888	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
517889	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Unknown Operations	0	
517890	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Switching Operations	0	
517891	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Operations Counter AL	98	
517892	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Operations Counter AF	98	
517893	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Maintenance Operations	0	
517894	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	General Comments	ok	
517895	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Patrol Inspection	General Comments		
517896	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
517897	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
517898	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
517899	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
517900	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Tank Leaks	None	
517901	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
517902	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Regulator As Left Counter	42344	
517903	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
517904	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
517905	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
517906	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
517907	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
517908	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Amps C Ø	150.0	
517909	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Amps B Ø	130.0	
517910	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Amps A Ø	110.0	
517911	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
517912	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
517913	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
517914	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	9 Months Operations	2	
517915	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
517916	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
517917	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
517918	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
517919	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Operations Ground	0	
517920	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
517921	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
517922	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
517923	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
517924	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
517925	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
517926	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
517927	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Amps C Ø	523.0	
517928	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Amps B Ø	525.0	
517929	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
517930	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Amps A Ø	533.0	
517931	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
517932	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
517933	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
517934	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	9 Month Operations	2	
517935	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
517936	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
517937	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
517938	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
517939	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
517940	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
517941	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Unknown Operations	0	
517942	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Switching Operations	0	
517943	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Operations Counter AL	387	
517944	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Operations Counter AF	387	
517945	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Maintenance Operations	0	
517946	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
517947	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	General Comments		
517948	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	General Comments		
517949	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Follow-up Action Required?	n	
517950	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
517951	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
517952	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations C Ø	0	
517953	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations B Ø	0	
517954	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations A Ø	0	
517955	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
517956	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
517957	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
517958	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
517959	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Operations B Ø	0	
517960	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Operations A Ø	0	
517961	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
517962	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
517963	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
517964	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
517965	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Oil Temp Present	33	°C
517966	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Oil Temp Max	65	°C
517967	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
517968	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
517969	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	LTC Totalizer Reading	4453.92	kw
517970	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
517971	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
517972	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
517973	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
517974	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Amps C Ø	0.0	
517975	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
517976	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
517977	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
517978	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
517979	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
517980	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
517981	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
517982	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
517983	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
517984	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
517985	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
517986	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
517987	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
517988	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
517989	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
517990	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
517991	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
517992	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
517993	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
517994	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	General Comments		
517995	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	General Comments		
517996	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
517997	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
517998	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
517999	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
518000	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
518001	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
518002	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Totalizer Meter Reading	.9060	
518003	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
518004	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
518005	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
518006	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
518007	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
518008	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
518009	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
518010	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
518011	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Oil Temp Present	35	°C
518012	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Oil Temp Max	35	°C
518013	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
518014	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
518015	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	LTC Totalizer Reading	8697.60	kw
518016	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
518017	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	General Comments		
518018	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Unknown Operations	0	
518019	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Switching Operations	0	
518020	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Operations Counter AL	81	
518021	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Operations Counter AF	81	
518022	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Maintenance Operations	0	
518023	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
518024	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
518025	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
518026	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
518027	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
518028	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
518029	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
518030	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
518031	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
518032	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
518033	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Operations A Ø	0	
518034	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Operations B Ø	0	
518035	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Operations C Ø	0	
518036	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Operations Ground	0	
518037	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Patrol Inspection	Follow-up Action Required?	n	
518038	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Follow-up Action Required?	n	
518039	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	General Comments		
518040	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
518041	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
518042	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Follow-up Action Required?	n	
518043	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
518044	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
518045	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
518046	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
518047	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
518048	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	General Comments		
518049	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
518050	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
518051	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
518052	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
518053	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
518054	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
518055	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
518056	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
518057	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
518058	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
518059	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
518060	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
518061	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
518062	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
518063	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	9 Month Operations	10	
518064	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Accumulated Fault Duty A Ph V	.90	%
518065	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Accumulated Fault Duty B Ph V	2.69	%
518066	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Accumulated Fault Duty C Ph V	.90	%
518067	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Amps A Ø	87.0	
518068	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Amps B Ø	88.0	
518069	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	9 Month Operations	0	
518070	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
518071	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	General Comments		
518072	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
518073	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
518074	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
518075	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
518076	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
518077	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
518078	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
518079	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LTCC000405	LTCControl	WS-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
518080	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LTCC000405	LTCControl	WS-TRANS 3	LTC Control Insp	General Comments	ok	
518081	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LTCC000405	LTCControl	WS-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
518082	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
518083	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LTCC000409	LTCControl	WS-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
518084	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Amps C Ø	89.0	
518085	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
518086	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Adjusted Amps A Phase V	34.02	
518087	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LTCC000409	LTCControl	WS-TRANS 2	LTC Control Insp	General Comments	ok	
518088	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LTCC000409	LTCControl	WS-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
518089	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
518090	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
518091	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Adjusted Amps B Phase V	34.02	
518092	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Adjusted Amps C Phase V	34.02	
518093	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	9 Month Operations	0	
518094	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Accumulated Fault Duty A Ph V	.90	%
518095	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Accumulated Fault Duty B Ph V	.90	%
518096	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Accumulated Fault Duty C Ph V	.90	%
518097	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Amps A Ø	0.0	
518098	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Amps B Ø	0.0	
518099	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Amps C Ø	0.0	
518100	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
518101	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
518102	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
518103	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
518104	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
518105	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
518106	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
518107	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
518108	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
518109	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
518110	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
518111	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
518112	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
518113	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
518114	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
518115	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
518116	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
518117	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
518118	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
518119	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
518120	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Percent Thermal Load C Ø Max	-60	%
518121	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
518122	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Percent Thermal Load A Ø Max	-60	%
518123	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Oil Temp Present	25	°C
518124	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
518125	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
518126	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
518127	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Amps A Ø	493.0	
518128	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Amps B Ø	497.0	
518129	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Amps C Ø	492.0	
518130	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
518131	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
518132	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
518133	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
518134	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Operations A Ø	0	
518135	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Operations B Ø	0	
518136	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Operations C Ø	0	
518137	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Operations Ground	0	
518138	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
518139	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Follow-up Action Required?	n	
518140	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Patrol Inspection	General Comments	ok	
518141	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	General Comments	ok	
518142	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Maintenance Operations	0	
518143	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Operations Counter AF	188	
518144	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Operations Counter AL	188	
518145	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Switching Operations	0	
518146	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Unknown Operations	0	
518147	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Oil Temp Max	35	°C
518148	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
518149	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
518150	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
518151	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	General Comments		
518152	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
518153	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
518154	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
518155	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
518156	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
518157	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
518158	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
518159	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
518160	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
518161	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
518162	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
518163	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
518164	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
518165	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
518166	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Operations Counter AF	56	
518167	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Operations Counter AL	56	
518168	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Switching Operations	0	
518169	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Unknown Operations	0	
518170	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Maintenance Operations	0	
518171	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	General Comments	ok	
518172	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Patrol Inspection	General Comments	ok	
518173	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Follow-up Action Required?	n	
518174	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Patrol Inspection	Follow-up Action Required?	n	
518175	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Operations Ground	0	
518176	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
518177	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Operations B Ø	0	
518178	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Operations A Ø	0	
518179	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
518180	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
518181	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
518182	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
518183	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Amps C Ø	104.0	
518184	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
518185	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Tank Leaks	None	
518186	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
518187	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
518188	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Regulator As Left Counter	32977	
518189	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
518190	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
518191	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
518192	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
518193	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
518194	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
518195	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
518196	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
518197	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	General Comments		
518198	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
518199	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
518200	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
518201	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
518202	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
518203	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
518204	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
518205	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
518206	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
518207	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
518208	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
518209	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
518210	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
518211	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
518212	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
518213	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
518214	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	9 Month Operations	2	
518215	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Amps C Ø	0.0	
518216	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Amps B Ø	0.0	
518217	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
518218	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Amps A Ø	0.0	
518219	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Accumulated Fault Duty C Ph V	.90	%
518220	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Unknown Operations	0	
518221	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Operations Counter AL	44	
518222	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Operations Counter AF	44	
518223	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Maintenance Operations	0	
518224	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	General Comments	ok	
518225	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Patrol Inspection	General Comments	ok	
518226	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Follow-up Action Required?	n	
518227	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Patrol Inspection	Follow-up Action Required?	n	
518228	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Switching Operations	0	
518229	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Operations Counter AL	187	
518230	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Operations Counter AF	187	
518231	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
518232	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Maintenance Operations	0	
518233	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	General Comments	ok	
518234	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Patrol Inspection	General Comments	ok	
518235	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Follow-up Action Required?	n	
518236	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Patrol Inspection	Follow-up Action Required?	n	
518237	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Operations Ground	0	
518238	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Operations C Ø	0	
518239	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Operations B Ø	0	
518240	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Operations A Ø	0	
518241	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
518242	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
518243	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Oil Temp Present	40	°C
518244	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Oil Temp Max	50	°C
518245	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
518246	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	200	psi
518247	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
518248	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
518249	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Bushing Condition	Good	
518250	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	LTC Totalizer Reading	15591.60	kw
518251	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
518252	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	General Comments		
518253	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	General Comments		
518254	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
518255	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
518256	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Follow-up Action Required?	n	
518257	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
518258	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Bushings Connection/Risers	Good	
518259	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
518260	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
518261	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
518262	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Paint Condition	Good	
518263	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Equipment Properly Labeled?	y	
518264	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
518265	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
518266	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
518267	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
518268	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	General Comments		
518269	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
518270	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
518271	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
518272	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
518273	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
518274	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
518275	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
518276	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
518277	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
518278	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Amps B Ø	106.0	
518279	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Amps A Ø	107.0	
518280	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
518281	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
518282	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
518283	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	9 Month Operations	0	
518284	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
518285	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
518286	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Winding Temp Present	40	°C
518287	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Winding Temp Max	50	°C
518288	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Totalizer Meter Reading	.8662	
518289	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
518290	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
518291	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
518292	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
518293	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
518294	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Unknown Operations	0	
518295	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Switching Operations	0	
518296	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Operations Counter AL	56	
518297	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Operations Counter AF	56	
518298	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Maintenance Operations	0	
518299	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	General Comments	open	
518300	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Patrol Inspection	General Comments	ok	
518301	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Follow-up Action Required?	n	
518302	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Patrol Inspection	Follow-up Action Required?	n	
518303	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Operations Ground	0	
518304	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Operations C Ø	0	
518305	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Operations B Ø	0	
518306	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Operations A Ø	0	
518307	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
518308	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
518309	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
518310	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
518311	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Unknown Operations	0	
518312	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Switching Operations	0	
518313	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Operations Ground	0	
518314	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Patrol Inspection	Follow-up Action Required?	n	
518315	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Follow-up Action Required?	n	
518316	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Patrol Inspection	General Comments		
518317	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	General Comments	open	
518318	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Maintenance Operations	0	
518319	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
518320	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
518321	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	General Comments		
518322	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
518323	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC As Found Counter	409296	
518324	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC As Left Counter	409296	
518325	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
518326	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000414	PowerFuse	WS-1471 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
518327	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000414	PowerFuse	WS-1471 POT	Disconnect Powerfuse Inspection	General Comments	ok	
518328	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
518329	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6L	
518330	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Min Tap Position	7L	
518331	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
518332	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	6	
518333	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
518334	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
518335	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
518336	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
518337	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000411	PowerFuse	WS-1474 POT	Disconnect Powerfuse Inspection	General Comments	ok	
518338	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000411	PowerFuse	WS-1474 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
518339	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000409	PowerFuse	WS-1303 POT	Disconnect Powerfuse Inspection	General Comments	ok	
518340	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000409	PowerFuse	WS-1303 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
518341	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LTCC000265	LTCControl	WS-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
518342	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LTCC000265	LTCControl	WS-TRANS 4	LTC Control Insp	General Comments	ok	
518343	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LTCC000265	LTCControl	WS-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
518344	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC As Left Counter	20114	
518345	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC As Found Counter	20114	
518346	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	ok	
518347	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	General Comments	ok	
518348	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
518349	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
518350	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000408	PowerFuse	WS-1304 POT	Disconnect Powerfuse Inspection	General Comments	ok	
518351	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000408	PowerFuse	WS-1304 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
518352	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Operations Counter AF	65	
518353	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Operations Counter AL	65	
518354	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Switching Operations	0	
518355	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Unknown Operations	0	
518356	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Operations Ground	0	
518357	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Operations C Ø	0	
518358	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Operations B Ø	0	
518359	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Operations A Ø	0	
518360	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
518361	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
518362	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	SF6 Indicator Zone	OK	
518363	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	9 Month Operations	6	
518364	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Accumulated Fault Duty A Ph V	3.36	%
518365	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Accumulated Fault Duty B Ph V	8.82	%
518366	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Accumulated Fault Duty C Ph V	3.36	%
518367	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Amps A Ø	60.0	
518368	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Amps B Ø	60.0	
518369	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Amps C Ø	60.0	
518370	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Bushing Condition	Good	
518371	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Bushings Connection/Risers	Good	
518372	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
518373	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
518374	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
518375	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Paint Condition	Good	
518376	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Equipment Properly Labeled?	y	
518377	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
518378	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
518379	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
518380	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations A Ø	0	
518381	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations B Ø	0	
518382	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations C Ø	0	
518383	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations Ground	0	
518384	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Follow-up Action Required?	n	
518385	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Follow-up Action Required?	n	
518386	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Foundation Condition	Good	
518387	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	General Comments		
518388	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	General Comments		
518389	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Grounds in Place?	y	
518390	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Maintenance Operations	0	
518391	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Moisture and Leak Free?	y	
518392	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Operations Counter AF	284	
518393	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Operations Counter AL	284	
518394	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000413	PowerFuse	WS-1472 POT	Disconnect Powerfuse Inspection	General Comments	ok	
518395	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000413	PowerFuse	WS-1472 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
518396	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000412	PowerFuse	WS-1473 POT	Disconnect Powerfuse Inspection	General Comments	ok	
518397	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
518398	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Switching Operations	0	
518399	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
518400	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
518401	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
518402	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
518403	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
518404	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
518405	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
518406	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
518407	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000412	PowerFuse	WS-1473 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
518408	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Tank Paint Condition	Good	
518409	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Unknown Operations	0	
518410	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Operations C Ø	0	
518411	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
518412	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
518413	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
518414	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
518415	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Operations A Ø	0	
518416	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Operations B Ø	0	
518417	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Operations C Ø	0	
518418	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Operations Ground	0	
518419	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Patrol Inspection	Follow-up Action Required?	n	
518420	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000407	PowerFuse	WS-1331 POT	Disconnect Powerfuse Inspection	General Comments	ok	
518421	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000407	PowerFuse	WS-1331 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
518422	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000405	PowerFuse	WS-1333 POT	Disconnect Powerfuse Inspection	General Comments	ok	
518423	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000405	PowerFuse	WS-1333 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
518424	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000404	PowerFuse	WS-1334 POT	Disconnect Powerfuse Inspection	General Comments	ok	
518425	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000404	PowerFuse	WS-1334 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
518426	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000403	PowerFuse	WS-1335 POT	Disconnect Powerfuse Inspection	General Comments	ok	
518427	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000403	PowerFuse	WS-1335 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
518428	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Unknown Operations	0	
518429	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Switching Operations	0	
518430	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Operations Counter AL	178	
518431	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Operations Counter AF	178	
518432	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Maintenance Operations	0	
518433	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	General Comments	ok	
518434	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Patrol Inspection	General Comments	ok	
518435	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Follow-up Action Required?	n	
518436	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Patrol Inspection	Follow-up Action Required?	n	
518437	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Operations Ground	0	
518438	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Operations C Ø	0	
518439	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Operations B Ø	0	
518440	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Operations A Ø	0	
518441	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
518442	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
518443	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
518444	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
518445	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Amps C Ø	72.0	
518446	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Amps B Ø	75.0	
518447	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Amps A Ø	71.0	
518448	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
518449	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
518450	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
518451	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	9 Month Operations	0	
518452	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Follow-up Action Required?	n	
518453	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Patrol Inspection	General Comments	ok	
518454	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	General Comments	open	
518455	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Maintenance Operations	0	
518456	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Unknown Operations	0	
518457	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Switching Operations	0	
518458	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Operations Counter AL	0	
518459	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Operations Counter AF	185	
518460	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
518461	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000410	PowerFuse	WS-1475 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
518462	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000410	PowerFuse	WS-1475 POT	Disconnect Powerfuse Inspection	General Comments	ok	
518463	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	9 Month Operations	2	
518464	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
518465	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
518466	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
518467	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Amps A Ø	625.0	
518468	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Amps B Ø	612.0	
518469	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Amps C Ø	619.0	
518470	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
518471	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
518472	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
518473	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
518474	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Amps C Ø	0.0	
518475	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Amps B Ø	0.0	
518476	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Amps A Ø	0.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
518477	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
518478	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
518479	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
518480	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	9 Month Operations	0	
518481	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
518482	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Patrol Inspection	General Comments	ok	
518483	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	General Comments	ok	
518484	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Maintenance Operations	0	
518485	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Operations Counter AF	106	
518486	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Operations Counter AL	106	
518487	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Switching Operations	0	
518488	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Unknown Operations	0	
518489	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
518490	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
518491	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
518492	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Operations Ground	0	
518493	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
518494	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
518495	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Patrol Inspection	General Comments		
518496	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	General Comments		
518497	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Maintenance Operations	0	
518498	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Operations Counter AF	3	
518499	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Operations Counter AL	3	
518500	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Switching Operations	0	
518501	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Unknown Operations	0	
518502	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	9 Month Operations	0	
518503	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
518504	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
518505	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
518506	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Amps A Ø	0.0	
518507	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Amps B Ø	0.0	
518508	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Amps C Ø	0.0	
518509	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
518510	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
518511	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
518512	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
518513	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	Oil Temp Present	30	°C
518514	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	Oil Temp Max	37	°C
518515	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
518516	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
518517	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
518518	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
518519	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	General Comments	ok	
518520	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	General Comments	ok	
518521	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
518522	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Unknown Operations	0	
518523	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Switching Operations	0	
518524	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Operations Counter AL	169	
518525	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Operations Counter AF	169	
518526	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Maintenance Operations	0	
518527	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	General Comments	open	
518528	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Patrol Inspection	General Comments	ok	
518529	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Follow-up Action Required?	n	
518530	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Patrol Inspection	Follow-up Action Required?	n	
518531	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Operations Ground	0	
518532	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
518533	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
518534	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
518535	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
518536	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
518537	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
518538	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Operations C Ø	0	
518539	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Operations B Ø	0	
518540	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Operations A Ø	0	
518541	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
518542	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
518543	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
518544	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
518545	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Amps C Ø	0.0	
518546	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Amps B Ø	0.0	
518547	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Amps A Ø	0.0	
518548	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	9 Months Operations	1	
518549	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
518550	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
518551	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
518552	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Amps A Ø	100.0	
518553	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Amps B Ø	50.0	
518554	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Amps C Ø	50.0	
518555	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
518556	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
518557	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
518558	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Maintenance Operations	0	
518559	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	General Comments	open	
518560	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Patrol Inspection	General Comments	ok	
518561	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Follow-up Action Required?	n	
518562	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
518563	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
518564	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
518565	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
518566	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
518567	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
518568	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
518569	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
518570	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
518571	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
518572	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
518573	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
518574	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
518575	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
518576	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Patrol Inspection	Follow-up Action Required?	n	
518577	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
518578	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
518579	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
518580	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
518581	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	General Comments		
518582	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
518583	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
518584	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
518585	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
518586	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
518587	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
518588	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	9 Month Operations	0	
518589	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
518590	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
518591	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
518592	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
518593	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
518594	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
518595	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
518596	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	36	°C
518597	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	38	°C
518598	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	36	°C
518599	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	38	°C
518600	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	36	°C
518601	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	38	°C
518602	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
518603	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
518604	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
518605	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
518606	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
518607	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	9 Month Operations	0	
518608	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
518609	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	General Comments		
518610	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	General Comments		
518611	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000394	PowerFuse	WS-1429 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
518612	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000394	PowerFuse	WS-1429 POT	Disconnect Powerfuse Inspection	General Comments	ok	
518613	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
518614	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Maintenance Operations	0	
518615	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000406	PowerFuse	WS-1332 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
518616	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000406	PowerFuse	WS-1332 POT	Disconnect Powerfuse Inspection	General Comments	ok	
518617	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
518618	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
518619	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Amps A Ø	111.0	
518620	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Operations A Ø	0	
518621	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
518622	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
518623	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
518624	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	9 Month Operations	0	
518625	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
518626	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
518627	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
518628	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Amps A Ø	0.0	
518629	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Amps B Ø	0.0	
518630	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Amps C Ø	0.0	
518631	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
518632	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
518633	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
518634	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
518635	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Operations A Ø	0	
518636	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Operations B Ø	0	
518637	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Operations C Ø	0	
518638	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Operations Ground	0	
518639	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Patrol Inspection	Follow-up Action Required?	n	
518640	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Follow-up Action Required?	n	
518641	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Patrol Inspection	Equipment Properly Labeled?	y	
518642	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Amps C Ø	0.0	
518643	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Amps B Ø	0.0	
518644	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Amps A Ø	0.0	
518645	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
518646	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
518647	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
518648	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Patrol Inspection	General Comments		
518649	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	General Comments	open	
518650	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Maintenance Operations	0	
518651	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Operations Counter AF	179	
518652	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	9 Month Operations	0	
518653	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Operations Counter AL	179	
518654	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Switching Operations	0	
518655	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Unknown Operations	0	
518656	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
518657	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
518658	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
518659	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
518660	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
518661	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
518662	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
518663	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	9 Month Operations	4	
518664	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
518665	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
518666	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
518667	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Amps A Ø	0.0	
518668	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Amps B Ø	0.0	
518669	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Amps C Ø	0.0	
518670	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
518671	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
518672	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
518673	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
518674	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations A Ø	0	
518675	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations B Ø	0	
518676	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations C Ø	0	
518677	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations Ground	0	
518678	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Patrol Inspection	Follow-up Action Required?	n	
518679	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Follow-up Action Required?	n	
518680	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Patrol Inspection	General Comments	ok	
518681	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	General Comments	open	
518682	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Maintenance Operations	0	
518683	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Operations Counter AF	49	
518684	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Operations Counter AL	49	
518685	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Switching Operations	0	
518686	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Unknown Operations	0	
518687	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
518688	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
518689	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations A Ø	0	
518690	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations B Ø	0	
518691	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
518692	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
518693	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
518694	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	9 Month Operations	0	
518695	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Oil Temp Max	30	°C
518696	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
518697	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
518698	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Operations Ground	0	
518699	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Operations C Ø	0	
518700	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Operations B Ø	0	
518701	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
518702	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations Ground	0	
518703	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
518704	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Follow-up Action Required?	n	
518705	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Amps B Ø	0.0	
518706	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Amps A Ø	0.0	
518707	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
518708	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
518709	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
518710	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	9 Month Operations	0	
518711	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Amps A Ø	66.0	
518712	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
518713	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
518714	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Amps A Ø	0.0	
518715	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Amps B Ø	0.0	
518716	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Amps C Ø	0.0	
518717	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
518718	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
518719	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
518720	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
518721	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations A Ø	0	
518722	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations B Ø	0	
518723	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations C Ø	0	
518724	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations Ground	0	
518725	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Patrol Inspection	Follow-up Action Required?	n	
518726	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Follow-up Action Required?	n	
518727	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Patrol Inspection	General Comments	ok	
518728	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	General Comments	open	
518729	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Accumulated Fault Duty B Ph V	.90	%
518730	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Accumulated Fault Duty A Ph V	.90	%
518731	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	9 Month Operations	0	
518732	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
518733	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	9 Month Operations	0	
518734	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Maintenance Operations	0	
518735	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Operations Counter AF	149	
518736	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Operations Counter AL	149	
518737	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Switching Operations	0	
518738	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Unknown Operations	0	
518739	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	9 Month Operations	3	
518740	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Accumulated Fault Duty A Ph V	.90	%
518741	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LTCC000231	LTCControl	WS-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
518742	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LTCC000231	LTCControl	WS-TRANS 1	LTC Control Insp	General Comments	ok	
518743	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LTCC000231	LTCControl	WS-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
518744	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Warning Signs OK?	y	
518745	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
518746	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Tank Leaks	None	
518747	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
518748	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
518749	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Grounds in Place?	y	
518750	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	General Comments		
518751	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
518752	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
518753	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Foundation Condition	Good	
518754	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Follow-up Action Required?	n	
518755	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Foundation Condition	Good	
518756	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
518757	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Vegetation	None	
518758	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
518759	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	General Comments		
518760	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
518761	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
518762	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
518763	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
518764	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
518765	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Clear of Trash?	y	
518766	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	General Comments		
518767	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Grounds in Place?	y	
518768	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Heaters (All) Functioning?	y	
518769	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
518770	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
518771	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
518772	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
518773	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
518774	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
518775	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
518776	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
518777	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
518778	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
518779	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
518780	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
518781	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Moisture and Leak Free?	y	
518782	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Tank Paint Condition	Good	
518783	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
518784	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
518785	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
518786	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
518787	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
518788	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Amps C Ø	65.0	
518789	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Operations Ground	0	
518790	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Operations C Ø	0	
518791	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Operations B Ø	0	
518792	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Operations A Ø	0	
518793	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
518794	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
518795	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
518796	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	9 Month Operations	0	
518797	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
518798	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
518799	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
518800	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Amps B Ø	66.0	
518801	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
518802	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Amps C Ø	0.0	
518803	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
518804	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
518805	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
518806	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
518807	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Amps C Ø	0.0	
518808	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Amps B Ø	0.0	
518809	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Amps A Ø	0.0	
518810	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
518811	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
518812	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
518813	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	9 Month Operations	0	
518814	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
518815	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
518816	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Patrol Inspection	General Comments		
518817	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
518818	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
518819	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Percent Thermal Load C Ø Max	-60	%
518820	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
518821	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Percent Thermal Load A Ø Max	-60	%
518822	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
518823	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Unknown Operations	0	
518824	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Switching Operations	0	
518825	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Operations Counter AL	70	
518826	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Operations Counter AF	70	
518827	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Maintenance Operations	0	
518828	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	General Comments	open	
518829	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Patrol Inspection	General Comments		
518830	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Follow-up Action Required?	n	
518831	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Patrol Inspection	Follow-up Action Required?	n	
518832	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Operations Ground	0	
518833	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Operations C Ø	0	
518834	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Operations B Ø	0	
518835	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Operations A Ø	0	
518836	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
518837	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
518838	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
518839	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
518840	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Amps C Ø	0.0	
518841	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Amps B Ø	0.0	
518842	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Amps A Ø	0.0	
518843	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
518844	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
518845	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
518846	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
518847	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
518848	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Unknown Operations	0	
518849	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Switching Operations	0	
518850	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Operations Counter AL	72	
518851	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Operations Counter AF	72	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
518852	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Follow-up Action Required?	n	
518853	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
518854	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
518855	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Capacitor Condition	Good	
518856	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
518857	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
518858	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Bushing Condition	Good	
518859	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	All Connections OK?	y	
518860	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Accumulated Fault Duty B Ph V	.90	%
518861	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Accumulated Fault Duty C Ph V	.90	%
518862	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Amps A Ø	87.0	
518863	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Amps B Ø	88.0	
518864	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Amps C Ø	85.0	
518865	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
518866	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
518867	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
518868	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
518869	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Operations A Ø	0	
518870	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Operations B Ø	0	
518871	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Operations C Ø	0	
518872	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Operations Ground	0	
518873	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Patrol Inspection	Follow-up Action Required?	n	
518874	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Follow-up Action Required?	n	
518875	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Patrol Inspection	General Comments	ok	
518876	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	General Comments	ok	
518877	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Maintenance Operations	0	
518878	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Operations Counter AF	276	
518879	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Operations Counter AL	276	
518880	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Switching Operations	0	
518881	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Unknown Operations	0	
518882	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
518883	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
518884	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
518885	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
518886	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
518887	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
518888	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Unknown Operations	0	
518889	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Switching Operations	0	
518890	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Operations Counter AL	205	
518891	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Operations Counter AF	205	
518892	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Maintenance Operations	0	
518893	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	General Comments	open	
518894	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Patrol Inspection	General Comments	ok	
518895	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Follow-up Action Required?	n	
518896	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Patrol Inspection	Follow-up Action Required?	n	
518897	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Operations Ground	0	
518898	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Operations C Ø	0	
518899	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Operations B Ø	0	
518900	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Operations A Ø	0	
518901	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	General Comments	yard light is out. Need a small bucket truck to replace.	
518902	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
518903	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
518904	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
518905	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
518906	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
518907	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
518908	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Clear of Trash?	y	
518909	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
518910	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Ambient Temp	54	°F
518911	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
518912	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
518913	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
518914	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
518915	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
518916	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
518917	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
518918	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Amps C Ø	0.0	
518919	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Amps B Ø	0.0	
518920	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Amps A Ø	0.0	
518921	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
518922	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
518923	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
518924	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
518925	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
518926	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
518927	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
518928	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
518929	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	9 Month Operations	0	
518930	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
518931	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
518932	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
518933	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
518934	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	General Comments		
518935	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
518936	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
518937	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Operations Counter	111	
518938	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
518939	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
518940	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
518941	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
518942	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
518943	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
518944	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	General Comments	nitrogen bottle 1100 psi	
518945	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
518946	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
518947	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
518948	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
518949	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Operations Counter AF	52	
518950	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Operations Counter AL	52	
518951	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Switching Operations	0	
518952	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Unknown Operations	0	
518953	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Patrol Inspection	Follow-up Action Required?	n	
518954	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Operations Ground	0	
518955	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Operations C Ø	0	
518956	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Operations B Ø	0	
518957	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Operations A Ø	0	
518958	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
518959	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
518960	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	General Comments		
518961	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
518962	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
518963	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
518964	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
518965	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
518966	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
518967	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
518968	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
518969	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
518970	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
518971	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
518972	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
518973	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
518974	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
518975	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
518976	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
518977	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
518978	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
518979	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
518980	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
518981	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
518982	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
518983	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
518984	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	General Comments		
518985	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
518986	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Foundation Condition	Good	
518987	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
518988	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
518989	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
518990	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
518991	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
518992	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
518993	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Vegetation	None	
518994	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
518995	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
518996	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
518997	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
518998	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000415	PowerFuse	WS-FUTURE SOUTH LINE POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
518999	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
519000	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000415	PowerFuse	WS-FUTURE SOUTH LINE POTS	Disconnect Powerfuse Inspection	General Comments	ok	
519001	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
519002	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BCH001150	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
519003	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Switching Operations	0	
519004	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Unknown Operations	0	
519005	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BCH001150	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
519006	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BCH001150	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
519007	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BCH001150	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
519008	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BCH001150	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
519009	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BCH001150	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
519010	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BCH001150	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
519011	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BCH001150	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
519012	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
519013	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
519014	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
519015	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Amps A Ø	0.0	
519016	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Amps B Ø	0.0	
519017	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Amps C Ø	0.0	
519018	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
519019	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
519020	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
519021	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
519022	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Operations A Ø	0	
519023	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Operations B Ø	0	
519024	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Operations C Ø	0	
519025	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Operations Ground	0	
519026	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Patrol Inspection	Follow-up Action Required?	n	
519027	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
519028	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
519029	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
519030	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
519031	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000416	PowerFuse	WS-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
519032	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000416	PowerFuse	WS-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
519033	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	General Comments		
519034	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
519035	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
519036	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
519037	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
519038	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
519039	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
519040	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
519041	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
519042	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	67	°F
519043	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
519044	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
519045	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	9 Month Operations	2	
519046	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Accumulated Fault Duty A Ph V	2.69	%
519047	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
519048	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
519049	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
519050	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
519051	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
519052	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
519053	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
519054	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
519055	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
519056	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
519057	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
519058	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
519059	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
519060	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
519061	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
519062	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
519063	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
519064	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Strip heater in control cabnite not working even after fuse was replaced	
519065	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	General Comments		
519066	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
519067	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
519068	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
519069	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
519070	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
519071	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
519072	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
519073	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	9 Month Operations	0	
519074	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
519075	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
519076	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
519077	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Amps A Ø	0.0	
519078	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Amps B Ø	0.0	
519079	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Amps C Ø	0.0	
519080	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
519081	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
519082	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
519083	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
519084	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Operations A Ø	0	
519085	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Operations B Ø	0	
519086	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Operations C Ø	0	
519087	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Operations Ground	0	
519088	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
519089	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Follow-up Action Required?	n	
519090	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Patrol Inspection	General Comments	ok	
519091	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	General Comments	ok	
519092	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Maintenance Operations	0	
519093	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Operations Counter AF	149	
519094	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Operations Counter AL	149	
519095	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	9 Month Operations	0	
519096	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Follow-up Action Required?	n	
519097	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Patrol Inspection	General Comments	ok	
519098	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	PF000330	PowerFuse	SV-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
519099	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	General Comments	open	
519100	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Maintenance Operations	0	
519101	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Operations Counter AF	107	
519102	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Operations Counter AL	107	
519103	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000392	PowerFuse	WS-14KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
519104	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000392	PowerFuse	WS-14KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
519105	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000393	PowerFuse	WS-FUTURE NORTH LINE POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
519106	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000393	PowerFuse	WS-FUTURE NORTH LINE POTS	Disconnect Powerfuse Inspection	General Comments	ok	
519107	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
519108	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
519109	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
519110	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
519111	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
519112	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
519113	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
519114	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	45	Seconds
519115	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Switching Operations	0	
519116	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Unknown Operations	0	
519117	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000396	PowerFuse	WS-1427 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
519118	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000396	PowerFuse	WS-1427 POT	Disconnect Powerfuse Inspection	General Comments	ok	
519119	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000397	PowerFuse	WS-1426 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
519120	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000397	PowerFuse	WS-1426 POT	Disconnect Powerfuse Inspection	General Comments	ok	
519121	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000398	PowerFuse	WS-1425 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
519122	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	PF000329	PowerFuse	SV-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
519123	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	PF000329	PowerFuse	SV-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
519124	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	PF000328	PowerFuse	SV-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
519125	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	PF000328	PowerFuse	SV-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
519126	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000389	PowerFuse	WS-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
519127	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000389	PowerFuse	WS-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
519128	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000388	PowerFuse	WS-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
519129	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000388	PowerFuse	WS-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
519130	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000386	PowerFuse	WS-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
519131	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000386	PowerFuse	WS-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
519132	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000385	PowerFuse	WS-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
519133	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000385	PowerFuse	WS-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
519134	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Unknown Operations	0	
519135	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Switching Operations	0	
519136	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Operations Counter AL	90	
519137	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Operations Counter AF	90	
519138	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Maintenance Operations	0	
519139	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000398	PowerFuse	WS-1425 POT	Disconnect Powerfuse Inspection	General Comments	ok	
519140	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	General Comments	ok	
519141	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Patrol Inspection	General Comments	ok	
519142	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Follow-up Action Required?	n	
519143	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Patrol Inspection	Follow-up Action Required?	n	
519144	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Operations Ground	0	
519145	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000391	PowerFuse	WS-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
519146	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000391	PowerFuse	WS-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
519147	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Operations Counter AF	60	
519148	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000390	PowerFuse	WS-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
519149	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000390	PowerFuse	WS-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
519150	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Operations Counter AL	60	
519151	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Switching Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
519152	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Unknown Operations	0	
519153	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	9 Month Operations	0	
519154	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
519155	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
519156	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
519157	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Amps A Ø	0.0	
519158	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	PF000330	PowerFuse	SV-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
519159	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	9 Month Operations	0	
519160	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
519161	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
519162	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
519163	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Amps A Ø	0.0	
519164	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Amps B Ø	0.0	
519165	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Amps C Ø	0.0	
519166	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
519167	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
519168	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
519169	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
519170	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Operations A Ø	0	
519171	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Operations B Ø	0	
519172	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Operations C Ø	0	
519173	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Operations Ground	0	
519174	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Patrol Inspection	Follow-up Action Required?	n	
519175	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Follow-up Action Required?	n	
519176	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Patrol Inspection	General Comments		
519177	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	General Comments	ok	
519178	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Maintenance Operations	0	
519179	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Operations Counter AF	89	
519180	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Operations Counter AL	89	
519181	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Amps B Ø	0.0	
519182	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Amps C Ø	0.0	
519183	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
519184	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
519185	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
519186	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
519187	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Switching Operations	0	
519188	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Unknown Operations	0	
519189	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations A Ø	0	
519190	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations B Ø	0	
519191	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations C Ø	0	
519192	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations Ground	0	
519193	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Patrol Inspection	Follow-up Action Required?	n	
519194	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
519195	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
519196	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
519197	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Amps C Ø	83.0	
519198	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Amps B Ø	84.0	
519199	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Amps A Ø	85.0	
519200	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
519201	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Accumulated Fault Duty B Ph V	.90	%
519202	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
519203	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Patrol Inspection	General Comments	ok	
519204	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Follow-up Action Required?	n	
519205	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Patrol Inspection	Follow-up Action Required?	n	
519206	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations Ground	0	
519207	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations C Ø	0	
519208	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations B Ø	0	
519209	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations A Ø	0	
519210	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
519211	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
519212	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
519213	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	9 Month Operations	1	
519214	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	General Comments	open	
519215	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Patrol Inspection	General Comments	ok	
519216	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Follow-up Action Required?	n	
519217	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	9 Month Operations	0	
519218	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
519219	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
519220	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
519221	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Amps A Ø	0.0	
519222	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Amps B Ø	0.0	
519223	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Amps C Ø	0.0	
519224	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
519225	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
519226	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Amps C Ø	0.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
519227	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Amps B Ø	0.0	
519228	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Amps A Ø	0.0	
519229	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
519230	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
519231	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
519232	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
519233	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
519234	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations A Ø	0	
519235	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations B Ø	0	
519236	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations C Ø	0	
519237	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations Ground	0	
519238	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Patrol Inspection	Follow-up Action Required?	n	
519239	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Follow-up Action Required?	n	
519240	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Patrol Inspection	General Comments	ok	
519241	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	General Comments	open	
519242	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Maintenance Operations	0	
519243	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Operations C Ø	0	
519244	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Unknown Operations	0	
519245	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Switching Operations	0	
519246	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Operations Counter AL	149	
519247	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Tank Paint Condition	Good	
519248	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
519249	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Moisture and Leak Free?	y	
519250	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Heaters (All) Functioning?	y	
519251	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Grounds in Place?	y	
519252	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000399	PowerFuse	WS-FUTURE 7-8 LINE POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
519253	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000399	PowerFuse	WS-FUTURE 7-8 LINE POTS	Disconnect Powerfuse Inspection	General Comments	ok	
519254	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000400	PowerFuse	WS-FUTURE 5-6 LINE POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
519255	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000400	PowerFuse	WS-FUTURE 5-6 LINE POTS	Disconnect Powerfuse Inspection	General Comments	ok	
519256	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000401	PowerFuse	WS-1337 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
519257	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000401	PowerFuse	WS-1337 POT	Disconnect Powerfuse Inspection	General Comments	ok	
519258	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000402	PowerFuse	WS-1336 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
519259	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000402	PowerFuse	WS-1336 POT	Disconnect Powerfuse Inspection	General Comments	ok	
519260	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Maintenance Operations	0	
519261	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	General Comments	open	
519262	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
519263	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	General Comments		
519264	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
519265	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
519266	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
519267	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
519268	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
519269	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
519270	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
519271	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
519272	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
519273	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
519274	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
519275	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
519276	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
519277	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	General Comments		
519278	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Foundation Condition	Good	
519279	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Follow-up Action Required?	n	
519280	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Equipment Properly Labeled?	y	
519281	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Paint Condition	Good	
519282	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
519283	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
519284	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
519285	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Bushings Connection/Risers	Good	
519286	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Bushing Condition	Good	
519287	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Operations Counter AF	149	
519288	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Maintenance Operations	0	
519289	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Operations B Ø	0	
519290	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Operations A Ø	0	
519291	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
519292	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
519293	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
519294	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
519295	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
519296	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
519297	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
519298	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
519299	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
519300	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	bottle= o psi bottle needs nitrogen	
519301	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
519302	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
519303	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
519304	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
519305	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
519306	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	9 Month Operations	0	
519307	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
519308	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
519309	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Amps C Ø	144.0	
519310	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Amps B Ø	142.0	
519311	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Amps A Ø	145.0	
519312	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
519313	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
519314	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
519315	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	9 Month Operations	1	
519316	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
519317	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Tank Leaks	None	
519318	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Tank Paint Condition	Good	
519319	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	106	
519320	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	32	°C
519321	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Min Tap Position	4L	
519322	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
519323	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Current Tap Position	2L	
519324	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
519325	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Unknown Operations	0	
519326	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Switching Operations	0	
519327	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Operations Counter AL	80	
519328	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Operations Counter AF	80	
519329	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
519330	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
519331	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Maintenance Operations	0	
519332	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	General Comments	open	
519333	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Patrol Inspection	General Comments		
519334	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Follow-up Action Required?	n	
519335	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
519336	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Regulator As Left Counter	40862	
519337	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
519338	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Patrol Inspection	Follow-up Action Required?	n	
519339	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
519340	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
519341	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Tank Leaks	None	
519342	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
519343	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Regulator As Left Counter	47461	
519344	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Bushing Condition	Good	
519345	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Bushings Connection/Risers	Good	
519346	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
519347	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
519348	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
519349	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
519350	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
519351	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
519352	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
519353	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.4	volts
519354	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Paint Condition	Good	
519355	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Operations Counter AF	222	
519356	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Operations Counter AL	222	
519357	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Switching Operations	0	
519358	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Equipment Properly Labeled?	y	
519359	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Follow-up Action Required?	n	
519360	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
519361	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
519362	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
519363	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
519364	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
519365	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
519366	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	General Comments	ok	
519367	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Maintenance Operations	0	
519368	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Foundation Condition	Good	
519369	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	General Comments		
519370	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Grounds in Place?	y	
519371	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Heaters (All) Functioning?	y	
519372	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Operations Counter AF	140	
519373	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Operations Counter AL	140	
519374	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Switching Operations	0	
519375	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Unknown Operations	0	
519376	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
519377	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
519378	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	General Comments		
519379	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
519380	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Unknown Operations	0	
519381	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Operations A Ø	0	
519382	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
519383	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
519384	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
519385	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
519386	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
519387	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
519388	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
519389	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
519390	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	PF000327	PowerFuse	SV-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
519391	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	PF000327	PowerFuse	SV-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
519392	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
519393	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
519394	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
519395	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
519396	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
519397	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
519398	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
519399	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
519400	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
519401	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
519402	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
519403	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	General Comments	ok	
519404	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	General Comments	ok	
519405	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
519406	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
519407	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
519408	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1700	psi
519409	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	Oil Temp Max	38	°C
519410	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
519411	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
519412	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
519413	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
519414	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
519415	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
519416	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
519417	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
519418	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
519419	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
519420	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
519421	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
519422	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Percent Thermal Load C Ø Max	30	%
519423	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	45	%
519424	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
519425	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
519426	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	General Comments		
519427	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
519428	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
519429	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
519430	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	39	°C
519431	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	37	°C
519432	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	39	°C
519433	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	37	°C
519434	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	39	°C
519435	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	37	°C
519436	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Comments	ok	
519437	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Equipment Properly Labeled?	y	
519438	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Follow-up Action Required?	n	
519439	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
519440	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
519441	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Amps A Ø	80.0	
519442	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Amps B Ø	79.0	
519443	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Amps C Ø	80.0	
519444	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
519445	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
519446	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
519447	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
519448	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Operations A Ø	0	
519449	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Operations B Ø	0	
519450	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Operations C Ø	0	
519451	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
519452	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Patrol Inspection	Follow-up Action Required?	n	
519453	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Follow-up Action Required?	n	
519454	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
519455	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
519456	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
519457	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	General Comments		
519458	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
519459	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	9 Month Operations	0	
519460	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
519461	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
519462	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
519463	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
519464	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Ambient Temp	60	°F
519465	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
519466	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
519467	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
519468	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
519469	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
519470	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
519471	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
519472	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
519473	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
519474	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
519475	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
519476	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
519477	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000387	PowerFuse	WS-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
519478	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Amps A Ø	0.0	
519479	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Amps B Ø	0.0	
519480	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Amps C Ø	0.0	
519481	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
519482	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
519483	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
519484	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
519485	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Operations A Ø	0	
519486	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Operations B Ø	0	
519487	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000387	PowerFuse	WS-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
519488	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	32	°C
519489	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	137	
519490	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
519491	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
519492	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
519493	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.2640	
519494	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
519495	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
519496	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	n	
519497	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
519498	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
519499	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
519500	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Bad	
519501	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
519502	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
519503	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Oil Temp Present	36	°C
519504	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
519505	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
519506	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
519507	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
519508	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
519509	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
519510	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Operations A Ø	0	
519511	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Operations B Ø	0	
519512	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Operations C Ø	0	
519513	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Operations Ground	0	
519514	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Patrol Inspection	Follow-up Action Required?	n	
519515	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Follow-up Action Required?	n	
519516	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
519517	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
519518	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
519519	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
519520	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	205.00	
519521	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6067.20	kw
519522	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
519523	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
519524	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
519525	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	General Comments		
519526	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	9 Month Operations	7	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
519527	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
519528	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Accumulated Fault Duty B Ph V	.90	%
519529	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
519530	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Amps A Ø	51.0	
519531	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Amps B Ø	48.0	
519532	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Amps C Ø	48.0	
519533	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
519534	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
519535	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
519536	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
519537	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Accumulated Fault Duty B Ph V	.90	%
519538	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000417	PowerFuse	WS-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
519539	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000417	PowerFuse	WS-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
519540	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
519541	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
519542	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Patrol Inspection	Follow-up Action Required?	n	
519543	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Patrol Inspection	General Comments		
519544	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	9 Month Operations	0	
519545	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LTCC000577	LTCControl	SV-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
519546	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LTCC000577	LTCControl	SV-TRANS 2	LTC Control Insp	General Comments		
519547	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LTCC000577	LTCControl	SV-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
519548	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Unknown Operations	1	
519549	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Switching Operations	0	
519550	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Operations Counter AL	164	
519551	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Operations Counter AF	164	
519552	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Maintenance Operations	0	
519553	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Patrol Inspection	General Comments	ok	
519554	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	General Comments	fault x	
519555	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Follow-up Action Required?	n	
519556	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Patrol Inspection	Follow-up Action Required?	n	
519557	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Operations Ground	0	
519558	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Operations C Ø	0	
519559	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Operations B Ø	0	
519560	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Operations A Ø	0	
519561	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Adjusted Amps C Phase V	34.02	
519562	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Adjusted Amps B Phase V	34.02	
519563	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Adjusted Amps A Phase V	34.02	
519564	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
519565	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Amps C Ø	77.0	
519566	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Amps B Ø	77.0	
519567	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Amps A Ø	78.0	
519568	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Accumulated Fault Duty C Ph V	.90	%
519569	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Accumulated Fault Duty B Ph V	.90	%
519570	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Accumulated Fault Duty A Ph V	.90	%
519571	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	9 Month Operations	3	
519572	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Accumulated Fault Duty C Ph V	.90	%
519573	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Amps A Ø	70.0	
519574	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Amps B Ø	69.0	
519575	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Amps C Ø	68.0	
519576	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
519577	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
519578	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
519579	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	General Comments	ok	
519580	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	General Comments	ok	
519581	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC As Found Counter	24052	
519582	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC As Left Counter	24052	
519583	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Current Tap Position	2L	
519584	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Max Tap Position	Neutral	
519585	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Min Tap Position	3L	
519586	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Patrol Inspection	Follow-up Action Required?	n	
519587	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Follow-up Action Required?	n	
519588	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Patrol Inspection	General Comments	ok	
519589	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	General Comments	open	
519590	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Maintenance Operations	0	
519591	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Operations Counter AF	71	
519592	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Operations Counter AL	71	
519593	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Switching Operations	0	
519594	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Unknown Operations	0	
519595	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	General Comments		
519596	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
519597	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Vegetation	None	
519598	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
519599	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
519600	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
519601	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
519602	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
519603	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
519604	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
519605	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
519606	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
519607	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
519608	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
519609	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
519610	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
519611	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
519612	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
519613	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations C Ø	0	
519614	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations Ground	0	
519615	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Patrol Inspection	Follow-up Action Required?	n	
519616	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Follow-up Action Required?	n	
519617	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Patrol Inspection	General Comments	ok	
519618	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	General Comments	ok	
519619	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Maintenance Operations	0	
519620	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
519621	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
519622	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
519623	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	General Comments		
519624	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
519625	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
519626	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
519627	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
519628	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
519629	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
519630	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Clear of Trash?	y	
519631	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
519632	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
519633	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Patrol Inspection	General Comments	ok	
519634	3/14/2019 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
519635	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations A Ø	0	
519636	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations B Ø	0	
519637	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Follow-up Action Required?	n	
519638	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Patrol Inspection	General Comments	ok	
519639	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
519640	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
519641	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
519642	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
519643	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Unknown Operations	0	
519644	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Switching Operations	0	
519645	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Operations Counter AL	95	
519646	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Operations Counter AF	95	
519647	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
519648	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	17.50	
519649	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.3	psi
519650	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	General Comments		
519651	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
519652	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
519653	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
519654	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Maintenance Operations	0	
519655	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	General Comments	ok	
519656	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Patrol Inspection	General Comments		
519657	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Follow-up Action Required?	n	
519658	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Patrol Inspection	Follow-up Action Required?	n	
519659	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
519660	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	General Comments	ok	
519661	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Operations Ground	0	
519662	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Operations C Ø	0	
519663	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Operations B Ø	0	
519664	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	9 Month Operations	0	
519665	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
519666	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
519667	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
519668	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Amps A Ø	0.0	
519669	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Amps B Ø	0.0	
519670	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Amps C Ø	0.0	
519671	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
519672	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
519673	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
519674	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
519675	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations A Ø	0	
519676	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
519677	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations C Ø	0	
519678	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Maintenance Operations	0	
519679	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Operations Counter AF	86	
519680	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Operations Counter AL	86	
519681	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Switching Operations	0	
519682	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Unknown Operations	0	
519683	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations Ground	0	
519684	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
519685	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
519686	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
519687	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
519688	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Unknown Operations	0	
519689	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Tank Paint Condition	Good	
519690	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Switching Operations	0	
519691	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
519692	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Operations Counter AL	176	
519693	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Operations Counter AF	176	
519694	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Moisture and Leak Free?	y	
519695	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Maintenance Operations	0	
519696	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Grounds in Place?	y	
519697	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
519698	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
519699	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
519700	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
519701	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	General Comments		
519702	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
519703	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
519704	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
519705	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
519706	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
519707	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
519708	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
519709	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
519710	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
519711	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
519712	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
519713	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
519714	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
519715	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
519716	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
519717	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	General Comments		
519718	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
519719	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
519720	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	General Comments		
519721	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	General Comments		
519722	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Foundation Condition	Good	
519723	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Follow-up Action Required?	n	
519724	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Follow-up Action Required?	n	
519725	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations Ground	0	
519726	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations C Ø	0	
519727	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations B Ø	0	
519728	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	Follow-up Action Required?	n	
519729	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
519730	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Unknown Operations	0	
519731	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations A Ø	0	
519732	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
519733	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
519734	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
519735	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Equipment Properly Labeled?	y	
519736	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Paint Condition	Good	
519737	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
519738	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
519739	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
519740	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
519741	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
519742	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Tank Leaks	None	
519743	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
519744	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
519745	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Regulator As Left Counter	29396	
519746	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
519747	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Bushings Connection/Risers	Good	
519748	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Bushing Condition	Good	
519749	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Amps C Ø	12.0	
519750	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Amps B Ø	12.0	
519751	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Amps A Ø	12.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
519752	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.4	volts
519753	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
519754	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
519755	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
519756	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
519757	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Operations Counter AL	234	
519758	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
519759	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
519760	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Operations Counter AF	234	
519761	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
519762	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
519763	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
519764	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
519765	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
519766	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
519767	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
519768	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
519769	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
519770	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
519771	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
519772	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	9 Month Operations	0	
519773	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
519774	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
519775	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
519776	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Amps A Ø	0.0	
519777	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Amps B Ø	0.0	
519778	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Amps C Ø	0.0	
519779	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
519780	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
519781	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Patrol Inspection	Follow-up Action Required?	n	
519782	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
519783	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
519784	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Operations A Ø	0	
519785	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Operations B Ø	0	
519786	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
519787	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
519788	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
519789	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
519790	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	27	
519791	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
519792	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
519793	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Current Tap Position	4L	
519794	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
519795	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC As Left Counter	220399	
519796	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC As Found Counter	220399	
519797	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
519798	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	General Comments		
519799	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
519800	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
519801	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
519802	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Amps A Ø	14.0	
519803	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Amps B Ø	15.0	
519804	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Amps C Ø	15.0	
519805	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
519806	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
519807	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
519808	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
519809	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Operations A Ø	0	
519810	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Operations B Ø	0	
519811	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Operations C Ø	0	
519812	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Operations Ground	0	
519813	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Patrol Inspection	Follow-up Action Required?	n	
519814	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Follow-up Action Required?	n	
519815	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Patrol Inspection	General Comments	ok	
519816	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	General Comments	ok	
519817	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Maintenance Operations	0	
519818	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Operations Counter AF	178	
519819	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Operations Counter AL	178	
519820	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Switching Operations	0	
519821	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Unknown Operations	0	
519822	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
519823	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Tank Leaks	None	
519824	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
519825	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
519826	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Regulator As Left Counter	36251	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
519827	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
519828	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
519829	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
519830	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
519831	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	General Comments		
519832	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	General Comments		
519833	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Foundation Condition	Good	
519834	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Follow-up Action Required?	n	
519835	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Unknown Operations	0	
519836	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Follow-up Action Required?	n	
519837	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations Ground	0	
519838	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations C Ø	0	
519839	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Switching Operations	0	
519840	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Operations Counter AL	143	
519841	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations B Ø	1	
519842	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Operations Counter AF	143	
519843	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Maintenance Operations	0	
519844	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	General Comments	open	
519845	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Patrol Inspection	General Comments		
519846	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations A Ø	1	
519847	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
519848	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Adjusted Amps B Phase V	3.95	
519849	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Adjusted Amps A Phase V	3.95	
519850	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Equipment Properly Labeled?	y	
519851	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Operations Ground	0	
519852	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Cabinet Paint Condition	Good	
519853	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
519854	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
519855	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
519856	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Bushings Connection/Risers	Good	
519857	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Bushing Condition	Good	
519858	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Amps C Ø	94.0	
519859	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Amps B Ø	92.0	
519860	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Amps A Ø	93.0	
519861	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
519862	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Accumulated Fault Duty B Ph V	.29	%
519863	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Accumulated Fault Duty A Ph V	.29	%
519864	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	9 Month Operations	6	
519865	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Follow-up Action Required?	n	
519866	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Patrol Inspection	General Comments	ok	
519867	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	General Comments	ok	
519868	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Maintenance Operations	0	
519869	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Operations Counter AF	182	
519870	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Operations Counter AL	182	
519871	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Switching Operations	0	
519872	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Unknown Operations	0	
519873	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC As Found Counter	416688	
519874	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
519875	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	General Comments		
519876	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
519877	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
519878	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	9 Month Operations	0	
519879	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Patrol Inspection	Follow-up Action Required?	n	
519880	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Follow-up Action Required?	n	
519881	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
519882	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
519883	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Patrol Inspection	General Comments	ok	
519884	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
519885	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
519886	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
519887	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
519888	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
519889	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
519890	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
519891	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
519892	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations B Ø	0	
519893	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations A Ø	0	
519894	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	General Comments	open	
519895	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Follow-up Action Required?	n	
519896	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Tank Paint Condition	Good	
519897	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
519898	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Moisture and Leak Free?	y	
519899	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Heaters (All) Functioning?	y	
519900	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Grounds in Place?	y	
519901	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
519902	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Foundation Condition	Good	
519903	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Follow-up Action Required?	n	
519904	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	0	
519905	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
519906	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
519907	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
519908	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
519909	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
519910	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
519911	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
519912	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	General Comments		
519913	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
519914	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
519915	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
519916	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
519917	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
519918	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
519919	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
519920	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
519921	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
519922	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
519923	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
519924	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
519925	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
519926	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
519927	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
519928	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
519929	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Operations B Ø	0	
519930	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Operations C Ø	0	
519931	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Accumulated Fault Duty C Ph V	1.90	%
519932	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Accumulated Fault Duty B Ph V	1.90	%
519933	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Switching Operations	0	
519934	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Operations Counter AL	128	
519935	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Operations Counter AF	128	
519936	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Maintenance Operations	0	
519937	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
519938	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
519939	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
519940	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Operations A Ø	0	
519941	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Operations B Ø	0	
519942	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Operations C Ø	0	
519943	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	General Comments	ok	
519944	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Patrol Inspection	General Comments	ok	
519945	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Follow-up Action Required?	n	
519946	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Patrol Inspection	Follow-up Action Required?	n	
519947	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations Ground	0	
519948	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations C Ø	0	
519949	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Operations Ground	0	
519950	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Patrol Inspection	Follow-up Action Required?	n	
519951	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Accumulated Fault Duty A Ph V	1.90	%
519952	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	9 Month Operations	4	
519953	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Operations C Ø	0	
519954	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Operations Ground	0	
519955	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Follow-up Action Required?	n	
519956	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Patrol Inspection	Follow-up Action Required?	n	
519957	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Patrol Inspection	General Comments	ok	
519958	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	General Comments	ok	
519959	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Maintenance Operations	0	
519960	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Operations Counter AF	107	
519961	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Operations Counter AL	107	
519962	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Switching Operations	0	
519963	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Unknown Operations	0	
519964	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
519965	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	4L	
519966	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
519967	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
519968	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
519969	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC As Left Counter	416488	
519970	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Unknown Operations	0	
519971	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Tank Paint Condition	Good	
519972	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Switching Operations	0	
519973	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Operations Counter AL	157	
519974	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Operations Counter AF	157	
519975	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Moisture and Leak Free?	y	
519976	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
519977	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Grounds in Place?	y	
519978	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
519979	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
519980	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
519981	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
519982	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
519983	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
519984	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
519985	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC As Left Counter	82911	
519986	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC As Found Counter	82911	
519987	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
519988	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	General Comments		
519989	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
519990	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
519991	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	All Connections OK?	y	
519992	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Bushing Condition	Good	
519993	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
519994	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
519995	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Capacitor Condition	Good	
519996	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
519997	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Unknown Operations	0	
519998	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
519999	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Follow-up Action Required?	n	
520000	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Foundation Condition	Good	
520001	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	9 Month Operations	0	
520002	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
520003	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
520004	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
520005	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Amps A Ø	0.0	
520006	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Switching Operations	0	
520007	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Operations Counter AL	207	
520008	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Operations Counter AF	207	
520009	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Maintenance Operations	0	
520010	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	General Comments	open	
520011	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Patrol Inspection	General Comments	ok	
520012	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Follow-up Action Required?	n	
520013	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Patrol Inspection	Follow-up Action Required?	n	
520014	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Operations Ground	0	
520015	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Operations C Ø	0	
520016	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
520017	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
520018	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Amps A Ø	0.0	
520019	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Amps B Ø	0.0	
520020	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Amps C Ø	0.0	
520021	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
520022	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
520023	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
520024	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
520025	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Operations A Ø	0	
520026	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Amps B Ø	0.0	
520027	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Amps C Ø	0.0	
520028	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Overall Condition	Good	
520029	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
520030	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
520031	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Follow-up Action Required?	n	
520032	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	General Comments		
520033	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Overall Condition	Good	
520034	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
520035	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
520036	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Follow-up Action Required?	y	
520037	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	General Comments	low volage input and output on battery charger	
520038	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Unknown Operations	0	
520039	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Operations B Ø	0	
520040	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Switching Operations	0	
520041	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Operations Counter AL	95	
520042	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Operations Counter AF	95	
520043	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Maintenance Operations	0	
520044	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	General Comments	open	
520045	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Patrol Inspection	General Comments	ok	
520046	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Operations A Ø	0	
520047	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
520048	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
520049	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
520050	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Amps A Ø	96.0	
520051	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
520052	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
520053	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
520054	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	165	
520055	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
520056	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
520057	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
520058	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
520059	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
520060	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Operations A Ø	0	
520061	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Operations B Ø	0	
520062	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Operations C Ø	0	
520063	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Operations Ground	0	
520064	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Patrol Inspection	Follow-up Action Required?	n	
520065	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Follow-up Action Required?	n	
520066	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Patrol Inspection	General Comments	ok	
520067	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	General Comments	open	
520068	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Maintenance Operations	0	
520069	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Operations Counter AF	49	
520070	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Operations Counter AL	49	
520071	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Switching Operations	0	
520072	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Unknown Operations	0	
520073	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	All Connections OK?	y	
520074	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Bushing Condition	Good	
520075	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
520076	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
520077	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Condition	Good	
520078	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
520079	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
520080	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Follow-up Action Required?	n	
520081	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Foundation Condition	Good	
520082	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
520083	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
520084	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
520085	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Amps C Ø	0.0	
520086	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Amps B Ø	0.0	
520087	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Amps A Ø	0.0	
520088	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
520089	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
520090	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	General Comments		
520091	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Grounds in Place?	y	
520092	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
520093	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
520094	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
520095	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
520096	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	9 Month Operations	0	
520097	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
520098	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Tank Leaks	None	
520099	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
520100	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Warning Signs OK?	y	
520101	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.510	millivolts
520102	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
520103	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
520104	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
520105	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
520106	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
520107	3/14/2019 15:05	Distribution	Whitley City Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	General Comments		
520108	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
520109	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	9 Month Operations	3	
520110	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
520111	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	LTC oil is high	
520112	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	General Comments	ok	
520113	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC As Found Counter	21616	
520114	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC As Left Counter	21616	
520115	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
520116	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	9 Month Operations	0	
520117	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Current Tap Position	2L	
520118	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
520119	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Min Tap Position	3L	
520120	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	31	°C
520121	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	130	
520122	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
520123	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
520124	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
520125	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
520126	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
520127	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	General Comments		
520128	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
520129	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
520130	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
520131	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
520132	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
520133	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	9 Month Operations	0	
520134	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Accumulated Fault Duty B Ph V	.90	%
520135	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Unknown Operations	0	
520136	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000395	PowerFuse	WS-1428 POT	Disconnect Powerfuse Inspection	General Comments	ok	
520137	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	PF000395	PowerFuse	WS-1428 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
520138	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
520139	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Accumulated Fault Duty A Ph V	.90	%
520140	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	9 Month Operations	0	
520141	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
520142	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
520143	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	General Comments		
520144	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Grounds in Place?	y	
520145	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
520146	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
520147	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Tank Leaks	None	
520148	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
520149	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Warning Signs OK?	y	
520150	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
520151	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Amps A Ø	115.0	
520152	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	9 Months Operations	0	
520153	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Amps B Ø	112.0	
520154	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Amps C Ø	115.0	
520155	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
520156	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Operations A Ø	0	
520157	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Operations B Ø	0	
520158	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Operations C Ø	0	
520159	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Operations Ground	0	
520160	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Patrol Inspection	Follow-up Action Required?	n	
520161	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Follow-up Action Required?	n	
520162	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Patrol Inspection	General Comments		
520163	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	General Comments	open	
520164	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Maintenance Operations	0	
520165	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	9 Month Operations	0	
520166	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
520167	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
520168	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
520169	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
520170	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Amps A Ø	0.0	
520171	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Amps B Ø	0.0	
520172	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Amps C Ø	0.0	
520173	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
520174	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
520175	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
520176	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
520177	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations A Ø	0	
520178	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations B Ø	0	
520179	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations C Ø	0	
520180	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations Ground	0	
520181	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
520182	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Follow-up Action Required?	n	
520183	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	General Comments		
520184	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	General Comments		
520185	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
520186	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Maintenance Operations	0	
520187	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Operations Counter AF	197	
520188	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Operations Counter AL	197	
520189	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Switching Operations	0	
520190	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Unknown Operations	0	
520191	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
520192	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Patrol Inspection	General Comments		
520193	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
520194	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	General Comments		
520195	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
520196	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
520197	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Switching Operations	0	
520198	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Amps B Ø	94.0	
520199	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
520200	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
520201	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Amps C Ø	0.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
520202	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Amps B Ø	0.0	
520203	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Amps A Ø	0.0	
520204	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Accumulated Fault Duty C Ph V	9.65	%
520205	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Accumulated Fault Duty B Ph V	7.72	%
520206	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Accumulated Fault Duty A Ph V	7.72	%
520207	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Amps C Ø	95.0	
520208	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	9 Month Operations	0	
520209	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
520210	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Follow-up Action Required?	n	
520211	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Patrol Inspection	Follow-up Action Required?	n	
520212	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Operations Ground	0	
520213	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Operations C Ø	0	
520214	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Operations B Ø	0	
520215	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Operations A Ø	0	
520216	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
520217	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
520218	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
520219	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
520220	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
520221	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
520222	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
520223	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Foundation Condition	Good	
520224	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
520225	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
520226	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Amps C Ø	0.0	
520227	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	9 Month Operations	0	
520228	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Amps B Ø	0.0	
520229	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Amps A Ø	0.0	
520230	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Accumulated Fault Duty C Ph V	.90	%
520231	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
520232	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
520233	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
520234	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Amps A Ø	0.0	
520235	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
520236	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
520237	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
520238	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
520239	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Operations A Ø	0	
520240	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Operations B Ø	0	
520241	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Operations C Ø	0	
520242	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Operations Ground	0	
520243	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Patrol Inspection	Follow-up Action Required?	n	
520244	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Amps B Ø	0.0	
520245	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Follow-up Action Required?	n	
520246	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Patrol Inspection	General Comments	ok	
520247	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	General Comments	ok	
520248	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Maintenance Operations	0	
520249	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Operations Counter AF	93	
520250	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Operations Counter AL	93	
520251	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Switching Operations	0	
520252	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
520253	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
520254	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
520255	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
520256	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations A Ø	0	
520257	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations B Ø	0	
520258	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations C Ø	0	
520259	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations Ground	0	
520260	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Patrol Inspection	Follow-up Action Required?	n	
520261	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Follow-up Action Required?	n	
520262	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Patrol Inspection	General Comments	ok	
520263	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	General Comments	open	
520264	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Maintenance Operations	0	
520265	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Operations Counter AF	145	
520266	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Operations Counter AL	145	
520267	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Switching Operations	0	
520268	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Unknown Operations	0	
520269	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Amps C Ø	0.0	
520270	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Unknown Operations	0	
520271	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
520272	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Maintenance Operations	0	
520273	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
520274	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
520275	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	LTCC000502	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	45	Seconds
520276	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
520277	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
520278	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
520279	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
520280	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
520281	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
520282	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	General Comments	Valve going into tank isnt closing all the way, has a small leak	
520283	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC As Found Counter	253504	
520284	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC As Left Counter	253515	
520285	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
520286	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Patrol Inspection	Follow-up Action Required?	n	
520287	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Operations Ground	0	
520288	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Operations C Ø	0	
520289	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Operations B Ø	0	
520290	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Operations A Ø	0	
520291	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Current Tap Position	6L	
520292	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Max Tap Position	1L	
520293	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
520294	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
520295	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Min Tap Position	12L	
520296	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
520297	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
520298	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Operations Since Last Insp	1013	
520299	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
520300	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
520301	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	General Comments	ok	
520302	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Patrol Inspection	General Comments	ok	
520303	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Follow-up Action Required?	n	
520304	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
520305	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Amps C Ø	104.0	
520306	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Amps B Ø	106.0	
520307	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Amps A Ø	106.0	
520308	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations Ground	0	
520309	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations C Ø	0	
520310	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
520311	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
520312	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
520313	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
520314	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
520315	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	LTCC000502	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
520316	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
520317	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
520318	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	LTCC000502	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
520319	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	LTCC000502	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
520320	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	LTCC000502	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
520321	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations B Ø	0	
520322	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
520323	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
520324	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
520325	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
520326	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	General Comments		
520327	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
520328	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
520329	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Operations Counter AL	170	
520330	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Operations Counter AF	170	
520331	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
520332	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
520333	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
520334	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
520335	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	9 Month Operations	2	
520336	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
520337	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
520338	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Patrol Inspection	General Comments		
520339	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
520340	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
520341	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
520342	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
520343	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
520344	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
520345	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
520346	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
520347	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
520348	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
520349	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
520350	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
520351	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
520352	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Unknown Operations	0	
520353	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Switching Operations	0	
520354	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Operations Counter AL	101	
520355	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Operations Counter AF	101	
520356	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
520357	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
520358	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
520359	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
520360	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Maintenance Operations	0	
520361	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	General Comments	ok	
520362	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Patrol Inspection	General Comments	ok	
520363	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Follow-up Action Required?	n	
520364	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
520365	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
520366	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
520367	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
520368	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Unknown Operations	0	
520369	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Switching Operations	0	
520370	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Operations Counter AL	69	
520371	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Operations Counter AF	69	
520372	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Operations Counter AL	563	
520373	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Operations Counter AF	563	
520374	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Patrol Inspection	Follow-up Action Required?	n	
520375	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Follow-up Action Required?	n	
520376	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Patrol Inspection	General Comments	ok	
520377	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	General Comments	open	
520378	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Maintenance Operations	0	
520379	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
520380	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
520381	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
520382	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Clear of Trash?	y	
520383	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
520384	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	LTCC000502	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
520385	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	LTCC000502	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
520386	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	LTCC000502	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
520387	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LTCC000482	LTCControl	SV-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
520388	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
520389	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Maintenance Operations	0	
520390	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
520391	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations C Ø	0	
520392	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	General Comments		
520393	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	General Comments		
520394	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Follow-up Action Required?	n	
520395	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
520396	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
520397	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Operations Counter AF	191	
520398	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Operations Counter AL	191	
520399	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Switching Operations	0	
520400	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
520401	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
520402	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Unknown Operations	0	
520403	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
520404	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
520405	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations Ground	0	
520406	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
520407	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
520408	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
520409	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
520410	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
520411	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
520412	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	General Comments		
520413	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
520414	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
520415	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Vegetation	None	
520416	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
520417	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
520418	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
520419	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
520420	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LTCC000482	LTCControl	SV-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
520421	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LTCC000482	LTCControl	SV-TRANS 1	LTC Control Insp	General Comments		
520422	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations A Ø	0	
520423	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
520424	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
520425	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
520426	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
520427	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Amps C Ø	0.0	
520428	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
520429	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
520430	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Amps B Ø	0.0	
520431	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
520432	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Amps A Ø	0.0	
520433	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
520434	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
520435	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
520436	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	9 Month Operations	0	
520437	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
520438	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	General Comments	ok	
520439	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
520440	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
520441	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
520442	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
520443	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Accumulated Fault Duty B Ph V	28.94	%
520444	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Accumulated Fault Duty C Ph V	28.94	%
520445	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Amps A Ø	0.0	
520446	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Amps B Ø	0.0	
520447	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Amps C Ø	0.0	
520448	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
520449	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
520450	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
520451	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
520452	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Operations A Ø	0	
520453	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
520454	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
520455	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
520456	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations A Ø	0	
520457	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations B Ø	0	
520458	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
520459	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
520460	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Operations A Ø	0	
520461	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Operations B Ø	0	
520462	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
520463	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
520464	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
520465	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
520466	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
520467	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
520468	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Operations C Ø	0	
520469	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Operations Ground	0	
520470	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
520471	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Unknown Operations	0	
520472	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Switching Operations	0	
520473	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Operations Ground	0	
520474	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Operations Counter AF	78	
520475	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Operations Counter AF	158	
520476	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Maintenance Operations	0	
520477	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	39	°C
520478	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	43	°C
520479	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	39	°C
520480	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.600	millivolts
520481	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	27.6	VDC
520482	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	27.6	VDC
520483	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
520484	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
520485	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
520486	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Operations Counter AL	78	
520487	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Switching Operations	0	
520488	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Unknown Operations	0	
520489	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BCH001168	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.620	millivolts
520490	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BCH001168	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
520491	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BCH001168	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
520492	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BCH001168	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
520493	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
520494	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
520495	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	General Comments	ok	
520496	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	General Comments	ok	
520497	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC As Found Counter	24128	
520498	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC As Left Counter	24128	
520499	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	9 Month Operations	0	
520500	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Accumulated Fault Duty A Ph V	7.72	%
520501	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
520502	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
520503	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
520504	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
520505	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	General Comments	ok	
520506	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
520507	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Accumulated Fault Duty B Ph V	7.72	%
520508	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
520509	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BCH001168	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
520510	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BCH001168	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
520511	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
520512	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
520513	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	BCH001168	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
520514	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	General Comments		
520515	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
520516	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
520517	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
520518	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
520519	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
520520	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
520521	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Equipment Properly Labeled?	y	
520522	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Paint Condition	Good	
520523	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
520524	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	General Comments		
520525	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
520526	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
520527	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
520528	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
520529	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Bushings Connection/Risers	Good	
520530	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Bushing Condition	Good	
520531	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	9 Months Operations	30	
520532	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
520533	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Accumulated Fault Duty B Ph AM	10.67	%
520534	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Accumulated Fault Duty C Ph AM	10.67	%
520535	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Amps A Ø	160.0	
520536	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
520537	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
520538	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	9 Month Operations	0	
520539	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Accumulated Fault Duty A Ph V	28.94	%
520540	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Amps B Ø	109.0	
520541	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Amps C Ø	108.0	
520542	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
520543	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	9 Month Operations	0	
520544	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
520545	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
520546	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
520547	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
520548	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
520549	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
520550	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Operations A Ø	0	
520551	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Operations B Ø	0	
520552	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Amps A Ø	0.0	
520553	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Operations C Ø	0	
520554	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Amps B Ø	0.0	
520555	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Amps C Ø	0.0	
520556	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
520557	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Operations Ground	0	
520558	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Patrol Inspection	Follow-up Action Required?	n	
520559	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Follow-up Action Required?	n	
520560	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Patrol Inspection	General Comments	ok	
520561	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	General Comments	ok	
520562	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Maintenance Operations	0	
520563	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
520564	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
520565	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
520566	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Operations A Ø	0	
520567	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Operations B Ø	0	
520568	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Operations C Ø	0	
520569	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
520570	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC As Found Counter	186900	
520571	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC As Left Counter	186900	
520572	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
520573	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Operations Ground	0	
520574	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
520575	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Maintenance Operations	0	
520576	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Operations Counter AF	87	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
520577	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Operations Counter AL	87	
520578	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Switching Operations	0	
520579	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Unknown Operations	0	
520580	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
520581	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Operations C Ø	0	
520582	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Operations B Ø	0	
520583	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
520584	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
520585	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
520586	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Foundation Condition	Good	
520587	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
520588	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Unknown Operations	0	
520589	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
520590	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
520591	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
520592	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
520593	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
520594	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
520595	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
520596	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Amps C Ø	77.0	
520597	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Amps B Ø	78.0	
520598	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Amps A Ø	78.0	
520599	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
520600	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
520601	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Current Tap Position	4L	
520602	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Max Tap Position	1R	
520603	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Min Tap Position	12L	
520604	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
520605	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
520606	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
520607	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
520608	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Operations Since Last Insp	959	
520609	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
520610	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Switching Operations	0	
520611	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
520612	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
520613	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
520614	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
520615	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
520616	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
520617	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
520618	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
520619	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
520620	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Current Tap Position	2L	
520621	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	General Comments		
520622	3/14/2019 10:15	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
520623	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Patrol Inspection	Follow-up Action Required?	n	
520624	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Max Tap Position	1L	
520625	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
520626	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
520627	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
520628	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
520629	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
520630	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Follow-up Action Required?	n	
520631	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Patrol Inspection	General Comments		
520632	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	General Comments	open	
520633	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
520634	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Amps B Ø	180.0	
520635	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Amps C Ø	215.0	
520636	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Accumulated Fault Duty C Ph V	7.72	%
520637	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	General Comments		
520638	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
520639	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
520640	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
520641	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Amps A Ø	0.0	
520642	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	General Comments		
520643	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
520644	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	General Comments		
520645	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
520646	3/15/2019 10:40	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	Follow-up Action Required?	n	
520647	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
520648	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
520649	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
520650	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
520651	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
520652	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
520653	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
520654	3/14/2019 14:21	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.5	psi
520655	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
520656	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
520657	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
520658	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
520659	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	112	
520660	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	32	°C
520661	3/14/2019 12:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
520662	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Min Tap Position	4L	
520663	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Amps C Ø	0.0	
520664	3/14/2019 13:04	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Amps B Ø	0.0	
520665	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LTCC000283	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
520666	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LTCC000283	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
520667	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LTCC000283	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
520668	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
520669	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	36432	
520670	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	4L	
520671	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	11L	
520672	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	3L	
520673	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	36432	
520674	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
520675	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	139	
520676	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
520677	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	16R	
520678	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	7R	
520679	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	8852	
520680	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	8852	
520681	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
520682	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
520683	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	1R	
520684	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	134	
520685	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
520686	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
520687	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
520688	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
520689	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Operations Counter	347	
520690	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
520691	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
520692	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	General Comments		
520693	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
520694	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
520695	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
520696	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
520697	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
520698	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
520699	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
520700	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
520701	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
520702	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
520703	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	76.0	
520704	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	67.0	
520705	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	71.0	
520706	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
520707	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments		
520708	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
520709	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
520710	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
520711	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Max	60	°C
520712	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Present	40	°C
520713	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
520714	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
520715	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	55	°C
520716	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
520717	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	40	°C
520718	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
520719	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
520720	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
520721	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
520722	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
520723	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
520724	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
520725	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
520726	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
520727	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
520728	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
520729	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
520730	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
520731	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1800	psi
520732	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
520733	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
520734	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
520735	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
520736	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
520737	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
520738	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
520739	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
520740	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
520741	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
520742	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
520743	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
520744	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
520745	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
520746	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LTCC000597	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
520747	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LTCC000597	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
520748	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LTCC000597	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
520749	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
520750	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments		
520751	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
520752	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
520753	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
520754	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Present	25	°C
520755	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Max	30	°C
520756	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
520757	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
520758	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	25	°C
520759	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	50	°C
520760	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
520761	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
520762	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
520763	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
520764	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
520765	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
520766	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
520767	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
520768	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
520769	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
520770	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
520771	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
520772	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
520773	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
520774	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
520775	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
520776	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
520777	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
520778	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
520779	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
520780	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
520781	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
520782	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
520783	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
520784	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
520785	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
520786	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
520787	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
520788	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.400	millivolts
520789	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	135.0	VDC
520790	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	135.0	VDC
520791	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	3.5	amps
520792	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
520793	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
520794	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
520795	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
520796	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	y	
520797	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
520798	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
520799	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	THE BAR BETWEEN CELLS 27 & 28 HAS SOME CORROSION AT CONNECTION OF 28	
520800	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
520801	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
520802	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
520803	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
520804	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
520805	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
520806	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
520807	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
520808	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
520809	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	LTCC000109	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
520810	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	LTCC000109	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
520811	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
520812	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
520813	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	LTCC000109	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
520814	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Switching Operations	5	
520815	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	LTCC000109	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
520816	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
520817	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
520818	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	LTCC000109	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
520819	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000209	PowerFuse	MG-464 POT	Disconnect Powerfuse Inspection	General Comments	ok	
520820	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000209	PowerFuse	MG-464 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
520821	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
520822	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Accumulated Fault Duty A Ph V	1.43	%
520823	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	9 Month Operations	11	
520824	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
520825	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
520826	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
520827	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
520828	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
520829	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	General Comments		
520830	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
520831	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
520832	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
520833	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	General Comments		
520834	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Operations Counter AL	178	
520835	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC As Found Counter	84934	
520836	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
520837	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC As Left Counter	84934	
520838	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	9 Months Operations	22	
520839	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
520840	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
520841	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Maintenance Operations	0	
520842	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Moisture and Leak Free?	y	
520843	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
520844	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
520845	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
520846	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
520847	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Operations Counter AF	173	
520848	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Oil Temp Present	40	°C
520849	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Oil Temp Max	65	°C
520850	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
520851	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
520852	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
520853	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	General Comments		
520854	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
520855	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
520856	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
520857	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
520858	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
520859	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
520860	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
520861	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
520862	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
520863	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
520864	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
520865	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
520866	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000220	PowerFuse	MG-1322 POT	Disconnect Powerfuse Inspection	General Comments	ok	
520867	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
520868	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
520869	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
520870	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
520871	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
520872	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	General Comments		
520873	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations C Ø	0	
520874	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations B Ø	0	
520875	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations A Ø	0	
520876	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
520877	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Grounds in Place?	y	
520878	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Maintenance Operations	0	
520879	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Moisture and Leak Free?	y	
520880	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
520881	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
520882	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Operations Counter AF	55	
520883	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Operations Counter AL	55	
520884	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
520885	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000220	PowerFuse	MG-1322 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
520886	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Switching Operations	4	
520887	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Tank Paint Condition	Good	
520888	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
520889	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
520890	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
520891	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	General Comments		
520892	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
520893	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
520894	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
520895	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
520896	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
520897	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
520898	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
520899	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
520900	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
520901	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
520902	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
520903	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0136	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
520904	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
520905	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
520906	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments	station under construction	
520907	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0136	BreakerOil	Retired Distribution	OCB Readings	General Comments	station under construction	
520908	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
520909	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
520910	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Moisture and Leak Free?	y	
520911	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
520912	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Amps C Ø	0.0	
520913	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Amps B Ø	0.0	
520914	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Amps A Ø	0.0	
520915	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	General Comments		
520916	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000210	PowerFuse	MG-411 POT	Disconnect Powerfuse Inspection	General Comments	ok	
520917	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000210	PowerFuse	MG-411 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
520918	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	LTCC000109	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
520919	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
520920	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
520921	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
520922	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
520923	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
520924	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000226	PowerFuse	MG-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
520925	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000226	PowerFuse	MG-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
520926	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
520927	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Switching Operations	4	
520928	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Tank Paint Condition	Good	
520929	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Unknown Operations	0	
520930	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
520931	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	45	°C
520932	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
520933	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	45	°C
520934	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
520935	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
520936	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Heaters (All) Functioning?	y	
520937	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Grounds in Place?	y	
520938	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
520939	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
520940	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
520941	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
520942	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations A Ø	0	
520943	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
520944	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
520945	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
520946	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
520947	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
520948	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
520949	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
520950	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
520951	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
520952	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
520953	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
520954	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
520955	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
520956	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
520957	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	LTCC000109	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
520958	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
520959	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
520960	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
520961	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
520962	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
520963	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
520964	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
520965	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
520966	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	General Comments		
520967	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	General Comments	TR-5 is carded	
520968	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
520969	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
520970	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-2.0	psi
520971	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	Oil Temp Max	65	°C
520972	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations B Ø	0	
520973	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations C Ø	0	
520974	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations Ground	0	
520975	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Follow-up Action Required?	n	
520976	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Follow-up Action Required?	n	
520977	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Foundation Condition	Good	
520978	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	General Comments		
520979	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	General Comments		
520980	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Unknown Operations	0	
520981	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Unknown Operations	0	
520982	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Switching Operations	0	
520983	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Operations Counter AL	223	
520984	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Operations Counter AF	223	
520985	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Maintenance Operations	0	
520986	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	General Comments		
520987	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
520988	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
520989	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0136	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
520990	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
520991	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
520992	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
520993	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
520994	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
520995	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
520996	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	General Comments		
520997	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
520998	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
520999	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
521000	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
521001	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
521002	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
521003	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
521004	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
521005	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
521006	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
521007	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
521008	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
521009	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
521010	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
521011	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	oil on ground	
521012	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
521013	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
521014	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000208	PowerFuse	MG-454 POT	Disconnect Powerfuse Inspection	General Comments	ok	
521015	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	451	
521016	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	485	
521017	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000208	PowerFuse	MG-454 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
521018	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
521019	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
521020	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
521021	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
521022	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
521023	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
521024	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
521025	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	LTCC000109	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
521026	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	LTCC000109	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
521027	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
521028	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
521029	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	31	°C
521030	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
521031	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
521032	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
521033	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
521034	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
521035	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
521036	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
521037	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
521038	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
521039	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
521040	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
521041	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Tank Paint Condition	Good	
521042	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Unknown Operations	0	
521043	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
521044	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
521045	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
521046	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
521047	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	LTC Totalizer Reading	3715.20	kw
521048	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
521049	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
521050	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
521051	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
521052	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
521053	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
521054	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
521055	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1423	
521056	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	99958	
521057	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	99958	
521058	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	General Comments		
521059	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
521060	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Maintenance Operations	0	
521061	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Operations Counter AF	475	
521062	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Operations Counter AL	475	
521063	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Switching Operations	1	
521064	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Follow-up Action Required?	n	
521065	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Unknown Operations	0	
521066	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
521067	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
521068	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Totalizer Meter Reading	.5160	
521069	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Unknown Operations	0	
521070	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	PF000428	PowerFuse	WO-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
521071	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Switching Operations	0	
521072	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
521073	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
521074	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
521075	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
521076	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
521077	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
521078	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
521079	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
521080	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000224	PowerFuse	MG-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
521081	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000224	PowerFuse	MG-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
521082	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Tank Leaks	None	
521083	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
521084	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
521085	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
521086	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Patrol Inspection	General Comments		
521087	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	Oil Temp Max	42	°C
521088	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
521089	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
521090	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
521091	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
521092	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
521093	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
521094	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
521095	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Accumulated Fault Duty B Ph V	.96	%
521096	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
521097	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
521098	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
521099	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
521100	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
521101	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
521102	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
521103	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
521104	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
521105	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
521106	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
521107	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	General Comments	carded didn;t insp	
521108	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Maintenance Operations	0	
521109	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Operations Counter AF	841	
521110	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3L	
521111	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
521112	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	Oil Temp Present	10	°C
521113	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	PF000428	PowerFuse	WO-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
521114	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
521115	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
521116	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
521117	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
521118	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
521119	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
521120	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
521121	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
521122	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Follow-up Action Required?	n	
521123	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Patrol Inspection	Follow-up Action Required?	n	
521124	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations Ground	0	
521125	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
521126	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
521127	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	30	°C
521128	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	31	°C
521129	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Equipment Properly Labeled?	y	
521130	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LTCC000388	LTCControl	WO-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
521131	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LTCC000388	LTCControl	WO-TRANS 1	LTC Control Insp	General Comments		
521132	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LTCC000388	LTCControl	WO-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
521133	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
521134	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	General Comments	CHANGED TO BANK 1 FOR 2019	
521135	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	General Comments		
521136	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Paint Condition	Good	
521137	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
521138	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
521139	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
521140	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
521141	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
521142	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Bushings Connection/Risers	Good	
521143	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
521144	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Bushing Condition	Good	
521145	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
521146	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
521147	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
521148	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
521149	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Patrol Inspection	General Comments		
521150	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
521151	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
521152	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
521153	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
521154	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
521155	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
521156	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
521157	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
521158	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
521159	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
521160	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
521161	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
521162	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
521163	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
521164	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
521165	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
521166	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
521167	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
521168	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
521169	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
521170	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Regulator As Left Counter	54581	
521171	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
521172	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
521173	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Amps C Ø	245.0	
521174	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Amps B Ø	270.0	
521175	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Amps A Ø	250.0	
521176	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Accumulated Fault Duty C Ph V	.96	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
521177	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
521178	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
521179	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
521180	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
521181	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
521182	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	General Comments		
521183	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
521184	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
521185	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
521186	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC Operations Since Last Insp	195	
521187	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
521188	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
521189	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
521190	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
521191	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
521192	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
521193	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
521194	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
521195	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	10	°C
521196	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations B Ø	0	
521197	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	75	°C
521198	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	10	°C
521199	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations C Ø	0	
521200	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations Ground	0	
521201	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Patrol Inspection	Follow-up Action Required?	n	
521202	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	74	°C
521203	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	10	°C
521204	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations B Ø	0	
521205	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations C Ø	0	
521206	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations Ground	0	
521207	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Follow-up Action Required?	n	
521208	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Follow-up Action Required?	n	
521209	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Foundation Condition	Good	
521210	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Follow-up Action Required?	n	
521211	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
521212	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Patrol Inspection	General Comments		
521213	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	74	°C
521214	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
521215	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
521216	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	General Comments		
521217	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Maintenance Operations	0	
521218	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
521219	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Operations Counter AF	419	
521220	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
521221	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Tank Leaks	None	
521222	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
521223	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
521224	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	9 Months Operations	1	
521225	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
521226	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	General Comments		
521227	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	General Comments	BFTC	
521228	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000214	PowerFuse	MG-4KV TFR POT	Disconnect Powerfuse Inspection	General Comments	ok	
521229	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000214	PowerFuse	MG-4KV TFR POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
521230	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000213	PowerFuse	MG-4KV REA TIE POT	Disconnect Powerfuse Inspection	General Comments	ok	
521231	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000213	PowerFuse	MG-4KV REA TIE POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
521232	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Maintenance Operations	0	
521233	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC Min Tap Position	8L	
521234	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC Max Tap Position	5L	
521235	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC Current Tap Position	8L	
521236	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
521237	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC As Left Counter	81830	
521238	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC As Found Counter	81822	
521239	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	General Comments		
521240	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	General Comments		
521241	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
521242	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	Follow-up Action Required?	n	
521243	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	205.00	
521244	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
521245	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
521246	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
521247	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
521248	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
521249	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
521250	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
521251	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000221	PowerFuse	MG-14KV BUS SEC A POT	Disconnect Powerfuse Inspection	General Comments	ok	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
521252	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000221	PowerFuse	MG-14KV BUS SEC A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
521253	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
521254	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
521255	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
521256	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
521257	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000225	PowerFuse	MG-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
521258	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000225	PowerFuse	MG-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
521259	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
521260	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
521261	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
521262	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Heaters (All) Functioning?	y	
521263	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Operations Counter AF	399	
521264	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Operations Counter AL	403	
521265	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
521266	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
521267	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
521268	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
521269	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
521270	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	5	
521271	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
521272	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	30	°C
521273	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
521274	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	32	°C
521275	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	32	°C
521276	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	31	°C
521277	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
521278	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000215	PowerFuse	MG-451 POT	Disconnect Powerfuse Inspection	General Comments	ok	
521279	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
521280	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
521281	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Amps A Ø	0.0	
521282	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Amps B Ø	0.0	
521283	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
521284	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
521285	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
521286	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
521287	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
521288	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	General Comments	THE SOUTH FENCE HAS TREE LIMBS HANGING OVER	
521289	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Amps C Ø	0.0	
521290	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
521291	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
521292	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
521293	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
521294	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations A Ø	0	
521295	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Unknown Operations	0	
521296	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Switching Operations	0	
521297	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Operations Counter AL	419	
521298	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
521299	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
521300	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Regulator As Left Counter	59334	
521301	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Operations Counter AL	841	
521302	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Switching Operations	0	
521303	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Unknown Operations	0	
521304	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000215	PowerFuse	MG-451 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
521305	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
521306	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
521307	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
521308	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
521309	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
521310	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
521311	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
521312	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
521313	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Follow-up Action Required?	n	
521314	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Current Tap Position	3L	
521315	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Max Tap Position	1L	
521316	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Min Tap Position	5L	
521317	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Operations Since Last Insp	146	
521318	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
521319	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
521320	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
521321	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
521322	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
521323	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
521324	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
521325	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	LTC Output Voltage Level	125.4	VAC
521326	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
521327	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
521328	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	VRR Time Delay	30	Seconds
521329	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	All Connections OK?	y	
521330	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	Follow-up Action Required?	n	
521331	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	General Comments		
521332	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	LTC Operation Checked?	y	
521333	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	9 Months Operations	3	
521334	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Accumulated Fault Duty A Ph AM	.56	%
521335	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Accumulated Fault Duty B Ph AM	.56	%
521336	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
521337	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Amps A Ø	100.0	
521338	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
521339	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
521340	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
521341	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	VRR Time Delay	30	Seconds
521342	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
521343	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
521344	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
521345	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
521346	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
521347	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
521348	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	Oil Temp Present	55	°C
521349	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	Oil Temp Max	55	°C
521350	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	400.00	
521351	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
521352	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
521353	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
521354	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	415.00	
521355	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
521356	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
521357	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Tank Paint Condition	Good	
521358	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Unknown Operations	0	
521359	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	9 Months Operations	9	
521360	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	General Comments		
521361	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	General Comments		
521362	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
521363	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
521364	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
521365	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000227	PowerFuse	MG-14KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
521366	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000217	PowerFuse	MG-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
521367	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000217	PowerFuse	MG-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
521368	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	9 Months Operations	20	
521369	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	9 Month Operations	8	
521370	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
521371	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
521372	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Accumulated Fault Duty C Ph V	2.27	%
521373	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Amps A Ø	120.0	
521374	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Amps B Ø	100.0	
521375	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Amps C Ø	100.0	
521376	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Bushing Condition	Good	
521377	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Bushings Connection/Risers	Good	
521378	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
521379	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
521380	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
521381	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Paint Condition	Good	
521382	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Equipment Properly Labeled?	y	
521383	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
521384	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
521385	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
521386	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations A Ø	0	
521387	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations B Ø	0	
521388	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations C Ø	0	
521389	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
521390	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
521391	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
521392	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Amps A Ø	0.0	
521393	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Amps B Ø	0.0	
521394	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Amps C Ø	0.0	
521395	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
521396	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
521397	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
521398	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
521399	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations A Ø	0	
521400	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations B Ø	0	
521401	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
521402	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations Ground	0	
521403	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Patrol Inspection	Follow-up Action Required?	n	
521404	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
521405	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Switching Operations	4	
521406	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	Follow-up Action Required?	n	
521407	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
521408	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	General Comments		
521409	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	General Comments		
521410	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC As Found Counter	176318	
521411	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC As Left Counter	176325	
521412	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	All Connections OK?	y	
521413	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	Follow-up Action Required?	n	
521414	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	General Comments		
521415	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	LTC Operation Checked?	y	
521416	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
521417	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	General Comments	top rail rusty .bottom of alot of the fence has a large gap	
521418	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
521419	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
521420	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations Ground	0	
521421	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Follow-up Action Required?	n	
521422	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
521423	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
521424	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
521425	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
521426	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
521427	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
521428	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
521429	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
521430	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
521431	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
521432	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Maintenance Operations	0	
521433	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
521434	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
521435	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
521436	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	General Comments		
521437	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	General Comments		
521438	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
521439	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
521440	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
521441	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	11911.68	kw
521442	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
521443	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
521444	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Oil Temp Max	2	°C
521445	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Oil Temp Present	0	°C
521446	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
521447	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
521448	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
521449	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
521450	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.2408	
521451	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Winding Temp Max	41	°C
521452	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Winding Temp Present	35	°C
521453	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Operations Counter AF	317	
521454	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Operations Counter AL	317	
521455	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Switching Operations	1	
521456	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Unknown Operations	0	
521457	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
521458	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	BCH000977	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
521459	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
521460	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	General Comments		
521461	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
521462	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
521463	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
521464	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
521465	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
521466	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
521467	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Clear of Trash?	y	
521468	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
521469	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
521470	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
521471	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Amps C Ø	0.0	
521472	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
521473	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
521474	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
521475	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
521476	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000212	PowerFuse	MG-417 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
521477	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000212	PowerFuse	MG-417 POT	Disconnect Powerfuse Inspection	General Comments	ok	
521478	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000222	PowerFuse	MG-14KV BUS SEC B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
521479	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
521480	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
521481	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Amps A Ø	0.0	
521482	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Amps B Ø	0.0	
521483	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Amps C Ø	0.0	
521484	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
521485	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
521486	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
521487	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
521488	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
521489	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
521490	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
521491	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
521492	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
521493	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
521494	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
521495	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
521496	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
521497	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
521498	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
521499	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
521500	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
521501	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
521502	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
521503	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
521504	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
521505	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
521506	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
521507	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
521508	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Vegetation	None	
521509	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
521510	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
521511	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	8.33	
521512	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
521513	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
521514	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
521515	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
521516	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
521517	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
521518	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	General Comments		
521519	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Follow-up Action Required?	n	
521520	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Patrol Inspection	General Comments		
521521	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	General Comments		
521522	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
521523	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
521524	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Operations A Ø	0	
521525	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
521526	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
521527	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
521528	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
521529	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
521530	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
521531	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
521532	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
521533	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
521534	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
521535	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
521536	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	8L	
521537	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
521538	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
521539	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
521540	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
521541	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
521542	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	9 Month Operations	0	
521543	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
521544	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
521545	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
521546	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
521547	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Bushings Connection/Risers	Good	
521548	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	9 Month Operations	10	
521549	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Bushing Condition	Good	
521550	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Amps C Ø	120.0	
521551	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Amps B Ø	110.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
521552	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Amps A Ø	100.0	
521553	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Accumulated Fault Duty C Ph V	9.98	%
521554	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Accumulated Fault Duty B Ph V	4.28	%
521555	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Accumulated Fault Duty A Ph V	4.28	%
521556	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	9 Month Operations	8	
521557	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Accumulated Fault Duty A Ph V	11.35	%
521558	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Accumulated Fault Duty B Ph V	13.62	%
521559	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Accumulated Fault Duty C Ph V	6.81	%
521560	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
521561	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
521562	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Amps A Ø	140.0	
521563	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Amps B Ø	110.0	
521564	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Amps C Ø	120.0	
521565	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	PF000429	PowerFuse	WO-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
521566	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	PF000429	PowerFuse	WO-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
521567	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Bushing Condition	Good	
521568	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Bushings Connection/Risers	Good	
521569	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
521570	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
521571	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
521572	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Paint Condition	Good	
521573	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
521574	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
521575	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
521576	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
521577	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
521578	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
521579	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
521580	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
521581	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
521582	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
521583	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
521584	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
521585	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
521586	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
521587	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
521588	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	9 Months Operations	24	
521589	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
521590	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
521591	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
521592	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
521593	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Min Tap Position	10L	
521594	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Max Tap Position	4L	
521595	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
521596	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	General Comments		
521597	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
521598	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000392	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
521599	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
521600	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
521601	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
521602	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
521603	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
521604	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
521605	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000392	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
521606	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
521607	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000392	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
521608	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
521609	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000392	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
521610	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000392	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
521611	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000392	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
521612	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
521613	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
521614	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Current Tap Position	7L	
521615	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
521616	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
521617	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
521618	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
521619	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
521620	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
521621	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000392	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
521622	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000392	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
521623	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
521624	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
521625	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
521626	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Regulator As Left Counter	80036	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
521627	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
521628	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Tank Leaks	None	
521629	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
521630	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
521631	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
521632	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	65294	
521633	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000392	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
521634	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000392	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
521635	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000392	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
521636	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000392	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
521637	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000392	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
521638	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000392	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
521639	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000392	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
521640	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
521641	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
521642	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	12L	
521643	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	3L	
521644	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
521645	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
521646	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
521647	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
521648	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
521649	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
521650	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000223	PowerFuse	MG-14KV BUS SEC C POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
521651	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000211	PowerFuse	MG-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
521652	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Follow-up Action Required?	n	
521653	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Foundation Condition	Good	
521654	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	General Comments		
521655	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	General Comments		
521656	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Grounds in Place?	y	
521657	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Heaters (All) Functioning?	y	
521658	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Maintenance Operations	2	
521659	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000211	PowerFuse	MG-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
521660	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Cap bank CT In Good Condition?	y	
521661	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
521662	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
521663	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
521664	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
521665	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
521666	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
521667	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
521668	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	General Comments		
521669	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
521670	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
521671	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
521672	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Moisture and Leak Free?	y	
521673	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
521674	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
521675	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
521676	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Operations Counter AF	772	
521677	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Operations Counter AL	778	
521678	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
521679	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
521680	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Trash Emptied?	y	
521681	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
521682	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
521683	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Panels Dusted?	y	
521684	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
521685	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
521686	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	General Comments		
521687	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
521688	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
521689	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Floor Swept?	y	
521690	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
521691	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
521692	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Evidence of Insects	None	
521693	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
521694	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
521695	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
521696	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
521697	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Broom on Site?	y	
521698	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
521699	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
521700	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
521701	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
521702	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000219	PowerFuse	MG-1330 POT	Disconnect Powerfuse Inspection	General Comments	ok	
521703	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000219	PowerFuse	MG-1330 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
521704	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000218	PowerFuse	MG-452 POT	Disconnect Powerfuse Inspection	General Comments	ok	
521705	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000218	PowerFuse	MG-452 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
521706	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000227	PowerFuse	MG-14KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
521707	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
521708	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
521709	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
521710	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
521711	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
521712	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
521713	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
521714	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
521715	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
521716	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
521717	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
521718	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
521719	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
521720	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
521721	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
521722	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
521723	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Amps A Ø	0.0	
521724	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Amps B Ø	0.0	
521725	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
521726	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	General Comments		
521727	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
521728	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
521729	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Foundation Condition	Good	
521730	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
521731	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
521732	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
521733	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Equipment Properly Labeled?	y	
521734	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
521735	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
521736	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
521737	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations A Ø	0	
521738	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations B Ø	0	
521739	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations C Ø	0	
521740	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations Ground	0	
521741	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Follow-up Action Required?	n	
521742	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
521743	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
521744	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
521745	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
521746	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
521747	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Evidence of Insects	None	
521748	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
521749	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
521750	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
521751	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Floor Swept?	n	
521752	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
521753	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
521754	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	General Comments	heater making clicking noises trying to oscillate.	
521755	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
521756	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Panels Dusted?	n	
521757	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
521758	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000216	PowerFuse	MG-407 POT	Disconnect Powerfuse Inspection	General Comments	ok	
521759	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000216	PowerFuse	MG-407 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
521760	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
521761	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
521762	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
521763	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
521764	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000223	PowerFuse	MG-14KV BUS SEC C POT	Disconnect Powerfuse Inspection	General Comments	ok	
521765	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Moisture and Leak Free?	y	
521766	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
521767	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
521768	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
521769	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Operations Counter AF	94	
521770	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Operations Counter AL	98	
521771	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
521772	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Switching Operations	4	
521773	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Tank Paint Condition	Good	
521774	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
521775	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
521776	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
521777	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
521778	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Unknown Operations	0	
521779	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
521780	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
521781	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
521782	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
521783	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
521784	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
521785	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
521786	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
521787	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
521788	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
521789	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	1870	
521790	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	1870	
521791	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
521792	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
521793	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
521794	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	General Comments	oil on ground	
521795	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	General Comments		
521796	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
521797	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
521798	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
521799	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
521800	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
521801	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
521802	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
521803	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
521804	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
521805	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
521806	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
521807	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	685	
521808	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	BCH001234	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.400	millivolts
521809	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	BCH001234	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
521810	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	BCH001234	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
521811	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	BCH001234	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
521812	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	BCH001234	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
521813	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	BCH001234	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
521814	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	685	
521815	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
521816	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
521817	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
521818	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Operations Counter AF	145	
521819	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Operations Counter AL	149	
521820	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
521821	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Amps B Ø	10.0	
521822	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
521823	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Amps C Ø	70.0	
521824	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Amps B Ø	70.0	
521825	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Amps A Ø	100.0	
521826	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Accumulated Fault Duty C Ph AM	6.17	%
521827	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Accumulated Fault Duty B Ph AM	9.54	%
521828	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
521829	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	9 Month Operations	12	
521830	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
521831	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
521832	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
521833	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Amps A Ø	10.0	
521834	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Accumulated Fault Duty A Ph AM	7.30	%
521835	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	9 Months Operations	0	
521836	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations Ground	0	
521837	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Follow-up Action Required?	n	
521838	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Foundation Condition	Good	
521839	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Follow-up Action Required?	n	
521840	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Foundation Condition	Good	
521841	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	General Comments		
521842	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	General Comments		
521843	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Grounds in Place?	y	
521844	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
521845	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Vegetation	None	
521846	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	General Comments		
521847	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	General Comments		
521848	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Grounds in Place?	y	
521849	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Heaters (All) Functioning?	y	
521850	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
521851	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
521852	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
521853	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
521854	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
521855	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Operations A Ø	0	
521856	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Operations B Ø	0	
521857	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
521858	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
521859	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
521860	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
521861	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
521862	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
521863	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
521864	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
521865	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
521866	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
521867	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	Oil Temp Present	55	°C
521868	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	Oil Temp Max	55	°C
521869	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Operations A Ø	0	
521870	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Operations B Ø	0	
521871	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Operations C Ø	0	
521872	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Operations Ground	0	
521873	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Patrol Inspection	Follow-up Action Required?	n	
521874	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Follow-up Action Required?	n	
521875	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
521876	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	240.00	
521877	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	245.00	
521878	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Maintenance Operations	0	
521879	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Operations Counter AL	104	
521880	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Switching Operations	0	
521881	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
521882	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
521883	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
521884	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
521885	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
521886	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
521887	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
521888	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
521889	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	220.00	
521890	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Totalizer Meter Reading	.6966	
521891	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
521892	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Top Oil Temperature Present	30	°C
521893	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Top Oil Temperature Max	50	°C
521894	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Unknown Operations	0	
521895	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	9 Month Operations	0	
521896	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
521897	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
521898	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
521899	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Amps A Ø	502.0	
521900	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Amps B Ø	480.0	
521901	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Amps C Ø	470.0	
521902	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
521903	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
521904	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
521905	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LTCC000098	LTCControl	WO-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
521906	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
521907	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
521908	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
521909	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
521910	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
521911	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
521912	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
521913	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
521914	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	LTC Totalizer Reading	5572.80	kw
521915	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LTCC000098	LTCControl	WO-TRANS 2	LTC Control Insp	General Comments		
521916	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LTCC000098	LTCControl	WO-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
521917	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
521918	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
521919	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
521920	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
521921	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
521922	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
521923	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations Ground	0	
521924	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
521925	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
521926	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
521927	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
521928	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	General Comments		
521929	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	General Comments		
521930	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
521931	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
521932	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Follow-up Action Required?	n	
521933	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
521934	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
521935	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
521936	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Amps C Ø	10.0	
521937	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Bushing Condition	Good	
521938	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Bushings Connection/Risers	Good	
521939	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
521940	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
521941	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
521942	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Cabinet Paint Condition	Good	
521943	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Equipment Properly Labeled?	y	
521944	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
521945	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
521946	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
521947	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
521948	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations A Ø	0	
521949	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
521950	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Switching Operations	4	
521951	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	BCH001234	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
521952	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Tank Paint Condition	Good	
521953	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Unknown Operations	0	
521954	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
521955	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
521956	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
521957	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
521958	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
521959	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
521960	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
521961	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
521962	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
521963	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
521964	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
521965	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
521966	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
521967	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
521968	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
521969	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
521970	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
521971	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
521972	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BCH000214	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
521973	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BCH000214	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
521974	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BCH000214	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
521975	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BCH000214	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
521976	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BCH000214	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
521977	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
521978	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Operations C Ø	0	
521979	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
521980	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	General Comments		
521981	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
521982	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
521983	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
521984	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
521985	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
521986	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
521987	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Operations Ground	0	
521988	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Patrol Inspection	Follow-up Action Required?	n	
521989	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Follow-up Action Required?	n	
521990	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Patrol Inspection	General Comments		
521991	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	General Comments	carded didn't insp	
521992	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Maintenance Operations	0	
521993	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Operations Counter AF	104	
521994	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
521995	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
521996	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Operations Counter AL	361	
521997	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Switching Operations	0	
521998	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Unknown Operations	0	
521999	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
522000	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Amps A Ø	0.0	
522001	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	BCH000977	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
522002	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	BCH000977	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
522003	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	BCH000977	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
522004	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	BCH000977	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
522005	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	BCH000977	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
522006	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Amps B Ø	100.0	
522007	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
522008	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
522009	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
522010	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Amps C Ø	100.0	
522011	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
522012	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	9 Month Operations	8	
522013	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
522014	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
522015	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
522016	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
522017	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
522018	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
522019	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
522020	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
522021	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
522022	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Accumulated Fault Duty A Ph V	9.98	%
522023	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Accumulated Fault Duty B Ph V	8.55	%
522024	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Accumulated Fault Duty C Ph V	7.12	%
522025	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Amps A Ø	300.0	
522026	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
522027	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
522028	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
522029	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
522030	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
522031	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
522032	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	BFTC	
522033	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
522034	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
522035	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
522036	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	308	
522037	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	308	
522038	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
522039	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
522040	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Paint Condition	Good	
522041	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Equipment Properly Labeled?	y	
522042	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
522043	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
522044	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
522045	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
522046	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
522047	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Amps B Ø	0.0	
522048	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
522049	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations A Ø	0	
522050	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations B Ø	0	
522051	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	PF000222	PowerFuse	MG-14KV BUS SEC B POT	Disconnect Powerfuse Inspection	General Comments	ok	
522052	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Operations B Ø	0	
522053	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Operations C Ø	0	
522054	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Operations Ground	0	
522055	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Patrol Inspection	Follow-up Action Required?	n	
522056	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Follow-up Action Required?	n	
522057	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Patrol Inspection	General Comments		
522058	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	General Comments	carded didn't insp	
522059	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Maintenance Operations	0	
522060	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Operations Counter AF	27	
522061	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Operations Counter AL	27	
522062	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	9 Months Operations	1	
522063	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
522064	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
522065	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
522066	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
522067	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
522068	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
522069	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
522070	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
522071	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
522072	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
522073	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Accumulated Fault Duty C Ph V	.80	%
522074	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Amps A Ø	259.0	
522075	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Amps B Ø	252.0	
522076	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	5.43	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
522077	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	5.43	%
522078	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	5.43	%
522079	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Amps C Ø	198.0	
522080	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Patrol Inspection	Equipment Properly Labeled?	y	
522081	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
522082	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
522083	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
522084	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations A Ø	0	
522085	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations B Ø	0	
522086	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations C Ø	0	
522087	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations Ground	0	
522088	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Patrol Inspection	Follow-up Action Required?	n	
522089	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Follow-up Action Required?	n	
522090	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Patrol Inspection	General Comments		
522091	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	General Comments		
522092	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Maintenance Operations	0	
522093	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Operations Counter AF	361	
522094	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
522095	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	34.72	%
522096	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	36.27	%
522097	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	30.86	%
522098	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	160.0	
522099	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	160.0	
522100	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	160.0	
522101	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
522102	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
522103	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
522104	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0113	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
522105	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
522106	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	General Comments		
522107	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
522108	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
522109	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
522110	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
522111	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
522112	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
522113	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
522114	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
522115	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	General Comments	station under construction	
522116	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	General Comments	station under construction	
522117	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
522118	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
522119	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Follow-up Action Required?	n	
522120	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
522121	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
522122	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
522123	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
522124	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
522125	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
522126	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations C Ø	0	
522127	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations B Ø	0	
522128	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations A Ø	0	
522129	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
522130	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
522131	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Operations Counter AF	720	
522132	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Operations Counter AL	720	
522133	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Switching Operations	0	
522134	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Unknown Operations	0	
522135	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	45.0	
522136	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	20.0	
522137	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	28.0	
522138	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
522139	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
522140	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
522141	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
522142	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
522143	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
522144	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
522145	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	290	
522146	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
522147	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Amps C Ø	0.0	
522148	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
522149	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
522150	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
522151	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
522152	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Ambient Temp	56	°F
522153	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
522154	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
522155	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
522156	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Clear of Trash?	y	
522157	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
522158	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
522159	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
522160	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
522161	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
522162	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
522163	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	General Comments		
522164	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
522165	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Amps B Ø	480.0	
522166	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Amps C Ø	480.0	
522167	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Bushing Condition	Good	
522168	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Bushings Connection/Risers	Good	
522169	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
522170	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
522171	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
522172	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Paint Condition	Good	
522173	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Equipment Properly Labeled?	y	
522174	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
522175	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
522176	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
522177	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
522178	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
522179	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
522180	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
522181	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Regulator As Left Counter	55571	
522182	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
522183	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Tank Leaks	None	
522184	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
522185	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
522186	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Operations A Ø	0	
522187	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Operations B Ø	0	
522188	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Operations C Ø	0	
522189	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Operations Ground	0	
522190	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations A Ø	0	
522191	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Patrol Inspection	Follow-up Action Required?	n	
522192	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations C Ø	0	
522193	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Unknown Operations	0	
522194	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Switching Operations	0	
522195	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Operations Counter AL	422	
522196	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Follow-up Action Required?	n	
522197	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Patrol Inspection	General Comments		
522198	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	General Comments		
522199	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Maintenance Operations	0	
522200	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations B Ø	0	
522201	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations C Ø	0	
522202	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations Ground	0	
522203	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Follow-up Action Required?	n	
522204	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Follow-up Action Required?	n	
522205	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Foundation Condition	Good	
522206	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	General Comments		
522207	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Operations Counter AF	422	
522208	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Maintenance Operations	0	
522209	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	General Comments		
522210	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	General Comments		
522211	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Grounds in Place?	y	
522212	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Heaters (All) Functioning?	y	
522213	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Maintenance Operations	0	
522214	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Moisture and Leak Free?	y	
522215	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Patrol Inspection	General Comments		
522216	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Follow-up Action Required?	n	
522217	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Patrol Inspection	Follow-up Action Required?	n	
522218	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations Ground	0	
522219	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
522220	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
522221	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
522222	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
522223	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
522224	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	2	
522225	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	15.46	%
522226	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	17.18	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
522227	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	17.18	%
522228	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
522229	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
522230	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
522231	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
522232	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
522233	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
522234	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
522235	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
522236	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
522237	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	80.0	
522238	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	80.0	
522239	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	80.0	
522240	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.72	%
522241	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
522242	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
522243	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
522244	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
522245	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
522246	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
522247	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
522248	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
522249	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	11.55	%
522250	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
522251	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
522252	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
522253	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
522254	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
522255	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
522256	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
522257	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
522258	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
522259	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
522260	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
522261	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
522262	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
522263	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
522264	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	General Comments		
522265	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
522266	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
522267	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	140	
522268	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	140	
522269	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
522270	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
522271	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
522272	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
522273	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
522274	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
522275	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
522276	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments	didn't insp	
522277	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
522278	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
522279	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	256	
522280	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	256	
522281	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
522282	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
522283	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.72	%
522284	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
522285	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
522286	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
522287	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
522288	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
522289	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
522290	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
522291	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
522292	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
522293	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
522294	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
522295	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
522296	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
522297	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
522298	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
522299	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
522300	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations A Ø	0	
522301	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
522302	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations C Ø	0	
522303	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations Ground	0	
522304	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	Follow-up Action Required?	n	
522305	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Follow-up Action Required?	n	
522306	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	General Comments		
522307	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	General Comments		
522308	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	Heaters (All) Functioning?	y	
522309	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Maintenance Operations	0	
522310	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Operations Counter AF	147	
522311	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Operations Counter AL	147	
522312	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Switching Operations	0	
522313	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Unknown Operations	0	
522314	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
522315	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
522316	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
522317	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
522318	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
522319	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
522320	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
522321	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
522322	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	0	
522323	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	11.55	%
522324	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	11.55	%
522325	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
522326	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
522327	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
522328	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	1	
522329	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
522330	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
522331	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
522332	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	161	
522333	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	161	
522334	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
522335	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
522336	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
522337	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
522338	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
522339	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
522340	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
522341	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
522342	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	LTCC000230	LTCControl	Retired Distribution	LTC Control Insp	General Comments	station under construction	
522343	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	LTCC000230	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
522344	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
522345	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
522346	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
522347	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	143	
522348	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	143	
522349	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
522350	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
522351	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
522352	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
522353	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
522354	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
522355	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Amps C Ø	524.0	
522356	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
522357	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
522358	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
522359	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
522360	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
522361	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
522362	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
522363	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations Ground	0	
522364	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
522365	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
522366	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
522367	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	General Comments		
522368	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	General Comments		
522369	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
522370	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Maintenance Operations	0	
522371	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Operations Counter AF	153	
522372	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Operations Counter AL	153	
522373	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Switching Operations	0	
522374	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Unknown Operations	0	
522375	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
522376	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
522377	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
522378	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
522379	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
522380	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
522381	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
522382	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
522383	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
522384	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
522385	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
522386	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
522387	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
522388	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
522389	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
522390	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
522391	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
522392	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
522393	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
522394	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
522395	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
522396	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	130	
522397	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	130	
522398	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
522399	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
522400	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
522401	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
522402	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Totalizer Meter Reading	1.1268	
522403	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
522404	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
522405	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
522406	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
522407	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.58	%
522408	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.58	%
522409	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.58	%
522410	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	50.0	
522411	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	50.0	
522412	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	50.0	
522413	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
522414	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
522415	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
522416	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
522417	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
522418	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.72	%
522419	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	4	
522420	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
522421	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
522422	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
522423	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
522424	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
522425	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
522426	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
522427	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
522428	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
522429	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	9 Month Operations	0	
522430	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	9.63	%
522431	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	9.63	%
522432	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	9.63	%
522433	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Amps A Ø	477.0	
522434	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Amps B Ø	478.0	
522435	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	161	
522436	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	161	
522437	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
522438	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
522439	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
522440	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.58	%
522441	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.58	%
522442	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.58	%
522443	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	50.0	
522444	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	50.0	
522445	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	50.0	
522446	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
522447	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
522448	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
522449	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
522450	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
522451	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
522452	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
522453	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
522454	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
522455	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
522456	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
522457	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
522458	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
522459	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
522460	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	240	
522461	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	240	
522462	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
522463	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
522464	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
522465	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
522466	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
522467	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
522468	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
522469	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
522470	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
522471	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	485	
522472	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	485	
522473	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
522474	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
522475	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
522476	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
522477	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
522478	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
522479	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
522480	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
522481	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
522482	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	General Comments		
522483	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
522484	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
522485	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
522486	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
522487	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
522488	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
522489	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
522490	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
522491	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
522492	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
522493	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
522494	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
522495	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
522496	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
522497	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
522498	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
522499	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
522500	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
522501	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
522502	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
522503	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
522504	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
522505	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
522506	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	7	
522507	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations C Ø	0	
522508	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations Ground	0	
522509	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Follow-up Action Required?	n	
522510	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
522511	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Unknown Operations	0	
522512	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Switching Operations	0	
522513	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Operations Counter AL	99967	
522514	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
522515	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
522516	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
522517	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
522518	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
522519	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
522520	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
522521	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
522522	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
522523	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
522524	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Follow-up Action Required?	n	
522525	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Foundation Condition	Good	
522526	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
522527	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	General Comments		
522528	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	150.0	
522529	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
522530	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
522531	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
522532	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
522533	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
522534	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	General Comments	36x30 heavy slab (1)	
522535	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
522536	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
522537	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
522538	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
522539	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
522540	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
522541	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
522542	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Clear of Trash?	y	
522543	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
522544	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
522545	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
522546	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
522547	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
522548	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
522549	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	General Comments		
522550	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
522551	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
522552	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
522553	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Vegetation	None	
522554	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
522555	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
522556	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
522557	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
522558	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
522559	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
522560	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
522561	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Foundation Condition	Good	
522562	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
522563	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Trench Covers in Place	Broken	Need size info and qty
522564	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Vegetation	None	
522565	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
522566	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
522567	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
522568	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
522569	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	457	
522570	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	457	
522571	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	9 Month Operations	13	
522572	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Accumulated Fault Duty A Ph V	29.25	%
522573	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Accumulated Fault Duty B Ph V	26.33	%
522574	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Accumulated Fault Duty C Ph V	19.75	%
522575	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Amps A Ø	200.0	
522576	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Amps B Ø	240.0	
522577	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Amps C Ø	180.0	
522578	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Bushing Condition	Good	
522579	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Bushings Connection/Risers	Good	
522580	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
522581	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
522582	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
522583	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Paint Condition	Good	
522584	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Equipment Properly Labeled?	y	
522585	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Adjusted Amps A Phase V	9.12	
522586	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Adjusted Amps B Phase V	9.12	
522587	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Adjusted Amps C Phase V	9.12	
522588	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations A Ø	0	
522589	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations B Ø	0	
522590	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
522591	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
522592	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Amps A Ø	168.0	
522593	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Amps B Ø	171.0	
522594	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Amps C Ø	172.0	
522595	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Patrol Inspection	Equipment Properly Labeled?	y	
522596	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
522597	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
522598	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
522599	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
522600	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
522601	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
522602	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
522603	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
522604	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
522605	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	General Comments		
522606	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
522607	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
522608	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
522609	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
522610	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
522611	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
522612	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
522613	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Operations A Ø	0	
522614	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Operations B Ø	0	
522615	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Operations C Ø	0	
522616	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Operations Ground	0	
522617	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Patrol Inspection	Follow-up Action Required?	n	
522618	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Follow-up Action Required?	n	
522619	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Patrol Inspection	General Comments		
522620	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	General Comments		
522621	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Patrol Inspection	Heaters (All) Functioning?	y	
522622	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Maintenance Operations	0	
522623	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Operations Counter AF	120	
522624	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Operations Counter AL	120	
522625	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
522626	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
522627	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Switching Operations	0	
522628	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Unknown Operations	0	
522629	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
522630	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
522631	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
522632	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
522633	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
522634	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
522635	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
522636	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
522637	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	Oil Temp Present	29	°C
522638	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	Oil Temp Max	32	°C
522639	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
522640	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
522641	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	9 Month Operations	5	
522642	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
522643	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
522644	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
522645	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Amps A Ø	0.0	
522646	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Amps B Ø	0.0	
522647	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Amps C Ø	0.0	
522648	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	Equipment Properly Labeled?	y	
522649	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
522650	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
522651	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
522652	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	150.0	
522653	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	150.0	
522654	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Operations Counter AF	99967	
522655	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Maintenance Operations	0	
522656	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	General Comments	carded didn't insp	
522657	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Patrol Inspection	General Comments		
522658	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Follow-up Action Required?	n	
522659	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Patrol Inspection	Follow-up Action Required?	n	
522660	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
522661	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
522662	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
522663	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
522664	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Grounds in Place?	y	
522665	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Maintenance Operations	0	
522666	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Moisture and Leak Free?	y	
522667	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Operations Counter AF	442	
522668	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Operations Counter AL	442	
522669	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Operations Ground	0	
522670	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Operations C Ø	0	
522671	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Operations B Ø	0	
522672	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Operations A Ø	0	
522673	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
522674	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
522675	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
522676	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
522677	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Amps C Ø	0.0	
522678	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Amps B Ø	0.0	
522679	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Amps A Ø	0.0	
522680	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
522681	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
522682	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
522683	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	9 Months Operations	80	
522684	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
522685	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Switching Operations	4	
522686	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Tank Paint Condition	Good	
522687	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Unknown Operations	2	
522688	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	16	°C
522689	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	28	°C
522690	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	29	°C
522691	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	34	°C
522692	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	17	°C
522693	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	29	°C
522694	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
522695	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
522696	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
522697	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
522698	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
522699	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
522700	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
522701	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	232	
522702	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	232	
522703	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
522704	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
522705	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
522706	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
522707	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
522708	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
522709	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	9 Month Operations	0	
522710	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
522711	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
522712	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
522713	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
522714	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	15	°C
522715	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	°C
522716	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
522717	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Min Tap Position	13L	
522718	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Max Tap Position	5L	
522719	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Current Tap Position	12L	
522720	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
522721	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
522722	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
522723	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
522724	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
522725	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
522726	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Foundation Condition	Good	
522727	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
522728	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
522729	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
522730	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	General Comments		
522731	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
522732	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
522733	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
522734	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
522735	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
522736	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
522737	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
522738	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
522739	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
522740	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
522741	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
522742	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
522743	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
522744	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
522745	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
522746	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
522747	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
522748	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
522749	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
522750	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
522751	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
522752	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
522753	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
522754	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
522755	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
522756	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
522757	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	General Comments		
522758	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	General Comments		
522759	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
522760	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
522761	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
522762	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
522763	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	8877.60	kw
522764	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
522765	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
522766	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Oil Temp Max	45	°C
522767	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
522768	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC As Left Counter	6908	
522769	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC As Found Counter	6908	
522770	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
522771	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	General Comments		
522772	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
522773	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
522774	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
522775	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Accumulated Fault Duty C Ph AM	4.49	%
522776	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Amps A Ø	162.0	
522777	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Amps B Ø	100.0	
522778	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Amps C Ø	152.0	
522779	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
522780	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
522781	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
522782	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
522783	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
522784	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	7L	
522785	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
522786	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
522787	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
522788	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
522789	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
522790	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
522791	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	Neutral	
522792	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	12L	
522793	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
522794	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
522795	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
522796	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
522797	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
522798	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	69265	
522799	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
522800	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
522801	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
522802	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
522803	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
522804	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
522805	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
522806	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations A Ø	0	
522807	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations B Ø	0	
522808	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
522809	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
522810	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
522811	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
522812	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	General Comments		
522813	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
522814	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
522815	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
522816	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
522817	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
522818	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
522819	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
522820	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
522821	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
522822	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations C Ø	0	
522823	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations Ground	0	
522824	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Patrol Inspection	Follow-up Action Required?	n	
522825	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Follow-up Action Required?	n	
522826	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
522827	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	General Comments		
522828	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Maintenance Operations	0	
522829	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Operations Counter AF	431	
522830	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Operations Counter AL	431	
522831	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Switching Operations	0	
522832	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Unknown Operations	0	
522833	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
522834	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
522835	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
522836	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	211	
522837	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
522838	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	LTC Totalizer Reading	3883.20	kw
522839	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
522840	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	General Comments	no cooling group selector	
522841	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	General Comments		
522842	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
522843	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
522844	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
522845	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Follow-up Action Required?	n	
522846	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
522847	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
522848	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
522849	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
522850	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
522851	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
522852	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
522853	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
522854	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
522855	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
522856	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
522857	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
522858	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
522859	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
522860	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
522861	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
522862	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
522863	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
522864	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
522865	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
522866	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
522867	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
522868	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
522869	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
522870	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
522871	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
522872	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
522873	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
522874	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
522875	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
522876	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
522877	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Accumulated Fault Duty A Ph V	10.36	%
522878	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Unknown Operations	0	
522879	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Switching Operations	0	
522880	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Operations Counter AL	581	
522881	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Operations Counter AF	581	
522882	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Maintenance Operations	0	
522883	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	General Comments		
522884	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Patrol Inspection	General Comments		
522885	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Follow-up Action Required?	n	
522886	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Patrol Inspection	Follow-up Action Required?	n	
522887	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations Ground	0	
522888	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations C Ø	0	
522889	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations B Ø	0	
522890	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations A Ø	0	
522891	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
522892	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	9 Month Operations	7	
522893	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
522894	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
522895	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
522896	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Amps C Ø	100.0	
522897	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
522898	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
522899	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
522900	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
522901	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
522902	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
522903	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
522904	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
522905	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
522906	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
522907	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
522908	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
522909	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
522910	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
522911	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
522912	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Unknown Operations	0	
522913	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Switching Operations	0	
522914	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Operations Counter AL	393	
522915	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Operations Counter AF	393	
522916	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Maintenance Operations	0	
522917	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	General Comments		
522918	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Oil Temp Present	40	°C
522919	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
522920	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
522921	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
522922	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
522923	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
522924	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
522925	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
522926	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
522927	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
522928	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
522929	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Totalizer Meter Reading	1.2330	
522930	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Patrol Inspection	General Comments		
522931	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Follow-up Action Required?	n	
522932	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Patrol Inspection	Follow-up Action Required?	n	
522933	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations Ground	0	
522934	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations C Ø	0	
522935	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations B Ø	0	
522936	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations A Ø	0	
522937	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
522938	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
522939	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
522940	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Patrol Inspection	Equipment Properly Labeled?	y	
522941	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Amps C Ø	108.0	
522942	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Amps B Ø	79.0	
522943	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Amps A Ø	134.0	
522944	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Accumulated Fault Duty C Ph V	12.75	%
522945	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Accumulated Fault Duty B Ph V	13.55	%
522946	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
522947	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
522948	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Totalizer Meter Reading	.4854	
522949	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
522950	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
522951	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
522952	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
522953	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
522954	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
522955	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
522956	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
522957	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Oil Temp Present	40	°C
522958	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Oil Temp Max	50	°C
522959	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
522960	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
522961	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
522962	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
522963	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
522964	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
522965	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
522966	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
522967	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
522968	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
522969	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
522970	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
522971	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
522972	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
522973	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Unknown Operations	0	
522974	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Tank Paint Condition	Good	
522975	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Switching Operations	4	
522976	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
522977	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Operations Counter AL	145	
522978	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Operations Counter AF	141	
522979	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Moisture and Leak Free?	y	
522980	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Maintenance Operations	0	
522981	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Heaters (All) Functioning?	y	
522982	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Grounds in Place?	y	
522983	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	General Comments		
522984	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	General Comments		
522985	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Foundation Condition	Good	
522986	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Follow-up Action Required?	n	
522987	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Follow-up Action Required?	n	
522988	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations Ground	0	
522989	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations C Ø	0	
522990	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations B Ø	0	
522991	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations A Ø	0	
522992	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
522993	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	60.0	
522994	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
522995	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Tank Leaks	None	
522996	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
522997	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Operations Counter	90	
522998	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
522999	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
523000	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	General Comments		
523001	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
523002	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
523003	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
523004	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
523005	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
523006	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
523007	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
523008	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
523009	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
523010	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Equipment Properly Labeled?	y	
523011	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Paint Condition	Good	
523012	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
523013	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
523014	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
523015	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Bushings Connection/Risers	Good	
523016	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Bushing Condition	Good	
523017	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Amps C Ø	50.0	
523018	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Amps B Ø	60.0	
523019	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Amps A Ø	80.0	
523020	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
523021	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
523022	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
523023	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
523024	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
523025	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
523026	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
523027	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
523028	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
523029	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
523030	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
523031	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
523032	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
523033	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
523034	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
523035	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
523036	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
523037	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Operations Since Last Insp	483	
523038	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
523039	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
523040	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
523041	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
523042	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
523043	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
523044	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
523045	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
523046	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
523047	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Oil Temp Present	43	°C
523048	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Oil Temp Max	43	°C
523049	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
523050	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
523051	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	LTC Totalizer Reading	10817.28	kw

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
523052	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
523053	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	General Comments		
523054	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	General Comments		
523055	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
523056	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
523057	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Follow-up Action Required?	n	
523058	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
523059	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
523060	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
523061	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
523062	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
523063	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
523064	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
523065	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
523066	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	1	
523067	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
523068	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	2	
523069	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
523070	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	139	
523071	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	139	
523072	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
523073	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
523074	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
523075	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
523076	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
523077	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
523078	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
523079	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
523080	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
523081	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
523082	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
523083	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
523084	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
523085	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
523086	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Amps A Ø	0.0	
523087	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Amps B Ø	0.0	
523088	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Amps C Ø	0.0	
523089	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
523090	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
523091	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
523092	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
523093	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations A Ø	0	
523094	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	99975	
523095	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	99975	
523096	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
523097	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
523098	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
523099	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
523100	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	General Comments		
523101	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
523102	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
523103	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
523104	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
523105	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
523106	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
523107	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
523108	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
523109	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
523110	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations B Ø	0	
523111	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations C Ø	0	
523112	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations Ground	0	
523113	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
523114	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Follow-up Action Required?	n	
523115	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Patrol Inspection	General Comments		
523116	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	General Comments		
523117	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Maintenance Operations	0	
523118	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Operations Counter AF	239	
523119	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Operations Counter AL	239	
523120	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Switching Operations	0	
523121	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Unknown Operations	0	
523122	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
523123	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
523124	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
523125	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
523126	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
523127	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
523128	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
523129	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
523130	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Clear of Trash?	y	
523131	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
523132	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
523133	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
523134	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
523135	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
523136	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	General Comments		
523137	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
523138	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
523139	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Vegetation	None	
523140	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
523141	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	9 Months Operations	0	
523142	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Accumulated Fault Duty A Ph AM	3.93	%
523143	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Accumulated Fault Duty B Ph AM	3.93	%
523144	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
523145	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
523146	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Amps C Ø	40.0	
523147	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Amps B Ø	31.0	
523148	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Amps A Ø	37.0	
523149	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	60.0	
523150	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	60.0	
523151	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
523152	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
523153	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
523154	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	5	
523155	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
523156	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
523157	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
523158	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	150	
523159	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	150	
523160	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
523161	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
523162	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
523163	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
523164	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
523165	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
523166	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
523167	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	9 Month Operations	8	
523168	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
523169	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
523170	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
523171	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
523172	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
523173	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
523174	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
523175	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
523176	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
523177	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
523178	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
523179	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
523180	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
523181	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
523182	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	50.0	
523183	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	50.0	
523184	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	50.0	
523185	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.72	%
523186	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.72	%
523187	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.72	%
523188	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	8	
523189	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
523190	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
523191	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
523192	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
523193	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC As Left Counter	240447	
523194	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC As Found Counter	240436	
523195	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	General Comments	theres an order to replace the drag hand cable	
523196	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	General Comments		
523197	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
523198	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	Follow-up Action Required?	n	
523199	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
523200	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
523201	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
523202	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
523203	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	2	
523204	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
523205	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	9 Months Operations	9	
523206	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
523207	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
523208	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
523209	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
523210	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
523211	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
523212	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
523213	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
523214	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
523215	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
523216	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
523217	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
523218	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
523219	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
523220	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
523221	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
523222	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
523223	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
523224	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	General Comments	A few limbs growing over fence on one side of station.	
523225	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
523226	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	9 Months Operations	0	
523227	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Accumulated Fault Duty A Ph AM	.56	%
523228	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Accumulated Fault Duty B Ph AM	.56	%
523229	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Accumulated Fault Duty C Ph AM	.56	%
523230	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
523231	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
523232	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
523233	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Clear of Trash?	y	
523234	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
523235	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
523236	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
523237	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
523238	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
523239	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	General Comments		
523240	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
523241	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
523242	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Vegetation	None	
523243	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Amps A Ø	90.0	
523244	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
523245	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
523246	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
523247	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	General Comments		
523248	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
523249	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
523250	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
523251	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
523252	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
523253	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	LTCC000077	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
523254	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Amps A Ø	18.0	
523255	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Amps B Ø	26.0	
523256	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Foundation Condition	Good	
523257	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
523258	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
523259	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
523260	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
523261	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
523262	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
523263	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Amps C Ø	12.0	
523264	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
523265	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
523266	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
523267	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
523268	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
523269	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Foundation Condition	Good	
523270	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
523271	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
523272	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	General Comments		
523273	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
523274	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
523275	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
523276	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
523277	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
523278	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
523279	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
523280	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
523281	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
523282	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
523283	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
523284	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
523285	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
523286	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	General Comments	station under construction	
523287	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
523288	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
523289	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
523290	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
523291	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
523292	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
523293	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
523294	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
523295	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
523296	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
523297	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
523298	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
523299	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
523300	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
523301	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
523302	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
523303	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
523304	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
523305	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
523306	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
523307	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
523308	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
523309	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
523310	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
523311	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
523312	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
523313	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
523314	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
523315	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
523316	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
523317	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.3	psi
523318	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
523319	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	General Comments		
523320	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
523321	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
523322	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
523323	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
523324	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
523325	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
523326	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
523327	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
523328	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
523329	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	Equipment Properly Labeled?	y	
523330	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
523331	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	All Connections OK?	y	
523332	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	Current Tap Position	10L	
523333	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	Follow-up Action Required?	n	
523334	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	General Comments		
523335	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	Max Tap Position	1L	
523336	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	Min Tap Position	11L	
523337	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
523338	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
523339	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
523340	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	VRR Base Voltage AF	125.0	VAC
523341	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	VRR Base Voltage AL	125.0	VAC
523342	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	VRR Counter AF	23924	
523343	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	VRR Counter AL	23924	
523344	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
523345	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
523346	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
523347	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations A Ø	1	
523348	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations B Ø	0	
523349	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Amps B Ø	50.0	
523350	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Amps C Ø	70.0	
523351	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
523352	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations Ground	0	
523353	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	Follow-up Action Required?	n	
523354	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Follow-up Action Required?	n	
523355	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	General Comments		
523356	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	General Comments		
523357	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
523358	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
523359	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	1	
523360	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
523361	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
523362	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
523363	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
523364	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
523365	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
523366	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
523367	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
523368	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
523369	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
523370	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
523371	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
523372	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
523373	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
523374	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
523375	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
523376	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
523377	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
523378	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
523379	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	VRR Time Delay	30	Seconds
523380	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
523381	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
523382	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
523383	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
523384	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
523385	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Current Tap Position	7L	
523386	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
523387	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
523388	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
523389	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
523390	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
523391	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
523392	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	General Comments		
523393	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
523394	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Operations Counter	293	
523395	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
523396	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
523397	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	LTCC000077	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
523398	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	LTCC000077	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
523399	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	LTCC000077	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
523400	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	LTCC000077	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
523401	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Amps A Ø	137.0	
523402	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Amps B Ø	132.0	
523403	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Amps C Ø	152.0	
523404	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
523405	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
523406	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
523407	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Vegetation	None	
523408	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
523409	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
523410	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
523411	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
523412	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
523413	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	General Comments		
523414	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
523415	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
523416	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
523417	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
523418	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
523419	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
523420	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
523421	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
523422	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	9 Month Operations	2	
523423	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Accumulated Fault Duty A Ph V	12.31	%
523424	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
523425	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
523426	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
523427	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
523428	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
523429	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
523430	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
523431	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
523432	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	General Comments		
523433	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
523434	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
523435	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Operations Counter	45	
523436	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
523437	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Tank Leaks	None	
523438	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
523439	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	LTCC000077	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
523440	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	LTCC000077	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
523441	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	LTCC000077	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	45	Seconds
523442	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
523443	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
523444	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	station under construction	
523445	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Accumulated Fault Duty B Ph V	16.81	%
523446	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Accumulated Fault Duty C Ph V	9.64	%
523447	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Amps A Ø	49.0	
523448	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
523449	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
523450	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Amps B Ø	37.0	
523451	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Amps C Ø	37.0	
523452	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
523453	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
523454	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
523455	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
523456	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
523457	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
523458	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
523459	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
523460	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
523461	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
523462	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
523463	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
523464	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
523465	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
523466	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
523467	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
523468	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
523469	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
523470	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
523471	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
523472	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
523473	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
523474	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
523475	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	General Comments		
523476	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
523477	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
523478	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
523479	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
523480	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
523481	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Fair	
523482	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	n	If no, which cells in comments
523483	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
523484	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	n	If no, which cells in comments
523485	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
523486	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
523487	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
523488	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	Cell #20 & #24 post is cracked and pushing up	
523489	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
523490	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
523491	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
523492	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
523493	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	9 Months Operations	13	
523494	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
523495	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
523496	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
523497	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Amps A Ø	0.0	
523498	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Amps B Ø	0.0	
523499	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Amps C Ø	0.0	
523500	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
523501	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
523502	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
523503	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
523504	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Operations A Ø	0	
523505	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Operations B Ø	0	
523506	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Operations C Ø	0	
523507	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Operations Ground	0	
523508	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Patrol Inspection	Follow-up Action Required?	n	
523509	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Follow-up Action Required?	n	
523510	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Patrol Inspection	General Comments		
523511	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
523512	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Vegetation	None	
523513	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
523514	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
523515	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
523516	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
523517	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
523518	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
523519	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
523520	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
523521	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
523522	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
523523	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
523524	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
523525	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
523526	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
523527	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
523528	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	General Comments		
523529	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
523530	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
523531	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
523532	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
523533	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
523534	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
523535	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
523536	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
523537	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	1432	
523538	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	1432	
523539	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
523540	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
523541	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
523542	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
523543	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
523544	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
523545	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
523546	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
523547	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
523548	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
523549	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
523550	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
523551	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
523552	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
523553	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
523554	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
523555	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
523556	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
523557	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
523558	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
523559	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
523560	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
523561	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
523562	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
523563	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
523564	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Foundation Condition	Good	
523565	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
523566	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
523567	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	General Comments		
523568	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
523569	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
523570	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
523571	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
523572	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
523573	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
523574	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
523575	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Clear of Trash?	y	
523576	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
523577	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
523578	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
523579	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
523580	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	General Comments		
523581	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Maintenance Operations	0	
523582	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Operations Counter AF	443	
523583	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Operations Counter AL	443	
523584	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Switching Operations	0	
523585	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Unknown Operations	0	
523586	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
523587	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	General Comments		
523588	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
523589	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
523590	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Vegetation	None	
523591	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0135	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
523592	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0135	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
523593	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0135	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
523594	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0135	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
523595	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0135	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
523596	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0135	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
523597	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0135	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
523598	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0135	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
523599	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0135	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
523600	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0135	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
523601	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0135	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
523602	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0135	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
523603	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0135	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments	station under construction	
523604	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0135	BreakerOil	Retired Distribution	OCB Readings	General Comments	station under construction	
523605	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0135	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
523606	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0135	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
523607	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0135	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
523608	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0135	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
523609	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
523610	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Vegetation	None	
523611	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
523612	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
523613	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
523614	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0135	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
523615	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0135	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
523616	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0135	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
523617	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
523618	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
523619	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	General Comments		
523620	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
523621	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
523622	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
523623	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
523624	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
523625	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
523626	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Clear of Trash?	y	
523627	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
523628	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
523629	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BB0135	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
523630	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
523631	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
523632	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
523633	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
523634	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
523635	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
523636	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
523637	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
523638	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	General Comments	station under construction	
523639	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
523640	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
523641	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
523642	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
523643	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
523644	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
523645	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
523646	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
523647	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Clear of Trash?	y	
523648	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
523649	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
523650	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
523651	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
523652	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
523653	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
523654	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
523655	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
523656	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
523657	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	General Comments	carded didn't insp	
523658	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Maintenance Operations	0	
523659	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Operations Counter AF	136	
523660	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Operations Counter AL	136	
523661	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Switching Operations	0	
523662	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Unknown Operations	0	
523663	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	9 Month Operations	8	
523664	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Accumulated Fault Duty A Ph V	20.73	%
523665	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Accumulated Fault Duty B Ph V	19.13	%
523666	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Accumulated Fault Duty C Ph V	19.93	%
523667	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Amps A Ø	27.0	
523668	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Amps B Ø	56.0	
523669	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Amps C Ø	54.0	
523670	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Patrol Inspection	Equipment Properly Labeled?	y	
523671	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
523672	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
523673	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
523674	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations A Ø	0	
523675	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations B Ø	0	
523676	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
523677	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	69	°F
523678	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
523679	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
523680	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations C Ø	0	
523681	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations Ground	0	
523682	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Patrol Inspection	Follow-up Action Required?	n	
523683	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
523684	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
523685	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
523686	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
523687	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
523688	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
523689	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
523690	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
523691	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
523692	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
523693	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Follow-up Action Required?	n	
523694	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Patrol Inspection	General Comments		
523695	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
523696	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Ambient Temp	53	°F
523697	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
523698	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
523699	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	104	
523700	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
523701	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
523702	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	104	
523703	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
523704	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
523705	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
523706	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
523707	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
523708	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
523709	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
523710	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
523711	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
523712	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
523713	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
523714	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
523715	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	40.0	
523716	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	3	
523717	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
523718	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
523719	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
523720	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	350.0	
523721	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	350.0	
523722	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	350.0	
523723	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
523724	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
523725	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
523726	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
523727	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
523728	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
523729	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
523730	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
523731	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
523732	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
523733	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
523734	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
523735	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
523736	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
523737	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
523738	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
523739	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
523740	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
523741	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
523742	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
523743	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
523744	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
523745	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
523746	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	115	
523747	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	115	
523748	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
523749	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
523750	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
523751	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
523752	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
523753	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	126.0	volts
523754	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	9 Month Operations	5	
523755	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Accumulated Fault Duty A Ph V	15.15	%
523756	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Accumulated Fault Duty B Ph V	17.54	%
523757	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Accumulated Fault Duty C Ph V	12.75	%
523758	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Amps A Ø	147.0	
523759	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Accumulated Fault Duty A Ph V	5.58	%
523760	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Accumulated Fault Duty B Ph V	4.78	%
523761	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Accumulated Fault Duty C Ph V	1.59	%
523762	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Amps A Ø	113.0	
523763	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Amps B Ø	99.0	
523764	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Amps C Ø	138.0	
523765	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	Equipment Properly Labeled?	y	
523766	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
523767	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
523768	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
523769	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations A Ø	0	
523770	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations B Ø	0	
523771	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations C Ø	0	
523772	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations Ground	0	
523773	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	Follow-up Action Required?	n	
523774	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Follow-up Action Required?	n	
523775	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
523776	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	General Comments		
523777	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	General Comments		
523778	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	Heaters (All) Functioning?	y	
523779	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	2	
523780	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
523781	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
523782	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
523783	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
523784	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
523785	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
523786	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
523787	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
523788	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
523789	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
523790	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
523791	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
523792	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
523793	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
523794	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Maintenance Operations	0	
523795	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Operations Counter AF	139	
523796	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Operations Counter AL	139	
523797	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Switching Operations	0	
523798	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Unknown Operations	1	
523799	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
523800	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
523801	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
523802	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
523803	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
523804	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
523805	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
523806	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
523807	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
523808	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
523809	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
523810	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
523811	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
523812	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
523813	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
523814	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
523815	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
523816	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
523817	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
523818	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
523819	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
523820	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
523821	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
523822	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	2	
523823	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
523824	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
523825	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
523826	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
523827	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
523828	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
523829	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
523830	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
523831	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
523832	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
523833	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
523834	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
523835	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
523836	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
523837	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
523838	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
523839	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	General Comments		
523840	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
523841	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
523842	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
523843	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
523844	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Clear of Trash?	y	
523845	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	9 Month Operations	8	
523846	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Accumulated Fault Duty A Ph V	3.31	%
523847	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Accumulated Fault Duty B Ph V	3.64	%
523848	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Accumulated Fault Duty C Ph V	2.98	%
523849	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Amps A Ø	60.0	
523850	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Amps B Ø	50.0	
523851	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Amps C Ø	60.0	
523852	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Bushing Condition	Good	
523853	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Bushings Connection/Risers	Good	
523854	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
523855	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
523856	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
523857	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Paint Condition	Good	
523858	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Equipment Properly Labeled?	y	
523859	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
523860	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
523861	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
523862	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations A Ø	0	
523863	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations B Ø	0	
523864	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations C Ø	0	
523865	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations Ground	0	
523866	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Follow-up Action Required?	n	
523867	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Follow-up Action Required?	n	
523868	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Foundation Condition	Good	
523869	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	General Comments		
523870	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	General Comments		
523871	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Grounds in Place?	y	
523872	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Heaters (All) Functioning?	y	
523873	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Maintenance Operations	0	
523874	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Moisture and Leak Free?	y	
523875	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Operations Counter AF	225	
523876	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Operations Counter AL	227	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
523877	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
523878	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Switching Operations	2	
523879	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Tank Paint Condition	Good	
523880	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Unknown Operations	0	
523881	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
523882	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Amps B Ø	141.0	
523883	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Amps C Ø	180.0	
523884	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	Equipment Properly Labeled?	y	
523885	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
523886	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
523887	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
523888	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations A Ø	0	
523889	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations B Ø	0	
523890	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations C Ø	0	
523891	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations Ground	0	
523892	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	Follow-up Action Required?	n	
523893	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Follow-up Action Required?	n	
523894	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	General Comments		
523895	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	General Comments		
523896	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	Heaters (All) Functioning?	y	
523897	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Maintenance Operations	0	
523898	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Operations Counter AF	138	
523899	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Operations Counter AL	138	
523900	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Switching Operations	0	
523901	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Unknown Operations	0	
523902	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Regulator As Left Counter	23924	
523903	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
523904	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
523905	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Tank Leaks	None	
523906	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	4	
523907	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
523908	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
523909	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	40.0	
523910	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	40.0	
523911	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	3.03	%
523912	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	3.03	%
523913	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	3.03	%
523914	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
523915	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
523916	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	550.0	
523917	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	550.0	
523918	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	550.0	
523919	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
523920	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
523921	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
523922	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
523923	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
523924	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
523925	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
523926	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
523927	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
523928	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
523929	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
523930	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
523931	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
523932	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
523933	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
523934	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
523935	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
523936	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
523937	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
523938	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	n	
523939	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
523940	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
523941	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
523942	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	113	
523943	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	113	
523944	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Unknown Operations	0	
523945	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
523946	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
523947	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
523948	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
523949	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
523950	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
523951	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
523952	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
523953	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
523954	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
523955	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
523956	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	General Comments		
523957	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
523958	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
523959	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
523960	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	General Comments		
523961	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
523962	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Max Tap Position	4L	
523963	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Min Tap Position	10L	
523964	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
523965	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
523966	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
523967	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
523968	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
523969	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
523970	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
523971	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
523972	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
523973	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
523974	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
523975	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
523976	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
523977	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
523978	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
523979	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
523980	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Operations Since Last Insp	471	
523981	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
523982	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Clear of Trash?	y	
523983	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
523984	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
523985	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
523986	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
523987	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
523988	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
523989	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Regulator As Left Counter	31576	
523990	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
523991	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Tank Leaks	None	
523992	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
523993	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
523994	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
523995	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
523996	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Cabinet Heaters Functioning?	y	
523997	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
523998	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Min Tap Position	6L	
523999	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Max Tap Position	1R	
524000	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Current Tap Position	1L	
524001	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
524002	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC As Left Counter	227486	
524003	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC As Found Counter	227486	
524004	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	General Comments	has pump and dessicant filter on ltc will not have pressure on it anymore	
524005	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
524006	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
524007	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
524008	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
524009	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
524010	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
524011	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
524012	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
524013	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
524014	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
524015	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	General Comments		
524016	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
524017	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Foundation Condition	Good	
524018	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
524019	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
524020	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
524021	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
524022	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
524023	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
524024	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
524025	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
524026	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
524027	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations B Ø	0	
524028	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations C Ø	0	
524029	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations Ground	0	
524030	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Patrol Inspection	Follow-up Action Required?	n	
524031	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Follow-up Action Required?	n	
524032	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Patrol Inspection	General Comments		
524033	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	General Comments		
524034	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	Heaters (All) Functioning?	y	
524035	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Maintenance Operations	0	
524036	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Operations Counter AF	171	
524037	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Operations Counter AL	171	
524038	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Switching Operations	0	
524039	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Unknown Operations	0	
524040	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
524041	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
524042	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
524043	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
524044	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
524045	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
524046	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
524047	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
524048	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
524049	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
524050	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	116	
524051	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	116	
524052	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
524053	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
524054	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
524055	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
524056	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
524057	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
524058	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
524059	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
524060	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Foundation Condition	Good	
524061	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
524062	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
524063	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Maintenance Operations	0	
524064	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Operations Counter AF	351	
524065	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Operations Counter AL	351	
524066	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Switching Operations	0	
524067	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
524068	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
524069	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
524070	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
524071	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
524072	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
524073	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
524074	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
524075	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
524076	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
524077	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
524078	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
524079	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
524080	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
524081	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
524082	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
524083	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
524084	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
524085	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	140.0	
524086	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	160.0	
524087	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	12.34	%
524088	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
524089	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
524090	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
524091	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
524092	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
524093	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
524094	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
524095	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
524096	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
524097	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
524098	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
524099	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
524100	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
524101	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
524102	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	12.34	%
524103	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	10.80	%
524104	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	17	
524105	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	141	
524106	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	141	
524107	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
524108	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
524109	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
524110	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
524111	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
524112	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
524113	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
524114	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
524115	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	42	
524116	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	38	
524117	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
524118	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
524119	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
524120	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
524121	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
524122	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
524123	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
524124	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
524125	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
524126	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
524127	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	9 Month Operations	1	
524128	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	General Comments		
524129	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
524130	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	Follow-up Action Required?	n	
524131	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	9 Month Operations	0	
524132	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Accumulated Fault Duty A Ph V	2.39	%
524133	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Accumulated Fault Duty B Ph V	2.39	%
524134	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Accumulated Fault Duty C Ph V	.80	%
524135	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Amps A Ø	75.0	
524136	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Amps B Ø	96.0	
524137	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Amps C Ø	62.0	
524138	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Patrol Inspection	Equipment Properly Labeled?	y	
524139	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
524140	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
524141	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
524142	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations A Ø	0	
524143	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations B Ø	0	
524144	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations C Ø	0	
524145	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations Ground	0	
524146	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Patrol Inspection	Follow-up Action Required?	n	
524147	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Follow-up Action Required?	n	
524148	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Patrol Inspection	General Comments		
524149	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	General Comments		
524150	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Maintenance Operations	0	
524151	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
524152	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
524153	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Operations Counter AF	342	
524154	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Operations Counter AL	342	
524155	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Switching Operations	0	
524156	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Unknown Operations	0	
524157	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
524158	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
524159	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
524160	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Current Tap Position	10L	
524161	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
524162	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
524163	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	305	
524164	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	305	
524165	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
524166	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
524167	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
524168	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
524169	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
524170	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
524171	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
524172	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	General Comments		
524173	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
524174	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
524175	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
524176	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	BFTC	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
524177	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
524178	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
524179	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
524180	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
524181	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	MB0112	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
524182	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
524183	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
524184	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
524185	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
524186	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
524187	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
524188	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
524189	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
524190	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
524191	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
524192	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
524193	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
524194	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	9 Month Operations	8	
524195	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Accumulated Fault Duty A Ph V	3.16	%
524196	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Accumulated Fault Duty B Ph V	3.16	%
524197	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Accumulated Fault Duty C Ph V	3.16	%
524198	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Amps A Ø	70.0	
524199	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Amps B Ø	70.0	
524200	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Amps C Ø	100.0	
524201	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Bushing Condition	Good	
524202	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Bushings Connection/Risers	Good	
524203	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
524204	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
524205	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
524206	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Paint Condition	Good	
524207	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Equipment Properly Labeled?	y	
524208	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
524209	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
524210	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
524211	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations A Ø	0	
524212	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations B Ø	0	
524213	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations C Ø	0	
524214	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations Ground	0	
524215	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Follow-up Action Required?	n	
524216	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Follow-up Action Required?	n	
524217	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Foundation Condition	Good	
524218	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	General Comments		
524219	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	9 Month Operations	10	
524220	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
524221	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	General Comments		
524222	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Grounds in Place?	y	
524223	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Heaters (All) Functioning?	y	
524224	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Maintenance Operations	0	
524225	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Moisture and Leak Free?	y	
524226	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Operations Counter AF	96	
524227	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Operations Counter AL	100	
524228	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Accumulated Fault Duty A Ph V	1.43	%
524229	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Accumulated Fault Duty B Ph V	1.43	%
524230	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Accumulated Fault Duty C Ph V	1.43	%
524231	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Amps A Ø	80.0	
524232	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Amps B Ø	80.0	
524233	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Amps C Ø	80.0	
524234	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Bushing Condition	Good	
524235	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Bushings Connection/Risers	Good	
524236	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
524237	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
524238	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
524239	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Paint Condition	Good	
524240	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Equipment Properly Labeled?	y	
524241	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
524242	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
524243	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Vent Fans OK?	y	
524244	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
524245	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
524246	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
524247	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
524248	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
524249	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
524250	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
524251	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
524252	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
524253	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
524254	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
524255	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
524256	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
524257	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
524258	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
524259	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
524260	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
524261	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
524262	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
524263	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
524264	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	General Comments		
524265	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
524266	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
524267	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
524268	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
524269	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
524270	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
524271	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
524272	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
524273	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
524274	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	General Comments		
524275	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
524276	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
524277	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
524278	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
524279	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	oil on ground	
524280	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
524281	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
524282	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	215.00	
524283	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
524284	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	30	°C
524285	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	30	°C
524286	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
524287	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
524288	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
524289	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
524290	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
524291	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
524292	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Follow-up Action Required?	n	
524293	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
524294	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
524295	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
524296	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
524297	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
524298	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
524299	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
524300	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
524301	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
524302	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
524303	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
524304	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
524305	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Bushing Condition	Good	
524306	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Bushings Connection/Risers	Good	
524307	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
524308	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
524309	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
524310	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Cabinet Paint Condition	Good	
524311	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Equipment Properly Labeled?	y	
524312	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
524313	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
524314	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
524315	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Operations A Ø	0	
524316	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Operations B Ø	0	
524317	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Operations C Ø	0	
524318	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Operations Ground	0	
524319	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Follow-up Action Required?	n	
524320	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Follow-up Action Required?	n	
524321	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Foundation Condition	Good	
524322	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	General Comments		
524323	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	General Comments	Breaker open; BFTC	
524324	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Grounds in Place?	y	
524325	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Maintenance Operations	0	
524326	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
524327	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Operations Counter AF	482	
524328	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Operations Counter AL	482	
524329	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
524330	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Switching Operations	4	
524331	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Tank Paint Condition	Good	
524332	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Unknown Operations	0	
524333	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	General Comments	carded didn't insp	
524334	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Patrol Inspection	General Comments		
524335	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Follow-up Action Required?	n	
524336	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Patrol Inspection	Follow-up Action Required?	n	
524337	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Operations Ground	0	
524338	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Operations C Ø	0	
524339	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Operations B Ø	0	
524340	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Operations A Ø	0	
524341	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
524342	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
524343	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
524344	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
524345	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Amps C Ø	0.0	
524346	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Amps B Ø	0.0	
524347	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Amps A Ø	0.0	
524348	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
524349	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
524350	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
524351	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	9 Months Operations	9	
524352	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
524353	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
524354	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Trash Emptied?	n	
524355	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
524356	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	General Comments		
524357	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
524358	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
524359	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
524360	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
524361	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations A Ø	0	
524362	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations B Ø	0	
524363	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations C Ø	0	
524364	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations Ground	0	
524365	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Follow-up Action Required?	n	
524366	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Follow-up Action Required?	n	
524367	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
524368	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Switching Operations	4	
524369	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Tank Paint Condition	Good	
524370	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Unknown Operations	0	
524371	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Foundation Condition	Good	
524372	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	General Comments		
524373	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	General Comments		
524374	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Grounds in Place?	y	
524375	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Heaters (All) Functioning?	y	
524376	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Maintenance Operations	0	
524377	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Moisture and Leak Free?	y	
524378	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Operations Counter AF	535	
524379	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Operations Counter AL	539	
524380	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
524381	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Switching Operations	4	
524382	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Tank Paint Condition	Good	
524383	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Unknown Operations	0	
524384	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	9 Month Operations	9	
524385	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
524386	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
524387	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
524388	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Amps A Ø	0.0	
524389	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Amps B Ø	0.0	
524390	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
524391	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
524392	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	General Comments	sec. is carded for smac	
524393	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
524394	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
524395	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
524396	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
524397	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Evidence of Insects	None	
524398	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
524399	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
524400	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Door Alarms OK?	y	
524401	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
524402	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
524403	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Unknown Operations	0	
524404	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Switching Operations	0	
524405	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Operations Counter AL	27	
524406	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Operations Counter AF	27	
524407	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Maintenance Operations	0	
524408	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Amps C Ø	0.0	
524409	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
524410	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
524411	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
524412	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
524413	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	General Comments		
524414	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
524415	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	Follow-up Action Required?	n	
524416	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
524417	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	General Comments		
524418	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	General Comments		
524419	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC As Found Counter	19739	
524420	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC As Left Counter	19739	
524421	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
524422	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Current Tap Position	5L	
524423	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
524424	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Min Tap Position	8L	
524425	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Operations Since Last Insp	450	
524426	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
524427	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
524428	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
524429	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
524430	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
524431	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	station under construction	
524432	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
524433	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
524434	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
524435	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
524436	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
524437	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
524438	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
524439	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
524440	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
524441	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
524442	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
524443	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
524444	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
524445	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
524446	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
524447	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
524448	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
524449	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
524450	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
524451	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
524452	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
524453	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
524454	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
524455	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	General Comments		
524456	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
524457	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Foundation Condition	Good	
524458	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
524459	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
524460	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
524461	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
524462	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
524463	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
524464	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Unknown Operations	0	
524465	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Switching Operations	0	
524466	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Operations Counter AL	369	
524467	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Operations Counter AF	369	
524468	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Unknown Operations	0	
524469	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Ambient Temp	69	°F
524470	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
524471	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
524472	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	14	
524473	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
524474	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Tank Leaks	None	
524475	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
524476	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Operations Counter	1967	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
524477	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
524478	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
524479	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	General Comments	FTC	
524480	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
524481	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
524482	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
524483	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
524484	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
524485	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
524486	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
524487	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
524488	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
524489	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
524490	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Amps C Ø	50.0	
524491	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Amps B Ø	51.0	
524492	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Amps A Ø	44.0	
524493	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	9 Month Operations	4	
524494	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Accumulated Fault Duty A Ph V	1.43	%
524495	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Accumulated Fault Duty B Ph V	2.85	%
524496	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Accumulated Fault Duty C Ph V	1.43	%
524497	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Amps A Ø	114.0	
524498	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Amps B Ø	173.0	
524499	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Amps C Ø	158.0	
524500	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Bushing Condition	Good	
524501	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Bushings Connection/Risers	Good	
524502	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
524503	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
524504	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
524505	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Paint Condition	Good	
524506	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Equipment Properly Labeled?	y	
524507	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
524508	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
524509	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
524510	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations A Ø	0	
524511	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations B Ø	0	
524512	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations C Ø	0	
524513	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations Ground	0	
524514	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Follow-up Action Required?	n	
524515	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Follow-up Action Required?	n	
524516	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Foundation Condition	Good	
524517	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	General Comments		
524518	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	General Comments		
524519	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Grounds in Place?	y	
524520	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Maintenance Operations	0	
524521	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Moisture and Leak Free?	y	
524522	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Operations Counter AF	108	
524523	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Operations Counter AL	110	
524524	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Switching Operations	2	
524525	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Tank Paint Condition	Good	
524526	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Unknown Operations	0	
524527	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
524528	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Bushings Connection/Risers	Good	
524529	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Bushing Condition	Good	
524530	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Amps C Ø	163.0	
524531	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Amps B Ø	175.0	
524532	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Amps A Ø	170.0	
524533	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Accumulated Fault Duty C Ph V	.48	%
524534	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
524535	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Accumulated Fault Duty A Ph V	.96	%
524536	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	9 Month Operations	9	
524537	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
524538	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
524539	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Totalizer Meter Reading	1.0690	
524540	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
524541	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
524542	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
524543	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
524544	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
524545	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
524546	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
524547	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
524548	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Operations Since Last Insp	378	
524549	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Min Tap Position	8L	
524550	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Max Tap Position	2L	
524551	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
524552	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
524553	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
524554	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
524555	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Oil Temp Present	40	°C
524556	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Oil Temp Max	65	°C
524557	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Current Tap Position	5L	
524558	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
524559	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC As Left Counter	81346	
524560	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC As Found Counter	81346	
524561	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	General Comments		
524562	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	General Comments		
524563	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
524564	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	Follow-up Action Required?	n	
524565	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
524566	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
524567	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	LTC Totalizer Reading	3420.80	kw
524568	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
524569	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
524570	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
524571	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	General Comments	Added water to all cells.	
524572	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
524573	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
524574	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
524575	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Water Added	If low,note cell #~'s
524576	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
524577	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
524578	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
524579	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
524580	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
524581	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
524582	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
524583	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
524584	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Clear of Trash?	y	
524585	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
524586	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
524587	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
524588	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
524589	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
524590	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
524591	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	General Comments		
524592	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
524593	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
524594	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Vegetation	None	
524595	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Maintenance Operations	0	
524596	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	General Comments		
524597	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Patrol Inspection	General Comments		
524598	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Follow-up Action Required?	n	
524599	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Patrol Inspection	Follow-up Action Required?	n	
524600	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations Ground	0	
524601	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations C Ø	0	
524602	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations B Ø	0	
524603	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations A Ø	0	
524604	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
524605	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
524606	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
524607	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Patrol Inspection	Equipment Properly Labeled?	y	
524608	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Amps C Ø	0.0	
524609	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Amps B Ø	0.0	
524610	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Amps A Ø	0.0	
524611	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Tank Paint Condition	Good	
524612	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Switching Operations	5	
524613	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
524614	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Operations Counter AL	230	
524615	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Operations Counter AF	225	
524616	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Moisture and Leak Free?	y	
524617	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Maintenance Operations	0	
524618	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Heaters (All) Functioning?	y	
524619	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Grounds in Place?	y	
524620	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	General Comments		
524621	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	General Comments		
524622	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Foundation Condition	Good	
524623	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Follow-up Action Required?	n	
524624	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Follow-up Action Required?	n	
524625	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Accumulated Fault Duty C Ph V	6.38	%
524626	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Accumulated Fault Duty B Ph V	6.38	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
524627	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Accumulated Fault Duty A Ph V	6.38	%
524628	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	9 Month Operations	0	
524629	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations Ground	0	
524630	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations C Ø	0	
524631	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations B Ø	0	
524632	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations A Ø	0	
524633	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
524634	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
524635	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
524636	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Equipment Properly Labeled?	y	
524637	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Paint Condition	Good	
524638	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
524639	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
524640	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Trash Emptied?	y	
524641	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Switch Diagram Present/Current	y	
524642	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Station Ground Set On Site?	y	
524643	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Restroom Clean & OK?	y	
524644	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Panels Dusted?	y	
524645	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Panel Lights OK?	y	
524646	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
524647	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
524648	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
524649	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
524650	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
524651	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
524652	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
524653	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
524654	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
524655	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
524656	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
524657	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
524658	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	General Comments		
524659	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
524660	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
524661	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Foundation Condition	Good	
524662	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
524663	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
524664	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
524665	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
524666	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
524667	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
524668	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	9 Month Operations	16	
524669	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Vegetation	None	
524670	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
524671	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
524672	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	General Comments		
524673	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
524674	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
524675	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
524676	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	General Comments		
524677	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
524678	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
524679	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Floor Swept?	y	
524680	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
524681	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
524682	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Evidence of Insects	None	
524683	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
524684	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Door Alarms OK?	y	
524685	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
524686	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
524687	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Broom on Site?	y	
524688	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
524689	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
524690	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
524691	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
524692	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Clear of Trash?	y	
524693	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
524694	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
524695	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
524696	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
524697	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
524698	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
524699	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
524700	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
524701	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Amps C Ø	.6	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
524702	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
524703	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
524704	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
524705	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
524706	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations A Ø	0	
524707	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations B Ø	0	
524708	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations C Ø	0	
524709	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations Ground	0	
524710	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Patrol Inspection	Follow-up Action Required?	n	
524711	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Follow-up Action Required?	n	
524712	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Patrol Inspection	General Comments		
524713	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	General Comments		
524714	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Maintenance Operations	0	
524715	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
524716	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
524717	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
524718	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
524719	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
524720	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
524721	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
524722	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
524723	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
524724	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Paint Condition	Good	
524725	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
524726	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
524727	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Operations Counter AF	343	
524728	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Operations Counter AL	343	
524729	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Switching Operations	0	
524730	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Unknown Operations	0	
524731	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
524732	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Bushings Connection/Risers	Good	
524733	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Bushing Condition	Good	
524734	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Amps C Ø	12.0	
524735	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Amps B Ø	12.0	
524736	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Amps A Ø	12.0	
524737	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Accumulated Fault Duty C Ph V	9.51	%
524738	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Accumulated Fault Duty B Ph V	8.78	%
524739	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Accumulated Fault Duty A Ph V	7.31	%
524740	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
524741	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
524742	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
524743	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
524744	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
524745	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
524746	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	188	
524747	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	188	
524748	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
524749	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
524750	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
524751	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
524752	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
524753	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
524754	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
524755	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
524756	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
524757	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	492	
524758	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	496	
524759	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
524760	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
524761	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
524762	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
524763	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
524764	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
524765	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BCH000488	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
524766	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
524767	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	14L	
524768	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	2L	
524769	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
524770	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
524771	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
524772	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
524773	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
524774	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
524775	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	10L	
524776	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
524777	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
524778	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
524779	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
524780	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
524781	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BCH000488	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
524782	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BCH000488	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
524783	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BCH000488	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
524784	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BCH000488	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
524785	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BCH000488	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
524786	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	BCH000488	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
524787	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
524788	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	64	°F
524789	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
524790	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
524791	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
524792	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
524793	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
524794	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
524795	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
524796	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
524797	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
524798	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
524799	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
524800	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
524801	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
524802	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
524803	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
524804	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	General Comments		
524805	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
524806	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
524807	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
524808	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
524809	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
524810	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
524811	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Current Tap Position	10L	
524812	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
524813	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
524814	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
524815	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
524816	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	General Comments		
524817	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
524818	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
524819	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
524820	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
524821	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
524822	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
524823	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
524824	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	126.0	volts
524825	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Regulator As Left Counter	23375	
524826	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
524827	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
524828	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Tank Leaks	None	
524829	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
524830	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
524831	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
524832	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Ambient Temp	74	°F
524833	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
524834	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
524835	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
524836	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
524837	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
524838	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
524839	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	General Comments		
524840	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
524841	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
524842	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
524843	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	General Comments		
524844	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
524845	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
524846	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
524847	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
524848	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
524849	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
524850	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
524851	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
524852	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
524853	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
524854	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
524855	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
524856	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
524857	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
524858	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
524859	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
524860	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
524861	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
524862	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
524863	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	59539	
524864	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
524865	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
524866	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
524867	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
524868	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
524869	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
524870	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
524871	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
524872	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
524873	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
524874	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
524875	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Operations A Ø	0	
524876	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Operations B Ø	0	
524877	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Operations C Ø	0	
524878	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Operations Ground	0	
524879	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
524880	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Follow-up Action Required?	n	
524881	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Patrol Inspection	General Comments		
524882	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
524883	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	General Comments		
524884	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Maintenance Operations	0	
524885	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
524886	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
524887	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
524888	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
524889	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
524890	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	General Comments		
524891	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
524892	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
524893	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Foundation Condition	Good	
524894	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
524895	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
524896	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
524897	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
524898	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
524899	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
524900	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Operations Counter AF	268	
524901	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Operations Counter AL	268	
524902	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Switching Operations	0	
524903	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Unknown Operations	0	
524904	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	Follow-up Action Required?	n	
524905	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
524906	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	General Comments	station under construction	
524907	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	General Comments	station under construction	
524908	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
524909	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
524910	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
524911	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
524912	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
524913	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
524914	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
524915	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
524916	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
524917	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
524918	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
524919	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
524920	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
524921	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
524922	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Floor Swept?	n	
524923	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
524924	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
524925	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Evidence of Insects	None	
524926	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
524927	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
524928	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
524929	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Broom on Site?	n	
524930	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
524931	3/13/2019 10:34	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
524932	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	VRR Time Delay	30	Seconds
524933	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
524934	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
524935	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
524936	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
524937	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
524938	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
524939	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
524940	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
524941	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
524942	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
524943	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
524944	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
524945	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
524946	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	LTC Operation Checked?	y	
524947	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	General Comments		
524948	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	Follow-up Action Required?	n	
524949	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	All Connections OK?	y	
524950	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	9 Months Operations	3	
524951	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
524952	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
524953	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
524954	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Amps A Ø	500.0	
524955	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Amps B Ø	500.0	
524956	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Amps C Ø	500.0	
524957	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
524958	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
524959	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
524960	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Follow-up Action Required?	n	
524961	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
524962	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
524963	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	General Comments		
524964	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	General Comments		
524965	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
524966	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	LTC Totalizer Reading	6881.76	kw
524967	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
524968	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
524969	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Oil Temp Max	60	°C
524970	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Oil Temp Present	40	°C
524971	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
524972	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
524973	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
524974	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
524975	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
524976	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
524977	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations C Ø	0	
524978	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
524979	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
524980	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
524981	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations B Ø	0	
524982	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations A Ø	0	
524983	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Adjusted Amps C Phase V	9.12	
524984	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Adjusted Amps B Phase V	9.12	
524985	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Adjusted Amps A Phase V	9.12	
524986	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Equipment Properly Labeled?	y	
524987	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
524988	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
524989	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Totalizer Meter Reading	.9558	
524990	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
524991	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
524992	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
524993	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
524994	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
524995	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
524996	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
524997	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
524998	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
524999	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
525000	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	General Comments	station under construction	
525001	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
525002	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
525003	3/13/2019 13:05	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
525004	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
525005	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
525006	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
525007	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
525008	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Amps C Ø	53.0	
525009	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Amps B Ø	61.0	
525010	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Amps A Ø	51.0	
525011	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	160.0	
525012	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	160.0	
525013	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	160.0	
525014	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
525015	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
525016	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
525017	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
525018	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
525019	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
525020	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Amps B Ø	.5	
525021	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
525022	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.51	%
525023	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.52	%
525024	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	5.06	%
525025	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	80.0	
525026	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	80.0	
525027	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	80.0	
525028	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
525029	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
525030	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
525031	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
525032	3/13/2019 13:21	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
525033	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
525034	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
525035	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
525036	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	General Comments		
525037	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
525038	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	9 Months Operations	0	
525039	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Accumulated Fault Duty A Ph AM	.56	%
525040	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Unknown Operations	0	
525041	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Switching Operations	0	
525042	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Operations Counter AL	289	
525043	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Operations Counter AF	289	
525044	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Maintenance Operations	0	
525045	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	General Comments	carded didn;t insp	
525046	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Patrol Inspection	General Comments		
525047	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Follow-up Action Required?	n	
525048	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Patrol Inspection	Follow-up Action Required?	n	
525049	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Operations Ground	0	
525050	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Operations C Ø	0	
525051	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Operations B Ø	0	
525052	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Operations A Ø	0	
525053	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
525054	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
525055	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
525056	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
525057	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Amps C Ø	0.0	
525058	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Amps B Ø	0.0	
525059	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Amps A Ø	0.0	
525060	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
525061	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
525062	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
525063	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	9 Months Operations	35	
525064	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Unknown Operations	2	
525065	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Tank Paint Condition	Good	
525066	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Switching Operations	4	
525067	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
525068	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Operations Counter AL	300	
525069	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Operations Counter AF	300	
525070	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Moisture and Leak Free?	y	
525071	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Maintenance Operations	0	
525072	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Grounds in Place?	y	
525073	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
525074	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
525075	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Amps A Ø	.5	
525076	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
525077	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	General Comments		
525078	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Foundation Condition	Good	
525079	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Follow-up Action Required?	n	
525080	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
525081	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Tank Leaks	None	
525082	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
525083	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Operations Counter	290	
525084	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
525085	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
525086	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	General Comments		
525087	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
525088	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Follow-up Action Required?	n	
525089	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations Ground	0	
525090	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
525091	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
525092	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
525093	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
525094	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
525095	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	General Comments		
525096	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
525097	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
525098	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
525099	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
525100	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
525101	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
525102	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
525103	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
525104	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
525105	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	All Connections OK?	y	
525106	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
525107	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Tank Leaks	None	
525108	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
525109	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Operations Counter	218	
525110	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
525111	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BCH000534	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
525112	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BCH000534	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
525113	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BCH000534	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
525114	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BCH000534	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
525115	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Amps C Ø	0.0	
525116	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Amps B Ø	0.0	
525117	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Amps A Ø	0.0	
525118	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
525119	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
525120	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
525121	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BCH000534	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
525122	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BCH000534	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
525123	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BCH000534	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
525124	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
525125	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	9 Months Operations	29	
525126	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	9 Months Operations	0	
525127	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
525128	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
525129	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
525130	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Amps A Ø	110.0	
525131	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Amps B Ø	100.0	
525132	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations C Ø	0	
525133	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations B Ø	0	
525134	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations A Ø	0	
525135	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
525136	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
525137	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
525138	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
525139	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Amps C Ø	2.0	
525140	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Amps B Ø	2.0	
525141	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Amps A Ø	2.0	
525142	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Accumulated Fault Duty C Ph AM	.56	%
525143	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Accumulated Fault Duty B Ph AM	1.68	%
525144	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
525145	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	9 Months Operations	5	
525146	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
525147	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
525148	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Totalizer Meter Reading	.0360	
525149	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
525150	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
525151	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
525152	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
525153	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
525154	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
525155	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	VRR Base Voltage AF	125.0	VAC
525156	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	VRR Base Voltage AL	125.0	VAC
525157	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	VRR Counter AF	19760	
525158	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	VRR Counter AL	19760	
525159	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
525160	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
525161	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	VRR Time Delay	30	Seconds
525162	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Unknown Operations	0	
525163	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Switching Operations	0	
525164	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Operations Counter AL	355	
525165	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	VRR Time Delay	40	Seconds
525166	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
525167	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
525168	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Operations Counter AF	355	
525169	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Maintenance Operations	0	
525170	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	General Comments		
525171	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Patrol Inspection	General Comments		
525172	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Follow-up Action Required?	n	
525173	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Patrol Inspection	Follow-up Action Required?	n	
525174	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Unknown Operations	0	
525175	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Switching Operations	0	
525176	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Operations Counter AL	85	
525177	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Operations Counter AF	850	
525178	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Maintenance Operations	0	
525179	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	General Comments	didn't insp	
525180	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Patrol Inspection	General Comments		
525181	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Follow-up Action Required?	n	
525182	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Patrol Inspection	Follow-up Action Required?	n	
525183	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Operations Ground	0	
525184	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
525185	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	LTC Operation Checked?	n	
525186	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	General Comments		
525187	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	Follow-up Action Required?	n	
525188	3/13/2019 11:55	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	All Connections OK?	y	
525189	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations Ground	0	
525190	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
525191	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Tank Leaks	None	
525192	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
525193	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Regulator As Left Counter	73562	
525194	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
525195	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
525196	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Operations C Ø	0	
525197	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Operations B Ø	0	
525198	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Operations A Ø	0	
525199	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
525200	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
525201	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
525202	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
525203	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
525204	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
525205	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
525206	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Min Tap Position	11L	
525207	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Max Tap Position	4L	
525208	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
525209	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	General Comments		
525210	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
525211	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
525212	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
525213	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
525214	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Current Tap Position	8L	
525215	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
525216	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
525217	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Patrol Inspection	General Comments		
525218	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	General Comments		
525219	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Maintenance Operations	0	
525220	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
525221	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
525222	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
525223	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
525224	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
525225	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
525226	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Operations Counter AF	240	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
525227	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Operations Counter AL	240	
525228	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Switching Operations	0	
525229	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Unknown Operations	0	
525230	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
525231	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
525232	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
525233	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
525234	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
525235	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
525236	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
525237	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Amps C Ø	30.0	
525238	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Amps B Ø	27.0	
525239	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Amps A Ø	27.0	
525240	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
525241	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	General Comments		
525242	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
525243	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
525244	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
525245	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
525246	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
525247	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
525248	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
525249	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
525250	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
525251	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
525252	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
525253	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
525254	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
525255	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	General Comments		
525256	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	General Comments		
525257	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
525258	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
525259	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
525260	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	100.00	
525261	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6609.60	kw
525262	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
525263	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
525264	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Oil Temp Max	25	°C
525265	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
525266	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
525267	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
525268	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
525269	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
525270	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Current Tap Position	10L	
525271	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
525272	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
525273	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
525274	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
525275	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9180	
525276	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
525277	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
525278	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
525279	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
525280	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
525281	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
525282	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
525283	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
525284	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
525285	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
525286	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Oil Temp Present	25	°C
525287	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Oil Temp Max	48	°C
525288	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
525289	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
525290	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
525291	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	462	
525292	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
525293	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5L	
525294	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
525295	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC As Left Counter	28372	
525296	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC As Found Counter	28372	
525297	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
525298	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	General Comments		
525299	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
525300	3/13/2019 10:58	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
525301	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Tank Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
525302	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
525303	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
525304	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Regulator As Left Counter	19760	
525305	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
525306	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Amps C Ø	110.0	
525307	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
525308	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
525309	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	LTC Totalizer Reading	115.20	kw
525310	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
525311	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	General Comments		
525312	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	General Comments		
525313	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
525314	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
525315	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Follow-up Action Required?	n	
525316	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
525317	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
525318	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
525319	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
525320	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
525321	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
525322	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
525323	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	126.0	volts
525324	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
525325	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
525326	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
525327	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
525328	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
525329	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
525330	3/13/2019 11:22	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
525331	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
525332	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Min Tap Position	13L	
525333	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
525334	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
525335	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations A Ø	0	
525336	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations B Ø	0	
525337	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations C Ø	0	
525338	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations Ground	0	
525339	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Patrol Inspection	Follow-up Action Required?	n	
525340	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Follow-up Action Required?	n	
525341	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
525342	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
525343	3/13/2019 13:52	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
525344	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	504	
525345	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
525346	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
525347	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
525348	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
525349	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
525350	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	General Comments	oil on ground	
525351	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	General Comments		
525352	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
525353	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
525354	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
525355	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BCH000478	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
525356	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BCH000478	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
525357	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
525358	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
525359	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
525360	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
525361	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
525362	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
525363	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	All Connections OK?	y	
525364	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	Follow-up Action Required?	n	
525365	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	General Comments		
525366	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	LTC Operation Checked?	y	
525367	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
525368	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
525369	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
525370	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
525371	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
525372	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
525373	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
525374	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
525375	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
525376	3/13/2019 11:29	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	VRR Time Delay	30	Seconds

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
525377	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BCH000478	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
525378	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
525379	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
525380	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
525381	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
525382	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
525383	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
525384	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
525385	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
525386	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	6	
525387	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
525388	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
525389	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
525390	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Operations Since Last Insp	813	
525391	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
525392	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Min Tap Position	7L	
525393	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Max Tap Position	3R	
525394	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Current Tap Position	3L	
525395	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
525396	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC As Left Counter	77928	
525397	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC As Found Counter	77918	
525398	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	General Comments		
525399	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	General Comments		
525400	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
525401	3/13/2019 15:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	Follow-up Action Required?	n	
525402	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
525403	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
525404	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
525405	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
525406	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
525407	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
525408	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
525409	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
525410	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
525411	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
525412	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
525413	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
525414	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
525415	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
525416	3/13/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
525417	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Amps B Ø	140.0	
525418	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Amps A Ø	100.0	
525419	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Accumulated Fault Duty C Ph AM	10.66	%
525420	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Accumulated Fault Duty B Ph AM	11.22	%
525421	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Accumulated Fault Duty A Ph AM	11.22	%
525422	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	9 Months Operations	0	
525423	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
525424	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
525425	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
525426	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
525427	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
525428	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
525429	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
525430	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BCH000478	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
525431	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
525432	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
525433	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
525434	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
525435	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
525436	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
525437	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
525438	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
525439	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
525440	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
525441	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
525442	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
525443	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
525444	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
525445	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	692	
525446	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	692	
525447	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	2	
525448	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
525449	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BCH000478	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
525450	3/13/2019 15:25	Distribution	Owingsville Quarterly Inspection	BCH000478	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
525451	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
525452	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
525453	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	Oil Temp Present	55	°C
525454	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	Oil Temp Max	55	°C
525455	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	420.00	
525456	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	435.00	
525457	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
525458	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	1	
525459	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	504	
525460	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
525461	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
525462	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
525463	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
525464	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
525465	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
525466	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
525467	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
525468	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
525469	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
525470	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	Min Tap Position	12L	
525471	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
525472	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
525473	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
525474	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
525475	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	VRR Base Voltage AF	125.0	VAC
525476	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	40	°C
525477	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	VRR Base Voltage AL	125.0	VAC
525478	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	VRR Counter AF	23375	
525479	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	235.00	
525480	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
525481	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	VRR Counter AL	23375	
525482	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
525483	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
525484	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	oil on ground	
525485	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	40	°C
525486	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
525487	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
525488	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
525489	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
525490	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
525491	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
525492	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
525493	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
525494	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
525495	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
525496	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
525497	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
525498	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	Min Tap Position	13L	
525499	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	Max Tap Position	4L	
525500	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	General Comments		
525501	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	Follow-up Action Required?	n	
525502	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	Current Tap Position	10L	
525503	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	All Connections OK?	y	
525504	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
525505	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
525506	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	569	
525507	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	569	
525508	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
525509	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
525510	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
525511	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
525512	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
525513	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	7	
525514	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
525515	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
525516	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
525517	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
525518	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	All Connections OK?	y	
525519	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	Current Tap Position	10L	
525520	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	Follow-up Action Required?	n	
525521	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	VRR Time Delay	30	Seconds
525522	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	General Comments		
525523	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
525524	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
525525	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	Battery Charger Current	5.0	amps
525526	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.6	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
525527	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.6	VDC
525528	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	4.300	millivolts
525529	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	General Comments		
525530	3/13/2019 16:23	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	Max Tap Position	2L	
525531	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
525532	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
525533	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
525534	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
525535	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
525536	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments	on the Annunciator, (press relief main tank) and (pump failure3) lights not worling replaced bulbs and still not working needs to be fix	
525537	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
525538	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
525539	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
525540	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
525541	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
525542	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
525543	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
525544	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
525545	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
525546	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
525547	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
525548	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
525549	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
525550	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
525551	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
525552	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
525553	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
525554	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
525555	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
525556	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Operational?	y	
525557	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
525558	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
525559	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
525560	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
525561	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
525562	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
525563	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
525564	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Accumulated Fault Duty B Ph AM	2.60	%
525565	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Accumulated Fault Duty A Ph AM	2.60	%
525566	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	9 Months Operations	4	
525567	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Operations Counter AL	403	
525568	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Operations Counter AF	403	
525569	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Maintenance Operations	0	
525570	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	General Comments		
525571	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Accumulated Fault Duty C Ph AM	2.60	%
525572	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Amps A Ø	619.0	
525573	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Amps B Ø	638.0	
525574	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Amps C Ø	694.0	
525575	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Follow-up Action Required?	n	
525576	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Unknown Operations	0	
525577	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Switching Operations	4	
525578	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Operations Ground	0	
525579	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Operations C Ø	0	
525580	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Operations A Ø	0	
525581	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
525582	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
525583	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Operations B Ø	0	
525584	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
525585	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
525586	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
525587	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
525588	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	260.0	
525589	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	200.0	
525590	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	200.0	
525591	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	32.76	%
525592	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	35.19	%
525593	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	25.48	%
525594	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	21	
525595	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
525596	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
525597	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
525598	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
525599	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	724	
525600	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	724	
525601	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
525602	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	IOC B phase	
525603	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
525604	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
525605	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
525606	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
525607	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
525608	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	220.0	
525609	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
525610	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
525611	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	240.0	
525612	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
525613	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
525614	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	913	
525615	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
525616	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
525617	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
525618	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
525619	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
525620	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	913	
525621	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
525622	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	200.0	
525623	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	31.55	%
525624	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	36.40	%
525625	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
525626	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	31.55	%
525627	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
525628	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
525629	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
525630	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
525631	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
525632	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
525633	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
525634	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
525635	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
525636	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
525637	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	647	
525638	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	647	
525639	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
525640	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
525641	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
525642	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
525643	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
525644	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
525645	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
525646	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
525647	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	120.0	
525648	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
525649	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	
525650	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	4.85	%
525651	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	6.07	%
525652	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
525653	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	16.99	%
525654	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
525655	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
525656	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
525657	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Fault Operations Ground	0	
525658	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Unknown Operations	0	
525659	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Switching Operations	0	
525660	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Follow-up Action Required?	n	
525661	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	9 Months Operations	1	
525662	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
525663	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Accumulated Fault Duty B Ph AM	1.21	%
525664	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Operations Counter AL	641	
525665	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Operations Counter AF	641	
525666	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
525667	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Amps A Ø	120.0	
525668	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Amps B Ø	100.0	
525669	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Maintenance Operations	0	
525670	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Fault Operations B Ø	0	
525671	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Fault Operations C Ø	0	
525672	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Fault Operations A Ø	0	
525673	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
525674	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
525675	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
525676	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Amps C Ø	120.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
525677	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	General Comments		
525678	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Patrol Inspection	General Comments		
525679	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Patrol Inspection	Follow-up Action Required?	n	
525680	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
525681	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
525682	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Patrol Inspection	General Comments		
525683	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Patrol Inspection	Follow-up Action Required?	n	
525684	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X3 Winding Temp Present	45	°C
525685	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X3 Winding Temp Max	56	°C
525686	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X2 Winding Temp Present	45	°C
525687	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X2 Winding Temp Max	55	°C
525688	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Present	45	°C
525689	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Max	55	°C
525690	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
525691	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
525692	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	40	°C
525693	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	51	°C
525694	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
525695	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
525696	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
525697	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
525698	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
525699	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
525700	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
525701	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Totalizer Meter Reading	1.2108	
525702	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
525703	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
525704	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
525705	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
525706	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
525707	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
525708	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
525709	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
525710	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
525711	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
525712	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
525713	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
525714	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Amps B Ø	293.0	
525715	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
525716	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Amps A Ø	290.0	
525717	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Accumulated Fault Duty C Ph V	1.02	%
525718	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
525719	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
525720	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
525721	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
525722	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
525723	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
525724	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
525725	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
525726	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
525727	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	General Comments		
525728	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
525729	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
525730	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Foundation Condition	Good	
525731	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
525732	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
525733	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
525734	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
525735	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
525736	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
525737	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
525738	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
525739	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Amps A Ø	24.0	
525740	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Amps B Ø	26.0	
525741	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Amps C Ø	33.0	
525742	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
525743	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
525744	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
525745	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
525746	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
525747	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
525748	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
525749	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Bushing Condition	Good	
525750	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Bushings Connection/Risers	Good	
525751	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
525752	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
525753	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
525754	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Paint Condition	Good	
525755	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	9 Month Operations	0	
525756	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Equipment Properly Labeled?	y	
525757	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
525758	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
525759	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
525760	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations A Ø	0	
525761	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations B Ø	0	
525762	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
525763	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
525764	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
525765	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
525766	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
525767	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
525768	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
525769	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
525770	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
525771	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
525772	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
525773	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
525774	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
525775	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
525776	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	LTCC000141	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
525777	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	LTCC000141	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
525778	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	LTCC000141	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
525779	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
525780	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
525781	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
525782	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	LTCC000141	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
525783	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
525784	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Oil Temp Max	34	°C
525785	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
525786	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
525787	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4207.68	kw
525788	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
525789	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
525790	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
525791	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
525792	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	General Comments		
525793	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	General Comments		
525794	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
525795	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
525796	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
525797	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
525798	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	57	°F
525799	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
525800	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
525801	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
525802	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
525803	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
525804	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
525805	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
525806	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Regulator As Left Counter	44749	
525807	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
525808	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Tank Leaks	None	
525809	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Winding Temp Present	27	°C
525810	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Winding Temp Max	32	°C
525811	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.7532	
525812	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
525813	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
525814	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
525815	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Amps C Ø	292.0	
525816	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
525817	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
525818	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
525819	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
525820	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
525821	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
525822	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
525823	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
525824	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
525825	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
525826	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
525827	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
525828	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
525829	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
525830	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
525831	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
525832	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
525833	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
525834	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
525835	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
525836	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
525837	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
525838	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
525839	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Amps C Ø	70.0	
525840	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Amps B Ø	49.0	
525841	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Amps A Ø	38.0	
525842	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
525843	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
525844	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
525845	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Paint Condition	Good	
525846	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Equipment Properly Labeled?	y	
525847	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
525848	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
525849	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
525850	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
525851	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Panels Dusted?	y	
525852	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
525853	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
525854	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	General Comments	needs 2 8ft single pin bulbs relpaced in control house	
525855	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
525856	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
525857	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Floor Swept?	y	
525858	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
525859	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations A Ø	0	
525860	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations B Ø	0	
525861	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations C Ø	0	
525862	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations Ground	0	
525863	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Follow-up Action Required?	n	
525864	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Follow-up Action Required?	n	
525865	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Foundation Condition	Good	
525866	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	General Comments		
525867	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	General Comments		
525868	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Grounds in Place?	y	
525869	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Heaters (All) Functioning?	y	
525870	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Maintenance Operations	0	
525871	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Moisture and Leak Free?	y	
525872	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Operations Counter AF	150	
525873	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Operations Counter AL	161	
525874	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
525875	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Switching Operations	11	
525876	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Tank Paint Condition	Good	
525877	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Unknown Operations	0	
525878	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	General Comments		
525879	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
525880	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Amps C Ø	91.0	
525881	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
525882	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Amps B Ø	86.0	
525883	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Amps A Ø	90.0	
525884	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Accumulated Fault Duty C Ph V	1.53	%
525885	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Accumulated Fault Duty B Ph V	1.02	%
525886	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Accumulated Fault Duty A Ph V	.51	%
525887	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	9 Month Operations	24	
525888	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	LTC Operation Checked?	y	
525889	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	General Comments		
525890	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	Follow-up Action Required?	n	
525891	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	All Connections OK?	y	
525892	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
525893	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Bushings Connection/Risers	Good	
525894	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
525895	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
525896	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
525897	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
525898	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
525899	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
525900	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
525901	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
525902	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
525903	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
525904	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Operations Counter	79	
525905	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
525906	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
525907	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
525908	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
525909	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Amps C Ø	24.0	
525910	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
525911	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
525912	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
525913	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	General Comments	RFTC	
525914	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
525915	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
525916	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
525917	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
525918	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
525919	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
525920	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
525921	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
525922	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
525923	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
525924	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Vegetation	None	
525925	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
525926	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Broom on Site?	y	
525927	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
525928	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
525929	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
525930	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
525931	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
525932	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	PF000055	PowerFuse	BI-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
525933	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	PF000055	PowerFuse	BI-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
525934	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
525935	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
525936	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	PF000054	PowerFuse	BI-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
525937	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	PF000054	PowerFuse	BI-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
525938	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
525939	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	9 Month Operations	18	
525940	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
525941	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Operations Counter	94	
525942	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
525943	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Accumulated Fault Duty A Ph V	.51	%
525944	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
525945	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	Follow-up Action Required?	n	
525946	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
525947	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	General Comments		
525948	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	General Comments		
525949	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC As Found Counter	334945	
525950	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC As Left Counter	334952	
525951	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Operations Since Last Insp	938	
525952	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Min Tap Position	14L	
525953	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Max Tap Position	4L	
525954	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	416	
525955	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
525956	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
525957	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
525958	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Current Tap Position	13L	
525959	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
525960	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	General Comments	RFTC	
525961	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
525962	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
525963	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
525964	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
525965	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Evidence of Insects	None	
525966	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
525967	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
525968	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
525969	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Control House Lighting OK?	n	
525970	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Amps B Ø	60.0	
525971	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Amps A Ø	40.0	
525972	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
525973	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Ambient Temp	57	°F
525974	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
525975	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Clear of Trash?	y	
525976	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
525977	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
525978	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
525979	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
525980	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
525981	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
525982	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Foundation Condition	Good	
525983	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Follow-up Action Required?	n	
525984	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Follow-up Action Required?	n	
525985	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations Ground	0	
525986	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations C Ø	0	
525987	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations B Ø	0	
525988	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations A Ø	0	
525989	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
525990	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
525991	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
525992	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
525993	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
525994	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
525995	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
525996	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
525997	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
525998	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Bushing Condition	Good	
525999	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Amps C Ø	480.0	
526000	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Amps B Ø	450.0	
526001	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Amps A Ø	450.0	
526002	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Accumulated Fault Duty C Ph V	.79	%
526003	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
526004	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
526005	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	General Comments		
526006	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
526007	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
526008	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
526009	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
526010	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	General Comments		
526011	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
526012	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
526013	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
526014	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
526015	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	94	
526016	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.8	psi
526017	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
526018	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
526019	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Switching Operations	1	
526020	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Tank Paint Condition	Good	
526021	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
526022	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
526023	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC As Left Counter	177963	
526024	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC As Found Counter	177963	
526025	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
526026	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	General Comments		
526027	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
526028	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
526029	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
526030	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
526031	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
526032	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Unknown Operations	0	
526033	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	BCH000212	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.6	VDC
526034	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	BCH000212	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.6	VDC
526035	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	BCH000212	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
526036	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	BCH000212	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
526037	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	BCH000212	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
526038	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Heaters (All) Functioning?	y	
526039	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Grounds in Place?	y	
526040	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	4.800	millivolts
526041	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.9	VDC
526042	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.9	VDC
526043	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	5.0	amps
526044	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
526045	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	General Comments		
526046	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	General Comments		
526047	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Foundation Condition	Good	
526048	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Follow-up Action Required?	n	
526049	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
526050	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
526051	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
526052	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
526053	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
526054	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	General Comments		
526055	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
526056	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
526057	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
526058	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
526059	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
526060	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
526061	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
526062	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
526063	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
526064	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
526065	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
526066	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
526067	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
526068	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
526069	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Follow-up Action Required?	n	
526070	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
526071	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
526072	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	General Comments		
526073	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	General Comments		
526074	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
526075	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	LTC Totalizer Reading	3201.60	kw
526076	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
526077	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
526078	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Oil Temp Max	58	°C
526079	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Oil Temp Present	28	°C
526080	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
526081	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
526082	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
526083	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
526084	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	9 Months Operations	1	
526085	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Maintenance Operations	0	
526086	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Moisture and Leak Free?	y	
526087	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Operations Counter AF	275	
526088	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Operations Counter AL	276	
526089	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
526090	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
526091	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	General Comments		
526092	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC As Found Counter	4919	
526093	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC As Left Counter	4919	
526094	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
526095	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Current Tap Position	6L	
526096	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Max Tap Position	4L	
526097	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Min Tap Position	10L	
526098	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	9 Months Operations	2	
526099	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Accumulated Fault Duty A Ph AM	2.66	%
526100	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
526101	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Operations Since Last Insp	480	
526102	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
526103	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
526104	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
526105	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
526106	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
526107	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
526108	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
526109	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Accumulated Fault Duty B Ph AM	6.64	%
526110	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Accumulated Fault Duty C Ph AM	1.33	%
526111	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Amps A Ø	100.0	
526112	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Amps B Ø	50.0	
526113	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Amps C Ø	50.0	
526114	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
526115	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
526116	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
526117	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
526118	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
526119	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
526120	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
526121	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
526122	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
526123	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
526124	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
526125	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
526126	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
526127	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations A Ø	0	
526128	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations B Ø	0	
526129	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations C Ø	0	
526130	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations Ground	0	
526131	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Patrol Inspection	Follow-up Action Required?	n	
526132	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Follow-up Action Required?	n	
526133	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Patrol Inspection	General Comments		
526134	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	234	
526135	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	General Comments	this is the correct vc	
526136	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Maintenance Operations	0	
526137	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Operations Counter AF	99957	
526138	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Operations Counter AL	99957	
526139	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Switching Operations	0	
526140	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Unknown Operations	0	
526141	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	General Comments		
526142	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
526143	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	Follow-up Action Required?	n	
526144	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
526145	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
526146	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
526147	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
526148	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
526149	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
526150	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
526151	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	238	
526152	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
526153	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
526154	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
526155	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
526156	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
526157	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
526158	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
526159	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
526160	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
526161	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
526162	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
526163	3/13/2019 12:15	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
526164	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Heaters (All) Functioning?	y	
526165	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Grounds in Place?	y	
526166	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	General Comments		
526167	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	General Comments		
526168	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Foundation Condition	Good	
526169	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Follow-up Action Required?	n	
526170	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Follow-up Action Required?	n	
526171	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations Ground	0	
526172	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations C Ø	0	
526173	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations B Ø	0	
526174	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations A Ø	0	
526175	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
526176	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
526177	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
526178	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Equipment Properly Labeled?	y	
526179	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Paint Condition	Good	
526180	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
526181	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
526182	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
526183	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Bushings Connection/Risers	Good	
526184	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Bushing Condition	Good	
526185	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Amps C Ø	0.0	
526186	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Amps B Ø	0.0	
526187	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Amps A Ø	3.0	
526188	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
526189	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
526190	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
526191	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	9 Month Operations	98	
526192	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	2.89	%
526193	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	2.89	%
526194	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Amps A Ø	200.0	
526195	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Amps B Ø	200.0	
526196	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Amps C Ø	200.0	
526197	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
526198	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
526199	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
526200	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
526201	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
526202	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
526203	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
526204	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
526205	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
526206	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
526207	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Patrol Inspection	General Comments		
526208	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	General Comments		
526209	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Maintenance Operations	0	
526210	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Operations Counter AF	323	
526211	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Operations Counter AL	323	
526212	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Switching Operations	1	
526213	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Unknown Operations	0	
526214	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	LTCC000141	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
526215	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	LTCC000141	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
526216	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	LTCC000141	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
526217	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	LTCC000141	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
526218	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	LTCC000141	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
526219	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
526220	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
526221	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
526222	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
526223	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
526224	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
526225	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
526226	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
526227	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
526228	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
526229	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
526230	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
526231	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
526232	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
526233	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
526234	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	General Comments		
526235	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
526236	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
526237	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
526238	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
526239	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
526240	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
526241	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Foundation Condition	Good	
526242	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
526243	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
526244	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
526245	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
526246	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
526247	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
526248	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
526249	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
526250	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
526251	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
526252	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Totalizer Meter Reading	.6670	
526253	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
526254	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
526255	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
526256	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
526257	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	418	
526258	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	26	°C
526259	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	36	°C
526260	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
526261	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	3.0	psi
526262	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	12L	
526263	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	4R	
526264	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	6L	
526265	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
526266	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	223078	
526267	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	223078	
526268	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
526269	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	General Comments		
526270	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
526271	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
526272	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
526273	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
526274	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
526275	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	General Comments		
526276	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
526277	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
526278	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Follow-up Action Required?	n	
526279	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations Ground	0	
526280	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations C Ø	0	
526281	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	All Connections OK?	y	
526282	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	Follow-up Action Required?	n	
526283	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	General Comments		
526284	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	LTC Operation Checked?	y	
526285	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
526286	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
526287	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
526288	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
526289	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
526290	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
526291	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	5L	
526292	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
526293	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
526294	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
526295	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
526296	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
526297	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
526298	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	6R	
526299	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	12L	
526300	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
526301	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
526302	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
526303	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
526304	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
526305	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	66702	
526306	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
526307	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
526308	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
526309	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
526310	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
526311	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	VRR Time Delay	45	Seconds
526312	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	PF000018	PowerFuse	BI-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
526313	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	PF000018	PowerFuse	BI-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
526314	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	2.89	%
526315	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Unknown Operations	0	
526316	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Tank Paint Condition	Good	
526317	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Switching Operations	1	
526318	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
526319	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Operations Counter AL	987	
526320	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Operations Counter AF	986	
526321	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Moisture and Leak Free?	y	
526322	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Maintenance Operations	1	
526323	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Operations Counter AL	310	
526324	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Operations Counter AF	309	
526325	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Moisture and Leak Free?	y	
526326	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Maintenance Operations	0	
526327	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Heaters (All) Functioning?	y	
526328	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Grounds in Place?	y	
526329	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
526330	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
526331	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations B Ø	0	
526332	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
526333	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
526334	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	254	
526335	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
526336	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Totalizer Meter Reading	.2550	
526337	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	254	
526338	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
526339	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
526340	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
526341	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
526342	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
526343	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments	lightening arrestor blown	
526344	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
526345	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
526346	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
526347	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
526348	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
526349	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
526350	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
526351	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
526352	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
526353	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
526354	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
526355	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
526356	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
526357	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
526358	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
526359	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
526360	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
526361	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
526362	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
526363	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
526364	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	General Comments		
526365	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
526366	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
526367	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Operations Counter	1009	
526368	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Unknown Operations	0	
526369	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Switching Operations	0	
526370	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Operations Counter AL	554	
526371	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Operations Counter AF	554	
526372	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Maintenance Operations	0	
526373	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	General Comments		
526374	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Patrol Inspection	General Comments		
526375	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Follow-up Action Required?	n	
526376	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Patrol Inspection	Follow-up Action Required?	n	
526377	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations Ground	0	
526378	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations C Ø	0	
526379	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
526380	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Tank Leaks	None	
526381	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
526382	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Oil Temp Max	41	°C
526383	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
526384	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
526385	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4317.60	kw
526386	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
526387	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
526388	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
526389	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
526390	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	General Comments		
526391	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
526392	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Trash Emptied?	n	
526393	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
526394	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
526395	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	General Comments		
526396	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	General Comments		
526397	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
526398	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
526399	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
526400	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
526401	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
526402	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
526403	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
526404	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
526405	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Grounds in Place?	y	
526406	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	General Comments		
526407	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	General Comments		
526408	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Foundation Condition	Good	
526409	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Follow-up Action Required?	n	
526410	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
526411	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
526412	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
526413	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
526414	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
526415	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
526416	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
526417	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
526418	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
526419	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
526420	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
526421	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
526422	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	General Comments		
526423	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
526424	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
526425	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
526426	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
526427	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
526428	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
526429	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
526430	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	52	°F
526431	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
526432	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
526433	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
526434	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
526435	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
526436	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
526437	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
526438	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
526439	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
526440	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
526441	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
526442	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
526443	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Oil Temp Present	40	°C
526444	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Oil Temp Max	50	°C
526445	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
526446	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Switching Operations	1	
526447	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Tank Paint Condition	Good	
526448	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Unknown Operations	0	
526449	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Switching Operations	0	
526450	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
526451	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
526452	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
526453	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
526454	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
526455	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
526456	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
526457	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
526458	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
526459	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
526460	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
526461	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Adequate	
526462	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
526463	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
526464	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
526465	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
526466	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
526467	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Unknown Operations	0	
526468	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Tank Paint Condition	Good	
526469	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Switching Operations	4	
526470	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
526471	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
526472	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Vegetation	None	
526473	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Operations Counter AL	442	
526474	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Operations Counter AF	438	
526475	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Moisture and Leak Free?	y	
526476	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Maintenance Operations	0	
526477	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Heaters (All) Functioning?	y	
526478	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations A Ø	0	
526479	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
526480	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
526481	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
526482	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
526483	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
526484	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
526485	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
526486	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
526487	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
526488	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
526489	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
526490	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
526491	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
526492	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
526493	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Foundation Condition	Good	
526494	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Follow-up Action Required?	n	
526495	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Follow-up Action Required?	n	
526496	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
526497	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	200.0	
526498	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
526499	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
526500	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
526501	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
526502	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
526503	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
526504	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
526505	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
526506	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
526507	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
526508	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
526509	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
526510	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
526511	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
526512	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
526513	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
526514	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
526515	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
526516	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
526517	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
526518	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
526519	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
526520	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.96	%
526521	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.96	%
526522	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.96	%
526523	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
526524	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
526525	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
526526	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Amps C Ø	30.0	
526527	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
526528	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
526529	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	General Comments	Added water to top half but ran out. Bottom still needs water, made work order.	
526530	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
526531	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
526532	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Low	If low,note cell #~'s
526533	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
526534	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
526535	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
526536	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.7990	
526537	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
526538	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
526539	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
526540	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
526541	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
526542	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations Counter AL	280	
526543	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Winding Temp Max	34	°C
526544	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Winding Temp Present	34	°C
526545	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
526546	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations Counter AF	280	
526547	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
526548	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
526549	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Maintenance Operations	0	
526550	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
526551	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	General Comments		
526552	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	General Comments		
526553	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
526554	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
526555	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
526556	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
526557	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
526558	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
526559	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
526560	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
526561	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LTCC000403	LTCControl	BI-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
526562	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LTCC000403	LTCControl	BI-TRANS 2	LTC Control Insp	General Comments		
526563	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LTCC000403	LTCControl	BI-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
526564	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	General Comments		
526565	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	General Comments		
526566	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
526567	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
526568	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
526569	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
526570	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
526571	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
526572	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
526573	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
526574	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
526575	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
526576	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
526577	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
526578	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
526579	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
526580	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
526581	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
526582	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
526583	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
526584	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
526585	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
526586	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	General Comments		
526587	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
526588	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
526589	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Foundation Condition	Good	
526590	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
526591	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
526592	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
526593	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Floor Swept?	y	
526594	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
526595	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
526596	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
526597	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
526598	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
526599	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
526600	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
526601	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
526602	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
526603	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
526604	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
526605	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
526606	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
526607	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
526608	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
526609	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
526610	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.31	%
526611	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Amps B Ø	30.0	
526612	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Amps A Ø	30.0	
526613	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	.65	%
526614	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.31	%
526615	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	140.0	
526616	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	240.0	
526617	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
526618	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
526619	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
526620	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
526621	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
526622	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
526623	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
526624	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
526625	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
526626	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
526627	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
526628	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	9 Month Operations	8	
526629	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
526630	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
526631	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Broom on Site?	y	
526632	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
526633	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
526634	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
526635	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
526636	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
526637	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
526638	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
526639	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Evidence of Insects	None	
526640	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
526641	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
526642	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
526643	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
526644	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
526645	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
526646	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
526647	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
526648	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
526649	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
526650	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
526651	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
526652	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
526653	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
526654	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
526655	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
526656	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
526657	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
526658	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
526659	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
526660	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
526661	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
526662	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
526663	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
526664	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	VRR Time Delay	30	Seconds
526665	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Operations Counter	14	
526666	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	All Connections OK?	y	
526667	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
526668	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
526669	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	Follow-up Action Required?	n	
526670	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	General Comments		
526671	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	LTC Operation Checked?	y	
526672	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
526673	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
526674	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
526675	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
526676	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	VRR Time Delay	30	Seconds
526677	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Equipment Properly Labeled?	y	
526678	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
526679	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
526680	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
526681	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
526682	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
526683	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
526684	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
526685	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
526686	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
526687	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	269	
526688	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	269	
526689	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
526690	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
526691	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
526692	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	General Comments		
526693	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	General Comments		
526694	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
526695	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	LTC Totalizer Reading	7712.64	kw
526696	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
526697	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
526698	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Oil Temp Max	45	°C
526699	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
526700	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
526701	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
526702	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	General Comments	RFTC	
526703	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
526704	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
526705	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Operations Counter	8	
526706	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
526707	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations B Ø	0	
526708	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Oil Temp Present	40	°C
526709	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
526710	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
526711	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
526712	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
526713	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
526714	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
526715	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
526716	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
526717	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
526718	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Tank Leaks	None	
526719	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
526720	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations A Ø	0	
526721	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Totalizer Meter Reading	.8034	
526722	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Tank Leaks	None	
526723	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
526724	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
526725	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
526726	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
526727	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
526728	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
526729	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
526730	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
526731	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
526732	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
526733	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
526734	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
526735	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
526736	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
526737	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
526738	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
526739	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	9 Month Operations	17	
526740	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
526741	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
526742	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
526743	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Amps A Ø	480.0	
526744	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Amps B Ø	480.0	
526745	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Amps C Ø	480.0	
526746	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Bushing Condition	Good	
526747	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
526748	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
526749	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
526750	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
526751	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
526752	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	2179.44	kw
526753	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	55.00	
526754	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
526755	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Oil Temp Max	50	°C
526756	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Oil Temp Present	45	°C
526757	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
526758	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
526759	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
526760	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
526761	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
526762	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
526763	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
526764	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
526765	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Paint Condition	Good	
526766	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
526767	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
526768	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
526769	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Bushings Connection/Risers	Good	
526770	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
526771	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Bushing Condition	Good	
526772	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
526773	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
526774	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Unknown Operations	0	
526775	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Tank Paint Condition	Good	
526776	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Switching Operations	0	
526777	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
526778	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Operations Counter AL	61	
526779	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Operations Counter AF	61	
526780	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
526781	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Maintenance Operations	0	
526782	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
526783	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Vegetation	None	
526784	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
526785	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
526786	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
526787	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
526788	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Grounds in Place?	y	
526789	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	General Comments		
526790	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	General Comments		
526791	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Trash Emptied?	y	
526792	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
526793	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
526794	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	General Comments		
526795	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	General Comments		
526796	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
526797	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
526798	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	6	
526799	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
526800	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	422	
526801	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
526802	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
526803	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	General Comments	RFTC	
526804	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
526805	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
526806	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
526807	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
526808	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
526809	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	General Comments		
526810	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
526811	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
526812	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
526813	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
526814	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
526815	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
526816	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	General Comments		
526817	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Follow-up Action Required?	n	
526818	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Operations Ground	0	
526819	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Operations C Ø	0	
526820	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Operations B Ø	0	
526821	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
526822	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Amps A Ø	200.0	
526823	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Accumulated Fault Duty C Ph AM	5.32	%
526824	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Accumulated Fault Duty B Ph AM	2.66	%
526825	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Accumulated Fault Duty A Ph AM	2.66	%
526826	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	9 Months Operations	0	
526827	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Max Tap Position	4R	
526828	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Min Tap Position	7L	
526829	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
526830	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
526831	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
526832	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
526833	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
526834	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Regulator As Left Counter	114955	
526835	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
526836	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
526837	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Operations A Ø	0	
526838	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
526839	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
526840	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
526841	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Tank Leaks	None	
526842	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
526843	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
526844	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
526845	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
526846	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
526847	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
526848	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Current Tap Position	3L	
526849	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
526850	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
526851	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
526852	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
526853	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	General Comments		
526854	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
526855	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
526856	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
526857	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
526858	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	General Comments		
526859	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	LTC Totalizer Reading	1530.00	kw
526860	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
526861	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	General Comments		
526862	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	General Comments		
526863	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
526864	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Amps C Ø	200.0	
526865	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Amps B Ø	200.0	
526866	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
526867	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
526868	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
526869	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
526870	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
526871	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
526872	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Amps A Ø	40.0	
526873	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Amps B Ø	32.0	
526874	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Amps C Ø	50.0	
526875	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
526876	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
526877	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
526878	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
526879	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
526880	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
526881	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
526882	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
526883	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
526884	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
526885	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
526886	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
526887	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
526888	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
526889	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
526890	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
526891	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
526892	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
526893	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Current Tap Position	2L	
526894	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
526895	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
526896	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
526897	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	50.0	
526898	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
526899	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
526900	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
526901	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
526902	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
526903	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
526904	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
526905	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
526906	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
526907	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
526908	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
526909	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
526910	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
526911	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
526912	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
526913	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
526914	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
526915	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
526916	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
526917	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Accumulated Fault Duty C Ph V	.71	%
526918	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Accumulated Fault Duty B Ph V	.71	%
526919	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Accumulated Fault Duty A Ph V	.71	%
526920	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	9 Month Operations	9	
526921	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
526922	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
526923	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
526924	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Clear of Trash?	y	
526925	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
526926	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
526927	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
526928	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
526929	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
526930	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
526931	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
526932	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Unknown Operations	0	
526933	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations Ground	0	
526934	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations C Ø	0	
526935	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Follow-up Action Required?	n	
526936	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
526937	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Max Tap Position	1R	
526938	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Min Tap Position	8L	
526939	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
526940	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Equipment Properly Labeled?	y	
526941	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Cabinet Paint Condition	Good	
526942	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
526943	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
526944	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
526945	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
526946	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Regulator As Left Counter	89869	
526947	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
526948	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
526949	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Tank Leaks	None	
526950	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
526951	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
526952	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
526953	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
526954	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
526955	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
526956	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
526957	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
526958	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
526959	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
526960	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
526961	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
526962	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
526963	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
526964	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
526965	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
526966	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
526967	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
526968	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Bushings Connection/Risers	Good	
526969	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Bushing Condition	Good	
526970	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Amps C Ø	60.0	
526971	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Amps B Ø	60.0	
526972	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Amps A Ø	60.0	
526973	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
526974	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.31	%
526975	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	.65	%
526976	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.31	%
526977	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
526978	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
526979	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
526980	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
526981	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
526982	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
526983	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
526984	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Regulator As Left Counter	59723	
526985	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
526986	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Tank Leaks	None	
526987	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
526988	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
526989	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
526990	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Current Tap Position	3L	
526991	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
526992	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
526993	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
526994	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
526995	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	General Comments		
526996	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
526997	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Max Tap Position	3L	
526998	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Min Tap Position	3L	
526999	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
527000	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
527001	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
527002	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
527003	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
527004	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	40	°C
527005	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
527006	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
527007	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
527008	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
527009	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
527010	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
527011	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
527012	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	Seeping	
527013	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
527014	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
527015	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
527016	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
527017	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
527018	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
527019	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
527020	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
527021	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Clear of Trash?	y	
527022	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
527023	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
527024	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
527025	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
527026	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
527027	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
527028	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	General Comments		
527029	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	General Comments		
527030	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC As Found Counter	111922	
527031	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC As Left Counter	111922	
527032	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
527033	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Current Tap Position	4L	
527034	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Max Tap Position	2L	
527035	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Min Tap Position	11L	
527036	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Operations Since Last Insp	722	
527037	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
527038	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
527039	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
527040	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
527041	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	35	°C
527042	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
527043	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	40	°C
527044	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
527045	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
527046	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
527047	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
527048	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
527049	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
527050	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
527051	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
527052	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
527053	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
527054	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
527055	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
527056	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
527057	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	General Comments		
527058	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
527059	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
527060	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
527061	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
527062	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
527063	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
527064	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
527065	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	n	
527066	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
527067	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
527068	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
527069	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
527070	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
527071	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
527072	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
527073	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Foundation Condition	Good	
527074	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
527075	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
527076	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
527077	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
527078	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
527079	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
527080	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Vegetation	None	
527081	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
527082	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
527083	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	General Comments		
527084	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
527085	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
527086	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
527087	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
527088	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
527089	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
527090	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Clear of Trash?	y	
527091	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
527092	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
527093	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
527094	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BCH000378	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
527095	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
527096	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
527097	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
527098	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
527099	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
527100	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
527101	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
527102	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
527103	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Regulator As Left Counter	91998	
527104	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
527105	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
527106	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Tank Leaks	None	
527107	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
527108	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	General Comments	X3 guage not able to reset	
527109	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	General Comments	small oil leak at bottom of radiator, nitro bottle needs filled,Strip Heaters need to be replaced, on the Annunciator (hot spot thermo) a	
527110	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
527111	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
527112	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	y	
527113	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	All Connections OK?	y	
527114	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	Follow-up Action Required?	n	
527115	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	General Comments		
527116	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
527117	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
527118	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
527119	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
527120	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
527121	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
527122	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
527123	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
527124	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
527125	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
527126	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	LTC Operation Checked?	y	
527127	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
527128	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
527129	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
527130	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	VRR Time Delay	30	Seconds
527131	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
527132	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
527133	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BCH000378	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
527134	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BCH000378	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
527135	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BCH000378	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
527136	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BCH000378	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
527137	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BCH000378	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
527138	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	BCH000378	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
527139	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
527140	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	General Comments		
527141	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
527142	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
527143	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
527144	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
527145	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
527146	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
527147	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
527148	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
527149	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
527150	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Regulator As Left Counter	63342	
527151	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
527152	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Tank Leaks	None	
527153	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
527154	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
527155	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
527156	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
527157	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
527158	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	5	
527159	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	3.21	%
527160	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	3.21	%
527161	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	3.21	%
527162	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
527163	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
527164	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
527165	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
527166	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
527167	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
527168	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
527169	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
527170	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
527171	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
527172	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
527173	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
527174	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
527175	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Winding Temp Present	39	°C
527176	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
527177	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
527178	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	General Comments		
527179	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
527180	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Winding Temp Max	52	°C
527181	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Totalizer Meter Reading	.7080	
527182	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
527183	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	LTCC000202	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
527184	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	LTCC000202	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
527185	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
527186	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
527187	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
527188	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	LTCC000202	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
527189	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	LTCC000202	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
527190	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Bushings Connection/Risers	Good	
527191	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Bushing Condition	Good	
527192	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Amps C Ø	180.0	
527193	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Amps B Ø	180.0	
527194	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Amps A Ø	180.0	
527195	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Accumulated Fault Duty C Ph V	2.13	%
527196	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Accumulated Fault Duty B Ph V	5.69	%
527197	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Accumulated Fault Duty A Ph V	2.13	%
527198	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	9 Month Operations	12	
527199	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
527200	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
527201	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
527202	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Operations Since Last Insp	229	
527203	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Min Tap Position	8L	
527204	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Max Tap Position	4L	
527205	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Current Tap Position	6L	
527206	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
527207	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC As Left Counter	228936	
527208	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC As Found Counter	228936	
527209	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	General Comments		
527210	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	General Comments		
527211	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
527212	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	Follow-up Action Required?	n	
527213	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
527214	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
527215	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
527216	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
527217	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
527218	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
527219	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
527220	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
527221	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
527222	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
527223	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	General Comments		
527224	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
527225	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
527226	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
527227	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
527228	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
527229	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
527230	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
527231	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
527232	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
527233	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
527234	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	27	
527235	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	27	
527236	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	5	
527237	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
527238	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
527239	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
527240	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
527241	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
527242	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
527243	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
527244	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
527245	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
527246	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
527247	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
527248	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
527249	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
527250	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	General Comments	Breaker 234,235 the foundation is crumbling.	
527251	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
527252	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
527253	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Foundation Condition	Crumbling	
527254	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
527255	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
527256	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
527257	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
527258	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
527259	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
527260	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
527261	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Vegetation	None	
527262	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	General Comments		
527263	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
527264	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
527265	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
527266	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
527267	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
527268	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
527269	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
527270	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
527271	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
527272	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
527273	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
527274	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Oil Temp Present	29	°C
527275	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Oil Temp Max	48	°C
527276	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
527277	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
527278	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	LTC Totalizer Reading	12744.00	kw
527279	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
527280	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	General Comments		
527281	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	General Comments		
527282	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
527283	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
527284	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Follow-up Action Required?	n	
527285	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
527286	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
527287	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
527288	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
527289	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
527290	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
527291	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
527292	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
527293	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
527294	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
527295	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
527296	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
527297	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
527298	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
527299	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
527300	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.0	amps
527301	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
527302	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
527303	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	General Comments		
527304	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
527305	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
527306	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
527307	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
527308	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	450	
527309	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	447	
527310	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
527311	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
527312	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
527313	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
527314	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
527315	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
527316	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
527317	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
527318	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
527319	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
527320	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Foundation Condition	Good	
527321	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
527322	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
527323	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Amps C Ø	100.0	
527324	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Amps B Ø	270.0	
527325	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Amps A Ø	250.0	
527326	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Accumulated Fault Duty C Ph AM	3.99	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
527327	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
527328	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
527329	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Accumulated Fault Duty B Ph AM	2.66	%
527330	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Accumulated Fault Duty A Ph AM	6.64	%
527331	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	9 Months Operations	4	
527332	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
527333	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	2	
527334	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	2	
527335	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
527336	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	1.43	
527337	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	1.43	
527338	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
527339	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
527340	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
527341	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
527342	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
527343	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
527344	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
527345	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	40.0	
527346	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	40.0	
527347	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	40.0	
527348	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
527349	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
527350	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Paint Condition	Good	
527351	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Equipment Properly Labeled?	y	
527352	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
527353	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
527354	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
527355	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations A Ø	0	
527356	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations B Ø	0	
527357	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations C Ø	0	
527358	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations Ground	0	
527359	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Follow-up Action Required?	n	
527360	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Follow-up Action Required?	n	
527361	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Foundation Condition	Good	
527362	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
527363	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	General Comments		
527364	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
527365	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
527366	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
527367	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
527368	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	General Comments		
527369	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	General Comments		
527370	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
527371	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
527372	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
527373	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
527374	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Grounds in Place?	y	
527375	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Heaters (All) Functioning?	y	
527376	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Maintenance Operations	0	
527377	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Moisture and Leak Free?	y	
527378	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Operations Counter AF	99981	
527379	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Operations Counter AL	99981	
527380	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
527381	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Switching Operations	0	
527382	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Tank Paint Condition	Good	
527383	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Unknown Operations	0	
527384	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	3	
527385	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
527386	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
527387	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
527388	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
527389	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
527390	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
527391	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
527392	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
527393	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
527394	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
527395	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
527396	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Winding Temp Present	25	°C
527397	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Winding Temp Max	25	°C
527398	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Totalizer Meter Reading	.9036	
527399	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
527400	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
527401	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
527402	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
527403	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
527404	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
527405	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
527406	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
527407	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Oil Temp Present	35	°C
527408	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Oil Temp Max	36	°C
527409	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
527410	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
527411	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	LTC Totalizer Reading	16264.80	kw
527412	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
527413	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	General Comments		
527414	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	General Comments		
527415	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
527416	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
527417	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Follow-up Action Required?	n	
527418	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
527419	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
527420	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
527421	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
527422	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
527423	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
527424	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
527425	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
527426	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
527427	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
527428	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
527429	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
527430	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.23	%
527431	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.95	%
527432	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.03	%
527433	3/12/2019 10:53	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	12	
527434	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
527435	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
527436	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
527437	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
527438	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
527439	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
527440	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
527441	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	General Comments		
527442	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
527443	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
527444	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
527445	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
527446	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
527447	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	General Comments		
527448	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
527449	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Max Tap Position	7R	
527450	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
527451	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
527452	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
527453	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
527454	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
527455	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
527456	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Regulator As Left Counter	43237	
527457	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
527458	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Tank Leaks	None	
527459	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
527460	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
527461	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
527462	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
527463	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
527464	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
527465	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
527466	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
527467	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
527468	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
527469	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
527470	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
527471	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
527472	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
527473	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	LTC Totalizer Reading	3949.20	kw
527474	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
527475	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
527476	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	9 Months Operations	2	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
527477	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Accumulated Fault Duty A Ph AM	2.66	%
527478	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Accumulated Fault Duty B Ph AM	34.55	%
527479	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Accumulated Fault Duty C Ph AM	5.32	%
527480	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Amps A Ø	200.0	
527481	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Amps B Ø	250.0	
527482	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
527483	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Oil Temp Max	40	°C
527484	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
527485	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
527486	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
527487	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
527488	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
527489	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
527490	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
527491	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
527492	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Totalizer Meter Reading	.6582	
527493	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
527494	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
527495	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Amps C Ø	200.0	
527496	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
527497	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
527498	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
527499	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
527500	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	General Comments		
527501	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
527502	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Vegetation	None	
527503	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
527504	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	General Comments		
527505	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
527506	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
527507	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
527508	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
527509	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
527510	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations A Ø	0	
527511	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
527512	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
527513	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
527514	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
527515	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
527516	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
527517	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
527518	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
527519	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
527520	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
527521	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
527522	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
527523	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
527524	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	General Comments		
527525	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
527526	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
527527	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Foundation Condition	Good	
527528	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
527529	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
527530	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
527531	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
527532	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
527533	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
527534	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
527535	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Clear of Trash?	y	
527536	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
527537	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
527538	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
527539	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
527540	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
527541	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
527542	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
527543	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
527544	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
527545	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
527546	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
527547	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
527548	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
527549	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Follow-up Action Required?	n	
527550	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
527551	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
527552	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	General Comments		
527553	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	General Comments		
527554	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
527555	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	General Comments		
527556	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Patrol Inspection	General Comments		
527557	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
527558	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
527559	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
527560	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
527561	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
527562	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
527563	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Regulator As Left Counter	39617	
527564	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
527565	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Tank Leaks	None	
527566	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
527567	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Follow-up Action Required?	n	
527568	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Patrol Inspection	General Comments		
527569	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Follow-up Action Required?	n	
527570	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Patrol Inspection	Follow-up Action Required?	n	
527571	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations Ground	0	
527572	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	General Comments		
527573	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Maintenance Operations	0	
527574	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations C Ø	0	
527575	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations B Ø	0	
527576	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	9 Month Operations	17	
527577	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Accumulated Fault Duty A Ph V	20.65	%
527578	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Operations Counter AF	930	
527579	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Accumulated Fault Duty B Ph V	16.72	%
527580	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Accumulated Fault Duty C Ph V	18.68	%
527581	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Amps A Ø	133.0	
527582	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations A Ø	0	
527583	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
527584	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
527585	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Operations Counter AL	930	
527586	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Switching Operations	0	
527587	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Unknown Operations	0	
527588	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
527589	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
527590	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Amps B Ø	164.0	
527591	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Amps C Ø	176.0	
527592	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Bushing Condition	Good	
527593	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Bushings Connection/Risers	Good	
527594	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
527595	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Clear of Trash?	y	
527596	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
527597	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
527598	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
527599	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	General Comments	Fabric and top rails rusty.	
527600	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
527601	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
527602	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
527603	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
527604	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
527605	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
527606	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
527607	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
527608	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
527609	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
527610	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
527611	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
527612	3/12/2019 11:15	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
527613	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Unknown Operations	0	
527614	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Switching Operations	0	
527615	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Operations Counter AL	619	
527616	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Operations Counter AF	619	
527617	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Maintenance Operations	0	
527618	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations B Ø	0	
527619	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations C Ø	0	
527620	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations Ground	0	
527621	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Patrol Inspection	Follow-up Action Required?	n	
527622	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
527623	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
527624	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
527625	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
527626	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
527627	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
527628	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
527629	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
527630	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
527631	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
527632	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	General Comments		
527633	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
527634	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
527635	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Vegetation	None	
527636	3/12/2019 12:23	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
527637	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
527638	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
527639	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	General Comments		
527640	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Grounds in Place?	y	
527641	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Heaters (All) Functioning?	y	
527642	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Maintenance Operations	0	
527643	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Moisture and Leak Free?	y	
527644	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Operations Counter AF	389	
527645	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Operations Counter AL	394	
527646	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Accumulated Fault Duty A Ph V	.91	%
527647	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Accumulated Fault Duty B Ph V	.46	%
527648	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Accumulated Fault Duty C Ph V	.46	%
527649	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Amps A Ø	109.0	
527650	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Amps B Ø	108.0	
527651	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Amps C Ø	101.0	
527652	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Bushing Condition	Good	
527653	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Bushings Connection/Risers	Good	
527654	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
527655	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
527656	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
527657	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Paint Condition	Good	
527658	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Equipment Properly Labeled?	y	
527659	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
527660	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
527661	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
527662	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
527663	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
527664	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
527665	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
527666	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	General Comments		
527667	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
527668	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
527669	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Switching Operations	5	
527670	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
527671	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
527672	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
527673	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations A Ø	0	
527674	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations B Ø	0	
527675	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations C Ø	0	
527676	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations Ground	0	
527677	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Follow-up Action Required?	n	
527678	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Follow-up Action Required?	n	
527679	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Foundation Condition	Good	
527680	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	General Comments		
527681	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	General Comments		
527682	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Grounds in Place?	y	
527683	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Maintenance Operations	0	
527684	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Moisture and Leak Free?	y	
527685	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Tank Paint Condition	Good	
527686	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
527687	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
527688	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
527689	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
527690	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
527691	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
527692	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
527693	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
527694	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Cabinet Paint Condition	Good	
527695	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Equipment Properly Labeled?	y	
527696	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
527697	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
527698	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
527699	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
527700	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations A Ø	0	
527701	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
527702	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
527703	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	Follow-up Action Required?	n	
527704	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
527705	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	General Comments		
527706	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	General Comments	NEW COUNTER	
527707	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC As Found Counter	10400	
527708	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC As Left Counter	7	
527709	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
527710	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Current Tap Position	9L	
527711	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	9 Month Operations	2	
527712	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Max Tap Position	2L	
527713	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Min Tap Position	12L	
527714	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Operations Since Last Insp	1210	
527715	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
527716	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Operations A Ø	0	
527717	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Operations B Ø	0	
527718	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Operations C Ø	0	
527719	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Operations Ground	0	
527720	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Follow-up Action Required?	n	
527721	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations C Ø	0	
527722	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations Ground	0	
527723	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Follow-up Action Required?	n	
527724	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Follow-up Action Required?	n	
527725	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Foundation Condition	Good	
527726	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	General Comments		
527727	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	General Comments		
527728	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Grounds in Place?	y	
527729	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
527730	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
527731	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
527732	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
527733	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Follow-up Action Required?	n	
527734	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Foundation Condition	Good	
527735	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	General Comments		
527736	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
527737	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Maintenance Operations	0	
527738	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
527739	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Operations Counter AF	213	
527740	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Operations Counter AL	213	
527741	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
527742	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Switching Operations	0	
527743	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Tank Paint Condition	Good	
527744	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Unknown Operations	0	
527745	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
527746	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
527747	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
527748	3/12/2019 12:18	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
527749	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Amps C Ø	57.0	
527750	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Bushing Condition	Good	
527751	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Bushings Connection/Risers	Good	
527752	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
527753	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
527754	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	39	°F
527755	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
527756	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
527757	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Paint Condition	Good	
527758	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Equipment Properly Labeled?	y	
527759	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
527760	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
527761	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
527762	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations A Ø	0	
527763	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations B Ø	0	
527764	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations C Ø	0	
527765	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations Ground	0	
527766	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Follow-up Action Required?	n	
527767	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Follow-up Action Required?	n	
527768	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Foundation Condition	Good	
527769	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	General Comments		
527770	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	General Comments		
527771	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Grounds in Place?	y	
527772	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Heaters (All) Functioning?	y	
527773	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
527774	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	9 Month Operations	13	
527775	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
527776	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
527777	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
527778	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Amps A Ø	0.0	
527779	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Maintenance Operations	0	
527780	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Moisture and Leak Free?	y	
527781	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Amps B Ø	0.0	
527782	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Operations Counter AF	869	
527783	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Operations Counter AL	869	
527784	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
527785	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Switching Operations	0	
527786	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Tank Paint Condition	Good	
527787	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Unknown Operations	0	
527788	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Amps C Ø	0.0	
527789	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Bushing Condition	Good	
527790	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Bushings Connection/Risers	Good	
527791	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
527792	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
527793	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
527794	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Paint Condition	Good	
527795	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Equipment Properly Labeled?	y	
527796	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
527797	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
527798	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
527799	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations A Ø	0	
527800	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations B Ø	0	
527801	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations C Ø	0	
527802	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	Follow-up Action Required?	n	
527803	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
527804	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	General Comments		
527805	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
527806	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Operations Counter AF	176	
527807	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
527808	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Operations Counter AL	177	
527809	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Switching Operations	1	
527810	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Tank Paint Condition	Good	
527811	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Unknown Operations	0	
527812	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Unknown Operations	0	
527813	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Unknown Operations	0	
527814	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	PF000019	PowerFuse	BI-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
527815	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	PF000019	PowerFuse	BI-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
527816	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
527817	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
527818	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Tank Paint Condition	Good	
527819	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Switching Operations	4	
527820	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
527821	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Operations Counter AL	610	
527822	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Operations Counter AF	606	
527823	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Moisture and Leak Free?	y	
527824	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Maintenance Operations	0	
527825	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Heaters (All) Functioning?	y	
527826	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Grounds in Place?	y	
527827	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
527828	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
527829	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
527830	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
527831	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
527832	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	General Comments		
527833	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	General Comments		
527834	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Foundation Condition	Good	
527835	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Follow-up Action Required?	n	
527836	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
527837	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Follow-up Action Required?	n	
527838	3/12/2019 15:08	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations Ground	0	
527839	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
527840	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
527841	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
527842	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
527843	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	General Comments		
527844	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
527845	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
527846	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
527847	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Operations Since Last Insp	350	
527848	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Min Tap Position	8L	
527849	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Max Tap Position	1L	
527850	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Current Tap Position	6L	
527851	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
527852	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC As Left Counter	57959	
527853	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC As Found Counter	57959	
527854	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	General Comments		
527855	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	9 Month Operations	22	
527856	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Accumulated Fault Duty A Ph V	8.76	%
527857	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Accumulated Fault Duty B Ph V	6.57	%
527858	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Accumulated Fault Duty C Ph V	7.67	%
527859	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Amps A Ø	55.0	
527860	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Amps B Ø	44.0	
527861	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
527862	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	LTCC000202	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
527863	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	9 Month Operations	0	
527864	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	LTCC000202	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
527865	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	LTCC000202	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
527866	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
527867	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
527868	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
527869	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
527870	3/12/2019 13:10	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
527871	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
527872	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
527873	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
527874	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Bushing Condition	Good	
527875	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Amps C Ø	430.0	
527876	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Amps B Ø	450.0	
527877	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Amps A Ø	450.0	
527878	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
527879	3/12/2019 11:45	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
527880	3/12/2019 15:39	Distribution	Morehead Quarterly Inspection	LTCC000202	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
527881	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
527882	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
527883	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
527884	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
527885	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
527886	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
527887	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
527888	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
527889	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
527890	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
527891	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
527892	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
527893	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
527894	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
527895	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
527896	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Unknown Operations	0	
527897	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Switching Operations	2	
527898	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AL	607	
527899	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AF	607	
527900	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Num Operations Last 9 Months	7	
527901	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Maintenance Operations	5	
527902	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	General Comments		
527903	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Follow-up Action Required?	n	
527904	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Fault Operations	0	
527905	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Amps C Ø	3.0	
527906	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Amps B Ø	4.0	
527907	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Amps A Ø	4.0	
527908	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Amps C Ø	29.0	
527909	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Fault Operations	0	
527910	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Follow-up Action Required?	n	
527911	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Amps B Ø	32.0	
527912	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Unknown Operations	0	
527913	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Amps A Ø	32.0	
527914	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Switching Operations	2	
527915	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AL	660	
527916	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	General Comments		
527917	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Maintenance Operations	0	
527918	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Num Operations Last 9 Months	2	
527919	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AF	660	
527920	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AL	421	
527921	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Switching Operations	0	
527922	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Unknown Operations	0	
527923	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AF	421	
527924	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Num Operations Last 9 Months	10	
527925	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Maintenance Operations	10	
527926	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
527927	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Follow-up Action Required?	n	
527928	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Fault Operations	0	
527929	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Amps C Ø	0.0	
527930	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Amps B Ø	0.0	
527931	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Amps A Ø	0.0	
527932	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Tank Paint Condition	Good	
527933	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
527934	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Bushing Condition	Good	
527935	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Moisture and Leak Free?	y	
527936	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Heaters (All) Functioning?	y	
527937	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Grounds in Place?	y	
527938	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Bushings Connection/Risers	Good	
527939	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
527940	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
527941	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Paint Condition	Good	
527942	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
527943	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Follow-up Action Required?	n	
527944	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Foundation Condition	Good	
527945	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	General Comments		
527946	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Moisture and Leak Free?	y	
527947	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Bushings Connection/Risers	Good	
527948	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
527949	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
527950	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Bushing Condition	Good	
527951	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
527952	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Tank Paint Condition	Good	
527953	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Heaters (All) Functioning?	y	
527954	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Grounds in Place?	y	
527955	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	General Comments		
527956	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Foundation Condition	Good	
527957	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Follow-up Action Required?	n	
527958	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
527959	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Paint Condition	Good	
527960	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Paint Condition	Good	
527961	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
527962	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Follow-up Action Required?	n	
527963	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Foundation Condition	Good	
527964	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	General Comments		
527965	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
527966	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Tank Paint Condition	Good	
527967	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Grounds in Place?	y	
527968	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Heaters (All) Functioning?	y	
527969	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Moisture and Leak Free?	y	
527970	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Bushing Condition	Good	
527971	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
527972	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
527973	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Bushings Connection/Risers	Good	
527974	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
527975	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	322	
527976	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
527977	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
527978	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
527979	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments	ok	
527980	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
527981	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
527982	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
527983	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	247	
527984	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	41.6	
527985	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
527986	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	36.1	
527987	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	26.9	
527988	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	231	
527989	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	215620	
527990	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
527991	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
527992	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Paint Condition	Good	
527993	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Patrol Inspection	General Comments		
527994	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	General Comments		
527995	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
527996	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
527997	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
527998	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
527999	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
528000	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
528001	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	9 Month Operations	1	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
528002	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
528003	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
528004	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
528005	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Bushing Condition	Good	
528006	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Bushings Connection/Risers	Good	
528007	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
528008	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
528009	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
528010	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
528011	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
528012	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Paint Condition	Good	
528013	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
528014	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Equipment Properly Labeled?	y	
528015	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
528016	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
528017	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
528018	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
528019	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
528020	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
528021	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
528022	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Bushings Connection/Risers	Good	
528023	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Bushing Condition	Good	
528024	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Patrol Inspection	Equipment Properly Labeled?	y	
528025	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
528026	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Amps A Ø	420.0	
528027	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
528028	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Amps C Ø	0.0	
528029	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Equipment Properly Labeled?	y	
528030	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Amps B Ø	435.0	
528031	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
528032	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
528033	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Amps C Ø	415.0	
528034	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Paint Condition	Good	
528035	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations A Ø	0	
528036	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	9 Month Operations	9	
528037	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Bushing Condition	Good	
528038	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Bushings Connection/Risers	Good	
528039	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
528040	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
528041	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
528042	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Operations Counter AL	312	
528043	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Switching Operations	0	
528044	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Unknown Operations	0	
528045	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
528046	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
528047	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
528048	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
528049	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
528050	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
528051	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
528052	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
528053	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BCH000229	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
528054	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
528055	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
528056	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
528057	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
528058	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	General Comments		
528059	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
528060	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Accumulated Fault Duty B Ph V	.22	%
528061	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
528062	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
528063	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Amps A Ø	100.0	
528064	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Amps B Ø	100.0	
528065	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Amps C Ø	100.0	
528066	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Amps B Ø	0.0	
528067	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Amps A Ø	0.0	
528068	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Clear of Trash?	y	
528069	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
528070	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
528071	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
528072	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
528073	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
528074	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Trash Emptied?	y	
528075	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
528076	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
528077	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	LTC Totalizer Reading	6168.96	kw
528078	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
528079	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	General Comments		
528080	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Bushing Condition	Good	
528081	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Bushings Connection/Risers	Good	
528082	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BCH000229	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
528083	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
528084	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BCH000229	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
528085	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BCH000229	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
528086	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations B Ø	0	
528087	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Panels Dusted?	y	
528088	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
528089	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations A Ø	0	
528090	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations B Ø	0	
528091	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations C Ø	0	
528092	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
528093	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations Ground	0	
528094	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
528095	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
528096	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Follow-up Action Required?	n	
528097	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Follow-up Action Required?	n	
528098	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Foundation Condition	Good	
528099	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	General Comments		
528100	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	4L	
528101	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	2R	
528102	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
528103	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
528104	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
528105	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
528106	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	General Comments		
528107	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
528108	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Grounds in Place?	y	
528109	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Heaters (All) Functioning?	y	
528110	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Maintenance Operations	0	
528111	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Moisture and Leak Free?	y	
528112	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Operations Counter AF	172	
528113	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Operations Counter AL	172	
528114	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Switching Operations	0	
528115	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
528116	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
528117	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
528118	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
528119	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
528120	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
528121	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
528122	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
528123	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
528124	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Maintenance Operations	0	
528125	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
528126	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
528127	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
528128	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
528129	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Operations Counter AF	312	
528130	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
528131	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Vegetation	None	
528132	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
528133	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	General Comments		
528134	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
528135	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0226	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
528136	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0226	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
528137	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0226	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
528138	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0226	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
528139	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0226	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
528140	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0226	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
528141	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0226	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
528142	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0226	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
528143	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0226	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
528144	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
528145	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	8	
528146	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	29.12	%
528147	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	24.27	%
528148	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	General Comments		
528149	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	8.49	%
528150	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	200.0	
528151	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	200.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
528152	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
528153	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	200.0	
528154	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Follow-up Action Required?	n	
528155	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
528156	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Patrol Inspection	Follow-up Action Required?	n	
528157	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Operations Ground	0	
528158	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Operations C Ø	0	
528159	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
528160	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
528161	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
528162	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
528163	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
528164	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
528165	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Clear of Trash?	y	
528166	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
528167	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
528168	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
528169	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
528170	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	General Comments		
528171	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
528172	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
528173	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
528174	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
528175	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
528176	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
528177	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
528178	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
528179	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
528180	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
528181	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
528182	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
528183	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	General Comments		
528184	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
528185	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
528186	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
528187	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Vegetation	None	
528188	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
528189	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Unknown Operations	0	
528190	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
528191	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
528192	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
528193	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Equipment Properly Labeled?	y	
528194	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Paint Condition	Good	
528195	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
528196	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
528197	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
528198	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Bushings Connection/Risers	Good	
528199	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Bushing Condition	Good	
528200	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Amps C Ø	49.0	
528201	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations A Ø	0	
528202	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations B Ø	0	
528203	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations C Ø	0	
528204	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations Ground	0	
528205	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Follow-up Action Required?	n	
528206	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Follow-up Action Required?	n	
528207	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Foundation Condition	Good	
528208	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	General Comments		
528209	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	General Comments		
528210	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0226	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
528211	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Amps B Ø	58.0	
528212	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Amps A Ø	59.0	
528213	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
528214	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
528215	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	79	
528216	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	79	
528217	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
528218	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
528219	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
528220	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
528221	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
528222	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Accumulated Fault Duty B Ph V	1.02	%
528223	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Accumulated Fault Duty A Ph V	2.72	%
528224	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	9 Month Operations	6	
528225	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0226	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
528226	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
528227	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
528228	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
528229	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
528230	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0226	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
528231	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0226	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
528232	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
528233	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0226	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
528234	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0226	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
528235	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Grounds in Place?	y	
528236	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Maintenance Operations	0	
528237	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Moisture and Leak Free?	y	
528238	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
528239	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Operations Counter AF	175	
528240	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Operations Counter AL	175	
528241	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Switching Operations	0	
528242	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0226	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
528243	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0226	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
528244	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0226	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
528245	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0226	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
528246	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	All Connections OK?	y	
528247	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	Follow-up Action Required?	n	
528248	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Maintenance Operations	0	
528249	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	General Comments	ok	
528250	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
528251	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Operations Counter AL	234	
528252	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Operations Counter AF	234	
528253	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Grounds in Place?	y	
528254	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	General Comments		
528255	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Moisture and Leak Free?	y	
528256	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Maintenance Operations	0	
528257	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Heaters (All) Functioning?	y	
528258	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
528259	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Grounds in Place?	y	
528260	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	General Comments		
528261	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	General Comments		
528262	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Foundation Condition	Good	
528263	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Follow-up Action Required?	n	
528264	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Follow-up Action Required?	n	
528265	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations Ground	0	
528266	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations C Ø	0	
528267	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations B Ø	0	
528268	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Accumulated Fault Duty C Ph V	.62	%
528269	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Amps A Ø	0.0	
528270	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Amps B Ø	0.0	
528271	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Amps C Ø	8.0	
528272	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	General Comments		
528273	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Bushing Condition	Good	
528274	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Bushings Connection/Risers	Good	
528275	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations A Ø	0	
528276	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
528277	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Oil Temp Max	38	°C
528278	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Foundation Condition	Good	
528279	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Oil Temp Present	33	°C
528280	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
528281	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
528282	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Equipment Properly Labeled?	y	
528283	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
528284	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
528285	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Paint Condition	Good	
528286	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
528287	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
528288	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
528289	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
528290	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
528291	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
528292	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
528293	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Follow-up Action Required?	n	
528294	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Accumulated Fault Duty C Ph V	3.36	%
528295	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Follow-up Action Required?	n	
528296	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Fault Operations	0	
528297	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Tank Paint Condition	Good	
528298	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Unknown Operations	0	
528299	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
528300	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
528301	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
528302	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	53	°F
528303	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
528304	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	VRR Time Delay	30	Seconds
528305	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
528306	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
528307	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
528308	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
528309	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
528310	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
528311	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Tank Oil Level	Good	
528312	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
528313	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
528314	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
528315	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	LTC Operation Checked?	y	
528316	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	General Comments		
528317	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
528318	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	Follow-up Action Required?	n	
528319	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Tank Leaks	None	
528320	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Switching Operations	0	
528321	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
528322	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Operations Counter AL	357	
528323	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Operations Counter AF	357	
528324	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	All Connections OK?	y	
528325	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	9 Month Operations	2	
528326	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Accumulated Fault Duty A Ph V	.62	%
528327	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Accumulated Fault Duty B Ph V	.62	%
528328	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	All Connections OK?	y	
528329	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Current Tap Position	4R	
528330	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Follow-up Action Required?	n	
528331	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	General Comments		
528332	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Max Tap Position	5R	
528333	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Min Tap Position	Neutral	
528334	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
528335	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
528336	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
528337	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Base Voltage AF	124.0	VAC
528338	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Base Voltage AL	124.0	VAC
528339	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
528340	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
528341	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Time Delay	45	Seconds
528342	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0226	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
528343	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
528344	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
528345	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
528346	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
528347	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
528348	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0226	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
528349	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	9 Month Operations	2	
528350	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Accumulated Fault Duty A Ph V	3.36	%
528351	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Number of Ops last 9 Months	0	
528352	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Moisture and Leak Free?	y	
528353	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Accumulated Fault Duty B Ph V	3.41	%
528354	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Unknown Operations	0	
528355	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Tank Paint Condition	Good	
528356	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Switching Operations	0	
528357	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
528358	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
528359	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
528360	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
528361	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
528362	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
528363	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Rubber Cracks	
528364	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
528365	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
528366	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
528367	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Tank Leaks	None	
528368	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
528369	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
528370	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Regulator As Left Counter	22283	
528371	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
528372	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
528373	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
528374	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
528375	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
528376	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
528377	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
528378	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
528379	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
528380	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
528381	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	General Comments		
528382	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
528383	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
528384	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
528385	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
528386	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
528387	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
528388	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
528389	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
528390	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
528391	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
528392	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
528393	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Tank Leaks	None	
528394	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
528395	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
528396	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Regulator As Left Counter	21106	
528397	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
528398	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
528399	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
528400	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
528401	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
528402	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
528403	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
528404	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
528405	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
528406	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
528407	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	General Comments		
528408	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
528409	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
528410	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
528411	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
528412	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
528413	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
528414	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
528415	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
528416	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
528417	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
528418	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
528419	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
528420	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
528421	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
528422	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
528423	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
528424	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
528425	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
528426	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
528427	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
528428	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
528429	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
528430	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
528431	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
528432	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
528433	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
528434	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Totalizer Meter Reading	.6426	
528435	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
528436	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
528437	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
528438	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
528439	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
528440	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
528441	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	200.00	
528442	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2000	psi
528443	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
528444	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
528445	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
528446	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
528447	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
528448	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Totalizer Meter Reading	.7992	
528449	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
528450	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
528451	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
528452	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
528453	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
528454	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
528455	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	General Comments	ok	
528456	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	General Comments	ok	
528457	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Grounds in Place?	y	
528458	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
528459	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Maintenance Operations	0	
528460	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
528461	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Operations Counter AF	73	
528462	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Operations Counter AL	73	
528463	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
528464	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Switching Operations	0	
528465	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Tank Paint Condition	Good	
528466	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Unknown Operations	0	
528467	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
528468	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
528469	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Fans Operational?	n	
528470	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
528471	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
528472	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
528473	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
528474	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
528475	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
528476	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
528477	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
528478	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
528479	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Operations A Ø	0	
528480	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Operations B Ø	0	
528481	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Operations C Ø	0	
528482	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Operations Ground	0	
528483	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Follow-up Action Required?	n	
528484	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Follow-up Action Required?	n	
528485	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Foundation Condition	Good	
528486	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	General Comments		
528487	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Follow-up Action Required?	n	
528488	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
528489	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
528490	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
528491	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	General Comments		
528492	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Grounds in Place?	y	
528493	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
528494	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Maintenance Operations	0	
528495	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
528496	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
528497	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
528498	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
528499	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
528500	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
528501	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
528502	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Foundation Condition	Good	
528503	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
528504	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
528505	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	General Comments	PT conduit needs attention. 603 switch handle needs ground braid. Need 2 more fuses	
528506	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
528507	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
528508	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
528509	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	3	
528510	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
528511	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
528512	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
528513	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
528514	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
528515	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
528516	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
528517	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
528518	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
528519	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
528520	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
528521	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
528522	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.8448	
528523	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Operations Counter AF	218	
528524	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Operations Counter AL	218	
528525	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
528526	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
528527	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
528528	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
528529	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
528530	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	827	
528531	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	827	
528532	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
528533	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
528534	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
528535	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
528536	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
528537	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
528538	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
528539	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
528540	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
528541	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
528542	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
528543	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Switching Operations	0	
528544	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Tank Paint Condition	Good	
528545	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Unknown Operations	0	
528546	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
528547	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
528548	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
528549	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
528550	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
528551	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
528552	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
528553	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	General Comments		
528554	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
528555	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
528556	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
528557	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	9 Month Operations	1	
528558	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Accumulated Fault Duty A Ph V	.55	%
528559	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
528560	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Accumulated Fault Duty C Ph V	.55	%
528561	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Accumulated Fault Duty B Ph V	.55	%
528562	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
528563	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
528564	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
528565	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
528566	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
528567	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
528568	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
528569	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
528570	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
528571	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
528572	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
528573	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
528574	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
528575	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
528576	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
528577	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
528578	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
528579	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
528580	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
528581	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
528582	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
528583	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
528584	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
528585	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
528586	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
528587	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
528588	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
528589	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
528590	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
528591	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	928	
528592	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
528593	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
528594	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	6082.56	kw
528595	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
528596	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
528597	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	55	°C
528598	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	30	°C
528599	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
528600	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
528601	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
528602	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
528603	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	16	
528604	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	1.21	%
528605	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	1.21	%
528606	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	1.21	%
528607	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	140.0	
528608	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	220.0	
528609	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	125.0	
528610	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
528611	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
528612	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
528613	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
528614	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
528615	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
528616	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
528617	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
528618	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
528619	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments		
528620	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	156299	
528621	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	156299	
528622	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
528623	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
528624	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
528625	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
528626	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	928	
528627	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
528628	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
528629	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
528630	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
528631	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
528632	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	2L	
528633	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	4L	
528634	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	8L	
528635	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	397	
528636	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
528637	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
528638	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
528639	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
528640	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
528641	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	5	
528642	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	4.85	%
528643	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	13.35	%
528644	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	6.07	%
528645	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	160.0	
528646	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	160.0	
528647	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	140.0	
528648	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
528649	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
528650	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
528651	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
528652	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
528653	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
528654	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
528655	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
528656	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
528657	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
528658	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
528659	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Equipment Properly Labeled?	y	
528660	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Paint Condition	Good	
528661	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
528662	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
528663	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
528664	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Bushings Connection/Risers	Good	
528665	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
528666	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
528667	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
528668	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	General Comments		
528669	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
528670	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
528671	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Foundation Condition	Good	
528672	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Bushing Condition	Good	
528673	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
528674	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
528675	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
528676	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
528677	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
528678	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
528679	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Amps C Ø	155.0	
528680	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	LTC Totalizer Reading	6606.72	kw
528681	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	PF000143	PowerFuse	FV-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
528682	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	PF000143	PowerFuse	FV-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	oik	
528683	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
528684	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
528685	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Oil Temp Max	60	°C
528686	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Oil Temp Present	30	°C
528687	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
528688	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
528689	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	PF000144	PowerFuse	FV-STA SER NO 8	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
528690	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	PF000144	PowerFuse	FV-STA SER NO 8	Disconnect Powerfuse Inspection	General Comments	ok	
528691	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
528692	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
528693	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
528694	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
528695	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Amps B Ø	117.0	
528696	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
528697	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
528698	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
528699	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Amps A Ø	126.0	
528700	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Accumulated Fault Duty C Ph V	6.46	%
528701	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Accumulated Fault Duty B Ph V	3.06	%
528702	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Accumulated Fault Duty A Ph V	10.54	%
528703	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
528704	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
528705	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
528706	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Patrol Inspection	Equipment Properly Labeled?	y	
528707	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Amps C Ø	400.0	
528708	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Amps B Ø	400.0	
528709	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
528710	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
528711	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	916	
528712	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	916	
528713	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
528714	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Evidence of Insects	None	
528715	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Follow-up Action Required?	n	
528716	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Follow-up Action Required?	n	
528717	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
528718	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
528719	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
528720	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
528721	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
528722	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
528723	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
528724	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Broom on Site?	y	
528725	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
528726	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
528727	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
528728	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
528729	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
528730	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
528731	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations C Ø	0	
528732	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	7	
528733	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	10.40	%
528734	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	10.40	%
528735	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	10.40	%
528736	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
528737	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
528738	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
528739	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Patrol Inspection	Follow-up Action Required?	n	
528740	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Patrol Inspection	General Comments		
528741	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
528742	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations Ground	0	
528743	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
528744	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
528745	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
528746	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
528747	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
528748	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
528749	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
528750	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
528751	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
528752	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
528753	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
528754	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
528755	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
528756	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
528757	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
528758	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	General Comments		
528759	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
528760	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
528761	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Floor Swept?	y	
528762	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
528763	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
528764	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Follow-up Action Required?	n	
528765	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
528766	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
528767	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
528768	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	70	
528769	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	70	
528770	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
528771	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
528772	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Tank Paint Condition	Good	
528773	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Unknown Operations	0	
528774	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Operations B Ø	0	
528775	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Operations A Ø	0	
528776	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Unknown Operations	0	
528777	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Tank Paint Condition	Good	
528778	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Switching Operations	1	
528779	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Operations Counter AL	234	
528780	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	General Comments		
528781	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	General Comments		
528782	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Operations Counter AF	234	
528783	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Moisture and Leak Free?	y	
528784	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Maintenance Operations	0	
528785	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Grounds in Place?	y	
528786	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
528787	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	General Comments		
528788	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	General Comments		
528789	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Foundation Condition	Good	
528790	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Follow-up Action Required?	n	
528791	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Follow-up Action Required?	n	
528792	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations Ground	0	
528793	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations C Ø	0	
528794	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations B Ø	0	
528795	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations A Ø	0	
528796	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
528797	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
528798	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
528799	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
528800	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
528801	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
528802	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
528803	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
528804	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
528805	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
528806	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
528807	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	9 Month Operations	0	
528808	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations C Ø	0	
528809	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations Ground	0	
528810	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Follow-up Action Required?	n	
528811	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
528812	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
528813	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
528814	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
528815	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
528816	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
528817	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Winding Temp Present	14	°C
528818	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Winding Temp Max	22	°C
528819	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
528820	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
528821	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
528822	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
528823	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
528824	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
528825	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
528826	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
528827	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
528828	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	78	
528829	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
528830	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
528831	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
528832	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
528833	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Follow-up Action Required?	n	
528834	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Foundation Condition	Good	
528835	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	General Comments		
528836	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	General Comments		
528837	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2696.64	kw
528838	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
528839	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
528840	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
528841	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	General Comments	Fans do not work no incoming power	
528842	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	General Comments		
528843	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
528844	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
528845	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
528846	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
528847	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
528848	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Oil Temp Present	18	°C
528849	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
528850	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
528851	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
528852	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Amps A Ø	650.0	
528853	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Amps B Ø	640.0	
528854	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Amps C Ø	645.0	
528855	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
528856	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
528857	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Bushing Condition	Good	
528858	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
528859	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
528860	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	PF000145	PowerFuse	FV-14KV TR 8 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
528861	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	PF000145	PowerFuse	FV-14KV TR 8 POT	Disconnect Powerfuse Inspection	General Comments	ok	
528862	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
528863	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
528864	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
528865	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
528866	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Follow-up Action Required?	n	
528867	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
528868	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
528869	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	General Comments		
528870	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	General Comments		
528871	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Oil Temp Max	60	°C
528872	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
528873	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	LTC Totalizer Reading	7672.32	kw
528874	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
528875	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-2.0	psi
528876	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Oil Temp Max	55	°C
528877	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Oil Temp Present	40	°C
528878	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
528879	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
528880	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	9 Month Operations	21	
528881	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
528882	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
528883	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
528884	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
528885	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
528886	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
528887	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
528888	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
528889	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
528890	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Amps A Ø	400.0	
528891	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.6854	
528892	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
528893	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
528894	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
528895	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
528896	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
528897	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
528898	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
528899	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
528900	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	General Comments		
528901	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
528902	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC As Found Counter	82279	
528903	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC As Left Counter	82279	
528904	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
528905	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
528906	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	9 Month Operations	0	
528907	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
528908	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
528909	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
528910	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Amps A Ø	490.0	
528911	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
528912	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
528913	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
528914	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
528915	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
528916	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
528917	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	General Comments		
528918	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
528919	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Foundation Condition	Good	
528920	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	General Comments	ok	
528921	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	General Comments	ok	
528922	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Grounds in Place?	y	
528923	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Heaters (All) Functioning?	y	
528924	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Maintenance Operations	0	
528925	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Moisture and Leak Free?	y	
528926	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Totalizer Meter Reading	.6882	
528927	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
528928	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Operations Counter AF	218	
528929	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Operations Counter AL	0	
528930	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
528931	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Switching Operations	0	
528932	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Tank Paint Condition	Good	
528933	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Unknown Operations	0	
528934	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
528935	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
528936	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
528937	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
528938	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
528939	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Amps B Ø	500.0	
528940	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Amps C Ø	477.0	
528941	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Bushing Condition	Good	
528942	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
528943	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
528944	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
528945	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
528946	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
528947	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
528948	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
528949	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
528950	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
528951	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations A Ø	0	
528952	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations B Ø	0	
528953	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
528954	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
528955	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
528956	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
528957	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
528958	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
528959	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
528960	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	General Comments		
528961	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
528962	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
528963	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
528964	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
528965	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
528966	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
528967	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
528968	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
528969	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Regulator As Left Counter	48269	
528970	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
528971	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
528972	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Tank Leaks	None	
528973	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
528974	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
528975	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Min Tap Position	12L	
528976	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Max Tap Position	4L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
528977	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Current Tap Position	7L	
528978	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
528979	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC As Left Counter	3735	
528980	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
528981	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
528982	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
528983	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
528984	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
528985	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
528986	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
528987	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
528988	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
528989	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
528990	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	General Comments		
528991	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
528992	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
528993	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
528994	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
528995	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
528996	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
528997	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
528998	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
528999	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
529000	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	General Comments		
529001	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
529002	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
529003	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
529004	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
529005	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
529006	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
529007	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
529008	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
529009	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
529010	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
529011	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
529012	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
529013	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
529014	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
529015	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Foundation Condition	Good	
529016	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
529017	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
529018	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	General Comments		
529019	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Regulator As Left Counter	109891	
529020	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
529021	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
529022	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Tank Leaks	None	
529023	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
529024	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
529025	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
529026	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
529027	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
529028	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
529029	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
529030	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
529031	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
529032	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
529033	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
529034	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
529035	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
529036	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
529037	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
529038	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
529039	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
529040	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
529041	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Tank Leaks	None	
529042	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
529043	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Operations Counter	48	
529044	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
529045	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
529046	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	General Comments		
529047	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
529048	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
529049	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
529050	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	VRR Time Delay	45	Seconds
529051	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
529052	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
529053	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
529054	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
529055	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	LTC Operation Checked?	y	
529056	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	General Comments		
529057	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	Follow-up Action Required?	n	
529058	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	All Connections OK?	y	
529059	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	Follow-up Action Required?	n	
529060	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
529061	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	General Comments		
529062	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	General Comments		
529063	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	9 Month Operations	71	
529064	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Accumulated Fault Duty A Ph V	13.86	%
529065	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Accumulated Fault Duty B Ph V	27.16	%
529066	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Accumulated Fault Duty C Ph V	13.30	%
529067	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Amps A Ø	150.0	
529068	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Amps B Ø	150.0	
529069	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Amps C Ø	150.0	
529070	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
529071	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
529072	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
529073	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC As Found Counter	4705	
529074	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC As Left Counter	4709	
529075	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
529076	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Current Tap Position	1L	
529077	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Max Tap Position	5R	
529078	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Min Tap Position	6L	
529079	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
529080	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Operations Since Last Insp	382	
529081	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
529082	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
529083	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
529084	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
529085	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Regulator As Left Counter	87704	
529086	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
529087	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
529088	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Tank Leaks	None	
529089	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
529090	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC As Found Counter	3735	
529091	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	General Comments		
529092	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	VRR Time Delay	30	Seconds
529093	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
529094	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	VRR Base Voltage AF	0.0	VAC
529095	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
529096	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
529097	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	LTC Operation Checked?	n	
529098	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	General Comments		
529099	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	Follow-up Action Required?	n	
529100	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	General Comments		
529101	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
529102	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	Follow-up Action Required?	n	
529103	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
529104	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	All Connections OK?	y	
529105	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
529106	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
529107	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Operations Since Last Insp	647	
529108	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Min Tap Position	7L	
529109	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Max Tap Position	4R	
529110	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
529111	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
529112	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC As Left Counter	2011	
529113	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BCH000919	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
529114	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BCH000919	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
529115	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BCH000919	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
529116	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BCH000919	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
529117	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BCH000919	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
529118	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BCH000919	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
529119	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LTCC000607	LTCControl	FV-TRANS 8	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
529120	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LTCC000607	LTCControl	FV-TRANS 8	LTC Control Insp	General Comments		
529121	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LTCC000607	LTCControl	FV-TRANS 8	LTC Control Insp	Follow-up Action Required?	n	
529122	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC As Found Counter	2002	
529123	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	General Comments	ok	
529124	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	General Comments		
529125	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
529126	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
529127	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
529128	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
529129	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
529130	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
529131	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
529132	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
529133	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Equipment Properly Labeled?	y	
529134	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
529135	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
529136	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	BCH000563	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
529137	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	BCH000563	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
529138	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	BCH000563	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
529139	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
529140	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	BCH000563	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
529141	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	BCH000563	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
529142	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	BCH000563	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
529143	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	LTCC000562	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
529144	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	LTCC000562	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
529145	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	LTCC000562	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
529146	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	LTCC000562	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
529147	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	LTCC000562	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Operation Checked?	y	
529148	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Paint Condition	Good	
529149	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
529150	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
529151	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
529152	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Bushings Connection/Risers	Good	
529153	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Bushing Condition	Good	
529154	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Amps C Ø	160.0	
529155	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Amps B Ø	130.0	
529156	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Amps A Ø	110.0	
529157	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Accumulated Fault Duty C Ph V	12.10	%
529158	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Accumulated Fault Duty B Ph V	11.43	%
529159	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	LTCC000562	LTCControl	932-Offline Distribution	LTC Control Insp	General Comments		
529160	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	LTCC000562	LTCControl	932-Offline Distribution	LTC Control Insp	Follow-up Action Required?	n	
529161	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	LTCC000562	LTCControl	932-Offline Distribution	LTC Control Insp	All Connections OK?	y	
529162	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Operations C Ø	0	
529163	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
529164	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
529165	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
529166	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
529167	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Accumulated Fault Duty A Ph V	10.75	%
529168	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	9 Month Operations	5	
529169	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
529170	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
529171	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1612	
529172	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Follow-up Action Required?	n	
529173	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
529174	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
529175	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
529176	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
529177	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	General Comments		
529178	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Follow-up Action Required?	n	
529179	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations Ground	0	
529180	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations C Ø	2	
529181	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	9 Month Operations	3	
529182	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Accumulated Fault Duty A Ph V	62.63	%
529183	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Accumulated Fault Duty B Ph V	60.96	%
529184	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Accumulated Fault Duty C Ph V	60.41	%
529185	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Amps A Ø	150.0	
529186	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Amps B Ø	150.0	
529187	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Amps C Ø	150.0	
529188	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Patrol Inspection	Equipment Properly Labeled?	y	
529189	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
529190	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
529191	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
529192	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Operations A Ø	0	
529193	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Operations B Ø	0	
529194	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations B Ø	0	
529195	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
529196	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
529197	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
529198	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
529199	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations A Ø	0	
529200	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Adjusted Amps C Phase V	8.38	
529201	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
529202	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
529203	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
529204	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
529205	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
529206	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
529207	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
529208	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
529209	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
529210	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
529211	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
529212	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
529213	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
529214	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
529215	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC Min Tap Position	8L	
529216	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC Operations Since Last Insp	556	
529217	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
529218	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
529219	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
529220	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
529221	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
529222	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
529223	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
529224	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	General Comments		
529225	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
529226	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	LTC Operation Checked?	y	
529227	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
529228	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
529229	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
529230	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	VRR Time Delay	30	Seconds
529231	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
529232	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
529233	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
529234	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Operations Since Last Insp	530	
529235	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
529236	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
529237	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
529238	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Clear of Trash?	y	
529239	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
529240	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
529241	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
529242	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
529243	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
529244	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
529245	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
529246	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
529247	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
529248	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
529249	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
529250	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
529251	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
529252	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	General Comments		
529253	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
529254	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
529255	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Vegetation	None	
529256	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
529257	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
529258	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Operations Ground	0	
529259	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Patrol Inspection	Follow-up Action Required?	n	
529260	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Follow-up Action Required?	n	
529261	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
529262	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
529263	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
529264	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
529265	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Patrol Inspection	General Comments		
529266	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	General Comments		
529267	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Maintenance Operations	0	
529268	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Operations Counter AF	124	
529269	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Operations Counter AL	124	
529270	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
529271	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
529272	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
529273	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	General Comments		
529274	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
529275	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Switching Operations	0	
529276	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
529277	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	All Connections OK?	y	
529278	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	Follow-up Action Required?	n	
529279	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	General Comments		
529280	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
529281	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
529282	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
529283	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
529284	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	General Comments	float has been changed to 55	
529285	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
529286	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
529287	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
529288	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
529289	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
529290	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
529291	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
529292	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
529293	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
529294	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
529295	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	Follow-up Action Required?	y	
529296	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	General Comments		
529297	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	General Comments	unable to reset min and max hands	
529298	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC As Found Counter	67639	
529299	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC As Left Counter	67639	
529300	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC Current Tap Position	5L	
529301	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC Max Tap Position	1L	
529302	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
529303	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
529304	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Tank Leaks	None	
529305	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
529306	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Operations Counter	95	
529307	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
529308	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
529309	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	General Comments		
529310	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
529311	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
529312	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
529313	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
529314	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
529315	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
529316	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
529317	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.5	VDC
529318	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.8	VDC
529319	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
529320	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
529321	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
529322	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
529323	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
529324	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
529325	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
529326	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
529327	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
529328	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
529329	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
529330	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
529331	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
529332	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
529333	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Winding Temp Present	33	°C
529334	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
529335	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
529336	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Amps C Ø	67.0	
529337	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Amps B Ø	63.0	
529338	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Amps A Ø	73.0	
529339	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Winding Temp Max	33	°C
529340	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Totalizer Meter Reading	1.4610	
529341	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
529342	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Top Oil Temperature Present	30	°C
529343	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Top Oil Temperature Max	40	°C
529344	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
529345	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
529346	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
529347	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
529348	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
529349	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
529350	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
529351	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
529352	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	General Comments		
529353	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	General Comments		
529354	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
529355	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
529356	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	General Comments		
529357	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
529358	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
529359	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
529360	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	292.32	kw
529361	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	26.00	
529362	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
529363	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Oil Temp Max	55	°C
529364	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
529365	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Patrol Inspection	Equipment Properly Labeled?	y	
529366	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Oil Temp Present	30	°C
529367	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
529368	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Amps C Ø	0.0	
529369	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Amps B Ø	0.0	
529370	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Amps A Ø	0.0	
529371	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
529372	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
529373	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
529374	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
529375	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
529376	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	9 Month Operations	0	
529377	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
529378	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
529379	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Ambient Temp	53	°F
529380	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
529381	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
529382	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
529383	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
529384	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Totalizer Meter Reading	.3654	
529385	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Clear of Trash?	y	
529386	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
529387	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
529388	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
529389	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Vegetation	None	
529390	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
529391	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
529392	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
529393	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Follow-up Action Required?	n	
529394	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
529395	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
529396	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
529397	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
529398	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	PF000139	PowerFuse	FV-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
529399	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	PF000139	PowerFuse	FV-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
529400	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
529401	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
529402	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
529403	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
529404	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Foundation Condition	Good	
529405	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
529406	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	PF000140	PowerFuse	FV-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
529407	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	PF000140	PowerFuse	FV-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
529408	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
529409	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	General Comments		
529410	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
529411	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
529412	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
529413	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
529414	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	PF000141	PowerFuse	FV-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
529415	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	PF000141	PowerFuse	FV-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
529416	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
529417	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	General Comments		
529418	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
529419	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
529420	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	PF000142	PowerFuse	FV-12KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
529421	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	PF000142	PowerFuse	FV-12KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
529422	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
529423	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
529424	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
529425	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
529426	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
529427	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
529428	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
529429	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	PF000357	PowerFuse	SH-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
529430	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	PF000357	PowerFuse	SH-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
529431	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
529432	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
529433	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
529434	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
529435	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
529436	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
529437	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
529438	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
529439	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
529440	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
529441	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
529442	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
529443	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
529444	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
529445	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
529446	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
529447	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
529448	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
529449	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
529450	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
529451	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
529452	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
529453	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
529454	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	LTC Totalizer Reading	14025.60	kw
529455	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
529456	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
529457	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	General Comments		
529458	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
529459	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
529460	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	General Comments		
529461	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	PF000358	PowerFuse	SH-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
529462	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
529463	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
529464	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
529465	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
529466	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
529467	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
529468	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	PF000358	PowerFuse	SH-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
529469	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
529470	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
529471	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
529472	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
529473	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
529474	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
529475	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0688	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
529476	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0688	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
529477	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0688	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
529478	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0688	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
529479	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	Follow-up Action Required?	n	
529480	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
529481	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	General Comments		
529482	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	General Comments		
529483	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC As Found Counter	4317	
529484	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0688	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	7R	
529485	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0688	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	5L	
529486	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC As Left Counter	4317	
529487	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
529488	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Current Tap Position	2R	
529489	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Max Tap Position	2R	
529490	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Min Tap Position	2R	
529491	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Operations Since Last Insp	0	
529492	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0688	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
529493	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0688	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
529494	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
529495	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
529496	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
529497	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0688	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
529498	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0688	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
529499	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0688	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
529500	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0688	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	9971	
529501	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0688	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
529502	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0688	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
529503	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0688	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
529504	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0688	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
529505	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
529506	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Min Tap Position	7L	
529507	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Operations Since Last Insp	536	
529508	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
529509	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
529510	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
529511	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Operations Counter AL	468	
529512	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Switching Operations	0	
529513	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Unknown Operations	0	
529514	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
529515	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	9 Month Operations	1	
529516	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
529517	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
529518	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	Follow-up Action Required?	n	
529519	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
529520	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	General Comments		
529521	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	General Comments		
529522	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC As Found Counter	249974	
529523	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	PF000132	PowerFuse	FV-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
529524	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	PF000132	PowerFuse	FV-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
529525	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
529526	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations A Ø	0	
529527	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations B Ø	0	
529528	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Unknown Operations	0	
529529	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Switching Operations	0	
529530	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Operations Counter AL	142	
529531	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	PF000133	PowerFuse	FV-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
529532	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	PF000133	PowerFuse	FV-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
529533	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Operations Counter AF	142	
529534	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Maintenance Operations	0	
529535	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	General Comments		
529536	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Patrol Inspection	General Comments		
529537	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations C Ø	0	
529538	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations Ground	0	
529539	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	PF000134	PowerFuse	FV-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
529540	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	PF000134	PowerFuse	FV-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
529541	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Patrol Inspection	Follow-up Action Required?	n	
529542	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Follow-up Action Required?	n	
529543	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Patrol Inspection	General Comments		
529544	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	General Comments		
529545	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Maintenance Operations	0	
529546	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Operations Counter AF	468	
529547	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	PF000135	PowerFuse	FV-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
529548	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	PF000135	PowerFuse	FV-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
529549	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC As Left Counter	249974	
529550	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
529551	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Current Tap Position	3L	
529552	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	PF000136	PowerFuse	FV-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
529553	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	PF000136	PowerFuse	FV-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
529554	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0688	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
529555	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0688	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
529556	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0688	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
529557	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0688	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
529558	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0688	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
529559	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0688	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1R	
529560	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0688	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
529561	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0688	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
529562	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Equipment Properly Labeled?	y	
529563	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
529564	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
529565	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
529566	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Follow-up Action Required?	n	
529567	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations A Ø	0	
529568	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations B Ø	0	
529569	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Patrol Inspection	Follow-up Action Required?	n	
529570	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations Ground	0	
529571	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations C Ø	0	
529572	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations Ground	0	
529573	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations C Ø	0	
529574	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations B Ø	0	
529575	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Follow-up Action Required?	n	
529576	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
529577	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations A Ø	0	
529578	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Foundation Condition	Good	
529579	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	General Comments		
529580	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	General Comments		
529581	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Grounds in Place?	y	
529582	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Maintenance Operations	0	
529583	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Moisture and Leak Free?	y	
529584	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Operations Counter AF	184	
529585	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Operations Counter AL	184	
529586	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
529587	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
529588	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Switching Operations	1	
529589	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Tank Paint Condition	Good	
529590	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Unknown Operations	0	
529591	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
529592	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
529593	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
529594	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
529595	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
529596	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
529597	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
529598	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
529599	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
529600	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
529601	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
529602	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
529603	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
529604	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
529605	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
529606	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
529607	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
529608	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
529609	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
529610	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
529611	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
529612	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
529613	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Amps C Ø	18.0	
529614	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Amps B Ø	17.0	
529615	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Amps A Ø	16.0	
529616	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Amps A Ø	36.0	
529617	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Amps B Ø	36.0	
529618	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Amps C Ø	33.0	
529619	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Bushing Condition	Good	
529620	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Bushings Connection/Risers	Good	
529621	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
529622	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0690	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
529623	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0690	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
529624	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0690	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
529625	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0690	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
529626	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0690	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
529627	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0690	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1R	
529628	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0690	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
529629	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0690	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
529630	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0690	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
529631	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0690	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
529632	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0690	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	General Comments		
529633	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0690	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
529634	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0690	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	4R	
529635	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0690	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	3L	
529636	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0690	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
529637	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0690	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
529638	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0690	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
529639	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0690	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
529640	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0690	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
529641	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0690	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	12311	
529642	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0690	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
529643	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0690	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
529644	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0690	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
529645	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	R0690	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
529646	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
529647	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
529648	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Paint Condition	Good	
529649	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	25	°C
529650	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	60	°C
529651	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	30	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
529652	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
529653	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations A Ø	0	
529654	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations B Ø	0	
529655	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations C Ø	0	
529656	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
529657	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
529658	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations Ground	0	
529659	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
529660	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
529661	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Follow-up Action Required?	n	
529662	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Follow-up Action Required?	n	
529663	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Foundation Condition	Good	
529664	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	General Comments		
529665	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	General Comments		
529666	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Grounds in Place?	y	
529667	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Maintenance Operations	0	
529668	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Moisture and Leak Free?	y	
529669	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Operations Counter AF	160	
529670	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Operations Counter AL	161	
529671	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Switching Operations	1	
529672	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Tank Paint Condition	Good	
529673	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Unknown Operations	0	
529674	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
529675	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	9 Month Operations	8	
529676	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
529677	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
529678	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
529679	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Amps A Ø	70.0	
529680	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Amps B Ø	60.0	
529681	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Amps C Ø	40.0	
529682	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Bushing Condition	Good	
529683	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
529684	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
529685	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
529686	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
529687	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
529688	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
529689	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
529690	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
529691	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
529692	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
529693	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
529694	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
529695	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
529696	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	General Comments		
529697	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
529698	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Operations Counter	212	
529699	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
529700	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
529701	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
529702	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Oil Temp Present	18	°C
529703	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
529704	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
529705	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
529706	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1654.56	kw
529707	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
529708	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
529709	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
529710	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	General Comments		
529711	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	General Comments		
529712	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
529713	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
529714	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
529715	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
529716	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
529717	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
529718	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
529719	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
529720	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Amps C Ø	469.0	
529721	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Bushing Condition	Good	
529722	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Bushings Connection/Risers	Good	
529723	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
529724	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
529725	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
529726	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
529727	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Equipment Properly Labeled?	y	
529728	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
529729	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
529730	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
529731	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
529732	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	60	°C
529733	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	27	°C
529734	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	60	°C
529735	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
529736	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Max Tap Position	8L	
529737	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Current Tap Position	9L	
529738	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
529739	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC As Left Counter	182037	
529740	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC As Found Counter	182037	
529741	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	General Comments	LTC glass needs to be cleaned extreamly hard to see what position the hands are on	
529742	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
529743	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
529744	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	Follow-up Action Required?	y	
529745	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
529746	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
529747	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
529748	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
529749	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
529750	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
529751	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
529752	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Unknown Operations	0	
529753	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
529754	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
529755	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Follow-up Action Required?	n	
529756	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
529757	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
529758	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
529759	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	General Comments		
529760	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Pressure OK?	y	
529761	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
529762	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
529763	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Bushing Condition	Good	
529764	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Bushing Oil Level	Good	
529765	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
529766	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
529767	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
529768	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
529769	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
529770	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
529771	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Fault Operations	0	
529772	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Follow-up Action Required?	n	
529773	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Follow-up Action Required?	n	
529774	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Foundation Condition	Good	
529775	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	General Comments	ONE FAN NOT WORKING NOW	
529776	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
529777	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	LTC Totalizer Reading	8176.32	kw
529778	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Bushings Connection/Risers	Good	
529779	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
529780	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
529781	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	LTC Operation Checked?	y	
529782	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
529783	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
529784	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
529785	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
529786	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Paint Condition	Good	
529787	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Equipment Properly Labeled?	y	
529788	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
529789	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	VRR Time Delay	30	Seconds
529790	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
529791	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
529792	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations A Ø	0	
529793	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	General Comments		
529794	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
529795	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
529796	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
529797	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
529798	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
529799	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
529800	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
529801	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
529802	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations B Ø	0	
529803	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations C Ø	0	
529804	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations Ground	0	
529805	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
529806	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Follow-up Action Required?	n	
529807	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Follow-up Action Required?	n	
529808	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Foundation Condition	Good	
529809	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	General Comments		
529810	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	General Comments		
529811	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Grounds in Place?	y	
529812	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Maintenance Operations	0	
529813	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
529814	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
529815	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Moisture and Leak Free?	y	
529816	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	475	
529817	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Min Tap Position	13L	
529818	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Operations Counter AF	155	
529819	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Operations Counter AL	57	
529820	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Switching Operations	2	
529821	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Tank Paint Condition	Good	
529822	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
529823	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Paint Condition	Good	
529824	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Equipment Properly Labeled?	y	
529825	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
529826	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
529827	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	9 Month Operations	3	
529828	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
529829	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Accumulated Fault Duty B Ph V	.47	%
529830	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
529831	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Amps A Ø	479.0	
529832	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Amps B Ø	465.0	
529833	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
529834	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations A Ø	0	
529835	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations B Ø	0	
529836	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations C Ø	0	
529837	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations Ground	0	
529838	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Follow-up Action Required?	n	
529839	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Follow-up Action Required?	n	
529840	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Amps A Ø	52.0	
529841	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Amps B Ø	60.0	
529842	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Amps C Ø	53.0	
529843	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
529844	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
529845	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
529846	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
529847	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
529848	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
529849	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
529850	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
529851	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
529852	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
529853	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
529854	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
529855	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
529856	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
529857	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
529858	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
529859	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
529860	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
529861	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
529862	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
529863	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
529864	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
529865	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	BCH000229	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
529866	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
529867	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Operations Since Last Insp	526	
529868	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Min Tap Position	8L	
529869	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Max Tap Position	4R	
529870	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Current Tap Position	4L	
529871	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
529872	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC As Left Counter	70429	
529873	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC As Found Counter	70423	
529874	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	General Comments		
529875	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	General Comments		
529876	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
529877	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
529878	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	Follow-up Action Required?	n	
529879	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
529880	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
529881	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
529882	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
529883	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
529884	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Operations Since Last Insp	768	
529885	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Min Tap Position	7L	
529886	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Max Tap Position	1R	
529887	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Current Tap Position	4L	
529888	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
529889	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Follow-up Action Required?	n	
529890	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
529891	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
529892	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
529893	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
529894	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
529895	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC As Left Counter	10577	
529896	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC As Found Counter	10572	
529897	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	General Comments		
529898	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	General Comments		
529899	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
529900	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
529901	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	Follow-up Action Required?	n	
529902	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
529903	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
529904	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
529905	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
529906	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
529907	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
529908	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
529909	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
529910	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
529911	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
529912	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
529913	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
529914	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	General Comments		
529915	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
529916	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Vegetation	None	
529917	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
529918	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
529919	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
529920	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
529921	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
529922	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
529923	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
529924	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	General Comments		
529925	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	General Comments	Nitro bottle empty needs filled at 0	
529926	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
529927	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
529928	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
529929	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
529930	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	Oil Temp Max	61	°C
529931	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	Oil Temp Present	23	°C
529932	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
529933	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
529934	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
529935	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
529936	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
529937	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
529938	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
529939	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
529940	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
529941	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.3788	
529942	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
529943	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
529944	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
529945	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
529946	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
529947	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
529948	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
529949	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Amps A Ø	6.4	
529950	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Amps B Ø	.9	
529951	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Amps C Ø	1.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
529952	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
529953	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
529954	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
529955	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
529956	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
529957	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	15	°C
529958	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	20	°C
529959	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
529960	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	General Comments	6 Pack nitro needs no be filled	
529961	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	General Comments		
529962	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
529963	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
529964	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
529965	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
529966	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
529967	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
529968	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	General Comments		
529969	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
529970	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
529971	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Operations Counter	28	
529972	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
529973	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Tank Leaks	None	
529974	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
529975	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Foundation Condition	Good	
529976	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	General Comments		
529977	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	General Comments		
529978	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Grounds in Place?	y	
529979	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Maintenance Operations	0	
529980	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Moisture and Leak Free?	y	
529981	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Operations Counter AF	154	
529982	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Operations Counter AL	156	
529983	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Switching Operations	2	
529984	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Tank Paint Condition	Good	
529985	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Unknown Operations	0	
529986	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
529987	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
529988	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
529989	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
529990	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
529991	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
529992	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
529993	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
529994	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Clear of Trash?	y	
529995	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
529996	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	General Comments		
529997	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
529998	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
529999	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Follow-up Action Required?	n	
530000	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	General Comments		
530001	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Prove All BFI DC Paths	na	
530002	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 1 or Aux Rly	n	
530003	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 2 or Aux Rly	na	
530004	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Alarm Operation Correct?	n	
530005	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Follow-up Action Required?	n	
530006	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
530007	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
530008	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
530009	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	General Comments		
530010	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Prove All BFI DC Paths	na	
530011	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Relay Trip Targets OK?	na	
530012	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 1 or Aux Rly	n	
530013	3/11/2019 11:31	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 2 or Aux Rly	na	
530014	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Unknown Operations	0	
530015	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Tank Paint Condition	Good	
530016	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Switching Operations	0	
530017	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
530018	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	General Comments		
530019	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
530020	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
530021	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
530022	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
530023	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1409	
530024	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Operations Counter AL	311	
530025	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Operations Counter AF	311	
530026	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
530027	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Maintenance Operations	1	
530028	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Heaters (All) Functioning?	y	
530029	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Grounds in Place?	y	
530030	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	General Comments		
530031	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	General Comments		
530032	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Foundation Condition	Good	
530033	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Follow-up Action Required?	n	
530034	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Follow-up Action Required?	n	
530035	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations Ground	0	
530036	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations C Ø	0	
530037	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations B Ø	0	
530038	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations A Ø	0	
530039	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
530040	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
530041	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
530042	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
530043	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
530044	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
530045	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
530046	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
530047	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
530048	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
530049	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
530050	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
530051	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
530052	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
530053	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
530054	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
530055	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
530056	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
530057	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
530058	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
530059	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC Current Tap Position	8L	
530060	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC Max Tap Position	5L	
530061	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC Min Tap Position	10L	
530062	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
530063	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	86	
530064	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
530065	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
530066	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
530067	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
530068	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
530069	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
530070	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Patrol Inspection	General Comments		
530071	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Patrol Inspection	Follow-up Action Required?	n	
530072	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Patrol Inspection	Equipment Properly Labeled?	y	
530073	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
530074	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
530075	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
530076	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
530077	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
530078	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
530079	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1053	
530080	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1053	
530081	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
530082	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	1	
530083	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
530084	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.6	VDC
530085	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.1	VDC
530086	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
530087	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
530088	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
530089	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
530090	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
530091	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
530092	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
530093	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	52	°F
530094	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC As Left Counter	12686	
530095	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
530096	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
530097	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6L	
530098	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
530099	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
530100	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	272	
530101	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
530102	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
530103	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
530104	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
530105	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Unknown Operations	0	
530106	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Tank Paint Condition	Good	
530107	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Switching Operations	0	
530108	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Operations Counter AL	255	
530109	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Operations Counter AF	255	
530110	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Moisture and Leak Free?	y	
530111	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Maintenance Operations	0	
530112	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Heaters (All) Functioning?	y	
530113	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Grounds in Place?	y	
530114	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	General Comments		
530115	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	General Comments		
530116	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Foundation Condition	Good	
530117	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
530118	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
530119	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
530120	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
530121	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
530122	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
530123	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
530124	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
530125	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1612	
530126	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
530127	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
530128	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
530129	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Equipment Properly Labeled?	y	
530130	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Paint Condition	Good	
530131	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
530132	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
530133	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
530134	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Bushings Connection/Risers	Good	
530135	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Bushing Condition	Good	
530136	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1409	
530137	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
530138	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
530139	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
530140	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
530141	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
530142	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
530143	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
530144	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
530145	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Amps C Ø	200.0	
530146	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Amps B Ø	100.0	
530147	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Amps A Ø	150.0	
530148	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Accumulated Fault Duty C Ph V	8.04	%
530149	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Accumulated Fault Duty B Ph V	17.55	%
530150	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Accumulated Fault Duty A Ph V	17.55	%
530151	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	9 Month Operations	2	
530152	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	46	°F
530153	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
530154	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
530155	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	General Comments		
530156	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	needs 2 dessicant filters changed out ontop of LTC	
530157	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC As Found Counter	12686	
530158	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
530159	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
530160	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
530161	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
530162	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
530163	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
530164	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
530165	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
530166	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
530167	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
530168	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Trip-energy Supply Verified	y	LED lights?
530169	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
530170	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Follow-up Action Required?	n	
530171	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	General Comments		
530172	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Max Tap Position	12R	
530173	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Min Tap Position	6R	
530174	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
530175	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
530176	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
530177	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Base Voltage AF	124.0	VAC
530178	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Base Voltage AL	124.0	VAC
530179	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Counter AF	117295	
530180	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Counter AL	117298	
530181	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
530182	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
530183	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Time Delay	45	Seconds
530184	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Negative DC Ground	9.0	VDC
530185	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	General Comments	water added to all cells	
530186	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
530187	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
530188	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
530189	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Water Added	If low,note cell #~'s
530190	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
530191	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
530192	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
530193	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
530194	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	46	°F
530195	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC As Found Counter	264694	
530196	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC As Left Counter	264694	
530197	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
530198	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
530199	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
530200	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
530201	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
530202	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
530203	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
530204	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
530205	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	60.0	
530206	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	60.0	
530207	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	60.0	
530208	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
530209	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
530210	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
530211	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
530212	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
530213	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
530214	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
530215	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Oil Temp Max	65	°C
530216	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Oil Temp Present	40	°C
530217	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
530218	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
530219	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
530220	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
530221	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
530222	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
530223	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	General Comments		
530224	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	General Comments		
530225	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Grounds in Place?	y	
530226	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Heaters (All) Functioning?	y	
530227	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Maintenance Operations	0	
530228	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
530229	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Number of Ops last 9 Months	5	
530230	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Operations Counter AF	419	
530231	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Operations Counter AL	419	
530232	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2019-03-11 00:00:00.000000	
530233	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
530234	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
530235	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Switching Operations	0	
530236	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
530237	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
530238	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
530239	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
530240	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
530241	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank Leaks	None	
530242	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank Paint Condition	Good	
530243	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Unknown Operations	0	
530244	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
530245	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Totalizer Meter Reading	1.7034	
530246	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
530247	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
530248	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
530249	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
530250	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	General Comments		
530251	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
530252	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
530253	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
530254	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Positive DC Ground	11.0	VDC
530255	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	All Connections OK?	y	
530256	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Current Tap Position	9R	
530257	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
530258	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
530259	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
530260	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
530261	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
530262	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
530263	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	General Comments		
530264	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
530265	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC As Found Counter	44561	
530266	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC As Left Counter	44561	
530267	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
530268	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
530269	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
530270	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
530271	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	8	
530272	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	7.28	%
530273	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
530274	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
530275	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
530276	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
530277	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
530278	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Evidence of Insects	None	
530279	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
530280	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
530281	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
530282	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
530283	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	General Comments		
530284	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
530285	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Trash Emptied?	y	
530286	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
530287	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
530288	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	16.99	%
530289	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	9.71	%
530290	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	150.0	
530291	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	160.0	
530292	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	125.0	
530293	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
530294	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
530295	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
530296	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
530297	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
530298	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
530299	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
530300	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Max Tap Position	7L	
530301	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
530302	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
530303	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	12	
530304	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
530305	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
530306	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
530307	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
530308	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
530309	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
530310	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
530311	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
530312	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
530313	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
530314	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
530315	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
530316	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	General Comments		
530317	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
530318	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
530319	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
530320	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
530321	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
530322	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
530323	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
530324	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
530325	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
530326	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	9	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
530327	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1485	
530328	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1485	
530329	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
530330	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
530331	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
530332	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
530333	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
530334	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
530335	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
530336	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
530337	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
530338	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	General Comments	ok	
530339	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
530340	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
530341	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Foundation Condition	Good	
530342	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
530343	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
530344	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
530345	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
530346	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
530347	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Radiator Leaks	None	
530348	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
530349	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Pumps Operational?	y	
530350	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Pumps Condition	Good	
530351	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Oil Temp Present	13	°C
530352	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Oil Temp Max	50	°C
530353	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
530354	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
530355	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
530356	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
530357	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Operations Counter AF	151	
530358	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Operations Counter AL	152	
530359	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Switching Operations	1	
530360	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Tank Paint Condition	Good	
530361	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Unknown Operations	0	
530362	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
530363	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
530364	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
530365	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
530366	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
530367	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
530368	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
530369	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
530370	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
530371	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
530372	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
530373	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Grounds in Place?	y	
530374	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	General Comments	TR needs nitro	
530375	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	General Comments	top oil not able to rest	
530376	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
530377	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Foundation Condition	Good	
530378	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Follow-up Action Required?	y	
530379	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
530380	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Fans Operational?	y	
530381	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Fans Condition	Good	
530382	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
530383	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
530384	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
530385	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
530386	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
530387	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
530388	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
530389	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Foundation Condition	Good	
530390	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	General Comments		
530391	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	General Comments		
530392	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
530393	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
530394	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Panels Dusted?	y	
530395	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
530396	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
530397	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
530398	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Grounds in Place?	y	
530399	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Maintenance Operations	0	
530400	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Moisture and Leak Free?	y	
530401	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
530402	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
530403	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
530404	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	9.71	%
530405	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	13.35	%
530406	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	9.71	%
530407	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	134.0	
530408	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	146.0	
530409	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X3 Winding Temp Present	17	°C
530410	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X3 Winding Temp Max	33	°C
530411	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X2 Winding Temp Present	17	°C
530412	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X2 Winding Temp Max	33	°C
530413	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X1 Winding Temp Present	16	°C
530414	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X1 Winding Temp Max	33	°C
530415	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
530416	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
530417	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Top Oil Temperature Max	50	°C
530418	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
530419	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
530420	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Tank Leaks	None	
530421	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
530422	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
530423	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	148.0	
530424	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
530425	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
530426	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
530427	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Foundation Condition	Good	
530428	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
530429	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
530430	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	General Comments		
530431	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
530432	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1304	
530433	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1304	
530434	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
530435	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
530436	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
530437	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Amps B Ø	51.0	
530438	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Amps C Ø	39.0	
530439	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Bushing Condition	Good	
530440	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Bushings Connection/Risers	Good	
530441	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
530442	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
530443	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	All Connections OK?	y	
530444	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	Follow-up Action Required?	n	
530445	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	General Comments		
530446	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	LTC Operation Checked?	y	
530447	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
530448	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Operations Counter AL	209	
530449	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Operations Counter AF	208	
530450	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Moisture and Leak Free?	y	
530451	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Maintenance Operations	0	
530452	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
530453	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
530454	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
530455	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
530456	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
530457	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
530458	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
530459	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
530460	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	Oil Temp Present	21	°C
530461	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
530462	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
530463	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
530464	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
530465	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	General Comments		
530466	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
530467	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Heaters (All) Functioning?	y	
530468	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Grounds in Place?	y	
530469	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	General Comments		
530470	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
530471	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Paint Condition	Good	
530472	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Equipment Properly Labeled?	y	
530473	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1039	
530474	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1039	
530475	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
530476	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
530477	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
530478	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Bushing Condition	Good	
530479	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
530480	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
530481	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	31	°C
530482	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	40	°C
530483	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	15	°C
530484	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	25	°C
530485	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	21	°C
530486	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	31	°C
530487	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
530488	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
530489	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
530490	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
530491	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
530492	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
530493	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
530494	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
530495	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
530496	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
530497	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
530498	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
530499	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
530500	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
530501	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
530502	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
530503	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
530504	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
530505	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	PF000137	PowerFuse	FV-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
530506	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	PF000137	PowerFuse	FV-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
530507	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	PF000359	PowerFuse	SH-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
530508	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	PF000359	PowerFuse	SH-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
530509	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	9 Month Operations	9	
530510	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Accumulated Fault Duty A Ph V	3.78	%
530511	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Accumulated Fault Duty B Ph V	3.40	%
530512	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Accumulated Fault Duty C Ph V	3.78	%
530513	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Amps A Ø	25.0	
530514	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Unknown Operations	0	
530515	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Tank Paint Condition	Good	
530516	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Switching Operations	1	
530517	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
530518	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
530519	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
530520	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
530521	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
530522	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
530523	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
530524	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
530525	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
530526	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	General Comments		
530527	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
530528	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
530529	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
530530	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
530531	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
530532	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.2774	
530533	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
530534	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
530535	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
530536	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
530537	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Foundation Condition	Good	
530538	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
530539	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
530540	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	General Comments		
530541	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
530542	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
530543	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
530544	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
530545	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
530546	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
530547	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
530548	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
530549	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	Oil Temp Max	31	°C
530550	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
530551	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
530552	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
530553	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
530554	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
530555	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
530556	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Oil Temp Present	0	°C
530557	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Oil Temp Max	0	°C
530558	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
530559	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	115.00	
530560	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1532.88	kw
530561	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
530562	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
530563	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
530564	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Tank Paint Condition	Good	
530565	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Vegetation	None	
530566	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
530567	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
530568	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
530569	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
530570	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Moisture and Leak Free?	y	
530571	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Grounds in Place?	y	
530572	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	General Comments	1 swop from 169-170 counter reading. no other place to put it	
530573	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	General Comments		
530574	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	General Comments		
530575	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	General Comments		
530576	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Foundation Condition	Good	
530577	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Follow-up Action Required?	y	
530578	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
530579	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
530580	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
530581	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
530582	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
530583	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Follow-up Action Required?	n	
530584	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
530585	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
530586	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
530587	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
530588	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
530589	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
530590	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
530591	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
530592	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
530593	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
530594	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
530595	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
530596	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
530597	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
530598	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
530599	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
530600	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
530601	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
530602	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
530603	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
530604	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
530605	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
530606	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Equipment Properly Labeled?	y	
530607	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Paint Condition	Good	
530608	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
530609	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
530610	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Cabinet Paint Condition	Good	
530611	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	PF000356	PowerFuse	SH-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
530612	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	PF000356	PowerFuse	SH-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
530613	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Equipment Properly Labeled?	y	
530614	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
530615	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
530616	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
530617	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
530618	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
530619	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	General Comments		
530620	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
530621	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
530622	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Operations A Ø	0	
530623	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Operations B Ø	0	
530624	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Operations C Ø	0	
530625	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	32	°C
530626	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
530627	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
530628	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	9 Month Operations	0	
530629	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	25	°C
530630	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	32	°C
530631	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	24	°C
530632	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	32	°C
530633	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	24	°C
530634	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Operations Ground	0	
530635	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Follow-up Action Required?	n	
530636	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Follow-up Action Required?	n	
530637	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	6	
530638	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
530639	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	General Comments		
530640	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	General Comments		
530641	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
530642	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
530643	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
530644	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
530645	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
530646	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
530647	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
530648	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
530649	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
530650	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
530651	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
530652	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
530653	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
530654	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
530655	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
530656	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Clear of Trash?	y	
530657	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
530658	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
530659	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
530660	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
530661	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
530662	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
530663	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	General Comments		
530664	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
530665	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
530666	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Vegetation	None	
530667	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
530668	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
530669	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	General Comments		
530670	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
530671	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
530672	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
530673	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
530674	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC
530675	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	Oil Temp Present	24	°C
530676	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
530677	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
530678	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
530679	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
530680	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Evidence of Insects	None	
530681	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
530682	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
530683	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
530684	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
530685	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Bushings Connection/Risers	Good	
530686	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Bushing Condition	Good	
530687	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Amps C Ø	75.0	
530688	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Amps B Ø	104.0	
530689	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Amps A Ø	90.0	
530690	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
530691	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
530692	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
530693	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
530694	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
530695	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
530696	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
530697	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
530698	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
530699	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
530700	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
530701	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
530702	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
530703	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
530704	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
530705	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
530706	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
530707	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
530708	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
530709	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	933	
530710	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	933	
530711	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
530712	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
530713	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
530714	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
530715	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments	gasket on bottom of door has fallen off needs to be replaced	
530716	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	General Comments		
530717	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
530718	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
530719	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	y	
530720	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
530721	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
530722	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
530723	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
530724	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
530725	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
530726	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	n	
530727	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
530728	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
530729	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
530730	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
530731	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
530732	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
530733	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
530734	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
530735	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
530736	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
530737	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
530738	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
530739	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
530740	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
530741	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Current Tap Position	4R	
530742	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
530743	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
530744	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
530745	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
530746	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Bushing Condition	Good	
530747	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Amps B Ø	64.0	
530748	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Amps A Ø	54.0	
530749	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Accumulated Fault Duty C Ph V	5.29	%
530750	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Accumulated Fault Duty B Ph V	5.67	%
530751	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Accumulated Fault Duty A Ph V	2.27	%
530752	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	9 Month Operations	4	
530753	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
530754	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
530755	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
530756	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
530757	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	9 Month Operations	11	
530758	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Accumulated Fault Duty A Ph V	1.43	%
530759	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
530760	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
530761	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Amps A Ø	95.0	
530762	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Amps B Ø	121.0	
530763	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Amps C Ø	100.0	
530764	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Bushing Condition	Good	
530765	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Bushings Connection/Risers	Good	
530766	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
530767	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
530768	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
530769	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Paint Condition	Good	
530770	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Equipment Properly Labeled?	y	
530771	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Vegetation	None	
530772	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
530773	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
530774	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
530775	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
530776	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
530777	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
530778	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
530779	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
530780	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
530781	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	1	
530782	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
530783	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
530784	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Tank Paint Condition	Good	
530785	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Unknown Operations	0	
530786	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
530787	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
530788	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
530789	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
530790	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
530791	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	General Comments		
530792	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
530793	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Foundation Condition	Good	
530794	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
530795	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
530796	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
530797	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
530798	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
530799	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
530800	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	49	°F
530801	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
530802	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
530803	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
530804	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
530805	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
530806	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
530807	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
530808	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
530809	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
530810	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
530811	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
530812	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
530813	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
530814	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
530815	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
530816	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	General Comments		
530817	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
530818	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
530819	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
530820	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
530821	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
530822	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
530823	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
530824	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
530825	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
530826	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	493	
530827	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
530828	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	508	
530829	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	508	
530830	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
530831	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
530832	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
530833	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
530834	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
530835	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
530836	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
530837	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
530838	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
530839	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
530840	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
530841	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
530842	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
530843	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Clear of Trash?	y	
530844	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
530845	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
530846	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
530847	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
530848	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
530849	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
530850	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
530851	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
530852	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations A Ø	0	
530853	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations B Ø	0	
530854	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations C Ø	0	
530855	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations Ground	0	
530856	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Follow-up Action Required?	n	
530857	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Follow-up Action Required?	n	
530858	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Foundation Condition	Good	
530859	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
530860	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
530861	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
530862	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	General Comments		
530863	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	General Comments		
530864	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Grounds in Place?	y	
530865	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Heaters (All) Functioning?	y	
530866	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Maintenance Operations	0	
530867	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Moisture and Leak Free?	y	
530868	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Operations Counter AF	2015	
530869	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Operations Counter AL	2021	
530870	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
530871	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Switching Operations	6	
530872	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
530873	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
530874	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Maintenance Operations	0	
530875	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Moisture and Leak Free?	y	
530876	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
530877	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
530878	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
530879	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
530880	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
530881	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
530882	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
530883	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
530884	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Operations Counter AF	206	
530885	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Operations Counter AL	207	
530886	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
530887	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Switching Operations	1	
530888	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Tank Paint Condition	Good	
530889	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Unknown Operations	0	
530890	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
530891	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
530892	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	VRR Time Delay	30	Seconds
530893	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations Ground	0	
530894	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations C Ø	0	
530895	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations B Ø	0	
530896	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations A Ø	0	
530897	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
530898	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
530899	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
530900	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Equipment Properly Labeled?	y	
530901	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Paint Condition	Good	
530902	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
530903	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
530904	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
530905	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
530906	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	55	°C
530907	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	60	°C
530908	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	55	°C
530909	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	60	°C
530910	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	55	°C
530911	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	60	°C
530912	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
530913	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	105.00	
530914	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
530915	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
530916	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
530917	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
530918	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
530919	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
530920	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
530921	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
530922	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	General Comments		
530923	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
530924	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
530925	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
530926	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
530927	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
530928	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
530929	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
530930	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
530931	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	128.0	
530932	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	141.0	
530933	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	138.0	
530934	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	46.11	%
530935	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	58.24	%
530936	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	29.12	%
530937	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	13	
530938	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Foundation Condition	Good	
530939	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Follow-up Action Required?	n	
530940	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Follow-up Action Required?	n	
530941	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
530942	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations A Ø	0	
530943	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations B Ø	0	
530944	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations C Ø	0	
530945	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations Ground	0	
530946	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Follow-up Action Required?	n	
530947	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Follow-up Action Required?	n	
530948	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Foundation Condition	Good	
530949	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	General Comments		
530950	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	General Comments		
530951	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Grounds in Place?	y	
530952	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Heaters (All) Functioning?	y	
530953	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
530954	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
530955	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
530956	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
530957	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
530958	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
530959	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
530960	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
530961	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	General Comments	Strip heater needs replaced in control cabnite	
530962	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	General Comments		
530963	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
530964	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
530965	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
530966	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
530967	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
530968	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
530969	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
530970	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
530971	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
530972	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
530973	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	n	
530974	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Bushings Connection/Risers	Good	
530975	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Bushing Condition	Good	
530976	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Amps C Ø	60.0	
530977	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
530978	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
530979	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
530980	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
530981	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
530982	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
530983	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
530984	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
530985	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
530986	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
530987	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
530988	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Tank Leaks	None	
530989	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
530990	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
530991	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Regulator As Left Counter	29468	
530992	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
530993	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
530994	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reg Oil Level	Good	
530995	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
530996	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
530997	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Min Tap Position	1R	
530998	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Max Tap Position	6R	
530999	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Grounds in Place?	y	
531000	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	General Comments		
531001	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
531002	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Foundation Condition	Good	
531003	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
531004	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
531005	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
531006	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
531007	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
531008	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
531009	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	Oil Temp Present	55	°C
531010	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	Oil Temp Max	80	°C
531011	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
531012	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	551	
531013	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	551	
531014	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
531015	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
531016	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
531017	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
531018	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
531019	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
531020	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
531021	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
531022	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
531023	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
531024	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
531025	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
531026	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
531027	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	164.0	
531028	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	137.0	
531029	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	145.0	
531030	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	4.85	%
531031	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
531032	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
531033	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
531034	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Bushing Condition	Good	
531035	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
531036	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
531037	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
531038	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Foundation Condition	Good	
531039	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	General Comments		
531040	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Grounds in Place?	y	
531041	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
531042	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Radiator Leaks	None	
531043	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
531044	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Tank Leaks	None	
531045	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
531046	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
531047	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
531048	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
531049	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
531050	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
531051	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
531052	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
531053	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
531054	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Equipment Properly Labeled?	y	
531055	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Tank Paint Condition	Good	
531056	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Unknown Operations	0	
531057	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Cabinet Paint Condition	Good	
531058	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
531059	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
531060	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
531061	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Bushings Connection/Risers	Good	
531062	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Bushing Condition	Good	
531063	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
531064	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Amps C Ø	67.0	
531065	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Amps B Ø	49.0	
531066	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Amps A Ø	63.0	
531067	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
531068	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
531069	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Accumulated Fault Duty A Ph V	.47	%
531070	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
531071	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
531072	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
531073	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
531074	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
531075	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Foundation Condition	Good	
531076	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
531077	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	9 Month Operations	29	
531078	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
531079	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	General Comments		
531080	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
531081	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
531082	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
531083	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
531084	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
531085	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	General Comments		
531086	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
531087	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	9 Month Operations	1	
531088	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
531089	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
531090	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
531091	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
531092	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
531093	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Follow-up Action Required?	n	
531094	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
531095	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
531096	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
531097	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	General Comments		
531098	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
531099	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
531100	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
531101	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
531102	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	16	
531103	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	169	
531104	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	173	
531105	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
531106	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations Ground	0	
531107	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations C Ø	0	
531108	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Follow-up Action Required?	n	
531109	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Follow-up Action Required?	n	
531110	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
531111	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
531112	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Operations Ground	0	
531113	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
531114	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
531115	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Operations Counter AF	212	
531116	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Operations Counter AL	217	
531117	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
531118	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Operations C Ø	0	
531119	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Operations B Ø	0	
531120	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Operations A Ø	0	
531121	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
531122	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Switching Operations	5	
531123	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
531124	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
531125	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
531126	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
531127	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
531128	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
531129	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
531130	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LTCC000578	LTCControl	FV-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
531131	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LTCC000578	LTCControl	FV-TRANS 4	LTC Control Insp	General Comments		
531132	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LTCC000578	LTCControl	FV-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
531133	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LTCC000578	LTCControl	FV-TRANS 4	LTC Control Insp	All Connections OK?	y	
531134	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
531135	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
531136	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
531137	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Patrol Inspection	Follow-up Action Required?	n	
531138	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Follow-up Action Required?	n	
531139	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Patrol Inspection	General Comments		
531140	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	General Comments		
531141	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Bushings Connection/Risers	Good	
531142	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Bushing Condition	Good	
531143	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Amps C Ø	10.0	
531144	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
531145	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
531146	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
531147	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
531148	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Amps B Ø	10.0	
531149	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Amps A Ø	10.0	
531150	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Accumulated Fault Duty C Ph V	6.58	%
531151	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Accumulated Fault Duty B Ph V	6.58	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
531152	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Accumulated Fault Duty A Ph V	5.85	%
531153	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	9 Month Operations	2	
531154	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
531155	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
531156	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
531157	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
531158	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	General Comments		
531159	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
531160	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Tank Leaks	None	
531161	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
531162	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
531163	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Regulator As Left Counter	117298	
531164	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.9	volts
531165	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
531166	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
531167	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
531168	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
531169	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
531170	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
531171	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
531172	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
531173	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
531174	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Maintenance Operations	0	
531175	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Operations Counter AF	49	
531176	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Operations Counter AL	49	
531177	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Switching Operations	0	
531178	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Unknown Operations	0	
531179	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
531180	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Vegetation	None	
531181	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
531182	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
531183	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	9 Month Operations	13	
531184	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Accumulated Fault Duty A Ph V	8.87	%
531185	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Accumulated Fault Duty B Ph V	7.76	%
531186	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Accumulated Fault Duty C Ph V	7.20	%
531187	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Amps A Ø	150.0	
531188	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
531189	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
531190	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
531191	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations B Ø	0	
531192	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	LTCC000615	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
531193	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	LTCC000615	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
531194	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	LTCC000615	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
531195	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	LTCC000615	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
531196	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations A Ø	0	
531197	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
531198	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
531199	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	LTCC000615	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
531200	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	LTCC000615	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
531201	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	LTCC000615	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
531202	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	LTCC000615	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
531203	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
531204	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Equipment Properly Labeled?	y	
531205	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Paint Condition	Good	
531206	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
531207	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
531208	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
531209	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Amps B Ø	150.0	
531210	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Amps C Ø	150.0	
531211	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Patrol Inspection	Equipment Properly Labeled?	y	
531212	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
531213	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
531214	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	LTCC000615	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
531215	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	LTCC000616	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
531216	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	LTCC000616	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
531217	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	LTCC000616	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
531218	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
531219	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations A Ø	0	
531220	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	LTCC000616	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
531221	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	LTCC000616	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
531222	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations B Ø	0	
531223	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations C Ø	0	
531224	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations Ground	0	
531225	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
531226	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
531227	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
531228	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
531229	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
531230	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
531231	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1079	
531232	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1079	
531233	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	1	
531234	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
531235	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
531236	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
531237	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments	checked fuses, Strip heator needs to be replaced	
531238	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	General Comments		
531239	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
531240	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
531241	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	y	
531242	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
531243	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	60.0	
531244	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Amps A Ø	127.0	
531245	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Amps B Ø	120.0	
531246	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Amps C Ø	125.0	
531247	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Bushing Condition	Good	
531248	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Bushings Connection/Risers	Good	
531249	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
531250	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
531251	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
531252	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Cabinet Paint Condition	Good	
531253	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Equipment Properly Labeled?	y	
531254	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
531255	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
531256	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
531257	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Operations A Ø	0	
531258	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Operations B Ø	0	
531259	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Operations C Ø	0	
531260	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Operations Ground	0	
531261	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Follow-up Action Required?	n	
531262	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Follow-up Action Required?	n	
531263	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Foundation Condition	Good	
531264	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	60.0	
531265	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	60.0	
531266	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
531267	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
531268	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
531269	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
531270	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
531271	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
531272	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
531273	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
531274	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
531275	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
531276	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
531277	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
531278	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
531279	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
531280	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	General Comments		
531281	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
531282	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Foundation Condition	Good	
531283	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
531284	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
531285	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
531286	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
531287	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
531288	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
531289	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
531290	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Vent Fans OK?	y	
531291	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
531292	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
531293	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Panels Dusted?	y	
531294	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Panel Lights OK?	y	
531295	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
531296	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
531297	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	General Comments		
531298	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
531299	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Follow-up Action Required?	n	
531300	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
531301	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
531302	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Accumulated Fault Duty B Ph V	1.35	%
531303	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Accumulated Fault Duty C Ph V	9.42	%
531304	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
531305	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Evidence of Insects	None	
531306	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
531307	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
531308	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Door Alarms OK?	y	
531309	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
531310	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
531311	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
531312	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
531313	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Grounds in Place?	y	
531314	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Amps A Ø	18.0	
531315	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Amps B Ø	19.0	
531316	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Amps C Ø	13.0	
531317	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
531318	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
531319	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
531320	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
531321	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
531322	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
531323	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
531324	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
531325	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
531326	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
531327	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	General Comments		
531328	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
531329	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
531330	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Operations Counter	20	
531331	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
531332	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
531333	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
531334	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Clear of Trash?	y	
531335	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Tank Leaks	None	
531336	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
531337	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	General Comments		
531338	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	General Comments		
531339	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
531340	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
531341	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
531342	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	General Comments		
531343	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
531344	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
531345	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
531346	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	General Comments		
531347	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Foundation Condition	Good	
531348	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
531349	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
531350	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
531351	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
531352	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
531353	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
531354	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
531355	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Foundation Condition	Good	
531356	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Follow-up Action Required?	n	
531357	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
531358	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
531359	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
531360	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
531361	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
531362	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
531363	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
531364	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	General Comments		
531365	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	General Comments		
531366	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Grounds in Place?	y	
531367	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Heaters (All) Functioning?	y	
531368	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Maintenance Operations	0	
531369	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Moisture and Leak Free?	y	
531370	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
531371	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
531372	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
531373	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
531374	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	n	
531375	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
531376	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
531377	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Vegetation	None	
531378	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
531379	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
531380	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	General Comments		
531381	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
531382	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
531383	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
531384	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Unknown Operations	0	
531385	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Tank Paint Condition	Good	
531386	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Switching Operations	0	
531387	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
531388	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Operations Counter AL	197	
531389	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Operations Counter AF	197	
531390	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Moisture and Leak Free?	y	
531391	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Maintenance Operations	1	
531392	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Heaters (All) Functioning?	y	
531393	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Unknown Operations	0	
531394	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Tank Paint Condition	Good	
531395	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Switching Operations	1	
531396	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Operations Counter AL	148	
531397	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Operations Counter AF	147	
531398	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Moisture and Leak Free?	y	
531399	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Maintenance Operations	0	
531400	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Grounds in Place?	y	
531401	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
531402	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
531403	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
531404	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
531405	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
531406	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Clear of Trash?	y	
531407	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Amps A Ø	61.0	
531408	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Amps B Ø	54.0	
531409	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
531410	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
531411	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
531412	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Ambient Temp	48	°F
531413	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
531414	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
531415	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
531416	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
531417	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
531418	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Unknown Operations	0	
531419	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Tank Paint Condition	Good	
531420	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Switching Operations	8	
531421	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Amps C Ø	64.0	
531422	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Bushing Condition	Good	
531423	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Bushings Connection/Risers	Good	
531424	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
531425	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
531426	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Operations Counter AL	331	
531427	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Operations Counter AF	327	
531428	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Moisture and Leak Free?	y	
531429	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Maintenance Operations	0	
531430	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Heaters (All) Functioning?	y	
531431	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Grounds in Place?	y	
531432	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	General Comments		
531433	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	General Comments		
531434	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Foundation Condition	Good	
531435	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Follow-up Action Required?	n	
531436	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Follow-up Action Required?	n	
531437	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations Ground	0	
531438	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations C Ø	0	
531439	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations B Ø	0	
531440	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations A Ø	0	
531441	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
531442	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
531443	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
531444	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Equipment Properly Labeled?	y	
531445	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
531446	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
531447	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
531448	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
531449	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
531450	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
531451	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
531452	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
531453	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
531454	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
531455	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
531456	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
531457	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
531458	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
531459	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	General Comments		
531460	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
531461	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
531462	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Foundation Condition	Good	
531463	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
531464	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
531465	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	LTCC000616	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
531466	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
531467	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	6.40	%
531468	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
531469	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
531470	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
531471	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
531472	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
531473	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
531474	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
531475	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	4	
531476	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	4	
531477	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
531478	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
531479	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	4.98	%
531480	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	6.40	%
531481	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	84.0	
531482	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
531483	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	108.0	
531484	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Vegetation	None	
531485	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
531486	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
531487	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	General Comments		
531488	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
531489	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
531490	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
531491	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	BCH000237	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
531492	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	BCH000237	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
531493	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	BCH000237	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
531494	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
531495	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
531496	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6378	
531497	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
531498	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
531499	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
531500	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
531501	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
531502	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Clear of Trash?	y	
531503	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
531504	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
531505	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
531506	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
531507	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
531508	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
531509	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
531510	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
531511	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6122.88	kw
531512	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
531513	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
531514	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	9 Month Operations	12	
531515	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
531516	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	13	
531517	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	13	
531518	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
531519	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
531520	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
531521	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
531522	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
531523	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
531524	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	General Comments		
531525	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
531526	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
531527	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
531528	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
531529	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
531530	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
531531	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
531532	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
531533	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Paint Condition	Good	
531534	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
531535	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
531536	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	9 Month Operations	11	
531537	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
531538	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
531539	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
531540	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	4.44	
531541	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	4.44	
531542	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	4.44	
531543	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
531544	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
531545	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
531546	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	1	
531547	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	General Comments	Fence and barbwire rusty	
531548	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
531549	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
531550	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
531551	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
531552	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
531553	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
531554	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
531555	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
531556	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
531557	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
531558	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
531559	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
531560	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
531561	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
531562	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
531563	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
531564	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Bushings Connection/Risers	Good	
531565	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Bushing Condition	Good	
531566	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Amps C Ø	200.0	
531567	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Amps B Ø	200.0	
531568	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Amps A Ø	200.0	
531569	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Accumulated Fault Duty C Ph V	.28	%
531570	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Accumulated Fault Duty B Ph V	.28	%
531571	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Accumulated Fault Duty A Ph V	.28	%
531572	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
531573	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
531574	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
531575	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
531576	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
531577	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
531578	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
531579	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
531580	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
531581	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
531582	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
531583	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	52	°F
531584	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
531585	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
531586	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
531587	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Totalizer Meter Reading	1.1172	
531588	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
531589	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
531590	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
531591	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
531592	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
531593	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
531594	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
531595	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
531596	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
531597	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
531598	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
531599	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
531600	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
531601	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
531602	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
531603	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
531604	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
531605	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
531606	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
531607	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
531608	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
531609	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
531610	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
531611	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	General Comments		
531612	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
531613	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
531614	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
531615	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
531616	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	704	
531617	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	704	
531618	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
531619	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
531620	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
531621	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
531622	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	General Comments		
531623	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
531624	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
531625	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
531626	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
531627	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
531628	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
531629	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Clear of Trash?	y	
531630	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
531631	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
531632	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
531633	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
531634	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
531635	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Tank Leaks	None	
531636	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
531637	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
531638	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Regulator As Left Counter	3150	
531639	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
531640	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
531641	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
531642	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
531643	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
531644	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
531645	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
531646	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
531647	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	General Comments		
531648	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
531649	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
531650	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
531651	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
531652	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
531653	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
531654	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
531655	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
531656	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
531657	3/11/2019 12:27	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
531658	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
531659	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
531660	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
531661	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
531662	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
531663	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
531664	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
531665	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Max Tap Position	12R	
531666	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Grounds in Place?	y	
531667	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	General Comments		
531668	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
531669	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Foundation Condition	Good	
531670	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
531671	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
531672	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
531673	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
531674	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
531675	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	778	
531676	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	7L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
531677	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Current Tap Position	9R	
531678	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
531679	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
531680	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
531681	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
531682	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Bushing Condition	Good	
531683	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
531684	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
531685	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
531686	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
531687	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	150.0	
531688	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	150.0	
531689	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	150.0	
531690	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
531691	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
531692	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	2R	
531693	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	Neutral	
531694	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
531695	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	164167	
531696	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	164165	
531697	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
531698	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
531699	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
531700	3/11/2019 10:22	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
531701	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	LTCC000616	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
531702	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	LTCC000616	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
531703	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
531704	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
531705	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
531706	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
531707	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
531708	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
531709	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
531710	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
531711	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
531712	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
531713	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
531714	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
531715	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
531716	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
531717	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	General Comments	Changed Charger to 55Vdc both float/Equalize...	
531718	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
531719	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
531720	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
531721	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
531722	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.7	VDC
531723	3/11/2019 12:35	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
531724	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
531725	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
531726	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
531727	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Oil Temp Present	36	°C
531728	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Oil Temp Max	52	°C
531729	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
531730	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
531731	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	LTC Totalizer Reading	8043.84	kw
531732	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
531733	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	General Comments		
531734	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	General Comments		
531735	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
531736	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
531737	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Follow-up Action Required?	n	
531738	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
531739	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
531740	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
531741	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
531742	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
531743	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
531744	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
531745	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
531746	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
531747	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
531748	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
531749	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
531750	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reg Oil Level	Good	
531751	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
531752	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
531753	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Min Tap Position	6R	
531754	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
531755	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
531756	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
531757	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
531758	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
531759	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
531760	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
531761	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	General Comments		
531762	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
531763	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
531764	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
531765	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
531766	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
531767	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
531768	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
531769	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
531770	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99983	
531771	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99983	
531772	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
531773	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
531774	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
531775	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Foundation Condition	Good	
531776	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
531777	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
531778	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
531779	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
531780	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
531781	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
531782	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
531783	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	General Comments		
531784	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
531785	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
531786	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
531787	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
531788	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
531789	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
531790	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
531791	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
531792	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Bushings Connection/Risers	Good	
531793	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Bushing Condition	Good	
531794	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Amps C Ø	60.0	
531795	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Amps B Ø	100.0	
531796	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
531797	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Switching Operations	0	
531798	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
531799	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Unknown Operations	0	
531800	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4453	
531801	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
531802	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Top Oil Temperature Present	20	°C
531803	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Top Oil Temperature Max	35	°C
531804	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
531805	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
531806	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
531807	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
531808	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
531809	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
531810	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
531811	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
531812	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
531813	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	712.48	kw
531814	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
531815	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	General Comments		
531816	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
531817	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
531818	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
531819	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
531820	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
531821	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
531822	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
531823	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Clear of Trash?	y	
531824	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
531825	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
531826	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
531827	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	n	
531828	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
531829	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
531830	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	General Comments	Washout in lot. No spill kit in station	
531831	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
531832	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Vegetation	None	
531833	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
531834	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
531835	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
531836	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
531837	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
531838	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
531839	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
531840	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
531841	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
531842	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	552	
531843	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	552	
531844	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
531845	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
531846	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Oil Temp Present	40	°C
531847	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Oil Temp Max	48	°C
531848	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
531849	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
531850	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	LTC Totalizer Reading	6311.52	kw
531851	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
531852	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	General Comments		
531853	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	General Comments		
531854	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
531855	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
531856	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Follow-up Action Required?	n	
531857	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
531858	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
531859	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
531860	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
531861	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
531862	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
531863	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
531864	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
531865	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
531866	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
531867	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
531868	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
531869	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
531870	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
531871	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
531872	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
531873	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
531874	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
531875	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
531876	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
531877	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
531878	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
531879	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
531880	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
531881	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Amps A Ø	100.0	
531882	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Accumulated Fault Duty C Ph V	.42	%
531883	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Accumulated Fault Duty B Ph V	.42	%
531884	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Accumulated Fault Duty A Ph V	.42	%
531885	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	9 Month Operations	8	
531886	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
531887	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
531888	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
531889	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
531890	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
531891	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
531892	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
531893	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
531894	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
531895	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
531896	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Totalizer Meter Reading	.8766	
531897	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
531898	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
531899	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
531900	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
531901	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
531902	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
531903	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
531904	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
531905	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
531906	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
531907	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
531908	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99985	
531909	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99985	
531910	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
531911	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
531912	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Unknown Operations	0	
531913	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Switching Operations	0	
531914	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Operations Counter AL	172	
531915	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Operations Counter AF	172	
531916	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Maintenance Operations	0	
531917	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	General Comments		
531918	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Patrol Inspection	General Comments		
531919	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Follow-up Action Required?	n	
531920	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Patrol Inspection	Follow-up Action Required?	n	
531921	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
531922	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
531923	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
531924	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
531925	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
531926	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
531927	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
531928	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
531929	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
531930	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
531931	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
531932	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
531933	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
531934	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
531935	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
531936	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
531937	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
531938	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
531939	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
531940	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
531941	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
531942	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	General Comments		
531943	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Follow-up Action Required?	n	
531944	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Equipment Properly Labeled?	y	
531945	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
531946	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
531947	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
531948	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
531949	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	450.0	
531950	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	450.0	
531951	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	400.0	
531952	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
531953	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Amps C Ø	0.0	
531954	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
531955	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
531956	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
531957	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
531958	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
531959	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
531960	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
531961	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
531962	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
531963	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
531964	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations A Ø	0	
531965	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations B Ø	0	
531966	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Totalizer Meter Multiplier	0	
531967	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
531968	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Heaters (All) Functioning?	y	
531969	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Grounds in Place?	y	
531970	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	General Comments		
531971	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	General Comments		
531972	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Foundation Condition	Good	
531973	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Follow-up Action Required?	n	
531974	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Follow-up Action Required?	n	
531975	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations Ground	0	
531976	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations C Ø	1	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
531977	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations B Ø	1	
531978	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations A Ø	1	
531979	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Adjusted Amps C Phase V	2.83	
531980	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Adjusted Amps B Phase V	2.83	
531981	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Adjusted Amps A Phase V	2.83	
531982	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Equipment Properly Labeled?	y	
531983	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Paint Condition	Good	
531984	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
531985	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
531986	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Winding Temp Max	20	°C
531987	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Winding Temp Present	10	°C
531988	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
531989	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
531990	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
531991	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
531992	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
531993	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
531994	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
531995	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
531996	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
531997	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
531998	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
531999	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
532000	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
532001	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
532002	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
532003	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	General Comments		
532004	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
532005	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
532006	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Foundation Condition	Good	
532007	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
532008	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
532009	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
532010	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
532011	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
532012	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
532013	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
532014	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
532015	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
532016	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
532017	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
532018	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
532019	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
532020	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
532021	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
532022	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
532023	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
532024	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
532025	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
532026	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
532027	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
532028	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
532029	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
532030	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
532031	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
532032	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	General Comments		
532033	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
532034	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
532035	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
532036	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
532037	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
532038	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
532039	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
532040	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
532041	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
532042	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Follow-up Action Required?	n	
532043	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
532044	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	General Comments		
532045	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	General Comments	Counter was entered wrong last quarter check	
532046	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
532047	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
532048	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Maintenance Operations	0	
532049	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
532050	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Operations Counter AF	443	
532051	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Operations Counter AL	443	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
532052	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations C Ø	0	
532053	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations Ground	0	
532054	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
532055	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
532056	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
532057	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	19651	
532058	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
532059	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
532060	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
532061	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
532062	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	2L	
532063	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	2R	
532064	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
532065	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
532066	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
532067	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
532068	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
532069	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
532070	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
532071	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
532072	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
532073	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
532074	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
532075	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
532076	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
532077	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
532078	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
532079	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
532080	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
532081	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
532082	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
532083	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
532084	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
532085	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
532086	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
532087	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
532088	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
532089	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
532090	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
532091	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
532092	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
532093	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
532094	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	52	°F
532095	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	Oil Temp Present	27	°C
532096	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	Oil Temp Max	46	°C
532097	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
532098	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
532099	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
532100	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Oil Temp Present	45	°C
532101	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Oil Temp Max	55	°C
532102	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
532103	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
532104	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
532105	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	LTC Totalizer Reading	15660.00	kw
532106	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
532107	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	General Comments		
532108	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	General Comments		
532109	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
532110	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
532111	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Follow-up Action Required?	n	
532112	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
532113	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
532114	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
532115	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
532116	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
532117	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
532118	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
532119	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
532120	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
532121	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	Follow-up Action Required?	n	
532122	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
532123	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
532124	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
532125	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
532126	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	All Connections OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
532127	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	Follow-up Action Required?	n	
532128	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	General Comments		
532129	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	LTC Operation Checked?	y	
532130	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
532131	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
532132	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
532133	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	VRR Time Delay	30	Seconds
532134	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	General Comments		
532135	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	General Comments		
532136	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC As Found Counter	13420	
532137	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Moisture and Leak Free?	y	
532138	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Num Operations Last 9 Months	2	
532139	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Operations Counter AF	50	
532140	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Operations Counter AL	50	
532141	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	1	
532142	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	SF6 Bushing Condition	Good	
532143	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	SF6 Pressure	80	psi
532144	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
532145	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Switching Operations	0	
532146	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Tank Paint Condition	Good	
532147	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
532148	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
532149	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Winding Temp Present	70	°C
532150	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Winding Temp Max	75	°C
532151	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Totalizer Meter Reading	.8700	
532152	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
532153	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
532154	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
532155	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
532156	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
532157	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	TV Winding Temp Present	40	°C
532158	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	TV Winding Temp Max	47	°C
532159	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
532160	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
532161	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
532162	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
532163	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
532164	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
532165	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	16	
532166	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
532167	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
532168	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
532169	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
532170	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.71	%
532171	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	96.0	
532172	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	96.0	
532173	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	84.0	
532174	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
532175	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
532176	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
532177	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
532178	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
532179	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
532180	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
532181	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
532182	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
532183	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
532184	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
532185	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
532186	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
532187	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
532188	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1R	
532189	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
532190	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
532191	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
532192	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
532193	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
532194	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
532195	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
532196	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
532197	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
532198	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
532199	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
532200	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
532201	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
532202	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	General Comments		
532203	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
532204	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	2R	
532205	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	4L	
532206	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
532207	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
532208	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
532209	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
532210	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	154555	
532211	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
532212	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
532213	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
532214	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
532215	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
532216	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
532217	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
532218	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
532219	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
532220	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
532221	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
532222	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	All Connections OK?	y	
532223	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	Follow-up Action Required?	n	
532224	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	General Comments		
532225	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	LTC Operation Checked?	y	
532226	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
532227	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
532228	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
532229	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	VRR Time Delay	45	Seconds
532230	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	100.00	
532231	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2200	psi
532232	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC As Left Counter	13426	
532233	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
532234	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Current Tap Position	9L	
532235	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
532236	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
532237	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
532238	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	General Comments		
532239	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
532240	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
532241	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
532242	3/11/2019 9:22	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
532243	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	LV Winding Temp Present	33	°C
532244	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	LV Winding Temp Max	43	°C
532245	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	HV Winding Temp Present	25	°C
532246	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	HV Winding Temp Max	38	°C
532247	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
532248	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	General Comments		
532249	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	General Comments		
532250	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
532251	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
532252	3/11/2019 14:14	Distribution	Imboden Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
532253	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Max Tap Position	5L	
532254	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
532255	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
532256	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
532257	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Min Tap Position	12L	
532258	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Operations Since Last Insp	713	
532259	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
532260	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
532261	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
532262	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
532263	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
532264	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
532265	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Patrol Inspection	Equipment Properly Labeled?	y	
532266	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
532267	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
532268	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations Ground	0	
532269	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations C Ø	0	
532270	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations B Ø	0	
532271	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
532272	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Operations A Ø	0	
532273	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations A Ø	0	
532274	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
532275	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
532276	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
532277	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Patrol Inspection	Equipment Properly Labeled?	y	
532278	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Amps C Ø	0.0	
532279	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Amps B Ø	0.0	
532280	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Amps A Ø	0.0	
532281	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
532282	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
532283	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Operations Since Last Insp	1014	
532284	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
532285	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
532286	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
532287	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
532288	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
532289	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
532290	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
532291	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
532292	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Foundation Condition	Good	
532293	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
532294	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
532295	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	General Comments		
532296	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
532297	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
532298	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
532299	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
532300	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
532301	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
532302	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
532303	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
532304	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
532305	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
532306	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
532307	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
532308	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
532309	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Readings	LTC Totalizer Reading	275.20	kw
532310	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
532311	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
532312	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
532313	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
532314	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
532315	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	Follow-up Action Required?	n	
532316	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
532317	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	General Comments		
532318	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	General Comments		
532319	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC As Found Counter	57244	
532320	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC As Left Counter	57246	
532321	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
532322	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Current Tap Position	2L	
532323	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Max Tap Position	2R	
532324	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Min Tap Position	6L	
532325	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
532326	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	31	°C
532327	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
532328	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
532329	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
532330	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	50	°C
532331	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	35	°C
532332	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
532333	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
532334	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
532335	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
532336	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
532337	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
532338	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
532339	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	4000	
532340	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Reading	.0688	
532341	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
532342	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	C0395	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
532343	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	9 Month Operations	8	
532344	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Accumulated Fault Duty A Ph V	55.42	%
532345	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Accumulated Fault Duty B Ph V	51.54	%
532346	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Accumulated Fault Duty C Ph V	49.88	%
532347	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Amps A Ø	150.0	
532348	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Amps B Ø	150.0	
532349	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Amps C Ø	150.0	
532350	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
532351	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
532352	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Fault Operations	0	
532353	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Follow-up Action Required?	n	
532354	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Follow-up Action Required?	n	
532355	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Foundation Condition	Good	
532356	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Gauge(s) Condition	Good	
532357	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
532358	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
532359	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	596	
532360	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
532361	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
532362	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
532363	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
532364	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
532365	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
532366	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
532367	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
532368	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
532369	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Evidence of Insects	None	
532370	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
532371	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
532372	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Floor Swept?	y	
532373	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
532374	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	General Comments		
532375	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
532376	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	General Comments		
532377	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
532378	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
532379	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Panels Dusted?	y	
532380	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
532381	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
532382	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
532383	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
532384	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	IOC A PHASE	
532385	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
532386	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	46	
532387	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	46	
532388	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
532389	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	General Comments		
532390	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Grounds in Place?	y	
532391	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Heaters (All) Functioning?	y	
532392	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Maintenance Operations	0	
532393	3/11/2019 9:42	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
532394	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
532395	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	9 Month Operations	1	
532396	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Operations B Ø	0	
532397	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Operations C Ø	0	
532398	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Operations Ground	0	
532399	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Patrol Inspection	Follow-up Action Required?	n	
532400	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Follow-up Action Required?	n	
532401	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Patrol Inspection	General Comments		
532402	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	General Comments		
532403	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Maintenance Operations	0	
532404	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Operations Counter AF	140	
532405	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Operations Counter AL	140	
532406	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Switching Operations	0	
532407	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Unknown Operations	0	
532408	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	8.7	
532409	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	21.1	
532410	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	14.0	
532411	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
532412	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
532413	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
532414	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
532415	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
532416	3/11/2019 10:32	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
532417	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
532418	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	16.99	%
532419	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	20.63	%
532420	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	13.35	%
532421	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	300.0	
532422	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	270.0	
532423	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	240.0	
532424	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
532425	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
532426	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Ambient Temperature	52	°F

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
532427	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Bushings Connection/Risers	Good	
532428	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
532429	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
532430	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Cabinet Paint Condition	Good	
532431	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
532432	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
532433	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
532434	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
532435	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
532436	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	200.0	
532437	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	200.0	
532438	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Current Tap Position	4R	
532439	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
532440	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
532441	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Foundation Condition	Good	
532442	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
532443	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	General Comments		
532444	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Grounds in Place?	y	
532445	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Max Tap Position	5R	
532446	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Min Tap Position	Neutral	
532447	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
532448	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
532449	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reg Oil Level	Good	
532450	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
532451	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
532452	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Regulator As Left Counter	0	
532453	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
532454	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
532455	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Tank Leaks	None	
532456	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Patrol Inspection	Equipment Properly Labeled?	y	
532457	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
532458	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
532459	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
532460	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations A Ø	0	
532461	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations B Ø	0	
532462	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	19.41	%
532463	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
532464	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LTCC000436	LTCControl	FV-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
532465	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LTCC000436	LTCControl	FV-TRANS 1	LTC Control Insp	General Comments	ok	
532466	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LTCC000437	LTCControl	FV-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
532467	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LTCC000437	LTCControl	FV-TRANS 3	LTC Control Insp	General Comments		
532468	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LTCC000437	LTCControl	FV-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
532469	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
532470	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
532471	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
532472	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LTCC000438	LTCControl	FV-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
532473	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LTCC000438	LTCControl	FV-TRANS 2	LTC Control Insp	General Comments		
532474	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
532475	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
532476	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	220.0	
532477	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	19.41	%
532478	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	19.41	%
532479	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	6	
532480	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations C Ø	0	
532481	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations Ground	0	
532482	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Patrol Inspection	Follow-up Action Required?	n	
532483	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Follow-up Action Required?	n	
532484	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Patrol Inspection	General Comments		
532485	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	General Comments		
532486	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Maintenance Operations	0	
532487	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Operations Counter AF	174	
532488	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	220.0	
532489	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	200.0	
532490	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	12.13	%
532491	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	23.05	%
532492	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	26.69	%
532493	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
532494	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Operations Counter AL	174	
532495	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
532496	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
532497	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
532498	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
532499	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	General Comments		
532500	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
532501	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
532502	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
532503	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Switching Operations	0	
532504	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Unknown Operations	0	
532505	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
532506	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
532507	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Vegetation	None	
532508	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	General Comments		
532509	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
532510	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
532511	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
532512	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
532513	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
532514	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
532515	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
532516	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
532517	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
532518	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
532519	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
532520	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
532521	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	600.0	
532522	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	700.0	
532523	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	550.0	
532524	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	1	
532525	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
532526	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1173	
532527	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1173	
532528	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
532529	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
532530	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
532531	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
532532	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
532533	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
532534	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
532535	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
532536	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
532537	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
532538	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
532539	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
532540	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
532541	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
532542	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
532543	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
532544	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
532545	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
532546	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
532547	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	44	
532548	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	44	
532549	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
532550	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
532551	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
532552	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
532553	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
532554	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
532555	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
532556	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
532557	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
532558	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	All Connections OK?	y	
532559	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	Follow-up Action Required?	n	
532560	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	General Comments		
532561	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	LTC Operation Checked?	y	
532562	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
532563	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
532564	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
532565	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	VRR Time Delay	30	Seconds
532566	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	2.60	%
532567	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	2.60	%
532568	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	2.60	%
532569	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
532570	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
532571	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
532572	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	9 Month Operations	0	
532573	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
532574	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
532575	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
532576	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Amps A Ø	0.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
532577	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Amps B Ø	0.0	
532578	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Amps C Ø	0.0	
532579	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
532580	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
532581	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
532582	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
532583	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
532584	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
532585	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
532586	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
532587	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
532588	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Bushing Condition	Good	
532589	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
532590	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
532591	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
532592	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
532593	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
532594	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	200.0	
532595	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	LTC Totalizer Reading	4005.12	kw
532596	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
532597	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
532598	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
532599	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
532600	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
532601	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
532602	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
532603	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
532604	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
532605	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Top Oil Temperature Max	60	°C
532606	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Foundation Condition	Good	
532607	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	General Comments		
532608	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	General Comments		
532609	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Grounds in Place?	y	
532610	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Heaters (All) Functioning?	y	
532611	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Maintenance Operations	0	
532612	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Moisture and Leak Free?	y	
532613	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Operations Counter AF	135	
532614	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Operations Counter AL	135	
532615	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Switching Operations	0	
532616	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Water Added	If low,note cell #~'s
532617	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
532618	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
532619	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Top Oil Temperature Present	35	°C
532620	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
532621	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Totalizer Meter Reading	1.2516	
532622	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Winding Temp Max	0	°C
532623	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Winding Temp Present	0	°C
532624	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
532625	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
532626	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Tank Paint Condition	Good	
532627	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Unknown Operations	0	
532628	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
532629	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
532630	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
532631	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
532632	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
532633	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	General Comments	all cells had water added	
532634	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Negative DC Ground	13.0	VDC
532635	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Positive DC Ground	14.0	VDC
532636	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
532637	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
532638	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
532639	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
532640	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
532641	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
532642	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
532643	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
532644	3/11/2019 11:22	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
532645	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
532646	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
532647	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	General Comments		
532648	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
532649	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	14784	
532650	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	14784	
532651	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
532652	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	3L	
532653	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	Neutral	
532654	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	12L	
532655	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
532656	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Vegetation	None	
532657	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
532658	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Equipment Properly Labeled?	y	
532659	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Follow-up Action Required?	n	
532660	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	General Comments		
532661	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
532662	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
532663	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	General Comments		
532664	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
532665	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
532666	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
532667	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
532668	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
532669	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
532670	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Clear of Trash?	y	
532671	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
532672	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
532673	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Ambient Temp	42	°F
532674	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Clear of Trash?	y	
532675	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
532676	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
532677	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
532678	3/11/2019 10:09	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Ambient Temp	42	°F
532679	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
532680	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LTCC000438	LTCControl	FV-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
532681	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
532682	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
532683	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
532684	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
532685	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
532686	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
532687	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
532688	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
532689	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
532690	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
532691	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
532692	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
532693	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	42	°F
532694	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
532695	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
532696	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
532697	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
532698	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
532699	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
532700	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
532701	3/11/2019 10:58	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
532702	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
532703	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
532704	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
532705	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
532706	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
532707	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
532708	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
532709	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	411.0	
532710	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	411.0	
532711	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	427.0	
532712	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
532713	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
532714	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
532715	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
532716	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
532717	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
532718	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	40	Seconds
532719	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Patrol Inspection	General Comments		
532720	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
532721	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
532722	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	9 Month Operations	1	
532723	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Accumulated Fault Duty A Ph V	7.43	%
532724	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Accumulated Fault Duty B Ph V	7.43	%
532725	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Accumulated Fault Duty C Ph V	6.57	%
532726	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Amps A Ø	150.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
532727	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Amps B Ø	100.0	
532728	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Amps C Ø	100.0	
532729	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Bushing Condition	Good	
532730	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Bushings Connection/Risers	Good	
532731	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Patrol Inspection	Follow-up Action Required?	n	
532732	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Patrol Inspection	Equipment Properly Labeled?	y	
532733	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
532734	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
532735	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Follow-up Action Required?	n	
532736	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
532737	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
532738	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Paint Condition	Good	
532739	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Equipment Properly Labeled?	y	
532740	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
532741	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
532742	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
532743	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations A Ø	0	
532744	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations B Ø	0	
532745	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations C Ø	0	
532746	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations Ground	0	
532747	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Follow-up Action Required?	n	
532748	3/11/2019 12:24	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Follow-up Action Required?	n	
532749	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
532750	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
532751	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	General Comments		
532752	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	General Comments		
532753	3/11/2019 14:43	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
532754	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
532755	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Patrol Inspection	General Comments		
532756	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Patrol Inspection	Follow-up Action Required?	n	
532757	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
532758	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
532759	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
532760	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	579	
532761	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	579	
532762	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	Follow-up Action Required?	n	
532763	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	16.09	%
532764	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	21.94	%
532765	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	15	
532766	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
532767	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	950	psi
532768	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
532769	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
532770	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Foundation Condition	Good	
532771	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	General Comments		
532772	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	General Comments		
532773	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Grounds in Place?	y	
532774	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Heaters (All) Functioning?	y	
532775	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Maintenance Operations	0	
532776	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
532777	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	General Comments		
532778	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Equipment Properly Labeled?	y	
532779	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Paint Condition	Good	
532780	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
532781	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
532782	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
532783	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	General Comments		
532784	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC As Found Counter	9313	
532785	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC As Left Counter	9313	
532786	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
532787	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
532788	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
532789	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
532790	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Current Tap Position	5L	
532791	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Max Tap Position	1L	
532792	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
532793	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Min Tap Position	8L	
532794	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
532795	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
532796	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Winding Temp Present	30	°C
532797	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Winding Temp Max	30	°C
532798	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Totalizer Meter Reading	1.0206	
532799	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
532800	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
532801	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
532802	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
532803	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
532804	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
532805	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
532806	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
532807	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Oil Temp Present	30	°C
532808	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Oil Temp Max	35	°C
532809	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
532810	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
532811	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
532812	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	LTC Totalizer Reading	4898.88	kw
532813	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
532814	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	9 Month Operations	4	
532815	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
532816	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
532817	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
532818	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
532819	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
532820	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
532821	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
532822	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
532823	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
532824	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
532825	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	96.0	
532826	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	96.0	
532827	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
532828	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
532829	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
532830	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	84.0	
532831	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
532832	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
532833	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
532834	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
532835	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Follow-up Action Required?	n	
532836	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
532837	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
532838	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	13.16	%
532839	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
532840	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
532841	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
532842	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
532843	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
532844	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
532845	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations A Ø	0	
532846	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations B Ø	0	
532847	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations C Ø	0	
532848	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations Ground	0	
532849	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Follow-up Action Required?	n	
532850	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Follow-up Action Required?	n	
532851	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
532852	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
532853	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
532854	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
532855	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
532856	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
532857	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	General Comments		
532858	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	General Comments		
532859	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
532860	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
532861	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
532862	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
532863	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Unknown Operations	0	
532864	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
532865	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
532866	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
532867	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Amps A Ø	0.0	
532868	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
532869	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
532870	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
532871	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Winding Temp Max	50	°C
532872	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
532873	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Amps B Ø	0.0	
532874	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C
532875	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
532876	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
532877	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
532878	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
532879	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
532880	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
532881	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
532882	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Amps A Ø	76.0	
532883	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
532884	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Accumulated Fault Duty B Ph V	.38	%
532885	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
532886	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
532887	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
532888	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
532889	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
532890	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
532891	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
532892	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
532893	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Oil Temp Max	15	°C
532894	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
532895	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	9 Month Operations	3	
532896	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Oil Temp Present	10	°C
532897	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
532898	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
532899	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
532900	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	284	
532901	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
532902	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
532903	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Moisture and Leak Free?	y	
532904	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Operations Counter AF	212	
532905	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Operations Counter AL	212	
532906	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
532907	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	284	
532908	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
532909	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
532910	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
532911	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Switching Operations	0	
532912	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
532913	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Tank Paint Condition	Good	
532914	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
532915	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
532916	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
532917	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Unknown Operations	0	
532918	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Tank Paint Condition	Good	
532919	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Switching Operations	2	
532920	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Operations Counter AL	209	
532921	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
532922	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Operations Counter AF	206	
532923	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
532924	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Moisture and Leak Free?	y	
532925	3/11/2019 13:59	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Maintenance Operations	0	
532926	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
532927	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
532928	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Accumulated Fault Duty A Ph V	.38	%
532929	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
532930	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	General Comments		
532931	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	General Comments		
532932	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
532933	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
532934	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
532935	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
532936	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
532937	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Bushings Connection/Risers	Good	
532938	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Bushing Condition	Good	
532939	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	20	°C
532940	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
532941	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Operations Since Last Insp	269	
532942	3/14/2019 8:11	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
532943	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
532944	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
532945	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
532946	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Amps C Ø	64.0	
532947	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Follow-up Action Required?	n	
532948	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
532949	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
532950	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
532951	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
532952	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
532953	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
532954	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
532955	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
532956	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
532957	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
532958	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
532959	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
532960	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
532961	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
532962	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
532963	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
532964	3/11/2019 14:20	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Amps B Ø	67.0	
532965	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	45	°C
532966	3/22/2019 10:40	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
532967	3/11/2019 14:56	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
532968	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
532969	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
532970	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
532971	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
532972	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
532973	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
532974	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
532975	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
532976	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
532977	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
532978	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
532979	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
532980	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations A Ø	0	
532981	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
532982	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Patrol Inspection	General Comments		
532983	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
532984	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations B Ø	0	
532985	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
532986	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
532987	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
532988	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
532989	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations C Ø	0	
532990	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Patrol Inspection	General Comments		
532991	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Patrol Inspection	Follow-up Action Required?	n	
532992	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	General Comments		
532993	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Patrol Inspection	Equipment Properly Labeled?	y	
532994	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
532995	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
532996	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
532997	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	PF000256	PowerFuse	NA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
532998	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	PF000256	PowerFuse	NA-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
532999	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
533000	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
533001	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
533002	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations Ground	0	
533003	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
533004	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
533005	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
533006	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
533007	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Follow-up Action Required?	n	
533008	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Follow-up Action Required?	n	
533009	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	PF000257	PowerFuse	NA-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
533010	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	PF000257	PowerFuse	NA-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
533011	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
533012	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	PF000255	PowerFuse	NA-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
533013	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	PF000255	PowerFuse	NA-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
533014	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
533015	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
533016	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Foundation Condition	Good	
533017	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	General Comments		
533018	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	General Comments		
533019	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
533020	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Moisture and Leak Free?	y	
533021	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Maintenance Operations	0	
533022	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Grounds in Place?	y	
533023	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
533024	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
533025	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	General Comments		
533026	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
533027	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
533028	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
533029	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
533030	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
533031	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
533032	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	6.700	millivolts
533033	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
533034	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
533035	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
533036	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Clear of Trash?	y	
533037	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
533038	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
533039	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
533040	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
533041	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
533042	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
533043	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
533044	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
533045	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
533046	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Foundation Condition	Good	
533047	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
533048	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	General Comments		
533049	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	134.1	VDC
533050	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	134.1	VDC
533051	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	3.5	amps
533052	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
533053	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
533054	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
533055	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
533056	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
533057	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Oil Temp Present	42	°C
533058	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Oil Temp Max	51	°C
533059	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
533060	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
533061	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	LTC Totalizer Reading	17521.92	kw
533062	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
533063	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
533064	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
533065	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
533066	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
533067	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
533068	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
533069	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
533070	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
533071	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Follow-up Action Required?	n	
533072	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
533073	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
533074	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	General Comments		
533075	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
533076	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
533077	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
533078	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
533079	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
533080	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
533081	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
533082	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
533083	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	General Comments		
533084	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
533085	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	General Comments		
533086	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	General Comments		
533087	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
533088	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
533089	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Tank Leaks	None	
533090	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
533091	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Operations Counter	58	
533092	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
533093	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	PF000259	PowerFuse	NA-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
533094	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	PF000259	PowerFuse	NA-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
533095	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
533096	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	PF000260	PowerFuse	NA-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
533097	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	PF000260	PowerFuse	NA-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
533098	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Tank Leaks	None	
533099	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
533100	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
533101	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
533102	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
533103	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
533104	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
533105	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
533106	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
533107	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
533108	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
533109	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Vegetation	None	
533110	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
533111	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
533112	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Regulator As Left Counter	202741	
533113	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
533114	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
533115	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
533116	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
533117	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
533118	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Min Tap Position	2L	
533119	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Max Tap Position	10R	
533120	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
533121	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	General Comments		
533122	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
533123	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
533124	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
533125	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Rust	
533126	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
533127	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
533128	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
533129	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
533130	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
533131	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
533132	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Current Tap Position	6R	
533133	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
533134	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
533135	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
533136	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
533137	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
533138	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
533139	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
533140	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
533141	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
533142	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
533143	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
533144	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
533145	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
533146	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
533147	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
533148	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
533149	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
533150	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
533151	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Amps A Ø	60.0	
533152	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Amps B Ø	62.0	
533153	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Amps C Ø	41.0	
533154	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
533155	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
533156	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
533157	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
533158	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
533159	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
533160	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
533161	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
533162	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
533163	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
533164	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
533165	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
533166	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
533167	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
533168	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Amps B Ø	186.0	
533169	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Amps C Ø	186.0	
533170	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Patrol Inspection	Equipment Properly Labeled?	y	
533171	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
533172	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
533173	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
533174	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Winding Temp Present	40	°C
533175	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
533176	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
533177	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
533178	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
533179	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
533180	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
533181	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
533182	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
533183	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
533184	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
533185	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	General Comments		
533186	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
533187	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
533188	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Winding Temp Max	40	°C
533189	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Totalizer Meter Reading	1.8252	
533190	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
533191	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
533192	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
533193	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
533194	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
533195	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
533196	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
533197	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations A Ø	0	
533198	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations B Ø	0	
533199	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations C Ø	0	
533200	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations Ground	0	
533201	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Patrol Inspection	Follow-up Action Required?	n	
533202	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
533203	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
533204	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Follow-up Action Required?	n	
533205	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Patrol Inspection	General Comments		
533206	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	General Comments		
533207	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Maintenance Operations	0	
533208	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Patrol Inspection	General Comments		
533209	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Operations Counter AF	186	
533210	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Operations Counter AL	186	
533211	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Switching Operations	0	
533212	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Unknown Operations	0	
533213	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	General Comments		
533214	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Maintenance Operations	0	
533215	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Operations Counter AF	387	
533216	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Operations Counter AL	387	
533217	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
533218	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
533219	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Switching Operations	0	
533220	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Tank Paint Condition	Good	
533221	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
533222	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
533223	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
533224	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
533225	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
533226	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
533227	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
533228	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
533229	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Unknown Operations	0	
533230	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	General Comments	missing one fan	
533231	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
533232	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
533233	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Operations Counter AF	237	
533234	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Operations Counter AL	237	
533235	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
533236	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Equipment Properly Labeled?	y	
533237	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Paint Condition	Good	
533238	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
533239	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
533240	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
533241	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Bushings Connection/Risers	Good	
533242	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Bushing Condition	Good	
533243	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Amps C Ø	320.0	
533244	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Amps B Ø	300.0	
533245	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Amps A Ø	260.0	
533246	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Accumulated Fault Duty C Ph V	5.97	%
533247	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
533248	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
533249	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
533250	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
533251	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	9 Month Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
533252	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Accumulated Fault Duty A Ph V	1.13	%
533253	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
533254	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Operations Counter AL	99956	
533255	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
533256	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Accumulated Fault Duty B Ph V	6.83	%
533257	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Accumulated Fault Duty A Ph V	5.97	%
533258	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations Ground	0	
533259	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
533260	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
533261	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
533262	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
533263	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
533264	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
533265	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	9 Month Operations	8	
533266	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
533267	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
533268	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Amps A Ø	179.0	
533269	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
533270	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
533271	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
533272	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
533273	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
533274	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
533275	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
533276	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
533277	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
533278	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
533279	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
533280	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
533281	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
533282	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
533283	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
533284	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	General Comments		
533285	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
533286	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
533287	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
533288	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Switching Operations	0	
533289	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Tank Paint Condition	Good	
533290	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Unknown Operations	0	
533291	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
533292	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
533293	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
533294	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
533295	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
533296	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Amps C Ø	1001.0	
533297	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Amps B Ø	1008.0	
533298	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Amps A Ø	997.0	
533299	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	1.13	%
533300	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	1.13	%
533301	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
533302	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
533303	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
533304	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	1.13	%
533305	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	9 Month Operations	0	
533306	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
533307	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	n	
533308	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
533309	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
533310	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
533311	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
533312	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
533313	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
533314	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
533315	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
533316	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
533317	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Bushing Condition	Good	
533318	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Amps C Ø	0.0	
533319	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Amps B Ø	0.0	
533320	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Amps A Ø	0.0	
533321	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
533322	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
533323	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
533324	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	9 Month Operations	6	
533325	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
533326	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
533327	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
533328	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
533329	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
533330	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	PF000258	PowerFuse	NA-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
533331	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	PF000258	PowerFuse	NA-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
533332	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
533333	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
533334	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
533335	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
533336	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
533337	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Vegetation	None	
533338	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	General Comments		
533339	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
533340	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
533341	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
533342	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
533343	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
533344	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
533345	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
533346	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
533347	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
533348	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
533349	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
533350	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
533351	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
533352	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
533353	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
533354	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
533355	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
533356	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
533357	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
533358	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
533359	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Clear of Trash?	y	
533360	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
533361	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
533362	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
533363	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
533364	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	General Comments		
533365	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
533366	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
533367	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
533368	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
533369	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
533370	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
533371	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
533372	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
533373	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
533374	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
533375	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
533376	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
533377	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Switching Operations	0	
533378	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Unknown Operations	0	
533379	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
533380	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
533381	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
533382	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
533383	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
533384	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
533385	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
533386	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	General Comments	Substation Name sign is faded. Hard to read the emergency number.	
533387	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	n	
533388	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
533389	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
533390	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
533391	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Clear of Trash?	y	
533392	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
533393	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
533394	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
533395	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
533396	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
533397	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	General Comments		
533398	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
533399	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Vegetation	None	
533400	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
533401	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
533402	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
533403	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
533404	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
533405	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
533406	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
533407	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
533408	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
533409	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
533410	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
533411	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	553	
533412	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
533413	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
533414	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
533415	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Operations Counter AF	99956	
533416	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
533417	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Maintenance Operations	0	
533418	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
533419	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	General Comments		
533420	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	General Comments		
533421	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	
533422	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Follow-up Action Required?	n	
533423	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	
533424	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations Ground	0	
533425	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations C Ø	0	
533426	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations B Ø	0	
533427	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations A Ø	0	
533428	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
533429	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
533430	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
533431	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
533432	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
533433	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
533434	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Foundation Condition	Good	
533435	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
533436	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
533437	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	General Comments		
533438	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
533439	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
533440	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
533441	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
533442	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
533443	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
533444	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
533445	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
533446	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
533447	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
533448	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
533449	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations A Ø	0	
533450	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Adjusted Amps C Phase V	11.99	
533451	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Adjusted Amps B Phase V	11.99	
533452	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
533453	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
533454	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
533455	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
533456	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
533457	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
533458	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
533459	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	General Comments		
533460	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
533461	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
533462	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
533463	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
533464	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
533465	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
533466	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
533467	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
533468	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Regulator As Left Counter	168447	
533469	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
533470	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
533471	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Tank Leaks	None	
533472	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
533473	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
533474	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations A Ø	0	
533475	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations B Ø	0	
533476	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
533477	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	9 Month Operations	0	
533478	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Accumulated Fault Duty A Ph V	1.13	%
533479	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Accumulated Fault Duty B Ph V	1.13	%
533480	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Accumulated Fault Duty C Ph V	1.13	%
533481	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Amps A Ø	141.0	
533482	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Amps B Ø	145.0	
533483	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Amps C Ø	142.0	
533484	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Patrol Inspection	Equipment Properly Labeled?	y	
533485	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations Ground	0	
533486	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
533487	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Follow-up Action Required?	n	
533488	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Patrol Inspection	General Comments		
533489	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	General Comments		
533490	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
533491	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Maintenance Operations	0	
533492	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Operations Counter AF	149	
533493	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Operations Counter AL	149	
533494	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Switching Operations	0	
533495	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Unknown Operations	0	
533496	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	9 Month Operations	0	
533497	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
533498	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
533499	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
533500	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Amps A Ø	420.0	
533501	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Amps B Ø	600.0	
533502	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Amps C Ø	600.0	
533503	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Bushing Condition	Good	
533504	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
533505	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
533506	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
533507	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	LTC Operation Checked?	y	
533508	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
533509	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
533510	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
533511	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	VRR Time Delay	30	Seconds
533512	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
533513	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
533514	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	23.0	
533515	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	23.0	
533516	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	20.0	
533517	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BCH001118	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
533518	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Moisture and Leak Free?	y	
533519	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Maintenance Operations	0	
533520	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Grounds in Place?	y	
533521	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	General Comments		
533522	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	General Comments		
533523	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Foundation Condition	Good	
533524	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Follow-up Action Required?	n	
533525	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Follow-up Action Required?	n	
533526	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
533527	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
533528	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Regulator As Left Counter	79891	
533529	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
533530	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
533531	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Tank Leaks	None	
533532	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
533533	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
533534	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
533535	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	General Comments		
533536	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
533537	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
533538	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
533539	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
533540	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
533541	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
533542	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
533543	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
533544	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
533545	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
533546	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	9 Month Operations	0	
533547	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
533548	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
533549	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
533550	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
533551	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
533552	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
533553	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
533554	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Amps A Ø	0.0	
533555	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Amps B Ø	0.0	
533556	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Amps C Ø	0.0	
533557	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
533558	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
533559	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
533560	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
533561	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
533562	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
533563	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations Ground	2	
533564	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations C Ø	0	
533565	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations B Ø	0	
533566	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
533567	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
533568	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Floor Swept?	y	
533569	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
533570	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
533571	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
533572	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
533573	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
533574	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
533575	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations A Ø	0	
533576	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations B Ø	0	
533577	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations C Ø	0	
533578	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations Ground	0	
533579	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Follow-up Action Required?	n	
533580	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Follow-up Action Required?	n	
533581	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Foundation Condition	Good	
533582	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	General Comments		
533583	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	General Comments		
533584	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Grounds in Place?	y	
533585	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Maintenance Operations	0	
533586	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
533587	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations B Ø	0	
533588	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations C Ø	0	
533589	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations Ground	0	
533590	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Patrol Inspection	Follow-up Action Required?	n	
533591	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Follow-up Action Required?	n	
533592	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Patrol Inspection	General Comments		
533593	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	General Comments		
533594	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Maintenance Operations	0	
533595	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Operations Counter AF	166	
533596	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Operations Counter AL	166	
533597	3/8/2019 14:46	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
533598	3/8/2019 14:46	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	General Comments		
533599	3/8/2019 14:46	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
533600	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Evidence of Insects	None	
533601	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
533602	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
533603	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
533604	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
533605	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Broom on Site?	y	
533606	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
533607	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
533608	3/8/2019 14:46	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
533609	3/8/2019 14:46	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
533610	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Switching Operations	0	
533611	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Unknown Operations	0	
533612	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Operations Counter AF	241	
533613	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Operations Counter AL	241	
533614	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
533615	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Switching Operations	0	
533616	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Tank Paint Condition	Good	
533617	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Unknown Operations	0	
533618	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LTCC000531	LTCControl	CG-TRANS 1	LTC Control Insp	Follow-up Action Required?	y	
533619	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LTCC000531	LTCControl	CG-TRANS 1	LTC Control Insp	General Comments	Animal Guard has fallen off	
533620	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Adjusted Amps A Phase V	11.99	
533621	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Equipment Properly Labeled?	y	
533622	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Paint Condition	Good	
533623	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
533624	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations A Ø	0	
533625	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
533626	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
533627	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
533628	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
533629	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
533630	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
533631	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
533632	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
533633	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Foundation Condition	Good	
533634	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
533635	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
533636	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	General Comments		
533637	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
533638	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
533639	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
533640	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
533641	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
533642	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
533643	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
533644	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
533645	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
533646	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
533647	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
533648	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
533649	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
533650	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
533651	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
533652	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
533653	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
533654	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
533655	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
533656	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
533657	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
533658	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
533659	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
533660	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
533661	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
533662	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
533663	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
533664	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
533665	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
533666	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
533667	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
533668	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
533669	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
533670	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
533671	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Trash Emptied?	y	
533672	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
533673	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
533674	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
533675	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
533676	3/8/2019 14:12	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
533677	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
533678	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
533679	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Panels Dusted?	y	
533680	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
533681	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
533682	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	General Comments		
533683	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
533684	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	337	
533685	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
533686	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
533687	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6L	
533688	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
533689	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
533690	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC As Left Counter	13743	
533691	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC As Found Counter	13743	
533692	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
533693	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	General Comments		
533694	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
533695	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
533696	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
533697	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
533698	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
533699	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
533700	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Unknown Operations	0	
533701	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
533702	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Current Tap Position	6R	
533703	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
533704	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
533705	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Switching Operations	0	
533706	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Operations Counter AL	181	
533707	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
533708	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
533709	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	General Comments		
533710	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
533711	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Operations Counter AF	181	
533712	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Maintenance Operations	0	
533713	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	General Comments		
533714	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Patrol Inspection	General Comments		
533715	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Follow-up Action Required?	n	
533716	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Patrol Inspection	Follow-up Action Required?	n	
533717	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations Ground	0	
533718	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations C Ø	0	
533719	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Max Tap Position	11R	
533720	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Min Tap Position	2L	
533721	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
533722	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations B Ø	0	
533723	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations A Ø	0	
533724	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
533725	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
533726	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
533727	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
533728	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Regulator As Left Counter	72503	
533729	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
533730	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
533731	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
533732	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
533733	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
533734	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Patrol Inspection	Equipment Properly Labeled?	y	
533735	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Amps C Ø	497.0	
533736	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Amps B Ø	505.0	
533737	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Amps A Ø	189.0	
533738	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Accumulated Fault Duty C Ph V	2.26	%
533739	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Accumulated Fault Duty B Ph V	3.39	%
533740	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Accumulated Fault Duty A Ph V	3.39	%
533741	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Amps B Ø	184.0	
533742	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Amps C Ø	193.0	
533743	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Patrol Inspection	Equipment Properly Labeled?	y	
533744	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
533745	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
533746	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
533747	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations A Ø	0	
533748	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
533749	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations B Ø	0	
533750	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations C Ø	0	
533751	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations Ground	0	
533752	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Patrol Inspection	Follow-up Action Required?	n	
533753	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Follow-up Action Required?	n	
533754	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Patrol Inspection	General Comments		
533755	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	General Comments		
533756	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Maintenance Operations	0	
533757	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	Oil Temp Max	31	°C
533758	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	Oil Temp Present	18	°C
533759	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
533760	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Operations Counter AF	173	
533761	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Operations Counter AL	173	
533762	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Switching Operations	0	
533763	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Unknown Operations	0	
533764	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Patrol Inspection	General Comments		
533765	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Patrol Inspection	Follow-up Action Required?	n	
533766	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Patrol Inspection	Equipment Properly Labeled?	y	
533767	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
533768	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
533769	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
533770	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
533771	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
533772	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
533773	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
533774	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
533775	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	32	°C
533776	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	18	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
533777	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	32	°C
533778	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	18	°C
533779	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	32	°C
533780	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	18	°C
533781	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
533782	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	General Comments		
533783	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
533784	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
533785	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
533786	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
533787	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
533788	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
533789	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
533790	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
533791	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
533792	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
533793	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
533794	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
533795	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
533796	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
533797	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
533798	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
533799	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
533800	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
533801	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
533802	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
533803	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
533804	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
533805	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
533806	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	Oil Temp Present	12	°C
533807	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
533808	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
533809	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
533810	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
533811	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
533812	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	General Comments		
533813	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
533814	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Unknown Operations	0	
533815	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Tank Paint Condition	Good	
533816	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Switching Operations	0	
533817	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
533818	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Operations Counter AL	378	
533819	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Operations Counter AF	378	
533820	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
533821	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
533822	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BCH001118	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
533823	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BCH001118	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
533824	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BCH001118	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
533825	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BCH001118	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
533826	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
533827	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BCH001118	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
533828	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BCH001118	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
533829	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
533830	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
533831	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	118	
533832	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
533833	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
533834	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	Oil Temp Max	25	°C
533835	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
533836	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
533837	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
533838	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	General Comments		
533839	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	General Comments		
533840	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
533841	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
533842	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
533843	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
533844	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
533845	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
533846	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
533847	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
533848	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Clear of Trash?	y	
533849	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
533850	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
533851	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
533852	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	All Connections OK?	y	
533853	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
533854	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
533855	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
533856	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	Follow-up Action Required?	n	
533857	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	General Comments		
533858	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	9 Month Operations	0	
533859	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Tank Leaks	None	
533860	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
533861	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
533862	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Vegetation	None	
533863	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
533864	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
533865	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
533866	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
533867	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
533868	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
533869	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
533870	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
533871	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
533872	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
533873	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	General Comments		
533874	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
533875	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
533876	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Broom on Site?	y	
533877	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
533878	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
533879	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
533880	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Evidence of Insects	None	
533881	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
533882	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
533883	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Floor Swept?	y	
533884	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
533885	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
533886	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	General Comments		
533887	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
533888	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Panels Dusted?	y	
533889	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
533890	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Trash Emptied?	y	
533891	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
533892	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
533893	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
533894	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
533895	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
533896	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
533897	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
533898	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
533899	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Foundation Condition	Good	
533900	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
533901	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	General Comments		
533902	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
533903	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
533904	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
533905	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
533906	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
533907	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
533908	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
533909	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
533910	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
533911	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
533912	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
533913	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
533914	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
533915	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
533916	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
533917	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
533918	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
533919	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
533920	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
533921	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
533922	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
533923	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
533924	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
533925	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
533926	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
533927	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Foundation Condition	Good	
533928	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	General Comments		
533929	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	General Comments		
533930	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Grounds in Place?	y	
533931	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Maintenance Operations	0	
533932	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Moisture and Leak Free?	y	
533933	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
533934	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
533935	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
533936	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
533937	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
533938	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
533939	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Unknown Operations	0	
533940	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
533941	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Tank Paint Condition	Good	
533942	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Switching Operations	0	
533943	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
533944	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Operations Counter AL	207	
533945	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Operations Counter AF	207	
533946	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Moisture and Leak Free?	y	
533947	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Maintenance Operations	0	
533948	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Grounds in Place?	y	
533949	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	General Comments		
533950	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	General Comments		
533951	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Foundation Condition	Good	
533952	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Follow-up Action Required?	n	
533953	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Follow-up Action Required?	n	
533954	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Operations Ground	0	
533955	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Operations C Ø	0	
533956	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Operations B Ø	0	
533957	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Operations A Ø	0	
533958	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
533959	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
533960	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
533961	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Equipment Properly Labeled?	y	
533962	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Cabinet Paint Condition	Good	
533963	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
533964	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
533965	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
533966	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Very Low	
533967	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Operations Since Last Insp	719	
533968	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Min Tap Position	12L	
533969	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Max Tap Position	1R	
533970	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Current Tap Position	8L	
533971	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
533972	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC As Left Counter	275641	
533973	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC As Found Counter	275637	
533974	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	General Comments	need to add oil	
533975	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
533976	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
533977	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
533978	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
533979	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Operations Counter AL	179	
533980	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Operations Counter AF	179	
533981	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Moisture and Leak Free?	y	
533982	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Maintenance Operations	0	
533983	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Grounds in Place?	y	
533984	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	General Comments		
533985	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	General Comments		
533986	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Foundation Condition	Good	
533987	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Follow-up Action Required?	n	
533988	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Follow-up Action Required?	n	
533989	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations Ground	0	
533990	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations C Ø	0	
533991	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations B Ø	0	
533992	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations A Ø	0	
533993	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
533994	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
533995	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
533996	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Equipment Properly Labeled?	y	
533997	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Paint Condition	Good	
533998	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
533999	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
534000	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
534001	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
534002	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Bushing Condition	Good	
534003	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Amps C Ø	131.0	
534004	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Amps B Ø	128.0	
534005	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Amps A Ø	119.0	
534006	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
534007	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
534008	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
534009	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
534010	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	9 Month Operations	3	
534011	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
534012	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
534013	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
534014	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Paint Condition	Good	
534015	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Equipment Properly Labeled?	y	
534016	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
534017	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
534018	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
534019	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations A Ø	0	
534020	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations B Ø	0	
534021	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations C Ø	0	
534022	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
534023	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations Ground	0	
534024	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Follow-up Action Required?	n	
534025	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Follow-up Action Required?	n	
534026	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
534027	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
534028	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
534029	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
534030	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
534031	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
534032	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
534033	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
534034	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
534035	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
534036	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	49	°F
534037	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
534038	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	9 Month Operations	7	
534039	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Accumulated Fault Duty A Ph V	.43	%
534040	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Accumulated Fault Duty B Ph V	.43	%
534041	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Accumulated Fault Duty C Ph V	.43	%
534042	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
534043	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
534044	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Trash Emptied?	y	
534045	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
534046	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
534047	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Panels Dusted?	y	
534048	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
534049	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
534050	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	General Comments		
534051	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
534052	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
534053	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
534054	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
534055	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
534056	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
534057	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
534058	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
534059	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
534060	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
534061	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
534062	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
534063	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
534064	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
534065	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	General Comments		
534066	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
534067	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
534068	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Floor Swept?	y	
534069	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
534070	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
534071	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Totalizer Meter Reading	.8490	
534072	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Winding Temp Max	45	°C
534073	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Amps A Ø	40.0	
534074	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
534075	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Amps B Ø	60.0	
534076	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Amps C Ø	60.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
534077	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Bushing Condition	Good	
534078	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Bushings Connection/Risers	Good	
534079	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
534080	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
534081	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
534082	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
534083	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Evidence of Insects	None	
534084	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
534085	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
534086	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
534087	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Broom on Site?	y	
534088	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
534089	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
534090	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
534091	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
534092	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	General Comments		
534093	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
534094	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
534095	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
534096	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
534097	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
534098	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
534099	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
534100	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
534101	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
534102	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
534103	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
534104	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
534105	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Follow-up Action Required?	n	
534106	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
534107	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
534108	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	General Comments		
534109	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	General Comments	Added Nitrogen	
534110	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
534111	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	LTC Totalizer Reading	12225.60	kw
534112	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
534113	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
534114	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Oil Temp Max	75	°C
534115	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Oil Temp Present	33	°C
534116	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
534117	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	Follow-up Action Required?	n	
534118	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
534119	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
534120	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
534121	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Clear of Trash?	y	
534122	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
534123	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
534124	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
534125	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
534126	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
534127	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
534128	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	General Comments		
534129	3/8/2019 10:36	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Vegetation	None	
534130	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
534131	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Unknown Operations	0	
534132	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Tank Paint Condition	Good	
534133	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Switching Operations	1	
534134	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Operations Counter AL	169	
534135	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Operations Counter AF	169	
534136	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
534137	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
534138	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
534139	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
534140	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
534141	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
534142	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
534143	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
534144	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	General Comments		
534145	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
534146	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
534147	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
534148	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
534149	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
534150	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
534151	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Winding Temp Present	20	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
534152	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Oil Temp Present	18	°C
534153	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
534154	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
534155	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
534156	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
534157	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
534158	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
534159	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
534160	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
534161	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
534162	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	9 Month Operations	2	
534163	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
534164	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	240	
534165	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.1800	
534166	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Patrol Inspection	General Comments		
534167	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Patrol Inspection	Follow-up Action Required?	n	
534168	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Patrol Inspection	Equipment Properly Labeled?	y	
534169	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	9 Month Operations	2	
534170	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
534171	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
534172	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
534173	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Amps A Ø	80.0	
534174	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Amps B Ø	64.0	
534175	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Amps C Ø	66.0	
534176	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Bushing Condition	Good	
534177	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Bushings Connection/Risers	Good	
534178	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
534179	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Winding Temp Max	25	°C
534180	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
534181	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
534182	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
534183	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
534184	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
534185	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
534186	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Oil Temp Max	40	°C
534187	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
534188	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
534189	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
534190	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
534191	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
534192	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
534193	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
534194	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.4322	
534195	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	400	
534196	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
534197	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
534198	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Unknown Operations	0	
534199	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Tank Paint Condition	Good	
534200	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Switching Operations	0	
534201	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Accumulated Fault Duty C Ph V	4.47	%
534202	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Accumulated Fault Duty B Ph V	2.68	%
534203	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Accumulated Fault Duty A Ph V	3.57	%
534204	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	9 Month Operations	7	
534205	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
534206	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	60	°C
534207	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
534208	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
534209	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
534210	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
534211	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Bushings Connection/Risers	Good	
534212	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Bushing Condition	Good	
534213	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Amps C Ø	300.0	
534214	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Amps B Ø	280.0	
534215	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Amps A Ø	300.0	
534216	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Unknown Operations	0	
534217	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Tank Paint Condition	Good	
534218	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Switching Operations	1	
534219	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Operations Counter AL	178	
534220	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Operations Counter AF	178	
534221	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Moisture and Leak Free?	y	
534222	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Maintenance Operations	0	
534223	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Grounds in Place?	y	
534224	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	General Comments		
534225	3/8/2019 14:46	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
534226	3/8/2019 14:46	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
534227	3/8/2019 14:46	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
534228	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	General Comments		
534229	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Foundation Condition	Good	
534230	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Follow-up Action Required?	n	
534231	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Follow-up Action Required?	n	
534232	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations Ground	0	
534233	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations C Ø	0	
534234	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations B Ø	0	
534235	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations A Ø	0	
534236	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
534237	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
534238	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
534239	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Undetermined	
534240	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
534241	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
534242	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
534243	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
534244	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
534245	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
534246	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Equipment Properly Labeled?	y	
534247	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Paint Condition	Good	
534248	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
534249	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
534250	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
534251	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
534252	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
534253	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Bushings Connection/Risers	Good	
534254	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
534255	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	General Comments		
534256	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Bushing Condition	Good	
534257	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	General Comments		
534258	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
534259	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
534260	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Amps C Ø	42.0	
534261	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Amps B Ø	38.0	
534262	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	43.20	kw
534263	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
534264	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
534265	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Oil Temp Max	24	°C
534266	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Amps A Ø	38.0	
534267	3/8/2019 14:12	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
534268	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Grounds in Place?	y	
534269	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	General Comments		
534270	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	General Comments		
534271	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Foundation Condition	Good	
534272	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Follow-up Action Required?	n	
534273	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Follow-up Action Required?	n	
534274	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations Ground	0	
534275	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations C Ø	0	
534276	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations B Ø	0	
534277	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations A Ø	0	
534278	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
534279	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
534280	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
534281	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Equipment Properly Labeled?	y	
534282	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Paint Condition	Good	
534283	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
534284	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
534285	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
534286	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Bushings Connection/Risers	Good	
534287	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Bushing Condition	Good	
534288	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
534289	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
534290	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
534291	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Clear of Trash?	y	
534292	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
534293	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
534294	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
534295	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
534296	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
534297	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	General Comments		
534298	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
534299	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Vegetation	None	
534300	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
534301	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
534302	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
534303	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
534304	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
534305	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
534306	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
534307	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
534308	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
534309	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	General Comments		
534310	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
534311	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
534312	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
534313	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
534314	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
534315	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
534316	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
534317	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
534318	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Amps C Ø	60.0	
534319	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Amps B Ø	55.0	
534320	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
534321	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Amps A Ø	62.0	
534322	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Accumulated Fault Duty C Ph V	.76	%
534323	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
534324	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Accumulated Fault Duty A Ph V	2.28	%
534325	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	9 Month Operations	4	
534326	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
534327	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	45	°C
534328	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
534329	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
534330	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
534331	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
534332	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
534333	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
534334	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
534335	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
534336	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
534337	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
534338	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
534339	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
534340	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1700	psi
534341	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
534342	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
534343	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	40	°C
534344	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	60	°C
534345	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
534346	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	General Comments		
534347	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
534348	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
534349	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
534350	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
534351	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
534352	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
534353	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
534354	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
534355	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
534356	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
534357	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
534358	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
534359	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	572.88	kw
534360	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
534361	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
534362	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
534363	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	General Comments		
534364	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	General Comments		
534365	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
534366	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
534367	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
534368	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
534369	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
534370	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
534371	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
534372	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
534373	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
534374	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
534375	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
534376	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
534377	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
534378	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
534379	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Unknown Operations	0	
534380	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Tank Paint Condition	Good	
534381	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Switching Operations	1	
534382	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Operations Counter AL	180	
534383	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Operations Counter AF	180	
534384	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Moisture and Leak Free?	y	
534385	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Maintenance Operations	0	
534386	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
534387	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	191	
534388	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
534389	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Min Tap Position	11L	
534390	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Max Tap Position	4R	
534391	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Current Tap Position	8L	
534392	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
534393	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC As Left Counter	52146	
534394	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Amps A Ø	0.0	
534395	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Amps B Ø	0.0	
534396	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
534397	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
534398	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
534399	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
534400	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
534401	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Amps C Ø	0.0	
534402	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Patrol Inspection	Equipment Properly Labeled?	y	
534403	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
534404	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
534405	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	9 Month Operations	1	
534406	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
534407	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
534408	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
534409	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
534410	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
534411	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Undetermined	
534412	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
534413	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Unknown Operations	0	
534414	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Switching Operations	0	
534415	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Operations Counter AL	128	
534416	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Operations Counter AF	128	
534417	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Maintenance Operations	0	
534418	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	General Comments	Racked Out	
534419	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Patrol Inspection	General Comments		
534420	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
534421	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
534422	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Patrol Inspection	Equipment Properly Labeled?	y	
534423	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Follow-up Action Required?	n	
534424	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Patrol Inspection	Follow-up Action Required?	n	
534425	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
534426	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Patrol Inspection	Follow-up Action Required?	n	
534427	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Patrol Inspection	General Comments		
534428	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Amps A Ø	456.0	
534429	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Amps B Ø	400.0	
534430	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Amps C Ø	453.0	
534431	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Bushing Condition	Good	
534432	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
534433	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
534434	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
534435	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
534436	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
534437	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
534438	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
534439	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	20	°C
534440	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	30	°C
534441	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
534442	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
534443	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations A Ø	0	
534444	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations B Ø	0	
534445	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations C Ø	0	
534446	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations Ground	0	
534447	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Follow-up Action Required?	n	
534448	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	20	°C
534449	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	30	°C
534450	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
534451	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	45	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
534452	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
534453	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Foundation Condition	Good	
534454	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	General Comments		
534455	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	General Comments		
534456	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Grounds in Place?	y	
534457	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Maintenance Operations	0	
534458	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Moisture and Leak Free?	y	
534459	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Operations Counter AF	313	
534460	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Operations Counter AL	313	
534461	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
534462	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Switching Operations	0	
534463	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Tank Paint Condition	Good	
534464	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Unknown Operations	0	
534465	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
534466	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
534467	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
534468	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
534469	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6L	
534470	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
534471	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	305	
534472	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
534473	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
534474	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
534475	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
534476	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
534477	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
534478	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
534479	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Totalizer Meter Reading	.5688	
534480	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
534481	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Top Oil Temperature Present	25	°C
534482	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Top Oil Temperature Max	55	°C
534483	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
534484	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
534485	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
534486	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
534487	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
534488	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
534489	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
534490	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
534491	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
534492	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	LTC Totalizer Reading	5460.48	kw
534493	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
534494	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	General Comments		
534495	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	General Comments		
534496	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
534497	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
534498	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Follow-up Action Required?	n	
534499	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
534500	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
534501	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
534502	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
534503	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
534504	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	General Comments		
534505	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	General Comments		
534506	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
534507	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
534508	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
534509	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
534510	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
534511	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
534512	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
534513	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
534514	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
534515	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
534516	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
534517	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
534518	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
534519	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
534520	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LTCC000213	LTCControl	NA-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
534521	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LTCC000213	LTCControl	NA-TRANS 2	LTC Control Insp	General Comments		
534522	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LTCC000213	LTCControl	NA-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
534523	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LTCC000212	LTCControl	NA-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
534524	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LTCC000212	LTCControl	NA-TRANS 1	LTC Control Insp	General Comments		
534525	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LTCC000212	LTCControl	NA-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
534526	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
534527	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Max Tap Position	9R	
534528	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LTCC000211	LTCControl	NA-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
534529	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LTCC000211	LTCControl	NA-TRANS 3	LTC Control Insp	General Comments		
534530	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LTCC000211	LTCControl	NA-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
534531	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Min Tap Position	3L	
534532	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
534533	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
534534	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
534535	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
534536	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
534537	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Regulator As Left Counter	199104	
534538	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
534539	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
534540	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Tank Leaks	None	
534541	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
534542	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
534543	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
534544	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	General Comments		
534545	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
534546	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC As Found Counter	101504	
534547	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
534548	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
534549	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
534550	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC As Left Counter	101504	
534551	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
534552	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
534553	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
534554	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
534555	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
534556	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
534557	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
534558	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	69	
534559	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
534560	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
534561	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
534562	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
534563	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
534564	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Tank Leaks	None	
534565	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
534566	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
534567	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Regulator As Left Counter	294816	
534568	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
534569	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
534570	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
534571	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
534572	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
534573	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
534574	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
534575	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
534576	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
534577	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
534578	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
534579	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
534580	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
534581	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
534582	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
534583	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	General Comments		
534584	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
534585	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
534586	3/8/2019 11:15	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
534587	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
534588	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations Ground	0	
534589	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
534590	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
534591	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
534592	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
534593	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
534594	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
534595	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
534596	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
534597	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
534598	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
534599	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
534600	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
534601	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
534602	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
534603	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
534604	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	General Comments		
534605	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
534606	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
534607	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
534608	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
534609	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
534610	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
534611	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Follow-up Action Required?	n	
534612	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Foundation Condition	Good	
534613	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
534614	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
534615	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
534616	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
534617	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
534618	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Current Tap Position	4R	
534619	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
534620	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
534621	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC As Found Counter	52146	
534622	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
534623	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
534624	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
534625	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
534626	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
534627	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
534628	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
534629	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
534630	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
534631	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	General Comments		
534632	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	General Comments		
534633	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
534634	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
534635	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
534636	3/11/2019 14:53	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	General Comments		
534637	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Grounds in Place?	y	
534638	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
534639	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
534640	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
534641	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations A Ø	0	
534642	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations B Ø	0	
534643	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations C Ø	0	
534644	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Maintenance Operations	0	
534645	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
534646	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Operations Counter AF	142	
534647	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Operations Counter AL	142	
534648	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Switching Operations	0	
534649	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Tank Paint Condition	Good	
534650	3/8/2019 14:12	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Unknown Operations	0	
534651	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	General Comments		
534652	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
534653	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
534654	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	General Comments		
534655	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
534656	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	Follow-up Action Required?	n	
534657	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCC000241	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
534658	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCC000241	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
534659	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
534660	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
534661	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
534662	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
534663	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
534664	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
534665	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
534666	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCC000241	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125.4	VAC
534667	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCC000241	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
534668	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCC000241	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
534669	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC As Left Counter	117981	
534670	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
534671	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
534672	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
534673	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
534674	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	9 Month Operations	0	
534675	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Current Tap Position	2R	
534676	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Max Tap Position	8R	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
534677	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Min Tap Position	4L	
534678	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
534679	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
534680	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
534681	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCC000241	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
534682	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCC000241	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
534683	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
534684	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Bushings Connection/Risers	Good	
534685	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
534686	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
534687	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Operations Since Last Insp	850	
534688	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
534689	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	PF000037	PowerFuse	CG-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
534690	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	PF000037	PowerFuse	CG-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
534691	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	PF000036	PowerFuse	CG-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
534692	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	PF000036	PowerFuse	CG-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
534693	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
534694	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
534695	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
534696	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
534697	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Bushing Condition	Good	
534698	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Amps C Ø	300.0	
534699	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Amps B Ø	300.0	
534700	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
534701	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
534702	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
534703	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
534704	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	Oil Temp Present	25	°C
534705	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	Oil Temp Max	25	°C
534706	3/8/2019 15:08	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
534707	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
534708	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Operations Since Last Insp	1085	
534709	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
534710	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
534711	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
534712	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
534713	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
534714	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Vegetation	None	
534715	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
534716	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
534717	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
534718	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
534719	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
534720	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
534721	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	General Comments		
534722	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
534723	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
534724	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
534725	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
534726	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
534727	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
534728	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Clear of Trash?	y	
534729	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
534730	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
534731	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
534732	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
534733	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
534734	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
534735	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
534736	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
534737	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
534738	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
534739	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
534740	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
534741	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Foundation Condition	Good	
534742	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
534743	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	General Comments		
534744	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
534745	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCC000241	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
534746	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
534747	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
534748	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	Follow-up Action Required?	n	
534749	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
534750	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	General Comments		
534751	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
534752	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
534753	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
534754	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	General Comments		
534755	3/8/2019 14:12	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC As Found Counter	117974	
534756	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Min Tap Position	12L	
534757	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Max Tap Position	2L	
534758	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Current Tap Position	6L	
534759	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
534760	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC As Left Counter	290489	
534761	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC As Found Counter	290477	
534762	3/8/2019 14:12	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	General Comments		
534763	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
534764	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	Follow-up Action Required?	n	
534765	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	General Comments		
534766	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
534767	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
534768	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
534769	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
534770	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	LTC Operation Checked?	y	
534771	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
534772	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
534773	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
534774	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
534775	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC As Found Counter	71154	
534776	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
534777	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	General Comments		
534778	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
534779	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Accumulated Fault Duty C Ph V	1.13	%
534780	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Accumulated Fault Duty B Ph V	1.13	%
534781	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
534782	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
534783	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Accumulated Fault Duty A Ph V	1.13	%
534784	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
534785	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
534786	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	9 Month Operations	0	
534787	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
534788	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
534789	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
534790	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	General Comments		
534791	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	VRR Time Delay	60	Seconds
534792	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
534793	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
534794	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations A Ø	0	
534795	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations B Ø	0	
534796	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Follow-up Action Required?	n	
534797	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
534798	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations C Ø	0	
534799	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations Ground	0	
534800	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	9 Month Operations	6	
534801	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Accumulated Fault Duty A Ph V	8.49	%
534802	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
534803	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
534804	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Amps A Ø	240.0	
534805	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Accumulated Fault Duty C Ph V	6.70	%
534806	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Accumulated Fault Duty B Ph V	7.59	%
534807	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
534808	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC As Left Counter	71154	
534809	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
534810	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	General Comments		
534811	3/8/2019 9:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Amps A Ø	186.0	
534812	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
534813	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Follow-up Action Required?	n	
534814	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
534815	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
534816	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
534817	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
534818	3/8/2019 13:51	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
534819	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Paint Condition	Good	
534820	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
534821	3/8/2019 14:12	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Equipment Properly Labeled?	y	
534822	3/8/2019 15:08	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	All Connections OK?	y	
534823	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
534824	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
534825	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Tank Leaks	None	
534826	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
534827	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
534828	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	General Comments		
534829	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
534830	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
534831	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
534832	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
534833	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Moisture and Leak Free?	y	
534834	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
534835	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Maintenance Operations	0	
534836	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
534837	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
534838	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
534839	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
534840	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
534841	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
534842	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	VRR Time Delay	30	Seconds
534843	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
534844	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	General Comments		
534845	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
534846	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
534847	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
534848	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
534849	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
534850	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
534851	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Unknown Operations	0	
534852	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Tank Paint Condition	Good	
534853	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Switching Operations	0	
534854	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
534855	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Equipment Properly Labeled?	y	
534856	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
534857	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
534858	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
534859	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Paint Condition	Good	
534860	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
534861	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
534862	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
534863	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
534864	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
534865	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
534866	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
534867	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
534868	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
534869	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations A Ø	0	
534870	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
534871	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
534872	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations B Ø	0	
534873	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations C Ø	0	
534874	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations Ground	0	
534875	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Follow-up Action Required?	n	
534876	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Follow-up Action Required?	n	
534877	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Foundation Condition	Good	
534878	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	General Comments		
534879	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
534880	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
534881	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Switching Operations	0	
534882	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
534883	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
534884	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
534885	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
534886	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Operations Counter AL	273	
534887	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
534888	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
534889	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Foundation Condition	Good	
534890	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	General Comments		
534891	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
534892	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
534893	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Operations Counter AF	273	
534894	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
534895	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
534896	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
534897	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
534898	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
534899	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
534900	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
534901	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
534902	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
534903	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	General Comments	ok	
534904	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
534905	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
534906	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
534907	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
534908	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
534909	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Vegetation	None	
534910	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
534911	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
534912	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
534913	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
534914	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
534915	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
534916	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
534917	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
534918	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
534919	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	General Comments		
534920	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
534921	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
534922	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Unknown Operations	0	
534923	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Tank Paint Condition	Good	
534924	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
534925	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
534926	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
534927	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
534928	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
534929	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
534930	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
534931	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
534932	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
534933	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Clear of Trash?	y	
534934	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
534935	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
534936	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
534937	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	General Comments		
534938	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
534939	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
534940	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
534941	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
534942	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
534943	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
534944	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
534945	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
534946	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
534947	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
534948	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	LTC Operation Checked?	y	
534949	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	General Comments		
534950	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	Follow-up Action Required?	n	
534951	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	All Connections OK?	y	
534952	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
534953	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
534954	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Tank Leaks	None	
534955	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
534956	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
534957	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
534958	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
534959	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
534960	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
534961	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
534962	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Regulator As Left Counter	30093	
534963	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
534964	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Regulator As Left Counter	5460	
534965	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
534966	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
534967	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
534968	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
534969	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	VRR Time Delay	30	Seconds
534970	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
534971	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
534972	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
534973	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
534974	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
534975	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
534976	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Max Tap Position	2L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
534977	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	LTC Operation Checked?	y	
534978	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	General Comments		
534979	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	Follow-up Action Required?	n	
534980	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	All Connections OK?	y	
534981	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	General Comments	There is 3 operation on this breaker that is not accounted for.	
534982	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Grounds in Place?	y	
534983	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
534984	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Maintenance Operations	0	
534985	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
534986	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Operations Counter AF	95	
534987	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Operations Counter AL	95	
534988	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
534989	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Switching Operations	3	
534990	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Tank Paint Condition	Good	
534991	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Unknown Operations	0	
534992	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	274	
534993	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	279	
534994	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
534995	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
534996	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
534997	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Accumulated Fault Duty C Ph V	4.59	%
534998	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Amps A Ø	249.0	
534999	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
535000	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
535001	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
535002	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
535003	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	VRR Time Delay	30	Seconds
535004	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
535005	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
535006	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
535007	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC As Found Counter	687361	
535008	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	LTC Operation Checked?	y	
535009	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	General Comments		
535010	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	Follow-up Action Required?	n	
535011	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	All Connections OK?	y	
535012	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC As Left Counter	687361	
535013	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
535014	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Current Tap Position	1R	
535015	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
535016	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
535017	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.38	%
535018	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	.69	%
535019	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.77	%
535020	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
535021	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
535022	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
535023	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Regulator As Left Counter	28481	
535024	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
535025	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Tank Leaks	None	
535026	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
535027	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
535028	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
535029	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
535030	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
535031	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
535032	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	General Comments	ok	
535033	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
535034	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
535035	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
535036	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
535037	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
535038	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
535039	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
535040	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
535041	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
535042	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
535043	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
535044	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
535045	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
535046	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
535047	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
535048	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
535049	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Amps A Ø	73.0	
535050	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
535051	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
535052	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
535053	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
535054	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9786	
535055	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
535056	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
535057	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
535058	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
535059	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
535060	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
535061	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
535062	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
535063	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Oil Temp Present	5	°C
535064	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Oil Temp Max	20	°C
535065	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
535066	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
535067	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2348.64	kw
535068	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
535069	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
535070	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
535071	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
535072	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	General Comments		
535073	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	General Comments		
535074	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
535075	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
535076	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
535077	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
535078	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
535079	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
535080	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Regulator As Left Counter	5864	
535081	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
535082	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
535083	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
535084	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
535085	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
535086	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
535087	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
535088	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
535089	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
535090	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
535091	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
535092	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	General Comments		
535093	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
535094	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
535095	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
535096	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	Follow-up Action Required?	n	
535097	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
535098	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	General Comments		
535099	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	9 Month Operations	1	
535100	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	General Comments		
535101	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Accumulated Fault Duty A Ph V	3.37	%
535102	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Accumulated Fault Duty B Ph V	3.37	%
535103	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Accumulated Fault Duty C Ph V	1.12	%
535104	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	9 Month Operations	5	
535105	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Accumulated Fault Duty A Ph V	4.59	%
535106	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Accumulated Fault Duty B Ph V	4.59	%
535107	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Follow-up Action Required?	n	
535108	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Follow-up Action Required?	n	
535109	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Foundation Condition	Good	
535110	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	General Comments		
535111	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	General Comments		
535112	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Grounds in Place?	y	
535113	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Maintenance Operations	0	
535114	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Moisture and Leak Free?	y	
535115	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Operations Counter AF	154	
535116	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Operations Counter AL	154	
535117	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Switching Operations	0	
535118	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Tank Paint Condition	Good	
535119	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Unknown Operations	0	
535120	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
535121	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
535122	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
535123	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
535124	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
535125	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
535126	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
535127	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
535128	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
535129	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
535130	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Grounds in Place?	y	
535131	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	General Comments		
535132	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	General Comments		
535133	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
535134	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
535135	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
535136	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
535137	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
535138	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
535139	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
535140	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
535141	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
535142	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Foundation Condition	Good	
535143	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Follow-up Action Required?	n	
535144	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Follow-up Action Required?	n	
535145	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BCH000254	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
535146	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations Ground	0	
535147	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations C Ø	0	
535148	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations B Ø	0	
535149	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
535150	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
535151	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations A Ø	0	
535152	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BCH000254	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
535153	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BCH000254	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
535154	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BCH000254	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
535155	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
535156	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
535157	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Heaters (All) Functioning?	y	
535158	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Maintenance Operations	2	
535159	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Moisture and Leak Free?	y	
535160	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Operations Counter AF	202	
535161	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Operations Counter AL	204	
535162	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
535163	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Amps B Ø	86.0	
535164	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Amps C Ø	70.0	
535165	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Bushing Condition	Good	
535166	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Bushings Connection/Risers	Good	
535167	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
535168	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
535169	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
535170	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Paint Condition	Good	
535171	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Equipment Properly Labeled?	y	
535172	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
535173	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
535174	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Amps B Ø	255.0	
535175	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Amps C Ø	249.0	
535176	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Bushing Condition	Good	
535177	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
535178	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
535179	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
535180	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
535181	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations A Ø	0	
535182	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
535183	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
535184	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9954	
535185	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
535186	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
535187	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
535188	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
535189	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
535190	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
535191	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
535192	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations B Ø	0	
535193	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
535194	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
535195	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
535196	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
535197	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations C Ø	0	
535198	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
535199	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
535200	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	General Comments		
535201	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
535202	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
535203	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
535204	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
535205	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
535206	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
535207	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
535208	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
535209	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
535210	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
535211	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations Ground	0	
535212	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
535213	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
535214	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
535215	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
535216	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
535217	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
535218	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
535219	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
535220	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
535221	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
535222	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
535223	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
535224	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
535225	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Follow-up Action Required?	n	
535226	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
535227	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
535228	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
535229	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
535230	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
535231	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
535232	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
535233	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
535234	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Oil Temp Present	30	°C
535235	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Oil Temp Max	70	°C
535236	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-2.0	psi
535237	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
535238	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	LTC Totalizer Reading	3542.40	kw
535239	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
535240	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	General Comments		
535241	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	General Comments		
535242	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
535243	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
535244	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
535245	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
535246	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
535247	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
535248	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
535249	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
535250	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
535251	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
535252	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
535253	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	General Comments		
535254	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
535255	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
535256	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
535257	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
535258	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Follow-up Action Required?	n	
535259	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
535260	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Foundation Condition	Good	
535261	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	General Comments		
535262	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	General Comments		
535263	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Grounds in Place?	y	
535264	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
535265	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
535266	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
535267	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
535268	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
535269	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
535270	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	243	
535271	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	239	
535272	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
535273	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
535274	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
535275	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
535276	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
535277	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	General Comments		
535278	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	General Comments		
535279	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
535280	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
535281	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
535282	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
535283	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
535284	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Heaters (All) Functioning?	y	
535285	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
535286	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
535287	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
535288	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
535289	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
535290	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
535291	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Tank Leaks	None	
535292	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
535293	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Regulator As Left Counter	113042	
535294	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
535295	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
535296	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
535297	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
535298	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
535299	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	General Comments		
535300	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC As Found Counter	5845	
535301	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC As Left Counter	5856	
535302	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Tank Leaks	None	
535303	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
535304	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Operations Counter	99989	
535305	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
535306	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
535307	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	General Comments		
535308	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
535309	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
535310	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
535311	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
535312	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
535313	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
535314	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
535315	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
535316	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
535317	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
535318	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
535319	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
535320	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
535321	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
535322	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
535323	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Amps C Ø	25.0	
535324	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
535325	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Current Tap Position	7L	
535326	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Max Tap Position	5L	
535327	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Min Tap Position	11L	
535328	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Operations Since Last Insp	346	
535329	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
535330	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
535331	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
535332	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
535333	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Amps B Ø	30.0	
535334	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Amps A Ø	35.0	
535335	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
535336	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
535337	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
535338	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Bushings Connection/Risers	Good	
535339	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Clear of Trash?	y	
535340	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
535341	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
535342	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
535343	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
535344	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
535345	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	240.0	
535346	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	240.0	
535347	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	240.0	
535348	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
535349	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
535350	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
535351	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
535352	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
535353	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
535354	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
535355	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
535356	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
535357	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
535358	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Vegetation	None	
535359	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	Follow-up Action Required?	n	
535360	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
535361	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
535362	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
535363	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
535364	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	General Comments		
535365	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	General Comments		
535366	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
535367	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
535368	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
535369	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
535370	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
535371	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
535372	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Clear of Trash?	y	
535373	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
535374	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
535375	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
535376	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
535377	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
535378	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
535379	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
535380	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
535381	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
535382	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
535383	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
535384	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
535385	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
535386	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
535387	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Oil Temp Present	25	°C
535388	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
535389	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
535390	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
535391	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Unknown Operations	0	
535392	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Tank Paint Condition	Good	
535393	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Switching Operations	1	
535394	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
535395	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Operations Counter AL	126	
535396	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Operations Counter AF	126	
535397	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
535398	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Maintenance Operations	0	
535399	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
535400	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Grounds in Place?	y	
535401	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	General Comments		
535402	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	General Comments		
535403	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Foundation Condition	Good	
535404	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Follow-up Action Required?	n	
535405	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Follow-up Action Required?	n	
535406	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Operations Ground	0	
535407	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Operations C Ø	0	
535408	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Operations B Ø	0	
535409	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Operations A Ø	0	
535410	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
535411	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
535412	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
535413	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
535414	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
535415	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
535416	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
535417	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
535418	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Operations Counter	199	
535419	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
535420	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
535421	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
535422	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
535423	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
535424	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
535425	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Totalizer Meter Reading	.6858	
535426	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
535427	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Accumulated Fault Duty A Ph V	12.25	%
535428	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Accumulated Fault Duty B Ph V	12.25	%
535429	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Accumulated Fault Duty C Ph V	3.06	%
535430	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Amps A Ø	5.0	
535431	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Amps B Ø	5.0	
535432	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Amps C Ø	5.0	
535433	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Bushing Condition	Good	
535434	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
535435	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
535436	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
535437	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
535438	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
535439	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Oil Temp Present	30	°C
535440	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Oil Temp Max	70	°C
535441	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
535442	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
535443	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
535444	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
535445	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Amps A Ø	128.0	
535446	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Amps B Ø	142.0	
535447	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Amps C Ø	118.0	
535448	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
535449	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
535450	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
535451	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
535452	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
535453	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	LTC Totalizer Reading	4937.76	kw
535454	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
535455	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
535456	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
535457	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
535458	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
535459	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	General Comments	Replaced Batteries	
535460	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
535461	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
535462	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
535463	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
535464	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
535465	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
535466	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
535467	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
535468	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
535469	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
535470	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
535471	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	56.0	VDC
535472	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations Ground	0	
535473	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Follow-up Action Required?	n	
535474	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
535475	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
535476	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	General Comments		
535477	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	Follow-up Action Required?	n	
535478	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
535479	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	General Comments		
535480	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	General Comments		
535481	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC As Found Counter	7508	
535482	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC As Left Counter	7525	
535483	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
535484	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Current Tap Position	1L	
535485	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Max Tap Position	5R	
535486	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	9 Month Operations	2	
535487	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
535488	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Min Tap Position	5L	
535489	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Operations Since Last Insp	538	
535490	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
535491	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
535492	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations C Ø	0	
535493	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations B Ø	0	
535494	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations A Ø	0	
535495	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
535496	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Follow-up Action Required?	n	
535497	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
535498	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
535499	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
535500	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
535501	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Fans Operational?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
535502	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
535503	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
535504	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.9774	
535505	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
535506	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
535507	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
535508	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
535509	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
535510	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
535511	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
535512	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
535513	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	General Comments		
535514	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	General Comments		
535515	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
535516	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
535517	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
535518	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
535519	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
535520	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
535521	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
535522	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
535523	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	General Comments		
535524	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
535525	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
535526	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
535527	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
535528	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
535529	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
535530	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
535531	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
535532	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Regulator As Left Counter	198352	
535533	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
535534	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
535535	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Tank Leaks	None	
535536	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
535537	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
535538	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
535539	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
535540	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	General Comments		
535541	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Oil Temp Max	55	°C
535542	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
535543	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
535544	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC As Left Counter	65746	
535545	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
535546	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
535547	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
535548	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC As Found Counter	65746	
535549	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	General Comments		
535550	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
535551	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	General Comments		
535552	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
535553	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
535554	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	General Comments		
535555	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
535556	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	Follow-up Action Required?	n	
535557	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
535558	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
535559	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
535560	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
535561	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Unknown Operations	0	
535562	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
535563	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Switching Operations	0	
535564	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Operations Counter AL	99957	
535565	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Operations Counter AF	99957	
535566	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1950	psi
535567	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
535568	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
535569	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
535570	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
535571	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Maintenance Operations	0	
535572	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
535573	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	General Comments		
535574	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	General Comments		
535575	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Follow-up Action Required?	n	
535576	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
535577	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations Ground	0	
535578	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations C Ø	0	
535579	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	9 Month Operations	3	
535580	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Accumulated Fault Duty A Ph V	.96	%
535581	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Accumulated Fault Duty B Ph V	.64	%
535582	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Accumulated Fault Duty C Ph V	.64	%
535583	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
535584	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
535585	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	General Comments		
535586	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
535587	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	18772	
535588	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	18772	
535589	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
535590	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	11L	
535591	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	4L	
535592	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	12L	
535593	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
535594	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	697	
535595	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
535596	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
535597	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
535598	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	9 Months Operations	21	
535599	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
535600	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
535601	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
535602	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Amps A Ø	50.0	
535603	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Amps B Ø	220.0	
535604	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Amps C Ø	230.0	
535605	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
535606	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
535607	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
535608	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
535609	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations A Ø	0	
535610	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations B Ø	0	
535611	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
535612	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
535613	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	1172.88	kw
535614	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
535615	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
535616	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	General Comments		
535617	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.000	millivolts
535618	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	General Comments		
535619	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	General Comments		
535620	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
535621	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
535622	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
535623	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Amps A Ø	202.0	
535624	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
535625	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
535626	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations A Ø	0	
535627	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations B Ø	0	
535628	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations C Ø	0	
535629	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations Ground	0	
535630	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Follow-up Action Required?	n	
535631	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Follow-up Action Required?	n	
535632	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
535633	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
535634	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
535635	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
535636	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
535637	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
535638	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
535639	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
535640	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
535641	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
535642	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
535643	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
535644	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
535645	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
535646	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
535647	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
535648	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
535649	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	9 Month Operations	3	
535650	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
535651	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
535652	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
535653	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Amps A Ø	130.0	
535654	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
535655	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Amps B Ø	17.0	
535656	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Amps C Ø	142.0	
535657	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Foundation Condition	Good	
535658	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	General Comments		
535659	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
535660	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
535661	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	General Comments		
535662	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Grounds in Place?	y	
535663	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
535664	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Heaters (All) Functioning?	y	
535665	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
535666	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
535667	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
535668	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Paint Condition	Good	
535669	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Equipment Properly Labeled?	y	
535670	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
535671	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
535672	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
535673	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Current Tap Position	10L	
535674	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Max Tap Position	5L	
535675	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Min Tap Position	12L	
535676	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Operations Since Last Insp	343	
535677	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
535678	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
535679	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
535680	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
535681	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
535682	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
535683	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
535684	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
535685	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
535686	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
535687	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
535688	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
535689	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
535690	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
535691	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
535692	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
535693	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
535694	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
535695	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
535696	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
535697	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
535698	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
535699	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
535700	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
535701	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
535702	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	General Comments		
535703	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
535704	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
535705	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Foundation Condition	Good	
535706	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
535707	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
535708	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
535709	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
535710	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
535711	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
535712	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Totalizer Meter Reading	.3690	
535713	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Winding Temp Present	0	°C
535714	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
535715	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
535716	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Equipment Properly Labeled?	y	
535717	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Paint Condition	Good	
535718	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
535719	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
535720	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
535721	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
535722	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
535723	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	General Comments		
535724	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
535725	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Max Tap Position	11L	
535726	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Min Tap Position	2R	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
535727	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
535728	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
535729	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
535730	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
535731	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
535732	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
535733	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
535734	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Bushings Connection/Risers	Good	
535735	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
535736	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
535737	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
535738	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
535739	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Regulator As Left Counter	25201	
535740	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
535741	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
535742	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Tank Leaks	None	
535743	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
535744	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
535745	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Tank Leaks	None	
535746	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
535747	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Bushing Condition	Good	
535748	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Amps C Ø	291.0	
535749	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Amps B Ø	265.0	
535750	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Amps A Ø	296.0	
535751	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
535752	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Accumulated Fault Duty B Ph V	.48	%
535753	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Accumulated Fault Duty A Ph V	.48	%
535754	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	9 Month Operations	21	
535755	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
535756	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
535757	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	General Comments		
535758	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
535759	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Max Tap Position	11L	
535760	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Min Tap Position	3R	
535761	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
535762	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
535763	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
535764	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
535765	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
535766	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Regulator As Left Counter	23955	
535767	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
535768	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
535769	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Tank Leaks	None	
535770	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
535771	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	General Comments		
535772	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
535773	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
535774	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
535775	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Vegetation	None	
535776	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
535777	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
535778	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
535779	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
535780	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
535781	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
535782	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	BCH000552	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
535783	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	BCH000552	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.3	VDC
535784	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	BCH000552	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.3	VDC
535785	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	BCH000552	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
535786	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	BCH000552	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
535787	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	BCH000552	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
535788	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	General Comments		
535789	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
535790	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
535791	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
535792	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
535793	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Current Tap Position	1R	
535794	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
535795	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
535796	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
535797	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
535798	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
535799	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Maintenance Operations	1	
535800	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Moisture and Leak Free?	y	
535801	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Operations Counter AF	171	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
535802	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Operations Counter AL	171	
535803	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Switching Operations	0	
535804	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Tank Paint Condition	Good	
535805	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Unknown Operations	0	
535806	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
535807	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
535808	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
535809	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
535810	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
535811	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
535812	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
535813	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
535814	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
535815	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Panels Dusted?	y	
535816	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
535817	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
535818	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	General Comments		
535819	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
535820	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
535821	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Floor Swept?	y	
535822	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
535823	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
535824	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Evidence of Insects	None	
535825	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
535826	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
535827	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
535828	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	n	If Bkr is Closed
535829	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Regulator As Left Counter	18911	
535830	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	120.5	volts
535831	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
535832	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
535833	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	General Comments		
535834	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
535835	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
535836	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
535837	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
535838	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
535839	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
535840	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Vegetation	None	
535841	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
535842	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
535843	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	General Comments		
535844	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
535845	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
535846	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
535847	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
535848	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
535849	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
535850	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
535851	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
535852	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	36	°F
535853	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
535854	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Bushing Condition	Good	
535855	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Amps C Ø	174.0	
535856	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Amps B Ø	163.0	
535857	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Clear of Trash?	y	
535858	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
535859	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
535860	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Ambient Temp	38	°F
535861	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
535862	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
535863	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
535864	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Min Tap Position	8L	
535865	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Max Tap Position	4R	
535866	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
535867	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
535868	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
535869	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
535870	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
535871	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
535872	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Vegetation	None	
535873	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
535874	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	General Comments		
535875	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
535876	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
535877	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
535878	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
535879	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
535880	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
535881	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Clear of Trash?	y	
535882	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
535883	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
535884	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Ambient Temp	41	°F
535885	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	9 Month Operations	10	
535886	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Accumulated Fault Duty A Ph V	1.72	%
535887	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Accumulated Fault Duty B Ph V	1.66	%
535888	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Accumulated Fault Duty C Ph V	1.66	%
535889	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Bushing Condition	Good	
535890	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Bushings Connection/Risers	Good	
535891	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
535892	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
535893	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
535894	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Paint Condition	Good	
535895	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Equipment Properly Labeled?	y	
535896	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
535897	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
535898	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
535899	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations A Ø	0	
535900	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations B Ø	0	
535901	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations C Ø	0	
535902	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations Ground	0	
535903	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Follow-up Action Required?	n	
535904	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Follow-up Action Required?	n	
535905	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Foundation Condition	Good	
535906	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	General Comments		
535907	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	General Comments		
535908	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Grounds in Place?	y	
535909	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Heaters (All) Functioning?	y	
535910	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Maintenance Operations	0	
535911	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Moisture and Leak Free?	y	
535912	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Operations Counter AF	108	
535913	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Operations Counter AL	108	
535914	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
535915	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Switching Operations	0	
535916	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Tank Paint Condition	Good	
535917	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Unknown Operations	0	
535918	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
535919	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
535920	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
535921	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
535922	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	General Comments		
535923	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	Follow-up Action Required?	n	
535924	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	All Connections OK?	y	
535925	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
535926	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
535927	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
535928	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	11432	
535929	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
535930	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
535931	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
535932	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
535933	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
535934	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	3R	
535935	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
535936	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
535937	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
535938	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
535939	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
535940	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
535941	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
535942	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
535943	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
535944	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
535945	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
535946	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
535947	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Grounds in Place?	y	
535948	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
535949	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Maintenance Operations	0	
535950	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Unknown Operations	0	
535951	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
535952	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Switching Operations	0	
535953	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
535954	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
535955	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Operations Counter AF	80	
535956	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	LTCC000122	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
535957	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	LTCC000122	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
535958	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	LTCC000122	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
535959	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	LTCC000122	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
535960	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	LTCC000122	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
535961	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	LTCC000122	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
535962	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	LTCC000122	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
535963	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	LTCC000122	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
535964	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Operations Counter AL	80	
535965	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
535966	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Switching Operations	0	
535967	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Tank Paint Condition	Good	
535968	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Unknown Operations	0	
535969	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
535970	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC
535971	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
535972	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
535973	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
535974	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	General Comments		
535975	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	General Comments		
535976	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Foundation Condition	Good	
535977	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Follow-up Action Required?	n	
535978	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Follow-up Action Required?	n	
535979	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations Ground	0	
535980	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations C Ø	0	
535981	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations B Ø	0	
535982	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations A Ø	0	
535983	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
535984	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
535985	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
535986	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Equipment Properly Labeled?	y	
535987	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Paint Condition	Good	
535988	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
535989	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
535990	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	9 Month Operations	1	
535991	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Accumulated Fault Duty A Ph V	3.49	%
535992	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Accumulated Fault Duty B Ph V	3.87	%
535993	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
535994	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Bushings Connection/Risers	Good	
535995	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Bushing Condition	Good	
535996	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Amps C Ø	120.0	
535997	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Amps B Ø	120.0	
535998	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Amps A Ø	120.0	
535999	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
536000	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Accumulated Fault Duty B Ph V	2.13	%
536001	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Accumulated Fault Duty A Ph V	1.42	%
536002	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	9 Month Operations	8	
536003	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
536004	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
536005	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
536006	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
536007	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
536008	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
536009	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
536010	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
536011	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
536012	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
536013	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	General Comments		
536014	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
536015	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
536016	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
536017	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
536018	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
536019	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
536020	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
536021	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
536022	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
536023	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
536024	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
536025	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
536026	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
536027	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
536028	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
536029	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
536030	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
536031	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
536032	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
536033	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
536034	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	General Comments		
536035	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
536036	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
536037	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Foundation Condition	Good	
536038	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
536039	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
536040	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
536041	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
536042	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
536043	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
536044	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Unknown Operations	0	
536045	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Tank Paint Condition	Good	
536046	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Switching Operations	4	
536047	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
536048	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Operations Counter AL	235	
536049	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Operations Counter AF	231	
536050	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Moisture and Leak Free?	y	
536051	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Maintenance Operations	0	
536052	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Heaters (All) Functioning?	y	
536053	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Grounds in Place?	y	
536054	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	General Comments		
536055	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
536056	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
536057	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
536058	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
536059	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
536060	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
536061	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
536062	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
536063	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
536064	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
536065	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
536066	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
536067	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
536068	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
536069	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
536070	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	37	°F
536071	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
536072	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
536073	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
536074	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
536075	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
536076	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
536077	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
536078	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
536079	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
536080	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
536081	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
536082	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
536083	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
536084	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
536085	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
536086	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
536087	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
536088	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
536089	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
536090	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Amps B Ø	14.0	
536091	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Amps C Ø	20.0	
536092	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Bushing Condition	Good	
536093	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Bushings Connection/Risers	Good	
536094	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
536095	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Amps C Ø	256.0	
536096	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Amps B Ø	262.0	
536097	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Amps A Ø	256.0	
536098	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Accumulated Fault Duty C Ph V	.07	%
536099	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Accumulated Fault Duty B Ph V	.07	%
536100	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Accumulated Fault Duty A Ph V	.07	%
536101	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	9 Month Operations	2	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
536102	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
536103	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
536104	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	9 Month Operations	1	
536105	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Paint Condition	Good	
536106	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Equipment Properly Labeled?	y	
536107	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
536108	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
536109	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
536110	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Operations A Ø	0	
536111	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Operations B Ø	0	
536112	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Operations C Ø	0	
536113	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Operations Ground	0	
536114	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Evidence of Insects	None	
536115	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
536116	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
536117	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Floor Swept?	y	
536118	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
536119	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
536120	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Unknown Operations	0	
536121	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Tank Paint Condition	Good	
536122	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Switching Operations	0	
536123	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
536124	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Operations Counter AL	206	
536125	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Operations Counter AF	206	
536126	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
536127	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Maintenance Operations	0	
536128	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
536129	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Grounds in Place?	y	
536130	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	General Comments		
536131	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
536132	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
536133	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
536134	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
536135	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations B Ø	0	
536136	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations A Ø	0	
536137	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
536138	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Amps C Ø	130.0	
536139	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Amps B Ø	100.0	
536140	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Amps A Ø	120.0	
536141	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
536142	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
536143	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
536144	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
536145	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Accumulated Fault Duty C Ph V	.43	%
536146	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Accumulated Fault Duty B Ph V	.43	%
536147	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Accumulated Fault Duty A Ph V	.43	%
536148	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
536149	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
536150	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
536151	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
536152	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Bushing Condition	Good	
536153	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Current Tap Position	4L	
536154	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Max Tap Position	1L	
536155	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Min Tap Position	8L	
536156	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Operations Since Last Insp	156	
536157	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC As Found Counter	133124	
536158	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC As Left Counter	133124	
536159	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
536160	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
536161	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
536162	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
536163	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
536164	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
536165	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	668	
536166	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	LTCC000248	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
536167	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	LTCC000248	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
536168	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	LTCC000248	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
536169	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	LTCC000248	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
536170	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	LTCC000248	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
536171	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	LTCC000248	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
536172	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
536173	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
536174	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
536175	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
536176	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
536177	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
536178	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	33	°F
536179	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
536180	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
536181	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
536182	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
536183	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
536184	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
536185	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
536186	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
536187	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	General Comments		
536188	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
536189	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
536190	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
536191	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Panels Dusted?	y	
536192	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
536193	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
536194	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
536195	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	9 Month Operations	0	
536196	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
536197	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
536198	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
536199	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Amps A Ø	184.0	
536200	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Amps B Ø	183.0	
536201	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Amps C Ø	216.0	
536202	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Bushing Condition	Good	
536203	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
536204	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
536205	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
536206	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
536207	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
536208	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
536209	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
536210	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
536211	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
536212	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Operations A Ø	0	
536213	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Operations B Ø	0	
536214	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Operations C Ø	0	
536215	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Operations Ground	0	
536216	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Follow-up Action Required?	n	
536217	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Follow-up Action Required?	n	
536218	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Foundation Condition	Good	
536219	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	General Comments		
536220	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	General Comments		
536221	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	VRR Time Delay	30	Seconds
536222	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
536223	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
536224	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
536225	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	LTC Operation Checked?	y	
536226	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	General Comments		
536227	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	Follow-up Action Required?	n	
536228	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	All Connections OK?	y	
536229	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	VRR Time Delay	30	Seconds
536230	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
536231	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
536232	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
536233	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	LTC Operation Checked?	y	
536234	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	General Comments		
536235	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	General Comments		
536236	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Foundation Condition	Good	
536237	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Follow-up Action Required?	n	
536238	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Follow-up Action Required?	n	
536239	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations Ground	0	
536240	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations C Ø	0	
536241	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	LTCC000248	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
536242	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	LTCC000248	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
536243	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Tank Paint Condition	Good	
536244	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Unknown Operations	0	
536245	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations B Ø	0	
536246	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations A Ø	0	
536247	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
536248	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Follow-up Action Required?	n	
536249	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Follow-up Action Required?	n	
536250	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Foundation Condition	Good	
536251	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
536252	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
536253	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
536254	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
536255	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
536256	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
536257	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
536258	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
536259	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Bushing Condition	Good	
536260	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Amps C Ø	0.0	
536261	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Amps B Ø	0.0	
536262	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Amps A Ø	0.0	
536263	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Accumulated Fault Duty C Ph V	.30	%
536264	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Accumulated Fault Duty B Ph V	.30	%
536265	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Accumulated Fault Duty A Ph V	.30	%
536266	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	9 Month Operations	1	
536267	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	General Comments		
536268	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	General Comments		
536269	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Grounds in Place?	y	
536270	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Heaters (All) Functioning?	y	
536271	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Maintenance Operations	1	
536272	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Moisture and Leak Free?	y	
536273	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Operations Counter AF	179	
536274	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Operations Counter AL	179	
536275	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Switching Operations	0	
536276	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Tank Paint Condition	Good	
536277	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Unknown Operations	0	
536278	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
536279	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
536280	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
536281	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
536282	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	General Comments		
536283	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
536284	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
536285	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
536286	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
536287	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
536288	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
536289	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
536290	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	General Comments		
536291	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
536292	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
536293	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
536294	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
536295	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
536296	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
536297	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
536298	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
536299	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Regulator As Left Counter	36864	
536300	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
536301	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
536302	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Tank Leaks	None	
536303	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
536304	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Moisture and Leak Free?	y	
536305	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Operations Counter AF	184	
536306	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Operations Counter AL	185	
536307	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Switching Operations	0	
536308	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Tank Paint Condition	Good	
536309	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
536310	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
536311	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
536312	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
536313	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
536314	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
536315	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
536316	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
536317	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	General Comments		
536318	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
536319	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
536320	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Bushing Condition	Good	
536321	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1214	
536322	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
536323	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
536324	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
536325	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
536326	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
536327	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
536328	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
536329	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
536330	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Oil Temp Present	50	°C
536331	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
536332	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
536333	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
536334	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	10765.44	kw
536335	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
536336	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.5	psi
536337	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
536338	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	General Comments	ok	
536339	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
536340	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
536341	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Paint Condition	Good	
536342	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Equipment Properly Labeled?	y	
536343	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
536344	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
536345	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
536346	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations A Ø	0	
536347	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations B Ø	0	
536348	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations C Ø	0	
536349	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations Ground	0	
536350	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Follow-up Action Required?	n	
536351	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Follow-up Action Required?	n	
536352	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Foundation Condition	Good	
536353	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	General Comments		
536354	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	General Comments		
536355	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Grounds in Place?	y	
536356	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Heaters (All) Functioning?	y	
536357	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Maintenance Operations	1	
536358	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.2	VDC
536359	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
536360	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
536361	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
536362	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
536363	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Totalizer Meter Reading	1.0146	
536364	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
536365	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
536366	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
536367	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
536368	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
536369	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
536370	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
536371	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
536372	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Oil Temp Present	32	°C
536373	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Oil Temp Max	55	°C
536374	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
536375	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
536376	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	LTC Totalizer Reading	2435.04	kw
536377	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
536378	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	General Comments		
536379	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
536380	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
536381	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
536382	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations A Ø	0	
536383	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
536384	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
536385	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
536386	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
536387	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
536388	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
536389	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
536390	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
536391	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
536392	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
536393	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
536394	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
536395	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Grounds in Place?	y	
536396	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	General Comments		
536397	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	General Comments		
536398	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations B Ø	0	
536399	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations C Ø	0	
536400	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations Ground	0	
536401	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
536402	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Follow-up Action Required?	n	
536403	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
536404	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
536405	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
536406	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
536407	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
536408	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
536409	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
536410	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
536411	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
536412	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
536413	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Foundation Condition	Good	
536414	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Follow-up Action Required?	n	
536415	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Follow-up Action Required?	n	
536416	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations Ground	0	
536417	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations C Ø	0	
536418	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations B Ø	0	
536419	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations A Ø	0	
536420	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
536421	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
536422	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
536423	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Follow-up Action Required?	n	
536424	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Foundation Condition	Good	
536425	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	General Comments	ok	
536426	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	General Comments	ok	
536427	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Grounds in Place?	y	
536428	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Heaters (All) Functioning?	y	
536429	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Maintenance Operations	0	
536430	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Moisture and Leak Free?	y	
536431	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Operations Counter AF	176	
536432	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Operations Counter AL	176	
536433	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
536434	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
536435	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Equipment Properly Labeled?	y	
536436	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Paint Condition	Good	
536437	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
536438	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
536439	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
536440	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Bushings Connection/Risers	Good	
536441	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Bushing Condition	Good	
536442	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Amps C Ø	60.0	
536443	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
536444	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
536445	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
536446	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
536447	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
536448	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
536449	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
536450	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
536451	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
536452	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
536453	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
536454	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
536455	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Amps C Ø	480.0	
536456	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Amps B Ø	420.0	
536457	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Amps A Ø	416.0	
536458	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Accumulated Fault Duty C Ph V	1.15	%
536459	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Accumulated Fault Duty B Ph V	1.15	%
536460	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Accumulated Fault Duty A Ph V	1.15	%
536461	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	9 Month Operations	0	
536462	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Unknown Operations	0	
536463	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Unknown Operations	0	
536464	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Tank Paint Condition	Good	
536465	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Switching Operations	0	
536466	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
536467	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	9 Month Operations	5	
536468	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Accumulated Fault Duty A Ph V	2.00	%
536469	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Accumulated Fault Duty B Ph V	1.00	%
536470	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Accumulated Fault Duty C Ph V	1.00	%
536471	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Amps A Ø	40.0	
536472	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Amps B Ø	45.0	
536473	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Unknown Operations	0	
536474	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
536475	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
536476	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
536477	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Panels Dusted?	y	
536478	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
536479	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Tank Paint Condition	Good	
536480	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Switching Operations	0	
536481	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
536482	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Operations Counter AL	186	
536483	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Operations Counter AF	185	
536484	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Moisture and Leak Free?	y	
536485	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Maintenance Operations	1	
536486	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Heaters (All) Functioning?	y	
536487	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	General Comments		
536488	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
536489	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
536490	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Floor Swept?	y	
536491	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
536492	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
536493	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Evidence of Insects	None	
536494	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
536495	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
536496	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
536497	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Vegetation	None	
536498	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
536499	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
536500	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
536501	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
536502	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Operations Counter AL	204	
536503	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Operations Counter AF	204	
536504	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Operations Counter AF	171	
536505	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Moisture and Leak Free?	y	
536506	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Maintenance Operations	0	
536507	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Heaters (All) Functioning?	y	
536508	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Grounds in Place?	y	
536509	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	General Comments		
536510	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	General Comments		
536511	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Foundation Condition	Good	
536512	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Follow-up Action Required?	n	
536513	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
536514	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	General Comments		
536515	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
536516	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
536517	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Follow-up Action Required?	n	
536518	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations Ground	0	
536519	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations C Ø	0	
536520	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations B Ø	0	
536521	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations A Ø	0	
536522	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
536523	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
536524	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
536525	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
536526	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
536527	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Clear of Trash?	y	
536528	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
536529	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
536530	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
536531	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
536532	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Equipment Properly Labeled?	y	
536533	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Paint Condition	Good	
536534	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
536535	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
536536	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
536537	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Bushings Connection/Risers	Good	
536538	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Bushing Condition	Good	
536539	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Amps C Ø	299.0	
536540	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Amps B Ø	211.0	
536541	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Amps A Ø	243.0	
536542	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
536543	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
536544	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
536545	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	9 Month Operations	1	
536546	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
536547	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
536548	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
536549	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
536550	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
536551	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
536552	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
536553	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
536554	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
536555	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
536556	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
536557	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
536558	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
536559	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	12.2	VDC
536560	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	12.9	VDC
536561	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
536562	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
536563	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
536564	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
536565	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
536566	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	General Comments		
536567	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
536568	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
536569	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Foundation Condition	Good	
536570	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
536571	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
536572	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
536573	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
536574	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
536575	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Accumulated Fault Duty C Ph V	3.10	%
536576	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Amps A Ø	180.0	
536577	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Amps B Ø	120.0	
536578	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Amps C Ø	120.0	
536579	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Bushing Condition	Good	
536580	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Bushings Connection/Risers	Good	
536581	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Unknown Operations	0	
536582	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Tank Paint Condition	Good	
536583	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
536584	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
536585	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
536586	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Paint Condition	Good	
536587	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Equipment Properly Labeled?	y	
536588	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
536589	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Regulator As Left Counter	306766	
536590	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
536591	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
536592	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
536593	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
536594	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Switching Operations	0	
536595	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
536596	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Operations Counter AL	171	
536597	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
536598	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
536599	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Unknown Operations	0	
536600	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Tank Paint Condition	Good	
536601	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Switching Operations	0	
536602	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
536603	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Operations Counter AL	180	
536604	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Operations Counter AF	180	
536605	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Moisture and Leak Free?	y	
536606	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Maintenance Operations	0	
536607	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Heaters (All) Functioning?	y	
536608	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	29.3	VDC
536609	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Grounds in Place?	y	
536610	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	General Comments		
536611	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	General Comments		
536612	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Foundation Condition	Good	
536613	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Follow-up Action Required?	n	
536614	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Follow-up Action Required?	n	
536615	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations Ground	0	
536616	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations C Ø	0	
536617	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations B Ø	0	
536618	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations A Ø	0	
536619	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
536620	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
536621	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	28.0	VDC
536622	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
536623	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
536624	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Tank Leaks	None	
536625	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
536626	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
536627	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Equipment Properly Labeled?	y	
536628	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Paint Condition	Good	
536629	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
536630	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
536631	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
536632	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Bushings Connection/Risers	Good	
536633	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Bushing Condition	Good	
536634	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	9 Month Operations	3	
536635	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Accumulated Fault Duty A Ph V	5.00	%
536636	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Amps C Ø	73.0	
536637	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Amps B Ø	62.0	
536638	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Amps A Ø	59.0	
536639	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
536640	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
536641	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
536642	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	9 Month Operations	1	
536643	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Accumulated Fault Duty B Ph V	4.06	%
536644	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Accumulated Fault Duty C Ph V	3.75	%
536645	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Amps A Ø	30.0	
536646	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Amps B Ø	60.0	
536647	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Amps C Ø	35.0	
536648	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Bushing Condition	Good	
536649	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Bushings Connection/Risers	Good	
536650	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
536651	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Maintenance Operations	0	
536652	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Grounds in Place?	y	
536653	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	General Comments		
536654	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	General Comments		
536655	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Foundation Condition	Good	
536656	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Follow-up Action Required?	n	
536657	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Follow-up Action Required?	n	
536658	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Operations Ground	0	
536659	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Operations C Ø	0	
536660	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Operations B Ø	0	
536661	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Operations A Ø	0	
536662	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
536663	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
536664	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
536665	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
536666	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
536667	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
536668	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
536669	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Unknown Operations	0	
536670	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Tank Paint Condition	Good	
536671	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Switching Operations	0	
536672	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Operations Counter AL	187	
536673	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Operations Counter AF	187	
536674	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Moisture and Leak Free?	y	
536675	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Maintenance Operations	0	
536676	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Heaters (All) Functioning?	y	
536677	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Grounds in Place?	y	
536678	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	General Comments		
536679	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	General Comments		
536680	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Foundation Condition	Good	
536681	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Follow-up Action Required?	n	
536682	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Follow-up Action Required?	n	
536683	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations Ground	0	
536684	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations C Ø	0	
536685	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations B Ø	0	
536686	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations A Ø	0	
536687	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
536688	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
536689	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
536690	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Equipment Properly Labeled?	y	
536691	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Paint Condition	Good	
536692	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
536693	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
536694	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
536695	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Bushings Connection/Risers	Good	
536696	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Bushing Condition	Good	
536697	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Amps C Ø	128.0	
536698	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Amps B Ø	163.0	
536699	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Amps A Ø	131.0	
536700	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Accumulated Fault Duty C Ph V	.76	%
536701	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Accumulated Fault Duty B Ph V	1.13	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
536702	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Accumulated Fault Duty A Ph V	1.13	%
536703	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	9 Month Operations	4	
536704	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
536705	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
536706	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
536707	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
536708	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
536709	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	General Comments		
536710	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
536711	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
536712	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
536713	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
536714	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
536715	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
536716	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
536717	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
536718	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
536719	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
536720	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	Follow-up Action Required?	n	
536721	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
536722	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	General Comments		
536723	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	General Comments		
536724	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC As Found Counter	4745	
536725	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC As Left Counter	4756	
536726	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
536727	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Current Tap Position	3R	
536728	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Max Tap Position	6R	
536729	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	120.0	
536730	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	120.0	
536731	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	120.0	
536732	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
536733	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
536734	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
536735	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
536736	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Min Tap Position	4L	
536737	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Operations Since Last Insp	303	
536738	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
536739	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
536740	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
536741	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
536742	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
536743	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
536744	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
536745	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
536746	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
536747	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
536748	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
536749	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
536750	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
536751	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	General Comments		
536752	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
536753	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
536754	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
536755	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
536756	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Heaters (All) Functioning?	y	
536757	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Maintenance Operations	1	
536758	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Moisture and Leak Free?	y	
536759	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Operations Counter AF	192	
536760	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Operations Counter AL	193	
536761	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Switching Operations	0	
536762	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Tank Paint Condition	Good	
536763	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Unknown Operations	0	
536764	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	BCH000458	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
536765	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	BCH000458	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
536766	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	BCH000458	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
536767	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
536768	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
536769	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
536770	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
536771	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
536772	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
536773	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
536774	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
536775	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
536776	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
536777	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
536778	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
536779	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
536780	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
536781	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
536782	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
536783	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
536784	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Vegetation	None	
536785	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
536786	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
536787	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
536788	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
536789	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
536790	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
536791	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
536792	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
536793	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
536794	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
536795	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
536796	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
536797	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
536798	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
536799	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	General Comments		
536800	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
536801	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Tank Leaks	None	
536802	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
536803	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
536804	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Regulator As Left Counter	116904	
536805	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
536806	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
536807	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
536808	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	General Comments	Added warning signs to both gates	
536809	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
536810	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
536811	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
536812	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
536813	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
536814	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Unknown Operations	0	
536815	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Tank Paint Condition	Good	
536816	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Switching Operations	0	
536817	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Operations Counter AL	209	
536818	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Operations Counter AF	209	
536819	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Moisture and Leak Free?	y	
536820	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Maintenance Operations	0	
536821	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Heaters (All) Functioning?	y	
536822	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
536823	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
536824	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
536825	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
536826	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
536827	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
536828	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
536829	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
536830	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
536831	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
536832	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	26.00	
536833	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1627.20	kw
536834	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
536835	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
536836	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
536837	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
536838	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
536839	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
536840	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
536841	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Grounds in Place?	y	
536842	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	General Comments		
536843	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	General Comments		
536844	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Foundation Condition	Good	
536845	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Follow-up Action Required?	n	
536846	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
536847	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	General Comments		
536848	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	General Comments		
536849	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
536850	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
536851	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
536852	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
536853	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
536854	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
536855	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
536856	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
536857	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
536858	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
536859	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
536860	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
536861	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	452	
536862	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	456	
536863	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
536864	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
536865	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
536866	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
536867	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
536868	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
536869	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
536870	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
536871	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
536872	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
536873	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
536874	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
536875	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
536876	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	General Comments		
536877	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
536878	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
536879	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Foundation Condition	Good	
536880	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
536881	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
536882	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
536883	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
536884	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
536885	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
536886	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	General Comments		
536887	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
536888	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
536889	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
536890	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
536891	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
536892	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
536893	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
536894	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
536895	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
536896	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
536897	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
536898	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
536899	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
536900	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
536901	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
536902	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6780	
536903	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
536904	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
536905	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
536906	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
536907	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
536908	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Clear of Trash?	y	
536909	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
536910	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
536911	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
536912	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
536913	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
536914	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
536915	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	General Comments		
536916	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
536917	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
536918	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
536919	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
536920	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
536921	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
536922	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
536923	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	General Comments		
536924	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
536925	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
536926	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
536927	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
536928	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
536929	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
536930	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
536931	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
536932	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
536933	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
536934	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
536935	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
536936	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
536937	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
536938	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
536939	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	General Comments		
536940	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
536941	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
536942	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
536943	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
536944	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
536945	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	General Comments		
536946	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.0	VDC
536947	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
536948	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Vegetation	None	
536949	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
536950	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	General Comments		
536951	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
536952	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
536953	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
536954	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
536955	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
536956	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
536957	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
536958	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9246	
536959	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
536960	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
536961	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
536962	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
536963	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
536964	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3185.28	kw
536965	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
536966	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
536967	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
536968	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	General Comments		
536969	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	General Comments		
536970	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
536971	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
536972	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
536973	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
536974	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
536975	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
536976	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
536977	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
536978	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
536979	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
536980	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
536981	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	General Comments		
536982	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
536983	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
536984	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
536985	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
536986	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
536987	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
536988	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
536989	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
536990	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
536991	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
536992	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
536993	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
536994	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
536995	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
536996	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
536997	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
536998	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
536999	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
537000	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
537001	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
537002	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
537003	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
537004	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
537005	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
537006	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
537007	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	General Comments		
537008	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
537009	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
537010	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Foundation Condition	Good	
537011	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
537012	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
537013	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
537014	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
537015	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
537016	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
537017	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
537018	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
537019	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
537020	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	General Comments		
537021	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
537022	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Max Tap Position	2R	
537023	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Min Tap Position	7L	
537024	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
537025	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
537026	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
537027	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
537028	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
537029	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Regulator As Left Counter	23583	
537030	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
537031	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Tank Leaks	None	
537032	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
537033	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
537034	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Clear of Trash?	y	
537035	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
537036	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
537037	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
537038	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LTCC000533	LTCControl	CR-TRANS 2-B	LTC Control Insp	General Comments	Not in service	
537039	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	9 Month Operations	2	
537040	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Accumulated Fault Duty A Ph V	4.69	%
537041	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Accumulated Fault Duty B Ph V	5.31	%
537042	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Accumulated Fault Duty C Ph V	3.75	%
537043	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Amps A Ø	190.0	
537044	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Amps B Ø	170.0	
537045	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Amps C Ø	175.0	
537046	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Bushing Condition	Good	
537047	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Bushings Connection/Risers	Good	
537048	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LTCC000533	LTCControl	CR-TRANS 2-B	LTC Control Insp	Follow-up Action Required?	n	
537049	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LTCC000533	LTCControl	CR-TRANS 2-B	LTC Control Insp	All Connections OK?	y	
537050	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
537051	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
537052	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
537053	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Paint Condition	Good	
537054	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Equipment Properly Labeled?	y	
537055	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
537056	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
537057	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
537058	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations A Ø	0	
537059	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations B Ø	0	
537060	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations C Ø	0	
537061	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations Ground	0	
537062	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Follow-up Action Required?	n	
537063	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Follow-up Action Required?	n	
537064	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Foundation Condition	Good	
537065	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	General Comments		
537066	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	General Comments		
537067	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Grounds in Place?	y	
537068	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
537069	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
537070	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
537071	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
537072	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Oil Temp Max	65	°C
537073	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
537074	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
537075	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2958.72	kw
537076	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
537077	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
537078	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
537079	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	General Comments		
537080	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	General Comments		
537081	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
537082	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
537083	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
537084	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
537085	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
537086	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
537087	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
537088	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
537089	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
537090	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
537091	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
537092	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
537093	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
537094	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Current Tap Position	3R	
537095	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
537096	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
537097	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
537098	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
537099	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
537100	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
537101	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
537102	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	General Comments		
537103	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
537104	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Max Tap Position	7R	
537105	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Min Tap Position	5L	
537106	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
537107	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
537108	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
537109	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
537110	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
537111	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Regulator As Left Counter	27218	
537112	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
537113	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Tank Leaks	None	
537114	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
537115	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
537116	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
537117	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
537118	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
537119	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
537120	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Current Tap Position	1L	
537121	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
537122	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	General Comments		
537123	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
537124	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
537125	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Foundation Condition	Good	
537126	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
537127	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
537128	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
537129	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
537130	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Regulator As Left Counter	7437	
537131	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
537132	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
537133	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Tank Leaks	None	
537134	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
537135	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Bushing Oil Level	Good	
537136	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
537137	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
537138	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Bushing Condition	Good	
537139	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
537140	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
537141	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
537142	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	General Comments		
537143	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Foundation Condition	Good	
537144	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Follow-up Action Required?	n	
537145	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
537146	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
537147	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	General Comments	need two more spare fuses only one in cabinet	
537148	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
537149	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
537150	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Foundation Condition	Good	
537151	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
537152	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
537153	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
537154	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
537155	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
537156	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
537157	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
537158	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Vegetation	None	
537159	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
537160	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
537161	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	General Comments		
537162	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
537163	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
537164	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
537165	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
537166	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
537167	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
537168	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
537169	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
537170	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
537171	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
537172	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
537173	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
537174	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
537175	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
537176	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
537177	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Regulator As Left Counter	9817	
537178	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
537179	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
537180	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Tank Leaks	None	
537181	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
537182	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
537183	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	General Comments		
537184	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
537185	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
537186	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
537187	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
537188	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
537189	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
537190	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
537191	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
537192	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
537193	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
537194	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
537195	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
537196	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
537197	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
537198	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
537199	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
537200	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
537201	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
537202	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
537203	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
537204	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
537205	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
537206	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
537207	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	General Comments		
537208	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
537209	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
537210	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
537211	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Foundation Condition	Good	
537212	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
537213	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
537214	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
537215	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
537216	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
537217	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
537218	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
537219	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
537220	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
537221	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
537222	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
537223	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Foundation Condition	Good	
537224	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
537225	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations C Ø	0	
537226	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
537227	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations A Ø	0	
537228	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
537229	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
537230	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
537231	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Equipment Properly Labeled?	y	
537232	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Paint Condition	Good	
537233	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
537234	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
537235	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
537236	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Bushings Connection/Risers	Good	
537237	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Bushing Condition	Good	
537238	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
537239	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
537240	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
537241	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
537242	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
537243	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
537244	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	Follow-up Action Required?	n	
537245	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
537246	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	General Comments		
537247	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
537248	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Maintenance Operations	0	
537249	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
537250	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Grounds in Place?	y	
537251	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	General Comments		
537252	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	General Comments		
537253	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Foundation Condition	Good	
537254	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Follow-up Action Required?	n	
537255	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Follow-up Action Required?	n	
537256	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Moisture and Leak Free?	y	
537257	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Operations Counter AF	88	
537258	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Operations Counter AL	88	
537259	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
537260	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Switching Operations	0	
537261	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations Ground	0	
537262	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations C Ø	0	
537263	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	General Comments		
537264	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC As Found Counter	2969	
537265	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC As Left Counter	2669	
537266	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
537267	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
537268	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
537269	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
537270	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
537271	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
537272	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
537273	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
537274	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
537275	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
537276	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
537277	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
537278	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
537279	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Clear of Trash?	y	
537280	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
537281	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
537282	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Ambient Temp	42	°F
537283	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
537284	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
537285	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	9 Month Operations	4	
537286	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Accumulated Fault Duty A Ph V	11.23	%
537287	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Accumulated Fault Duty B Ph V	10.85	%
537288	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Accumulated Fault Duty C Ph V	10.07	%
537289	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	General Comments		
537290	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	Desiccant needs replaced	
537291	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Amps A Ø	180.0	
537292	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Amps B Ø	200.0	
537293	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Amps C Ø	180.0	
537294	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Bushing Condition	Good	
537295	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Bushings Connection/Risers	Good	
537296	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
537297	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
537298	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
537299	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Paint Condition	Good	
537300	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Equipment Properly Labeled?	y	
537301	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
537302	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
537303	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
537304	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations A Ø	0	
537305	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations B Ø	0	
537306	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	9 Month Operations	2	
537307	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Accumulated Fault Duty A Ph V	.64	%
537308	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Accumulated Fault Duty B Ph V	.64	%
537309	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Unknown Operations	0	
537310	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Tank Paint Condition	Good	
537311	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Switching Operations	1	
537312	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
537313	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Operations Counter AL	181	
537314	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Operations Counter AF	181	
537315	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Accumulated Fault Duty C Ph V	.64	%
537316	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Amps A Ø	14.0	
537317	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations C Ø	0	
537318	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations Ground	0	
537319	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Follow-up Action Required?	n	
537320	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Follow-up Action Required?	n	
537321	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Foundation Condition	Good	
537322	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	General Comments	ok	
537323	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	General Comments	ok	
537324	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Grounds in Place?	y	
537325	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Heaters (All) Functioning?	y	
537326	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Maintenance Operations	0	
537327	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Follow-up Action Required?	n	
537328	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations Ground	0	
537329	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
537330	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
537331	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
537332	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Unknown Operations	0	
537333	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Tank Paint Condition	Good	
537334	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Accumulated Fault Duty B Ph V	.31	%
537335	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Accumulated Fault Duty C Ph V	.31	%
537336	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Amps A Ø	0.0	
537337	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Amps B Ø	0.0	
537338	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Amps C Ø	0.0	
537339	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Bushing Condition	Good	
537340	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Bushings Connection/Risers	Good	
537341	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Clear of Trash?	y	
537342	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
537343	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
537344	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
537345	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Winding Temp Max	45	°C
537346	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
537347	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
537348	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Tank Leaks	None	
537349	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
537350	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Radiator Leaks	None	
537351	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
537352	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Oil Temp Max	35	°C
537353	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
537354	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Grounds in Place?	y	
537355	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
537356	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Switching Operations	0	
537357	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Operations Counter AL	137	
537358	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Operations Counter AF	137	
537359	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Moisture and Leak Free?	y	
537360	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Maintenance Operations	0	
537361	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Heaters (All) Functioning?	y	
537362	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
537363	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Grounds in Place?	y	
537364	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	General Comments		
537365	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
537366	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
537367	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
537368	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Paint Condition	Good	
537369	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Equipment Properly Labeled?	y	
537370	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
537371	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
537372	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
537373	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations A Ø	0	
537374	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations B Ø	0	
537375	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations C Ø	0	
537376	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
537377	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
537378	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
537379	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
537380	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
537381	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Follow-up Action Required?	n	
537382	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations Ground	0	
537383	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations C Ø	0	
537384	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations B Ø	0	
537385	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations A Ø	0	
537386	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
537387	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
537388	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
537389	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Equipment Properly Labeled?	y	
537390	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Paint Condition	Good	
537391	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
537392	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
537393	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
537394	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Bushings Connection/Risers	Good	
537395	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
537396	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Bushing Condition	Good	
537397	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Amps C Ø	120.0	
537398	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Amps B Ø	20.0	
537399	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Amps A Ø	20.0	
537400	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Accumulated Fault Duty C Ph V	2.01	%
537401	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Accumulated Fault Duty B Ph V	1.87	%
537402	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Accumulated Fault Duty A Ph V	1.87	%
537403	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	9 Month Operations	6	
537404	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
537405	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
537406	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
537407	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
537408	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
537409	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
537410	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
537411	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
537412	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
537413	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
537414	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	9 Month Operations	3	
537415	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Accumulated Fault Duty A Ph V	.31	%
537416	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
537417	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
537418	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
537419	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
537420	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
537421	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
537422	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
537423	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
537424	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	37	°F
537425	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
537426	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Vegetation	None	
537427	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
537428	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
537429	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	General Comments		
537430	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
537431	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
537432	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
537433	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
537434	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	General Comments		
537435	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
537436	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
537437	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
537438	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
537439	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
537440	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
537441	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Clear of Trash?	y	
537442	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
537443	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
537444	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Ambient Temp	38	°F
537445	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
537446	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
537447	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
537448	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
537449	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
537450	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
537451	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
537452	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
537453	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
537454	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	General Comments		
537455	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	General Comments		
537456	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
537457	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
537458	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
537459	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
537460	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
537461	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
537462	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
537463	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
537464	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
537465	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	General Comments		
537466	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
537467	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
537468	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
537469	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
537470	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
537471	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
537472	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
537473	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
537474	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
537475	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
537476	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
537477	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
537478	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
537479	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
537480	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	General Comments		
537481	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
537482	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
537483	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
537484	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
537485	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
537486	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
537487	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
537488	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
537489	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
537490	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
537491	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
537492	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
537493	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
537494	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
537495	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	General Comments		
537496	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
537497	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
537498	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Foundation Condition	Good	
537499	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
537500	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
537501	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
537502	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
537503	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
537504	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
537505	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
537506	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
537507	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
537508	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
537509	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
537510	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
537511	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
537512	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	General Comments		
537513	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
537514	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
537515	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
537516	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations Ground	0	
537517	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Follow-up Action Required?	n	
537518	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Follow-up Action Required?	n	
537519	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
537520	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
537521	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
537522	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
537523	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
537524	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
537525	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Foundation Condition	Good	
537526	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
537527	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	General Comments		
537528	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Grounds in Place?	y	
537529	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Heaters (All) Functioning?	y	
537530	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Maintenance Operations	1	
537531	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Moisture and Leak Free?	y	
537532	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Operations Counter AF	137	
537533	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Operations Counter AL	138	
537534	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Switching Operations	0	
537535	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Tank Paint Condition	Good	
537536	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Unknown Operations	0	
537537	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Vegetation	None	
537538	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
537539	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
537540	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
537541	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
537542	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Operations Since Last Insp	750	
537543	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	15	°C
537544	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
537545	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Counter Readings	Follow-up Action Required?	n	
537546	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
537547	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Counter Readings	General Comments		
537548	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	General Comments		
537549	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC As Found Counter	310380	
537550	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC As Left Counter	310380	
537551	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
537552	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Current Tap Position	11L	
537553	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
537554	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
537555	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Amps A Ø	74.0	
537556	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Amps B Ø	70.0	
537557	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Max Tap Position	6L	
537558	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Min Tap Position	13L	
537559	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
537560	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Amps C Ø	70.0	
537561	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Operations Since Last Insp	570	
537562	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
537563	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
537564	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
537565	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Min Tap Position	12L	
537566	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Max Tap Position	3L	
537567	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Current Tap Position	9L	
537568	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
537569	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC As Left Counter	46778	
537570	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC As Found Counter	46778	
537571	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	General Comments		
537572	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	General Comments		
537573	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
537574	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	Follow-up Action Required?	n	
537575	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
537576	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
537577	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
537578	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
537579	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
537580	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
537581	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Bushing Condition	Good	
537582	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Bushings Connection/Risers	Good	
537583	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
537584	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
537585	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
537586	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Paint Condition	Good	
537587	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Equipment Properly Labeled?	y	
537588	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
537589	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
537590	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
537591	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
537592	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
537593	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
537594	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
537595	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
537596	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
537597	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Regulator As Left Counter	26631	
537598	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
537599	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
537600	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Tank Leaks	None	
537601	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
537602	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Bushings Connection/Risers	Good	
537603	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
537604	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
537605	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
537606	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Cabinet Paint Condition	Good	
537607	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Equipment Properly Labeled?	y	
537608	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
537609	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
537610	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
537611	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Operations A Ø	0	
537612	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Operations B Ø	0	
537613	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Operations C Ø	0	
537614	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Operations Ground	0	
537615	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Follow-up Action Required?	n	
537616	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Follow-up Action Required?	n	
537617	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Foundation Condition	Good	
537618	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	General Comments		
537619	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	General Comments		
537620	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Grounds in Place?	y	
537621	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Maintenance Operations	0	
537622	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Moisture and Leak Free?	y	
537623	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Operations Counter AF	156	
537624	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Operations Counter AL	156	
537625	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Switching Operations	2	
537626	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Tank Paint Condition	Good	
537627	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Unknown Operations	0	
537628	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
537629	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
537630	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
537631	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
537632	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
537633	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Clear of Trash?	y	
537634	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
537635	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
537636	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
537637	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	180.0	
537638	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Amps A Ø	0.0	
537639	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Amps B Ø	0.0	
537640	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Amps C Ø	0.0	
537641	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Bushing Condition	Good	
537642	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Bushings Connection/Risers	Good	
537643	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	9 Month Operations	1	
537644	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
537645	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
537646	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
537647	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
537648	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
537649	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
537650	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
537651	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
537652	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
537653	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Bushing Condition	Good	
537654	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Bushings Connection/Risers	Good	
537655	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
537656	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
537657	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
537658	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
537659	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
537660	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
537661	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
537662	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
537663	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
537664	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Paint Condition	Good	
537665	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Equipment Properly Labeled?	y	
537666	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
537667	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
537668	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
537669	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations A Ø	0	
537670	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations B Ø	0	
537671	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations C Ø	0	
537672	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations Ground	0	
537673	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Follow-up Action Required?	n	
537674	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Follow-up Action Required?	n	
537675	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Foundation Condition	Good	
537676	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
537677	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	General Comments		
537678	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Grounds in Place?	y	
537679	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Heaters (All) Functioning?	y	
537680	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Maintenance Operations	0	
537681	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Moisture and Leak Free?	y	
537682	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Operations Counter AF	184	
537683	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
537684	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Operations Counter AL	184	
537685	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Switching Operations	0	
537686	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Tank Paint Condition	Good	
537687	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Unknown Operations	0	
537688	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
537689	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
537690	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
537691	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Oil Temp Max	35	°C
537692	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Oil Temp Present	30	°C
537693	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
537694	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
537695	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
537696	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
537697	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
537698	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations A Ø	0	
537699	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
537700	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	General Comments		
537701	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
537702	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
537703	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations B Ø	0	
537704	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations C Ø	0	
537705	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations Ground	0	
537706	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Follow-up Action Required?	n	
537707	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Follow-up Action Required?	n	
537708	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Foundation Condition	Good	
537709	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	General Comments		
537710	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	General Comments		
537711	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
537712	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
537713	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
537714	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
537715	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
537716	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
537717	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Follow-up Action Required?	n	
537718	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
537719	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
537720	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	General Comments		
537721	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	General Comments		
537722	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Grounds in Place?	y	
537723	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Heaters (All) Functioning?	y	
537724	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Maintenance Operations	0	
537725	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Moisture and Leak Free?	y	
537726	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Operations Counter AF	197	
537727	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Operations Counter AL	197	
537728	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Switching Operations	0	
537729	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Tank Paint Condition	Good	
537730	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Unknown Operations	0	
537731	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
537732	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
537733	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
537734	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	LTC Totalizer Reading	15660.00	kw
537735	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
537736	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
537737	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	9 Month Operations	11	
537738	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Accumulated Fault Duty A Ph V	4.99	%
537739	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Accumulated Fault Duty B Ph V	4.99	%
537740	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Accumulated Fault Duty C Ph V	4.99	%
537741	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Amps A Ø	98.0	
537742	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Amps B Ø	97.0	
537743	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Amps C Ø	137.0	
537744	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
537745	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
537746	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	General Comments		
537747	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
537748	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
537749	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
537750	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
537751	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
537752	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
537753	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
537754	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
537755	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
537756	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
537757	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
537758	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
537759	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
537760	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
537761	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
537762	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
537763	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
537764	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Vegetation	None	
537765	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
537766	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
537767	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3271.68	kw
537768	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
537769	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
537770	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
537771	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
537772	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
537773	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
537774	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations A Ø	0	
537775	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations B Ø	0	
537776	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	9 Month Operations	11	
537777	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
537778	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	General Comments		
537779	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
537780	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
537781	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
537782	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
537783	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
537784	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
537785	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
537786	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Vegetation	None	
537787	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
537788	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
537789	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	General Comments		
537790	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
537791	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	General Comments		
537792	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	General Comments		
537793	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
537794	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
537795	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
537796	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
537797	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
537798	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
537799	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
537800	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
537801	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
537802	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	120.0	
537803	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	120.0	
537804	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
537805	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Grounds in Place?	y	
537806	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Tank Paint Condition	Good	
537807	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Switching Operations	2	
537808	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Operations Counter AL	162	
537809	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Operations Counter AF	162	
537810	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
537811	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
537812	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
537813	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
537814	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
537815	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
537816	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
537817	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
537818	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	216	
537819	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	212	
537820	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
537821	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
537822	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
537823	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
537824	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
537825	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	General Comments		
537826	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
537827	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
537828	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
537829	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
537830	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Winding Temp Present	15	°C
537831	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Winding Temp Max	30	°C
537832	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6816	
537833	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
537834	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
537835	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
537836	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
537837	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
537838	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
537839	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Moisture and Leak Free?	y	
537840	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Maintenance Operations	0	
537841	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Grounds in Place?	y	
537842	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	General Comments		
537843	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	General Comments		
537844	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Accumulated Fault Duty C Ph V	.47	%
537845	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Amps A Ø	137.0	
537846	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Amps B Ø	156.0	
537847	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Amps C Ø	181.0	
537848	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Bushing Condition	Good	
537849	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Bushings Connection/Risers	Good	
537850	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
537851	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
537852	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
537853	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Cabinet Paint Condition	Good	
537854	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Equipment Properly Labeled?	y	
537855	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
537856	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
537857	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Oil Temp Present	15	°C
537858	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
537859	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
537860	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
537861	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	General Comments		
537862	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
537863	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
537864	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
537865	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
537866	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
537867	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
537868	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
537869	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
537870	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	9 Month Operations	33	
537871	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Accumulated Fault Duty A Ph V	.66	%
537872	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Accumulated Fault Duty B Ph V	.33	%
537873	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Accumulated Fault Duty C Ph V	.33	%
537874	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Amps A Ø	57.0	
537875	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Amps B Ø	63.0	
537876	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Amps C Ø	68.0	
537877	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Bushing Condition	Good	
537878	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Regulator As Left Counter	25930	
537879	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
537880	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
537881	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Tank Leaks	None	
537882	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
537883	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
537884	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
537885	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
537886	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Equipment Properly Labeled?	y	
537887	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Paint Condition	Good	
537888	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
537889	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
537890	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
537891	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Bushings Connection/Risers	Good	
537892	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Bushing Condition	Good	
537893	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Amps C Ø	40.0	
537894	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Amps B Ø	40.0	
537895	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Amps A Ø	50.0	
537896	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
537897	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
537898	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Accumulated Fault Duty A Ph V	.66	%
537899	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	9 Month Operations	5	
537900	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
537901	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
537902	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
537903	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
537904	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
537905	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
537906	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
537907	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
537908	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
537909	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
537910	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	General Comments		
537911	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
537912	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
537913	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
537914	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
537915	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
537916	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
537917	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
537918	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
537919	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
537920	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
537921	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
537922	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
537923	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Clear of Trash?	y	
537924	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
537925	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
537926	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
537927	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	General Comments		
537928	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
537929	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
537930	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
537931	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
537932	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
537933	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
537934	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
537935	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
537936	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
537937	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
537938	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
537939	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
537940	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
537941	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Unknown Operations	0	
537942	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Tank Paint Condition	Good	
537943	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Switching Operations	0	
537944	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Operations Counter AL	186	
537945	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Operations Counter AF	186	
537946	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Moisture and Leak Free?	y	
537947	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Maintenance Operations	5	
537948	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Heaters (All) Functioning?	y	
537949	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Grounds in Place?	y	
537950	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	General Comments		
537951	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	General Comments		
537952	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Foundation Condition	Good	
537953	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Follow-up Action Required?	n	
537954	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Follow-up Action Required?	n	
537955	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations Ground	0	
537956	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations C Ø	0	
537957	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations B Ø	0	
537958	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations A Ø	0	
537959	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
537960	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
537961	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
537962	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
537963	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
537964	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
537965	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
537966	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
537967	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Unknown Operations	0	
537968	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	9 Month Operations	4	
537969	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Accumulated Fault Duty A Ph V	4.49	%
537970	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Accumulated Fault Duty B Ph V	4.49	%
537971	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Accumulated Fault Duty C Ph V	4.49	%
537972	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Amps A Ø	80.0	
537973	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Amps B Ø	104.0	
537974	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Amps C Ø	74.0	
537975	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
537976	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	9 Month Operations	2	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
537977	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Accumulated Fault Duty A Ph V	.41	%
537978	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Bushing Condition	Good	
537979	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Bushings Connection/Risers	Good	
537980	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
537981	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	General Comments		
537982	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
537983	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC As Found Counter	356510	
537984	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Accumulated Fault Duty B Ph V	.41	%
537985	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Accumulated Fault Duty C Ph V	.41	%
537986	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
537987	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
537988	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC As Left Counter	356510	
537989	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
537990	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
537991	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
537992	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Amps A Ø	11.0	
537993	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
537994	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	648	
537995	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
537996	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
537997	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
537998	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
537999	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	VRR Time Delay	30	Seconds
538000	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
538001	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
538002	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Paint Condition	Good	
538003	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Equipment Properly Labeled?	y	
538004	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
538005	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
538006	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
538007	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations A Ø	0	
538008	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations B Ø	0	
538009	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations C Ø	0	
538010	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations Ground	0	
538011	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Follow-up Action Required?	n	
538012	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Follow-up Action Required?	n	
538013	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Foundation Condition	Good	
538014	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
538015	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	9 Month Operations	1	
538016	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
538017	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
538018	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
538019	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
538020	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
538021	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Accumulated Fault Duty C Ph V	.33	%
538022	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Amps A Ø	64.0	
538023	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
538024	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	152442	
538025	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Amps B Ø	59.0	
538026	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Amps C Ø	55.0	
538027	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
538028	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
538029	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Bushing Condition	Good	
538030	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Bushings Connection/Risers	Good	
538031	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
538032	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
538033	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
538034	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
538035	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Paint Condition	Good	
538036	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Equipment Properly Labeled?	y	
538037	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
538038	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
538039	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
538040	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations A Ø	0	
538041	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	General Comments		
538042	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	General Comments		
538043	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Grounds in Place?	y	
538044	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Maintenance Operations	0	
538045	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Moisture and Leak Free?	y	
538046	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Operations Counter AF	169	
538047	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations B Ø	0	
538048	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations C Ø	0	
538049	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Operations Counter AL	169	
538050	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations Ground	0	
538051	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
538052	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Follow-up Action Required?	n	
538053	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Foundation Condition	Good	
538054	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	General Comments		
538055	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	General Comments		
538056	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Grounds in Place?	y	
538057	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Maintenance Operations	0	
538058	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Moisture and Leak Free?	y	
538059	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	PF000066	PowerFuse	CR-14KV TR 1-A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
538060	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	PF000066	PowerFuse	CR-14KV TR 1-A POT	Disconnect Powerfuse Inspection	General Comments	ok	
538061	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Operations Counter AF	158	
538062	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Operations Counter AL	158	
538063	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Switching Operations	2	
538064	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Tank Paint Condition	Good	
538065	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	PF000068	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
538066	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	PF000068	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	General Comments	ok	
538067	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Unknown Operations	0	
538068	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	PF000069	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
538069	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	PF000069	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	General Comments	ok	
538070	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Switching Operations	0	
538071	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Tank Paint Condition	Good	
538072	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	PF000070	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
538073	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	PF000070	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	General Comments	ok	
538074	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
538075	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
538076	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
538077	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
538078	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	LTC Operation Checked?	y	
538079	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	General Comments		
538080	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	Follow-up Action Required?	n	
538081	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	All Connections OK?	y	
538082	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Unknown Operations	3	
538083	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Tank Paint Condition	Good	
538084	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Switching Operations	0	
538085	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Operations Counter AL	179	
538086	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Operations Counter AF	178	
538087	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	9 Month Operations	0	
538088	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
538089	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
538090	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
538091	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Amps A Ø	157.0	
538092	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Moisture and Leak Free?	y	
538093	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Maintenance Operations	1	
538094	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Amps B Ø	170.0	
538095	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Amps C Ø	167.0	
538096	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Bushing Condition	Good	
538097	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Bushings Connection/Risers	Good	
538098	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
538099	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
538100	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
538101	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Paint Condition	Good	
538102	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Equipment Properly Labeled?	y	
538103	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
538104	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
538105	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
538106	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations A Ø	0	
538107	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations B Ø	0	
538108	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations C Ø	0	
538109	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations Ground	0	
538110	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Follow-up Action Required?	n	
538111	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Follow-up Action Required?	n	
538112	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Foundation Condition	Good	
538113	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	General Comments		
538114	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	General Comments		
538115	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Grounds in Place?	y	
538116	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Heaters (All) Functioning?	y	
538117	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Grounds in Place?	y	
538118	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	General Comments		
538119	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	General Comments		
538120	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Heaters (All) Functioning?	y	
538121	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Maintenance Operations	0	
538122	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Moisture and Leak Free?	y	
538123	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Operations Counter AF	177	
538124	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Foundation Condition	Good	
538125	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Follow-up Action Required?	n	
538126	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Operations Counter AL	177	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
538127	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
538128	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
538129	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
538130	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
538131	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Amps A Ø	124.0	
538132	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
538133	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
538134	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Amps B Ø	115.0	
538135	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Amps C Ø	120.0	
538136	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
538137	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
538138	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Bushing Condition	Good	
538139	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Bushings Connection/Risers	Good	
538140	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
538141	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
538142	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	General Comments		
538143	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
538144	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
538145	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	4R	
538146	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
538147	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
538148	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	5L	
538149	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
538150	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	General Comments		
538151	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Grounds in Place?	y	
538152	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
538153	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Paint Condition	Good	
538154	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Equipment Properly Labeled?	y	
538155	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
538156	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
538157	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
538158	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations A Ø	0	
538159	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations B Ø	0	
538160	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations C Ø	0	
538161	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations Ground	0	
538162	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Follow-up Action Required?	n	
538163	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Follow-up Action Required?	n	
538164	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Foundation Condition	Good	
538165	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	General Comments		
538166	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	General Comments		
538167	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Grounds in Place?	y	
538168	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Heaters (All) Functioning?	y	
538169	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Maintenance Operations	0	
538170	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Moisture and Leak Free?	y	
538171	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Operations Counter AF	143	
538172	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Operations Counter AL	143	
538173	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
538174	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Switching Operations	0	
538175	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Tank Paint Condition	Good	
538176	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Unknown Operations	0	
538177	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
538178	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
538179	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
538180	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	92377	
538181	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
538182	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
538183	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
538184	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
538185	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Tank Paint Condition	Good	
538186	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Switching Operations	0	
538187	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
538188	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
538189	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
538190	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
538191	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
538192	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
538193	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
538194	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Operations Counter AL	379	
538195	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Operations Counter AF	379	
538196	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Moisture and Leak Free?	y	
538197	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Maintenance Operations	0	
538198	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Heaters (All) Functioning?	y	
538199	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Grounds in Place?	y	
538200	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	General Comments		
538201	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
538202	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
538203	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	General Comments		
538204	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Foundation Condition	Good	
538205	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Follow-up Action Required?	n	
538206	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Follow-up Action Required?	n	
538207	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Operations Ground	0	
538208	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Operations C Ø	0	
538209	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Operations B Ø	0	
538210	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Operations A Ø	0	
538211	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
538212	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
538213	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
538214	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Paint Condition	Good	
538215	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Equipment Properly Labeled?	y	
538216	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
538217	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
538218	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
538219	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations A Ø	0	
538220	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	9 Month Operations	26	
538221	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
538222	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
538223	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
538224	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Amps A Ø	43.0	
538225	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Amps B Ø	45.0	
538226	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Amps C Ø	35.0	
538227	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Bushing Condition	Good	
538228	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Bushings Connection/Risers	Good	
538229	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
538230	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
538231	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
538232	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Cabinet Paint Condition	Good	
538233	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Equipment Properly Labeled?	y	
538234	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
538235	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
538236	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
538237	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
538238	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
538239	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
538240	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Totalizer Meter Reading	.8700	
538241	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Winding Temp Max	50	°C
538242	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Winding Temp Present	45	°C
538243	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
538244	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
538245	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
538246	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
538247	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
538248	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations C Ø	0	
538249	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations Ground	0	
538250	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Follow-up Action Required?	n	
538251	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Follow-up Action Required?	n	
538252	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
538253	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
538254	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
538255	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Operating Linkage OK?	n	
538256	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
538257	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
538258	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
538259	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
538260	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	General Comments	1911 transfer switch will not close. its in a bind	
538261	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
538262	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
538263	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Foundation Condition	Good	
538264	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Follow-up Action Required?	y	
538265	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
538266	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Foundation Condition	Good	
538267	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	General Comments		
538268	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	General Comments		
538269	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Grounds in Place?	y	
538270	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
538271	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
538272	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
538273	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
538274	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
538275	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	9 Month Operations	4	
538276	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Accumulated Fault Duty A Ph V	5.61	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
538277	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Accumulated Fault Duty B Ph V	5.61	%
538278	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Accumulated Fault Duty C Ph V	5.61	%
538279	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Amps A Ø	80.0	
538280	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Amps B Ø	93.0	
538281	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Amps C Ø	84.0	
538282	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Bushing Condition	Good	
538283	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
538284	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Bushings Connection/Risers	Good	
538285	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Unknown Operations	0	
538286	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	General Comments		
538287	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
538288	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
538289	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Accumulated Fault Duty C Ph V	.96	%
538290	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Accumulated Fault Duty B Ph V	1.43	%
538291	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
538292	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Amps A Ø	24.0	
538293	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Amps B Ø	37.0	
538294	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Amps C Ø	40.0	
538295	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Bushing Condition	Good	
538296	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Bushings Connection/Risers	Good	
538297	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
538298	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Accumulated Fault Duty A Ph V	.96	%
538299	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	9 Month Operations	25	
538300	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
538301	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
538302	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
538303	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
538304	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
538305	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
538306	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Paint Condition	Good	
538307	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Equipment Properly Labeled?	y	
538308	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
538309	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1R	
538310	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
538311	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
538312	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
538313	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
538314	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Adjusted Amps A Phase V	4.44	
538315	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
538316	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
538317	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
538318	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	4R	
538319	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
538320	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
538321	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
538322	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations A Ø	1	
538323	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations B Ø	0	
538324	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations C Ø	0	
538325	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations Ground	0	
538326	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Follow-up Action Required?	n	
538327	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Follow-up Action Required?	n	
538328	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Foundation Condition	Good	
538329	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	General Comments		
538330	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	General Comments		
538331	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Grounds in Place?	y	
538332	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Maintenance Operations	0	
538333	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Moisture and Leak Free?	y	
538334	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Operations Counter AF	178	
538335	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Operations Counter AL	178	
538336	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Switching Operations	2	
538337	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Tank Paint Condition	Good	
538338	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Unknown Operations	0	
538339	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	9 Month Operations	34	
538340	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Accumulated Fault Duty A Ph V	.66	%
538341	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Accumulated Fault Duty B Ph V	.33	%
538342	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
538343	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
538344	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
538345	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations A Ø	0	
538346	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations B Ø	0	
538347	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations C Ø	0	
538348	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations Ground	0	
538349	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Follow-up Action Required?	n	
538350	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Follow-up Action Required?	n	
538351	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
538352	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	General Comments		
538353	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	General Comments		
538354	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Grounds in Place?	y	
538355	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Maintenance Operations	0	
538356	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Moisture and Leak Free?	y	
538357	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Operations Counter AF	137	
538358	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Operations Counter AL	137	
538359	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Switching Operations	2	
538360	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Tank Paint Condition	Good	
538361	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Unknown Operations	0	
538362	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations B Ø	0	
538363	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations C Ø	0	
538364	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations Ground	0	
538365	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Follow-up Action Required?	n	
538366	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Follow-up Action Required?	n	
538367	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Foundation Condition	Good	
538368	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
538369	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
538370	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
538371	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Equipment Properly Labeled?	y	
538372	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Cabinet Paint Condition	Good	
538373	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
538374	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
538375	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Tank Leaks	None	
538376	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
538377	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
538378	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
538379	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
538380	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
538381	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
538382	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Regulator As Left Counter	29362	
538383	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
538384	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
538385	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
538386	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
538387	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
538388	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
538389	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Bushings Connection/Risers	Good	
538390	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Bushing Condition	Good	
538391	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Amps C Ø	60.0	
538392	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	9 Month Operations	35	
538393	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Amps B Ø	61.0	
538394	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Amps A Ø	59.0	
538395	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Accumulated Fault Duty A Ph V	.66	%
538396	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
538397	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
538398	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
538399	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
538400	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
538401	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
538402	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
538403	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
538404	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.400	millivolts
538405	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	136.1	VDC
538406	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
538407	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	136.1	VDC
538408	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
538409	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
538410	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
538411	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
538412	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
538413	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
538414	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
538415	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
538416	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
538417	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
538418	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
538419	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
538420	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	General Comments		
538421	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
538422	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Max Tap Position	12R	
538423	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
538424	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
538425	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
538426	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
538427	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
538428	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
538429	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
538430	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Regulator As Left Counter	15406	
538431	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
538432	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
538433	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Tank Leaks	None	
538434	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
538435	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
538436	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	Reset Tap Drag Hands	Reset	
538437	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
538438	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC Operations Since Last Insp	15	
538439	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
538440	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
538441	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
538442	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
538443	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
538444	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Current Tap Position	3R	
538445	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
538446	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
538447	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
538448	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	General Comments		
538449	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
538450	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
538451	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	General Comments		
538452	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
538453	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
538454	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Maintenance Operations	0	
538455	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
538456	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BAT000594	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
538457	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BAT000594	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	32	°F
538458	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BAT000594	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
538459	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BAT000594	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
538460	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BAT000594	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
538461	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BAT000594	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
538462	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BAT000594	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
538463	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BAT000594	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
538464	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BAT000594	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
538465	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BAT000594	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
538466	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
538467	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
538468	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
538469	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
538470	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.1	VDC
538471	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.1	VDC
538472	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
538473	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
538474	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BAT000594	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
538475	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BAT000594	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
538476	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BAT000594	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
538477	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BAT000594	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
538478	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
538479	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
538480	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
538481	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	170	
538482	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Oil Temp Max	60	°C
538483	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Oil Temp Present	30	°C
538484	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
538485	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
538486	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
538487	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	174	
538488	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
538489	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
538490	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
538491	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
538492	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
538493	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
538494	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
538495	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
538496	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
538497	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
538498	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
538499	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
538500	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
538501	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Totalizer Meter Reading	.9582	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
538502	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
538503	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
538504	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
538505	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
538506	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Regulator As Left Counter	16323	
538507	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
538508	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
538509	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Tank Leaks	None	
538510	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
538511	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC Min Tap Position	4R	
538512	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC Max Tap Position	7R	
538513	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC Current Tap Position	5R	
538514	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
538515	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC As Left Counter	121443	
538516	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC As Found Counter	121443	
538517	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	General Comments		
538518	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	General Comments		
538519	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
538520	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	Follow-up Action Required?	n	
538521	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
538522	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
538523	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
538524	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
538525	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
538526	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
538527	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Follow-up Action Required?	n	
538528	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
538529	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
538530	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	General Comments		
538531	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	General Comments		
538532	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
538533	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	LTC Totalizer Reading	6359.04	kw
538534	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
538535	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
538536	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Oil Temp Max	65	°C
538537	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Oil Temp Present	40	°C
538538	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
538539	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
538540	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
538541	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
538542	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
538543	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
538544	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
538545	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
538546	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
538547	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Totalizer Meter Reading	.6624	
538548	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
538549	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
538550	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
538551	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
538552	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
538553	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
538554	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
538555	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
538556	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	General Comments		
538557	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
538558	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
538559	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Min Tap Position	8R	
538560	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
538561	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
538562	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
538563	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
538564	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
538565	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
538566	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
538567	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Tank Leaks	None	
538568	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
538569	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
538570	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Regulator As Left Counter	321024	
538571	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
538572	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
538573	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
538574	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
538575	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
538576	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Min Tap Position	11L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
538577	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Max Tap Position	5L	
538578	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
538579	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	General Comments		
538580	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
538581	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
538582	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
538583	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
538584	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
538585	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
538586	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
538587	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
538588	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
538589	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
538590	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	General Comments		
538591	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
538592	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
538593	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Clear of Trash?	y	
538594	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
538595	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
538596	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
538597	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
538598	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
538599	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	General Comments		
538600	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
538601	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
538602	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Vegetation	None	
538603	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
538604	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
538605	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
538606	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
538607	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
538608	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
538609	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
538610	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
538611	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
538612	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Amps A Ø	0.0	
538613	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Amps B Ø	0.0	
538614	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Amps C Ø	0.0	
538615	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Bushing Condition	Good	
538616	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	360.0	
538617	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Totalizer Meter Reading	.8934	
538618	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	360.0	
538619	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	360.0	
538620	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
538621	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
538622	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
538623	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
538624	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
538625	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
538626	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
538627	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
538628	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
538629	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
538630	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
538631	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
538632	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
538633	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
538634	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
538635	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	General Comments		
538636	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
538637	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
538638	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
538639	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
538640	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
538641	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
538642	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
538643	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
538644	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
538645	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
538646	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
538647	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
538648	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
538649	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
538650	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	General Comments		
538651	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
538652	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
538653	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
538654	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
538655	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
538656	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
538657	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
538658	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
538659	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
538660	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
538661	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
538662	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
538663	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
538664	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
538665	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
538666	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	General Comments		
538667	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
538668	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
538669	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
538670	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
538671	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
538672	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
538673	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
538674	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
538675	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PF000271	PowerFuse	PI-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
538676	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PF000271	PowerFuse	PI-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
538677	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
538678	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PF000270	PowerFuse	PI-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
538679	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
538680	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
538681	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	PF000270	PowerFuse	PI-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
538682	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
538683	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
538684	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
538685	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
538686	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
538687	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
538688	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
538689	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Follow-up Action Required?	n	
538690	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
538691	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
538692	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
538693	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	General Comments		
538694	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	General Comments		
538695	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
538696	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	LTC Totalizer Reading	8576.64	kw
538697	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
538698	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
538699	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
538700	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
538701	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
538702	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Oil Temp Max	60	°C
538703	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Oil Temp Present	45	°C
538704	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
538705	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
538706	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
538707	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
538708	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
538709	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
538710	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
538711	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
538712	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
538713	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
538714	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
538715	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	9 Month Operations	2	
538716	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Accumulated Fault Duty A Ph V	13.78	%
538717	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Accumulated Fault Duty B Ph V	13.78	%
538718	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Accumulated Fault Duty C Ph V	3.06	%
538719	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
538720	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	66.5	VDC
538721	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
538722	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
538723	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
538724	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
538725	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
538726	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
538727	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
538728	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
538729	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Foundation Condition	Good	
538730	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
538731	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
538732	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	General Comments		
538733	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Operations A Ø	0	
538734	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Operations B Ø	0	
538735	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Operations C Ø	0	
538736	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Operations Ground	0	
538737	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
538738	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Follow-up Action Required?	n	
538739	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Follow-up Action Required?	n	
538740	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Foundation Condition	Good	
538741	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	General Comments		
538742	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	General Comments		
538743	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
538744	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
538745	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
538746	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
538747	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
538748	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
538749	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
538750	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
538751	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
538752	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
538753	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
538754	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
538755	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
538756	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
538757	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
538758	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Follow-up Action Required?	n	
538759	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
538760	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
538761	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	General Comments		
538762	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	General Comments		
538763	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
538764	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	LTC Totalizer Reading	4599.36	kw
538765	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
538766	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
538767	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Grounds in Place?	y	
538768	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
538769	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
538770	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
538771	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
538772	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
538773	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
538774	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
538775	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
538776	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
538777	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
538778	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
538779	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
538780	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	General Comments		
538781	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	General Comments	Bad Temp Gauge	
538782	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
538783	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
538784	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
538785	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
538786	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	Oil Temp Max	0	°C
538787	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	Oil Temp Present	0	°C
538788	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
538789	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
538790	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
538791	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
538792	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
538793	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
538794	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
538795	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
538796	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
538797	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
538798	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
538799	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	69.5	VDC
538800	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
538801	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
538802	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
538803	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
538804	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
538805	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
538806	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
538807	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	Oil Temp Present	15	°C
538808	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
538809	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
538810	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
538811	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
538812	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
538813	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
538814	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
538815	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
538816	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	General Comments		
538817	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	General Comments		
538818	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
538819	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
538820	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
538821	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
538822	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
538823	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
538824	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
538825	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
538826	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
538827	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
538828	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
538829	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
538830	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
538831	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
538832	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
538833	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Totalizer Meter Reading	.4854	
538834	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
538835	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
538836	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
538837	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
538838	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
538839	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
538840	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
538841	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
538842	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
538843	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
538844	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
538845	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	140	
538846	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Amps A Ø	33.0	
538847	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Amps B Ø	50.0	
538848	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Amps C Ø	37.9	
538849	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	145	
538850	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
538851	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
538852	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	102	
538853	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
538854	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
538855	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
538856	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	General Comments		
538857	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
538858	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
538859	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
538860	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
538861	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
538862	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
538863	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
538864	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
538865	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
538866	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
538867	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	General Comments		
538868	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
538869	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Trash Emptied?	y	
538870	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
538871	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
538872	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
538873	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Panels Dusted?	y	
538874	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
538875	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
538876	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
538877	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
538878	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	General Comments		
538879	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
538880	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
538881	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
538882	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
538883	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
538884	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Equipment Properly Labeled?	y	
538885	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BCH000479	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
538886	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BCH000479	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
538887	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BCH000479	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
538888	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BCH000479	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
538889	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BCH000479	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
538890	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BCH000479	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
538891	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Paint Condition	Good	
538892	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
538893	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
538894	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
538895	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Bushings Connection/Risers	Good	
538896	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Bushing Condition	Good	
538897	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Amps C Ø	175.0	
538898	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Amps B Ø	130.0	
538899	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Amps A Ø	130.0	
538900	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
538901	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
538902	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Accumulated Fault Duty A Ph V	.24	%
538903	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	9 Month Operations	10	
538904	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	Follow-up Action Required?	n	
538905	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
538906	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	General Comments		
538907	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	General Comments		
538908	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC As Found Counter	196337	
538909	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC As Left Counter	196337	
538910	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
538911	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Current Tap Position	8L	
538912	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Max Tap Position	3L	
538913	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Min Tap Position	8L	
538914	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
538915	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
538916	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
538917	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Follow-up Action Required?	n	
538918	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
538919	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
538920	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	General Comments		
538921	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	General Comments		
538922	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
538923	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	LTC Totalizer Reading	4659.84	kw
538924	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
538925	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
538926	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Oil Temp Max	55	°C
538927	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Oil Temp Present	45	°C
538928	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
538929	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
538930	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
538931	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
538932	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
538933	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Operations Since Last Insp	423	
538934	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations C Ø	0	
538935	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations Ground	0	
538936	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Follow-up Action Required?	n	
538937	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Follow-up Action Required?	n	
538938	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Foundation Condition	Good	
538939	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	General Comments		
538940	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	General Comments		
538941	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Grounds in Place?	y	
538942	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Heaters (All) Functioning?	y	
538943	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Maintenance Operations	0	
538944	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Moisture and Leak Free?	y	
538945	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Operations Counter AF	135	
538946	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Operations Counter AL	135	
538947	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Switching Operations	0	
538948	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Tank Paint Condition	Good	
538949	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Unknown Operations	0	
538950	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
538951	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
538952	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
538953	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
538954	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
538955	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
538956	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
538957	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
538958	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
538959	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
538960	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
538961	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
538962	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Follow-up Action Required?	n	
538963	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
538964	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
538965	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	General Comments		
538966	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	General Comments		
538967	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
538968	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	LTC Totalizer Reading	5731.20	kw
538969	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
538970	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Unknown Operations	0	
538971	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Operations Counter AL	269	
538972	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
538973	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Oil Temp Max	60	°C
538974	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Oil Temp Present	20	°C
538975	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
538976	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
538977	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
538978	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
538979	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
538980	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
538981	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
538982	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
538983	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Totalizer Meter Reading	.5970	
538984	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Operations Counter AF	269	
538985	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Moisture and Leak Free?	y	
538986	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Maintenance Operations	0	
538987	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Heaters (All) Functioning?	y	
538988	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
538989	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Floor Swept?	y	
538990	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
538991	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
538992	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Evidence of Insects	None	
538993	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
538994	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
538995	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
538996	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
538997	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Broom on Site?	y	
538998	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Basement Condition Acceptible	y	
538999	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
539000	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
539001	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
539002	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Clear of Trash?	y	
539003	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
539004	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
539005	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
539006	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
539007	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	LTCC000627	LTCControl	552-1	LTC Control Insp	VRR Time Delay	30	Seconds
539008	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	LTCC000627	LTCControl	552-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
539009	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	LTCC000627	LTCControl	552-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
539010	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	LTCC000627	LTCControl	552-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
539011	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	LTCC000627	LTCControl	552-1	LTC Control Insp	LTC Operation Checked?	y	
539012	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	LTCC000627	LTCControl	552-1	LTC Control Insp	General Comments		
539013	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	LTCC000627	LTCControl	552-1	LTC Control Insp	Follow-up Action Required?	n	
539014	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	LTCC000627	LTCControl	552-1	LTC Control Insp	All Connections OK?	y	
539015	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
539016	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
539017	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	General Comments		
539018	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
539019	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
539020	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Vegetation	None	
539021	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	9 Month Operations	2	
539022	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Accumulated Fault Duty A Ph V	2.80	%
539023	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Accumulated Fault Duty B Ph V	2.80	%
539024	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Accumulated Fault Duty C Ph V	1.87	%
539025	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Amps A Ø	150.0	
539026	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
539027	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
539028	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Amps B Ø	150.0	
539029	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Amps C Ø	150.0	
539030	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Bushing Condition	Good	
539031	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Bushings Connection/Risers	Good	
539032	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
539033	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
539034	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
539035	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Paint Condition	Good	
539036	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Equipment Properly Labeled?	y	
539037	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
539038	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
539039	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
539040	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations A Ø	0	
539041	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations B Ø	0	
539042	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
539043	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Switching Operations	1	
539044	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Tank Paint Condition	Good	
539045	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	LTC Operations Since Last Insp	0	
539046	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	LTC Current Tap Position	14R	
539047	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
539048	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	LTC As Left Counter	77072	
539049	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	LTC As Found Counter	77072	
539050	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	General Comments		
539051	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Unknown Operations	0	
539052	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
539053	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
539054	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
539055	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
539056	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	21.35	%
539057	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	21.35	%
539058	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	21.35	%
539059	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Amps A Ø	0.0	
539060	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Amps B Ø	0.0	
539061	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Amps C Ø	0.0	
539062	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
539063	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
539064	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
539065	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
539066	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
539067	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
539068	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
539069	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
539070	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
539071	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
539072	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
539073	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	General Comments		
539074	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	General Comments		
539075	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
539076	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	Follow-up Action Required?	n	
539077	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
539078	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
539079	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Operations Counter AF	284	
539080	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Operations Counter AL	284	
539081	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
539082	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
539083	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
539084	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
539085	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Readings	Winding Temp Present	42	°C
539086	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Readings	Winding Temp Max	42	°C
539087	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Readings	Totalizer Meter Reading	.5760	
539088	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
539089	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
539090	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
539091	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
539092	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
539093	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
539094	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
539095	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
539096	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Min Tap Position	1L	
539097	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
539098	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
539099	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
539100	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
539101	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
539102	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
539103	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
539104	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
539105	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	Changed float voltage	
539106	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
539107	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
539108	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
539109	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
539110	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
539111	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
539112	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	1.5	VDC
539113	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.1	VDC
539114	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
539115	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
539116	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
539117	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
539118	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
539119	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Foundation Condition	Good	
539120	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
539121	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
539122	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	General Comments		
539123	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
539124	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
539125	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
539126	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
539127	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
539128	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Regulator As Left Counter	13456	
539129	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
539130	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
539131	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Tank Leaks	None	
539132	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
539133	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
539134	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
539135	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
539136	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
539137	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
539138	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
539139	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
539140	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
539141	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
539142	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
539143	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
539144	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
539145	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
539146	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
539147	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Operations Counter AF	100	
539148	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Operations Counter AL	100	
539149	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
539150	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
539151	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
539152	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
539153	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
539154	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
539155	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
539156	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
539157	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
539158	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
539159	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
539160	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
539161	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	General Comments		
539162	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
539163	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
539164	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
539165	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
539166	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
539167	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
539168	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
539169	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
539170	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Regulator As Left Counter	11671	
539171	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
539172	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
539173	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Tank Leaks	None	
539174	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
539175	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
539176	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
539177	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
539178	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
539179	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
539180	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
539181	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Operations Counter AL	442	
539182	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	9 Month Operations	1	
539183	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Accumulated Fault Duty A Ph V	.47	%
539184	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
539185	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Operations Counter AF	438	
539186	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Moisture and Leak Free?	y	
539187	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Maintenance Operations	0	
539188	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Heaters (All) Functioning?	y	
539189	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Grounds in Place?	y	
539190	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	General Comments		
539191	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	General Comments		
539192	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Foundation Condition	Good	
539193	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Follow-up Action Required?	n	
539194	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Follow-up Action Required?	n	
539195	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations Ground	0	
539196	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations C Ø	0	
539197	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations B Ø	0	
539198	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations A Ø	0	
539199	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
539200	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
539201	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
539202	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
539203	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
539204	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Readings	Oil Temp Present	25	°C
539205	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Readings	Oil Temp Max	40	°C
539206	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
539207	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
539208	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Readings	LTC Totalizer Reading	10368.00	kw
539209	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
539210	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
539211	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
539212	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	General Comments		
539213	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Readings	General Comments		
539214	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	General Comments		
539215	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
539216	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
539217	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Readings	Follow-up Action Required?	n	
539218	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
539219	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
539220	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Unknown Operations	0	
539221	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Tank Paint Condition	Good	
539222	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Unknown Operations	0	
539223	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Tank Paint Condition	Good	
539224	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
539225	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	n	
539226	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
539227	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
539228	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
539229	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
539230	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
539231	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
539232	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
539233	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
539234	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
539235	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
539236	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
539237	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
539238	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	39	°F
539239	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
539240	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Positive DC Ground	17.3	VDC
539241	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
539242	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
539243	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Switching Operations	4	
539244	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Switching Operations	0	
539245	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
539246	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
539247	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
539248	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
539249	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
539250	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
539251	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	99975	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
539252	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	99975	
539253	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
539254	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
539255	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
539256	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
539257	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
539258	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
539259	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
539260	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
539261	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
539262	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations A Ø	0	
539263	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations B Ø	0	
539264	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations C Ø	0	
539265	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations Ground	0	
539266	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Follow-up Action Required?	n	
539267	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Follow-up Action Required?	n	
539268	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Foundation Condition	Good	
539269	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	General Comments		
539270	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	General Comments		
539271	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Grounds in Place?	y	
539272	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Heaters (All) Functioning?	y	
539273	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Maintenance Operations	0	
539274	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Moisture and Leak Free?	y	
539275	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Operations Counter AF	172	
539276	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Operations Counter AL	172	
539277	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
539278	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Switching Operations	0	
539279	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
539280	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
539281	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Oil Temp Present	20	°C
539282	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Oil Temp Max	35	°C
539283	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
539284	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
539285	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	LTC Totalizer Reading	6232.32	kw
539286	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
539287	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	General Comments		
539288	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Tank Paint Condition	Good	
539289	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Unknown Operations	0	
539290	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
539291	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Bushing Condition	Good	
539292	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
539293	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
539294	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
539295	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
539296	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
539297	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
539298	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	General Comments		
539299	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	General Comments		
539300	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
539301	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
539302	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
539303	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
539304	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
539305	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
539306	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
539307	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
539308	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
539309	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Fans Condition	Good	
539310	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
539311	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
539312	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Follow-up Action Required?	n	
539313	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Foundation Condition	Good	
539314	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
539315	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	General Comments	Needs nitrogen. 6 pack is empty and transformer is in vacuum.	
539316	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	General Comments	Not in Service	
539317	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Grounds in Place?	y	
539318	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
539319	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
539320	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
539321	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Oil Temp Max	35	°C
539322	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Oil Temp Present	30	°C
539323	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Percent Thermal Load B Ø Max	0	%
539324	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Pumps Condition	Good	
539325	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Pumps Operational?	y	
539326	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
539327	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Radiator Leaks	None	
539328	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
539329	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
539330	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Tank Leaks	None	
539331	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
539332	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
539333	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
539334	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
539335	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
539336	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
539337	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
539338	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
539339	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
539340	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
539341	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
539342	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	General Comments		
539343	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
539344	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
539345	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
539346	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
539347	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
539348	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
539349	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
539350	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
539351	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
539352	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
539353	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
539354	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
539355	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Winding Temp Present	10	°C
539356	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Winding Temp Max	35	°C
539357	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Totalizer Meter Reading	.6492	
539358	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
539359	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
539360	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
539361	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
539362	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Paint Condition	Good	
539363	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Equipment Properly Labeled?	y	
539364	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
539365	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
539366	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	General Comments		
539367	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
539368	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	General Comments		
539369	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	General Comments		
539370	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Grounds in Place?	y	
539371	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
539372	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	Oil Temp Max	50	°C
539373	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
539374	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Radiator Leaks	None	
539375	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
539376	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
539377	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Tank Leaks	None	
539378	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
539379	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
539380	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
539381	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
539382	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
539383	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
539384	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
539385	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
539386	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
539387	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
539388	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
539389	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
539390	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
539391	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
539392	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
539393	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
539394	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
539395	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
539396	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
539397	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Follow-up Action Required?	n	
539398	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
539399	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
539400	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
539401	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
539402	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
539403	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
539404	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Fault Operations	0	
539405	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
539406	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
539407	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
539408	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
539409	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
539410	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
539411	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Bushing Oil Level	Good	
539412	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Bushing Condition	Good	
539413	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Amps C Ø	0.0	
539414	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Amps B Ø	0.0	
539415	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Amps A Ø	0.0	
539416	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
539417	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Air Pressure OK?	y	
539418	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Fans Operational?	y	
539419	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
539420	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	Follow-up Action Required?	n	
539421	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Foundation Condition	Good	
539422	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
539423	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Follow-up Action Required?	n	
539424	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
539425	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
539426	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
539427	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
539428	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
539429	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
539430	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Unknown Operations	0	
539431	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Tank Paint Condition	Good	
539432	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Tank Leaks	None	
539433	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
539434	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
539435	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
539436	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Switching Operations	0	
539437	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
539438	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Operations Counter AL	1405	
539439	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Operations Counter AF	1405	
539440	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Number of Ops last 9 Months	1	
539441	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
539442	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Maintenance Operations	0	
539443	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Grounds in Place?	y	
539444	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	General Comments		
539445	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	General Comments		
539446	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
539447	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Foundation Condition	Good	
539448	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Follow-up Action Required?	n	
539449	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Follow-up Action Required?	n	
539450	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
539451	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
539452	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
539453	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
539454	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
539455	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
539456	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	General Comments		
539457	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
539458	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
539459	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Foundation Condition	Good	
539460	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
539461	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
539462	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
539463	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
539464	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
539465	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
539466	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
539467	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
539468	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
539469	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
539470	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
539471	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
539472	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
539473	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
539474	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
539475	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
539476	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Clear of Trash?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
539477	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
539478	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
539479	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
539480	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
539481	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
539482	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
539483	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
539484	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
539485	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
539486	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
539487	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
539488	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
539489	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
539490	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
539491	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
539492	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
539493	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	General Comments		
539494	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
539495	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Equipment Properly Labeled?	y	
539496	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Paint Condition	Good	
539497	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
539498	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
539499	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
539500	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Bushings Connection/Risers	Good	
539501	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Bushing Condition	Good	
539502	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
539503	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
539504	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Amps C Ø	187.0	
539505	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.2	VDC
539506	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Bushing Condition	Good	
539507	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
539508	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
539509	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
539510	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
539511	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
539512	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
539513	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
539514	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
539515	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Fans Condition	Good	
539516	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Fans Operational?	y	
539517	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.7	VDC
539518	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
539519	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
539520	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
539521	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
539522	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
539523	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
539524	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
539525	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
539526	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
539527	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	General Comments		
539528	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
539529	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
539530	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
539531	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
539532	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
539533	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
539534	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
539535	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
539536	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
539537	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	119	
539538	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
539539	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
539540	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
539541	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	119	
539542	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
539543	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
539544	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
539545	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
539546	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
539547	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
539548	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
539549	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
539550	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
539551	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
539552	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
539553	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
539554	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
539555	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
539556	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
539557	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
539558	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
539559	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
539560	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
539561	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Foundation Condition	Good	
539562	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Follow-up Action Required?	n	
539563	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Follow-up Action Required?	n	
539564	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations Ground	0	
539565	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations C Ø	0	
539566	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations B Ø	0	
539567	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
539568	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
539569	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations A Ø	0	
539570	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
539571	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
539572	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
539573	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
539574	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Vegetation	None	
539575	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
539576	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	General Comments		
539577	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
539578	3/7/2019 13:45	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
539579	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Amps C Ø	121.0	
539580	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Amps B Ø	120.0	
539581	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Amps A Ø	110.0	
539582	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
539583	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Accumulated Fault Duty B Ph V	1.03	%
539584	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Accumulated Fault Duty A Ph V	2.06	%
539585	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	9 Month Operations	28	
539586	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
539587	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	General Comments		
539588	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
539589	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
539590	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
539591	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
539592	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Equipment Properly Labeled?	y	
539593	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
539594	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	General Comments		
539595	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
539596	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
539597	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations A Ø	0	
539598	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations B Ø	0	
539599	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations C Ø	0	
539600	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	General Comments		
539601	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC As Found Counter	263	
539602	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC As Left Counter	267	
539603	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
539604	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Current Tap Position	9L	
539605	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Max Tap Position	8L	
539606	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Min Tap Position	13L	
539607	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
539608	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
539609	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
539610	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
539611	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations Ground	0	
539612	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Follow-up Action Required?	n	
539613	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Follow-up Action Required?	n	
539614	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Foundation Condition	Good	
539615	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	General Comments		
539616	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	General Comments		
539617	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Grounds in Place?	y	
539618	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Heaters (All) Functioning?	y	
539619	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Maintenance Operations	0	
539620	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BCH000477	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
539621	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BCH000477	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
539622	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BCH000477	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
539623	3/7/2019 13:02	Distribution	Falmouth Quarterly Inspection	BCH000477	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
539624	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Moisture and Leak Free?	y	
539625	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Operations Counter AF	454	
539626	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Operations Counter AL	459	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
539627	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
539628	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Switching Operations	5	
539629	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Tank Paint Condition	Good	
539630	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Unknown Operations	0	
539631	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
539632	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
539633	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
539634	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Amps B Ø	234.0	
539635	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Amps A Ø	244.0	
539636	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
539637	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	VRR Time Delay	30	Seconds
539638	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
539639	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
539640	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
539641	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
539642	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	9 Month Operations	4	
539643	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Heaters (All) Functioning?	y	
539644	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Maintenance Operations	0	
539645	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Moisture and Leak Free?	y	
539646	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Operations Counter AF	168	
539647	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Operations Counter AL	168	
539648	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
539649	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Switching Operations	0	
539650	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Tank Paint Condition	Good	
539651	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Unknown Operations	0	
539652	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	General Comments		
539653	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	Follow-up Action Required?	n	
539654	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	General Comments		
539655	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Foundation Condition	Good	
539656	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Follow-up Action Required?	n	
539657	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Follow-up Action Required?	n	
539658	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations Ground	0	
539659	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
539660	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
539661	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
539662	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Operations Since Last Insp	319	
539663	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Min Tap Position	10L	
539664	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Max Tap Position	5L	
539665	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Current Tap Position	7L	
539666	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
539667	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC As Left Counter	38314	
539668	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC As Found Counter	38305	
539669	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	General Comments		
539670	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	General Comments		
539671	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
539672	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	Follow-up Action Required?	n	
539673	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations C Ø	0	
539674	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations B Ø	0	
539675	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations A Ø	0	
539676	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
539677	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
539678	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
539679	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Equipment Properly Labeled?	y	
539680	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Paint Condition	Good	
539681	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
539682	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
539683	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
539684	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Bushings Connection/Risers	Good	
539685	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Bushing Condition	Good	
539686	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
539687	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
539688	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Ambient Temp	23	°F
539689	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
539690	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
539691	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Clear of Trash?	y	
539692	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
539693	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
539694	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
539695	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
539696	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
539697	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
539698	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	General Comments		
539699	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
539700	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
539701	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Vegetation	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
539702	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
539703	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
539704	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
539705	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
539706	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	General Comments		
539707	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Amps C Ø	55.0	
539708	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Amps B Ø	58.0	
539709	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Amps A Ø	46.0	
539710	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Switching Operations	0	
539711	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
539712	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Operations Counter AL	99842	
539713	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Operations Counter AF	99842	
539714	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
539715	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Tank Leaks	None	
539716	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
539717	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
539718	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Regulator As Left Counter	5851	
539719	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
539720	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
539721	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
539722	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
539723	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Vegetation	None	
539724	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
539725	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
539726	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
539727	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
539728	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
539729	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
539730	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Maintenance Operations	0	
539731	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
539732	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Grounds in Place?	y	
539733	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	General Comments		
539734	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	General Comments		
539735	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Foundation Condition	Good	
539736	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Follow-up Action Required?	n	
539737	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Follow-up Action Required?	n	
539738	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations Ground	0	
539739	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	General Comments		
539740	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	General Comments		
539741	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
539742	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
539743	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
539744	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
539745	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
539746	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
539747	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
539748	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
539749	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
539750	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
539751	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
539752	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
539753	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
539754	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
539755	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
539756	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
539757	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
539758	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	43	°F
539759	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
539760	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
539761	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Unknown Operations	0	
539762	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	45	°C
539763	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	25	°C
539764	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
539765	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
539766	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
539767	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
539768	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
539769	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
539770	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
539771	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
539772	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	9 Month Operations	1	
539773	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
539774	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
539775	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
539776	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Reading	.1794	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
539777	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
539778	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
539779	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
539780	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Tank Leaks	None	
539781	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
539782	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Operations Counter	48	
539783	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
539784	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
539785	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	General Comments	changed battery	
539786	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
539787	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
539788	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
539789	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
539790	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
539791	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
539792	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
539793	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
539794	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
539795	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
539796	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
539797	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
539798	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
539799	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
539800	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
539801	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
539802	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
539803	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	General Comments	ok	
539804	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
539805	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
539806	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
539807	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
539808	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
539809	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
539810	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
539811	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
539812	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Regulator As Left Counter	28417	
539813	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
539814	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
539815	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Tank Leaks	None	
539816	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
539817	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	122.3	VAC
539818	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
539819	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	122.0	VAC
539820	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	122.0	VAC
539821	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
539822	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
539823	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
539824	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
539825	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
539826	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Tank Leaks	None	
539827	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
539828	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	9 Month Operations	5	
539829	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Accumulated Fault Duty A Ph V	25.85	%
539830	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Accumulated Fault Duty B Ph V	19.38	%
539831	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Accumulated Fault Duty C Ph V	19.38	%
539832	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Amps A Ø	10.0	
539833	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Amps B Ø	50.0	
539834	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Amps C Ø	50.0	
539835	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Bushing Condition	Good	
539836	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Bushings Connection/Risers	Good	
539837	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
539838	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
539839	3/7/2019 9:36	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
539840	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
539841	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
539842	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
539843	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
539844	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
539845	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
539846	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Min Tap Position	4L	
539847	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Max Tap Position	4R	
539848	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
539849	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
539850	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
539851	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
539852	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
539853	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
539854	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Clear of Trash?	y	
539855	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
539856	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
539857	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
539858	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
539859	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
539860	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
539861	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
539862	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
539863	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
539864	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
539865	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations C Ø	0	
539866	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations B Ø	0	
539867	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations A Ø	0	
539868	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
539869	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
539870	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
539871	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
539872	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
539873	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
539874	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
539875	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
539876	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
539877	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
539878	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
539879	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
539880	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
539881	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	General Comments		
539882	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	General Comments	ok	
539883	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
539884	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
539885	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
539886	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
539887	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	117.50	
539888	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
539889	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	Oil Temp Max	57	°C
539890	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	Oil Temp Present	26	°C
539891	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
539892	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
539893	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
539894	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
539895	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
539896	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
539897	3/7/2019 14:31	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
539898	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
539899	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	General Comments		
539900	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
539901	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
539902	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
539903	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
539904	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
539905	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
539906	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
539907	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
539908	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Foundation Condition	Good	
539909	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
539910	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
539911	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	General Comments		
539912	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
539913	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
539914	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
539915	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
539916	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
539917	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
539918	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
539919	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Clear of Trash?	y	
539920	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
539921	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
539922	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
539923	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
539924	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
539925	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
539926	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Ambient Temp	35	°F

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
539927	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
539928	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Unknown Operations	0	
539929	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Tank Paint Condition	Good	
539930	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
539931	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Switching Operations	0	
539932	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
539933	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Operations Counter AL	171	
539934	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Operations Counter AF	171	
539935	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Moisture and Leak Free?	y	
539936	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Maintenance Operations	0	
539937	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Heaters (All) Functioning?	y	
539938	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Grounds in Place?	y	
539939	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
539940	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
539941	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
539942	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	General Comments		
539943	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	General Comments		
539944	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Foundation Condition	Good	
539945	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Follow-up Action Required?	n	
539946	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Follow-up Action Required?	n	
539947	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations Ground	0	
539948	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations C Ø	0	
539949	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations B Ø	0	
539950	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations A Ø	0	
539951	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
539952	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Operations Counter AF	350	
539953	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Number of Ops last 9 Months	10	
539954	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
539955	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Air Leaks	None	
539956	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
539957	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Unknown Operations	0	
539958	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank Paint Condition	Good	
539959	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank Leaks	None	
539960	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
539961	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
539962	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
539963	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
539964	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Vegetation	None	
539965	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
539966	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
539967	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
539968	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	General Comments		
539969	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
539970	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
539971	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
539972	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
539973	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
539974	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	General Comments		
539975	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	General Comments		
539976	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
539977	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
539978	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
539979	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	LTC Totalizer Reading	2384.64	kw
539980	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
539981	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
539982	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Oil Temp Max	75	°C
539983	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Oil Temp Present	25	°C
539984	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
539985	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
539986	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
539987	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
539988	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
539989	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
539990	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
539991	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Vegetation	None	
539992	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
539993	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
539994	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
539995	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	General Comments		
539996	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
539997	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
539998	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
539999	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
540000	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
540001	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
S40002	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Clear of Trash?	y	
S40003	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
S40004	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
S40005	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Switching Operations	0	
S40006	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
S40007	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2019-03-07 00:00:00.000000	
S40008	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Operations Counter AL	350	
S40009	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
S40010	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Bushings Connection/Risers	Good	
S40011	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Bushing Condition	Good	
S40012	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Amps C Ø	59.0	
S40013	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	All Connections OK?	y	
S40014	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	Follow-up Action Required?	n	
S40015	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	General Comments		
S40016	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	LTC Operation Checked?	y	
S40017	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	LTC Output Voltage Level	125.2	VAC
S40018	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
S40019	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
S40020	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
S40021	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
S40022	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
S40023	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
S40024	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
S40025	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
S40026	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
S40027	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
S40028	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
S40029	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
S40030	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
S40031	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	General Comments		
S40032	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
S40033	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
S40034	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Foundation Condition	Good	
S40035	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
S40036	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
S40037	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
S40038	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
S40039	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
S40040	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
S40041	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	VRR Time Delay	30	Seconds
S40042	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
S40043	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
S40044	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	General Comments		
S40045	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
S40046	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
S40047	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
S40048	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
S40049	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
S40050	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
S40051	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	LTC Totalizer Reading	861.12	kw
S40052	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
S40053	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
S40054	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
S40055	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	28.7	VDC
S40056	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	29.3	VDC
S40057	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
S40058	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
S40059	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
S40060	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Amps B Ø	54.0	
S40061	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Amps A Ø	64.0	
S40062	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
S40063	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Maintenance Operations	0	
S40064	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Heaters (All) Functioning?	y	
S40065	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Grounds in Place?	y	
S40066	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	General Comments		
S40067	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	General Comments		
S40068	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
S40069	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Foundation Condition	Good	
S40070	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Follow-up Action Required?	n	
S40071	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Follow-up Action Required?	n	
S40072	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Fault Operations	0	
S40073	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
S40074	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
S40075	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
S40076	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
S40077	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
S40078	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
S40079	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Bushing Oil Level	Good	
S40080	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Bushing Condition	Good	
S40081	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
S40082	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
S40083	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
S40084	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
S40085	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Totalizer Meter Reading	.4968	
S40086	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
S40087	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
S40088	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
S40089	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
S40090	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Pressure OK?	y	
S40091	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Leaks	None	
S40092	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
S40093	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
S40094	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
S40095	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
S40096	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
S40097	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
S40098	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
S40099	3/7/2019 9:48	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
S40100	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
S40101	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
S40102	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
S40103	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
S40104	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
S40105	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
S40106	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
S40107	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
S40108	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
S40109	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
S40110	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
S40111	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
S40112	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
S40113	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Equipment Properly Labeled?	y	
S40114	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Paint Condition	Good	
S40115	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
S40116	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
S40117	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
S40118	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	7.300	millivolts
S40119	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
S40120	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
S40121	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
S40122	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
S40123	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	General Comments		
S40124	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
S40125	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
S40126	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Dry Cell Battery Install Date	2018-03-08 00:00:00.000000	
S40127	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
S40128	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
S40129	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
S40130	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
S40131	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
S40132	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
S40133	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	26.7	VDC
S40134	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	.7	AMPS
S40135	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
S40136	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
S40137	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
S40138	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	General Comments		
S40139	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
S40140	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
S40141	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Amps C Ø	250.0	
S40142	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Amps B Ø	250.0	
S40143	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
S40144	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
S40145	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
S40146	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
S40147	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
S40148	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
S40149	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Amps A Ø	190.0	
S40150	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
S40151	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
S40152	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
S40153	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
S40154	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
S40155	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
S40156	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Vegetation	None	
S40157	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
S40158	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
S40159	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
S40160	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
S40161	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
S40162	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
S40163	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
S40164	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	General Comments		
S40165	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	9 Months Operations	15	
S40166	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
S40167	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
S40168	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
S40169	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
S40170	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Tank Leaks	None	
S40171	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
S40172	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
S40173	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Regulator As Left Counter	26361	
S40174	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
S40175	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
S40176	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
S40177	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
S40178	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
S40179	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	VRR Time Delay	30	Seconds
S40180	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
S40181	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Min Tap Position	2R	
S40182	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Max Tap Position	11L	
S40183	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
S40184	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
S40185	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
S40186	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Operations Since Last Insp	407	
S40187	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
S40188	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
S40189	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	General Comments		
S40190	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
S40191	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
S40192	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
S40193	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
S40194	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	LTC Operation Checked?	y	
S40195	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	General Comments		
S40196	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	Follow-up Action Required?	n	
S40197	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
S40198	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
S40199	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
S40200	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
S40201	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
S40202	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
S40203	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
S40204	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
S40205	3/7/2019 13:21	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	All Connections OK?	y	
S40206	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
S40207	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
S40208	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
S40209	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
S40210	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
S40211	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Foundation Condition	Good	
S40212	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
S40213	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
S40214	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
S40215	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
S40216	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
S40217	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
S40218	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	General Comments		
S40219	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
S40220	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
S40221	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
S40222	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
S40223	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Paint Condition	Good	
S40224	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Equipment Properly Labeled?	y	
S40225	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
S40226	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
S40227	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
S40228	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations A Ø	0	
S40229	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations B Ø	0	
S40230	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations C Ø	0	
S40231	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations Ground	0	
S40232	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Follow-up Action Required?	n	
S40233	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Follow-up Action Required?	n	
S40234	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	General Comments		
S40235	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
S40236	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
S40237	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
S40238	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
S40239	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.000	millivolts
S40240	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
S40241	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	General Comments		
S40242	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
S40243	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
S40244	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
S40245	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
S40246	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
S40247	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
S40248	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
S40249	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
S40250	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
S40251	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
S40252	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
S40253	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
S40254	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
S40255	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
S40256	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
S40257	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
S40258	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
S40259	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
S40260	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
S40261	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
S40262	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
S40263	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
S40264	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
S40265	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
S40266	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
S40267	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	General Comments		
S40268	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
S40269	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
S40270	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Foundation Condition	Good	
S40271	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
S40272	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
S40273	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
S40274	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
S40275	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
S40276	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
S40277	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
S40278	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	Follow-up Action Required?	n	
S40279	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
S40280	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	General Comments		
S40281	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	General Comments		
S40282	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC As Found Counter	4584	
S40283	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC As Left Counter	4584	
S40284	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
S40285	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Current Tap Position	4L	
S40286	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Max Tap Position	4L	
S40287	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Min Tap Position	8L	
S40288	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
S40289	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Min Tap Position	11L	
S40290	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Operations Since Last Insp	336	
S40291	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
S40292	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
S40293	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
S40294	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Max Tap Position	4L	
S40295	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Current Tap Position	5L	
S40296	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
S40297	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC As Left Counter	69745	
S40298	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC As Found Counter	69745	
S40299	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	General Comments		
S40300	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	General Comments		
S40301	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
S40302	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	Follow-up Action Required?	n	
S40303	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	9 Month Operations	8	
S40304	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
S40305	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
S40306	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
S40307	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Amps A Ø	60.0	
S40308	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Amps B Ø	60.0	
S40309	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Amps C Ø	60.0	
S40310	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Bushing Condition	Good	
S40311	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Bushings Connection/Risers	Good	
S40312	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
S40313	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
S40314	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Foundation Condition	Good	
S40315	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
S40316	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
S40317	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
S40318	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
S40319	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	General Comments		
S40320	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
S40321	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
S40322	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LTCC000585	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
S40323	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LTCC000585	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
S40324	3/7/2019 11:07	Distribution	Cane Run Generating Quarterly Inspection	LTCC000585	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
S40325	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
S40326	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	General Comments		
S40327	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
S40328	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
S40329	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
S40330	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Maintenance Operations	0	
S40331	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
S40332	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
S40333	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
S40334	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
S40335	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
S40336	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	General Comments		
S40337	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	General Comments		
S40338	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
S40339	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
S40340	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Follow-up Action Required?	n	
S40341	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
S40342	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
S40343	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
S40344	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations Ground	0	
S40345	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations C Ø	0	
S40346	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations B Ø	0	
S40347	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Operations A Ø	0	
S40348	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Operations B Ø	0	
S40349	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
S40350	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Totalizer Meter Reading	2.4372	
S40351	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations A Ø	0	
S40352	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
S40353	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Operations C Ø	0	
S40354	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Operations Ground	0	
S40355	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Follow-up Action Required?	n	
S40356	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Follow-up Action Required?	n	
S40357	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
S40358	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
S40359	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
S40360	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
S40361	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Foundation Condition	Good	
S40362	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	General Comments		
S40363	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	General Comments		
S40364	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Grounds in Place?	y	
S40365	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
S40366	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
S40367	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
S40368	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
S40369	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
S40370	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Maintenance Operations	0	
S40371	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
S40372	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
S40373	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
S40374	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
S40375	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	General Comments		
S40376	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
S40377	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
S40378	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
S40379	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
S40380	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
S40381	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	12009.60	kw
S40382	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
S40383	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Switching Operations	0	
S40384	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Tank Paint Condition	Good	
S40385	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Unknown Operations	0	
S40386	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Follow-up Action Required?	n	
S40387	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations Ground	0	
S40388	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations C Ø	0	
S40389	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations B Ø	0	
S40390	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations A Ø	0	
S40391	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Adjusted Amps C Phase V	12.58	
S40392	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Adjusted Amps B Phase V	12.58	
S40393	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Adjusted Amps A Phase V	12.58	
S40394	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Equipment Properly Labeled?	y	
S40395	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Paint Condition	Good	
S40396	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
S40397	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
S40398	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
S40399	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Bushings Connection/Risers	Good	
S40400	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Bushing Condition	Good	
S40401	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Amps C Ø	100.0	
S40402	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Amps B Ø	110.0	
S40403	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Amps A Ø	120.0	
S40404	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Accumulated Fault Duty C Ph V	1.25	%
S40405	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Accumulated Fault Duty B Ph V	1.25	%
S40406	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Accumulated Fault Duty A Ph V	.94	%
S40407	3/7/2019 10:43	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	9 Month Operations	6	
S40408	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Maintenance Operations	0	
S40409	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	9 Month Operations	9	
S40410	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Accumulated Fault Duty A Ph V	3.20	%
S40411	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Accumulated Fault Duty B Ph V	2.28	%
S40412	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Accumulated Fault Duty C Ph V	1.83	%
S40413	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Amps A Ø	120.0	
S40414	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Amps B Ø	120.0	
S40415	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Amps C Ø	96.0	
S40416	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Bushing Condition	Good	
S40417	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Bushings Connection/Risers	Good	
S40418	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
S40419	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
S40420	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
S40421	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Moisture and Leak Free?	y	
S40422	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Operations Counter AF	182	
S40423	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Operations Counter AL	182	
S40424	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Switching Operations	0	
S40425	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Unknown Operations	0	
S40426	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Switching Operations	0	
S40427	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Operations Counter AL	353	
S40428	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Operations Counter AF	353	
S40429	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Tank Paint Condition	Good	
S40430	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Unknown Operations	0	
S40431	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
S40432	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
S40433	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
S40434	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
S40435	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Amps B Ø	30.0	
S40436	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Amps C Ø	20.0	
S40437	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	General Comments		
S40438	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Grounds in Place?	y	
S40439	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	61.00	
S40440	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5849.28	kw
S40441	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
S40442	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
S40443	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
S40444	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	General Comments		
S40445	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	General Comments		
S40446	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
S40447	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Heaters (All) Functioning?	y	
S40448	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
S40449	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Maintenance Operations	0	
S40450	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Moisture and Leak Free?	y	
S40451	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
S40452	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
S40453	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	General Comments		
S40454	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
S40455	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Operations Counter AF	139	
S40456	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Operations Counter AL	139	
S40457	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Ambient Temp	42	°F
S40458	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
S40459	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Switching Operations	0	
S40460	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Moisture and Leak Free?	y	
S40461	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
S40462	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Clear of Trash?	y	
S40463	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
S40464	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
S40465	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Tank Paint Condition	Good	
S40466	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Unknown Operations	0	
S40467	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
S40468	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
S40469	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Operations Counter AF	40	
S40470	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Operations Counter AL	40	
S40471	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
S40472	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
S40473	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
S40474	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	General Comments	Under frequency is controlled in SEL	
S40475	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
S40476	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
S40477	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
S40478	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
S40479	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
S40480	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Switching Operations	0	
S40481	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Unknown Operations	0	
S40482	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
S40483	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
S40484	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Vegetation	None	
S40485	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
S40486	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
S40487	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
S40488	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
S40489	3/5/2019 10:51	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
S40490	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
S40491	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
S40492	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
S40493	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
S40494	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
S40495	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
S40496	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
S40497	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
S40498	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
S40499	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
S40500	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
S40501	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
S40502	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
S40503	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
S40504	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
S40505	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
S40506	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
S40507	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Oil Temp Present	50	°C
S40508	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	9 Month Operations	2	
S40509	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Accumulated Fault Duty A Ph V	3.74	%
S40510	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Accumulated Fault Duty B Ph V	2.80	%
S40511	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Accumulated Fault Duty C Ph V	2.80	%
S40512	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Amps A Ø	150.0	
S40513	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Amps B Ø	100.0	
S40514	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Amps C Ø	120.0	
S40515	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Bushing Condition	Good	
S40516	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Bushings Connection/Risers	Good	
S40517	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
S40518	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
S40519	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Oil Temp Max	75	°C
S40520	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
S40521	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
S40522	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Paint Condition	Good	
S40523	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Equipment Properly Labeled?	y	
S40524	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
S40525	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
S40526	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
S40527	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations A Ø	0	
S40528	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations B Ø	0	
S40529	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
S40530	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
S40531	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
S40532	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
S40533	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
S40534	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
S40535	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
S40536	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
S40537	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations C Ø	0	
S40538	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations Ground	0	
S40539	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Follow-up Action Required?	n	
S40540	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Follow-up Action Required?	n	
S40541	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Foundation Condition	Good	
S40542	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.2510	
S40543	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	General Comments		
S40544	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	General Comments		
S40545	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
S40546	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
S40547	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
S40548	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
S40549	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
S40550	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
S40551	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
S40552	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
S40553	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
S40554	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
S40555	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
S40556	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
S40557	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
S40558	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
S40559	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
S40560	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
S40561	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
S40562	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
S40563	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
S40564	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
S40565	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	General Comments		
S40566	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
S40567	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
S40568	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Foundation Condition	Good	
S40569	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
S40570	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
S40571	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
S40572	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
S40573	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
S40574	3/7/2019 10:17	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
S40575	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
S40576	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
S40577	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
S40578	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
S40579	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
S40580	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
S40581	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
S40582	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
S40583	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
S40584	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	All Connections OK?	y	
S40585	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	Follow-up Action Required?	n	
S40586	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	General Comments		
S40587	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	LTC Operation Checked?	y	
S40588	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
S40589	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
S40590	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	BCH000300	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.9	VDC
S40591	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	BCH000300	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
S40592	3/7/2019 9:26	Distribution	Texas Gas Quarterly Inspection	BCH000300	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
S40593	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6270	
S40594	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
S40595	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
S40596	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
S40597	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
S40598	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
S40599	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	General Comments	ok	
S40600	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
S40601	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Ambient Temp	42	°F

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
540602	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
540603	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Clear of Trash?	y	
540604	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
540605	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
540606	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
540607	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
540608	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
540609	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
540610	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Clear of Trash?	y	
540611	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
540612	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
540613	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Ambient Temp	29	°F
540614	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
540615	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
540616	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
540617	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
540618	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
540619	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
540620	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
540621	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
540622	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	General Comments	ok	
540623	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
540624	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
540625	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Vegetation	None	
540626	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
540627	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
540628	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
540629	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
540630	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
540631	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
540632	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
540633	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
540634	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
540635	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
540636	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
540637	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Foundation Condition	Good	
540638	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
540639	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
540640	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	General Comments	ok	
540641	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
540642	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
540643	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
540644	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
540645	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
540646	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
540647	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
540648	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
540649	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
540650	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
540651	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
540652	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
540653	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
540654	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	950	
540655	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
540656	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
540657	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
540658	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
540659	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
540660	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
540661	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
540662	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
540663	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
540664	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
540665	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	176	
540666	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	185	
540667	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	9	
540668	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
540669	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
540670	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
540671	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
540672	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1504.80	kw
540673	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
540674	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
540675	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	General Comments	ok	
540676	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
540677	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
540678	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
540679	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
540680	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	General Comments		
540681	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	General Comments		
540682	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
540683	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
540684	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
540685	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
540686	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
540687	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
540688	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
540689	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
540690	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
540691	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
540692	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
540693	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
540694	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
540695	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
540696	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
540697	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
540698	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
540699	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	39	°F
540700	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
540701	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
540702	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
540703	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
540704	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
540705	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
540706	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
540707	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
540708	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
540709	3/7/2019 13:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
540710	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
540711	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
540712	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
540713	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
540714	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	70.0	
540715	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	70.0	
540716	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	80.0	
540717	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
540718	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
540719	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
540720	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	640.0	
540721	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	640.0	
540722	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	640.0	
540723	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
540724	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
540725	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
540726	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
540727	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
540728	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
540729	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
540730	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
540731	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
540732	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
540733	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
540734	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
540735	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
540736	3/7/2019 9:56	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
540737	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
540738	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
540739	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
540740	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
540741	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
540742	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
540743	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
540744	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
540745	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
540746	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
540747	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
540748	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	General Comments		
540749	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
540750	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
540751	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
540752	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
540753	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	6	
540754	3/7/2019 11:44	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	950	
540755	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
540756	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
540757	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
540758	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
540759	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
540760	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Switching Operations	4	
540761	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Tank Paint Condition	Good	
540762	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Unknown Operations	0	
540763	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	13	
540764	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.08	%
540765	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
540766	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
540767	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
540768	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
540769	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
540770	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
540771	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
540772	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
540773	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
540774	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
540775	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
540776	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
540777	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	General Comments		
540778	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
540779	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Foundation Condition	Good	
540780	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
540781	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
540782	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
540783	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
540784	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
540785	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	General Comments		
540786	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
540787	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
540788	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
540789	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
540790	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
540791	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
540792	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
540793	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
540794	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
540795	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
540796	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
540797	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
540798	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
540799	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
540800	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
540801	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
540802	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
540803	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
540804	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
540805	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
540806	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
540807	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
540808	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
540809	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
540810	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.0	VDC
540811	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
540812	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
540813	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
540814	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Foundation Condition	Good	
540815	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
540816	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
540817	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
540818	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
540819	3/7/2019 8:50	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
540820	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
540821	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Paint Condition	Good	
540822	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
540823	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
540824	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
540825	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	General Comments		
540826	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
540827	3/7/2019 12:48	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
540828	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Grounds in Place?	y	
540829	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Heaters (All) Functioning?	y	
540830	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Maintenance Operations	0	
540831	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Moisture and Leak Free?	y	
540832	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
540833	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
540834	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
540835	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Vegetation	None	
540836	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
540837	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
540838	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	General Comments		
540839	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
540840	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
540841	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
540842	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
540843	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
540844	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
540845	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Clear of Trash?	y	
540846	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
540847	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
540848	3/7/2019 13:15	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
540849	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
540850	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
540851	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
540852	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
540853	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Operations Counter AF	211	
540854	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Operations Counter AL	215	
540855	3/7/2019 16:41	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
540856	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
540857	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Vegetation	None	
540858	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
540859	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
540860	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	General Comments	ok	
540861	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
540862	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
540863	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
540864	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
540865	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
540866	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
540867	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
540868	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
540869	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
540870	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
540871	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Totalizer Meter Reading	.6000	
540872	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
540873	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
540874	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
540875	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
540876	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
540877	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
540878	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
540879	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
540880	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
540881	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
540882	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Oil Temp Present	30	°C
540883	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Oil Temp Max	40	°C
540884	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
540885	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
540886	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	LTC Totalizer Reading	5760.00	kw
540887	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
540888	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	General Comments		
540889	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	General Comments		
540890	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
540891	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
540892	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
540893	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
540894	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Follow-up Action Required?	n	
540895	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
540896	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
540897	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
540898	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
540899	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
540900	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
540901	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
S40902	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
S40903	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
S40904	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
S40905	3/7/2019 13:34	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
S40906	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
S40907	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
S40908	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
S40909	3/7/2019 10:46	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
S40910	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
S40911	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
S40912	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
S40913	3/7/2019 12:56	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
S40914	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
S40915	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	18.9	VDC
S40916	3/7/2019 10:48	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	14.0	VDC
S40917	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
S40918	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	n	
S40919	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
S40920	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	
S40921	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
S40922	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
S40923	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
S40924	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
S40925	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
S40926	3/7/2019 16:17	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
S40927	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
S40928	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
S40929	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
S40930	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
S40931	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
S40932	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
S40933	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
S40934	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
S40935	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
S40936	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
S40937	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
S40938	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
S40939	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
S40940	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
S40941	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
S40942	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	General Comments	ok	
S40943	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
S40944	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
S40945	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
S40946	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
S40947	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Foundation Condition	Good	
S40948	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	General Comments		
S40949	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
S40950	3/7/2019 9:07	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
S40951	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
S40952	3/7/2019 12:57	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Panel Lights OK?	y	
S40953	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
S40954	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
S40955	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	76	
S40956	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
S40957	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
S40958	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
S40959	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
S40960	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
S40961	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
S40962	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
S40963	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
S40964	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	82.0	
S40965	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
S40966	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
S40967	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	76	
S40968	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	5	
S40969	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	7.97	%
S40970	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	7.97	%
S40971	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	5.32	%
S40972	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	62.0	
S40973	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	74.0	
S40974	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
S40975	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
S40976	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
540977	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0647	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	2.66	%
540978	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0647	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
540979	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0647	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	3.99	%
540980	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0647	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
540981	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0647	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	52.0	
540982	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0647	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	30.0	
540983	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0647	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	39.0	
540984	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0647	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
540985	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0647	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
540986	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0647	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
540987	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0647	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
540988	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0647	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
540989	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0647	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
540990	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0647	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
540991	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0647	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
540992	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0647	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	50	
540993	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0647	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	50	
540994	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0647	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
540995	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0647	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
540996	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0647	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
540997	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0647	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
540998	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0647	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
540999	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0647	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
541000	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0647	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
541001	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0646	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
541002	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0646	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
541003	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0646	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
541004	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0646	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
541005	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0646	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	259	
541006	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0646	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	259	
541007	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0646	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
541008	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0646	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	1	
541009	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0646	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
541010	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0646	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
541011	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0646	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
541012	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0646	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
541013	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0646	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
541014	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0646	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
541015	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0646	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	68.0	
541016	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0646	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	81.0	
541017	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0646	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	86.0	
541018	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0646	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	1.33	%
541019	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0646	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	5.32	%
541020	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0646	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	3.99	%
541021	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0646	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
541022	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0646	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
541023	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0646	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
541024	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0646	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
541025	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0645	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	146.0	
541026	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0645	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	123.0	
541027	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0645	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	133.0	
541028	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0645	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	2.66	%
541029	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0645	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	7.97	%
541030	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0645	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	2.66	%
541031	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0645	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	6	
541032	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0645	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
541033	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0645	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
541034	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0645	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
541035	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0645	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
541036	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0645	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
541037	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0645	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
541038	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0645	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
541039	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0645	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
541040	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0645	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
541041	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0645	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
541042	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0645	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1	
541043	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0645	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1	
541044	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0645	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
541045	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0645	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
541046	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0645	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
541047	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0645	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
541048	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0645	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
541049	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
541050	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	3.99	%
541051	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	9.30	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
541052	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
541053	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
541054	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	30	
541055	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	30	
541056	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
541057	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
541058	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
541059	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
541060	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
541061	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
541062	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
541063	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
541064	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
541065	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
541066	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	137.0	
541067	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	148.0	
541068	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	230.0	
541069	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	7.97	%
541070	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
541071	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
541072	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
541073	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
541074	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	57	
541075	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	57	
541076	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
541077	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
541078	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
541079	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
541080	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
541081	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
541082	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
541083	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
541084	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
541085	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
541086	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
541087	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	459.0	
541088	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	436.0	
541089	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	538.0	
541090	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	5	
541091	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	8.66	%
541092	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	8.66	%
541093	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	8.66	%
541094	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
541095	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
541096	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
541097	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	VRR Base Voltage AF	0.0	VAC
541098	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations A Ø	0	
541099	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations B Ø	0	
541100	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations C Ø	0	
541101	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations Ground	0	
541102	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
541103	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
541104	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Bushings Connection/Risers	Good	
541105	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Bushing Condition	Good	
541106	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Amps C Ø	120.0	
541107	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Amps B Ø	100.0	
541108	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Amps A Ø	150.0	
541109	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Accumulated Fault Duty C Ph V	2.45	%
541110	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Accumulated Fault Duty B Ph V	2.80	%
541111	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Accumulated Fault Duty A Ph V	2.45	%
541112	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	9 Month Operations	2	
541113	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Follow-up Action Required?	n	
541114	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Follow-up Action Required?	n	
541115	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations B Ø	0	
541116	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations A Ø	0	
541117	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
541118	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
541119	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
541120	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Foundation Condition	Good	
541121	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Tank Paint Condition	Good	
541122	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Unknown Operations	0	
541123	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
541124	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
541125	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Equipment Properly Labeled?	y	
541126	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Switching Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
541127	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
541128	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Operations Counter AL	66	
541129	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Operations Counter AF	66	
541130	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Paint Condition	Good	
541131	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
541132	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	9 Month Operations	3	
541133	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Accumulated Fault Duty A Ph V	.59	%
541134	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Accumulated Fault Duty B Ph V	.37	%
541135	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Accumulated Fault Duty C Ph V	.37	%
541136	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Amps A Ø	37.0	
541137	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Amps B Ø	0.0	
541138	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Amps C Ø	6.0	
541139	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
541140	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
541141	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
541142	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Cabinet Paint Condition	Good	
541143	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
541144	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
541145	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
541146	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
541147	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	All Connections OK?	y	
541148	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Moisture and Leak Free?	y	
541149	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Maintenance Operations	0	
541150	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Grounds in Place?	y	
541151	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	General Comments		
541152	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	General Comments		
541153	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Foundation Condition	Good	
541154	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Follow-up Action Required?	n	
541155	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	Follow-up Action Required?	n	
541156	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Follow-up Action Required?	n	
541157	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations Ground	0	
541158	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations C Ø	0	
541159	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	General Comments	ok	
541160	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	LTC Operation Checked?	n	
541161	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
541162	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
541163	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Foundation Condition	Good	
541164	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Follow-up Action Required?	n	
541165	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Follow-up Action Required?	n	
541166	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations Ground	0	
541167	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations C Ø	0	
541168	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations B Ø	0	
541169	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations A Ø	0	
541170	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
541171	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
541172	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
541173	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Equipment Properly Labeled?	y	
541174	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Cabinet Paint Condition	Good	
541175	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
541176	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
541177	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
541178	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Amps C Ø	143.0	
541179	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Amps B Ø	152.0	
541180	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Amps A Ø	123.0	
541181	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Accumulated Fault Duty C Ph V	.11	%
541182	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Accumulated Fault Duty B Ph V	.05	%
541183	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Accumulated Fault Duty A Ph V	.11	%
541184	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	9 Month Operations	2	
541185	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Unknown Operations	0	
541186	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Tank Paint Condition	Good	
541187	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Switching Operations	0	
541188	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
541189	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Operations Counter AL	81	
541190	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Operations Counter AF	81	
541191	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Moisture and Leak Free?	y	
541192	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Maintenance Operations	0	
541193	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Grounds in Place?	y	
541194	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	General Comments		
541195	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	General Comments		
541196	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Foundation Condition	Good	
541197	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Follow-up Action Required?	n	
541198	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Follow-up Action Required?	n	
541199	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Operations Counter AF	136	
541200	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Operations Counter AL	136	
541201	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Switching Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
541202	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Tank Paint Condition	Good	
541203	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Unknown Operations	0	
541204	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations Ground	0	
541205	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations C Ø	0	
541206	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations B Ø	0	
541207	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations A Ø	0	
541208	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
541209	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
541210	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
541211	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
541212	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
541213	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
541214	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
541215	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Equipment Properly Labeled?	y	
541216	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Cabinet Paint Condition	Good	
541217	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
541218	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
541219	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
541220	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Amps C Ø	153.0	
541221	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Amps B Ø	148.0	
541222	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Amps A Ø	169.0	
541223	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Accumulated Fault Duty C Ph V	.11	%
541224	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Accumulated Fault Duty B Ph V	.11	%
541225	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Accumulated Fault Duty A Ph V	.11	%
541226	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	9 Month Operations	4	
541227	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
541228	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations A Ø	0	
541229	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations B Ø	0	
541230	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations C Ø	0	
541231	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations Ground	0	
541232	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
541233	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
541234	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
541235	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Follow-up Action Required?	n	
541236	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Follow-up Action Required?	n	
541237	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Foundation Condition	Good	
541238	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	General Comments		
541239	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	General Comments		
541240	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Grounds in Place?	y	
541241	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Heaters (All) Functioning?	y	
541242	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Maintenance Operations	0	
541243	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Moisture and Leak Free?	y	
541244	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
541245	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
541246	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
541247	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
541248	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
541249	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
541250	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
541251	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
541252	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
541253	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
541254	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	General Comments		
541255	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
541256	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Unknown Operations	0	
541257	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Tank Paint Condition	Good	
541258	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Switching Operations	0	
541259	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
541260	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Operations Counter AL	74	
541261	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Operations Counter AF	74	
541262	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Moisture and Leak Free?	y	
541263	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Maintenance Operations	0	
541264	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Grounds in Place?	y	
541265	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	General Comments		
541266	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	General Comments		
541267	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
541268	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
541269	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	General Comments		
541270	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
541271	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
541272	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
541273	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
541274	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
541275	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
541276	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
541277	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
541278	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Regulator As Left Counter	6261	
541279	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
541280	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
541281	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Tank Leaks	None	
541282	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
541283	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Unknown Operations	0	
541284	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
541285	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
541286	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
541287	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
541288	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
541289	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
541290	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
541291	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
541292	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Switching Operations	0	
541293	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
541294	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
541295	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
541296	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
541297	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
541298	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
541299	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
541300	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Operations Counter AL	84	
541301	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
541302	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	8	°C
541303	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
541304	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
541305	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
541306	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
541307	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
541308	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
541309	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
541310	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
541311	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
541312	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
541313	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
541314	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
541315	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
541316	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
541317	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
541318	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Amps C Ø	18.0	
541319	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Amps B Ø	43.0	
541320	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Amps A Ø	40.0	
541321	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
541322	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Accumulated Fault Duty B Ph V	.05	%
541323	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
541324	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	9 Month Operations	1	
541325	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
541326	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
541327	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
541328	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
541329	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
541330	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
541331	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
541332	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
541333	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
541334	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
541335	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	General Comments		
541336	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
541337	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
541338	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
541339	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
541340	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
541341	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
541342	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
541343	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
541344	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Regulator As Left Counter	6615	
541345	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
541346	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
541347	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Tank Leaks	None	
541348	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
541349	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
541350	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
541351	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
541352	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
541353	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
541354	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
541355	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
541356	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
541357	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
541358	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Panels Dusted?	y	
541359	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
541360	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
541361	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Trash Emptied?	y	
541362	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
541363	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
541364	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
541365	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
541366	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
541367	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
541368	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
541369	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
541370	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
541371	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
541372	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
541373	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
541374	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
541375	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
541376	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
541377	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
541378	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
541379	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
541380	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
541381	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
541382	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
541383	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
541384	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
541385	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
541386	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
541387	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
541388	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Amps C Ø	385.0	
541389	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Amps B Ø	343.0	
541390	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Amps A Ø	429.0	
541391	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
541392	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
541393	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
541394	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	9 Month Operations	0	
541395	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
541396	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
541397	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
541398	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
541399	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
541400	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
541401	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
541402	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Unknown Operations	0	
541403	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Tank Paint Condition	Good	
541404	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Switching Operations	0	
541405	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
541406	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Operations Counter AL	79	
541407	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Operations Counter AF	79	
541408	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Moisture and Leak Free?	y	
541409	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Maintenance Operations	0	
541410	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Grounds in Place?	y	
541411	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	General Comments		
541412	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	General Comments		
541413	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
541414	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
541415	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
541416	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
541417	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
541418	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
541419	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
541420	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
541421	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
541422	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
541423	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
541424	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
541425	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
541426	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
541427	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
541428	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	General Comments		
541429	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
541430	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
541431	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
541432	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
541433	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
541434	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
541435	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
541436	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
541437	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Regulator As Left Counter	5871	
541438	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
541439	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
541440	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Tank Leaks	None	
541441	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
541442	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
541443	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
541444	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Operations Counter AF	84	
541445	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
541446	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Maintenance Operations	0	
541447	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
541448	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	General Comments		
541449	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	General Comments		
541450	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
541451	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
541452	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	VRR Time Delay	30	Seconds
541453	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	VRR Base Voltage AL	0.0	VAC
541454	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
541455	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations Ground	0	
541456	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
541457	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
541458	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
541459	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
541460	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
541461	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
541462	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
541463	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
541464	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
541465	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	3494.40	kw
541466	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
541467	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
541468	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	8	°C
541469	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
541470	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
541471	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Unknown Operations	0	
541472	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Switching Operations	0	
541473	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Operations Counter AL	156	
541474	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
541475	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	General Comments		
541476	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
541477	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
541478	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
541479	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
541480	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
541481	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
541482	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
541483	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
541484	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
541485	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
541486	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
541487	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
541488	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
541489	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
541490	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
541491	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
541492	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
541493	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
541494	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
541495	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
541496	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
541497	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
541498	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
541499	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Vegetation	None	
541500	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
541501	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
541502	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
541503	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
541504	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
541505	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	General Comments	4 yard lights are out. One of the lights will need bucket truck to be changed	
541506	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
541507	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
541508	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
541509	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
541510	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	4.0	VDC
541511	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	2.0	VDC
541512	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
541513	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
541514	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
541515	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
541516	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
541517	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
541518	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
541519	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
541520	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Unknown Operations	0	
541521	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Switching Operations	0	
541522	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Operations Counter AL	364	
541523	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
541524	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
541525	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
541526	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
541527	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
541528	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
541529	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
541530	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
541531	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
541532	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps B Ø	25.0	
541533	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Operations Counter AF	364	
541534	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Maintenance Operations	0	
541535	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	General Comments		
541536	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Patrol Inspection	General Comments		
541537	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Follow-up Action Required?	n	
541538	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Patrol Inspection	Follow-up Action Required?	n	
541539	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations Ground	0	
541540	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations C Ø	0	
541541	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations B Ø	0	
541542	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations A Ø	0	
541543	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
541544	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
541545	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
541546	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Patrol Inspection	Equipment Properly Labeled?	y	
541547	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Amps C Ø	60.0	
541548	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Amps B Ø	25.0	
541549	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Amps A Ø	25.0	
541550	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Accumulated Fault Duty C Ph V	19.13	%
541551	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Accumulated Fault Duty B Ph V	13.55	%
541552	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Accumulated Fault Duty A Ph V	13.55	%
541553	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps A Ø	80.0	
541554	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.17	%
541555	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	.17	%
541556	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.17	%
541557	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	9 Month Operations	2	
541558	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	9 Month Operations	20	
541559	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
541560	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
541561	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
541562	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
541563	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
541564	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
541565	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Maintenance Operations	1	
541566	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Heaters (All) Functioning?	y	
541567	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
541568	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
541569	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	General Comments		
541570	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
541571	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Foundation Condition	Good	
541572	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Grounds in Place?	y	
541573	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	General Comments	ok	
541574	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	General Comments	ok	
541575	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Foundation Condition	Good	
541576	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
541577	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Follow-up Action Required?	n	
541578	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations Ground	0	
541579	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations C Ø	0	
541580	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations B Ø	0	
541581	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations A Ø	0	
541582	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
541583	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
541584	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
541585	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Equipment Properly Labeled?	y	
541586	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
541587	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
541588	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Paint Condition	Good	
541589	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
541590	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
541591	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
541592	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Bushings Connection/Risers	Good	
541593	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Bushing Condition	Good	
541594	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Amps C Ø	250.0	
541595	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Amps B Ø	250.0	
541596	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Amps A Ø	240.0	
541597	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Accumulated Fault Duty C Ph V	2.58	%
541598	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Accumulated Fault Duty B Ph V	1.10	%
541599	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Accumulated Fault Duty A Ph V	1.10	%
541600	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	9 Month Operations	3	
541601	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
541602	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
541603	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
541604	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Clear of Trash?	y	
541605	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
541606	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
541607	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
541608	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
541609	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
541610	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
541611	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	General Comments		
541612	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
541613	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Vegetation	None	
541614	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
541615	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
541616	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
541617	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
541618	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
541619	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
541620	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
541621	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
541622	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	30	°F
541623	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
541624	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Operations Counter AF	156	
541625	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Maintenance Operations	0	
541626	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	General Comments		
541627	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Patrol Inspection	General Comments		
541628	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Follow-up Action Required?	n	
541629	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Patrol Inspection	Follow-up Action Required?	n	
541630	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations Ground	0	
541631	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations C Ø	0	
541632	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations B Ø	0	
541633	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations A Ø	0	
541634	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
541635	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
541636	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
541637	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
541638	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
541639	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
541640	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
541641	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
541642	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Patrol Inspection	Equipment Properly Labeled?	y	
541643	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Amps C Ø	20.0	
541644	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Ambient Temp	14	°F
541645	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	1.0920	
541646	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
541647	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
541648	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
541649	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
541650	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
541651	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
541652	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
541653	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Amps B Ø	80.0	
541654	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Amps A Ø	70.0	
541655	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Accumulated Fault Duty C Ph V	2.39	%
541656	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Accumulated Fault Duty B Ph V	2.39	%
541657	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Accumulated Fault Duty A Ph V	4.78	%
541658	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	9 Month Operations	4	
541659	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LTCC000273	LTCControl	MK-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
541660	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LTCC000273	LTCControl	MK-TRANS 1	LTC Control Insp	General Comments		
541661	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LTCC000273	LTCControl	MK-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
541662	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Unknown Operations	0	
541663	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Tank Paint Condition	Good	
541664	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Switching Operations	0	
541665	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Operations Counter AL	180	
541666	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Operations Counter AF	180	
541667	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Moisture and Leak Free?	y	
541668	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Accumulated Fault Duty A Ph V	.48	%
541669	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	9 Month Operations	11	
541670	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
541671	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
541672	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
541673	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
541674	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
541675	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
541676	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
541677	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
541678	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
541679	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
541680	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
541681	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
541682	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
541683	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
541684	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	General Comments		
541685	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
541686	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
541687	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
541688	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
541689	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
541690	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	General Comments		
541691	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
541692	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
541693	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
541694	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
541695	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
541696	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
541697	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
541698	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	28	°F
541699	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
541700	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
541701	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	General Comments		
541702	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
541703	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
541704	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	VRR Time Delay	30	Seconds
541705	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
541706	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
541707	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
541708	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
541709	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
541710	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
541711	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
541712	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
541713	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
541714	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
541715	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
541716	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
541717	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
541718	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
541719	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
541720	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
541721	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
541722	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
541723	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
541724	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
541725	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
541726	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
541727	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
541728	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
541729	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
541730	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
541731	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
541732	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
541733	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Foundation Condition	Good	
541734	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
541735	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	General Comments		
541736	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
541737	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
541738	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
541739	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
541740	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
541741	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
541742	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
541743	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
541744	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
541745	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
541746	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
541747	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
541748	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
541749	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Equipment Properly Labeled?	y	
541750	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Cabinet Paint Condition	Good	
541751	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
541752	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
541753	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
541754	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
541755	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Clear of Trash?	y	
541756	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
541757	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
541758	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
541759	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
541760	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
541761	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
541762	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	General Comments		
541763	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
541764	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
541765	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Vegetation	None	
541766	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Amps C Ø	45.0	
541767	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Amps B Ø	10.0	
541768	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Amps A Ø	63.0	
541769	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Accumulated Fault Duty C Ph V	.21	%
541770	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Accumulated Fault Duty B Ph V	.32	%
541771	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
541772	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations A Ø	0	
541773	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations B Ø	0	
541774	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations C Ø	0	
541775	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations Ground	0	
541776	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Patrol Inspection	Follow-up Action Required?	n	
541777	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Follow-up Action Required?	n	
541778	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Patrol Inspection	General Comments		
541779	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	General Comments		
541780	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Maintenance Operations	0	
541781	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Operations Counter AF	468	
541782	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Operations Counter AL	468	
541783	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Switching Operations	0	
541784	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Unknown Operations	0	
541785	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
541786	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
541787	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
541788	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
541789	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
541790	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
541791	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
541792	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	35	°C
541793	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
541794	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
541795	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
541796	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
541797	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
541798	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Unknown Operations	0	
541799	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
541800	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Switching Operations	0	
541801	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AL	405	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
541802	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AF	405	
541803	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
541804	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Maintenance Operations	1	
541805	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
541806	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
541807	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	General Comments		
541808	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	General Comments		
541809	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
541810	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
541811	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
541812	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
541813	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
541814	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
541815	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
541816	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
541817	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
541818	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
541819	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
541820	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
541821	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
541822	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
541823	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
541824	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
541825	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Clear of Trash?	y	
541826	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
541827	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
541828	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
541829	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
541830	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
541831	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
541832	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
541833	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	General Comments		
541834	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
541835	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
541836	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Vegetation	None	
541837	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
541838	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
541839	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
541840	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
541841	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
541842	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	LTC Operation Checked?	y	
541843	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	General Comments		
541844	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	Follow-up Action Required?	n	
541845	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	All Connections OK?	y	
541846	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
541847	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
541848	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
541849	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Foundation Condition	Good	
541850	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
541851	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
541852	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	General Comments	no spare fuse barrels	
541853	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
541854	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
541855	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
541856	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
541857	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
541858	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
541859	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
541860	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
541861	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
541862	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
541863	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
541864	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
541865	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	9 Month Operations	6	
541866	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Accumulated Fault Duty A Ph V	7.97	%
541867	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Accumulated Fault Duty B Ph V	2.39	%
541868	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Accumulated Fault Duty C Ph V	1.59	%
541869	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Amps A Ø	117.0	
541870	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Amps B Ø	140.0	
541871	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Amps C Ø	200.0	
541872	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Patrol Inspection	Equipment Properly Labeled?	y	
541873	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
541874	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
541875	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Moisture and Leak Free?	y	
541876	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Maintenance Operations	2	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
541877	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Heaters (All) Functioning?	y	
541878	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Grounds in Place?	y	
541879	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	General Comments	ok	
541880	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	General Comments	ok	
541881	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Foundation Condition	Good	
541882	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Follow-up Action Required?	n	
541883	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Follow-up Action Required?	n	
541884	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations Ground	0	
541885	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations C Ø	0	
541886	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations B Ø	0	
541887	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations A Ø	0	
541888	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
541889	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
541890	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
541891	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Equipment Properly Labeled?	y	
541892	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Paint Condition	Good	
541893	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
541894	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
541895	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
541896	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Bushings Connection/Risers	Good	
541897	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Bushing Condition	Good	
541898	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
541899	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
541900	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
541901	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	9 Month Operations	3	
541902	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
541903	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
541904	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
541905	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
541906	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
541907	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
541908	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
541909	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
541910	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
541911	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
541912	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
541913	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
541914	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	General Comments	no spare fuses	
541915	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
541916	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Switching Operations	0	
541917	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	196	
541918	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	196	
541919	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
541920	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	General Comments	open	
541921	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
541922	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
541923	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
541924	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
541925	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
541926	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
541927	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
541928	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
541929	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
541930	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
541931	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
541932	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
541933	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
541934	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
541935	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
541936	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
541937	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
541938	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	9 Month Operations	2	
541939	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Accumulated Fault Duty A Ph V	28.96	%
541940	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Accumulated Fault Duty B Ph V	31.38	%
541941	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Accumulated Fault Duty C Ph V	28.96	%
541942	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Amps A Ø	20.0	
541943	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Amps B Ø	6.0	
541944	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Amps C Ø	20.0	
541945	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Bushing Condition	Good	
541946	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Bushings Connection/Risers	Good	
541947	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
541948	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
541949	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
541950	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Paint Condition	Good	
541951	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
541952	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
541953	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
541954	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
541955	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations A Ø	0	
541956	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations B Ø	0	
541957	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations C Ø	0	
541958	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations Ground	0	
541959	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Follow-up Action Required?	n	
541960	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Follow-up Action Required?	n	
541961	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Foundation Condition	Good	
541962	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	General Comments		
541963	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	General Comments		
541964	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Grounds in Place?	y	
541965	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Heaters (All) Functioning?	y	
541966	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Maintenance Operations	0	
541967	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Moisture and Leak Free?	y	
541968	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Operations Counter AF	163	
541969	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Operations Counter AL	163	
541970	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Switching Operations	0	
541971	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Tank Paint Condition	Good	
541972	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Unknown Operations	0	
541973	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Unknown Operations	0	
541974	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Tank Paint Condition	Good	
541975	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Switching Operations	0	
541976	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Operations Counter AL	181	
541977	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Operations Counter AF	181	
541978	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	General Comments		
541979	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
541980	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
541981	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
541982	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
541983	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Vegetation	None	
541984	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
541985	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
541986	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
541987	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
541988	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
541989	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
541990	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
541991	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
541992	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
541993	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
541994	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
541995	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
541996	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	22	°F
541997	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
541998	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
541999	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
542000	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.6	VDC
542001	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	General Comments		
542002	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
542003	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
542004	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
542005	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
542006	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
542007	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
542008	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
542009	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
542010	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
542011	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
542012	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
542013	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	General Comments		
542014	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
542015	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
542016	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Foundation Condition	Good	
542017	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
542018	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
542019	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
542020	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
542021	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
542022	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
542023	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
542024	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	40.0	
542025	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	40.0	
542026	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	40.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
542027	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
542028	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
542029	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
542030	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
542031	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
542032	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
542033	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
542034	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
542035	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
542036	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
542037	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
542038	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	30.80	%
542039	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	30.80	%
542040	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	30.80	%
542041	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations	12	
542042	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
542043	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
542044	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Foundation Condition	Good	
542045	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
542046	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
542047	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
542048	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
542049	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
542050	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
542051	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
542052	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Vegetation	None	
542053	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
542054	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
542055	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
542056	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	General Comments	ok	
542057	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
542058	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
542059	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
542060	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
542061	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
542062	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
542063	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Clear of Trash?	y	
542064	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
542065	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
542066	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Ambient Temp	27	°F
542067	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Ambient Temp	25	°F
542068	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
542069	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
542070	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Clear of Trash?	y	
542071	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
542072	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
542073	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
542074	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	BCH000820	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
542075	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	BCH000820	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
542076	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	BCH000820	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.2	VDC
542077	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	BCH000820	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.2	VDC
542078	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
542079	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
542080	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
542081	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
542082	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
542083	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
542084	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
542085	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
542086	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
542087	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
542088	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
542089	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	General Comments		
542090	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
542091	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Ambient Temp	31	°F
542092	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
542093	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
542094	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Clear of Trash?	y	
542095	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
542096	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
542097	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
542098	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
542099	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
542100	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
542101	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
542102	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
542103	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
542104	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Vegetation	None	
542105	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
542106	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	All Identified and Legible?	y	
542107	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
542108	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Conductors and Connectors OK?	y	
542109	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Contacts Engaged Properly?	y	
542110	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Equipment Properly Labeled?	y	
542111	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Follow-up Action Required?	n	
542112	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Foundation Condition	Good	
542113	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Free of Audible Arcing?	y	
542114	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	General Comments		
542115	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
542116	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
542117	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
542118	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Ground Connections Intact?	y	
542119	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Insulators In Good Condition?	y	
542120	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Linkage Grounds in Place?	y	
542121	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Live Parts Good Condition?	y	
542122	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Operating Linkage OK?	y	
542123	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
542124	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Tank Leaks	None	
542125	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
542126	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
542127	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
542128	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Regulator As Left Counter	94248	
542129	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
542130	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
542131	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
542132	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
542133	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
542134	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
542135	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
542136	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
542137	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
542138	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
542139	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	18	°C
542140	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
542141	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
542142	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
542143	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
542144	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
542145	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
542146	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
542147	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
542148	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
542149	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
542150	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
542151	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
542152	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
542153	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
542154	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
542155	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
542156	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
542157	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
542158	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
542159	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
542160	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
542161	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
542162	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Tank Leaks	None	
542163	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
542164	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Regulator As Left Counter	88051	
542165	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
542166	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
542167	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
542168	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
542169	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
542170	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Min Tap Position	6L	
542171	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Max Tap Position	2R	
542172	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
542173	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
542174	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	36	°F
542175	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	General Comments		
542176	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
542177	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
542178	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
542179	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
542180	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Current Tap Position	1L	
542181	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
542182	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
542183	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
542184	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
542185	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
542186	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
542187	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
542188	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	General Comments		
542189	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
542190	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
542191	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
542192	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
542193	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
542194	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
542195	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
542196	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
542197	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
542198	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
542199	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
542200	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
542201	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
542202	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
542203	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Foundation Condition	Good	
542204	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
542205	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
542206	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	General Comments		
542207	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
542208	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
542209	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
542210	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
542211	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	4L	
542212	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
542213	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
542214	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
542215	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
542216	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
542217	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
542218	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
542219	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
542220	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
542221	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
542222	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
542223	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
542224	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	5R	
542225	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
542226	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
542227	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
542228	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
542229	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
542230	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	83711	
542231	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
542232	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
542233	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
542234	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
542235	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
542236	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
542237	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
542238	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
542239	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
542240	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
542241	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	General Comments		
542242	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
542243	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
542244	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
542245	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
542246	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Current Tap Position	4R	
542247	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
542248	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
542249	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
542250	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
542251	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
542252	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
542253	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
542254	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
542255	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
542256	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
542257	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	General Comments		
542258	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
542259	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Positive DC Ground	28.0	VDC
542260	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
542261	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
542262	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
542263	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Signage Visible, and Proper?	y	
542264	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Site Service Trans Condition	OK	
542265	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Steel Structures Rust Free?	y	
542266	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Surge Arrester Condition	Good	
542267	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	PF001202	PowerFuse	MK-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
542268	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	PF001202	PowerFuse	MK-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
542269	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	PF001201	PowerFuse	MK-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
542270	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	PF001201	PowerFuse	MK-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
542271	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
542272	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
542273	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
542274	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
542275	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
542276	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
542277	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
542278	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
542279	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	General Comments		
542280	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	General Comments		
542281	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
542282	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
542283	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
542284	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
542285	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	Oil Temp Present	20	°C
542286	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
542287	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
542288	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
542289	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
542290	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
542291	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
542292	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
542293	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
542294	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
542295	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
542296	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
542297	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
542298	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
542299	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
542300	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
542301	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
542302	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
542303	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
542304	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
542305	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
542306	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
542307	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
542308	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
542309	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	General Comments		
542310	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
542311	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
542312	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
542313	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
542314	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
542315	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Tank Leaks	None	
542316	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
542317	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Regulator As Left Counter	53608	
542318	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
542319	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
542320	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
542321	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
542322	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
542323	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
542324	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
542325	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
542326	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
542327	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
542328	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
542329	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
542330	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
542331	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
542332	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
542333	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
542334	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
542335	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
542336	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
542337	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
542338	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
542339	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
542340	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
542341	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
542342	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	40.0	
542343	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	40.0	
542344	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
542345	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
542346	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
542347	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
542348	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
542349	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
542350	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
542351	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
542352	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
542353	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
542354	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
542355	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
542356	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
542357	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
542358	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
542359	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
542360	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
542361	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
542362	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
542363	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
542364	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
542365	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
542366	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
542367	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
542368	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
542369	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	40.0	
542370	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
542371	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps C Ø	150.0	
542372	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps B Ø	175.0	
542373	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps A Ø	220.0	
542374	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
542375	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
542376	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
542377	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	9 Month Operations	2	
542378	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	Follow-up Action Required?	n	
542379	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
542380	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	General Comments	ok	
542381	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	General Comments	ok	
542382	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC As Found Counter	266	
542383	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC As Left Counter	272	
542384	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
542385	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Current Tap Position	3R	
542386	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Max Tap Position	4R	
542387	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Min Tap Position	Neutral	
542388	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
542389	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Operations Since Last Insp	43	
542390	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
542391	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
542392	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
542393	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
542394	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
542395	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
542396	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
542397	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
542398	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
542399	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
542400	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
542401	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
542402	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
542403	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
542404	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
542405	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
542406	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
542407	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	.05	%
542408	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	.05	%
542409	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	.05	%
542410	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	2	
542411	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Unknown Operations	0	
542412	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Tank Paint Condition	Good	
542413	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Switching Operations	0	
542414	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
542415	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Operations Counter AL	57	
542416	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Operations Counter AF	57	
542417	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Moisture and Leak Free?	y	
542418	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Maintenance Operations	0	
542419	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
542420	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Evidence of Insects	None	
542421	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Grounds in Place?	y	
542422	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	General Comments		
542423	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	General Comments		
542424	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
542425	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
542426	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Floor Swept?	y	
542427	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Foundation Condition	Good	
542428	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Follow-up Action Required?	n	
542429	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Follow-up Action Required?	n	
542430	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
542431	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
542432	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	General Comments		
542433	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Operations Ground	0	
542434	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Operations C Ø	0	
542435	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Operations B Ø	0	
542436	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Operations A Ø	0	
542437	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
542438	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
542439	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
542440	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
542441	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Cabinet Paint Condition	Good	
542442	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Tank Paint Condition	Good	
542443	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
542444	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
542445	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	96	
542446	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	96	
542447	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
542448	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
542449	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Grounds in Place?	y	
542450	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	General Comments		
542451	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
542452	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	11.2	
542453	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	13.8	
542454	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	20.3	
542455	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
542456	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
542457	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Broom on Site?	y	
542458	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
542459	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
542460	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
542461	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
542462	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
542463	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Evidence of Insects	None	
542464	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
542465	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
542466	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
542467	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
542468	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
542469	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
542470	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	567	
542471	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
542472	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Floor Swept?	y	
542473	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
542474	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
542475	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	General Comments		
542476	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
542477	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
542478	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Panels Dusted?	y	
542479	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
542480	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
542481	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Trash Emptied?	y	
542482	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
542483	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
542484	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
542485	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
542486	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Broom on Site?	y	
542487	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
542488	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
542489	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
542490	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
542491	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
542492	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Foundation Condition	Good	
542493	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
542494	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
542495	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
542496	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
542497	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
542498	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
542499	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
542500	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
542501	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
542502	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
542503	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
542504	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
542505	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
542506	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Min Tap Position	7L	
542507	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
542508	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
542509	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
542510	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
542511	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
542512	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
542513	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
542514	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	General Comments		
542515	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
542516	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
542517	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
542518	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Regulator As Left Counter	205434	
542519	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
542520	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Tank Leaks	None	
542521	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
542522	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
542523	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
542524	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	General Comments		
542525	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
542526	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	101680	
542527	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	101680	
542528	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
542529	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	General Comments		
542530	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
542531	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	8L	
542532	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Ambient Temp	22	°F
542533	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
542534	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Clear of Trash?	y	
542535	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
542536	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
542537	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
542538	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
542539	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
542540	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
542541	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	General Comments		
542542	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
542543	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
542544	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	3L	
542545	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
542546	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
542547	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
542548	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
542549	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
542550	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
542551	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
542552	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
542553	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
542554	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
542555	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
542556	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Readings	General Comments		
542557	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
542558	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
542559	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
542560	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
542561	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
542562	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	209	
542563	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	209	
542564	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
542565	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
542566	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
542567	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
542568	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
542569	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
542570	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	BCH000462	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
542571	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	BCH000462	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
542572	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	BCH000462	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
542573	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	BCH000462	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
542574	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	BCH000462	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
542575	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
542576	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
542577	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
542578	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
542579	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
542580	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
542581	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
542582	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
542583	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
542584	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
542585	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
542586	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
542587	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
542588	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
542589	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
542590	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Current Tap Position	1L	
542591	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
542592	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
542593	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
542594	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
542595	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	General Comments	Oil level low	
542596	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
542597	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	General Comments		
542598	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
542599	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Free of Audible Arcing?	y	
542600	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Follow-up Action Required?	n	
542601	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Equipment Properly Labeled?	y	
542602	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Contacts Engaged Properly?	y	
542603	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Conductors and Connectors OK?	y	
542604	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	All Identified and Legible?	y	
542605	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Unknown Operations	0	
542606	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
542607	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Switching Operations	0	
542608	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AL	209	
542609	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AF	209	
542610	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
542611	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Maintenance Operations	1	
542612	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
542613	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
542614	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
542615	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
542616	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
542617	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	37	°F
542618	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
542619	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
542620	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
542621	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	General Comments		
542622	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	General Comments		
542623	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
542624	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
542625	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
542626	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
542627	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
542628	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
542629	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Readings	General Comments		
542630	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
542631	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
542632	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
542633	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
542634	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
542635	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
542636	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
542637	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
542638	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
542639	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
542640	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
542641	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
542642	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Foundation Condition	Good	
542643	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
542644	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
542645	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	General Comments	No spare fuse barrels	
542646	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
542647	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
542648	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
542649	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	10L	
542650	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
542651	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	589	
542652	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
542653	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
542654	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
542655	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
542656	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Vegetation	None	
542657	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
542658	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
542659	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
542660	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
542661	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
542662	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	111	
542663	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
542664	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	-1	°C
542665	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
542666	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
542667	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6L	
542668	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
542669	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
542670	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC As Left Counter	17470	
542671	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC As Found Counter	17470	
542672	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
542673	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	General Comments		
542674	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
542675	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
542676	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LTCC000041	LTCControl	SSC-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
542677	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LTCC000041	LTCControl	SSC-Offline-Distribution	LTC Control Insp	General Comments		
542678	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LTCC000041	LTCControl	SSC-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
542679	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Wood Structures OK?	y	
542680	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Surge Arrester Condition	Good	
542681	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
542682	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Site Service Trans Condition	OK	
542683	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Signage Visible, and Proper?	y	
542684	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
542685	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
542686	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Live Parts Good Condition?	y	
542687	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Linkage Grounds in Place?	y	
542688	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Insulators In Good Condition?	y	
542689	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
542690	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
542691	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
542692	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
542693	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
542694	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
542695	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	557	
542696	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	557	
542697	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
542698	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
542699	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
542700	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Ground Connections Intact?	y	
542701	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
542702	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
542703	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Paint Condition	Good	
542704	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Equipment Properly Labeled?	y	
542705	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
542706	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
542707	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
542708	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations A Ø	0	
542709	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations B Ø	0	
542710	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations C Ø	0	
542711	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations Ground	0	
542712	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Follow-up Action Required?	n	
542713	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Follow-up Action Required?	n	
542714	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Foundation Condition	Good	
542715	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	General Comments		
542716	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	General Comments		
542717	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Grounds in Place?	y	
542718	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Heaters (All) Functioning?	y	
542719	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
542720	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Tank Leaks	None	
542721	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
542722	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Regulator As Left Counter	40884	
542723	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
542724	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
542725	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
542726	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
542727	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
542728	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
542729	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
542730	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
542731	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	General Comments		
542732	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
542733	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
542734	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
542735	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
542736	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
542737	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
542738	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
542739	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
542740	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
542741	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
542742	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Maintenance Operations	1	
542743	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Moisture and Leak Free?	y	
542744	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Operations Counter AF	170	
542745	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Operations Counter AL	170	
542746	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
542747	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Switching Operations	0	
542748	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
542749	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Paint Condition	Good	
542750	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Equipment Properly Labeled?	y	
542751	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
542752	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
542753	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
542754	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations A Ø	0	
542755	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations B Ø	0	
542756	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations C Ø	0	
542757	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations Ground	0	
542758	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Follow-up Action Required?	n	
542759	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Follow-up Action Required?	n	
542760	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Foundation Condition	Good	
542761	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	General Comments		
542762	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	General Comments		
542763	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Grounds in Place?	y	
542764	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Heaters (All) Functioning?	y	
542765	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Maintenance Operations	1	
542766	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Moisture and Leak Free?	y	
542767	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Operations Counter AF	158	
542768	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Operations Counter AL	158	
542769	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
542770	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Switching Operations	0	
542771	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Tank Paint Condition	Good	
542772	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Unknown Operations	0	
542773	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	10.0	
542774	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	10.0	
542775	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	10.0	
542776	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
542777	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
542778	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
542779	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
542780	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
542781	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
542782	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
542783	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
542784	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
542785	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	9 Month Operations	4	
542786	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Accumulated Fault Duty A Ph V	9.65	%
542787	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Accumulated Fault Duty B Ph V	9.65	%
542788	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Accumulated Fault Duty C Ph V	9.65	%
542789	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Amps A Ø	43.0	
542790	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Amps B Ø	36.0	
542791	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Amps C Ø	29.0	
542792	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Bushing Condition	Good	
542793	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Bushings Connection/Risers	Good	
542794	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
542795	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Maintenance Operations	1	
542796	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
542797	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
542798	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
542799	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
542800	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
542801	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	82850	
542802	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
542803	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
542804	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
542805	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
542806	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	5L	
542807	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	6R	
542808	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
542809	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
542810	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
542811	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
542812	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
542813	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
542814	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	General Comments		
542815	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	5R	
542816	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
542817	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
542818	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
542819	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
542820	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
542821	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	General Comments		
542822	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
542823	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
542824	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
542825	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
542826	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
542827	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
542828	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
542829	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
542830	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
542831	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
542832	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
542833	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
542834	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
542835	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
542836	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
542837	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
542838	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
542839	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Vegetation	None	
542840	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
542841	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
542842	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Tank Paint Condition	Good	
542843	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Unknown Operations	0	
542844	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
542845	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
542846	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
542847	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	60121	
542848	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
542849	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
542850	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
542851	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
542852	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
542853	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
542854	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
542855	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	General Comments		
542856	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
542857	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
542858	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
542859	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	5R	
542860	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
542861	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
542862	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
542863	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
542864	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	15	
542865	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	15	
542866	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
542867	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
542868	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
542869	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
542870	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
542871	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
542872	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
542873	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
542874	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
542875	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
542876	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
542877	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
542878	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	4R	
542879	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
542880	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
542881	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
542882	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
542883	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
542884	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Unknown Operations	0	
542885	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
542886	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Switching Operations	0	
542887	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AL	218	
542888	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AF	218	
542889	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
542890	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
542891	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
542892	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
542893	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Max	21	°C
542894	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Present	21	°C
542895	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Readings	X2 Winding Temp Max	21	°C
542896	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Readings	X2 Winding Temp Present	21	°C
542897	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Readings	X3 Winding Temp Max	21	°C
542898	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Readings	X3 Winding Temp Present	21	°C
542899	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
542900	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	General Comments		
542901	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
542902	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
542903	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
542904	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
542905	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
542906	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
542907	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
542908	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
542909	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
542910	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
542911	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
542912	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
542913	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
542914	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LTCC000523	LTCControl	JT-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
542915	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LTCC000523	LTCControl	JT-TRANS 1	LTC Control Insp	General Comments		
542916	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LTCC000523	LTCControl	JT-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
542917	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	31	°C
542918	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	45	°C
542919	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	26	°C
542920	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	57	°C
542921	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	31	°C
542922	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	44	°C
542923	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
542924	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
542925	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
542926	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
542927	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
542928	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
542929	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
542930	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
542931	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
542932	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	Oil Temp Present	18	°C
542933	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	Oil Temp Max	31	°C
542934	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
542935	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
542936	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
542937	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
542938	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
542939	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
542940	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
542941	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
542942	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	General Comments		
542943	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
542944	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
542945	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
542946	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
542947	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
542948	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
542949	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
542950	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
542951	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
542952	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
542953	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
542954	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
542955	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	General Comments		
542956	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
542957	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
542958	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2411.52	kw
542959	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
542960	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
542961	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
542962	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
542963	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
542964	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
542965	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
542966	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
542967	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
542968	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
542969	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
542970	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
542971	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7536	
542972	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
542973	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
542974	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
542975	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
542976	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
542977	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	30	°C
542978	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	17	°C
542979	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
542980	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
542981	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
542982	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
542983	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
542984	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
542985	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
542986	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
542987	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Tank Leaks	None	
542988	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
542989	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Operations Counter	196	
542990	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
542991	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
542992	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	General Comments		
542993	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
542994	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
542995	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
542996	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
542997	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
542998	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
542999	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
543000	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
543001	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
543002	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
543003	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Amps C Ø	96.0	
543004	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Amps B Ø	97.0	
543005	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Amps A Ø	97.0	
543006	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
543007	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
543008	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
543009	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	124	
543010	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
543011	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
543012	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
543013	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
543014	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
543015	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC As Left Counter	112199	
543016	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC As Found Counter	112199	
543017	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
543018	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	General Comments		
543019	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
543020	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
543021	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	9 Month Operations	2	
543022	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Accumulated Fault Duty A Ph V	9.65	%
543023	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Accumulated Fault Duty B Ph V	9.65	%
543024	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Accumulated Fault Duty C Ph V	9.65	%
543025	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Amps A Ø	48.0	
543026	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Amps B Ø	50.0	
543027	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Amps C Ø	79.0	
543028	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Bushing Condition	Good	
543029	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Bushings Connection/Risers	Good	
543030	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
543031	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
543032	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	General Comments	X2 Guage could not be reset	
543033	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitro	
543034	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
543035	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
543036	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	y	
543037	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
543038	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
543039	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
543040	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
543041	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
543042	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
543043	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
543044	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
543045	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
543046	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
543047	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
543048	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	Reset Tap Drag Hands	Reset	
543049	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
543050	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Operations Since Last Insp	0	
543051	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Min Tap Position	Neutral	
543052	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Max Tap Position	Neutral	
543053	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Current Tap Position	Neutral	
543054	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
543055	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC As Left Counter	24	
543056	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC As Found Counter	24	
543057	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	General Comments	ok	
543058	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	General Comments	ok	
543059	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
543060	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	Follow-up Action Required?	n	
543061	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Amps A Ø	142.0	
543062	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Amps B Ø	180.0	
543063	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Amps C Ø	120.0	
543064	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
543065	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
543066	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
543067	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
543068	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
543069	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
543070	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
543071	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
543072	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
543073	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
543074	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	General Comments		
543075	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
543076	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
S43077	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Operations Counter	159	
S43078	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
S43079	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Tank Leaks	None	
S43080	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Moisture and Leak Free?	y	
S43081	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Operations Counter AF	107	
S43082	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Operations Counter AL	107	
S43083	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Switching Operations	0	
S43084	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Tank Paint Condition	Good	
S43085	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Unknown Operations	0	
S43086	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
S43087	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
S43088	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
S43089	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
S43090	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
S43091	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Current Tap Position	5R	
S43092	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
S43093	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
S43094	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
S43095	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
S43096	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	General Comments		
S43097	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
S43098	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
S43099	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
S43100	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
S43101	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
S43102	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
S43103	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Regulator As Left Counter	38863	
S43104	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
S43105	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Tank Leaks	None	
S43106	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
S43107	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
S43108	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
S43109	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	General Comments		
S43110	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	General Comments		
S43111	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
S43112	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
S43113	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
S43114	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
S43115	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
S43116	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	Oil Temp Max	60	°C
S43117	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	Oil Temp Present	40	°C
S43118	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
S43119	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
S43120	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
S43121	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
S43122	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
S43123	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
S43124	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
S43125	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
S43126	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
S43127	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Paint Condition	Good	
S43128	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
S43129	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
S43130	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
S43131	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations A Ø	0	
S43132	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations B Ø	0	
S43133	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations C Ø	0	
S43134	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations Ground	0	
S43135	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Follow-up Action Required?	n	
S43136	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Follow-up Action Required?	n	
S43137	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Foundation Condition	Good	
S43138	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	General Comments		
S43139	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	General Comments		
S43140	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Grounds in Place?	y	
S43141	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Heaters (All) Functioning?	y	
S43142	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
S43143	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
S43144	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
S43145	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
S43146	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
S43147	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
S43148	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
S43149	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
S43150	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
S43151	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
543152	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
543153	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Adjusted Amps B Phase V	16.19	
543154	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
543155	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations A Ø	0	
543156	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations B Ø	1	
543157	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations C Ø	0	
543158	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations Ground	0	
543159	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Follow-up Action Required?	n	
543160	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Follow-up Action Required?	n	
543161	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Foundation Condition	Good	
543162	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	General Comments		
543163	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	General Comments		
543164	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Grounds in Place?	y	
543165	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Heaters (All) Functioning?	y	
543166	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Maintenance Operations	1	
543167	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Moisture and Leak Free?	y	
543168	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Operations Counter AF	252	
543169	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Operations Counter AL	252	
543170	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Switching Operations	0	
543171	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Tank Paint Condition	Good	
543172	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Unknown Operations	0	
543173	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Maintenance Operations	0	
543174	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Switching Operations	0	
543175	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
543176	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Operations Counter AL	185	
543177	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Operations Counter AF	185	
543178	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Moisture and Leak Free?	y	
543179	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Maintenance Operations	0	
543180	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Heaters (All) Functioning?	y	
543181	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Grounds in Place?	y	
543182	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	General Comments		
543183	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	General Comments		
543184	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Foundation Condition	Good	
543185	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Follow-up Action Required?	n	
543186	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Follow-up Action Required?	n	
543187	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations Ground	0	
543188	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations C Ø	0	
543189	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations B Ø	0	
543190	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations A Ø	0	
543191	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
543192	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
543193	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
543194	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Equipment Properly Labeled?	y	
543195	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Cabinet Paint Condition	Good	
543196	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
543197	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
543198	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
543199	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Bushings Connection/Risers	Good	
543200	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Bushing Condition	Good	
543201	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Amps C Ø	69.0	
543202	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Amps B Ø	76.0	
543203	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Amps A Ø	66.0	
543204	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
543205	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
543206	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Accumulated Fault Duty A Ph V	.68	%
543207	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	9 Month Operations	1	
543208	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
543209	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
543210	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
543211	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
543212	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
543213	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
543214	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
543215	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	Oil Temp Present	20	°C
543216	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
543217	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
543218	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
543219	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
543220	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	General Comments		
543221	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
543222	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
543223	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
543224	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
543225	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
543226	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
543227	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	General Comments		
543228	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	General Comments		
543229	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
543230	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
543231	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	612.00	kw
543232	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
543233	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
543234	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Oil Temp Present	18	°C
543235	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
543236	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
543237	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
543238	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
543239	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
543240	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
543241	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
543242	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
543243	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.5100	
543244	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
543245	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
543246	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
543247	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
543248	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
543249	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Current Tap Position	3R	
543250	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
543251	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
543252	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
543253	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
543254	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	General Comments		
543255	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
543256	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
543257	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
543258	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
543259	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
543260	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
543261	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
543262	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
543263	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Regulator As Left Counter	43796	
543264	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
543265	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Tank Leaks	None	
543266	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
543267	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Unknown Operations	0	
543268	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Tank Paint Condition	Good	
543269	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
543270	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
543271	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
543272	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
543273	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Tank Leaks	None	
543274	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
543275	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Operations Counter	327	
543276	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
543277	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
543278	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
543279	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
543280	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
543281	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
543282	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
543283	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
543284	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
543285	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	General Comments		
543286	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
543287	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
543288	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Foundation Condition	Good	
543289	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
543290	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
543291	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
543292	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	General Comments		
543293	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
543294	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
543295	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
543296	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
543297	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
543298	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
543299	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
543300	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
543301	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
543302	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
543303	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Amps C Ø	116.0	
543304	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Amps B Ø	112.0	
543305	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Amps A Ø	179.0	
543306	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
543307	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
543308	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
543309	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
543310	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
543311	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Vegetation	None	
543312	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
543313	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
543314	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	General Comments		
543315	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
543316	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	General Comments		
543317	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
543318	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
543319	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
543320	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
543321	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
543322	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
543323	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Clear of Trash?	y	
543324	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
543325	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
543326	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Ambient Temp	28	°F
543327	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
543328	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps C Ø	175.0	
543329	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps B Ø	180.0	
543330	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps A Ø	200.0	
543331	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
543332	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
543333	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
543334	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	9 Month Operations	2	
543335	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
543336	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
543337	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
543338	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
543339	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
543340	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
543341	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
543342	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
543343	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
543344	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	General Comments		
543345	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	General Comments		
543346	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
543347	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
543348	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
543349	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2764.80	kw
543350	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
543351	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
543352	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
543353	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
543354	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
543355	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
543356	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
543357	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
543358	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
543359	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
543360	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
543361	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
543362	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1520	
543363	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
543364	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
543365	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
543366	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	General Comments		
543367	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
543368	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
543369	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Foundation Condition	Good	
543370	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
543371	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
543372	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
543373	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
543374	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
543375	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
543376	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
543377	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
543378	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
543379	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	9 Month Operations	2	
543380	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Accumulated Fault Duty A Ph V	1.05	%
543381	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Accumulated Fault Duty B Ph V	1.05	%
543382	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Accumulated Fault Duty C Ph V	1.05	%
543383	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Amps A Ø	120.0	
543384	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Amps B Ø	100.0	
543385	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Amps C Ø	150.0	
543386	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Bushing Condition	Good	
543387	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Bushings Connection/Risers	Good	
543388	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
543389	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
543390	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
543391	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Paint Condition	Good	
543392	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Equipment Properly Labeled?	y	
543393	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
543394	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
543395	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
543396	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
543397	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
543398	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
543399	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	9 Month Operations	5	
543400	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Accumulated Fault Duty A Ph V	15.69	%
543401	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Accumulated Fault Duty B Ph V	20.51	%
543402	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Accumulated Fault Duty C Ph V	18.10	%
543403	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Amps A Ø	40.0	
543404	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Amps B Ø	120.0	
543405	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Amps C Ø	60.0	
543406	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Bushing Condition	Good	
543407	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Bushings Connection/Risers	Good	
543408	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
543409	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
543410	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
543411	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
543412	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
543413	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
543414	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
543415	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
543416	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Clear of Trash?	y	
543417	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
543418	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
543419	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
543420	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
543421	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Undetermined	
543422	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
543423	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	General Comments		
543424	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
543425	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
543426	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
543427	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
543428	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
543429	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
543430	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
543431	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
543432	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
543433	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
543434	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	33	°C
543435	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
543436	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
543437	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
543438	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
543439	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
543440	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	can't read oil guage	
543441	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
543442	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
543443	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
543444	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
543445	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
543446	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
543447	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
543448	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
543449	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
543450	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
543451	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
543452	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
543453	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
543454	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
543455	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
543456	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
543457	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
543458	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
543459	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
543460	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
543461	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
543462	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
543463	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
543464	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
543465	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
543466	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
543467	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
543468	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
543469	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
543470	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
543471	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
543472	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
543473	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
543474	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
543475	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Current Tap Position	1L	
543476	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
543477	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
543478	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
543479	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
543480	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	General Comments		
543481	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
543482	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
543483	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Min Tap Position	6L	
543484	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
543485	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
543486	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
543487	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
543488	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
543489	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Regulator As Left Counter	80649	
543490	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
543491	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Tank Leaks	None	
543492	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
543493	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	9 Month Operations	2	
543494	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	1.93	%
543495	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	1.93	%
543496	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	1.93	%
543497	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Amps A Ø	400.0	
543498	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Amps B Ø	390.0	
543499	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Amps C Ø	480.0	
543500	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
543501	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
543502	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
543503	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
543504	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
543505	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
543506	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
543507	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Patrol Inspection	General Comments		
543508	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	General Comments		
543509	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Maintenance Operations	0	
543510	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Operations Counter AF	136	
543511	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Operations Counter AL	136	
543512	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Switching Operations	0	
543513	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Unknown Operations	0	
543514	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LTCC000622	LTCControl	MK-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
543515	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LTCC000622	LTCControl	MK-TRANS 2	LTC Control Insp	General Comments		
543516	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LTCC000622	LTCControl	MK-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
543517	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
543518	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
543519	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
543520	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	142	
543521	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	-2	°C
543522	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	27	°C
543523	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Min Tap Position	7L	
543524	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
543525	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3L	
543526	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
543527	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC As Left Counter	7548	
543528	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC As Found Counter	7548	
543529	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
543530	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	General Comments		
543531	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
543532	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
543533	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	16	°C
543534	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	35	°C
543535	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	15	°C
543536	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	35	°C
543537	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	15	°C
543538	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	35	°C
543539	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
543540	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
543541	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
543542	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
543543	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
543544	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
543545	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
543546	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
543547	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	Oil Temp Present	15	°C
543548	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	Oil Temp Max	34	°C
543549	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
543550	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
543551	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
543552	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	General Comments		
543553	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
543554	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
543555	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
543556	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
543557	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
543558	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
543559	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
543560	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
543561	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
543562	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
543563	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Tank Leaks	None	
543564	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
543565	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Regulator As Left Counter	75536	
543566	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
543567	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
543568	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
543569	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
543570	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
543571	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Min Tap Position	14L	
543572	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
543573	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
543574	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	General Comments		
543575	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
543576	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
543577	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
543578	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
543579	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
543580	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
543581	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
543582	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
543583	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
543584	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
543585	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
543586	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Patrol Inspection	General Comments		
543587	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	General Comments		
543588	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Maintenance Operations	0	
543589	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Operations Counter AF	399	
543590	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Operations Counter AL	399	
543591	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Switching Operations	0	
543592	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Unknown Operations	0	
543593	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
543594	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
543595	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
543596	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
543597	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
543598	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Current Tap Position	4R	
543599	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
543600	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
543601	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
543602	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
543603	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
543604	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Patrol Inspection	General Comments		
543605	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	General Comments		
543606	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Maintenance Operations	0	
543607	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Operations Counter AF	240	
543608	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Operations Counter AL	240	
543609	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Switching Operations	0	
543610	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Unknown Operations	0	
543611	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	9 Month Operations	8	
543612	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Accumulated Fault Duty A Ph V	21.52	%
543613	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Accumulated Fault Duty B Ph V	17.54	%
543614	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Accumulated Fault Duty C Ph V	20.73	%
543615	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Amps A Ø	114.0	
543616	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Amps B Ø	112.0	
543617	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Amps C Ø	103.0	
543618	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
543619	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
543620	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Vegetation	None	
543621	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
543622	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
543623	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	General Comments		
543624	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
543625	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
543626	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
543627	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
543628	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
543629	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
543630	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Clear of Trash?	y	
543631	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
543632	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
543633	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Ambient Temp	27	°F
543634	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
543635	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
543636	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
543637	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations A Ø	0	
543638	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations B Ø	0	
543639	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations C Ø	0	
543640	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations Ground	0	
543641	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Patrol Inspection	Follow-up Action Required?	n	
543642	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Follow-up Action Required?	n	
543643	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
543644	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	General Comments	barbwire broke in a few places, attempted to temporarily repair and rusty	
543645	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
543646	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
543647	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
543648	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
543649	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
543650	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
543651	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
543652	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
543653	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
543654	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
543655	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
543656	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
543657	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
543658	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
543659	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
543660	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
543661	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
543662	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
543663	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
543664	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
543665	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
543666	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
543667	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
543668	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
543669	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
543670	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
543671	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
543672	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
543673	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
543674	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
543675	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
543676	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
543677	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
543678	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
543679	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
543680	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
543681	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
543682	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
543683	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
543684	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
543685	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
543686	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
543687	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
543688	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
543689	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
543690	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
543691	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
543692	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
543693	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
543694	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
543695	3/6/2019 8:12	Distribution	Middletown Quarterly Inspection	PF000235	PowerFuse	MT-STA SER NO 4 LINE	Disconnect Powerfuse Inspection	General Comments	ok	
543696	3/6/2019 8:12	Distribution	Middletown Quarterly Inspection	PF000235	PowerFuse	MT-STA SER NO 4 LINE	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
543697	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	PF000186	PowerFuse	JT-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
543698	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	PF000186	PowerFuse	JT-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
543699	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	PF000185	PowerFuse	JT-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
543700	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	PF000185	PowerFuse	JT-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
543701	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	PF000229	PowerFuse	MK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
543702	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	PF000229	PowerFuse	MK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
543703	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	PF000228	PowerFuse	MK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
543704	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	PF000228	PowerFuse	MK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
543705	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
543706	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
543707	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
543708	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
543709	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
543710	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
543711	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
543712	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
543713	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
543714	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
543715	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
543716	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
543717	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
543718	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	General Comments		
543719	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
543720	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
543721	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	-1	psi
543722	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
543723	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
543724	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
543725	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
543726	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
543727	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
543728	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
543729	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
543730	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	1.0974	
543731	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
543732	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
543733	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
543734	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
543735	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
543736	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
543737	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
543738	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
543739	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	28	°C
543740	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
543741	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
543742	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	1755.84	kw
543743	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
543744	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Oil Temp Present	22	°C
543745	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Oil Temp Max	55	°C
543746	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
543747	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
543748	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	600.48	kw
543749	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
543750	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BCH001231	Charger	142-Battery Charger	Battery Charger Patrol Insp	General Comments		
543751	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BCH001231	Charger	142-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
543752	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BCH001231	Charger	142-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
543753	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BCH001231	Charger	142-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
543754	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BCH001231	Charger	142-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC
543755	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
543756	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
543757	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	General Comments		
543758	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	General Comments		
543759	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
543760	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
543761	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
543762	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
543763	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
543764	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
543765	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
543766	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
543767	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
543768	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
543769	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
543770	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	PF000187	PowerFuse	JT-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
543771	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	PF000187	PowerFuse	JT-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
543772	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	PF000188	PowerFuse	JT-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
543773	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	PF000188	PowerFuse	JT-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
543774	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	9 Month Operations	4	
543775	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	3.85	%
543776	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	3.85	%
543777	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	3.85	%
543778	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Amps A Ø	260.0	
543779	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Amps B Ø	320.0	
543780	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Amps C Ø	270.0	
543781	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
543782	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
543783	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
543784	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
543785	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
543786	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
543787	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
543788	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations Ground	0	
543789	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
543790	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	General Comments		
543791	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	General Comments		
543792	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
543793	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
543794	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
543795	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
543796	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	4633.92	kw
543797	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
543798	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
543799	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Oil Temp Max	20	°C
543800	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Oil Temp Present	20	°C
543801	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
543802	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
543803	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
543804	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
543805	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
543806	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
543807	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
543808	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
543809	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Totalizer Meter Reading	.9654	
543810	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Winding Temp Max	30	°C
543811	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Winding Temp Present	20	°C
543812	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
543813	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Vegetation	None	
543814	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
543815	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
543816	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
543817	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
543818	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
543819	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	General Comments	lots of construction in station	
543820	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
543821	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
543822	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
543823	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
543824	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
543825	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
543826	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Clear of Trash?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
543827	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
543828	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
543829	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Ambient Temp	20	°F
543830	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.5004	
543831	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
543832	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
543833	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
543834	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
543835	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
543836	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
543837	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
543838	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations A Ø	0	
543839	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations B Ø	0	
543840	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations C Ø	0	
543841	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations Ground	0	
543842	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Patrol Inspection	Follow-up Action Required?	n	
543843	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Follow-up Action Required?	n	
543844	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Patrol Inspection	General Comments		
543845	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	General Comments		
543846	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Maintenance Operations	0	
543847	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
543848	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
543849	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
543850	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
543851	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
543852	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Current Tap Position	5R	
543853	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
543854	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
543855	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
543856	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
543857	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	General Comments		
543858	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
543859	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Max Tap Position	5R	
543860	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Min Tap Position	4L	
543861	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
543862	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
543863	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
543864	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
543865	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	126.0	volts
543866	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Regulator As Left Counter	63742	
543867	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
543868	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
543869	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Tank Leaks	None	
543870	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
543871	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Operations Counter AF	211	
543872	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Operations Counter AL	211	
543873	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Switching Operations	0	
543874	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Unknown Operations	0	
543875	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	All Connections OK?	y	
543876	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	Follow-up Action Required?	n	
543877	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	General Comments	ok	
543878	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	LTC Operation Checked?	y	
543879	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
543880	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
543881	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
543882	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
543883	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	VRR Time Delay	30	Seconds
543884	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Unknown Operations	0	
543885	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
543886	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
543887	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
543888	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
543889	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
543890	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
543891	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
543892	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Regulator As Left Counter	8538	
543893	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
543894	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
543895	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Tank Leaks	None	
543896	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
543897	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
543898	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
543899	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
543900	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
543901	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
543902	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Current Tap Position	1R	
543903	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
543904	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
543905	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
543906	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
543907	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	General Comments		
543908	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
543909	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Max Tap Position	1R	
543910	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Min Tap Position	7L	
543911	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
543912	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
543913	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
543914	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
543915	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
543916	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Regulator As Left Counter	59103	
543917	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
543918	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
543919	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Tank Leaks	None	
543920	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
543921	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	9 Month Operations	6	
543922	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Accumulated Fault Duty A Ph V	19.93	%
543923	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Accumulated Fault Duty B Ph V	11.96	%
543924	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Accumulated Fault Duty C Ph V	19.13	%
543925	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Amps A Ø	40.0	
543926	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Amps B Ø	30.0	
543927	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Amps C Ø	80.0	
543928	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Patrol Inspection	Equipment Properly Labeled?	y	
543929	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
543930	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
543931	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
543932	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
543933	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	General Comments		
543934	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	General Comments		
543935	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
543936	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
543937	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
543938	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
543939	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
543940	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
543941	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
543942	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
543943	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
543944	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
543945	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
543946	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
543947	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
543948	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
543949	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
543950	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
543951	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
543952	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
543953	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Tank Leaks	None	
543954	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
543955	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Regulator As Left Counter	43968	
543956	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
543957	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
543958	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
543959	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
543960	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
543961	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
543962	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
543963	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
543964	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	General Comments		
543965	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
543966	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
543967	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
543968	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
543969	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
543970	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
543971	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
543972	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
543973	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
543974	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
543975	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
543976	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
543977	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
543978	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
543979	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Tank Paint Condition	Good	
543980	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Switching Operations	0	
543981	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
543982	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Operations Counter AL	226	
543983	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Operations Counter AF	266	
543984	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Moisture and Leak Free?	y	
543985	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Maintenance Operations	0	
543986	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Heaters (All) Functioning?	y	
543987	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Grounds in Place?	y	
543988	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	General Comments		
543989	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	General Comments		
543990	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Foundation Condition	Good	
543991	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Follow-up Action Required?	n	
543992	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Follow-up Action Required?	n	
543993	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations Ground	0	
543994	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations C Ø	0	
543995	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations B Ø	0	
543996	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations A Ø	0	
543997	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
543998	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
543999	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
544000	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Equipment Properly Labeled?	y	
544001	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Paint Condition	Good	
544002	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
544003	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
544004	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
544005	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Bushings Connection/Risers	Good	
544006	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Bushing Condition	Good	
544007	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Amps C Ø	160.0	
544008	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Amps B Ø	140.0	
544009	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Amps A Ø	130.0	
544010	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Accumulated Fault Duty C Ph V	.65	%
544011	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Accumulated Fault Duty B Ph V	.65	%
544012	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Accumulated Fault Duty A Ph V	1.96	%
544013	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	9 Month Operations	8	
544014	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
544015	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
544016	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
544017	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
544018	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
544019	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
544020	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
544021	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	Oil Temp Present	23	°C
544022	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	Oil Temp Max	70	°C
544023	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
544024	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	96.00	
544025	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
544026	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
544027	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Min Tap Position	13L	
544028	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
544029	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
544030	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	General Comments		
544031	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
544032	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
544033	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
544034	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
544035	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
544036	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
544037	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
544038	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
544039	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
544040	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
544041	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
544042	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
544043	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
544044	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
544045	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
544046	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
544047	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
544048	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
544049	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
544050	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
544051	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
S44052	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
S44053	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
S44054	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
S44055	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
S44056	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
S44057	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
S44058	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
S44059	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
S44060	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Regulator As Left Counter	72640	
S44061	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
S44062	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Tank Leaks	None	
S44063	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
S44064	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
S44065	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
S44066	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
S44067	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
S44068	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
S44069	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
S44070	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
S44071	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
S44072	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
S44073	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
S44074	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
S44075	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
S44076	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
S44077	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	General Comments		
S44078	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
S44079	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
S44080	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
S44081	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
S44082	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
S44083	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
S44084	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
S44085	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
S44086	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Regulator As Left Counter	44538	
S44087	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
S44088	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Tank Leaks	None	
S44089	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
S44090	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
S44091	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
S44092	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
S44093	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
S44094	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
S44095	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Current Tap Position	3R	
S44096	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
S44097	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
S44098	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
S44099	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
S44100	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	General Comments		
S44101	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
S44102	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Max Tap Position	16R	
S44103	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
S44104	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
S44105	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
S44106	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
S44107	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
S44108	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
S44109	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Regulator As Left Counter	35084	
S44110	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
S44111	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Tank Leaks	None	
S44112	3/6/2019 9:12	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
S44113	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Tank Paint Condition	Adequate	
S44114	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Tank Leaks	None	
S44115	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
S44116	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Regulator As Left Counter	71824	
S44117	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.4	volts
S44118	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
S44119	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
S44120	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
S44121	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
S44122	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
S44123	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
S44124	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
S44125	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
S44126	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
544127	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
544128	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Regulator As Left Counter	7150	
544129	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
544130	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
544131	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Tank Leaks	None	
544132	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
544133	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
544134	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
544135	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
544136	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
544137	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
544138	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Current Tap Position	2R	
544139	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
544140	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
544141	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
544142	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
544143	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	General Comments		
544144	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
544145	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
544146	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
544147	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
544148	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
544149	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
544150	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
544151	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
544152	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Regulator As Left Counter	7278	
544153	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
544154	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
544155	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Tank Leaks	None	
544156	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
544157	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
544158	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
544159	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
544160	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
544161	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
544162	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
544163	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
544164	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
544165	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
544166	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
544167	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	General Comments		
544168	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
544169	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	General Comments		
544170	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
544171	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
544172	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
544173	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
544174	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
544175	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
544176	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
544177	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
544178	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Regulator As Left Counter	171626	
544179	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
544180	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Tank Leaks	None	
544181	3/6/2019 14:13	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
544182	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
544183	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
544184	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
544185	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
544186	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
544187	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
544188	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Foundation Condition	Good	
544189	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
544190	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
544191	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	General Comments		
544192	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
544193	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
544194	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
544195	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
544196	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
544197	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
544198	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
544199	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
544200	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
544201	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
S44202	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
S44203	3/6/2019 14:18	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
S44204	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
S44205	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
S44206	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
S44207	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
S44208	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
S44209	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
S44210	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
S44211	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
S44212	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
S44213	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
S44214	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	General Comments		
S44215	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
S44216	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
S44217	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Heaters (All) Functioning?	y	
S44218	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Maintenance Operations	0	
S44219	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Moisture and Leak Free?	y	
S44220	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Amps A Ø	50.0	
S44221	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Amps B Ø	60.0	
S44222	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Operations Counter AF	204	
S44223	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Operations Counter AL	204	
S44224	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Operations Counter AF	139	
S44225	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Operations Counter AL	139	
S44226	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Accumulated Fault Duty C Ph V	8.77	%
S44227	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Accumulated Fault Duty B Ph V	6.38	%
S44228	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Current Tap Position	2R	
S44229	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
S44230	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
S44231	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Amps C Ø	80.0	
S44232	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Patrol Inspection	Equipment Properly Labeled?	y	
S44233	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
S44234	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
S44235	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
S44236	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
S44237	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
S44238	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations A Ø	0	
S44239	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations B Ø	0	
S44240	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations C Ø	0	
S44241	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations Ground	0	
S44242	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Patrol Inspection	Follow-up Action Required?	n	
S44243	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Follow-up Action Required?	n	
S44244	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	General Comments		
S44245	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
S44246	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Patrol Inspection	General Comments		
S44247	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	General Comments		
S44248	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	General Comments		
S44249	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Maintenance Operations	0	
S44250	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
S44251	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
S44252	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
S44253	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
S44254	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
S44255	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Follow-up Action Required?	y	
S44256	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Foundation Condition	Good	
S44257	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
S44258	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
S44259	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	General Comments	Insulator broken on bypass for X0081	
S44260	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
S44261	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
S44262	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	17	°C
S44263	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	35	°C
S44264	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	17	°C
S44265	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
S44266	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	General Comments		
S44267	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
S44268	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
S44269	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
S44270	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
S44271	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
S44272	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
S44273	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
S44274	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Winding Temp Present	12	°C
S44275	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Winding Temp Max	28	°C
S44276	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5214	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
S44277	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
S44278	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Tank Leaks	None	
S44279	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
S44280	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
S44281	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
S44282	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
S44283	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Paint Condition	Good	
S44284	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
S44285	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
S44286	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
S44287	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Equipment Properly Labeled?	y	
S44288	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
S44289	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations A Ø	0	
S44290	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations B Ø	0	
S44291	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations C Ø	0	
S44292	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations Ground	0	
S44293	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Patrol Inspection	Follow-up Action Required?	n	
S44294	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Follow-up Action Required?	n	
S44295	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Patrol Inspection	General Comments		
S44296	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	17	°C
S44297	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
S44298	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
S44299	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations A Ø	0	
S44300	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations B Ø	0	
S44301	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations C Ø	0	
S44302	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations Ground	0	
S44303	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Follow-up Action Required?	n	
S44304	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Follow-up Action Required?	n	
S44305	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Foundation Condition	Good	
S44306	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	General Comments		
S44307	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	General Comments		
S44308	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	35	°C
S44309	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
S44310	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	General Comments	open	
S44311	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Maintenance Operations	0	
S44312	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Grounds in Place?	y	
S44313	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
S44314	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Switching Operations	0	
S44315	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
S44316	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
S44317	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
S44318	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	896.64	kw
S44319	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
S44320	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
S44321	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
S44322	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	General Comments	Fans not hooked to electricity	
S44323	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	General Comments		
S44324	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
S44325	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
S44326	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
S44327	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
S44328	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Fans Operational?	n	
S44329	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
S44330	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
S44331	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
S44332	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
S44333	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
S44334	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	Follow-up Action Required?	n	
S44335	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
S44336	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
S44337	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
S44338	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Oil Temp Present	12	°C
S44339	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Oil Temp Max	12	°C
S44340	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
S44341	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
S44342	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5005.44	kw
S44343	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
S44344	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
S44345	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	General Comments		
S44346	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	General Comments		
S44347	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC As Found Counter	19720	
S44348	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC As Left Counter	19720	
S44349	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
S44350	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Current Tap Position	6L	
S44351	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Max Tap Position	6L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
544352	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
544353	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
544354	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Min Tap Position	12L	
544355	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Operations Since Last Insp	261	
544356	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
544357	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
544358	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
544359	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	General Comments		
544360	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	General Comments		
544361	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	35	°C
544362	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
544363	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
544364	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
544365	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
544366	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
544367	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
544368	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
544369	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
544370	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
544371	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
544372	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
544373	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
544374	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
544375	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
544376	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
544377	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
544378	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
544379	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
544380	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
544381	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
544382	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
544383	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
544384	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
544385	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
544386	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
544387	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
544388	3/6/2019 8:37	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
544389	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Totalizer Meter Reading	1.1208	
544390	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Operations Counter AF	176	
544391	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Operations Counter AL	176	
544392	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
544393	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
544394	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
544395	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
544396	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Follow-up Action Required?	n	
544397	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
544398	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	Oil Temp Present	17	°C
544399	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	Oil Temp Max	35	°C
544400	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
544401	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
544402	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
544403	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
544404	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
544405	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
544406	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Oil Temp Present	30	°C
544407	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
544408	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
544409	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Accumulated Fault Duty C Ph V	7.17	%
544410	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Amps A Ø	98.0	
544411	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Amps B Ø	120.0	
544412	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Amps C Ø	106.0	
544413	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Patrol Inspection	Equipment Properly Labeled?	y	
544414	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
544415	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
544416	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
544417	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations A Ø	0	
544418	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations B Ø	0	
544419	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations C Ø	0	
544420	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations Ground	0	
544421	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Patrol Inspection	Follow-up Action Required?	n	
544422	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Follow-up Action Required?	n	
544423	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Patrol Inspection	General Comments		
544424	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	General Comments		
544425	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Maintenance Operations	0	
544426	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Operations Counter AF	341	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
S44427	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Operations Counter AL	341	
S44428	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Switching Operations	0	
S44429	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Unknown Operations	0	
S44430	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	General Comments	ok	
S44431	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	General Comments	ok	
S44432	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
S44433	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Foundation Condition	Good	
S44434	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Follow-up Action Required?	n	
S44435	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
S44436	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Fans Operational?	y	
S44437	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Fans Condition	Good	
S44438	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
S44439	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
S44440	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
S44441	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
S44442	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
S44443	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
S44444	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
S44445	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
S44446	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
S44447	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations Ground	0	
S44448	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations C Ø	0	
S44449	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations B Ø	0	
S44450	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations A Ø	0	
S44451	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
S44452	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
S44453	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
S44454	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
S44455	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Patrol Inspection	Equipment Properly Labeled?	y	
S44456	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Amps C Ø	117.0	
S44457	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
S44458	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
S44459	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
S44460	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
S44461	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
S44462	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
S44463	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	General Comments		
S44464	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
S44465	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
S44466	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
S44467	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
S44468	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
S44469	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
S44470	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
S44471	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
S44472	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Regulator As Left Counter	59597	
S44473	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
S44474	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Tank Leaks	None	
S44475	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Patrol Inspection	Follow-up Action Required?	n	
S44476	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
S44477	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Tank Leaks	None	
S44478	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
S44479	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Regulator As Left Counter	148743	
S44480	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
S44481	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
S44482	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
S44483	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
S44484	3/6/2019 10:32	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
S44485	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
S44486	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
S44487	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
S44488	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Totalizer Meter Multiplier	0	
S44489	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
S44490	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
S44491	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Tank Leaks	None	
S44492	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
S44493	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
S44494	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Radiator Leaks	None	
S44495	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
S44496	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Oil Temp Present	0	°C
S44497	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Oil Temp Max	40	°C
S44498	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
S44499	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
S44500	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
S44501	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
544502	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	9 Month Operations	7	
544503	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Accumulated Fault Duty A Ph V	9.57	%
544504	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Accumulated Fault Duty B Ph V	11.16	%
544505	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Accumulated Fault Duty A Ph V	21.72	%
544506	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Accumulated Fault Duty B Ph V	20.51	%
544507	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Accumulated Fault Duty C Ph V	20.51	%
544508	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Amps A Ø	110.0	
544509	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Amps B Ø	70.0	
544510	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	General Comments	ok	
544511	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	Follow-up Action Required?	n	
544512	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	As Left Float Voltage	55.4	VDC
544513	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	As Found Float Voltage	55.4	VDC
544514	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Accumulated Fault Duty A Ph V	28.96	%
544515	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Accumulated Fault Duty B Ph V	45.86	%
544516	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Accumulated Fault Duty C Ph V	30.17	%
544517	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Amps A Ø	5.0	
544518	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Amps B Ø	0.0	
544519	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Amps C Ø	20.0	
544520	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Bushing Condition	Good	
544521	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Bushings Connection/Risers	Good	
544522	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
544523	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
544524	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
544525	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Accumulated Fault Duty A Ph V	12.75	%
544526	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	9 Month Operations	5	
544527	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Min Tap Position	6L	
544528	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
544529	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Accumulated Fault Duty C Ph V	8.77	%
544530	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Accumulated Fault Duty B Ph V	11.16	%
544531	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Accumulated Fault Duty A Ph V	17.54	%
544532	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
544533	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
544534	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
544535	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
544536	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
544537	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	Oil Temp Present	55	°C
544538	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
544539	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
544540	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	9 Month Operations	2	
544541	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
544542	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
544543	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
544544	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
544545	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
544546	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	Winding Temp Present	58	°C
544547	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
544548	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
544549	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
544550	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
544551	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Regulator As Left Counter	60335	
544552	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
544553	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Amps B Ø	150.0	
544554	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Amps A Ø	80.0	
544555	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
544556	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
544557	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
544558	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
544559	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
544560	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
544561	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
544562	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
544563	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
544564	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
544565	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	General Comments		
544566	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	General Comments		
544567	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
544568	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
544569	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Bushing Condition	Good	
544570	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
544571	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
544572	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	800	psi
544573	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
544574	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
544575	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
544576	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
544577	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
544578	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
544579	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Max Tap Position	9R	
544580	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
544581	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	General Comments		
544582	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
544583	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
544584	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
544585	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
544586	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Current Tap Position	6R	
544587	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
544588	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
544589	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
544590	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
544591	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
544592	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Follow-up Action Required?	n	
544593	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Patrol Inspection	General Comments		
544594	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	General Comments		
544595	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Maintenance Operations	0	
544596	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Operations Counter AF	201	
544597	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Operations Counter AL	201	
544598	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Switching Operations	0	
544599	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Unknown Operations	0	
544600	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	9 Month Operations	3	
544601	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	9 Month Operations	8	
544602	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
544603	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
544604	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
544605	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BAT001086	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
544606	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BAT001086	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
544607	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BAT001086	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	8.8	VDC
544608	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BAT001086	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	8.4	VDC
544609	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BAT001086	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
544610	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BAT001086	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
544611	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BAT001086	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
544612	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BAT001086	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
544613	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BAT001086	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
544614	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BAT001086	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
544615	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BAT001086	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
544616	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BAT001086	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	23	°F
544617	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	BAT001086	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
544618	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Unknown Operations	0	
544619	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Tank Paint Condition	Good	
544620	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Switching Operations	0	
544621	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
544622	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Operations Counter AL	181	
544623	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Operations Counter AF	181	
544624	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	General Comments		
544625	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
544626	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
544627	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
544628	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
544629	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
544630	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
544631	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
544632	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
544633	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
544634	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
544635	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Moisture and Leak Free?	y	
544636	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
544637	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
544638	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
544639	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
544640	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
544641	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Current Tap Position	5R	
544642	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
544643	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
544644	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Maintenance Operations	1	
544645	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Heaters (All) Functioning?	y	
544646	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
544647	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Grounds in Place?	y	
544648	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	General Comments		
544649	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
544650	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
544651	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
544652	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
544653	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
544654	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
544655	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
544656	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Oil Temp Max	55	°C
544657	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
544658	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
544659	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	LTC Totalizer Reading	4371.84	kw
544660	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
544661	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	General Comments		
544662	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	General Comments		
544663	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
544664	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
544665	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Totalizer Meter Reading	.5520	
544666	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
544667	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
544668	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
544669	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
544670	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
544671	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
544672	3/6/2019 11:12	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Max Tap Position	2R	
544673	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
544674	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
544675	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
544676	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
544677	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
544678	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
544679	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
544680	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
544681	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
544682	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Totalizer Meter Reading	.6072	
544683	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
544684	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
544685	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	LTC Totalizer Reading	5299.20	kw
544686	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
544687	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	General Comments	ok	
544688	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	General Comments	ok	
544689	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
544690	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
544691	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Follow-up Action Required?	n	
544692	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
544693	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
544694	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	General Comments		
544695	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
544696	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
544697	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
544698	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
544699	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
544700	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
544701	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
544702	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
544703	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
544704	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
544705	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
544706	3/6/2019 15:49	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
544707	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
544708	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BAT001085	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
544709	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BAT001085	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
544710	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BAT001085	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
544711	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BAT001085	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
544712	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BAT001085	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
544713	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BAT001085	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
544714	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BAT001085	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
544715	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BAT001085	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
544716	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BAT001085	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
544717	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BAT001085	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
544718	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Follow-up Action Required?	n	
544719	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Follow-up Action Required?	n	
544720	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations Ground	0	
544721	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations C Ø	0	
544722	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations B Ø	1	
544723	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations A Ø	1	
544724	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
544725	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Adjusted Amps B Phase V	16.19	
544726	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Adjusted Amps A Phase V	16.19	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
S44727	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Equipment Properly Labeled?	y	
S44728	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Paint Condition	Good	
S44729	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
S44730	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
S44731	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
S44732	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Bushings Connection/Risers	Good	
S44733	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Bushing Condition	Good	
S44734	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Amps C Ø	110.0	
S44735	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Switching Operations	0	
S44736	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
S44737	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
S44738	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
S44739	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
S44740	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
S44741	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
S44742	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
S44743	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
S44744	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
S44745	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
S44746	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Unknown Operations	0	
S44747	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Tank Paint Condition	Good	
S44748	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Switching Operations	0	
S44749	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
S44750	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
S44751	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
S44752	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
S44753	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
S44754	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
S44755	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
S44756	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
S44757	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
S44758	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
S44759	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
S44760	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
S44761	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Unknown Operations	0	
S44762	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
S44763	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
S44764	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
S44765	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	General Comments		
S44766	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
S44767	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
S44768	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
S44769	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
S44770	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
S44771	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
S44772	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Regulator As Left Counter	204395	
S44773	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
S44774	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Tank Leaks	None	
S44775	3/6/2019 10:00	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
S44776	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	9 Month Operations	1	
S44777	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Accumulated Fault Duty A Ph V	.80	%
S44778	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	General Comments		
S44779	3/6/2019 12:30	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Foundation Condition	Good	
S44780	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
S44781	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
S44782	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
S44783	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Oil Temp Present	35	°C
S44784	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Oil Temp Max	70	°C
S44785	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
S44786	3/6/2019 11:07	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
S44787	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
S44788	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
S44789	3/6/2019 13:07	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
S44790	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BAT001085	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
S44791	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BAT001085	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
S44792	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BAT001085	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
S44793	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Accumulated Fault Duty B Ph V	.80	%
S44794	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Accumulated Fault Duty C Ph V	.80	%
S44795	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
S44796	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Amps A Ø	0.0	
S44797	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
S44798	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
S44799	3/6/2019 11:12	Distribution	Bevier Quarterly Inspection	BAT001085	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.0	VDC
S44800	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
S44801	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
544802	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
544803	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Unknown Operations	0	
544804	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Patrol Inspection	Equipment Properly Labeled?	y	
544805	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Amps C Ø	0.0	
544806	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
544807	3/6/2019 11:39	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Amps B Ø	0.0	
544808	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
544809	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
544810	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
544811	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
544812	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	General Comments		
544813	3/6/2019 9:21	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
544814	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
544815	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
544816	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
544817	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
544818	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
544819	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	6.02	%
544820	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	12.05	%
544821	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	12.05	%
544822	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	14	
544823	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
544824	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
544825	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
544826	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	148	
544827	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	148	
544828	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
544829	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	open	
544830	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	1	
544831	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
544832	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
544833	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
544834	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
544835	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
544836	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
544837	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
544838	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
544839	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	33.54	
544840	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	33.54	
544841	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	33.54	
544842	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	3	
544843	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	3	
544844	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	3	
544845	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
544846	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
544847	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	open	
544848	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
544849	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	252	
544850	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	252	
544851	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
544852	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
544853	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
544854	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
544855	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	4.82	%
544856	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	4.82	%
544857	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	4.82	%
544858	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	10	
544859	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
544860	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
544861	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
544862	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	1	
544863	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
544864	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
544865	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	open	
544866	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
544867	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	38	
544868	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	38	
544869	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
544870	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
544871	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	1	
544872	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	3.61	%
544873	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	9	
544874	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	2.41	%
544875	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	9.64	%
544876	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
544877	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
544878	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
544879	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
544880	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
544881	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
544882	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
544883	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
544884	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
544885	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
544886	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	16.86	%
544887	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	18.07	%
544888	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	6.02	%
544889	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
544890	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
544891	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	15	
544892	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
544893	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
544894	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
544895	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
544896	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
544897	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
544898	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
544899	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
544900	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
544901	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	open	
544902	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
544903	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	302	
544904	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	302	
544905	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
544906	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
544907	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
544908	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
544909	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
544910	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
544911	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
544912	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
544913	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	33.54	
544914	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	33.54	
544915	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	33.54	
544916	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	3	
544917	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	3	
544918	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	3	
544919	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
544920	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
544921	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	19.27	%
544922	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	21.68	%
544923	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	18.07	%
544924	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	26	
544925	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
544926	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1054	
544927	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1054	
544928	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
544929	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	open	
544930	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
544931	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
544932	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
544933	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
544934	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
544935	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
544936	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
544937	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
544938	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
544939	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
544940	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
544941	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	176	
544942	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	176	
544943	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
544944	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	open	
544945	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
544946	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
544947	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
544948	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
544949	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
544950	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
544951	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
544952	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
544953	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
544954	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
544955	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
544956	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
544957	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
544958	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.2078	
544959	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
544960	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
544961	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Cabinet Paint Condition	Good	
544962	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
544963	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
544964	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
544965	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
544966	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
544967	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
544968	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
544969	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
544970	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Equipment Properly Labeled?	y	
544971	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
544972	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	General Comments		
544973	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
544974	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
544975	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
544976	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Fault Operations	0	
544977	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
544978	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
544979	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Clear of Trash?	y	
544980	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
544981	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
544982	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
544983	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
544984	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Clear of Trash?	y	
544985	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
544986	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Ambient Temp	23	°F
544987	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
544988	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
544989	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
544990	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
544991	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
544992	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
544993	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
544994	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
544995	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
544996	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
544997	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
544998	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
544999	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
545000	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
545001	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
545002	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	10.00	
545003	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2174.04	kw
545004	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
545005	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
545006	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
545007	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
545008	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	General Comments		
545009	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	General Comments		
545010	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
545011	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
545012	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
545013	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
545014	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
545015	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
545016	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
545017	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
545018	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
545019	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
545020	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
545021	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	LTC Operations Since Last Insp	637	
545022	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	LTC Min Tap Position	1R	
545023	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	LTC Max Tap Position	6L	
545024	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	120.00	
545025	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Oil Temp Max	35	°C
545026	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Oil Temp Present	35	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
S45027	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
S45028	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
S45029	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
S45030	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
S45031	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Totalizer Meter Reading	.9000	
S45032	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
S45033	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
S45034	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
S45035	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Ambient Temperature	22	°F
S45036	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Bushings Connection/Risers	Good	
S45037	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
S45038	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
S45039	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
S45040	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
S45041	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
S45042	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
S45043	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
S45044	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	LTC As Left Counter	9780	
S45045	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	LTC As Found Counter	9775	
S45046	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Mechanism Patrol Inspection	General Comments		
S45047	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	General Comments		
S45048	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
S45049	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
S45050	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
S45051	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
S45052	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
S45053	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	LTCC000067	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
S45054	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
S45055	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	LTCC000067	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
S45056	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Patrol Inspection	General Comments		
S45057	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Patrol Inspection	Follow-up Action Required?	n	
S45058	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.50	%
S45059	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
S45060	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
S45061	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
S45062	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
S45063	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
S45064	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	717	
S45065	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
S45066	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
S45067	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
S45068	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
S45069	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
S45070	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
S45071	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
S45072	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
S45073	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Patrol Inspection	Equipment Properly Labeled?	y	
S45074	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
S45075	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
S45076	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC As Left Counter	119894	
S45077	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC As Found Counter	119894	
S45078	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
S45079	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
S45080	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
S45081	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
S45082	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
S45083	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Maintenance Operations	0	
S45084	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Heaters (All) Functioning?	y	
S45085	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Oil Temp Present	20	°C
S45086	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Oil Temp Max	40	°C
S45087	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
S45088	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
S45089	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
S45090	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Totalizer Meter Reading	.7030	
S45091	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	LTC Totalizer Reading	2548.80	kw
S45092	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
S45093	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
S45094	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
S45095	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
S45096	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
S45097	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
S45098	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
S45099	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
S45100	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
S45101	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
545102	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Follow-up Action Required?	n	
545103	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Follow-up Action Required?	n	
545104	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
545105	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Foundation Condition	Good	
545106	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Gauge(s) Condition	Good	
545107	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
545108	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	General Comments		
545109	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	General Comments		
545110	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Grounds in Place?	y	
545111	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	Follow-up Action Required?	n	
545112	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
545113	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
545114	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
545115	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Heaters (All) Functioning?	y	
545116	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Maintenance Operations	0	
545117	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Moisture and Leak Free?	y	
545118	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Num Operations Last 9 Months	1	
545119	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Operations Counter AF	46	
545120	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Operations Counter AL	46	
545121	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
545122	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
545123	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
545124	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
545125	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
545126	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
545127	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
545128	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
545129	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
545130	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
545131	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
545132	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
545133	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
545134	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
545135	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	SF6 Bushing Condition	Good	
545136	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	SF6 Pressure	87	psi
545137	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
545138	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Switching Operations	0	
545139	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
545140	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Totalizer Meter Reading	.4248	
545141	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
545142	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
545143	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
545144	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
545145	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	13	
545146	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	7.50	%
545147	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	13.34	%
545148	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Tank Paint Condition	Good	
545149	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
545150	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
545151	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
545152	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
545153	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
545154	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
545155	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
545156	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
545157	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
545158	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
545159	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Patrol Inspection	Follow-up Action Required?	n	
545160	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Patrol Inspection	General Comments		
545161	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	General Comments		
545162	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
545163	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
545164	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
545165	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
545166	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
545167	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Foundation Condition	Good	
545168	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
545169	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
545170	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
545171	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	General Comments		
545172	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
545173	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
545174	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
545175	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
545176	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
S45177	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
S45178	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
S45179	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
S45180	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
S45181	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
S45182	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
S45183	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
S45184	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
S45185	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
S45186	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
S45187	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
S45188	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
S45189	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
S45190	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	10.0	
S45191	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	10.0	
S45192	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	10.0	
S45193	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
S45194	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	General Comments		
S45195	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
S45196	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
S45197	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Panels Dusted?	y	
S45198	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
S45199	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
S45200	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
S45201	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	9 Month Operations	8	
S45202	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Accumulated Fault Duty A Ph V	1.94	%
S45203	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Accumulated Fault Duty B Ph V	2.71	%
S45204	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Accumulated Fault Duty C Ph V	2.71	%
S45205	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
S45206	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
S45207	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
S45208	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
S45209	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
S45210	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
S45211	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	LTC Totalizer Reading	7505.28	kw
S45212	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
S45213	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	General Comments	added nitrogen	
S45214	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	General Comments		
S45215	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
S45216	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
S45217	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
S45218	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
S45219	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
S45220	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Top Oil Temperature Max	30	°C
S45221	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Top Oil Temperature Present	20	°C
S45222	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
S45223	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Follow-up Action Required?	n	
S45224	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
S45225	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
S45226	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
S45227	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
S45228	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
S45229	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
S45230	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
S45231	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
S45232	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
S45233	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
S45234	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
S45235	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
S45236	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Totalizer Meter Reading	.7818	
S45237	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Vegetation	None	
S45238	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
S45239	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
S45240	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
S45241	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	General Comments		
S45242	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
S45243	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
S45244	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
S45245	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
S45246	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
S45247	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
S45248	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
S45249	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
S45250	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
S45251	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
545252	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
545253	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
545254	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
545255	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	63	
545256	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	63	
545257	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
545258	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
545259	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
545260	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
545261	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
545262	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	BCH000209	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
545263	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	BCH000209	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
545264	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	BCH000209	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
545265	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	BCH000209	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
545266	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	BCH000209	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
545267	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
545268	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	General Comments		
545269	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
545270	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
545271	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Operations Counter	742	
545272	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
545273	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	General Comments		
545274	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
545275	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
545276	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
545277	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
545278	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
545279	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
545280	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Amps C Ø	63.0	
545281	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Amps B Ø	55.0	
545282	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Amps A Ø	51.0	
545283	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
545284	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
545285	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
545286	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
545287	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
545288	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
545289	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
545290	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	General Comments		
545291	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	General Comments		
545292	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
545293	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
545294	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
545295	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
545296	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
545297	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
545298	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
545299	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	8640.00	kw
545300	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	128.33	
545301	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
545302	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
545303	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
545304	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
545305	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
545306	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
545307	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Oil Temp Present	26	°C
545308	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
545309	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Amps A Ø	70.0	
545310	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Unknown Operations	0	
545311	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Tank Paint Condition	Good	
545312	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Switching Operations	0	
545313	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	LTCC000067	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
545314	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	LTCC000067	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
545315	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	LTCC000067	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
545316	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	LTCC000067	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
545317	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
545318	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Operations Counter AL	160	
545319	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Operations Counter AF	160	
545320	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
545321	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
545322	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
545323	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Moisture and Leak Free?	y	
545324	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
545325	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
545326	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
545327	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
545328	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
545329	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
545330	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
545331	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	General Comments		
545332	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
545333	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC As Found Counter	19507	
545334	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC As Left Counter	19507	
545335	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
545336	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
545337	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
545338	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
545339	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
545340	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5L	
545341	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
545342	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	240	
545343	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
545344	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
545345	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
545346	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
545347	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Floor Swept?	y	
545348	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
545349	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
545350	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
545351	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Vegetation	None	
545352	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
545353	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
545354	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	General Comments		
545355	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
545356	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Evidence of Insects	None	
545357	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
545358	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
545359	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
545360	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
545361	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
545362	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
545363	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
545364	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
545365	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	General Comments		
545366	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
545367	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
545368	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
545369	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
545370	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
545371	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
545372	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
545373	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
545374	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Amps C Ø	56.0	
545375	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Amps B Ø	56.0	
545376	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Amps A Ø	56.0	
545377	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
545378	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
545379	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
545380	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
545381	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
545382	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	249	
545383	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Amps C Ø	31.2	
545384	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Amps B Ø	22.7	
545385	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Amps A Ø	20.0	
545386	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	120	
545387	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	General Comments		
545388	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	General Comments		
545389	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC As Found Counter	295765	
545390	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC As Left Counter	295770	
545391	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
545392	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
545393	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Max Tap Position	8L	
545394	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Min Tap Position	3R	
545395	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Operations Since Last Insp	702	
545396	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
545397	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
545398	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
545399	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Tank Leaks	None	
545400	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
545401	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
545402	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
545403	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
545404	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
545405	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Regulator As Left Counter	20374	
545406	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
545407	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
545408	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
545409	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
545410	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
545411	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
545412	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
545413	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
545414	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	General Comments		
545415	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
545416	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
545417	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
545418	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
545419	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
545420	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
545421	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
545422	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
545423	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
545424	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
545425	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	PF000003	PowerFuse	AK-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
545426	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	PF000003	PowerFuse	AK-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
545427	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	23	°F
545428	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
545429	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
545430	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
545431	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
545432	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
545433	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
545434	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
545435	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
545436	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
545437	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
545438	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
545439	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
545440	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
545441	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Tank Leaks	None	
545442	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
545443	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Operations Counter	800	
545444	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
545445	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
545446	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	General Comments		
545447	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
545448	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	All Connections OK?	y	
545449	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	Follow-up Action Required?	n	
545450	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	General Comments		
545451	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	LTC Operation Checked?	y	
545452	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	LTC Output Voltage Level	126.0	VAC
545453	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
545454	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	VRR Base Voltage AF	125.5	VAC
545455	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	VRR Base Voltage AL	125.5	VAC
545456	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	VRR Time Delay	30	Seconds
545457	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
545458	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
545459	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Patrol Inspection	General Comments		
545460	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
545461	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
545462	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
545463	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
545464	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
545465	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
545466	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
545467	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
545468	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
545469	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Amps C Ø	56.0	
545470	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Amps B Ø	60.0	
545471	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Amps A Ø	56.0	
545472	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
545473	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
545474	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
545475	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
545476	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
S45477	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
S45478	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
S45479	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	Follow-up Action Required?	n	
S45480	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
S45481	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	PF000309	PowerFuse	PL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
S45482	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	PF000309	PowerFuse	PL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
S45483	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
S45484	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	General Comments		
S45485	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
S45486	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
S45487	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Tank Leaks	None	
S45488	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
S45489	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
S45490	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Regulator As Left Counter	75938	
S45491	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
S45492	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
S45493	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
S45494	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
S45495	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	General Comments		
S45496	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
S45497	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
S45498	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
S45499	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	PF000310	PowerFuse	PL-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
S45500	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	PF000310	PowerFuse	PL-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
S45501	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
S45502	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	285	
S45503	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
S45504	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Tank Leaks	None	
S45505	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
S45506	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Operations Counter	1756	
S45507	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
S45508	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
S45509	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	General Comments		
S45510	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
S45511	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
S45512	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Max Tap Position	12R	
S45513	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
S45514	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
S45515	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
S45516	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
S45517	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
S45518	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
S45519	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
S45520	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
S45521	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
S45522	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
S45523	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
S45524	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
S45525	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
S45526	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
S45527	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
S45528	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
S45529	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
S45530	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
S45531	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
S45532	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
S45533	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
S45534	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
S45535	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
S45536	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
S45537	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
S45538	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
S45539	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
S45540	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
S45541	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
S45542	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
S45543	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Foundation Condition	Good	
S45544	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
S45545	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
S45546	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	General Comments		
S45547	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
S45548	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
S45549	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
S45550	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
S45551	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
545552	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
545553	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
545554	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
545555	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
545556	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
545557	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
545558	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
545559	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
545560	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Clear of Trash?	y	
545561	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
545562	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
545563	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Ambient Temp	22	°F
545564	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
545565	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
545566	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
545567	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
545568	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
545569	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
545570	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
545571	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
545572	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
545573	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
545574	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
545575	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
545576	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
545577	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
545578	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
545579	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
545580	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
545581	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
545582	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
545583	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
545584	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	General Comments		
545585	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
545586	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
545587	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Foundation Condition	Good	
545588	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
545589	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
545590	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
545591	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
545592	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
545593	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
545594	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
545595	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
545596	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
545597	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
545598	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
545599	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
545600	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
545601	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
545602	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
545603	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
545604	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	General Comments		
545605	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
545606	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
545607	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Vegetation	None	
545608	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
545609	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
545610	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	General Comments		
545611	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
545612	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
545613	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
545614	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
545615	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
545616	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
545617	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Clear of Trash?	y	
545618	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
545619	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Ambient Temp	22	°F
545620	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
545621	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Vegetation	None	
545622	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
545623	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
545624	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
545625	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
545626	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
545627	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
545628	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
545629	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
545630	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
545631	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
545632	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
545633	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
545634	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
545635	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
545636	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Ambient Temp	22	°F
545637	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
545638	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
545639	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Clear of Trash?	y	
545640	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
545641	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
545642	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
545643	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
545644	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
545645	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Ambient Temp	23	°F
545646	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
545647	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Clear of Trash?	y	
545648	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
545649	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
545650	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
545651	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
545652	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
545653	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	General Comments		
545654	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
545655	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
545656	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Vegetation	None	
545657	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
545658	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
545659	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	General Comments		
545660	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
545661	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
545662	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
545663	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
545664	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
545665	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Vegetation	None	
545666	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
545667	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Ambient Temp	20	°F
545668	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
545669	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	General Comments	SOUTH FENCE HAS A FEW TREES WITH LIMBS HANGING OVER FENCE	
545670	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
545671	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
545672	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	14.28	%
545673	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	18.04	%
545674	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	12.78	%
545675	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	12.0	
545676	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	12.0	
545677	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	12.0	
545678	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Patrol Inspection	Follow-up Action Required?	n	
545679	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Patrol Inspection	Equipment Properly Labeled?	y	
545680	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Winding Temp Present	20	°C
545681	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Winding Temp Max	30	°C
545682	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Totalizer Meter Reading	.7134	
545683	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
545684	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
545685	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
545686	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
545687	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
545688	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
545689	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
545690	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
545691	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Oil Temp Present	20	°C
545692	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Oil Temp Max	30	°C
545693	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
545694	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
545695	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	1712.16	kw
545696	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
545697	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
545698	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
545699	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
545700	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	General Comments		
545701	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
545702	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
545703	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
545704	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
545705	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
545706	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
545707	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
545708	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
545709	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
545710	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
545711	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
545712	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
545713	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
545714	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
545715	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
545716	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
545717	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
545718	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
545719	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
545720	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
545721	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
545722	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
545723	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
545724	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
545725	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
545726	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
545727	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
545728	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
545729	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
545730	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
545731	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
545732	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
545733	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
545734	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
545735	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
545736	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
545737	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
545738	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
545739	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	26	
545740	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	26	
545741	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
545742	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
545743	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
545744	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
545745	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Patrol Inspection	Equipment Properly Labeled?	y	
545746	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Patrol Inspection	Follow-up Action Required?	n	
545747	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Patrol Inspection	General Comments		
545748	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
545749	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
545750	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
545751	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
545752	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
545753	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
545754	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Oil Temp Max	40	°C
545755	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
545756	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
545757	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	LTC Totalizer Reading	6748.80	kw
545758	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
545759	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	General Comments		
545760	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
545761	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
545762	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
545763	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
545764	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
545765	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	General Comments		
545766	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
545767	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Vegetation	None	
545768	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
545769	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	General Comments		
545770	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
545771	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
545772	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Follow-up Action Required?	n	
545773	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
545774	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
545775	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
545776	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
545777	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
545778	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
545779	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
545780	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
545781	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
545782	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
545783	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
545784	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
545785	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
545786	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
545787	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Totalizer Meter Reading	.6468	
545788	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
545789	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
545790	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Patrol Inspection	General Comments		
545791	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
545792	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
545793	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
545794	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
545795	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
545796	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Oil Temp Present	15	°C
545797	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Oil Temp Max	64	°C
545798	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
545799	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
545800	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	LTC Totalizer Reading	6209.28	kw
545801	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
545802	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	General Comments	added 1 lbs nitrogen	
545803	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	General Comments		
545804	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
545805	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
545806	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Follow-up Action Required?	n	
545807	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
545808	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
545809	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
545810	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
545811	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
545812	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
545813	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
545814	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
545815	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
545816	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
545817	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
545818	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
545819	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
545820	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
545821	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
545822	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
545823	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
545824	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
545825	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
545826	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
545827	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
545828	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
545829	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
545830	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Totalizer Meter Reading	1.1196	
545831	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Winding Temp Max	52	°C
545832	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Winding Temp Present	25	°C
545833	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
545834	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
545835	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
545836	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
545837	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
545838	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
545839	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
545840	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Foundation Condition	Good	
545841	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	General Comments	one insulator chipped..	
545842	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
545843	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Insulators In Good Condition?	n	
545844	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
545845	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
545846	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
545847	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
545848	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
545849	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
545850	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	General Comments		
545851	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
545852	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
545853	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.7	amps
545854	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
545855	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
545856	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
545857	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
545858	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
545859	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	Follow-up Action Required?	n	
545860	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
545861	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	General Comments		
545862	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	General Comments		
545863	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC As Found Counter	15883	
545864	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Positive DC Ground	65.4	VDC
545865	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Negative DC Ground	68.4	VDC
545866	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC As Left Counter	15883	
545867	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
545868	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Current Tap Position	4L	
545869	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Max Tap Position	2L	
545870	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	General Comments		
545871	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Min Tap Position	12L	
545872	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
545873	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
545874	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	21	°C
545875	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	53	°C
545876	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Operations Since Last Insp	777	
545877	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
545878	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
545879	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
545880	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
545881	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
545882	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
545883	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
545884	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
545885	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
545886	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
545887	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
545888	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
545889	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
545890	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
545891	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
545892	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Operations Counter	15	
545893	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
545894	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	General Comments		
545895	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
545896	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
545897	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
545898	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
545899	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
545900	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Amps C Ø	10.0	
545901	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Amps B Ø	14.0	
545902	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Amps A Ø	35.0	
545903	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
545904	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
545905	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
545906	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	General Comments	2 large gaps under fence on side closest to the scrap yard ...top rail getting rusty ...1 bayonet is broken.	
545907	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
545908	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
545909	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
545910	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
545911	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
545912	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
545913	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
545914	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
545915	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
545916	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
545917	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
545918	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
545919	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
545920	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
545921	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
545922	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
545923	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
545924	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Follow-up Action Required?	n	
545925	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
545926	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
545927	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	General Comments		
545928	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	General Comments		
545929	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
545930	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
545931	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
545932	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
545933	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
545934	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
545935	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
545936	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
545937	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
545938	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
545939	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
545940	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
545941	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
545942	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
545943	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
545944	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
545945	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
545946	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
545947	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	General Comments		
545948	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
545949	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
545950	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
545951	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
545952	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
545953	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
545954	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
545955	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
545956	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
545957	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.4	volts
545958	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Regulator As Left Counter	29333	
545959	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
545960	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
545961	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Tank Leaks	None	
545962	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	LTC Totalizer Reading	16122.24	kw
545963	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
545964	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
545965	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
545966	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	700	psi
545967	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Oil Temp Max	51	°C
545968	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Oil Temp Present	24	°C
545969	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
545970	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	BCH001119	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
545971	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	BCH001119	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
545972	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	BCH001119	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
545973	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	BCH001119	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
545974	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
545975	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
545976	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
545977	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
545978	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	BCH001119	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
545979	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	BCH001119	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
545980	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	BCH001119	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.430	millivolts
545981	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
545982	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
545983	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
545984	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
545985	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Unknown Operations	0	
545986	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Tank Paint Condition	Good	
545987	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
545988	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
545989	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
545990	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
545991	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
545992	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
545993	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
545994	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	General Comments		
545995	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
545996	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
545997	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
545998	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
545999	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
546000	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
546001	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Clear of Trash?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
546002	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
546003	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
546004	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
546005	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
546006	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Bushings Connection/Risers	Good	
546007	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Bushing Condition	Good	
546008	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Ambient Temp	22	°F
546009	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Switching Operations	0	
546010	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Operations Counter AL	192	
546011	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Operations Counter AF	192	
546012	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Moisture and Leak Free?	y	
546013	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Tank Leaks	None	
546014	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
546015	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
546016	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
546017	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Amps C Ø	20.0	
546018	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Amps B Ø	20.0	
546019	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Amps A Ø	20.0	
546020	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Accumulated Fault Duty C Ph V	1.67	%
546021	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Accumulated Fault Duty B Ph V	1.67	%
546022	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Accumulated Fault Duty A Ph V	1.67	%
546023	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	9 Month Operations	8	
546024	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
546025	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
546026	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
546027	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
546028	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
546029	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
546030	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
546031	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Current Tap Position	5L	
546032	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
546033	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
546034	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
546035	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Current Tap Position	2L	
546036	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
546037	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
546038	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
546039	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Patrol Inspection	General Comments		
546040	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
546041	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
546042	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
546043	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
546044	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	General Comments		
546045	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
546046	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Max Tap Position	4L	
546047	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Min Tap Position	12L	
546048	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
546049	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
546050	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
546051	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
546052	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
546053	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Regulator As Left Counter	8985	
546054	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
546055	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
546056	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Tank Leaks	None	
546057	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
546058	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
546059	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	General Comments		
546060	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
546061	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
546062	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
546063	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
546064	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
546065	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Regulator As Left Counter	8814	
546066	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
546067	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
546068	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Tank Leaks	None	
546069	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
546070	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
546071	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
546072	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
546073	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
546074	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
546075	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
546076	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
546077	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
546078	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Current Tap Position	3L	
546079	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
546080	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
546081	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
546082	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	General Comments		
546083	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
546084	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Max Tap Position	2L	
546085	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Min Tap Position	11L	
546086	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Bushings Connection/Risers	Good	
546087	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Bushing Condition	Good	
546088	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Amps C Ø	381.0	
546089	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Amps B Ø	369.0	
546090	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Amps A Ø	376.0	
546091	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Unknown Operations	0	
546092	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Tank Paint Condition	Good	
546093	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Switching Operations	4	
546094	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
546095	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
546096	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
546097	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Accumulated Fault Duty A Ph V	.07	%
546098	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	9 Month Operations	0	
546099	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
546100	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
546101	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	62	
546102	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
546103	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
546104	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	67	
546105	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Amps C Ø	41.2	
546106	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Amps B Ø	35.2	
546107	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Amps A Ø	30.0	
546108	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	49	
546109	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Operations Counter AL	247	
546110	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Operations Counter AF	247	
546111	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Moisture and Leak Free?	y	
546112	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Maintenance Operations	0	
546113	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Grounds in Place?	y	
546114	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	General Comments		
546115	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	General Comments		
546116	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Foundation Condition	Good	
546117	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Follow-up Action Required?	n	
546118	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Follow-up Action Required?	n	
546119	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations Ground	0	
546120	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
546121	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Vegetation	None	
546122	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
546123	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
546124	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
546125	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
546126	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
546127	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Regulator As Left Counter	10103	
546128	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
546129	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
546130	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations C Ø	0	
546131	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations B Ø	0	
546132	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations A Ø	0	
546133	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
546134	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
546135	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
546136	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Equipment Properly Labeled?	y	
546137	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Paint Condition	Good	
546138	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Equipment Properly Labeled?	y	
546139	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Paint Condition	Good	
546140	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
546141	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
546142	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
546143	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Bushings Connection/Risers	Good	
546144	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Bushing Condition	Good	
546145	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Amps C Ø	140.0	
546146	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Amps B Ø	180.0	
546147	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Amps A Ø	150.0	
546148	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
546149	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
546150	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
546151	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	9 Month Operations	3	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
546152	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
546153	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
546154	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
546155	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
546156	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
546157	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	General Comments		
546158	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
546159	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Replaced	
546160	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
546161	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
546162	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
546163	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
546164	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
546165	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
546166	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
546167	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
546168	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
546169	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	9 Month Operations	1	
546170	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
546171	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
546172	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
546173	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Amps A Ø	166.0	
546174	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Amps B Ø	169.0	
546175	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Amps C Ø	175.0	
546176	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Bushing Condition	Good	
546177	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Bushings Connection/Risers	Good	
546178	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
546179	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
546180	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
546181	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Paint Condition	Good	
546182	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Equipment Properly Labeled?	y	
546183	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
546184	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
546185	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
546186	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations A Ø	0	
546187	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations B Ø	0	
546188	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations C Ø	0	
546189	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations Ground	0	
546190	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Follow-up Action Required?	n	
546191	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Follow-up Action Required?	n	
546192	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Foundation Condition	Good	
546193	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	General Comments		
546194	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	General Comments		
546195	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Grounds in Place?	y	
546196	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Maintenance Operations	0	
546197	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Moisture and Leak Free?	y	
546198	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Operations Counter AF	174	
546199	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Operations Counter AL	174	
546200	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Switching Operations	0	
546201	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Tank Paint Condition	Good	
546202	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Unknown Operations	0	
546203	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	27	°C
546204	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	45	°C
546205	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
546206	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
546207	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
546208	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
546209	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Unknown Operations	0	
546210	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Tank Paint Condition	Good	
546211	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Switching Operations	4	
546212	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Operations Counter AL	288	
546213	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Operations Counter AF	288	
546214	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Moisture and Leak Free?	y	
546215	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Max Tap Position	1L	
546216	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
546217	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Broom on Site?	n	
546218	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
546219	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
546220	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Maintenance Operations	0	
546221	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Grounds in Place?	y	
546222	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	General Comments		
546223	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	General Comments		
546224	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Foundation Condition	Good	
546225	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Follow-up Action Required?	n	
546226	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
546227	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations Ground	0	
546228	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
546229	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Evidence of Insects	None	
546230	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
546231	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
546232	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Floor Swept?	n	
546233	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
546234	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
546235	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	General Comments		
546236	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
546237	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Trash Emptied?	n	
546238	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Min Tap Position	8L	
546239	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
546240	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
546241	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
546242	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
546243	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
546244	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Regulator As Left Counter	111039	
546245	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
546246	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
546247	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Tank Leaks	None	
546248	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
546249	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
546250	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
546251	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
546252	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
546253	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
546254	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Current Tap Position	1L	
546255	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
546256	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
546257	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
546258	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
546259	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	General Comments		
546260	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
546261	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Max Tap Position	1R	
546262	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Min Tap Position	5L	
546263	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
546264	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
546265	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
546266	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
546267	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
546268	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Regulator As Left Counter	113364	
546269	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
546270	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
546271	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
546272	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
546273	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Tank Leaks	None	
546274	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
546275	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
546276	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
546277	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
546278	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
546279	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
546280	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
546281	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
546282	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
546283	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
546284	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
546285	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
546286	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations C Ø	0	
546287	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations B Ø	0	
546288	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations A Ø	0	
546289	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
546290	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
546291	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
546292	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
546293	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
546294	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
546295	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
546296	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
546297	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
546298	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
546299	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	32060	
546300	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
546301	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
546302	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
546303	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
546304	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC Operations Since Last Insp	480	
546305	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Paint Condition	Good	
546306	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Equipment Properly Labeled?	y	
546307	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Adjusted Amps A Phase V	4.69	
546308	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Adjusted Amps B Phase V	4.69	
546309	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
546310	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations A Ø	1	
546311	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations B Ø	1	
546312	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations C Ø	0	
546313	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations Ground	0	
546314	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Follow-up Action Required?	n	
546315	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Follow-up Action Required?	n	
546316	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Foundation Condition	Good	
546317	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	General Comments		
546318	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	General Comments		
546319	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Grounds in Place?	y	
546320	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Maintenance Operations	0	
546321	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Moisture and Leak Free?	y	
546322	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Operations Counter AF	298	
546323	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Operations Counter AL	298	
546324	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
546325	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Switching Operations	8	
546326	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Tank Paint Condition	Good	
546327	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Unknown Operations	0	
546328	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
546329	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	120.5	VAC
546330	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	120.5	VAC
546331	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	120.3	VAC
546332	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
546333	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
546334	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
546335	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC Min Tap Position	11L	
546336	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
546337	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC Current Tap Position	2L	
546338	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
546339	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC As Left Counter	9563	
546340	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC As Found Counter	9563	
546341	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
546342	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
546343	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	General Comments		
546344	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
546345	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
546346	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
546347	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
546348	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
546349	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
546350	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
546351	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
546352	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
546353	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
546354	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
546355	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
546356	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
546357	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
546358	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
546359	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
546360	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	General Comments		
546361	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	General Comments		
546362	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
546363	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	Follow-up Action Required?	n	
546364	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
546365	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
546366	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	General Comments		
546367	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
546368	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Tank Leaks	None	
546369	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BCH000497	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
546370	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BCH000497	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
546371	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BCH000497	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
546372	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BCH000497	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
546373	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BCH000497	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
546374	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BCH000497	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
546375	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
546376	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
546377	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
546378	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Operations Since Last Insp	807	
546379	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Min Tap Position	9L	
546380	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Max Tap Position	4R	
546381	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Current Tap Position	2L	
546382	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
546383	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC As Left Counter	187892	
546384	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC As Found Counter	187885	
546385	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	General Comments		
546386	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	General Comments		
546387	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
546388	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	Follow-up Action Required?	n	
546389	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
546390	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
546391	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
546392	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Operations Since Last Insp	426	
546393	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Min Tap Position	10L	
546394	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
546395	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Current Tap Position	4L	
546396	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
546397	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC As Left Counter	55968	
546398	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC As Found Counter	55957	
546399	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	General Comments		
546400	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	General Comments		
546401	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
546402	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	Follow-up Action Required?	n	
546403	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
546404	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
546405	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
546406	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
546407	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
546408	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
546409	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	9 Month Operations	18	
546410	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Accumulated Fault Duty A Ph V	4.51	%
546411	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Accumulated Fault Duty B Ph V	3.76	%
546412	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Accumulated Fault Duty C Ph V	4.51	%
546413	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Amps A Ø	120.0	
546414	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
546415	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Amps B Ø	180.0	
546416	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Amps C Ø	120.0	
546417	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
546418	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
546419	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
546420	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
546421	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
546422	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	Follow-up Action Required?	n	
546423	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
546424	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
546425	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	General Comments		
546426	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	General Comments	has breather installed	
546427	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
546428	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	LTC Totalizer Reading	6730.56	kw
546429	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
546430	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
546431	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	Oil Temp Max	40	°C
546432	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	Oil Temp Present	20	°C
546433	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
546434	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
546435	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
546436	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
546437	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
546438	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
546439	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
546440	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
546441	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	Totalizer Meter Reading	.9348	
546442	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
546443	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
546444	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Bushing Condition	Good	
546445	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Bushings Connection/Risers	Good	
546446	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
546447	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
546448	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
546449	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
546450	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
546451	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
546452	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
546453	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
546454	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
546455	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
546456	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	10.52	%
546457	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	12.78	%
546458	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	7.52	%
546459	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
546460	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
546461	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Tank Paint Condition	Good	
546462	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
546463	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
546464	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
546465	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
546466	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
546467	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
546468	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	General Comments		
546469	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
546470	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Switching Operations	0	
546471	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
546472	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Operations Counter AL	175	
546473	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Operations Counter AF	175	
546474	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Moisture and Leak Free?	y	
546475	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Maintenance Operations	0	
546476	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Heaters (All) Functioning?	y	
546477	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Grounds in Place?	y	
546478	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	General Comments		
546479	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	General Comments		
546480	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Foundation Condition	Good	
546481	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Follow-up Action Required?	n	
546482	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Follow-up Action Required?	n	
546483	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations Ground	0	
546484	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations C Ø	0	
546485	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations B Ø	0	
546486	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations A Ø	0	
546487	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
546488	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
546489	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
546490	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
546491	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
546492	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
546493	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
546494	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
546495	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
546496	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
546497	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
546498	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
546499	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
546500	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments		
546501	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
546502	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
546503	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
546504	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
546505	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
546506	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
546507	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
546508	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Equipment Properly Labeled?	y	
546509	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Paint Condition	Good	
546510	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
546511	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
546512	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
546513	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
546514	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Current Tap Position	6L	
546515	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
546516	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
546517	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
546518	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	General Comments		
546519	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
546520	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Max Tap Position	5L	
546521	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Min Tap Position	13L	
546522	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
546523	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
546524	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Operations Counter	1434	
546525	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
546526	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
546527	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	General Comments		
546528	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
546529	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
546530	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
546531	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
546532	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
546533	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
546534	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
546535	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
546536	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
546537	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Amps C Ø	56.0	
546538	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Amps B Ø	56.0	
546539	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
546540	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC As Found Counter	161054	
546541	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC As Left Counter	161054	
546542	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
546543	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
546544	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4L	
546545	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
546546	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
546547	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	732	
546548	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
546549	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
546550	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
546551	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Amps A Ø	56.0	
546552	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
546553	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	320	
546554	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
546555	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
546556	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
546557	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
546558	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
546559	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
546560	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
546561	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
546562	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
546563	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Patrol Inspection	Equipment Properly Labeled?	y	
546564	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
546565	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
546566	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
546567	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
546568	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Patrol Inspection	Follow-up Action Required?	n	
546569	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Patrol Inspection	General Comments		
546570	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
546571	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
546572	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
546573	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
546574	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
546575	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
546576	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
546577	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
546578	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
546579	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
546580	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
546581	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
546582	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
546583	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
546584	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
546585	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
546586	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
546587	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
546588	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
546589	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
546590	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
546591	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
546592	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
546593	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Unknown Operations	0	
546594	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
546595	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
546596	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
546597	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
546598	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
546599	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
546600	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2100	psi
546601	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
546602	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
546603	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Operations Counter AF	148	
546604	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Operations Counter AL	148	
546605	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Switching Operations	0	
546606	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Tank Paint Condition	Good	
546607	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Unknown Operations	0	
546608	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Regulator As Left Counter	114382	
546609	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
546610	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
546611	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Tank Leaks	None	
546612	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
546613	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
546614	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
546615	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
546616	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
546617	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
546618	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Bushings Connection/Risers	Good	
546619	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
546620	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Ventilation Free of Debris?	y	
546621	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Moisture and Leak Free?	y	
546622	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	General Comments	one bulb in light needs replaced	
546623	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
546624	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Follow-up Action Required?	n	
546625	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
546626	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000114	LTCControl	PL-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
546627	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Floor Swept?	n	
546628	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Floor Condition Acceptable?	y	
546629	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
546630	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Bushing Condition	Good	
546631	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Amps C Ø	45.0	
546632	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
546633	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
546634	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
546635	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000114	LTCControl	PL-TRANS 1	LTC Control Insp	General Comments	OK	
546636	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
546637	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
546638	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
546639	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
546640	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
546641	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
546642	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
546643	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
546644	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
546645	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
546646	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
546647	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
546648	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
546649	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
546650	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	General Comments		
546651	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
546652	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Foundation Condition	Good	
546653	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
546654	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
546655	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
546656	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
546657	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
546658	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Patrol Inspection	Follow-up Action Required?	n	
546659	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Patrol Inspection	General Comments		
546660	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
546661	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
546662	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
546663	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
546664	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
546665	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
546666	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
546667	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
546668	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
546669	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations A Ø	0	
546670	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Ambient Temp	25	°F
546671	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
546672	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Clear of Trash?	y	
546673	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
546674	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
546675	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
546676	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
546677	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
546678	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
546679	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
546680	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
546681	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
546682	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
546683	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
546684	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
546685	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
546686	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
546687	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
546688	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	50	°C
546689	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	20	°C
546690	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	20	°C
546691	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	20	°C
546692	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	50	°C
546693	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
546694	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Patrol Inspection	General Comments		
546695	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	20	°C
546696	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Patrol Inspection	Follow-up Action Required?	n	
546697	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Patrol Inspection	Equipment Properly Labeled?	y	
546698	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
546699	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
546700	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Current Tap Position	3L	
546701	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
546702	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
546703	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
546704	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
546705	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	General Comments		
546706	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
546707	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Max Tap Position	2L	
546708	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Min Tap Position	8L	
546709	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
546710	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	General Comments		
546711	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
546712	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	VRR Time Delay	60	Seconds
546713	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
546714	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
546715	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
546716	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
546717	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	LTC Operation Checked?	y	
546718	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	General Comments		
546719	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	Follow-up Action Required?	n	
546720	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	All Connections OK?	y	
546721	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	9 Month Operations	2	
546722	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
546723	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
546724	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
546725	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Amps A Ø	646.0	
546726	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Amps B Ø	642.0	
546727	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Amps C Ø	629.0	
546728	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Foundation Condition	Good	
546729	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
546730	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
546731	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Bushing Condition	Good	
546732	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
546733	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
546734	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
546735	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
546736	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
546737	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
546738	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
546739	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
546740	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
546741	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
546742	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
546743	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
546744	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
546745	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
546746	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
546747	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
546748	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
546749	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Operations A Ø	0	
546750	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Operations B Ø	0	
546751	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
546752	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Operations Ground	0	
546753	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Follow-up Action Required?	n	
546754	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Follow-up Action Required?	n	
546755	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Foundation Condition	Good	
546756	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	General Comments		
546757	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	General Comments		
546758	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Grounds in Place?	y	
546759	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations A Ø	0	
546760	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations B Ø	0	
546761	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations C Ø	0	
546762	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations Ground	0	
546763	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Follow-up Action Required?	n	
546764	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Follow-up Action Required?	n	
546765	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Foundation Condition	Good	
546766	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
546767	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	General Comments		
546768	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	General Comments		
546769	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Grounds in Place?	y	
546770	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
546771	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
546772	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
546773	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Patrol Inspection	Grounds in Place?	y	
546774	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Patrol Inspection	General Comments		
546775	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Patrol Inspection	Follow-up Action Required?	n	
546776	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
546777	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
546778	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	General Comments		
546779	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
546780	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
546781	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
546782	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
546783	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
546784	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
546785	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
546786	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations C Ø	0	
546787	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations Ground	0	
546788	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	LTCC000067	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
546789	3/5/2019 11:22	Distribution	Denham Street Quarterly Inspection	LTCC000067	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
546790	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Follow-up Action Required?	n	
546791	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Follow-up Action Required?	n	
546792	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Foundation Condition	Good	
546793	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	General Comments		
546794	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
546795	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
546796	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
546797	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
546798	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
546799	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
546800	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Maintenance Operations	0	
546801	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Moisture and Leak Free?	y	
546802	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Operations Counter AF	183	
546803	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Operations Counter AL	183	
546804	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Switching Operations	0	
546805	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Tank Paint Condition	Good	
546806	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Unknown Operations	0	
546807	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
546808	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Adequate	
546809	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
546810	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	General Comments		
546811	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Grounds in Place?	y	
546812	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
546813	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
546814	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
546815	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
546816	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
546817	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
546818	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
546819	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
546820	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
546821	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
546822	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
546823	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
546824	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
546825	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
546826	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
546827	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
546828	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
546829	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
546830	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
546831	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
546832	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Follow-up Action Required?	n	
546833	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
546834	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
546835	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	General Comments		
546836	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	General Comments		
546837	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
546838	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
546839	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
546840	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
546841	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	General Comments		
546842	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
546843	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
546844	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Foundation Condition	Good	
546845	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
546846	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
546847	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
546848	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
546849	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
546850	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
546851	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
546852	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	General Comments		
546853	3/5/2019 10:38	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Vegetation	None	
546854	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
546855	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
546856	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
546857	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
546858	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
546859	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
546860	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
546861	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
546862	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
546863	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
546864	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
546865	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
546866	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
546867	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
546868	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
546869	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
546870	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
546871	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
546872	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
546873	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
546874	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
546875	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
546876	3/5/2019 10:54	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
546877	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
546878	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
546879	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
546880	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	9 Month Operations	2	
546881	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Accumulated Fault Duty A Ph V	1.29	%
546882	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Amps B Ø	40.0	
546883	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Evidence of Insects	None	
546884	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Doors and Locks Secure?	y	
546885	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
546886	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Control House Lighting OK?	y	
546887	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Broom on Site?	n	
546888	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Accumulated Fault Duty B Ph V	.64	%
546889	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
546890	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Accumulated Fault Duty C Ph V	.64	%
546891	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Amps A Ø	150.0	
546892	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Amps B Ø	120.0	
546893	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Amps C Ø	130.0	
546894	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Bushing Condition	Good	
546895	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Bushings Connection/Risers	Good	
546896	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
546897	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
546898	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
546899	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations B Ø	0	
546900	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
546901	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
546902	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
546903	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
546904	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
546905	3/5/2019 11:04	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
546906	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
546907	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Paint Condition	Good	
546908	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Equipment Properly Labeled?	y	
546909	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
546910	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
546911	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
546912	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	General Comments		
546913	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
546914	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
546915	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
546916	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
546917	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
546918	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
546919	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	PF000001	PowerFuse	AK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
546920	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
546921	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
546922	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
546923	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
546924	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	9 Month Operations	4	
546925	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	General Comments		
546926	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
546927	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
546928	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
546929	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	LTC Operation Checked?	y	
546930	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
546931	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
546932	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
546933	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	VRR Time Delay	30	Seconds
546934	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	PF000001	PowerFuse	AK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
546935	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
546936	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	General Comments		
546937	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Temp alarms going to annu in TR control cabnite are isolated and need to be fixed sending in alarms when it should not be	
546938	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
546939	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	45	°C
546940	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	27	°C
546941	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
546942	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
546943	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	Oil Temp Present	27	°C
546944	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
546945	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
546946	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
546947	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
546948	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
546949	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Adjusted Amps B Phase V	5.20	
546950	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Adjusted Amps C Phase V	5.20	
546951	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations A Ø	0	
546952	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations B Ø	1	
546953	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	25	°F
546954	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
546955	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
546956	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
546957	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
546958	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
546959	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
546960	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
546961	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
546962	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
546963	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
546964	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
546965	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
546966	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
546967	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations A Ø	0	
546968	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations B Ø	0	
546969	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations C Ø	0	
546970	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations Ground	0	
546971	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Follow-up Action Required?	n	
546972	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Follow-up Action Required?	n	
546973	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Foundation Condition	Good	
546974	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	General Comments		
546975	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	General Comments		
546976	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	PF000002	PowerFuse	AK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
546977	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	PF000002	PowerFuse	AK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
546978	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	PF000004	PowerFuse	AK-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
546979	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	PF000004	PowerFuse	AK-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
546980	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
546981	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
546982	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
546983	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
546984	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	9 Month Operations	10	
546985	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Accumulated Fault Duty A Ph V	6.07	%
546986	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Accumulated Fault Duty B Ph V	7.90	%
546987	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Accumulated Fault Duty C Ph V	4.86	%
546988	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Amps A Ø	100.0	
546989	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Amps B Ø	128.0	
546990	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Amps C Ø	96.0	
546991	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Bushing Condition	Good	
546992	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Bushings Connection/Risers	Good	
546993	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
546994	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Accumulated Fault Duty A Ph V	.32	%
546995	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
546996	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
546997	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Amps A Ø	250.0	
546998	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Amps B Ø	290.0	
546999	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Amps C Ø	240.0	
547000	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
547001	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
547002	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
547003	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
547004	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
547005	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
547006	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
547007	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
547008	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
547009	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Foundation Condition	Good	
547010	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
547011	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
547012	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	General Comments		
547013	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
547014	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
547015	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
547016	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
547017	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
547018	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
547019	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
547020	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Paint Condition	Good	
547021	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Equipment Properly Labeled?	y	
547022	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
547023	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
547024	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
547025	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
547026	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
547027	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
547028	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
547029	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
547030	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
547031	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
547032	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
547033	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
547034	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Bushing Condition	Good	
547035	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	Follow-up Action Required?	n	
547036	3/5/2019 12:34	Distribution	Eastview Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	All Connections OK?	y	
547037	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Equipment Properly Labeled?	y	
547038	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
547039	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
547040	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Paint Condition	Good	
547041	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
547042	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
547043	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
547044	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
547045	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
547046	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
547047	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
547048	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
547049	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations Ground	0	
547050	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
547051	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
S47052	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
S47053	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Maintenance Operations	0	
S47054	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
S47055	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
S47056	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Follow-up Action Required?	n	
S47057	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Follow-up Action Required?	n	
S47058	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Grounds in Place?	y	
S47059	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	27	°C
S47060	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
S47061	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
S47062	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Foundation Condition	Good	
S47063	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
S47064	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	General Comments		
S47065	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Patrol Inspection	Equipment Properly Labeled?	y	
S47066	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Patrol Inspection	Follow-up Action Required?	n	
S47067	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Patrol Inspection	General Comments		
S47068	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	General Comments		
S47069	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
S47070	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
S47071	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
S47072	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
S47073	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
S47074	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
S47075	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
S47076	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Adequate	
S47077	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
S47078	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
S47079	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Grounds in Place?	y	
S47080	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations C Ø	1	
S47081	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	45	°C
S47082	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Maintenance Operations	0	
S47083	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Moisture and Leak Free?	y	
S47084	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Operations Counter AF	249	
S47085	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Operations Counter AL	249	
S47086	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Switching Operations	0	
S47087	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Tank Paint Condition	Good	
S47088	3/5/2019 12:23	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Unknown Operations	0	
S47089	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
S47090	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
S47091	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
S47092	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
S47093	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
S47094	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1211	
S47095	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Bushings Connection/Risers	Good	
S47096	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
S47097	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	27	°C
S47098	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	45	°C
S47099	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
S47100	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
S47101	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Paint Condition	Good	
S47102	3/5/2019 11:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Equipment Properly Labeled?	y	
S47103	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1211	
S47104	3/5/2019 13:50	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
S47105	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
S47106	3/5/2019 12:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
S47107	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	General Comments		
S47108	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
S47109	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
S47110	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
S47111	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
S47112	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
S47113	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
S47114	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
S47115	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
S47116	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
S47117	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
S47118	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
S47119	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
S47120	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Operations Counter	1490	
S47121	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
S47122	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
S47123	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
S47124	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	5.0	
S47125	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
S47126	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	5.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
547127	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	5.0	
547128	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	General Comments		
547129	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
547130	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
547131	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	456	
547132	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
547133	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
547134	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
547135	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
547136	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
547137	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
547138	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	11	
547139	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	12	
547140	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	14	
547141	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
547142	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Operations Counter AL	208	
547143	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Switching Operations	2	
547144	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Tank Paint Condition	Good	
547145	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Unknown Operations	0	
547146	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	General Comments		
547147	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Patrol Inspection	General Comments	ok	
547148	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Maintenance Operations	0	
547149	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
547150	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Equipment Properly Labeled?	y	
547151	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
547152	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Bushings Connection/Risers	Good	
547153	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Operations Counter AF	154	
547154	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Amps C Ø	419	
547155	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Operations Counter AF	208	
547156	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
547157	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Bushing Condition	Good	
547158	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
547159	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
547160	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
547161	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
547162	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
547163	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Bushing Condition	Good	
547164	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
547165	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations A Ø	0	
547166	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations B Ø	0	
547167	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Tank Paint Condition	Good	
547168	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Unknown Operations	0	
547169	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations C Ø	0	
547170	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations Ground	0	
547171	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Follow-up Action Required?	n	
547172	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Follow-up Action Required?	n	
547173	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Adjusted Amps A Phase V	0	
547174	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Foundation Condition	Good	
547175	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	General Comments		
547176	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
547177	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Equipment Properly Labeled?	y	
547178	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
547179	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
547180	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
547181	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
547182	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
547183	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
547184	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
547185	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Heaters (All) Functioning?	y	
547186	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Grounds in Place?	y	
547187	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	General Comments		
547188	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	General Comments		
547189	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Foundation Condition	Good	
547190	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Follow-up Action Required?	n	
547191	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Maintenance Operations	0	
547192	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Paint Condition	Good	
547193	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
547194	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations Ground	0	
547195	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Follow-up Action Required?	n	
547196	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
547197	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations B Ø	0	
547198	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations C Ø	0	
547199	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations Ground	0	
547200	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Follow-up Action Required?	n	
547201	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
547202	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Foundation Condition	Good	
547203	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	General Comments		
547204	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	General Comments		
547205	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Grounds in Place?	y	
547206	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Heaters (All) Functioning?	y	
547207	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
547208	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Accumulated Fault Duty C Ph V	0	%
547209	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Maintenance Operations	0	
547210	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Moisture and Leak Free?	y	
547211	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Operations Counter AF	190	
547212	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Bushing Condition	Good	
547213	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
547214	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Operations Counter AL	190	
547215	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Switching Operations	0	
547216	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
547217	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
547218	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
547219	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1	psi
547220	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Operations Since Last Insp	486	
547221	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
547222	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations A Ø	0	
547223	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
547224	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
547225	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Amps A Ø	429	
547226	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Amps B Ø	460	
547227	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
547228	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Moisture and Leak Free?	y	
547229	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Operations Counter AF	206	
547230	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
547231	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations Ground	0	
547232	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
547233	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
547234	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
547235	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
547236	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Bushings Connection/Risers	Good	
547237	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Bushing Condition	Good	
547238	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Amps C Ø	50.0	
547239	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Amps B Ø	50.0	
547240	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Amps A Ø	50.0	
547241	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Accumulated Fault Duty C Ph V	12.52	%
547242	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Accumulated Fault Duty B Ph V	9.57	%
547243	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Accumulated Fault Duty A Ph V	11.04	%
547244	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	9 Month Operations	6	
547245	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
547246	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations C Ø	0	
547247	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations B Ø	0	
547248	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations A Ø	0	
547249	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Adjusted Amps C Phase V	0	
547250	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Adjusted Amps B Phase V	0	
547251	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Adjusted Amps A Phase V	0	
547252	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Equipment Properly Labeled?	y	
547253	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Paint Condition	Good	
547254	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
547255	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
547256	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
547257	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Bushings Connection/Risers	Good	
547258	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Bushing Condition	Good	
547259	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Amps C Ø	249	
547260	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Amps B Ø	295	
547261	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Amps A Ø	244	
547262	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Accumulated Fault Duty C Ph V	.76	%
547263	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Accumulated Fault Duty B Ph V	.38	%
547264	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Accumulated Fault Duty A Ph V	1.13	%
547265	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	9 Month Operations	4	
547266	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	9 Month Operations	9	
547267	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
547268	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
547269	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Unknown Operations	0	
547270	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
547271	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
547272	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	16	
547273	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Accumulated Fault Duty A Ph V	1.70	%
547274	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Accumulated Fault Duty B Ph V	1.70	%
547275	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Accumulated Fault Duty C Ph V	1.70	%
547276	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Amps A Ø	80.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
547277	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Amps B Ø	20.0	
547278	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Amps C Ø	20.0	
547279	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
547280	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
547281	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
547282	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	16	
547283	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations A Ø	0	
547284	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations B Ø	0	
547285	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations C Ø	0	
547286	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations Ground	0	
547287	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Follow-up Action Required?	n	
547288	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	General Comments		
547289	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Maintenance Operations	0	
547290	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
547291	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
547292	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	1.93	%
547293	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	General Comments		
547294	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Grounds in Place?	y	
547295	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Maintenance Operations	0	
547296	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Moisture and Leak Free?	y	
547297	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Operations Counter AF	165	
547298	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Operations Counter AL	165	
547299	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Switching Operations	0	
547300	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Tank Paint Condition	Good	
547301	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Unknown Operations	0	
547302	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
547303	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
547304	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Min Tap Position	8L	
547305	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
547306	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
547307	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
547308	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Amps C Ø	260.0	
547309	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Accumulated Fault Duty B Ph V	0	%
547310	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
547311	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Max Tap Position	4L	
547312	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Current Tap Position	4L	
547313	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
547314	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC As Left Counter	6934	
547315	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC As Found Counter	6934	
547316	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
547317	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
547318	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	General Comments		
547319	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	General Comments		
547320	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
547321	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	Follow-up Action Required?	n	
547322	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
547323	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Amps C Ø	180.0	
547324	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Amps B Ø	250.0	
547325	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Amps A Ø	170.0	
547326	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Accumulated Fault Duty C Ph V	2.19	%
547327	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Accumulated Fault Duty B Ph V	.88	%
547328	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Unknown Operations	0	
547329	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Accumulated Fault Duty A Ph V	0	%
547330	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	9 Month Operations	0	
547331	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Switching Operations	4	
547332	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Accumulated Fault Duty A Ph V	1.31	%
547333	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Operations Counter AL	735	
547334	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	9 Month Operations	10	
547335	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Operations Counter AF	731	
547336	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Operations Counter AL	208	
547337	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Switching Operations	0	
547338	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Tank Paint Condition	Good	
547339	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Paint Condition	Good	
547340	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
547341	3/4/2019 13:33	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
547342	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Amps B Ø	275.0	
547343	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Amps A Ø	295.0	
547344	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	1.93	%
547345	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	1.93	%
547346	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
547347	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
547348	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
547349	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	130	
547350	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	130	
547351	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	130	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
547352	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
547353	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
547354	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Amps B Ø	185.0	
547355	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Amps C Ø	180.0	
547356	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Bushing Condition	Good	
547357	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Bushings Connection/Risers	Good	
547358	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
547359	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
547360	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	Follow-up Action Required?	n	
547361	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
547362	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	General Comments		
547363	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	General Comments		
547364	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC As Found Counter	14637	
547365	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC As Left Counter	14637	
547366	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
547367	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Current Tap Position	10L	
547368	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Max Tap Position	6L	
547369	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Min Tap Position	12L	
547370	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Operations Since Last Insp	318	
547371	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
547372	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
547373	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
547374	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
547375	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations A Ø	0	
547376	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations B Ø	0	
547377	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations C Ø	0	
547378	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
547379	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
547380	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
547381	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
547382	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
547383	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	320.0	
547384	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	335.0	
547385	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations Ground	0	
547386	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Follow-up Action Required?	n	
547387	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Follow-up Action Required?	n	
547388	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
547389	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
547390	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
547391	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	General Comments		
547392	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	General Comments	LTC PRD alarm on annciator will not clear in Transformer CCC	
547393	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
547394	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
547395	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
547396	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1800	psi
547397	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	Oil Temp Max	57	°C
547398	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	Oil Temp Present	17	°C
547399	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
547400	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
547401	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
547402	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
547403	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
547404	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Foundation Condition	Good	
547405	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
547406	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
547407	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
547408	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
547409	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	51	°C
547410	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	9	°C
547411	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	57	°C
547412	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	General Comments		
547413	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	360.0	
547414	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
547415	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
547416	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
547417	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
547418	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
547419	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
547420	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
547421	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	General Comments		
547422	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
547423	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
547424	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
547425	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
547426	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
547427	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
547428	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
547429	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
547430	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
547431	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
547432	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
547433	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
547434	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	LTC Totalizer Reading	11396.16	kw
547435	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
547436	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	General Comments		
547437	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	General Comments		
547438	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
547439	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
547440	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Follow-up Action Required?	n	
547441	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	9 Month Operations	1	
547442	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
547443	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
547444	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
547445	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
547446	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
547447	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
547448	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
547449	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
547450	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
547451	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
547452	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
547453	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
547454	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	General Comments		
547455	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
547456	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Amps A Ø	858.0	
547457	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Amps B Ø	875.0	
547458	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
547459	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Amps C Ø	861.0	
547460	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Bushing Condition	Good	
547461	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
547462	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2000	psi
547463	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Oil Temp Max	40	°C
547464	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Oil Temp Present	30	°C
547465	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
547466	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
547467	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
547468	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
547469	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
547470	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
547471	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
547472	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
547473	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Totalizer Meter Reading	.7914	
547474	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Winding Temp Max	45	°C
547475	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Winding Temp Present	30	°C
547476	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
547477	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
547478	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
547479	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
547480	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
547481	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
547482	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
547483	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
547484	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
547485	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
547486	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
547487	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
547488	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
547489	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
547490	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
547491	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Amps A Ø	190.0	
547492	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations A Ø	0	
547493	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations B Ø	0	
547494	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations C Ø	0	
547495	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Fault Operations	0	
547496	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Follow-up Action Required?	n	
547497	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Follow-up Action Required?	n	
547498	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Foundation Condition	Good	
547499	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Gauge(s) Condition	Good	
547500	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	General Comments		
547501	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
S47502	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Follow-up Action Required?	n	
S47503	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Follow-up Action Required?	n	
S47504	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	All Connections OK?	y	
S47505	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	Follow-up Action Required?	n	
S47506	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	General Comments		
S47507	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	LTC Operation Checked?	y	
S47508	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	LTC Output Voltage Level	124	VAC
S47509	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
S47510	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	VRR Base Voltage AF	124	VAC
S47511	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	VRR Base Voltage AL	124	VAC
S47512	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	VRR Time Delay	30	Seconds
S47513	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Foundation Condition	Good	
S47514	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	General Comments		
S47515	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	General Comments	y	
S47516	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	9 Month Operations	9	
S47517	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Accumulated Fault Duty A Ph V	15.32	%
S47518	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Accumulated Fault Duty B Ph V	11.92	%
S47519	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Accumulated Fault Duty C Ph V	11.92	%
S47520	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Amps A Ø	180.0	
S47521	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Amps B Ø	200.0	
S47522	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Amps C Ø	180.0	
S47523	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
S47524	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
S47525	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Grounds in Place?	y	
S47526	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
S47527	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Heaters (All) Functioning?	y	
S47528	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations A Ø	0	
S47529	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations B Ø	0	
S47530	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations C Ø	0	
S47531	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations Ground	0	
S47532	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	9 Month Operations	6	
S47533	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Accumulated Fault Duty A Ph V	.64	%
S47534	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Accumulated Fault Duty B Ph V	.32	%
S47535	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Follow-up Action Required?	n	
S47536	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
S47537	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Maintenance Operations	0	
S47538	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Maintenance Operations	0	
S47539	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Operations Counter AL	154	
S47540	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations Ground	0	
S47541	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations C Ø	0	
S47542	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Moisture and Leak Free?	y	
S47543	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Num Operations Last 9 Months	1	
S47544	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	General Comments		
S47545	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Accumulated Fault Duty C Ph V	.96	%
S47546	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Amps A Ø	39.0	
S47547	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Amps B Ø	46.0	
S47548	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Amps C Ø	53.0	
S47549	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Operations Counter AF	41	
S47550	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Operations Counter AL	41	
S47551	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	SF6 Bushing Condition	Good	
S47552	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	SF6 Pressure	67	psi
S47553	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	SF6 Pressure Indicator	good	
S47554	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
S47555	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Switching Operations	0	
S47556	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Tank Paint Condition	Good	
S47557	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations B Ø	0	
S47558	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations A Ø	0	
S47559	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Adjusted Amps C Phase V	0	
S47560	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Adjusted Amps B Phase V	0	
S47561	3/4/2019 13:33	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
S47562	3/4/2019 13:33	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
S47563	3/4/2019 13:33	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.1	VDC
S47564	3/4/2019 13:33	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.1	VDC
S47565	3/4/2019 13:33	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
S47566	3/4/2019 13:33	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
S47567	3/4/2019 13:33	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
S47568	3/4/2019 13:33	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
S47569	3/4/2019 13:33	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
S47570	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
S47571	3/4/2019 13:33	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
S47572	3/4/2019 13:33	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
S47573	3/4/2019 13:33	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
S47574	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Grounds in Place?	y	
S47575	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
S47576	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
547577	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
547578	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Paint Condition	Good	
547579	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
547580	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
547581	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
547582	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
547583	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	17	°C
547584	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	58	°C
547585	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	18	°C
547586	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
547587	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
547588	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
547589	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
547590	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
547591	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
547592	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
547593	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	9	
547594	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	64	
547595	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	64	
547596	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Unknown Operations	0	
547597	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Tank Paint Condition	Good	
547598	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Switching Operations	0	
547599	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Operations Counter AL	177	
547600	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	9 Month Operations	0	
547601	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
547602	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
547603	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
547604	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Operations Counter AF	177	
547605	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
547606	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Maintenance Operations	0	
547607	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
547608	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Grounds in Place?	y	
547609	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	General Comments		
547610	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	General Comments		
547611	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Foundation Condition	Good	
547612	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Equipment Properly Labeled?	y	
547613	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Follow-up Action Required?	n	
547614	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Follow-up Action Required?	n	
547615	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Ambient Temperature	21	°F
547616	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Bushings Connection/Risers	Good	
547617	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
547618	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
547619	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Cabinet Paint Condition	Good	
547620	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Equipment Properly Labeled?	y	
547621	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	9 Month Operations	5	
547622	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Accumulated Fault Duty A Ph V	2.03	%
547623	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Accumulated Fault Duty B Ph V	2.44	%
547624	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Accumulated Fault Duty C Ph V	2.03	%
547625	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Unknown Operations	0	
547626	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Switching Operations	0	
547627	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
547628	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
547629	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
547630	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
547631	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
547632	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
547633	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
547634	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
547635	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	9 Month Operations	6	
547636	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Accumulated Fault Duty A Ph V	2.44	%
547637	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Accumulated Fault Duty B Ph V	2.85	%
547638	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Accumulated Fault Duty C Ph V	2.03	%
547639	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Amps A Ø	345.0	
547640	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Amps B Ø	360.0	
547641	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Amps C Ø	355.0	
547642	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Bushing Condition	Good	
547643	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Bushings Connection/Risers	Good	
547644	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
547645	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
547646	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
547647	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Paint Condition	Good	
547648	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Equipment Properly Labeled?	y	
547649	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
547650	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
547651	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
547652	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations A Ø	0	
547653	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations B Ø	0	
547654	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations C Ø	0	
547655	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations Ground	0	
547656	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Follow-up Action Required?	n	
547657	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Follow-up Action Required?	n	
547658	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Foundation Condition	Good	
547659	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	General Comments		
547660	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	General Comments		
547661	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Grounds in Place?	y	
547662	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Heaters (All) Functioning?	y	
547663	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Maintenance Operations	0	
547664	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Moisture and Leak Free?	y	
547665	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Operations Counter AF	166	
547666	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Operations Counter AL	166	
547667	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
547668	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Switching Operations	0	
547669	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Tank Paint Condition	Good	
547670	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Unknown Operations	0	
547671	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Moisture and Leak Free?	y	
547672	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Operations Counter AF	238	
547673	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Operations Counter AL	238	
547674	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Switching Operations	0	
547675	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Tank Paint Condition	Good	
547676	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Unknown Operations	0	
547677	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Unknown Operations	0	
547678	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
547679	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Switching Operations	0	
547680	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Operations Counter AL	262	
547681	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Operations Counter AF	262	
547682	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
547683	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Maintenance Operations	0	
547684	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
547685	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
547686	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	General Comments	BREAKER OPEN	
547687	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	General Comments		
547688	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
547689	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Follow-up Action Required?	n	
547690	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
547691	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations Ground	0	
547692	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations C Ø	0	
547693	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations B Ø	0	
547694	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations A Ø	0	
547695	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
547696	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
547697	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
547698	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
547699	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
547700	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
547701	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
547702	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
547703	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
547704	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
547705	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Amps C Ø	0.0	
547706	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Amps B Ø	0.0	
547707	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Amps A Ø	0.0	
547708	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
547709	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
547710	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
547711	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	9 Month Operations	2	
547712	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
547713	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
547714	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Follow-up Action Required?	n	
547715	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
547716	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
547717	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	General Comments		
547718	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	General Comments		
547719	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
547720	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	9 Month Operations	1	
547721	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
547722	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Accumulated Fault Duty B Ph V	.83	%
547723	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
547724	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Amps A Ø	29.0	
547725	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Amps B Ø	12.0	
547726	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Amps C Ø	22.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
547727	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Bushing Condition	Good	
547728	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Bushings Connection/Risers	Good	
547729	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
547730	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
547731	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
547732	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Paint Condition	Good	
547733	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Equipment Properly Labeled?	y	
547734	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
547735	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
547736	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
547737	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations A Ø	0	
547738	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations B Ø	0	
547739	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations C Ø	0	
547740	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations Ground	0	
547741	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Follow-up Action Required?	n	
547742	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Follow-up Action Required?	n	
547743	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Foundation Condition	Good	
547744	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	General Comments		
547745	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	General Comments		
547746	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Grounds in Place?	y	
547747	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Heaters (All) Functioning?	y	
547748	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Maintenance Operations	0	
547749	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Moisture and Leak Free?	y	
547750	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Operations Counter AF	174	
547751	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Operations Counter AL	174	
547752	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Switching Operations	0	
547753	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
547754	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
547755	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
547756	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
547757	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
547758	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
547759	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
547760	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	694	
547761	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	694	
547762	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
547763	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
547764	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
547765	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
547766	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
547767	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
547768	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
547769	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
547770	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
547771	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
547772	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
547773	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
547774	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
547775	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
547776	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
547777	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
547778	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
547779	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
547780	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
547781	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
547782	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
547783	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
547784	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
547785	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
547786	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
547787	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	185.0	
547788	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	182.0	
547789	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	178.0	
547790	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.88	%
547791	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	5.25	%
547792	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	3.50	%
547793	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
547794	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
547795	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
547796	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
547797	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations A Ø	0	
547798	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations B Ø	0	
547799	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations C Ø	0	
547800	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations Ground	0	
547801	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
547802	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
547803	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Switching Operations	0	
547804	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Operations Counter AL	207	
547805	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Operations Counter AF	207	
547806	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Maintenance Operations	0	
547807	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	General Comments		
547808	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Patrol Inspection	General Comments		
547809	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Follow-up Action Required?	n	
547810	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Patrol Inspection	Follow-up Action Required?	n	
547811	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations Ground	0	
547812	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations C Ø	0	
547813	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations B Ø	0	
547814	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations A Ø	0	
547815	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
547816	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
547817	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
547818	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Patrol Inspection	Equipment Properly Labeled?	y	
547819	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Amps C Ø	101.0	
547820	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Amps B Ø	96.0	
547821	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Amps A Ø	84.0	
547822	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Accumulated Fault Duty C Ph V	19.93	%
547823	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Accumulated Fault Duty B Ph V	32.68	%
547824	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Accumulated Fault Duty A Ph V	20.73	%
547825	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	General Comments		
547826	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
547827	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	9 Month Operations	2	
547828	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
547829	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
547830	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
547831	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
547832	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
547833	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
547834	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
547835	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Bushings Connection/Risers	Good	
547836	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
547837	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
547838	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
547839	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Paint Condition	Good	
547840	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
547841	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
547842	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
547843	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
547844	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	VRR Time Delay	30	Seconds
547845	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
547846	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
547847	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
547848	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	LTC Operation Checked?	y	
547849	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	General Comments		
547850	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	Follow-up Action Required?	n	
547851	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	All Connections OK?	y	
547852	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	LTCC000554	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
547853	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	LTCC000554	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
547854	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	LTCC000554	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
547855	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	LTCC000554	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
547856	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	LTCC000554	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
547857	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	LTCC000554	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
547858	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	LTCC000554	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
547859	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Operations Counter AL	155	
547860	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Switching Operations	1	
547861	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Tank Paint Condition	Good	
547862	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Unknown Operations	0	
547863	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	LTCC000554	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
547864	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
547865	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
547866	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
547867	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
547868	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	55070	
547869	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	55075	
547870	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
547871	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	4L	
547872	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Unknown Operations	2	
547873	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	13L	
547874	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	1R	
547875	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	539	
547876	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
547877	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
547878	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
547879	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Amps C Ø	20.0	
547880	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Amps B Ø	20.0	
547881	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Amps A Ø	20.0	
547882	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Accumulated Fault Duty C Ph V	10.21	%
547883	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Accumulated Fault Duty B Ph V	8.51	%
547884	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Accumulated Fault Duty A Ph V	6.81	%
547885	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	9 Month Operations	9	
547886	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Follow-up Action Required?	n	
547887	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Foundation Condition	Good	
547888	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	General Comments		
547889	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	General Comments		
547890	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Grounds in Place?	y	
547891	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Heaters (All) Functioning?	y	
547892	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Maintenance Operations	0	
547893	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
547894	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	General Comments	NO INSPECTION CAME UP FOR BATTERIES NO POSITVE OR NEGITIVE GROUND, TEMP IS 65 F, AND WATER LEVEL WAS GOOD	
547895	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
547896	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
547897	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
547898	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
547899	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
547900	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
547901	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	General Comments		
547902	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
547903	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC As Found Counter	32315	
547904	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC As Left Counter	32315	
547905	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
547906	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
547907	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
547908	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5L	
547909	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
547910	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	°C
547911	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	740	
547912	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
547913	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
547914	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
547915	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
547916	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
547917	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	12.81	%
547918	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	16.37	%
547919	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	17.08	%
547920	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	130.0	
547921	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
547922	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
547923	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Follow-up Action Required?	n	
547924	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
547925	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
547926	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
547927	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
547928	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
547929	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
547930	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
547931	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
547932	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
547933	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
547934	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
547935	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	General Comments		
547936	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
547937	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
547938	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
547939	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
547940	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
547941	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
547942	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
547943	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
547944	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	257	
547945	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	257	
547946	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
547947	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
547948	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Unknown Operations	0	
547949	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Switching Operations	4	
547950	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Operations Counter AL	308	
547951	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Operations Counter AF	304	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
547952	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Maintenance Operations	0	
547953	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	General Comments		
547954	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Follow-up Action Required?	n	
547955	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations Ground	0	
547956	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations C Ø	0	
547957	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations B Ø	0	
547958	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations A Ø	0	
547959	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
547960	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	General Comments		
547961	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
547962	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
547963	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Floor Swept?	y	
547964	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
547965	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
547966	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Evidence of Insects	None	
547967	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
547968	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
547969	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
547970	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
547971	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
547972	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
547973	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Accumulated Fault Duty C Ph V	1.25	%
547974	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Accumulated Fault Duty B Ph V	1.67	%
547975	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Accumulated Fault Duty A Ph V	2.08	%
547976	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	9 Month Operations	1	
547977	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	9 Month Operations	5	
547978	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Accumulated Fault Duty A Ph V	21.52	%
547979	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Accumulated Fault Duty B Ph V	24.71	%
547980	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Accumulated Fault Duty C Ph V	16.74	%
547981	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Amps A Ø	153.0	
547982	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Unknown Operations	1	
547983	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Switching Operations	0	
547984	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	VRR Time Delay	30	Seconds
547985	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Operations Counter AL	178	
547986	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Operations Counter AF	178	
547987	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Maintenance Operations	0	
547988	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	General Comments		
547989	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Patrol Inspection	General Comments		
547990	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Follow-up Action Required?	n	
547991	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Patrol Inspection	Follow-up Action Required?	n	
547992	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations Ground	0	
547993	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations C Ø	0	
547994	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
547995	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
547996	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
547997	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
547998	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	LTC Operation Checked?	y	
547999	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	General Comments		
548000	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	LTC Totalizer Reading	5414.40	kw
548001	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
548002	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	General Comments		
548003	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	General Comments		
548004	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
548005	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
548006	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Follow-up Action Required?	n	
548007	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
548008	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
548009	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
548010	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
548011	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
548012	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
548013	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
548014	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
548015	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
548016	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
548017	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
548018	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
548019	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
548020	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations C Ø	0	
548021	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations B Ø	0	
548022	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations A Ø	0	
548023	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
548024	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
548025	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
548026	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
548027	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Paint Condition	Good	
548028	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
548029	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
548030	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
548031	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Bushings Connection/Risers	Good	
548032	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Bushing Condition	Good	
548033	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Amps C Ø	458.0	
548034	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Amps B Ø	466.0	
548035	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Amps A Ø	444.0	
548036	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
548037	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
548038	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
548039	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
548040	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Panels Dusted?	n	
548041	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Evidence of Insects	None	
548042	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
548043	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
548044	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
548045	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
548046	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
548047	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
548048	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Unknown Operations	0	
548049	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Tank Paint Condition	Good	
548050	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
548051	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
548052	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Amps A Ø	0.0	
548053	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Amps B Ø	0.0	
548054	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Amps C Ø	0.0	
548055	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Bushing Condition	Good	
548056	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Bushings Connection/Risers	Good	
548057	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
548058	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
548059	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
548060	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Paint Condition	Good	
548061	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Switching Operations	0	
548062	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
548063	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Operations Counter AL	155	
548064	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Operations Counter AF	155	
548065	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Moisture and Leak Free?	y	
548066	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Maintenance Operations	3	
548067	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Heaters (All) Functioning?	y	
548068	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Grounds in Place?	y	
548069	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	General Comments		
548070	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	General Comments		
548071	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Equipment Properly Labeled?	y	
548072	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
548073	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
548074	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
548075	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations A Ø	0	
548076	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations B Ø	0	
548077	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations C Ø	0	
548078	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations Ground	0	
548079	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Follow-up Action Required?	n	
548080	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Follow-up Action Required?	n	
548081	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Foundation Condition	Good	
548082	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations B Ø	0	
548083	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations A Ø	0	
548084	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
548085	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
548086	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
548087	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Patrol Inspection	Equipment Properly Labeled?	y	
548088	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Amps C Ø	141.0	
548089	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Amps B Ø	158.0	
548090	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	Follow-up Action Required?	n	
548091	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	All Connections OK?	y	
548092	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	Follow-up Action Required?	n	
548093	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
548094	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	General Comments		
548095	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	General Comments		
548096	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC As Found Counter	120770	
548097	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC As Left Counter	120770	
548098	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
548099	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Current Tap Position	4L	
548100	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
548101	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Min Tap Position	8L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
548102	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
548103	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
548104	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
548105	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
548106	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Operations Since Last Insp	875	
548107	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
548108	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Very Low	
548109	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
548110	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
548111	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	9 Month Operations	3	
548112	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
548113	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
548114	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
548115	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Panels Dusted?	y	
548116	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
548117	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	General Comments		
548118	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
548119	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
548120	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Floor Swept?	y	
548121	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
548122	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
548123	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
548124	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	General Comments		
548125	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	General Comments		
548126	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC As Found Counter	12259	
548127	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC As Left Counter	12259	
548128	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
548129	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Current Tap Position	1R	
548130	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Max Tap Position	4R	
548131	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Min Tap Position	6L	
548132	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
548133	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Operations Since Last Insp	821	
548134	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
548135	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
548136	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
548137	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
548138	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
548139	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
548140	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	General Comments		
548141	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	General Comments		
548142	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC As Found Counter	7985	
548143	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC As Left Counter	7987	
548144	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
548145	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Current Tap Position	3L	
548146	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Max Tap Position	15L	
548147	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Min Tap Position	3R	
548148	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Operations Since Last Insp	735	
548149	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
548150	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
548151	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
548152	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
548153	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
548154	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
548155	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Operations Since Last Insp	296	
548156	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Min Tap Position	9L	
548157	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Max Tap Position	3L	
548158	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Current Tap Position	5L	
548159	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
548160	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC As Left Counter	82817	
548161	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC As Found Counter	82813	
548162	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	General Comments		
548163	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	General Comments		
548164	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
548165	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Tank Paint Condition	Good	
548166	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Unknown Operations	0	
548167	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	LTC Totalizer Reading	6238.08	kw
548168	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
548169	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
548170	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
548171	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
548172	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
548173	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
548174	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
548175	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
548176	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
548177	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Top Oil Temperature Max	40	°C
548178	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Top Oil Temperature Present	30	°C
548179	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
548180	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Totalizer Meter Reading	.6498	
548181	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Winding Temp Max	0	°C
548182	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Winding Temp Present	0	°C
548183	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
548184	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
548185	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
548186	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
548187	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
548188	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	Follow-up Action Required?	n	
548189	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
548190	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
548191	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	135	
548192	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	135	
548193	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
548194	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
548195	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
548196	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
548197	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
548198	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
548199	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
548200	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
548201	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
548202	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
548203	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
548204	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	Follow-up Action Required?	n	
548205	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
548206	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
548207	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
548208	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
548209	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
548210	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	VRR Time Delay	30	Seconds
548211	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	LTC Operation Checked?	y	
548212	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	General Comments		
548213	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	Follow-up Action Required?	n	
548214	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	All Connections OK?	y	
548215	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Unknown Operations	0	
548216	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Tank Paint Condition	Good	
548217	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Switching Operations	0	
548218	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Operations Counter AL	262	
548219	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Operations Counter AF	262	
548220	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Moisture and Leak Free?	y	
548221	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Maintenance Operations	0	
548222	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Heaters (All) Functioning?	y	
548223	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Grounds in Place?	y	
548224	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
548225	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
548226	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Winding Temp Present	0	°C
548227	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Winding Temp Max	0	°C
548228	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Totalizer Meter Reading	.5640	
548229	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
548230	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Top Oil Temperature Present	25	°C
548231	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Top Oil Temperature Max	40	°C
548232	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
548233	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
548234	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
548235	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	General Comments		
548236	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	General Comments		
548237	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Foundation Condition	Good	
548238	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Follow-up Action Required?	n	
548239	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Follow-up Action Required?	n	
548240	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
548241	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
548242	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations Ground	0	
548243	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
548244	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
548245	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
548246	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
548247	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	Follow-up Action Required?	n	
548248	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
548249	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
548250	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
548251	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
548252	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
548253	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
548254	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
548255	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
548256	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
548257	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
548258	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	70.0	
548259	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
548260	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	13.14	%
548261	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	13.14	%
548262	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	12.45	%
548263	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
548264	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	VRR Time Delay	30	Seconds
548265	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
548266	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
548267	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
548268	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
548269	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Panels Dusted?	y	
548270	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
548271	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	General Comments		
548272	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
548273	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
548274	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Floor Swept?	y	
548275	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
548276	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
548277	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Evidence of Insects	None	
548278	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
548279	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
548280	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
548281	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
548282	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
548283	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
548284	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
548285	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	All Connections OK?	y	
548286	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	Follow-up Action Required?	n	
548287	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	General Comments		
548288	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	LTC Operation Checked?	y	
548289	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC As Left Counter	20164	
548290	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
548291	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Current Tap Position	1L	
548292	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Max Tap Position	2R	
548293	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Min Tap Position	7L	
548294	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
548295	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
548296	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
548297	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
548298	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Operations Since Last Insp	1112	
548299	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
548300	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
548301	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
548302	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Very Low	
548303	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
548304	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
548305	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Winding Temp Present	15	°C
548306	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Winding Temp Max	30	°C
548307	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7110	
548308	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
548309	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
548310	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
548311	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
548312	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
548313	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
548314	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
548315	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
548316	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Oil Temp Present	10	°C
548317	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
548318	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
548319	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
548320	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2559.60	kw
548321	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
548322	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
548323	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
548324	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
548325	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
548326	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
548327	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
548328	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
548329	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.58	%
548330	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
548331	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations A Ø	0	
548332	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations B Ø	0	
548333	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations C Ø	0	
548334	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations Ground	0	
548335	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Follow-up Action Required?	n	
548336	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Follow-up Action Required?	n	
548337	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	General Comments		
548338	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
548339	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	LTC Totalizer Reading	9020.16	kw
548340	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
548341	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
548342	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Oil Temp Max	50	°C
548343	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Oil Temp Present	40	°C
548344	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
548345	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
548346	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
548347	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
548348	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
548349	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
548350	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
548351	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
548352	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Totalizer Meter Reading	.9396	
548353	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Foundation Condition	Good	
548354	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	General Comments		
548355	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	General Comments		
548356	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Grounds in Place?	y	
548357	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Heaters (All) Functioning?	y	
548358	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Maintenance Operations	1	
548359	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Moisture and Leak Free?	y	
548360	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Operations Counter AF	99950	
548361	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Operations Counter AL	99950	
548362	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
548363	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Switching Operations	0	
548364	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Tank Paint Condition	Good	
548365	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Unknown Operations	0	
548366	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	Follow-up Action Required?	n	
548367	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
548368	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	General Comments		
548369	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	General Comments		
548370	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC As Found Counter	20164	
548371	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
548372	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
548373	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
548374	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
548375	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Operations Since Last Insp	893	
548376	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Min Tap Position	11L	
548377	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Max Tap Position	3L	
548378	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Current Tap Position	4L	
548379	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
548380	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	701	
548381	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	701	
548382	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
548383	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Unknown Operations	0	
548384	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Tank Paint Condition	Good	
548385	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Switching Operations	2	
548386	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Operations Counter AL	218	
548387	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Operations Counter AF	216	
548388	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Moisture and Leak Free?	y	
548389	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Maintenance Operations	0	
548390	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Heaters (All) Functioning?	y	
548391	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Grounds in Place?	y	
548392	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	General Comments		
548393	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	General Comments		
548394	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Foundation Condition	Good	
548395	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC As Left Counter	245246	
548396	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC As Found Counter	245243	
548397	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	General Comments		
548398	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Follow-up Action Required?	n	
548399	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
548400	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
548401	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
548402	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Follow-up Action Required?	n	
548403	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations Ground	0	
548404	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations C Ø	0	
548405	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations B Ø	0	
548406	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations A Ø	0	
548407	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Adjusted Amps C Phase V	0	
548408	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Adjusted Amps B Phase V	0	
548409	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Adjusted Amps A Phase V	0	
548410	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Equipment Properly Labeled?	y	
548411	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Paint Condition	Good	
548412	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	342.0	
548413	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	363.0	
548414	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	330.0	
548415	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
548416	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
548417	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
548418	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
548419	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
548420	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	General Comments		
548421	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
548422	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
548423	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
548424	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
548425	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
548426	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
548427	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
548428	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
548429	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
548430	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
548431	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
548432	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
548433	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
548434	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
548435	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
548436	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
548437	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
548438	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
548439	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
548440	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
548441	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
548442	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
548443	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
548444	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
548445	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
548446	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
548447	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
548448	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
548449	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
548450	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
548451	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
548452	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
548453	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	9 Month Operations	1	
548454	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
548455	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
548456	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Accumulated Fault Duty C Ph V	.35	%
548457	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Amps A Ø	129.0	
548458	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Amps B Ø	125.0	
548459	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Amps C Ø	125.0	
548460	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Bushing Condition	Good	
548461	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Bushings Connection/Risers	Good	
548462	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
548463	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
548464	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
548465	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Paint Condition	Good	
548466	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Equipment Properly Labeled?	y	
548467	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
548468	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
548469	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
548470	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations A Ø	0	
548471	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations B Ø	0	
548472	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations C Ø	0	
548473	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations Ground	0	
548474	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Follow-up Action Required?	n	
548475	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Follow-up Action Required?	n	
548476	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
548477	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
548478	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
548479	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
548480	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	259	
548481	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	259	
548482	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
548483	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
548484	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
548485	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
548486	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
548487	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
548488	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
548489	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
548490	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
548491	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
548492	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
548493	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
548494	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Bushings Connection/Risers	Good	
548495	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
548496	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
548497	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
548498	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	9 Month Operations	3	
548499	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Accumulated Fault Duty A Ph V	1.18	%
548500	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Paint Condition	Good	
548501	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Equipment Properly Labeled?	y	
548502	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
548503	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
548504	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
548505	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
548506	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Operations Since Last Insp	2716	
548507	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	40	°C
548508	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
548509	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
548510	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Min Tap Position	3R	
548511	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Max Tap Position	16R	
548512	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Current Tap Position	14R	
548513	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
548514	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC As Left Counter	95911	
548515	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC As Found Counter	95911	
548516	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	General Comments		
548517	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	General Comments		
548518	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
548519	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	Follow-up Action Required?	n	
548520	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
548521	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
548522	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
548523	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations A Ø	0	
548524	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations B Ø	0	
548525	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations C Ø	0	
548526	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations Ground	0	
548527	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Follow-up Action Required?	n	
548528	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Follow-up Action Required?	n	
548529	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Foundation Condition	Good	
548530	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Accumulated Fault Duty B Ph V	1.18	%
548531	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Accumulated Fault Duty C Ph V	1.18	%
548532	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Amps A Ø	100.0	
548533	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Amps B Ø	100.0	
548534	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Amps C Ø	100.0	
548535	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	General Comments		
548536	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
548537	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
548538	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	92.0	
548539	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	121.0	
548540	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	63.0	
548541	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	7.88	%
548542	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	7.00	%
548543	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	7.88	%
548544	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
548545	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Grounds in Place?	y	
548546	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Heaters (All) Functioning?	y	
548547	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	General Comments		
548548	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Grounds in Place?	y	
548549	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Heaters (All) Functioning?	y	
548550	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Maintenance Operations	0	
548551	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
548552	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Operations Counter AF	187	
548553	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Operations Counter AL	187	
548554	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
548555	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Switching Operations	0	
548556	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Tank Paint Condition	Good	
548557	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Unknown Operations	0	
548558	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Maintenance Operations	0	
548559	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Moisture and Leak Free?	y	
548560	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Operations Counter AF	332	
548561	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Operations Counter AL	332	
548562	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
548563	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Switching Operations	0	
548564	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Tank Paint Condition	Good	
548565	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
548566	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
548567	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
548568	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
548569	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Follow-up Action Required?	n	
548570	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
548571	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
548572	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	General Comments		
548573	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Unknown Operations	0	
548574	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
548575	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
548576	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
548577	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Bushings Connection/Risers	Good	
548578	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
548579	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
548580	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
548581	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
548582	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
548583	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
548584	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
548585	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
548586	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
548587	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
548588	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
548589	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Paint Condition	Good	
548590	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Equipment Properly Labeled?	y	
548591	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Maintenance Operations	0	
548592	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
548593	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
548594	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Operations Counter AF	705	
548595	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Operations Counter AL	709	
548596	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Switching Operations	4	
548597	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Unknown Operations	0	
548598	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Foundation Condition	Good	
548599	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	General Comments		
548600	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	General Comments		
548601	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Grounds in Place?	y	
548602	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Heaters (All) Functioning?	y	
548603	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Maintenance Operations	0	
548604	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Moisture and Leak Free?	y	
548605	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Operations Counter AF	165	
548606	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Operations Counter AL	165	
548607	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
548608	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Switching Operations	0	
548609	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Tank Paint Condition	Good	
548610	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Unknown Operations	0	
548611	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
548612	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
548613	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
548614	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
548615	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
548616	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
548617	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	General Comments		
548618	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
548619	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
548620	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
548621	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
548622	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
548623	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
548624	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3978	
548625	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Bushings Connection/Risers	Good	
548626	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
548627	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Amps C Ø	90.0	
548628	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Amps B Ø	60.0	
548629	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Amps A Ø	70.0	
548630	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Accumulated Fault Duty C Ph V	.44	%
548631	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Accumulated Fault Duty B Ph V	.88	%
548632	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Accumulated Fault Duty A Ph V	1.31	%
548633	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	9 Month Operations	5	
548634	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LTCC000522	LTCControl	CS-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
548635	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LTCC000522	LTCControl	CS-TRANS 1	LTC Control Insp	General Comments	ok	
548636	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	9 Month Operations	2	
548637	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Accumulated Fault Duty A Ph V	.46	%
548638	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Accumulated Fault Duty B Ph V	.46	%
548639	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Accumulated Fault Duty C Ph V	.46	%
548640	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Amps A Ø	112.0	
548641	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Amps B Ø	142.0	
548642	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Amps C Ø	118.0	
548643	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Bushing Condition	Good	
548644	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Bushings Connection/Risers	Good	
548645	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
548646	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
548647	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
548648	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Paint Condition	Good	
548649	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Equipment Properly Labeled?	y	
548650	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
548651	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
548652	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
548653	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations A Ø	0	
548654	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations B Ø	0	
548655	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations C Ø	0	
548656	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations Ground	0	
548657	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Follow-up Action Required?	n	
548658	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Follow-up Action Required?	n	
548659	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Grounds in Place?	y	
548660	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	General Comments		
548661	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	General Comments		
548662	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Foundation Condition	Good	
548663	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Follow-up Action Required?	n	
548664	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Follow-up Action Required?	n	
548665	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations Ground	0	
548666	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations C Ø	0	
548667	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations B Ø	0	
548668	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations A Ø	0	
548669	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
548670	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
548671	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
548672	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Equipment Properly Labeled?	y	
548673	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Paint Condition	Good	
548674	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
548675	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
548676	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
548677	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
548678	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
548679	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
548680	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
548681	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
548682	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
548683	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
548684	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
548685	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
548686	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
548687	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
548688	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	General Comments		
548689	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	General Comments		
548690	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
548691	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
548692	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
548693	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1909.44	kw
548694	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
548695	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
548696	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
548697	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
548698	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
548699	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
548700	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
548701	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
548702	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
548703	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	9 Month Operations	5	
548704	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Accumulated Fault Duty A Ph V	.46	%
548705	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Accumulated Fault Duty B Ph V	.46	%
548706	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
548707	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Amps A Ø	45.0	
548708	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Amps B Ø	60.0	
548709	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Amps C Ø	13.0	
548710	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Bushing Condition	Good	
548711	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Bushings Connection/Risers	Good	
548712	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
548713	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
548714	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
548715	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Paint Condition	Good	
548716	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Equipment Properly Labeled?	y	
548717	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
548718	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
548719	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
548720	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations A Ø	0	
548721	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations B Ø	0	
548722	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations C Ø	0	
548723	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations Ground	0	
548724	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Follow-up Action Required?	n	
548725	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Follow-up Action Required?	n	
548726	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Foundation Condition	Good	
548727	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	General Comments		
548728	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	General Comments		
548729	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Grounds in Place?	y	
548730	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Maintenance Operations	0	
548731	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Moisture and Leak Free?	y	
548732	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Operations Counter AF	155	
548733	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	9 Month Operations	1	
548734	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
548735	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
548736	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
548737	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Amps A Ø	399.0	
548738	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Amps B Ø	407.0	
548739	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Amps C Ø	385.0	
548740	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Bushing Condition	Good	
548741	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Foundation Condition	Good	
548742	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	General Comments		
548743	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	General Comments		
548744	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Grounds in Place?	y	
548745	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Maintenance Operations	0	
548746	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Moisture and Leak Free?	y	
548747	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Operations Counter AF	161	
548748	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Operations Counter AL	161	
548749	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Switching Operations	1	
548750	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Tank Paint Condition	Good	
548751	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Unknown Operations	0	
548752	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
548753	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
548754	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.8448	
548755	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
548756	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
548757	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
548758	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
548759	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
548760	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
548761	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
548762	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
548763	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	20	°C
548764	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	40	°C
548765	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
548766	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
548767	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	4055.04	kw
548768	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
548769	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
548770	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
548771	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
548772	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
548773	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
548774	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
548775	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
548776	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
548777	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
548778	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
548779	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
548780	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
548781	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
548782	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
548783	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
548784	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
548785	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
548786	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	950	
548787	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	950	
548788	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
548789	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
548790	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
548791	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
548792	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
548793	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
548794	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
548795	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
548796	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
548797	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
548798	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
548799	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
548800	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
548801	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
548802	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
548803	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
548804	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	LTCC000198	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
548805	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	LTCC000198	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124	VAC
548806	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	LTCC000198	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124	VAC
548807	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	LTCC000198	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125	VAC
548808	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	LTCC000198	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
548809	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	LTCC000198	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
548810	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	LTCC000198	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
548811	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	LTCC000198	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
548812	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
548813	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
548814	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
548815	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
548816	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
548817	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
548818	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
548819	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	123.0	
548820	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	95.0	
548821	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	62.0	
548822	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	3.50	%
548823	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	4.38	%
548824	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
548825	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
548826	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
548827	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	General Comments		
548828	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
548829	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	Follow-up Action Required?	n	
548830	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Bushings Connection/Risers	Good	
548831	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Bushing Condition	Good	
548832	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Amps C Ø	152	
548833	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Amps B Ø	154	
548834	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Amps A Ø	159	
548835	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Accumulated Fault Duty C Ph V	0	%
548836	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Accumulated Fault Duty B Ph V	1.13	%
548837	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Accumulated Fault Duty A Ph V	0	%
548838	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	9 Month Operations	4	
548839	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000206	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
548840	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000206	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
548841	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000206	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
548842	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000206	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
548843	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000206	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
548844	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000206	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
548845	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000206	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
548846	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000206	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
548847	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000206	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
548848	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	VRR Time Delay	30	Seconds
548849	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
548850	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
548851	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	LTC Output Voltage Level	124.3	VAC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
548852	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	LTC Operation Checked?	y	
548853	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	General Comments		
548854	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	Follow-up Action Required?	n	
548855	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	All Connections OK?	y	
548856	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	VRR Time Delay	30	Seconds
548857	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
548858	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
548859	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	LTC Output Voltage Level	125.2	VAC
548860	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	LTC Operation Checked?	y	
548861	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	General Comments		
548862	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	Follow-up Action Required?	n	
548863	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	All Connections OK?	y	
548864	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
548865	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Follow-up Action Required?	n	
548866	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Follow-up Action Required?	n	
548867	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Foundation Condition	Good	
548868	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	General Comments		
548869	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	General Comments		
548870	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Grounds in Place?	y	
548871	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
548872	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Maintenance Operations	0	
548873	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
548874	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Operations Counter AF	99946	
548875	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
548876	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Operations Counter AL	99946	
548877	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
548878	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Switching Operations	0	
548879	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Unknown Operations	0	
548880	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Tank Paint Condition	Good	
548881	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
548882	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
548883	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Equipment Properly Labeled?	y	
548884	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Paint Condition	Good	
548885	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
548886	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
548887	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
548888	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Tank Paint Condition	Good	
548889	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Bushings Connection/Risers	Good	
548890	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Bushing Condition	Good	
548891	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Unknown Operations	0	
548892	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Amps C Ø	175.0	
548893	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Amps B Ø	180.0	
548894	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Amps A Ø	240.0	
548895	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Accumulated Fault Duty C Ph V	5.03	%
548896	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Accumulated Fault Duty B Ph V	2.74	%
548897	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Accumulated Fault Duty A Ph V	4.57	%
548898	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	9 Month Operations	17	
548899	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Switching Operations	0	
548900	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
548901	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Operations Counter AL	245	
548902	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Operations Counter AF	245	
548903	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Moisture and Leak Free?	y	
548904	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Maintenance Operations	0	
548905	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Heaters (All) Functioning?	y	
548906	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	4.38	%
548907	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
548908	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Unknown Operations	0	
548909	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Tank Paint Condition	Good	
548910	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Switching Operations	5	
548911	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
548912	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Operations Counter AL	203	
548913	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Operations Counter AF	203	
548914	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Moisture and Leak Free?	y	
548915	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Maintenance Operations	0	
548916	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Heaters (All) Functioning?	y	
548917	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Grounds in Place?	y	
548918	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	General Comments		
548919	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	General Comments		
548920	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Foundation Condition	Good	
548921	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Follow-up Action Required?	n	
548922	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Follow-up Action Required?	n	
548923	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations Ground	0	
548924	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations C Ø	0	
548925	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations B Ø	0	
548926	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
548927	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	9 Month Operations	1	
548928	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
548929	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
548930	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
548931	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Amps A Ø	490.0	
548932	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Amps B Ø	497.0	
548933	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Amps C Ø	490.0	
548934	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Bushing Condition	Good	
548935	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
548936	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
548937	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
548938	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
548939	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
548940	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
548941	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
548942	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
548943	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
548944	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations A Ø	0	
548945	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations B Ø	0	
548946	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations C Ø	0	
548947	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations Ground	0	
548948	3/4/2019 13:33	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
548949	3/4/2019 13:33	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
548950	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
548951	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
548952	3/4/2019 13:33	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
548953	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
548954	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
548955	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
548956	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Ambient Temp	22	°F
548957	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
548958	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
548959	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Clear of Trash?	y	
548960	3/4/2019 13:33	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
548961	3/4/2019 13:33	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
548962	3/4/2019 13:33	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
548963	3/4/2019 13:33	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
548964	3/4/2019 13:33	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
548965	3/4/2019 13:33	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
548966	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
548967	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
548968	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
548969	3/4/2019 13:33	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
548970	3/4/2019 13:33	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
548971	3/4/2019 13:33	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
548972	3/4/2019 13:33	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
548973	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
548974	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
548975	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
548976	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	General Comments		
548977	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
548978	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
548979	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Vegetation	None	
548980	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
548981	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Vegetation	None	
548982	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
548983	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
548984	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
548985	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
548986	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	General Comments		
548987	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
548988	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
548989	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
548990	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
548991	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	General Comments		
548992	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
548993	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
548994	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
548995	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
548996	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
548997	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
548998	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
548999	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
549000	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	20	°F
549001	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
549002	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
549003	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
549004	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
549005	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
549006	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	141.0	
549007	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	130.0	
549008	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
549009	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
549010	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
549011	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
549012	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
549013	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
549014	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
549015	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	General Comments		
549016	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
549017	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
549018	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
549019	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
549020	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
549021	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
549022	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
549023	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
549024	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
549025	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
549026	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
549027	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
549028	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
549029	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
549030	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
549031	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
549032	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
549033	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
549034	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
549035	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
549036	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
549037	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
549038	3/4/2019 13:33	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
549039	3/4/2019 13:33	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
549040	3/4/2019 13:33	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Foundation Condition	Good	
549041	3/4/2019 13:33	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
549042	3/4/2019 13:33	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
549043	3/4/2019 13:33	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
549044	3/4/2019 13:33	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
549045	3/4/2019 13:33	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
549046	3/4/2019 13:33	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
549047	3/4/2019 13:33	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
549048	3/4/2019 13:33	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Vegetation	None	
549049	3/4/2019 13:33	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
549050	3/4/2019 13:33	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	General Comments		
549051	3/4/2019 13:33	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
549052	3/4/2019 13:33	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
549053	3/4/2019 13:33	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
549054	3/4/2019 13:33	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
549055	3/4/2019 13:33	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
549056	3/4/2019 13:33	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
549057	3/4/2019 13:33	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Clear of Trash?	y	
549058	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
549059	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Switching Operations	5	
549060	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Tank Paint Condition	Good	
549061	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Unknown Operations	0	
549062	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
549063	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
549064	3/4/2019 13:33	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
549065	3/4/2019 13:33	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
549066	3/4/2019 13:33	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Ambient Temp	22	°F
549067	3/4/2019 13:33	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
549068	3/4/2019 13:33	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	General Comments	ok	
549069	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
549070	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Foundation Condition	Good	
549071	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
549072	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
549073	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
549074	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
549075	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
549076	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
549077	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Ambient Temp	21	°F
549078	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
549079	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
549080	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Trash Emptied?	y	
549081	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
549082	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
549083	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
549084	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Panels Dusted?	y	
549085	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
549086	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
549087	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
549088	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
549089	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Vegetation	None	
549090	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
549091	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
549092	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	General Comments		
549093	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
549094	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
549095	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
549096	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
549097	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
549098	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
549099	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
549100	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
549101	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
549102	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
549103	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
549104	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
549105	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
549106	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
549107	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
549108	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
549109	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
549110	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
549111	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	28	°F
549112	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
549113	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	LTCC000061	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
549114	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	LTCC000061	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
549115	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	LTCC000061	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
549116	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	LTCC000061	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
549117	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	LTCC000061	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
549118	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	LTCC000061	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
549119	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	LTCC000061	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
549120	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	LTCC000061	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
549121	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
549122	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Clear of Trash?	y	
549123	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Oil Temp Present	20	°C
549124	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
549125	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
549126	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
549127	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
549128	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
549129	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	130.0	
549130	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
549131	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
549132	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
549133	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
549134	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
549135	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
549136	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Follow-up Action Required?	n	
549137	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
549138	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
549139	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	General Comments		
549140	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	General Comments		
549141	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
549142	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	LTC Totalizer Reading	6503.04	kw
549143	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
549144	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
549145	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Oil Temp Max	40	°C
549146	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
549147	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
549148	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
549149	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
549150	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	32	
549151	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	32	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
549152	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
549153	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
549154	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
549155	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
549156	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
549157	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
549158	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
549159	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
549160	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
549161	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Clear of Trash?	y	
549162	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
549163	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
549164	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
549165	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Readings	General Comments		
549166	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
549167	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
549168	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
549169	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
549170	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
549171	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
549172	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
549173	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
549174	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
549175	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
549176	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
549177	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
549178	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
549179	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
549180	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
549181	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
549182	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
549183	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
549184	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
549185	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
549186	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
549187	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
549188	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	General Comments		
549189	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
549190	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Max Tap Position	6L	
549191	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
549192	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
549193	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
549194	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
549195	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
549196	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
549197	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Regulator As Left Counter	24525	
549198	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
549199	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
549200	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Tank Leaks	None	
549201	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
549202	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
549203	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
549204	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
549205	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
549206	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
549207	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
549208	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
549209	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
549210	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
549211	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
549212	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
549213	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
549214	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	General Comments		
549215	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
549216	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
549217	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Min Tap Position	16L	
549218	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
549219	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
549220	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
549221	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
549222	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
549223	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Regulator As Left Counter	24040	
549224	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
549225	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
549226	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Tank Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
549227	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
549228	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Amps A Ø	0.0	
549229	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
549230	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
549231	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
549232	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
549233	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
549234	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
549235	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	General Comments		
549236	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
549237	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
549238	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
549239	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
549240	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
549241	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
549242	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Clear of Trash?	y	
549243	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
549244	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Ambient Temp	28	°F
549245	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Accumulated Fault Duty C Ph V	4.78	%
549246	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Accumulated Fault Duty B Ph V	4.78	%
549247	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Accumulated Fault Duty A Ph V	4.78	%
549248	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	9 Month Operations	1	
549249	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
549250	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
549251	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
549252	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
549253	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
549254	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
549255	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
549256	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Follow-up Action Required?	n	
549257	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
549258	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
549259	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	General Comments		
549260	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	General Comments		
549261	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
549262	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	LTC Totalizer Reading	8046.00	kw
549263	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
549264	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
549265	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
549266	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
549267	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Oil Temp Max	70	°C
549268	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Oil Temp Present	30	°C
549269	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
549270	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
549271	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
549272	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
549273	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
549274	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
549275	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
549276	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
549277	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations B Ø	0	
549278	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations A Ø	0	
549279	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
549280	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
549281	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
549282	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Patrol Inspection	Equipment Properly Labeled?	y	
549283	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Amps C Ø	0.0	
549284	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	General Comments		
549285	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
549286	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
549287	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Foundation Condition	Good	
549288	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
549289	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
549290	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
549291	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
549292	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
549293	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
549294	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
549295	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
549296	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
549297	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Vegetation	None	
549298	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Amps B Ø	0.0	
549299	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
549300	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
549301	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
549302	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
549303	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
549304	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
549305	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
549306	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
549307	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
549308	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
549309	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	General Comments		
549310	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
549311	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
549312	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0	VDC
549313	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0	VDC
549314	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
549315	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
549316	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
549317	3/4/2019 13:33	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
549318	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
549319	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
549320	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
549321	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
549322	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	General Comments		
549323	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
549324	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
549325	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
549326	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
549327	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
549328	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Foundation Condition	Good	
549329	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
549330	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Ambient Temp	22	°F
549331	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
549332	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
549333	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Clear of Trash?	y	
549334	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
549335	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
549336	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
549337	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
549338	3/4/2019 13:33	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
549339	3/4/2019 13:33	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
549340	3/4/2019 13:33	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
549341	3/4/2019 13:33	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
549342	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
549343	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
549344	3/4/2019 13:33	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
549345	3/4/2019 13:33	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
549346	3/4/2019 13:33	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
549347	3/4/2019 13:33	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	General Comments	No spare fuses at station	
549348	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
549349	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
549350	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	General Comments		
549351	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
549352	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
549353	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Vegetation	None	
549354	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
549355	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
549356	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
549357	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
549358	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
549359	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
549360	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
549361	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Foundation Condition	Good	
549362	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
549363	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
549364	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	General Comments		
549365	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
549366	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
549367	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
549368	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
549369	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
549370	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
549371	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	General Comments		
549372	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
549373	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
549374	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
549375	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
549376	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
549377	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
549378	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
549379	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
549380	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
549381	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
549382	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
549383	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
549384	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
549385	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Maintenance Operations	0	
549386	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Moisture and Leak Free?	y	
549387	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Operations Counter AF	221	
549388	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Operations Counter AL	221	
549389	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Totalizer Meter Reading	.4470	
549390	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
549391	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
549392	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
549393	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Winding Temp Max	30	°C
549394	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Winding Temp Present	30	°C
549395	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
549396	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
549397	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
549398	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
549399	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
549400	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
549401	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
549402	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
549403	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
549404	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	General Comments		
549405	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
549406	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
549407	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	BCH000404	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
549408	3/4/2019 13:33	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
549409	3/4/2019 13:33	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
549410	3/4/2019 13:33	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
549411	3/4/2019 13:33	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
549412	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	BCH000404	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
549413	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	BCH000404	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
549414	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	BCH000404	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
549415	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	BCH000404	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
549416	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	BCH000404	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
549417	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
549418	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
549419	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
549420	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
549421	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
549422	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
549423	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
549424	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
549425	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
549426	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
549427	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
549428	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
549429	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
549430	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
549431	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
549432	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
549433	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
549434	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
549435	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
549436	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
549437	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
549438	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
549439	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
549440	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BCH000392	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
549441	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BCH000392	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
549442	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BCH000392	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
549443	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BCH000392	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
549444	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BCH000392	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
549445	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BCH000392	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
549446	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
549447	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	General Comments		
549448	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
549449	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Unknown Operations	0	
549450	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Switching Operations	0	
549451	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Operations Counter AL	192	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
549452	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Operations Counter AF	192	
549453	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Maintenance Operations	0	
549454	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	General Comments		
549455	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Patrol Inspection	General Comments		
549456	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Follow-up Action Required?	n	
549457	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Patrol Inspection	Follow-up Action Required?	n	
549458	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations Ground	0	
549459	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations C Ø	0	
549460	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations B Ø	0	
549461	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations A Ø	0	
549462	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
549463	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
549464	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
549465	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Patrol Inspection	Equipment Properly Labeled?	y	
549466	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Amps C Ø	22.0	
549467	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Amps B Ø	20.0	
549468	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Amps A Ø	58.0	
549469	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Accumulated Fault Duty C Ph V	29.50	%
549470	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Accumulated Fault Duty B Ph V	7.97	%
549471	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Accumulated Fault Duty A Ph V	7.97	%
549472	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	9 Month Operations	4	
549473	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	Follow-up Action Required?	n	
549474	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
549475	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	General Comments		
549476	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	General Comments		
549477	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC As Found Counter	41899	
549478	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC As Left Counter	41899	
549479	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
549480	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
549481	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Foundation Condition	Good	
549482	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
549483	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
549484	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
549485	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	80	
549486	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	20	
549487	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	60	
549488	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
549489	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
549490	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	20	°F
549491	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
549492	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
549493	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
549494	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
549495	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
549496	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Regulator As Left Counter	90511	
549497	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
549498	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
549499	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Tank Leaks	None	
549500	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
549501	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Operations Counter AF	259	
549502	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Operations Counter AL	261	
549503	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Switching Operations	2	
549504	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Tank Paint Condition	Good	
549505	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Unknown Operations	0	
549506	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
549507	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
549508	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
549509	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
549510	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
549511	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
549512	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
549513	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
549514	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
549515	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
549516	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
549517	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
549518	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Follow-up Action Required?	n	
549519	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
549520	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
549521	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	General Comments		
549522	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
549523	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
549524	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
549525	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
549526	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
549527	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
549528	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
549529	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
549530	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
549531	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
549532	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
549533	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
549534	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
549535	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
549536	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
549537	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
549538	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
549539	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
549540	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
549541	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
549542	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	nothing showing up for battery bank inspection	
549543	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
549544	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
549545	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
549546	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
549547	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
549548	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
549549	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
549550	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
549551	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
549552	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
549553	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
549554	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
549555	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Foundation Condition	Good	
549556	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
549557	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
549558	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
549559	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
549560	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
549561	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
549562	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
549563	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
549564	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
549565	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
549566	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
549567	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Current Tap Position	3R	
549568	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Max Tap Position	6R	
549569	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Min Tap Position	3L	
549570	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
549571	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	60	°C
549572	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	40	°C
549573	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BCH000483	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
549574	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BCH000483	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
549575	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BCH000483	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
549576	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
549577	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
549578	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BCH000483	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
549579	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BCH000483	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
549580	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	General Comments		
549581	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
549582	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	LTC Totalizer Reading	12398.40	kw
549583	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
549584	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
549585	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Oil Temp Max	25	°C
549586	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BCH000483	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
549587	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
549588	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
549589	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BCH000483	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
549590	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Operations Since Last Insp	914	
549591	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
549592	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
549593	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	FE000478	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
549594	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	FE000478	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
549595	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	FE000478	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
549596	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	FE000478	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
549597	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	FE000478	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
549598	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	FE000478	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
549599	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
549600	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
549601	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Winding Temp Present	20	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
549602	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Winding Temp Max	50	°C
549603	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Totalizer Meter Reading	.6888	
549604	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
549605	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
549606	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
549607	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
549608	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
549609	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
549610	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
549611	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
549612	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Oil Temp Present	25	°C
549613	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
549614	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
549615	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
549616	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Ambient Temp	18	°F
549617	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
549618	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
549619	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
549620	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
549621	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
549622	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
549623	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Amps A Ø	116.0	
549624	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Amps B Ø	105.0	
549625	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Amps C Ø	97.0	
549626	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
549627	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
549628	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
549629	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
549630	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
549631	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
549632	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
549633	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
549634	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
549635	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	FE000478	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
549636	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	FE000478	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
549637	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	FE000478	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
549638	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	FE000478	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
549639	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
549640	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
549641	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
549642	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
549643	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
549644	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
549645	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
549646	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Follow-up Action Required?	y	
549647	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
549648	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	General Comments	counter was verified. it was entered incorrectly the last check.	
549649	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
549650	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
549651	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Operations Counter	25	
549652	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
549653	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Tank Leaks	None	
549654	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
549655	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
549656	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	FE000478	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
549657	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	FE000478	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
549658	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	FE000478	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
549659	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	FE000478	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
549660	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
549661	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
549662	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
549663	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
549664	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
549665	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
549666	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	FE000478	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
549667	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
549668	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
549669	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
549670	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
549671	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
549672	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
549673	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	General Comments		
549674	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
549675	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Vegetation	None	
549676	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
549677	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
549678	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	General Comments		
549679	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
549680	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
549681	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
549682	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
549683	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
549684	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
549685	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Clear of Trash?	y	
549686	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
549687	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
549688	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Ambient Temp	18	°F
549689	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
549690	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	General Comments		
549691	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
549692	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
549693	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
549694	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
549695	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
549696	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
549697	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Clear of Trash?	y	
549698	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
549699	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
549700	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
549701	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
549702	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
549703	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
549704	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
549705	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
549706	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	9 Month Operations	4	
549707	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Accumulated Fault Duty A Ph V	0	%
549708	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Accumulated Fault Duty B Ph V	0	%
549709	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Accumulated Fault Duty C Ph V	0	%
549710	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Amps A Ø	82	
549711	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Amps B Ø	78	
549712	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Amps C Ø	65	
549713	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Bushing Condition	Good	
549714	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Bushings Connection/Risers	Good	
549715	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
549716	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	General Comments		
549717	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
549718	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
549719	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
549720	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
549721	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
549722	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
549723	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
549724	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
549725	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
549726	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
549727	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
549728	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
549729	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
549730	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
549731	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
549732	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Foundation Condition	Good	
549733	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
549734	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
549735	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
549736	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Ambient Temp	23	°F
549737	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
549738	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
549739	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
549740	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
549741	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
549742	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
549743	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
549744	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
549745	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
549746	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
549747	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
549748	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
549749	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
549750	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	General Comments		
549751	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
549752	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	General Comments	RESTROOM IS OUT OF ORDER, NEEDS FIXED	
549753	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
549754	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
549755	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
549756	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
549757	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
549758	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Totalizer Meter Reading	.6774	
549759	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
549760	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
549761	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Floor Swept?	y	
549762	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
549763	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
549764	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Evidence of Insects	None	
549765	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
549766	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
549767	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
549768	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
549769	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Broom on Site?	y	
549770	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
549771	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
549772	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Amps A Ø	80.0	
549773	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Amps B Ø	80.0	
549774	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Amps C Ø	80.0	
549775	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
549776	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
549777	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
549778	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
549779	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
549780	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
549781	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
549782	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
549783	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
549784	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
549785	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	General Comments		
549786	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
549787	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
549788	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Operations Counter	1484	
549789	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
549790	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Tank Leaks	None	
549791	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
549792	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Vegetation	None	
549793	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
549794	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
549795	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
549796	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
549797	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
549798	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
549799	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations C Ø	0	
549800	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations Ground	0	
549801	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Follow-up Action Required?	n	
549802	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Follow-up Action Required?	n	
549803	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Foundation Condition	Good	
549804	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
549805	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	General Comments		
549806	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	General Comments		
549807	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Grounds in Place?	y	
549808	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Heaters (All) Functioning?	y	
549809	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Maintenance Operations	0	
549810	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Moisture and Leak Free?	y	
549811	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
549812	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
549813	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
549814	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	General Comments		
549815	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
549816	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	General Comments		
549817	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Grounds in Place?	y	
549818	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Heaters (All) Functioning?	y	
549819	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Maintenance Operations	0	
549820	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Moisture and Leak Free?	y	
549821	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Operations Counter AF	219	
549822	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Operations Counter AL	221	
549823	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
549824	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Switching Operations	2	
549825	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Tank Paint Condition	Good	
549826	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
549827	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Ambient Temp	24	°F
549828	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
549829	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
549830	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Clear of Trash?	y	
549831	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
549832	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
549833	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
549834	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
549835	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
549836	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
549837	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	General Comments		
549838	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
549839	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Vegetation	None	
549840	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
549841	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
549842	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
549843	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
549844	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
549845	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
549846	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Current Tap Position	7R	
549847	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
549848	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
549849	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
549850	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
549851	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	General Comments		
549852	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
549853	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Max Tap Position	8R	
549854	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
549855	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
549856	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.000	millivolts
549857	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
549858	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
549859	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
549860	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	General Comments		
549861	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
549862	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
549863	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
549864	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
549865	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	General Comments		
549866	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
549867	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
549868	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
549869	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Paint Condition	Good	
549870	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Equipment Properly Labeled?	y	
549871	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
549872	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	9 Month Operations	7	
549873	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Accumulated Fault Duty A Ph V	6.04	%
549874	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Accumulated Fault Duty B Ph V	8.31	%
549875	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Accumulated Fault Duty C Ph V	5.29	%
549876	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Amps A Ø	16	
549877	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Amps B Ø	25	
549878	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Amps C Ø	16	
549879	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Bushing Condition	Good	
549880	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
549881	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
549882	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BB0083	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
549883	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
549884	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
549885	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
549886	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Bushings Connection/Risers	Good	
549887	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
549888	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
549889	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
549890	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
549891	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
549892	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
549893	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
549894	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Paint Condition	Good	
549895	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Equipment Properly Labeled?	y	
549896	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Adjusted Amps A Phase V	0	
549897	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Adjusted Amps B Phase V	0	
549898	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Adjusted Amps C Phase V	0	
549899	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations A Ø	0	
549900	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations B Ø	0	
549901	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
549902	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations Ground	0	
549903	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Follow-up Action Required?	n	
549904	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Follow-up Action Required?	n	
549905	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
549906	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
549907	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
549908	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
549909	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
549910	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Adjusted Amps A Phase V	0	
549911	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Adjusted Amps B Phase V	0	
549912	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Foundation Condition	Good	
549913	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	General Comments		
549914	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Adjusted Amps C Phase V	0	
549915	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations A Ø	0	
549916	3/4/2019 8:26	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations B Ø	0	
549917	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
549918	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
549919	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
549920	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
549921	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
549922	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
549923	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
549924	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
549925	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Max Tap Position	8R	
549926	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
549927	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
549928	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
549929	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
549930	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	General Comments		
549931	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
549932	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
549933	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
549934	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
549935	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
549936	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
549937	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Clear of Trash?	y	
549938	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
549939	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Ambient Temp	28	°F
549940	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Current Tap Position	6R	
549941	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
549942	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
549943	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	General Comments		
549944	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
549945	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
549946	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
549947	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
549948	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
549949	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
549950	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
549951	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
549952	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
549953	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Tank Leaks	None	
549954	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
549955	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Operations Counter	1418	
549956	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
549957	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
549958	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	General Comments		
549959	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
549960	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
549961	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
549962	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
549963	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
549964	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
549965	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
549966	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
549967	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
549968	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
549969	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
549970	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
549971	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
549972	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	General Comments		
549973	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
549974	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
549975	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
549976	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
549977	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
549978	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
549979	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
549980	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
549981	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
549982	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
549983	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Winding Temp Present	25	°C
549984	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Winding Temp Max	40	°C
549985	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Totalizer Meter Reading	.6430	
549986	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
549987	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Top Oil Temperature Present	20	°C
549988	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Top Oil Temperature Max	30	°C
549989	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
549990	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
549991	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
549992	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
549993	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
549994	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
549995	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
549996	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
549997	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
549998	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
549999	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	LTC Totalizer Reading	11574.00	kw
550000	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
550001	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	General Comments		
550002	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	General Comments		
550003	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
550004	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
550005	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Follow-up Action Required?	n	
550006	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
550007	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
550008	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
550009	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
550010	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Tank Leaks	None	
550011	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
550012	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
550013	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
550014	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
550015	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
550016	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Vegetation	None	
550017	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
550018	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
550019	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	General Comments		
550020	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
550021	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Regulator As Left Counter	52244	
550022	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
550023	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
550024	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
550025	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
550026	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Oil Temp Present	35	°C
550027	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Oil Temp Max	65	°C
550028	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
550029	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
550030	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	LTC Totalizer Reading	5734.08	kw
550031	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
550032	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	General Comments		
550033	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	General Comments		
550034	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
550035	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
550036	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Follow-up Action Required?	n	
550037	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
550038	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
550039	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
550040	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
550041	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
550042	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
550043	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
550044	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
550045	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
550046	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
550047	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
550048	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
550049	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
550050	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
550051	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
550052	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
550053	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
550054	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
550055	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
550056	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
550057	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
550058	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
550059	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
550060	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	General Comments		
550061	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
550062	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
550063	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Foundation Condition	Good	
550064	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
550065	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
550066	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
550067	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
550068	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
550069	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
550070	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
550071	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
550072	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Winding Temp Present	60	°C
550073	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Winding Temp Max	75	°C
550074	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Totalizer Meter Reading	.9532	
550075	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
550076	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
550077	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
550078	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
550079	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
550080	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
550081	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Amps A Ø	40.0	
550082	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Amps B Ø	40.0	
550083	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Amps C Ø	40.0	
550084	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
550085	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
550086	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
550087	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
550088	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
550089	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
550090	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
550091	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
550092	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
550093	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
550094	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
550095	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
550096	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
550097	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
550098	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Amps C Ø	5.0	
550099	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Amps B Ø	5.0	
550100	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Amps A Ø	5.0	
550101	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
550102	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
550103	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
550104	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	General Comments		
550105	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
550106	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
550107	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Operations Counter	1448	
550108	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Bushings Connection/Risers	Good	
550109	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Bushing Condition	Good	
550110	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Amps C Ø	50.0	
550111	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Amps B Ø	65.0	
550112	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Amps A Ø	60.0	
550113	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
550114	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Accumulated Fault Duty B Ph V	.91	%
550115	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Accumulated Fault Duty A Ph V	1.83	%
550116	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	9 Month Operations	9	
550117	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
550118	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Tank Leaks	None	
550119	3/4/2019 14:07	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
550120	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
550121	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
550122	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Winding Temp Present	0	°C
550123	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Winding Temp Max	0	°C
550124	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Totalizer Meter Reading	1.1946	
550125	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
550126	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
550127	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
550128	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
550129	3/4/2019 13:18	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
550130	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
550131	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Clear of Trash?	y	
550132	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
550133	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
550134	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
550135	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
550136	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
550137	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
550138	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
550139	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
550140	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Foundation Condition	Good	
550141	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
550142	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
550143	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	General Comments		
550144	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
550145	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
550146	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
550147	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
550148	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
550149	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
550150	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
550151	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
550152	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	General Comments		
550153	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
550154	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	General Comments		
550155	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
550156	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
550157	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
550158	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
550159	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
550160	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
550161	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
550162	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Vegetation	None	
550163	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
550164	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Heaters (All) Functioning?	y	
550165	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Grounds in Place?	y	
550166	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	General Comments		
550167	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	General Comments		
550168	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
550169	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
550170	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
550171	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
550172	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
550173	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
550174	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
550175	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
550176	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
550177	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
550178	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Broom on Site?	y	
550179	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Control House Lighting OK?	n	
550180	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
550181	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
550182	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
550183	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	General Comments		
550184	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
550185	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
550186	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
550187	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
550188	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
550189	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
550190	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
550191	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
550192	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Foundation Condition	Good	
550193	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
550194	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
550195	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
550196	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
550197	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
550198	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
550199	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
550200	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
550201	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
550202	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
550203	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
550204	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
550205	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
550206	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
550207	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	General Comments		
550208	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
550209	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
550210	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
550211	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
550212	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
550213	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Tank Leaks	None	
550214	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
550215	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
550216	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Regulator As Left Counter	24654	
550217	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
550218	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
550219	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
550220	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
550221	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
550222	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
550223	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
550224	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
550225	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
550226	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
550227	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
550228	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
550229	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
550230	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
550231	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
550232	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
550233	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
550234	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
550235	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
550236	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
550237	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
550238	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
550239	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
550240	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
550241	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0	VDC
550242	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0	VDC
550243	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
550244	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
550245	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
550246	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
550247	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	114	
550248	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	114	
550249	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	7	
550250	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
550251	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
550252	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
550253	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
550254	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	General Comments		
550255	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
550256	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
550257	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
550258	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
550259	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
550260	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
550261	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	BCH000574	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
550262	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	BCH000574	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
550263	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	BCH000574	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
550264	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	BCH000574	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
550265	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	BCH000574	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
550266	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	BCH000574	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
550267	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
550268	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Foundation Condition	Good	
550269	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
550270	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
550271	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Follow-up Action Required?	n	
550272	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Follow-up Action Required?	n	
550273	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Operations Ground	0	
550274	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Operations C Ø	0	
550275	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Operations B Ø	0	
550276	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
550277	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
550278	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
550279	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
550280	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Equipment Properly Labeled?	y	
550281	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Paint Condition	Good	
550282	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
550283	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
550284	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
550285	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
550286	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
550287	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
550288	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
550289	3/5/2019 12:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
550290	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
550291	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Evidence of Insects	None	
550292	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
550293	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
550294	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Floor Swept?	y	
550295	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
550296	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
550297	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	General Comments	5 4ft lights are out in control house	
550298	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
550299	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
550300	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Panels Dusted?	y	
550301	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
550302	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
550303	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Trash Emptied?	y	
550304	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
550305	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
550306	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
550307	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
550308	3/4/2019 13:33	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
550309	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	General Comments	Batt. Bank inspection was blank, no form to open. 20C temp. All connections ok	
550310	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
550311	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
550312	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
550313	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
550314	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
550315	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
550316	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
550317	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
550318	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
550319	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
550320	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
550321	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
550322	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
550323	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
550324	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	PF000075	PowerFuse	CS-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
550325	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	PF000075	PowerFuse	CS-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
550326	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	PF000076	PowerFuse	CS-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
550327	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
550328	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
550329	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	PF000076	PowerFuse	CS-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
550330	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
550331	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
550332	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
550333	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
550334	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
550335	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
550336	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
550337	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	General Comments		
550338	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
550339	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
550340	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
550341	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
550342	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
550343	3/4/2019 8:35	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
550344	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	General Comments		
550345	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
550346	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
550347	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
550348	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
550349	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Amps A Ø	5.0	
550350	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
550351	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
550352	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	General Comments		
550353	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
550354	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Regulator As Left Counter	91207	
550355	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
550356	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
550357	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
550358	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Tank Leaks	None	
550359	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
550360	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
550361	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
550362	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
550363	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
550364	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
550365	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
550366	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
550367	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Amps B Ø	5.0	
550368	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Maintenance Operations	0	
550369	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Operations Counter AF	129	
550370	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Operations Counter AL	129	
550371	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
550372	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Amps C Ø	5.0	
550373	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
550374	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
550375	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
550376	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Current Tap Position	7R	
550377	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
550378	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
550379	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
550380	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
550381	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
550382	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
550383	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
550384	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
550385	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
550386	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
550387	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
550388	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
550389	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	General Comments		
550390	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Switching Operations	0	
550391	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Oil Temp Max	60	°C
550392	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
550393	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
550394	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Operations Counter	873	
550395	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
550396	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Tank Leaks	None	
550397	3/4/2019 13:33	Distribution	Island Quarterly Inspection	BCH000420	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
550398	3/4/2019 13:33	Distribution	Island Quarterly Inspection	BCH000420	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
550399	3/4/2019 13:33	Distribution	Island Quarterly Inspection	BCH000420	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
550400	3/4/2019 11:21	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
550401	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
550402	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Unknown Operations	1	
550403	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
550404	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Oil Temp Present	55	°C
550405	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
550406	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
550407	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
550408	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
550409	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
550410	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
550411	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
550412	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
550413	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
550414	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
550415	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
550416	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
550417	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Patrol Inspection	Follow-up Action Required?	n	
550418	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations Ground	0	
550419	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations C Ø	0	
550420	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
550421	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Follow-up Action Required?	n	
550422	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
550423	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
550424	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	General Comments		
550425	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	General Comments		
550426	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
550427	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
550428	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
550429	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	LTC Totalizer Reading	17157.60	kw
550430	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
550431	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
550432	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
550433	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
550434	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
550435	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
550436	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
550437	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
550438	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
550439	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
550440	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
550441	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Patrol Inspection	General Comments		
550442	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
550443	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
550444	3/4/2019 11:58	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
550445	3/4/2019 12:22	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
550446	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
550447	3/4/2019 12:58	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Follow-up Action Required?	n	
550448	3/4/2019 13:33	Distribution	Island Quarterly Inspection	BCH000420	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
550449	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
550450	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Max Tap Position	8R	
550451	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
550452	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
550453	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
550454	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
550455	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
550456	3/4/2019 15:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
550457	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
550458	3/4/2019 11:26	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
550459	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
550460	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
550461	3/4/2019 11:03	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
550462	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Min Tap Position	4L	
550463	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
550464	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
550465	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
550466	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	1545	
550467	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
550468	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Patrol Inspection	General Comments		
550469	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	General Comments		
550470	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
550471	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Max Tap Position	1R	
550472	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Switching Operations	0	
550473	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Maintenance Operations	0	
550474	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Current Tap Position	Neutral	
550475	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Unknown Operations	0	
550476	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	General Comments		
550477	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Operations Counter AF	164	
550478	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Operations Counter AL	164	
550479	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
550480	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC As Found Counter	15281	
550481	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
550482	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Switching Operations	0	
550483	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
550484	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC As Left Counter	15281	
550485	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
550486	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Unknown Operations	0	
550487	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
550488	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	180.0	
550489	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	160.0	
550490	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	160.0	
550491	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
550492	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
550493	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
550494	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
550495	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
550496	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
550497	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
550498	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	60.0	
550499	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
550500	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
550501	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	100.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
550502	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	40.0	
550503	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
550504	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
550505	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
550506	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
550507	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
550508	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
550509	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
550510	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	4	
550511	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
550512	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
550513	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
550514	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	General Comments		
550515	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
550516	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
550517	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
550518	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
550519	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
550520	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
550521	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
550522	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
550523	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
550524	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
550525	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
550526	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
550527	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
550528	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
550529	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
550530	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
550531	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
550532	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
550533	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	General Comments		
550534	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
550535	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
550536	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
550537	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
550538	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
550539	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
550540	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
550541	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
550542	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
550543	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
550544	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
550545	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
550546	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
550547	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
550548	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
550549	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
550550	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
550551	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
550552	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
550553	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	General Comments	A few limbs are starting to grow over the fence	
550554	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
550555	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
550556	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
550557	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Amps C Ø	413.0	
550558	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Amps B Ø	415.0	
550559	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Amps A Ø	552.0	
550560	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
550561	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Readings	General Comments		
550562	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
550563	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	9.63	%
550564	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	9.63	%
550565	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	9.63	%
550566	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	9 Month Operations	1	
550567	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
550568	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
550569	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
550570	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
550571	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
550572	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
550573	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
550574	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1587	
550575	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
550576	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
550577	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
550578	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
550579	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
550580	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
550581	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
550582	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Clear of Trash?	y	
550583	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
550584	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
550585	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
550586	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
550587	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
550588	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
550589	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
550590	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
550591	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
550592	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
550593	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
550594	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
550595	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
550596	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
550597	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
550598	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
550599	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
550600	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1340	
550601	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1340	
550602	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	3	
550603	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
550604	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
550605	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
550606	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Foundation Condition	Good	
550607	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	General Comments		
550608	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Grounds in Place?	y	
550609	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
550610	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	General Comments		
550611	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
550612	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
550613	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
550614	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
550615	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Vegetation	None	
550616	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
550617	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
550618	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
550619	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
550620	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	603	
550621	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Min Tap Position	14L	
550622	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Max Tap Position	7L	
550623	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
550624	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
550625	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
550626	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Operations Counter AL	389	
550627	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Operations Counter AF	389	
550628	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
550629	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
550630	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations Ground	0	
550631	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Maintenance Operations	0	
550632	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	General Comments		
550633	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
550634	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
550635	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
550636	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
550637	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Patrol Inspection	General Comments		
550638	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Follow-up Action Required?	n	
550639	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Patrol Inspection	Follow-up Action Required?	n	
550640	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations Ground	0	
550641	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
550642	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	30	°C
550643	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	30	°C
550644	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
550645	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.3	psi
550646	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	Oil Temp Max	35	°C
550647	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
550648	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
550649	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
550650	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
550651	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
550652	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
550653	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
550654	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
550655	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations C Ø	0	
550656	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations B Ø	0	
550657	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
550658	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations A Ø	0	
550659	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
550660	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
550661	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
550662	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
550663	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
550664	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
550665	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
550666	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
550667	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
550668	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
550669	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
550670	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
550671	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
550672	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
550673	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
550674	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
550675	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
550676	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
550677	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
550678	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
550679	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
550680	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
550681	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
550682	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
550683	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
550684	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
550685	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
550686	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
550687	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
550688	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
550689	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
550690	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
550691	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
550692	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Totalizer Meter Reading	.8005	
550693	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
550694	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
550695	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
550696	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
550697	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
550698	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
550699	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
550700	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
550701	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	100.0	
550702	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
550703	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
550704	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
550705	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	1	
550706	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1516	
550707	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1516	
550708	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
550709	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
550710	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
550711	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
550712	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
550713	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
550714	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
550715	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
550716	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
550717	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
550718	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Trash Emptied?	n	
550719	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
550720	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	General Comments		
550721	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
550722	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
550723	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Floor Swept?	n	
550724	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
550725	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
550726	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
550727	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
550728	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
550729	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Totalizer Meter Reading	.5472	
550730	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Winding Temp Max	40	°C
550731	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Winding Temp Present	30	°C
550732	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	310.00	
550733	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
550734	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
550735	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
550736	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Evidence of Insects	None	
550737	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
550738	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
550739	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
550740	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Broom on Site?	n	
550741	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
550742	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
550743	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
550744	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
550745	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments		
550746	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
550747	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
550748	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
550749	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
550750	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
550751	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
550752	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
550753	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
550754	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
550755	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
550756	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
550757	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
550758	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Bushings Connection/Risers	Good	
550759	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Bushing Condition	Good	
550760	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
550761	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
550762	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Trash Emptied?	n	
550763	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
550764	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
550765	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
550766	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
550767	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
550768	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
550769	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
550770	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
550771	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
550772	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
550773	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
550774	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
550775	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
550776	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Tank Paint Condition	Good	
550777	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
550778	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
550779	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Moisture and Leak Free?	y	
550780	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Grounds in Place?	y	
550781	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
550782	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	General Comments		
550783	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	PF001205	PowerFuse	AL-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
550784	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	PF001205	PowerFuse	AL-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
550785	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
550786	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
550787	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Foundation Condition	Good	
550788	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Follow-up Action Required?	n	
550789	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	PF001206	PowerFuse	AL-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
550790	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	PF001206	PowerFuse	AL-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
550791	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Equipment Properly Labeled?	y	
550792	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Paint Condition	Good	
550793	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	PF001207	PowerFuse	AL-14KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
550794	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	PF001207	PowerFuse	AL-14KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
550795	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
550796	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
550797	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
550798	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
550799	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
550800	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
550801	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
550802	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
550803	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
550804	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
550805	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
550806	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
550807	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
550808	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
550809	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
550810	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
550811	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
550812	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
550813	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Bushing Condition	Good	
550814	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Bushings Connection/Risers	Good	
550815	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
550816	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
550817	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
550818	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Paint Condition	Good	
550819	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Equipment Properly Labeled?	y	
550820	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Follow-up Action Required?	n	
550821	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Foundation Condition	Good	
550822	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	General Comments		
550823	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Readings	General Comments		
550824	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Grounds in Place?	y	
550825	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Moisture and Leak Free?	y	
550826	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
550827	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
550828	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
550829	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
550830	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Tank Paint Condition	Good	
550831	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
550832	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
550833	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	80.0	
550834	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	60.0	
550835	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
550836	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
550837	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
550838	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
550839	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
550840	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
550841	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	General Comments		
550842	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
550843	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC As Found Counter	59479	
550844	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
550845	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Broom on Site?	y	
550846	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
550847	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	General Comments		
550848	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	General Comments	will need nitro	
550849	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
550850	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
550851	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
550852	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
550853	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
550854	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
550855	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Foundation Condition	Good	
550856	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
550857	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC As Left Counter	59479	
550858	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
550859	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
550860	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
550861	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Operations Since Last Insp	159	
550862	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
550863	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	General Comments		
550864	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
550865	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
550866	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
550867	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Min Tap Position	2R	
550868	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Max Tap Position	4L	
550869	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
550870	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
550871	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
550872	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
550873	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
550874	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
550875	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
550876	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Current Tap Position	2R	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
550877	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
550878	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC As Left Counter	230835	
550879	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC As Found Counter	230832	
550880	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	General Comments		
550881	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
550882	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
550883	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
550884	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
550885	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
550886	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	General Comments		
550887	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
550888	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	Follow-up Action Required?	n	
550889	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
550890	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7R	
550891	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
550892	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	978	
550893	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	982	
550894	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
550895	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
550896	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
550897	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
550898	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
550899	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
550900	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
550901	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
550902	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
550903	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
550904	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	560.0	
550905	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	560.0	
550906	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	540.0	
550907	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
550908	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
550909	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
550910	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
550911	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
550912	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
550913	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
550914	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
550915	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
550916	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
550917	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
550918	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
550919	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
550920	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
550921	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
550922	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
550923	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	General Comments		
550924	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
550925	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
550926	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
550927	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	1	
550928	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	903	
550929	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	903	
550930	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
550931	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
550932	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
550933	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
550934	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
550935	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
550936	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
550937	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
550938	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
550939	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
550940	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
550941	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
550942	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
550943	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
550944	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
550945	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
550946	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
550947	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
550948	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
550949	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
550950	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
550951	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
550952	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
550953	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
550954	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	General Comments		
550955	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
550956	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
550957	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
550958	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
550959	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
550960	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
550961	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments		
550962	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
550963	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
550964	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Swept?	y	
550965	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
550966	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
550967	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
550968	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
550969	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
550970	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
550971	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
550972	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
550973	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
550974	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
550975	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
550976	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
550977	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
550978	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Operations Counter AL	314	
550979	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Operations Counter AF	310	
550980	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Moisture and Leak Free?	y	
550981	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Maintenance Operations	0	
550982	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Grounds in Place?	y	
550983	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	General Comments	Blown lightning arrester	
550984	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	General Comments		
550985	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Foundation Condition	Good	
550986	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Follow-up Action Required?	n	
550987	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Bushings Connection/Risers	Good	
550988	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
550989	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
550990	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
550991	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Paint Condition	Good	
550992	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Equipment Properly Labeled?	y	
550993	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
550994	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
550995	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Follow-up Action Required?	n	
550996	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Operations Ground	0	
550997	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Operations C Ø	0	
550998	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Operations B Ø	0	
550999	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Operations A Ø	0	
551000	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
551001	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
551002	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
551003	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Equipment Properly Labeled?	y	
551004	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
551005	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations A Ø	0	
551006	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations B Ø	0	
551007	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations C Ø	0	
551008	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations Ground	0	
551009	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Follow-up Action Required?	n	
551010	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Follow-up Action Required?	n	
551011	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Foundation Condition	Good	
551012	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	General Comments		
551013	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	General Comments		
551014	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Grounds in Place?	y	
551015	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Heaters (All) Functioning?	y	
551016	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Maintenance Operations	0	
551017	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Moisture and Leak Free?	y	
551018	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Operations Counter AF	509	
551019	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
551020	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
551021	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
551022	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
551023	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
551024	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
551025	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
551026	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
551027	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
551028	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
551029	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
551030	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	LTCC000167	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
551031	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	LTCC000167	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
551032	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	LTCC000167	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
551033	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
551034	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	LTCC000167	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
551035	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	LTCC000167	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
551036	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
551037	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1706	
551038	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1706	
551039	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
551040	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
551041	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
551042	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
551043	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
551044	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
551045	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
551046	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
551047	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
551048	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
551049	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Totalizer Meter Reading	1.2380	
551050	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
551051	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
551052	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Accumulated Fault Duty B Ph V	.80	%
551053	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Amps C Ø	60.0	
551054	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Amps B Ø	67.0	
551055	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Amps A Ø	95.0	
551056	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0232	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
551057	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0232	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
551058	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0232	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
551059	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0232	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
551060	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0232	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
551061	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0232	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
551062	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Accumulated Fault Duty C Ph V	10.36	%
551063	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Accumulated Fault Duty B Ph V	19.13	%
551064	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Accumulated Fault Duty A Ph V	15.94	%
551065	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LTCC000406	LTCControl	FM-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
551066	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
551067	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
551068	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
551069	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	9 Month Operations	3	
551070	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Accumulated Fault Duty A Ph V	.60	%
551071	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Accumulated Fault Duty B Ph V	.60	%
551072	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
551073	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
551074	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
551075	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
551076	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Accumulated Fault Duty C Ph V	.60	%
551077	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Amps A Ø	250.0	
551078	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
551079	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
551080	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Patrol Inspection	Equipment Properly Labeled?	y	
551081	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Amps C Ø	255.0	
551082	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Amps B Ø	243.0	
551083	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
551084	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
551085	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
551086	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
551087	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
551088	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Accumulated Fault Duty A Ph V	.80	%
551089	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	9 Month Operations	0	
551090	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
551091	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
551092	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
551093	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
551094	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
551095	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
551096	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
551097	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
551098	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Amps B Ø	254.0	
551099	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Amps C Ø	235.0	
551100	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Bushing Condition	Good	
551101	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
551102	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
551103	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
551104	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
551105	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
551106	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	PF000007	PowerFuse	AL-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
551107	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Unknown Operations	0	
551108	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Tank Paint Condition	Good	
551109	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Switching Operations	4	
551110	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
551111	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	PF000007	PowerFuse	AL-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
551112	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
551113	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
551114	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
551115	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
551116	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
551117	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	General Comments		
551118	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	LTC Operation Checked?	y	
551119	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
551120	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
551121	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
551122	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
551123	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
551124	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
551125	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
551126	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
551127	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
551128	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	General Comments		
551129	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	50.0	
551130	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	Desiccant needs replaced.	
551131	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	50.0	
551132	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	50.0	
551133	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
551134	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
551135	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
551136	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
551137	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	VRR Time Delay	30	Seconds
551138	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
551139	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Accumulated Fault Duty C Ph V	17.54	%
551140	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	BCH000216	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
551141	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	BCH000216	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
551142	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Accumulated Fault Duty B Ph V	22.32	%
551143	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Accumulated Fault Duty A Ph V	19.13	%
551144	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations A Ø	0	
551145	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations B Ø	0	
551146	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
551147	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
551148	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
551149	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Amps B Ø	12.0	
551150	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC As Found Counter	108514	
551151	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC As Left Counter	108514	
551152	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	9 Month Operations	20	
551153	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	50	°C
551154	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	65	°C
551155	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
551156	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	30	°C
551157	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
551158	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	40	°C
551159	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Unknown Operations	0	
551160	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Tank Paint Condition	Good	
551161	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
551162	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	100.0	
551163	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	100.0	
551164	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	100.0	
551165	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
551166	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
551167	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
551168	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
551169	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Cabinet Paint Condition	Good	
551170	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
551171	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Switching Operations	1	
551172	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
551173	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Operations Counter AL	189	
551174	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Operations Counter AF	189	
551175	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Moisture and Leak Free?	y	
551176	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
551177	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Heaters (All) Functioning?	y	
551178	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Grounds in Place?	y	
551179	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	General Comments		
551180	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	General Comments		
551181	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Foundation Condition	Good	
551182	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Follow-up Action Required?	n	
551183	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Follow-up Action Required?	n	
551184	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations Ground	0	
551185	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations C Ø	0	
551186	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
551187	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
551188	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Bushings Connection/Risers	Good	
551189	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Bushing Condition	Good	
551190	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Amps C Ø	12.0	
551191	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	LTCC000167	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
551192	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	LTCC000167	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
551193	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	LTCC000167	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
551194	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	LTCC000386	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
551195	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	LTCC000386	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
551196	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	LTCC000386	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
551197	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
551198	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
551199	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	LTCC000386	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
551200	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	LTCC000386	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
551201	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	LTCC000386	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
551202	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	LTCC000386	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
551203	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	LTCC000386	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
551204	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	9 Month Operations	4	
551205	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LTCC000406	LTCControl	FM-TRANS 2	LTC Control Insp	General Comments		
551206	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	General Comments		
551207	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
551208	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
551209	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
551210	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
551211	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LTCC000360	LTCControl	FM-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
551212	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LTCC000360	LTCControl	FM-TRANS 1	LTC Control Insp	General Comments		
551213	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LTCC000360	LTCControl	FM-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
551214	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Amps A Ø	281.0	
551215	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
551216	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
551217	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
551218	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
551219	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
551220	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
551221	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LTCC000406	LTCControl	FM-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
551222	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	140.0	
551223	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	BCH000216	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
551224	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	BCH000216	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
551225	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	BCH000216	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
551226	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
551227	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.40	%
551228	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
551229	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
551230	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
551231	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	All Connections OK?	y	
551232	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Operations Counter AL	509	
551233	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
551234	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Switching Operations	0	
551235	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Tank Paint Condition	Good	
551236	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Unknown Operations	0	
551237	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	9 Month Operations	2	
551238	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Accumulated Fault Duty A Ph V	.60	%
551239	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Accumulated Fault Duty B Ph V	.60	%
551240	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
551241	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Amps A Ø	203.0	
551242	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Amps B Ø	217.0	
551243	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Amps C Ø	219.0	
551244	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
551245	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Bushing Condition	Good	
551246	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Bushings Connection/Risers	Good	
551247	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
551248	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
551249	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
551250	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Paint Condition	Good	
551251	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
551252	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
551253	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
551254	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
551255	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
551256	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
551257	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
551258	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
551259	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
551260	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
551261	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
551262	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
551263	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
551264	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
551265	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	Follow-up Action Required?	n	
551266	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
551267	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
551268	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
551269	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
551270	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
551271	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Follow-up Action Required?	n	
551272	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
551273	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
551274	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
551275	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
551276	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
551277	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
551278	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
551279	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
551280	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
551281	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
551282	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
551283	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
551284	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
551285	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	General Comments		
551286	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
551287	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
551288	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
551289	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
551290	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
551291	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
551292	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	9 Month Operations	6	
551293	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
551294	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
551295	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
551296	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Amps A Ø	136.0	
551297	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Amps B Ø	147.0	
551298	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
551299	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Clear of Trash?	y	
551300	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
551301	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
551302	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
551303	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
551304	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
551305	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
551306	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
551307	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
551308	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
551309	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
551310	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Amps C Ø	125.0	
551311	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Bushing Condition	Good	
551312	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Bushings Connection/Risers	Good	
551313	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
551314	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
551315	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
551316	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Paint Condition	Good	
551317	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Equipment Properly Labeled?	y	
551318	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
551319	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
551320	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
551321	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	General Comments		
551322	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
551323	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
551324	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
551325	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
551326	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
551327	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
551328	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
551329	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
551330	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations A Ø	0	
551331	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
551332	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
551333	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
551334	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
551335	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
551336	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
551337	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations B Ø	0	
551338	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations C Ø	0	
551339	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations Ground	0	
551340	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0235	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
551341	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
551342	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
551343	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
551344	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
551345	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
551346	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
551347	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	General Comments		
551348	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
551349	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
551350	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Foundation Condition	Good	
551351	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
551352	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
551353	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
551354	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
551355	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
551356	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
551357	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
551358	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
551359	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
551360	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
551361	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
551362	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
551363	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Radiator Leaks	None	
551364	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
551365	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Foundation Condition	Good	
551366	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0235	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
551367	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Tank Leaks	None	
551368	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
551369	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
551370	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
551371	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
551372	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
551373	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
551374	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
551375	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
551376	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
551377	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Vegetation	None	
551378	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
551379	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
551380	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
551381	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	General Comments		
551382	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
551383	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
551384	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Oil Temp Present	30	°C
551385	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Oil Temp Max	45	°C
551386	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
551387	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
551388	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
551389	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	LTC Totalizer Reading	3842.40	kw
551390	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
551391	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	General Comments		
551392	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	General Comments		
551393	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
551394	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
551395	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
551396	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
551397	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1587	
551398	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
551399	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
551400	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
551401	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0235	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
551402	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0235	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
551403	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
551404	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
551405	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
551406	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	827	
551407	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	827	
551408	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0235	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
551409	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0235	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
551410	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
551411	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
551412	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
551413	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
551414	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	General Comments		
551415	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
551416	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
551417	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
551418	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
551419	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
551420	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
551421	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
551422	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
551423	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
551424	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
551425	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
551426	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
551427	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
551428	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
551429	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
551430	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
551431	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
551432	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
551433	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
551434	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
551435	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	9 Month Operations	8	
551436	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Accumulated Fault Duty A Ph V	3.92	%
551437	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Accumulated Fault Duty B Ph V	5.88	%
551438	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Accumulated Fault Duty C Ph V	3.92	%
551439	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
551440	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Amps A Ø	12.0	
551441	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
551442	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Follow-up Action Required?	n	
551443	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
551444	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
551445	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
551446	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
551447	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
551448	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	General Comments		
551449	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	General Comments		
551450	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
551451	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
551452	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Readings	General Comments		
551453	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	LTC Totalizer Reading	8913.60	kw
551454	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
551455	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
551456	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
551457	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
551458	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Unknown Operations	0	
551459	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Switching Operations	0	
551460	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Operations Counter AL	206	
551461	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Operations Counter AF	206	
551462	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Maintenance Operations	0	
551463	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	General Comments	R&C	
551464	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Patrol Inspection	General Comments		
551465	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Follow-up Action Required?	n	
551466	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Patrol Inspection	Follow-up Action Required?	n	
551467	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations Ground	0	
551468	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations C Ø	0	
551469	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations B Ø	0	
551470	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
551471	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
551472	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations A Ø	0	
551473	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
551474	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
551475	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
551476	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
551477	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Amps C Ø	0.0	
551478	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Amps B Ø	0.0	
551479	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Amps A Ø	0.0	
551480	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Accumulated Fault Duty C Ph V	.80	%
551481	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
551482	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Oil Temp Max	70	°C
551483	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	General Comments		
551484	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
551485	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
551486	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Oil Temp Present	47	°C
551487	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
551488	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
551489	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Follow-up Action Required?	n	
551490	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Follow-up Action Required?	n	
551491	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Foundation Condition	Good	
551492	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	General Comments		
551493	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	General Comments		
551494	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
551495	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
551496	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
551497	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Grounds in Place?	y	
551498	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Maintenance Operations	0	
551499	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Moisture and Leak Free?	y	
551500	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
551501	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
551502	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
551503	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
551504	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
551505	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
551506	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
551507	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
551508	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
551509	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
551510	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
551511	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
551512	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
551513	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Operations Counter AF	202	
551514	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Operations Counter AL	202	
551515	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Switching Operations	3	
551516	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Tank Paint Condition	Good	
551517	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Unknown Operations	0	
551518	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
551519	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
551520	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
551521	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
551522	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
551523	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
551524	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
551525	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
551526	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	18	
551527	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1664	
551528	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1664	
551529	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
551530	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
551531	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
551532	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
551533	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
551534	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
551535	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
551536	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
551537	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
551538	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
551539	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1589	
551540	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1589	
551541	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
551542	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
551543	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
551544	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
551545	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
551546	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
551547	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
551548	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	General Comments		
551549	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
551550	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
551551	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
551552	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
551553	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
551554	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
551555	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
551556	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
551557	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
551558	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
551559	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
551560	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
551561	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
551562	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
551563	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
551564	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
551565	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Operations Counter AL	199	
551566	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Operations Counter AF	199	
551567	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Heaters (All) Functioning?	y	
551568	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Grounds in Place?	y	
551569	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
551570	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Ventilation Free of Debris?	y	
551571	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Trash Emptied?	y	
551572	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	PF000014	PowerFuse	AL-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
551573	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	PF000014	PowerFuse	AL-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
551574	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
551575	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
551576	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
551577	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	PF000015	PowerFuse	AL-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
551578	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	PF000015	PowerFuse	AL-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
551579	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
551580	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
551581	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	PF000016	PowerFuse	AL-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
551582	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	PF000016	PowerFuse	AL-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
551583	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
551584	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Maintenance Operations	0	
551585	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	General Comments		
551586	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Patrol Inspection	General Comments		
551587	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Follow-up Action Required?	n	
551588	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Patrol Inspection	Follow-up Action Required?	n	
551589	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations Ground	0	
551590	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
551591	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
551592	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
551593	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
551594	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
551595	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
551596	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
551597	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
551598	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
551599	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
551600	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations C Ø	0	
551601	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations B Ø	0	
551602	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations A Ø	0	
551603	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Switch Diagram Present/Current	y	
551604	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Station Ground Set On Site?	y	
551605	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Panels Dusted?	y	
551606	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Panel Lights OK?	y	
551607	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
551608	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
551609	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
551610	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Patrol Inspection	Equipment Properly Labeled?	y	
551611	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Amps C Ø	103.0	
551612	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Amps B Ø	99.0	
551613	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Amps A Ø	183.0	
551614	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Accumulated Fault Duty C Ph V	30.29	%
551615	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Accumulated Fault Duty B Ph V	31.89	%
551616	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
551617	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
551618	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
551619	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Amps B Ø	200.0	
551620	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Amps A Ø	232.0	
551621	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Accumulated Fault Duty C Ph V	8.61	%
551622	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Accumulated Fault Duty B Ph V	10.76	%
551623	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Accumulated Fault Duty A Ph V	15.78	%
551624	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	9 Month Operations	4	
551625	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	General Comments		
551626	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
551627	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
551628	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
551629	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
551630	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Tank Paint Condition	Good	
551631	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
551632	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Operations Counter AL	268	
551633	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
551634	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
551635	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
551636	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
551637	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
551638	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
551639	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
551640	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
551641	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
551642	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
551643	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
551644	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
551645	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
551646	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
551647	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
551648	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
551649	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
551650	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
551651	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
551652	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
551653	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
551654	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	General Comments		
551655	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
551656	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
551657	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
551658	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	16	
551659	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Unknown Operations	0	
551660	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Switching Operations	0	
551661	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1852	
551662	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Operations Counter AF	268	
551663	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Moisture and Leak Free?	y	
551664	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Maintenance Operations	5	
551665	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1852	
551666	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
551667	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	2	
551668	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
551669	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
551670	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
551671	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
551672	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
551673	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
551674	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations Ground	0	
551675	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Follow-up Action Required?	n	
551676	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	PF000127	PowerFuse	FM-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
551677	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	PF000127	PowerFuse	FM-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
551678	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Follow-up Action Required?	n	
551679	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Foundation Condition	Good	
551680	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	General Comments		
551681	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	General Comments		
551682	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	PF000126	PowerFuse	FM-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
551683	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	PF000126	PowerFuse	FM-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
551684	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	PF000125	PowerFuse	FM-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
551685	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	PF000125	PowerFuse	FM-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
551686	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	PF000124	PowerFuse	FM-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
551687	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	PF000124	PowerFuse	FM-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
551688	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Grounds in Place?	y	
551689	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Heaters (All) Functioning?	y	
551690	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Maintenance Operations	0	
551691	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Moisture and Leak Free?	y	
551692	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Operations Counter AF	1040	
551693	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	BCH000279	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
551694	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	BCH000279	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
551695	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	BCH000279	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
551696	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	BCH000279	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.5	amps
551697	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	BCH000279	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
551698	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	BCH000279	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
551699	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	BCH000279	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	14.000	millivolts
551700	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Operations Counter AL	1042	
551701	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
551702	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Switching Operations	2	
551703	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Tank Paint Condition	Good	
551704	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Unknown Operations	0	
551705	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Moisture and Leak Free?	y	
551706	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	General Comments		
551707	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
551708	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	General Comments		
551709	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	General Comments		
551710	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Foundation Condition	Good	
551711	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Follow-up Action Required?	n	
551712	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Follow-up Action Required?	n	
551713	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Operations Ground	0	
551714	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Operations C Ø	0	
551715	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Operations B Ø	0	
551716	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Operations A Ø	0	
551717	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
551718	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
551719	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
551720	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Equipment Properly Labeled?	y	
551721	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Cabinet Paint Condition	Good	
551722	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
551723	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
551724	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Follow-up Action Required?	n	
551725	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Floor Swept?	y	
551726	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Floor Condition Acceptable?	y	
551727	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
551728	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Evidence of Insects	None	
551729	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
551730	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
551731	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
551732	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
551733	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Accumulated Fault Duty A Ph V	30.29	%
551734	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	9 Month Operations	3	
551735	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
551736	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
551737	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
551738	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
551739	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
551740	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
551741	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	84	
551742	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
551743	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Min Tap Position	6R	
551744	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Max Tap Position	9R	
551745	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Current Tap Position	7R	
551746	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
551747	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC As Left Counter	78515	
551748	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC As Found Counter	78515	
551749	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
551750	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	General Comments		
551751	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
551752	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
551753	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
551754	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
551755	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
551756	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
551757	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
551758	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
551759	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
551760	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
551761	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
551762	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
551763	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
551764	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	9 Month Operations	2	
551765	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Accumulated Fault Duty A Ph V	.83	%
551766	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Accumulated Fault Duty B Ph V	.83	%
551767	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Accumulated Fault Duty C Ph V	.83	%
551768	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Amps A Ø	155.0	
551769	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Amps B Ø	125.0	
551770	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Amps C Ø	118.0	
551771	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Bushing Condition	Good	
551772	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Bushings Connection/Risers	Good	
551773	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
551774	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
551775	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
551776	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
551777	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Equipment Properly Labeled?	y	
551778	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
551779	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
551780	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
551781	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations A Ø	0	
551782	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations B Ø	0	
551783	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations C Ø	0	
551784	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
551785	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
551786	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Equipment Properly Labeled?	y	
551787	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Follow-up Action Required?	n	
551788	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Foundation Condition	Good	
551789	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	General Comments		
551790	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Grounds in Place?	y	
551791	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Moisture and Leak Free?	y	
551792	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
551793	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Tank Paint Condition	Good	
551794	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
551795	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
551796	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
551797	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
551798	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
551799	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
551800	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
551801	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
551802	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
551803	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Follow-up Action Required?	n	
551804	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
551805	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
551806	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
551807	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
551808	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
551809	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
551810	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	General Comments		
551811	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	General Comments		
551812	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
551813	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	LTC Totalizer Reading	2658.00	kw
551814	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
551815	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
551816	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Oil Temp Max	57	°C
551817	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Oil Temp Present	46	°C
551818	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
551819	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
551820	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	9 Month Operations	8	
551821	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Accumulated Fault Duty A Ph V	1.96	%
551822	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Accumulated Fault Duty B Ph V	1.96	%
551823	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Accumulated Fault Duty C Ph V	1.96	%
551824	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Amps A Ø	12.0	
551825	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Amps B Ø	12.0	
551826	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Amps C Ø	12.0	
551827	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Bushing Condition	Good	
551828	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Bushings Connection/Risers	Good	
551829	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
551830	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
551831	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
551832	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Paint Condition	Good	
551833	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Equipment Properly Labeled?	y	
551834	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
551835	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
551836	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
551837	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations A Ø	0	
551838	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations B Ø	0	
551839	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
551840	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Trash Emptied?	y	
551841	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
551842	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
551843	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
551844	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
551845	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
551846	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
551847	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
551848	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
551849	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
551850	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
551851	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
551852	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
551853	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
551854	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Readings	General Comments		
551855	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
551856	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
551857	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
551858	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
551859	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	988	
551860	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	988	
551861	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
551862	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
551863	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
551864	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
551865	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
551866	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
551867	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
551868	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Bushing Condition	Good	
551869	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Bushings Connection/Risers	Good	
551870	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
551871	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
551872	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
551873	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Paint Condition	Good	
551874	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
551875	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
551876	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
551877	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
551878	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
551879	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
551880	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
551881	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
551882	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	General Comments	fence is old, looks rough ...couple of wash out spots on creek side of fence...corner fence post has been hit and bent in, making the to	
551883	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
551884	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
551885	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
551886	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
551887	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
551888	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
551889	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
551890	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
551891	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
551892	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
551893	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
551894	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
551895	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
551896	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Bushings Connection/Risers	Good	
551897	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Bushing Condition	Good	
551898	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Amps C Ø	135.0	
551899	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Amps B Ø	137.0	
551900	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Amps A Ø	153.0	
551901	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Accumulated Fault Duty C Ph V	.21	%
551902	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Accumulated Fault Duty B Ph V	.21	%
551903	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Accumulated Fault Duty A Ph V	.21	%
551904	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	9 Month Operations	2	
551905	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
551906	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
551907	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
551908	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	General Comments		
551909	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	General Comments		
551910	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Patrol Inspection	General Comments		
551911	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Follow-up Action Required?	n	
551912	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Patrol Inspection	Follow-up Action Required?	n	
551913	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations Ground	0	
551914	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations C Ø	0	
551915	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations B Ø	0	
551916	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations A Ø	0	
551917	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
551918	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
551919	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Grounds in Place?	y	
551920	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Maintenance Operations	0	
551921	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Moisture and Leak Free?	y	
551922	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Operations Counter AF	326	
551923	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Operations Counter AL	330	
551924	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
551925	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Switching Operations	4	
551926	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
551927	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Unknown Operations	0	
551928	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Clear of Trash?	y	
551929	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
551930	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
551931	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
551932	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1186	
551933	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1186	
551934	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
551935	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
551936	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
551937	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
551938	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
551939	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Totalizer Meter Reading	.4430	
551940	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
551941	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
551942	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Unknown Operations	0	
551943	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
551944	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
551945	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
551946	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
551947	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Patrol Inspection	Equipment Properly Labeled?	y	
551948	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Amps C Ø	214.0	
551949	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations C Ø	0	
551950	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations Ground	0	
551951	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Follow-up Action Required?	n	
551952	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Follow-up Action Required?	n	
551953	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Unknown Operations	0	
551954	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Switching Operations	0	
551955	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Operations Counter AL	576	
551956	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Operations Counter AF	576	
551957	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Maintenance Operations	0	
551958	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
551959	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Vegetation	None	
551960	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
551961	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
551962	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
551963	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
551964	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	General Comments		
551965	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
551966	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
551967	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
551968	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	General Comments		
551969	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Foundation Condition	Good	
551970	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
551971	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
551972	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
551973	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
551974	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
551975	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
551976	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
551977	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
551978	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
551979	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
551980	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Unknown Operations	0	
551981	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Tank Paint Condition	Good	
551982	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Switching Operations	0	
551983	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
551984	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Operations Counter AL	206	
551985	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Operations Counter AF	206	
551986	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Moisture and Leak Free?	y	
551987	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Maintenance Operations	0	
551988	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Heaters (All) Functioning?	y	
551989	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Grounds in Place?	y	
551990	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	General Comments		
551991	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	General Comments		
551992	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Foundation Condition	Good	
551993	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Follow-up Action Required?	n	
551994	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Follow-up Action Required?	n	
551995	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations Ground	0	
551996	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations C Ø	0	
551997	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations B Ø	0	
551998	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations A Ø	0	
551999	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
552000	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
552001	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
552002	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Equipment Properly Labeled?	y	
552003	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Paint Condition	Good	
552004	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
552005	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
552006	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
552007	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
552008	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
552009	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
552010	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
552011	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
552012	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
552013	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
552014	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
552015	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
552016	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
552017	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
552018	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
552019	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
552020	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
552021	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
552022	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
552023	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
552024	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
552025	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
552026	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
552027	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
552028	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
552029	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	30.80	%
552030	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	32.73	%
552031	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	32.73	%
552032	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	1	
552033	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
552034	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
552035	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	9 Month Operations	21	
552036	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Accumulated Fault Duty A Ph V	4.87	%
552037	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Accumulated Fault Duty B Ph V	4.33	%
552038	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Accumulated Fault Duty C Ph V	4.33	%
552039	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Amps A Ø	142.0	
552040	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Amps B Ø	120.0	
552041	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Amps C Ø	140.0	
552042	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Bushing Condition	Good	
552043	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Bushings Connection/Risers	Good	
552044	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
552045	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
552046	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
552047	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Paint Condition	Good	
552048	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Equipment Properly Labeled?	y	
552049	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
552050	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
552051	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
552052	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations A Ø	0	
552053	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations B Ø	0	
552054	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations C Ø	0	
552055	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations Ground	0	
552056	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Follow-up Action Required?	n	
552057	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Follow-up Action Required?	n	
552058	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Foundation Condition	Good	
552059	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	General Comments		
552060	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
552061	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Equipment Properly Labeled?	y	
552062	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Paint Condition	Good	
552063	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
552064	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
552065	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	Oil Temp Max	36	°C
552066	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
552067	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
552068	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Bushings Connection/Risers	Good	
552069	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Bushing Condition	Good	
552070	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
552071	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
552072	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Amps C Ø	76.0	
552073	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Amps B Ø	55.0	
552074	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Amps A Ø	69.0	
552075	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
552076	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
552077	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Accumulated Fault Duty C Ph V	7.16	%
552078	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Accumulated Fault Duty B Ph V	5.96	%
552079	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	LV Winding Temp Present	45	°C
552080	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	LV Winding Temp Max	45	°C
552081	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Accumulated Fault Duty A Ph V	5.37	%
552082	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	9 Month Operations	1	
552083	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
552084	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
552085	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
552086	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
552087	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
552088	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
552089	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
552090	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
552091	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
552092	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
552093	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	229	
552094	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	229	
552095	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
552096	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
552097	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	General Comments		
552098	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
552099	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
552100	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
552101	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	General Comments	GAUGE RESET HANDS INOP	
552102	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
552103	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
552104	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
552105	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
552106	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
552107	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
552108	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
552109	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
552110	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
552111	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
552112	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
552113	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
552114	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
552115	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
552116	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
552117	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	General Comments		
552118	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
552119	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
552120	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
552121	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
552122	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
552123	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
552124	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
552125	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
552126	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
552127	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
552128	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
552129	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
552130	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
552131	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
552132	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
552133	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	Follow-up Action Required?	n	
552134	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
552135	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	General Comments		
552136	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	General Comments		
552137	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC As Found Counter	21074	
552138	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC As Left Counter	21074	
552139	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
552140	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Current Tap Position	4L	
552141	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
552142	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
552143	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
552144	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
552145	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
552146	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Max Tap Position	1L	
552147	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	General Comments	No cooling group positioning	
552148	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	General Comments		
552149	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
552150	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
552151	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
552152	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
552153	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
552154	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
552155	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
552156	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
552157	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
552158	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
552159	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
552160	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
552161	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
552162	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
552163	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
552164	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
552165	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Min Tap Position	8L	
552166	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Operations Since Last Insp	621	
552167	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
552168	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
552169	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
552170	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	General Comments		
552171	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Grounds in Place?	y	
552172	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
552173	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
552174	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
552175	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
552176	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
552177	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Heaters (All) Functioning?	y	
552178	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Maintenance Operations	0	
552179	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Moisture and Leak Free?	y	
552180	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Operations Counter AF	231	
552181	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Operations Counter AL	231	
552182	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
552183	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Switching Operations	5	
552184	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Tank Paint Condition	Good	
552185	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Unknown Operations	0	
552186	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
552187	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Vegetation	None	
552188	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
552189	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	General Comments		
552190	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
552191	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
552192	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
552193	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
552194	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
552195	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
552196	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Clear of Trash?	y	
552197	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
552198	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
552199	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Ambient Temp	38	°F
552200	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	21	°C
552201	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	33	°C
552202	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	20	°C
552203	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	33	°C
552204	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	20	°C
552205	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	33	°C
552206	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
552207	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
552208	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
552209	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
552210	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
552211	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
552212	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
552213	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
552214	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
552215	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
552216	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	Oil Temp Max	33	°C
552217	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1700	psi
552218	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
552219	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
552220	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
552221	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
552222	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
552223	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
552224	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
552225	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
552226	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
552227	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
552228	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
552229	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
552230	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
552231	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
552232	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
552233	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
552234	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
552235	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
552236	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
552237	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	General Comments		
552238	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
552239	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
552240	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
552241	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	5	
552242	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1055	
552243	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1055	
552244	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
552245	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
552246	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
552247	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
552248	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
552249	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Unknown Operations	0	
552250	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Switching Operations	0	
552251	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Operations Counter AL	151	
552252	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Operations Counter AF	151	
552253	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Maintenance Operations	0	
552254	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	General Comments		
552255	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Patrol Inspection	General Comments		
552256	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Follow-up Action Required?	n	
552257	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Patrol Inspection	Follow-up Action Required?	n	
552258	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations Ground	0	
552259	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations C Ø	0	
552260	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations B Ø	0	
552261	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations A Ø	0	
552262	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
552263	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
552264	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
552265	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Patrol Inspection	Equipment Properly Labeled?	y	
552266	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Amps C Ø	0.0	
552267	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Amps B Ø	0.0	
552268	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Amps A Ø	0.0	
552269	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Accumulated Fault Duty C Ph V	1.59	%
552270	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Accumulated Fault Duty B Ph V	1.59	%
552271	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Accumulated Fault Duty A Ph V	1.59	%
552272	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	9 Month Operations	0	
552273	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
552274	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
552275	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
552276	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
552277	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LTCC000472	LTCControl	AL-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
552278	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LTCC000472	LTCControl	AL-TRANS 3	LTC Control Insp	General Comments		
552279	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LTCC000472	LTCControl	AL-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
552280	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LTCC000471	LTCControl	AL-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
552281	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Doors and Locks Secure?	y	
552282	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Door Alarms OK?	y	
552283	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
552284	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Control House Lighting OK?	y	
552285	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Broom on Site?	y	
552286	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
552287	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
552288	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
552289	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
552290	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
552291	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
552292	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
552293	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
552294	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
552295	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
552296	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
552297	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
552298	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	General Comments		
552299	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
552300	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
552301	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	12	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
552302	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	20.63	%
552303	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	20.63	%
552304	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	10.92	%
552305	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	180.0	
552306	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	170.0	
552307	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	160.0	
552308	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
552309	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
552310	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
552311	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
552312	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
552313	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
552314	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
552315	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
552316	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
552317	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
552318	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
552319	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
552320	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
552321	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1769	
552322	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1769	
552323	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
552324	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
552325	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
552326	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Bushings Connection/Risers	Good	
552327	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Bushing Condition	Good	
552328	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Amps C Ø	36.0	
552329	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Amps B Ø	38.0	
552330	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Amps A Ø	30.0	
552331	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Accumulated Fault Duty C Ph V	5.41	%
552332	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Accumulated Fault Duty B Ph V	6.50	%
552333	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Accumulated Fault Duty A Ph V	7.04	%
552334	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	9 Month Operations	9	
552335	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
552336	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
552337	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
552338	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
552339	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
552340	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
552341	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
552342	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
552343	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
552344	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
552345	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
552346	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
552347	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
552348	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
552349	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
552350	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
552351	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
552352	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
552353	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
552354	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
552355	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
552356	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Unknown Operations	0	
552357	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Tank Paint Condition	Good	
552358	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Switching Operations	0	
552359	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
552360	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
552361	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
552362	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
552363	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LTCC000494	LTCControl	AL-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
552364	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LTCC000494	LTCControl	AL-TRANS 4	LTC Control Insp	General Comments		
552365	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LTCC000494	LTCControl	AL-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
552366	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
552367	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
552368	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
552369	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Operations Counter AL	201	
552370	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Operations Counter AF	201	
552371	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Moisture and Leak Free?	y	
552372	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Maintenance Operations	0	
552373	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Heaters (All) Functioning?	y	
552374	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Grounds in Place?	y	
552375	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
552376	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
552377	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	General Comments		
552378	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	General Comments		
552379	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
552380	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
552381	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	Oil Temp Present	36	°C
552382	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Foundation Condition	Good	
552383	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Follow-up Action Required?	n	
552384	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Follow-up Action Required?	n	
552385	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations Ground	0	
552386	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations C Ø	0	
552387	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations B Ø	0	
552388	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations A Ø	0	
552389	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
552390	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
552391	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LTCC000471	LTCControl	AL-TRANS 2	LTC Control Insp	General Comments		
552392	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LTCC000471	LTCControl	AL-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
552393	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Unknown Operations	0	
552394	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Tank Paint Condition	Good	
552395	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Switching Operations	2	
552396	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Operations Counter AL	203	
552397	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Operations Counter AF	201	
552398	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Moisture and Leak Free?	y	
552399	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Maintenance Operations	0	
552400	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Grounds in Place?	y	
552401	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	General Comments		
552402	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	General Comments		
552403	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Foundation Condition	Good	
552404	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Follow-up Action Required?	n	
552405	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Follow-up Action Required?	n	
552406	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations Ground	0	
552407	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations C Ø	0	
552408	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations B Ø	0	
552409	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations A Ø	0	
552410	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
552411	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
552412	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
552413	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Equipment Properly Labeled?	y	
552414	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Paint Condition	Good	
552415	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
552416	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
552417	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
552418	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
552419	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
552420	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
552421	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Clear of Trash?	y	
552422	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
552423	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
552424	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
552425	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
552426	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
552427	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
552428	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	General Comments		
552429	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
552430	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Vegetation	None	
552431	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
552432	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Bushings Connection/Risers	Good	
552433	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Bushing Condition	Good	
552434	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Amps C Ø	280.0	
552435	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Amps B Ø	280.0	
552436	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Amps A Ø	270.0	
552437	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
552438	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Accumulated Fault Duty B Ph V	5.04	%
552439	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Accumulated Fault Duty A Ph V	4.65	%
552440	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	9 Month Operations	2	
552441	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
552442	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
552443	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
552444	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
552445	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
552446	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
552447	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Follow-up Action Required?	n	
552448	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Patrol Inspection	General Comments		
552449	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	9 Month Operations	0	
552450	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Accumulated Fault Duty A Ph V	.94	%
552451	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Accumulated Fault Duty B Ph V	.94	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
552452	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Accumulated Fault Duty C Ph V	.94	%
552453	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Amps A Ø	380.0	
552454	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Amps B Ø	360.0	
552455	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Amps C Ø	360.0	
552456	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Bushing Condition	Good	
552457	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
552458	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
552459	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
552460	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
552461	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
552462	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
552463	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
552464	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
552465	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	General Comments		
552466	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Maintenance Operations	0	
552467	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Operations Counter AF	210	
552468	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Operations Counter AL	210	
552469	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Switching Operations	0	
552470	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Unknown Operations	0	
552471	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
552472	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations A Ø	0	
552473	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations B Ø	0	
552474	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations C Ø	0	
552475	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations Ground	0	
552476	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Follow-up Action Required?	n	
552477	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Follow-up Action Required?	n	
552478	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Foundation Condition	Good	
552479	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	General Comments		
552480	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	General Comments		
552481	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Grounds in Place?	y	
552482	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
552483	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Maintenance Operations	0	
552484	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
552485	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Operations Counter AF	164	
552486	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Operations Counter AL	164	
552487	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
552488	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Switching Operations	0	
552489	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Tank Paint Condition	Good	
552490	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Unknown Operations	0	
552491	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	BAT000166	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
552492	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	BAT000166	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
552493	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	BAT000166	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
552494	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	BAT000166	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
552495	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	BAT000166	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
552496	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	BAT000166	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
552497	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	BAT000166	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
552498	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	BAT000166	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
552499	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Foundation Condition	Good	
552500	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
552501	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	General Comments		
552502	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
552503	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
552504	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
552505	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
552506	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
552507	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
552508	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
552509	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
552510	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
552511	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
552512	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
552513	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
552514	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
552515	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	LTC Operation Checked?	n	
552516	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	General Comments		
552517	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	Follow-up Action Required?	n	
552518	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	All Connections OK?	y	
552519	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
552520	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	5.32	%
552521	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	1.33	%
552522	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	1.33	%
552523	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	120.0	
552524	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	140.0	
552525	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	110.0	
552526	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
552527	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
552528	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
552529	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
552530	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
552531	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
552532	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
552533	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
552534	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
552535	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
552536	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
552537	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
552538	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
552539	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1286	
552540	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1286	
552541	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
552542	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
552543	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Patrol Inspection	Equipment Properly Labeled?	y	
552544	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
552545	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
552546	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
552547	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations A Ø	0	
552548	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations B Ø	0	
552549	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations C Ø	0	
552550	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations Ground	0	
552551	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Patrol Inspection	Follow-up Action Required?	n	
552552	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
552553	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
552554	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
552555	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
552556	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
552557	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
552558	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
552559	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	General Comments		
552560	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
552561	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
552562	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
552563	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
552564	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
552565	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
552566	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
552567	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
552568	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
552569	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
552570	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
552571	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
552572	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
552573	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Heaters (All) Functioning?	y	
552574	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Grounds in Place?	y	
552575	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	General Comments		
552576	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	General Comments		
552577	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Foundation Condition	Good	
552578	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Follow-up Action Required?	n	
552579	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
552580	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
552581	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
552582	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
552583	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Follow-up Action Required?	n	
552584	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations Ground	0	
552585	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations C Ø	0	
552586	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations B Ø	0	
552587	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations A Ø	0	
552588	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
552589	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
552590	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
552591	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Equipment Properly Labeled?	y	
552592	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
552593	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	Follow-up Action Required?	n	
552594	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
552595	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	General Comments		
552596	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	General Comments		
552597	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
552598	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
552599	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
552600	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
552601	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
552602	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
552603	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
552604	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
552605	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	BAT000166	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
552606	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
552607	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
552608	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
552609	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Operations Since Last Insp	850	
552610	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
552611	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Min Tap Position	15L	
552612	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Max Tap Position	2L	
552613	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Current Tap Position	7L	
552614	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
552615	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC As Left Counter	32739	
552616	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC As Found Counter	32728	
552617	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	General Comments		
552618	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	General Comments		
552619	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
552620	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	Follow-up Action Required?	n	
552621	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	VRR Time Delay	45	Seconds
552622	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
552623	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
552624	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
552625	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	LTC Operation Checked?	n	
552626	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	General Comments		
552627	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	Follow-up Action Required?	n	
552628	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	All Connections OK?	y	
552629	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Unknown Operations	0	
552630	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Tank Paint Condition	Good	
552631	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Switching Operations	3	
552632	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
552633	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Operations Counter AL	144	
552634	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Operations Counter AF	144	
552635	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Moisture and Leak Free?	y	
552636	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Maintenance Operations	0	
552637	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	40	°C
552638	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	60	°C
552639	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	35	°C
552640	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	65	°C
552641	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	45	°C
552642	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	65	°C
552643	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
552644	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
552645	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
552646	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
552647	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
552648	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
552649	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
552650	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
552651	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
552652	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
552653	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
552654	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	Oil Temp Present	32	°C
552655	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	Oil Temp Max	55	°C
552656	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
552657	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
552658	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
552659	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
552660	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
552661	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
552662	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
552663	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
552664	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Readings	General Comments		
552665	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
552666	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
552667	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
552668	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
552669	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1538	
552670	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1538	
552671	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
552672	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
552673	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
552674	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
552675	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
552676	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
552677	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
552678	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
552679	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
552680	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
552681	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
552682	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
552683	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
552684	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
552685	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
552686	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	General Comments		
552687	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	General Comments		
552688	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
552689	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
552690	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
552691	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
552692	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
552693	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
552694	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
552695	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
552696	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
552697	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
552698	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
552699	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
552700	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
552701	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Follow-up Action Required?	n	
552702	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
552703	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
552704	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
552705	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
552706	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
552707	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
552708	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
552709	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
552710	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
552711	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	34	°F
552712	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
552713	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
552714	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
552715	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
552716	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
552717	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
552718	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
552719	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
552720	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	General Comments		
552721	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
552722	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
552723	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
552724	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
552725	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	PF000012	PowerFuse	AL-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
552726	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	PF000012	PowerFuse	AL-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
552727	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
552728	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
552729	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
552730	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
552731	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
552732	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
552733	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
552734	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
552735	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
552736	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
552737	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
552738	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
552739	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
552740	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
552741	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Oil Temp Present	30	°C
552742	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Oil Temp Max	35	°C
552743	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
552744	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
552745	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	LTC Totalizer Reading	9849.60	kw
552746	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
552747	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
552748	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
552749	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	General Comments	Blown lightning arrester 522	
552750	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
552751	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
552752	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Foundation Condition	Good	
552753	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
552754	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
552755	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
552756	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
552757	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	General Comments		
552758	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
552759	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
552760	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
552761	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
552762	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
552763	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
552764	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
552765	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
552766	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
552767	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
552768	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
552769	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
552770	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
552771	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
552772	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
552773	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
552774	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
552775	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Oil	
552776	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
552777	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
552778	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
552779	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
552780	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
552781	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Follow-up Action Required?	n	
552782	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
552783	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
552784	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	General Comments		
552785	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.6	amps
552786	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
552787	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	General Comments	ltc very wet, i believe is mostly oil	
552788	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
552789	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	LTC Totalizer Reading	1768.32	kw
552790	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
552791	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
552792	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Oil Temp Max	52	°C
552793	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Oil Temp Present	20	°C
552794	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
552795	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
552796	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
552797	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
552798	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
552799	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
552800	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
552801	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
552802	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Totalizer Meter Reading	.5526	
552803	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
552804	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
552805	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
552806	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	General Comments		
552807	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
552808	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
552809	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
552810	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	VRR Time Delay	30	Seconds
552811	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
552812	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
552813	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
552814	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
552815	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
552816	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
552817	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	General Comments		
552818	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
552819	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
552820	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
552821	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
552822	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1553	
552823	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1553	
552824	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
552825	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
552826	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	45	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
552827	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	45	°C
552828	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
552829	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	85.00	
552830	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
552831	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
552832	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
552833	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
552834	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
552835	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
552836	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
552837	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
552838	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
552839	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
552840	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
552841	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.400	millivolts
552842	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
552843	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
552844	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
552845	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
552846	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
552847	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
552848	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
552849	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
552850	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
552851	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
552852	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
552853	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	Oil Temp Present	40	°C
552854	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	Oil Temp Max	65	°C
552855	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
552856	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
552857	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
552858	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	General Comments		
552859	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
552860	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
552861	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
552862	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
552863	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
552864	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
552865	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
552866	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
552867	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
552868	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
552869	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	9 Month Operations	19	
552870	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
552871	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
552872	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
552873	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Amps A Ø	524.0	
552874	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Amps B Ø	540.0	
552875	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Amps C Ø	525.0	
552876	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
552877	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
552878	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
552879	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
552880	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
552881	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
552882	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
552883	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
552884	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
552885	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
552886	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	15	
552887	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	2353	
552888	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	2353	
552889	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
552890	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	3	
552891	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
552892	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
552893	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
552894	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
552895	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
552896	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
552897	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
552898	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
552899	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
552900	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
552901	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
552902	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
552903	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
552904	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
552905	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	General Comments		
552906	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	General Comments		
552907	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
552908	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
552909	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Maintenance Operations	0	
552910	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
552911	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Operations Counter AF	319	
552912	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Operations Counter AL	319	
552913	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
552914	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Switching Operations	0	
552915	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
552916	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Unknown Operations	0	
552917	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
552918	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
552919	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
552920	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Unknown Operations	0	
552921	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Tank Paint Condition	Good	
552922	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Maintenance Operations	0	
552923	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Heaters (All) Functioning?	y	
552924	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Grounds in Place?	y	
552925	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	General Comments		
552926	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	General Comments		
552927	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Foundation Condition	Good	
552928	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Follow-up Action Required?	n	
552929	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Follow-up Action Required?	n	
552930	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations Ground	0	
552931	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations C Ø	0	
552932	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations B Ø	0	
552933	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations A Ø	0	
552934	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
552935	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
552936	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
552937	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
552938	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
552939	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
552940	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
552941	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
552942	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
552943	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
552944	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
552945	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
552946	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
552947	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Clear of Trash?	y	
552948	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
552949	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
552950	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
552951	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
552952	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
552953	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
552954	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
552955	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	General Comments		
552956	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
552957	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
552958	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
552959	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Equipment Properly Labeled?	y	
552960	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Paint Condition	Good	
552961	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
552962	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
552963	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
552964	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Bushings Connection/Risers	Good	
552965	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Bushing Condition	Good	
552966	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Amps C Ø	291.0	
552967	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Amps B Ø	296.0	
552968	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Amps A Ø	285.0	
552969	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
552970	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
552971	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
552972	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
552973	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
552974	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	9 Month Operations	28	
552975	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
552976	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
552977	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Paint Condition	Good	
552978	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
552979	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
552980	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
552981	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Bushings Connection/Risers	Good	
552982	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Bushing Condition	Good	
552983	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Amps C Ø	0.0	
552984	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Amps B Ø	0.0	
552985	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Amps A Ø	0.0	
552986	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
552987	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
552988	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
552989	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	9 Month Operations	37	
552990	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
552991	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
552992	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Broom on Site?	y	
552993	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
552994	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
552995	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
552996	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
552997	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Evidence of Insects	None	
552998	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
552999	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
553000	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Floor Swept?	y	
553001	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
553002	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
553003	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	General Comments		
553004	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
553005	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
553006	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
553007	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
553008	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
553009	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
553010	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	100.0	
553011	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	100.0	
553012	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	100.0	
553013	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
553014	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
553015	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
553016	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
553017	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
553018	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
553019	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
553020	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
553021	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
553022	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
553023	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
553024	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
553025	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Panels Dusted?	y	
553026	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
553027	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
553028	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Switching Operations	0	
553029	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
553030	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Operations Counter AL	211	
553031	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Operations Counter AF	211	
553032	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Moisture and Leak Free?	y	
553033	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
553034	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
553035	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
553036	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
553037	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
553038	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Foundation Condition	Good	
553039	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
553040	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
553041	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	General Comments		
553042	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
553043	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
553044	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
553045	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
553046	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
553047	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
553048	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
553049	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
553050	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
553051	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
553052	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
553053	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
553054	3/1/2019 13:10	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
553055	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
553056	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
553057	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
553058	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
553059	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
553060	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
553061	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	432.0	
553062	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	490.0	
553063	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	480.0	
553064	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
553065	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
553066	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Maintenance Operations	0	
553067	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Heaters (All) Functioning?	y	
553068	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
553069	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Grounds in Place?	y	
553070	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	General Comments		
553071	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	General Comments		
553072	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Foundation Condition	Good	
553073	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Follow-up Action Required?	n	
553074	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Follow-up Action Required?	n	
553075	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations Ground	0	
553076	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations C Ø	0	
553077	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations B Ø	0	
553078	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations A Ø	0	
553079	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
553080	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
553081	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Operations Since Last Insp	7473	
553082	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
553083	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
553084	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
553085	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
553086	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
553087	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	582	
553088	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	582	
553089	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
553090	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
553091	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
553092	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
553093	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
553094	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Amps B Ø	73.0	
553095	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Amps C Ø	91.0	
553096	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Bushing Condition	Good	
553097	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
553098	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
553099	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
553100	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Current Tap Position	3L	
553101	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Max Tap Position	1R	
553102	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Min Tap Position	10L	
553103	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Operations Since Last Insp	110	
553104	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
553105	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
553106	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
553107	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
553108	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Vegetation	None	
553109	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
553110	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
553111	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
553112	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
553113	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
553114	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
553115	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
553116	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	PF000013	PowerFuse	AL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
553117	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	PF000013	PowerFuse	AL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
553118	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	General Comments		
553119	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	General Comments		
553120	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
553121	3/1/2019 13:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
553122	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
553123	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
553124	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
553125	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
553126	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
553127	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
553128	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
553129	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	Follow-up Action Required?	n	
553130	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
553131	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	General Comments		
553132	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	General Comments		
553133	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC As Found Counter	70109	
553134	3/25/2019 9:15	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC As Left Counter	70122	
553135	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
553136	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
553137	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
553138	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
553139	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	General Comments		
553140	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
553141	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
553142	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
553143	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	1	
553144	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	212	
553145	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	212	
553146	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
553147	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
553148	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
553149	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
553150	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC As Left Counter	71921	
553151	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	9 Month Operations	5	
553152	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
553153	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
553154	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
553155	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
553156	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
553157	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
553158	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
553159	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Amps A Ø	75.0	
553160	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Current Tap Position	7L	
553161	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Max Tap Position	5L	
553162	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Min Tap Position	14L	
553163	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	PF000011	PowerFuse	AL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
553164	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	PF000011	PowerFuse	AL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
553165	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	PF000010	PowerFuse	AL-GND TR 4	Disconnect Powerfuse Inspection	General Comments	ok	
553166	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	PF000010	PowerFuse	AL-GND TR 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
553167	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	PF000009	PowerFuse	AL-GND TR 3	Disconnect Powerfuse Inspection	General Comments	ok	
553168	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	PF000009	PowerFuse	AL-GND TR 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
553169	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	PF000008	PowerFuse	AL-GND TR 2	Disconnect Powerfuse Inspection	General Comments	ok	
553170	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	PF000008	PowerFuse	AL-GND TR 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
553171	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	PF000006	PowerFuse	AL-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
553172	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	PF000006	PowerFuse	AL-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
553173	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
553174	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
553175	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
553176	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
553177	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
553178	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
553179	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
553180	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
553181	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
553182	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
553183	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
553184	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
553185	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC As Found Counter	48417	
553186	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC As Left Counter	48417	
553187	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
553188	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
553189	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4L	
553190	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Min Tap Position	14L	
553191	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
553192	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	23	°C
553193	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
553194	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
553195	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
553196	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
553197	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
553198	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
553199	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
553200	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	510	
553201	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
553202	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
553203	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
553204	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Unknown Operations	0	
553205	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Tank Paint Condition	Good	
553206	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Switching Operations	0	
553207	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
553208	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Operations Counter AL	171	
553209	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Operations Counter AF	171	
553210	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Moisture and Leak Free?	y	
553211	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
553212	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Bushings Connection/Risers	Good	
553213	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
553214	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
553215	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
553216	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
553217	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
553218	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
553219	3/25/2019 9:20	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Paint Condition	Good	
553220	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
553221	3/1/2019 11:07	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
553222	3/1/2019 9:59	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
553223	3/1/2019 13:48	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC As Found Counter	71912	
553224	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
553225	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
553226	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	40	°C
553227	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	40	°C
553228	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
553229	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
553230	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	40	°C
553231	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	30	°C
553232	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
553233	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
553234	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
553235	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
553236	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
553237	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	598	
553238	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	602	
553239	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
553240	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
553241	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
553242	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
553243	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	4	
553244	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
553245	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
553246	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Bushing Condition	Good	
553247	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	480.0	
553248	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
553249	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	352	
553250	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	440.0	
553251	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	400.0	
553252	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
553253	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
553254	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
553255	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
553256	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
553257	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
553258	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
553259	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
553260	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
553261	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
553262	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
553263	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
553264	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
553265	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
553266	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	180.0	
553267	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	352	
553268	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	190.0	
553269	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	180.0	
553270	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
553271	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
553272	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
553273	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
553274	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
553275	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	360	
553276	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	365	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
553277	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
553278	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	5	
553279	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	1.20	%
553280	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	2.41	%
553281	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
553282	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Bushings Connection/Risers	Good	
553283	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
553284	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
553285	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
553286	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
553287	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
553288	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
553289	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
553290	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
553291	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
553292	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
553293	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
553294	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
553295	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
553296	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
553297	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
553298	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
553299	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
553300	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
553301	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
553302	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
553303	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
553304	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
553305	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
553306	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
553307	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
553308	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
553309	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
553310	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Cabinet Paint Condition	Good	
553311	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Equipment Properly Labeled?	y	
553312	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Follow-up Action Required?	n	
553313	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Foundation Condition	Good	
553314	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
553315	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
553316	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
553317	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
553318	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
553319	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	General Comments		
553320	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	12	
553321	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Grounds in Place?	y	
553322	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Heaters (All) Functioning?	y	
553323	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Moisture and Leak Free?	y	
553324	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
553325	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Tank Paint Condition	Good	
553326	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
553327	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
553328	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	General Comments		
553329	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	Oil Temp Max	38	°C
553330	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	Oil Temp Present	32	°C
553331	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
553332	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
553333	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	40	°C
553334	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
553335	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
553336	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
553337	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
553338	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
553339	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
553340	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
553341	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
553342	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
553343	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
553344	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	12	
553345	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
553346	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	200.0	
553347	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	220.0	
553348	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	240.0	
553349	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	1.20	%
553350	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
553351	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
553352	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	24	
553353	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Operations Counter AL	834	
553354	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Operations Counter AF	834	
553355	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Maintenance Operations	0	
553356	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	General Comments		
553357	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Follow-up Action Required?	n	
553358	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Operations Ground	0	
553359	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Operations C Ø	0	
553360	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Operations B Ø	0	
553361	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Operations A Ø	0	
553362	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Unknown Operations	2	
553363	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Switching Operations	0	
553364	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
553365	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
553366	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
553367	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Amps C Ø	440.0	
553368	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Amps B Ø	450.0	
553369	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Amps A Ø	380.0	
553370	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Accumulated Fault Duty C Ph AM	1.20	%
553371	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Accumulated Fault Duty B Ph AM	1.20	%
553372	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Accumulated Fault Duty A Ph AM	1.20	%
553373	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	9 Months Operations	28	
553374	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
553375	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
553376	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Operations Counter AL	523	
553377	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Operations Counter AF	523	
553378	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
553379	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
553380	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
553381	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
553382	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
553383	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
553384	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
553385	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
553386	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Maintenance Operations	0	
553387	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	General Comments		
553388	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Follow-up Action Required?	n	
553389	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Operations Ground	0	
553390	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Operations C Ø	0	
553391	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
553392	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Operations B Ø	0	
553393	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Operations A Ø	0	
553394	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Adjusted Amps C Phase AM	22.36	
553395	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Adjusted Amps B Phase AM	22.36	
553396	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Adjusted Amps A Phase AM	22.36	
553397	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Amps C Ø	440.0	
553398	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Amps B Ø	450.0	
553399	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Amps A Ø	450.0	
553400	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Accumulated Fault Duty C Ph AM	2.41	%
553401	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Accumulated Fault Duty B Ph AM	2.41	%
553402	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Accumulated Fault Duty A Ph AM	2.41	%
553403	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	9 Months Operations	8	
553404	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
553405	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	General Comments		
553406	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
553407	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
553408	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Foundation Condition	Good	
553409	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
553410	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
553411	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
553412	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
553413	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
553414	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
553415	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	30	°C
553416	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.8320	
553417	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	334	
553418	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	334	
553419	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
553420	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
553421	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
553422	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
553423	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
553424	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
553425	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
553426	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
553427	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
553428	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
553429	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
553430	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Mechanism Patrol Inspection	General Comments		
553431	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
553432	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.57	%
553433	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.35	%
553434	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.35	%
553435	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	11	
553436	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
553437	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
553438	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
553439	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Clear of Trash?	y	
553440	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
553441	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
553442	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
553443	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
553444	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
553445	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	General Comments		
553446	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
553447	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
553448	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
553449	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
553450	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
553451	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
553452	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
553453	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
553454	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
553455	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
553456	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
553457	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Unknown Operations	1	
553458	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Switching Operations	0	
553459	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
553460	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
553461	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Vegetation	None	
553462	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
553463	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	55	°C
553464	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
553465	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
553466	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
553467	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
553468	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
553469	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
553470	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
553471	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	2662.40	kw
553472	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
553473	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
553474	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
553475	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
553476	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
553477	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
553478	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
553479	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
553480	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	120.0	
553481	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	120.0	
553482	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	120.0	
553483	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.57	%
553484	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.35	%
553485	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.35	%
553486	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
553487	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
553488	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
553489	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
553490	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	240.0	
553491	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
553492	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
553493	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
553494	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
553495	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
553496	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
553497	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
553498	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
553499	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
553500	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
553501	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
553502	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
553503	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
553504	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
553505	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
553506	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
553507	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
553508	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	4.82	%
553509	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
553510	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
553511	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
553512	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
553513	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
553514	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	General Comments		
553515	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	6.02	%
553516	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	7.23	%
553517	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
553518	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
553519	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	29	
553520	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
553521	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	Follow-up Action Required?	n	
553522	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
553523	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
553524	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	General Comments		
553525	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	General Comments		
553526	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Foundation Condition	Good	
553527	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
553528	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
553529	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
553530	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
553531	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
553532	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
553533	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
553534	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	LTC Totalizer Reading	3302.40	kw
553535	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
553536	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
553537	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	Oil Temp Max	35	°C
553538	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	Oil Temp Present	30	°C
553539	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
553540	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
553541	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
553542	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
553543	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	General Comments		
553544	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
553545	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
553546	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
553547	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
553548	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
553549	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
553550	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
553551	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
553552	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
553553	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
553554	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
553555	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
553556	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
553557	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
553558	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
553559	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
553560	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
553561	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
553562	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
553563	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
553564	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	22.36	
553565	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
553566	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
553567	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Operations A Ø	2	
553568	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
553569	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
553570	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99992	
553571	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Operations B Ø	1	
553572	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
553573	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
553574	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
553575	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	General Comments	AB Phase IOC	
553576	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
553577	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Operations Counter AF	45	
553578	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Operations Counter AL	45	
553579	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Switching Operations	0	
553580	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Unknown Operations	0	
553581	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99992	
553582	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
553583	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
553584	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
553585	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
553586	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
553587	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
553588	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
553589	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
553590	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
553591	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
553592	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
553593	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	300.0	
553594	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	220.0	
553595	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	General Comments		
553596	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
553597	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
553598	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
553599	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
553600	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
553601	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
553602	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
553603	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
553604	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
553605	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	BCH000523	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
553606	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	36	°F
553607	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
553608	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	9 Months Operations	25	
553609	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	BCH000523	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
553610	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	BCH000523	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
553611	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	BCH000523	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
553612	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	6.02	%
553613	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	12.05	%
553614	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	4.82	%
553615	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Amps A Ø	220.0	
553616	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
553617	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Amps B Ø	240.0	
553618	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Amps C Ø	220.0	
553619	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
553620	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
553621	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Unknown Operations	1	
553622	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Switching Operations	0	
553623	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Operations Counter AL	161	
553624	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Operations Counter AF	161	
553625	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
553626	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
553627	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
553628	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
553629	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
553630	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
553631	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
553632	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
553633	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
553634	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
553635	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
553636	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
553637	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	General Comments	VC changed, no targets	
553638	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
553639	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
553640	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
553641	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
553642	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
553643	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
553644	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
553645	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
553646	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
553647	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
553648	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
553649	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
553650	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
553651	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
553652	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	Totalizer Meter Reading	1.0320	
553653	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
553654	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
553655	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
553656	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
553657	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	General Comments		
553658	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	Oil Temp Max	48	°C
553659	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	Oil Temp Present	40	°C
553660	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20	
553661	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
553662	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	55	°C
553663	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	40	°C
553664	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	44	°C
553665	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	38	°C
553666	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	40	°C
553667	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	38	°C
553668	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	LTCC000053	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
553669	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	LTCC000053	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
553670	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	LTCC000053	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
553671	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	LTCC000053	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
553672	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	LTCC000053	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
553673	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	LTCC000053	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
553674	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	LTCC000053	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
553675	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	LTCC000053	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
553676	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
553677	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
553678	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
553679	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
553680	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
553681	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
553682	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
553683	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	BCH000616	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
553684	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	BCH000616	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
553685	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	BCH000616	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
553686	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	BCH000616	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
553687	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	BCH000616	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
553688	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	BCH000616	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
553689	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
553690	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
553691	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
553692	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
553693	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
553694	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
553695	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
553696	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
553697	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
553698	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	General Comments		
553699	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
553700	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	7.23	%
553701	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	11077	
553702	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
553703	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
553704	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
553705	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	8.43	%
553706	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	9 Months Operations	28	
553707	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
553708	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
553709	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
553710	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
553711	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
553712	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
553713	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
553714	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	4L	
553715	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	4R	
553716	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
553717	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
553718	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
553719	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
553720	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
553721	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
553722	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
553723	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
553724	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	3R	
553725	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	4L	
553726	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
553727	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Vegetation	None	
553728	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
553729	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
553730	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
553731	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	General Comments		
553732	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
553733	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
553734	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
553735	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
553736	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
553737	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
553738	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Clear of Trash?	y	
553739	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
553740	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	81392	
553741	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
553742	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
553743	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
553744	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
553745	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
553746	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
553747	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
553748	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
553749	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
553750	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
553751	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
553752	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
553753	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
553754	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
553755	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	5R	
553756	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
553757	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	3L	
553758	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
553759	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
553760	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
553761	2/28/2019 13:54	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
553762	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
553763	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
553764	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Amps C Ø	300.0	
553765	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Amps B Ø	280.0	
553766	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
553767	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
553768	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
553769	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
553770	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Amps A Ø	360.0	
553771	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	6.02	%
553772	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
553773	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
553774	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
553775	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
553776	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
553777	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
553778	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
553779	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
553780	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
553781	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
553782	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
553783	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	110190	
553784	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
553785	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
553786	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
553787	2/28/2019 9:22	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
553788	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	28	
553789	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
553790	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
553791	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
553792	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
553793	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
553794	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
553795	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	5.94	%
553796	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
553797	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
553798	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
553799	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	5.03	%
553800	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
553801	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
553802	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
553803	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	LTC Operation Checked?	y	
553804	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	General Comments		
553805	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	Follow-up Action Required?	n	
553806	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	All Connections OK?	y	
553807	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
553808	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
553809	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	Follow-up Action Required?	n	
553810	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
553811	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
553812	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
553813	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
553814	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	General Comments		
553815	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
553816	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
553817	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
553818	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
553819	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	9 Month Operations	0	
553820	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
553821	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
553822	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
553823	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
553824	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
553825	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
553826	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
553827	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
553828	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BAT001366	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
553829	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BAT001366	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	62	°F
553830	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BAT001366	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
553831	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BAT001366	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
553832	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
553833	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
553834	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
553835	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
553836	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
553837	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
553838	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	WORKED ON COUNTER (CAN NOT READ)	
553839	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
553840	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
553841	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BAT001366	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
553842	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BAT001366	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
553843	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BAT001366	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
553844	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BAT001366	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
553845	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BAT001366	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
553846	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BAT001366	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
553847	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BAT001366	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
553848	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
553849	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
553850	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
553851	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
553852	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
553853	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
553854	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
553855	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Amps C Ø	20.0	
553856	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Amps B Ø	20.0	
553857	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Amps A Ø	20.0	
553858	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	General Comments		
553859	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
553860	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
553861	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
553862	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
553863	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
553864	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
553865	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
553866	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
553867	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	VRR Time Delay	30	Seconds
553868	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
553869	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
553870	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
553871	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
553872	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1977	
553873	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1977	
553874	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
553875	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
553876	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	910	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
553877	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	914	
553878	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
553879	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
553880	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	99948	
553881	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	99952	
553882	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
553883	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
553884	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC Current Tap Position	4L	
553885	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
553886	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC Min Tap Position	12L	
553887	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
553888	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
553889	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
553890	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC Operations Since Last Insp	565	
553891	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
553892	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
553893	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
553894	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
553895	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
553896	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
553897	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
553898	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
553899	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
553900	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
553901	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
553902	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
553903	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
553904	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
553905	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
553906	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
553907	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
553908	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Unknown Operations	0	
553909	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Tank Paint Condition	Good	
553910	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
553911	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	LTCC000547	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
553912	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	LTCC000547	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
553913	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	LTCC000547	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
553914	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	LTCC000547	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
553915	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	LTCC000547	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
553916	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	LTCC000547	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
553917	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	LTCC000547	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
553918	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	LTCC000547	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
553919	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	LTCC000547	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
553920	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	5.03	%
553921	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
553922	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
553923	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
553924	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
553925	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
553926	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
553927	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
553928	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
553929	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
553930	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
553931	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
553932	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	9 Month Operations	1	
553933	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
553934	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
553935	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
553936	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
553937	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
553938	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
553939	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
553940	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
553941	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
553942	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
553943	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	General Comments		
553944	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
553945	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
553946	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
553947	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
553948	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
553949	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
553950	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
553951	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
553952	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
553953	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
553954	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
553955	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
553956	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
553957	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
553958	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
553959	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
553960	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
553961	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
553962	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
553963	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	General Comments		
553964	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC As Found Counter	94038	
553965	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC As Left Counter	94038	
553966	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
553967	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
553968	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
553969	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
553970	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
553971	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
553972	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
553973	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
553974	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
553975	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
553976	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
553977	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
553978	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
553979	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
553980	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
553981	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
553982	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
553983	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	13	
553984	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
553985	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	General Comments		
553986	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
553987	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
553988	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
553989	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
553990	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
553991	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Clear of Trash?	y	
553992	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
553993	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
553994	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
553995	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Unknown Operations	0	
553996	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
553997	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Switching Operations	0	
553998	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
553999	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	13	
554000	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Operations Counter AL	158	
554001	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Operations Counter AF	158	
554002	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
554003	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Maintenance Operations	0	
554004	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
554005	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
554006	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	General Comments		
554007	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
554008	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
554009	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
554010	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
554011	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
554012	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
554013	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
554014	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
554015	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
554016	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
554017	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
554018	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
554019	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
554020	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
554021	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
554022	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
554023	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
554024	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
554025	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Foundation Condition	Good	
554026	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
554027	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
554028	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	General Comments		
554029	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
554030	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
554031	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
554032	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
554033	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
554034	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
554035	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
554036	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
554037	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
554038	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
554039	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
554040	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
554041	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	336	
554042	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	340	
554043	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
554044	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
554045	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
554046	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
554047	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
554048	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
554049	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
554050	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
554051	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
554052	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
554053	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
554054	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	200.0	
554055	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	240.0	
554056	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	200.0	
554057	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.01	%
554058	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.01	%
554059	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0240	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.01	%
554060	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
554061	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Vegetation	None	
554062	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Foundation Condition	Good	
554063	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	General Comments		
554064	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	General Comments		
554065	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Grounds in Place?	y	
554066	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Heaters (All) Functioning?	y	
554067	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Maintenance Operations	0	
554068	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Moisture and Leak Free?	y	
554069	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Operations Counter AF	444	
554070	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Operations Counter AL	448	
554071	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
554072	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Switching Operations	4	
554073	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Tank Paint Condition	Good	
554074	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Unknown Operations	0	
554075	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
554076	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
554077	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
554078	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
554079	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
554080	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
554081	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
554082	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
554083	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
554084	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
554085	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
554086	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
554087	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
554088	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
554089	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
554090	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
554091	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
554092	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.97	%
554093	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.97	%
554094	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.97	%
554095	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	
554096	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
554097	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
554098	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0349	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
554099	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BCH000507	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
554100	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BCH000507	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
554101	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BCH000507	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
554102	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
554103	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
554104	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
554105	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
554106	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
554107	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
554108	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
554109	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
554110	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
554111	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
554112	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
554113	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
554114	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
554115	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
554116	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
554117	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
554118	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
554119	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
554120	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	400.0	
554121	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	480.0	
554122	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	480.0	
554123	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
554124	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
554125	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	9 Month Operations	15	
554126	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Accumulated Fault Duty A Ph V	14.02	%
554127	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Accumulated Fault Duty B Ph V	14.49	%
554128	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Accumulated Fault Duty C Ph V	16.36	%
554129	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Amps A Ø	275.0	
554130	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Amps B Ø	275.0	
554131	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Amps C Ø	250.0	
554132	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Bushing Condition	Good	
554133	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Bushings Connection/Risers	Good	
554134	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
554135	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
554136	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
554137	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Cabinet Paint Condition	Good	
554138	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Equipment Properly Labeled?	y	
554139	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
554140	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
554141	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
554142	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Operations A Ø	0	
554143	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
554144	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
554145	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
554146	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
554147	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
554148	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	General Comments		
554149	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	General Comments		
554150	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
554151	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
554152	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Operations B Ø	0	
554153	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Operations C Ø	0	
554154	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Operations Ground	0	
554155	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
554156	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Follow-up Action Required?	n	
554157	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Follow-up Action Required?	n	
554158	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
554159	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
554160	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Follow-up Action Required?	n	
554161	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Foundation Condition	Good	
554162	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Gauge(s) Condition	Good	
554163	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	General Comments		
554164	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Grounds in Place?	y	
554165	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Max Tap Position	1L	
554166	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Min Tap Position	12L	
554167	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Moisture and Leak Free?	y	
554168	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
554169	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Reg Oil Level	Good	
554170	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Reg Operation Checked?	y	
554171	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
554172	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Regulator As Left Counter	358888	
554173	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
554174	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Surge Arrester Condition	Good	
554175	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Tank Leaks	None	
554176	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
554177	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Operations A Ø	0	
554178	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Operations B Ø	0	
554179	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Operations C Ø	0	
554180	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Operations Ground	0	
554181	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Follow-up Action Required?	n	
554182	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Follow-up Action Required?	n	
554183	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Foundation Condition	Good	
554184	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	General Comments		
554185	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Bushing Condition	Good	
554186	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	General Comments		
554187	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Grounds in Place?	y	
554188	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
554189	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	YD000359	Yard	Retired Distribution	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
554190	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	YD000359	Yard	Retired Distribution	Yard Patrol Inspection	General Comments		
554191	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	YD000359	Yard	Retired Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
554192	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	YD000359	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
554193	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	YD000359	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
554194	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	YD000359	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
554195	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	YD000359	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
554196	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	YD000359	Yard	Retired Distribution	Yard Patrol Inspection	Clear of Trash?	y	
554197	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	YD000359	Yard	Retired Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
554198	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	YD000359	Yard	Retired Distribution	Yard Patrol Inspection	Ambient Temp	62	°F
554199	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
554200	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
554201	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC Max Tap Position	1R	
554202	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC Current Tap Position	5L	
554203	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
554204	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC As Left Counter	46803	
554205	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC As Found Counter	46803	
554206	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	General Comments		
554207	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	General Comments		
554208	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
554209	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	Follow-up Action Required?	n	
554210	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
554211	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Linkage Grounds in Place?	y	
554212	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
554213	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
554214	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	General Comments		
554215	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
554216	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
554217	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Foundation Condition	Good	
554218	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
554219	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
554220	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
554221	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
554222	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
554223	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
554224	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Bushing Condition	Good	
554225	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
554226	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
554227	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
554228	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	YD000359	Yard	Retired Distribution	Yard Patrol Inspection	Vegetation	None	
554229	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
554230	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Current Tap Position	6L	
554231	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	YD000359	Yard	Retired Distribution	Yard Patrol Inspection	Switch Stick and Container OK?	y	
554232	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Amps A Ø	640.0	
554233	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Amps B Ø	640.0	
554234	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Amps C Ø	640.0	
554235	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Bushing Condition	Good	
554236	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
554237	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
554238	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
554239	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
554240	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
554241	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
554242	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
554243	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
554244	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
554245	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
554246	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
554247	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
554248	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
554249	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
554250	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
554251	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Fans Operational?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
554252	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
554253	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Follow-up Action Required?	n	
554254	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
554255	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
554256	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	General Comments		
554257	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	General Comments		
554258	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
554259	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	LTC Totalizer Reading	15007.68	kw
554260	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
554261	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
554262	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Oil Temp Max	40	°C
554263	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
554264	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
554265	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
554266	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
554267	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
554268	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
554269	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
554270	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
554271	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Totalizer Meter Reading	1.0422	
554272	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Max Tap Position	1L	
554273	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Min Tap Position	11L	
554274	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Moisture and Leak Free?	y	
554275	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Winding Temp Max	70	°C
554276	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
554277	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
554278	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
554279	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Reg Oil Level	Good	
554280	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Reg Operation Checked?	y	
554281	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
554282	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Tank Paint Condition	Good	
554283	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Tank Leaks	None	
554284	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Surge Arrester Condition	Good	
554285	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
554286	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Regulator As Left Counter	11205	
554287	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
554288	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Bushing Condition	Good	
554289	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
554290	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
554291	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
554292	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
554293	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Current Tap Position	7L	
554294	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
554295	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Current Tap Position	7L	
554296	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
554297	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Maintenance Operations	0	
554298	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
554299	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Follow-up Action Required?	n	
554300	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Foundation Condition	Good	
554301	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Gauge(s) Condition	Good	
554302	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
554303	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Follow-up Action Required?	n	
554304	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Foundation Condition	Good	
554305	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Gauge(s) Condition	Good	
554306	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	General Comments		
554307	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Grounds in Place?	y	
554308	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Max Tap Position	2L	
554309	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Min Tap Position	10L	
554310	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Moisture and Leak Free?	y	
554311	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
554312	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Reg Oil Level	Good	
554313	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Reg Operation Checked?	y	
554314	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
554315	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Regulator As Left Counter	27706	
554316	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
554317	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Surge Arrester Condition	Good	
554318	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Tank Leaks	None	
554319	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Tank Paint Condition	Good	
554320	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Operations Counter AF	250	
554321	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Operations Counter AL	250	
554322	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
554323	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	General Comments		
554324	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Grounds in Place?	y	
554325	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Switching Operations	0	
554326	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
554327	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Unknown Operations	0	
554328	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
554329	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
554330	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Accumulated Fault Duty B Ph V	18.22	%
554331	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Accumulated Fault Duty C Ph V	16.82	%
554332	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Amps A Ø	400.0	
554333	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Amps B Ø	400.0	
554334	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Amps C Ø	400.0	
554335	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Bushing Condition	Good	
554336	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Bushings Connection/Risers	Good	
554337	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
554338	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	Oil Temp Max	40	°C
554339	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
554340	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
554341	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
554342	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
554343	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
554344	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
554345	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
554346	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
554347	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
554348	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Oil Temp Max	55	°C
554349	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
554350	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
554351	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
554352	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Cabinet Paint Condition	Good	
554353	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Equipment Properly Labeled?	y	
554354	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	534.24	kw
554355	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
554356	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
554357	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
554358	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
554359	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
554360	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	LTC Totalizer Reading	17245.44	kw
554361	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
554362	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	General Comments		
554363	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	General Comments		
554364	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.2226	
554365	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
554366	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
554367	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
554368	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
554369	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
554370	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
554371	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
554372	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
554373	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	General Comments		
554374	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Foundation Condition	Good	
554375	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Follow-up Action Required?	n	
554376	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Follow-up Action Required?	n	
554377	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Operations Ground	0	
554378	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Operations C Ø	0	
554379	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Operations B Ø	0	
554380	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Operations A Ø	0	
554381	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
554382	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
554383	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	General Comments		
554384	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
554385	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
554386	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC Operations Since Last Insp	655	
554387	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
554388	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
554389	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
554390	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
554391	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
554392	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
554393	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
554394	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
554395	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
554396	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
554397	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC Min Tap Position	10L	
554398	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
554399	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
554400	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
554401	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
554402	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
554403	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	General Comments		
554404	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Grounds in Place?	y	
554405	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Heaters (All) Functioning?	y	
554406	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Maintenance Operations	0	
554407	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Moisture and Leak Free?	y	
554408	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Operations Counter AF	389	
554409	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
554410	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
554411	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
554412	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Accumulated Fault Duty A Ph V	17.29	%
554413	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	9 Month Operations	7	
554414	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
554415	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
554416	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
554417	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
554418	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
554419	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
554420	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
554421	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
554422	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Totalizer Meter Reading	1.1976	
554423	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Winding Temp Max	55	°C
554424	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
554425	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
554426	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
554427	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
554428	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Follow-up Action Required?	n	
554429	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
554430	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0366	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
554431	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Operating Linkage OK?	y	
554432	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
554433	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Switching Operations	0	
554434	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
554435	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Site Service Trans Condition	OK	
554436	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
554437	2/27/2019 15:58	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Steel Structures Rust Free?	y	
554438	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
554439	2/27/2019 15:11	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Operations Counter AL	389	
554440	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	CX0868	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
554441	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	CX0868	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	120.0	
554442	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	CX0868	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	120.0	
554443	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	CX0868	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	120.0	
554444	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	CX0868	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
554445	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	CX0868	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
554446	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	CX0868	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
554447	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	CX0868	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
554448	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	CX0868	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
554449	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	CX0868	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
554450	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	CX0868	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
554451	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	CX0868	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
554452	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	CX0868	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
554453	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	CX0868	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
554454	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	CX0868	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
554455	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	CX0868	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	General Comments		
554456	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	CX0868	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
554457	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	CX0868	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
554458	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	CX0868	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Operations Counter	1121	
554459	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	CX0868	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
554460	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
554461	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	130.0	
554462	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
554463	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
554464	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
554465	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
554466	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
554467	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	125.0	
554468	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	140.0	
554469	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
554470	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
554471	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
554472	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
554473	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	General Comments		
554474	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
554475	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
554476	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Operations Counter	106	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
554477	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
554478	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
554479	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
554480	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
554481	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Equipment Properly Labeled?	y	
554482	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Cabinet Paint Condition	Good	
554483	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
554484	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
554485	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
554486	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
554487	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Amps C Ø	80.0	
554488	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Amps B Ø	80.0	
554489	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
554490	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Bushings Connection/Risers	Good	
554491	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
554492	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Ambient Temp	48	°F
554493	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
554494	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
554495	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
554496	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
554497	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
554498	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
554499	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Clear of Trash?	y	
554500	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
554501	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
554502	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Clear of Trash?	y	
554503	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
554504	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
554505	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
554506	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
554507	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Foundation Condition	Good	
554508	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
554509	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Bushing Condition	Good	
554510	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
554511	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
554512	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
554513	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
554514	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
554515	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
554516	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	General Comments		
554517	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	General Comments		
554518	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
554519	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
554520	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
554521	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
554522	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
554523	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
554524	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
554525	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
554526	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
554527	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
554528	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
554529	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Unknown Operations	0	
554530	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Tank Paint Condition	Good	
554531	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Switching Operations	0	
554532	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Operations Counter AL	183	
554533	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Operations Counter AF	183	
554534	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
554535	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
554536	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
554537	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
554538	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
554539	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
554540	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
554541	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
554542	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	General Comments		
554543	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
554544	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
554545	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
554546	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
554547	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
554548	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
554549	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
554550	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
554551	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
554552	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
554553	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Operations Counter AL	209	
554554	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Operations Counter AF	207	
554555	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Moisture and Leak Free?	y	
554556	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Maintenance Operations	0	
554557	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
554558	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Grounds in Place?	y	
554559	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	General Comments		
554560	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	General Comments		
554561	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Foundation Condition	Good	
554562	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Follow-up Action Required?	n	
554563	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Follow-up Action Required?	n	
554564	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Operations Ground	0	
554565	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
554566	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
554567	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
554568	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Clear of Trash?	y	
554569	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
554570	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
554571	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
554572	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
554573	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
554574	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Unknown Operations	0	
554575	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
554576	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
554577	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	General Comments		
554578	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
554579	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
554580	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
554581	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Vegetation	None	
554582	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
554583	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Operations C Ø	0	
554584	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Operations B Ø	0	
554585	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Operations A Ø	0	
554586	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
554587	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
554588	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
554589	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
554590	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
554591	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
554592	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
554593	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
554594	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
554595	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
554596	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	9 Month Operations	6	
554597	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
554598	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
554599	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Accumulated Fault Duty C Ph V	.35	%
554600	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Amps A Ø	100.0	
554601	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Amps B Ø	140.0	
554602	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Amps C Ø	90.0	
554603	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Bushing Condition	Good	
554604	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Bushings Connection/Risers	Good	
554605	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
554606	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Vegetation	None	
554607	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
554608	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
554609	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
554610	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
554611	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Cabinet Paint Condition	Good	
554612	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	9 Month Operations	8	
554613	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Accumulated Fault Duty A Ph V	.29	%
554614	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
554615	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
554616	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Amps A Ø	100.0	
554617	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Amps B Ø	100.0	
554618	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Amps C Ø	100.0	
554619	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Bushing Condition	Good	
554620	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Bushings Connection/Risers	Good	
554621	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
554622	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
554623	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
554624	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Cabinet Paint Condition	Good	
554625	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Equipment Properly Labeled?	y	
554626	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
554627	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
554628	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
554629	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Operations A Ø	0	
554630	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Operations B Ø	0	
554631	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Unknown Operations	0	
554632	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Tank Paint Condition	Good	
554633	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Switching Operations	4	
554634	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
554635	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Operations Counter AL	245	
554636	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
554637	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Tank Leaks	None	
554638	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
554639	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
554640	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	Totalizer Meter Reading	1.0494	
554641	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
554642	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
554643	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
554644	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Operations Counter	1380	
554645	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
554646	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
554647	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	General Comments		
554648	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
554649	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
554650	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
554651	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
554652	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
554653	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
554654	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
554655	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Vegetation	None	
554656	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
554657	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
554658	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
554659	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
554660	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
554661	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
554662	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
554663	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	Oil Temp Present	40	°C
554664	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	Oil Temp Max	85	°C
554665	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
554666	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
554667	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
554668	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
554669	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
554670	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	LTC Totalizer Reading	10074.24	kw
554671	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
554672	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	General Comments		
554673	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	General Comments		
554674	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
554675	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Unknown Operations	0	
554676	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Tank Paint Condition	Good	
554677	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Switching Operations	2	
554678	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
554679	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
554680	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	Follow-up Action Required?	n	
554681	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
554682	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
554683	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
554684	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
554685	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Follow-up Action Required?	n	
554686	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Foundation Condition	Good	
554687	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	General Comments		
554688	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	General Comments		
554689	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Grounds in Place?	y	
554690	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Heaters (All) Functioning?	y	
554691	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Maintenance Operations	0	
554692	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Moisture and Leak Free?	y	
554693	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Operations Counter AF	286	
554694	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Operations Counter AL	290	
554695	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
554696	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Switching Operations	4	
554697	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Tank Paint Condition	Good	
554698	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Moisture and Leak Free?	y	
554699	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Operations Counter AF	165	
554700	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Operations Counter AL	165	
554701	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Switching Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
554702	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Tank Paint Condition	Good	
554703	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Unknown Operations	0	
554704	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	9 Month Operations	2	
554705	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
554706	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
554707	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
554708	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Amps A Ø	50.0	
554709	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Amps B Ø	50.0	
554710	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Amps C Ø	70.0	
554711	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Bushing Condition	Good	
554712	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Bushings Connection/Risers	Good	
554713	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
554714	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
554715	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
554716	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Cabinet Paint Condition	Good	
554717	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Equipment Properly Labeled?	y	
554718	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
554719	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
554720	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
554721	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Operations A Ø	0	
554722	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Operations B Ø	0	
554723	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Operations C Ø	0	
554724	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Operations Ground	0	
554725	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Follow-up Action Required?	n	
554726	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Follow-up Action Required?	n	
554727	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Foundation Condition	Good	
554728	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	General Comments		
554729	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	General Comments		
554730	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Grounds in Place?	y	
554731	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Maintenance Operations	0	
554732	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Moisture and Leak Free?	y	
554733	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Operations Counter AF	241	
554734	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Moisture and Leak Free?	y	
554735	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Maintenance Operations	0	
554736	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Operations C Ø	0	
554737	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Heaters (All) Functioning?	y	
554738	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Grounds in Place?	y	
554739	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	General Comments		
554740	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	General Comments		
554741	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Foundation Condition	Good	
554742	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Follow-up Action Required?	n	
554743	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Follow-up Action Required?	n	
554744	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Operations Ground	0	
554745	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Operations C Ø	0	
554746	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Operations B Ø	0	
554747	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Operations A Ø	0	
554748	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
554749	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
554750	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Equipment Properly Labeled?	y	
554751	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
554752	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
554753	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
554754	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Operations A Ø	0	
554755	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Operations B Ø	0	
554756	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Operations C Ø	0	
554757	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Operations Ground	0	
554758	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Follow-up Action Required?	n	
554759	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Follow-up Action Required?	n	
554760	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Foundation Condition	Good	
554761	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	General Comments		
554762	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	General Comments		
554763	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
554764	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Equipment Properly Labeled?	y	
554765	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Cabinet Paint Condition	Good	
554766	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
554767	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
554768	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
554769	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Bushings Connection/Risers	Good	
554770	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Bushing Condition	Good	
554771	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Grounds in Place?	y	
554772	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Maintenance Operations	0	
554773	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Amps C Ø	60.0	
554774	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Amps B Ø	60.0	
554775	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Amps A Ø	40.0	
554776	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
554777	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
554778	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
554779	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	9 Month Operations	12	
554780	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Operations Ground	0	
554781	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Follow-up Action Required?	n	
554782	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
554783	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
554784	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
554785	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	General Comments		
554786	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
554787	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
554788	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
554789	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
554790	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
554791	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
554792	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
554793	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
554794	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
554795	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	LTCC000200	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
554796	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	LTCC000200	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
554797	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	LTCC000200	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
554798	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	LTCC000200	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
554799	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	LTCC000200	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
554800	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
554801	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
554802	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	General Comments		
554803	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Grounds in Place?	y	
554804	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Heaters (All) Functioning?	y	
554805	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Maintenance Operations	0	
554806	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Moisture and Leak Free?	y	
554807	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Operations Counter AF	263	
554808	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Operations Counter AL	263	
554809	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
554810	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Switching Operations	0	
554811	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Tank Paint Condition	Good	
554812	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Unknown Operations	0	
554813	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BCH000509	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
554814	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BCH000509	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
554815	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BCH000509	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
554816	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BCH000509	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
554817	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BCH000509	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
554818	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BCH000509	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
554819	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BCH000509	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
554820	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
554821	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
554822	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
554823	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
554824	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
554825	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
554826	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
554827	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
554828	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
554829	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	General Comments		
554830	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
554831	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	LTCC000200	LTCControl	930-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
554832	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	LTCC000200	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
554833	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	LTCC000200	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
554834	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	LTCC000200	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
554835	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
554836	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
554837	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
554838	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
554839	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
554840	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
554841	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
554842	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	General Comments		
554843	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
554844	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
554845	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
554846	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
554847	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
554848	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
554849	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
554850	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
554851	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
554852	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
554853	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
554854	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
554855	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	General Comments		
554856	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
554857	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
554858	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
554859	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Clear of Trash?	y	
554860	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
554861	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
554862	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
554863	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
554864	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
554865	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	General Comments		
554866	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
554867	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
554868	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Vegetation	None	
554869	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
554870	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
554871	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
554872	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
554873	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
554874	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
554875	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
554876	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Foundation Condition	Good	
554877	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
554878	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
554879	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
554880	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
554881	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
554882	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
554883	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
554884	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Regulator As Left Counter	14754	
554885	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
554886	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
554887	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Tank Leaks	None	
554888	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
554889	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	BCH000522	Charger	796-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
554890	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	BCH000522	Charger	796-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
554891	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	BCH000522	Charger	796-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
554892	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	BCH000522	Charger	796-Battery Charger	Battery Charger Patrol Insp	General Comments		
554893	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
554894	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
554895	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
554896	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
554897	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
554898	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
554899	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
554900	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Tank Leaks	None	
554901	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
554902	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
554903	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
554904	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Regulator As Left Counter	56774	
554905	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	120.0	volts
554906	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
554907	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
554908	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
554909	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
554910	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
554911	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
554912	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	General Comments		
554913	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
554914	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
554915	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
554916	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
554917	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
554918	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
554919	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
554920	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	119.0	volts
554921	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Regulator As Left Counter	66771	
554922	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
554923	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
554924	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Min Tap Position	16L	
554925	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
554926	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Tank Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
554927	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
554928	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
554929	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
554930	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	General Comments		
554931	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
554932	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
554933	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
554934	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
554935	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
554936	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
554937	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
554938	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
554939	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
554940	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
554941	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
554942	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
554943	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
554944	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
554945	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
554946	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
554947	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
554948	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
554949	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Tank Leaks	None	
554950	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
554951	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Regulator As Left Counter	18085	
554952	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
554953	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
554954	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
554955	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
554956	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
554957	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Min Tap Position	1R	
554958	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Max Tap Position	8R	
554959	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
554960	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	General Comments		
554961	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
554962	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
554963	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
554964	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
554965	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Current Tap Position	4R	
554966	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
554967	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
554968	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
554969	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
554970	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
554971	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
554972	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Tank Leaks	None	
554973	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
554974	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
554975	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Regulator As Left Counter	17639	
554976	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
554977	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
554978	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
554979	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
554980	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
554981	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Min Tap Position	3L	
554982	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
554983	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
554984	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	General Comments		
554985	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
554986	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
554987	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
554988	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
554989	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
554990	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
554991	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
554992	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
554993	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
554994	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
554995	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
554996	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
554997	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
554998	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
554999	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
555000	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
555001	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
555002	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
555003	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
555004	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	General Comments		
555005	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
555006	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
555007	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
555008	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
555009	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
555010	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
555011	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
555012	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
555013	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Regulator As Left Counter	15826	
555014	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
555015	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
555016	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
555017	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
555018	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
555019	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC Operations Since Last Insp	753	
555020	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC Min Tap Position	6L	
555021	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC Max Tap Position	5R	
555022	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC Current Tap Position	3R	
555023	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
555024	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC As Left Counter	4482	
555025	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC As Found Counter	4482	
555026	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	General Comments		
555027	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	General Comments		
555028	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
555029	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	Follow-up Action Required?	n	
555030	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
555031	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Tank Leaks	None	
555032	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
555033	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
555034	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
555035	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
555036	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
555037	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
555038	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
555039	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
555040	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
555041	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
555042	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	9 Month Operations	11	
555043	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Accumulated Fault Duty A Ph V	1.54	%
555044	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
555045	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
555046	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Amps A Ø	160.0	
555047	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
555048	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
555049	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
555050	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
555051	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
555052	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
555053	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
555054	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
555055	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	General Comments		
555056	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
555057	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
555058	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
555059	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	All Connections OK?	y	
555060	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	Follow-up Action Required?	n	
555061	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
555062	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
555063	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
555064	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
555065	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	General Comments		
555066	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
555067	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
555068	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
555069	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
555070	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
555071	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
555072	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
555073	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
555074	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
555075	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
555076	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
555077	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
555078	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
555079	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Foundation Condition	Good	
555080	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
555081	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
555082	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	General Comments		
555083	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	LTC Operation Checked?	y	
555084	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
555085	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
555086	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
555087	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	VRR Time Delay	30	Seconds
555088	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
555089	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
555090	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
555091	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
555092	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
555093	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
555094	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
555095	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
555096	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
555097	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
555098	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
555099	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
555100	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
555101	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BCH000529	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
555102	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BCH000529	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
555103	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BCH000529	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
555104	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BCH000529	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
555105	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BCH000529	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
555106	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BCH000529	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
555107	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
555108	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
555109	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Tank Leaks	None	
555110	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
555111	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC Max Tap Position	2L	
555112	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC Current Tap Position	7L	
555113	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
555114	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC As Left Counter	15722	
555115	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC As Found Counter	15722	
555116	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	General Comments		
555117	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	General Comments		
555118	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
555119	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	Follow-up Action Required?	n	
555120	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Operations Ground	0	
555121	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Follow-up Action Required?	n	
555122	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Follow-up Action Required?	n	
555123	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Foundation Condition	Good	
555124	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	General Comments		
555125	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
555126	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Tank Leaks	None	
555127	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
555128	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Regulator As Left Counter	13860	
555129	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
555130	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
555131	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
555132	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
555133	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
555134	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Min Tap Position	13L	
555135	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Max Tap Position	15R	
555136	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
555137	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	General Comments		
555138	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
555139	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
555140	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
555141	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
555142	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Current Tap Position	3R	
555143	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
555144	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
555145	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
555146	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
555147	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
555148	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
555149	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
555150	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
555151	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
555152	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
555153	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
555154	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
555155	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Amps B Ø	160.0	
555156	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Amps C Ø	160.0	
555157	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Bushing Condition	Good	
555158	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Bushings Connection/Risers	Good	
555159	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
555160	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
555161	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
555162	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Cabinet Paint Condition	Good	
555163	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Equipment Properly Labeled?	y	
555164	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
555165	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
555166	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
555167	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Operations A Ø	0	
555168	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Operations B Ø	0	
555169	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
555170	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
555171	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
555172	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
555173	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
555174	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
555175	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
555176	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
555177	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
555178	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Operations C Ø	0	
555179	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
555180	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
555181	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
555182	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
555183	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
555184	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Current Tap Position	4R	
555185	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
555186	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
555187	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
555188	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
555189	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	General Comments		
555190	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
555191	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
555192	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
555193	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
555194	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
555195	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
555196	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
555197	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
555198	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Regulator As Left Counter	14986	
555199	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
555200	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
555201	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
555202	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
555203	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC Operations Since Last Insp	368	
555204	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
555205	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
555206	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC Min Tap Position	10L	
555207	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BCH000529	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
555208	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
555209	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
555210	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
555211	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
555212	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
555213	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
555214	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
555215	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	Follow-up Action Required?	n	
555216	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
555217	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
555218	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	General Comments		
555219	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	General Comments		
555220	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
555221	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
555222	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
555223	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
555224	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
555225	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
555226	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
555227	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
555228	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
555229	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	General Comments		
555230	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
555231	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
555232	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
555233	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
555234	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
555235	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
555236	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
555237	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
555238	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
555239	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
555240	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
555241	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
555242	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
555243	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	LTC Totalizer Reading	8640.00	kw
555244	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
555245	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
555246	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
555247	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
555248	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
555249	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	LTC Operation Checked?	y	
555250	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	General Comments		
555251	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	Follow-up Action Required?	n	
555252	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Operations Ground	0	
555253	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Follow-up Action Required?	n	
555254	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Follow-up Action Required?	n	
555255	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Foundation Condition	Good	
555256	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	General Comments		
555257	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	General Comments		
555258	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Grounds in Place?	y	
555259	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Heaters (All) Functioning?	y	
555260	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Maintenance Operations	0	
555261	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Moisture and Leak Free?	y	
555262	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Operations Counter AF	293	
555263	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Operations Counter AL	297	
555264	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
555265	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Switching Operations	4	
555266	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	FE000285	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
555267	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	FE000285	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
555268	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	FE000285	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
555269	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
555270	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
555271	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
555272	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
555273	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
555274	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
555275	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
555276	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
555277	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
555278	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	General Comments		
555279	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
555280	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
555281	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Operations Counter	1107	
555282	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
555283	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Tank Leaks	None	
555284	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
555285	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Tank Paint Condition	Good	
555286	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Unknown Operations	0	
555287	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
555288	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
555289	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
555290	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.3782	
555291	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
555292	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
555293	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
555294	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
555295	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
555296	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
555297	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
555298	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	General Comments		
555299	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	General Comments		
555300	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
555301	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Vegetation	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
555302	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
555303	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
555304	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	General Comments		
555305	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
555306	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
555307	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
555308	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
555309	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
555310	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
555311	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Clear of Trash?	y	
555312	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
555313	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
555314	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	105.00	
555315	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
555316	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
555317	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
555318	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
555319	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
555320	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
555321	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
555322	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
555323	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
555324	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
555325	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
555326	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9030	
555327	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
555328	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
555329	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
555330	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
555331	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
555332	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
555333	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
555334	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
555335	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
555336	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
555337	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
555338	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
555339	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2889.60	kw
555340	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
555341	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	All Connections OK?	y	
555342	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
555343	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
555344	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
555345	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
555346	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
555347	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
555348	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
555349	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	Top Oil Temperature Max	35	°C
555350	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	Top Oil Temperature Present	25	°C
555351	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
555352	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	Totalizer Meter Reading	.9000	
555353	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
555354	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
555355	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
555356	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
555357	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
555358	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
555359	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
555360	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
555361	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
555362	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
555363	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
555364	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
555365	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
555366	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	LTCC000397	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
555367	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	LTCC000397	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
555368	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	LTCC000397	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
555369	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	LTCC000397	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
555370	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	LTCC000397	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
555371	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
555372	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
555373	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	LTCC000397	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
555374	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	LTCC000397	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
555375	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	LTCC000397	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
555376	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
555377	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
555378	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	General Comments		
555379	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	General Comments		
555380	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
555381	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
555382	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
555383	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
555384	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1440.96	kw
555385	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	Follow-up Action Required?	n	
555386	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	General Comments		
555387	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	General Comments		
555388	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
555389	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Grounds in Place?	y	
555390	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
555391	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
555392	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
555393	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Heaters (All) Functioning?	y	
555394	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Maintenance Operations	0	
555395	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Moisture and Leak Free?	y	
555396	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
555397	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Bushings Connection/Risers	Good	
555398	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Bushing Condition	Good	
555399	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Amps C Ø	160.0	
555400	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Amps B Ø	100.0	
555401	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Amps A Ø	120.0	
555402	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
555403	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
555404	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
555405	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
555406	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
555407	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
555408	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
555409	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
555410	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
555411	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
555412	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
555413	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
555414	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	Follow-up Action Required?	n	
555415	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
555416	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
555417	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	General Comments		
555418	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
555419	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	9 Month Operations	4	
555420	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	General Comments		
555421	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
555422	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	LTC Totalizer Reading	7344.00	kw
555423	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
555424	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
555425	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	Oil Temp Max	50	°C
555426	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	Oil Temp Present	45	°C
555427	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
555428	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
555429	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
555430	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Cabinet Paint Condition	Good	
555431	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Equipment Properly Labeled?	y	
555432	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
555433	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Accumulated Fault Duty B Ph V	3.14	%
555434	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Accumulated Fault Duty C Ph V	1.75	%
555435	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Amps A Ø	150.0	
555436	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Amps B Ø	120.0	
555437	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Amps C Ø	160.0	
555438	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Bushing Condition	Good	
555439	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Bushings Connection/Risers	Good	
555440	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
555441	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
555442	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
555443	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Cabinet Paint Condition	Good	
555444	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Equipment Properly Labeled?	y	
555445	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
555446	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
555447	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
555448	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Operations A Ø	0	
555449	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Operations B Ø	0	
555450	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Operations C Ø	0	
555451	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
555452	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Follow-up Action Required?	n	
555453	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Follow-up Action Required?	n	
555454	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Foundation Condition	Good	
555455	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	General Comments		
555456	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	General Comments		
555457	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Grounds in Place?	y	
555458	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Heaters (All) Functioning?	y	
555459	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
555460	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
555461	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Operations A Ø	0	
555462	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Operations B Ø	0	
555463	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Operations C Ø	0	
555464	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Operations Ground	0	
555465	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Maintenance Operations	0	
555466	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Moisture and Leak Free?	y	
555467	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Operations Counter AF	250	
555468	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Follow-up Action Required?	n	
555469	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Operations Counter AL	250	
555470	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Switching Operations	0	
555471	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Tank Paint Condition	Good	
555472	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Unknown Operations	0	
555473	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Follow-up Action Required?	n	
555474	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Foundation Condition	Good	
555475	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Amps A Ø	40.0	
555476	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Amps B Ø	40.0	
555477	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Amps C Ø	40.0	
555478	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
555479	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	Follow-up Action Required?	n	
555480	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
555481	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	General Comments		
555482	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Mechanism Patrol Inspection	General Comments		
555483	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC As Found Counter	33553	
555484	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC As Left Counter	33553	
555485	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
555486	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC Current Tap Position	2L	
555487	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC Max Tap Position	4R	
555488	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC Min Tap Position	6L	
555489	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC Operations Since Last Insp	362	
555490	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
555491	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
555492	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
555493	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	FE000285	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
555494	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	FE000285	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
555495	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	FE000285	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
555496	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	FE000285	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
555497	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
555498	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
555499	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Amps A Ø	75.0	
555500	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Amps B Ø	75.0	
555501	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Amps C Ø	75.0	
555502	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Bushing Condition	Good	
555503	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Bushings Connection/Risers	Good	
555504	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
555505	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
555506	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
555507	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Cabinet Paint Condition	Good	
555508	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Equipment Properly Labeled?	y	
555509	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
555510	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
555511	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
555512	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	VRR Time Delay	30	Seconds
555513	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
555514	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	FE000285	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
555515	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	FE000285	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
555516	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Operations A Ø	0	
555517	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Operations B Ø	0	
555518	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Operations C Ø	0	
555519	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
555520	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
555521	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
555522	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
555523	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Operations Counter AF	243	
555524	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Operations Counter AL	243	
555525	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
555526	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
555527	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	Totalizer Meter Reading	.7650	
555528	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
555529	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
555530	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Switching Operations	0	
555531	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Tank Paint Condition	Good	
555532	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Accumulated Fault Duty A Ph V	4.54	%
555533	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	9 Month Operations	11	
555534	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Unknown Operations	0	
555535	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	FE000285	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
555536	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	FE000285	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
555537	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	FE000285	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
555538	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	FE000285	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
555539	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	FE000285	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
555540	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	FE000285	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
555541	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
555542	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
555543	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
555544	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
555545	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
555546	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
555547	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
555548	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
555549	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	General Comments		
555550	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	General Comments	GAUGE STILL BROKE	
555551	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
555552	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
555553	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
555554	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	826.92	kw
555555	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	28.33	
555556	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
555557	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	Oil Temp Max	0	°C
555558	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
555559	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
555560	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
555561	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
555562	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	9 Month Operations	8	
555563	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
555564	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
555565	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
555566	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
555567	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
555568	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
555569	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
555570	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
555571	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
555572	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
555573	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
555574	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Follow-up Action Required?	n	
555575	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
555576	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
555577	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	General Comments		
555578	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	General Comments		
555579	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
555580	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	LTC Totalizer Reading	8547.84	kw
555581	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
555582	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
555583	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
555584	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
555585	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
555586	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
555587	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
555588	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
555589	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
555590	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
555591	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	General Comments		
555592	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
555593	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
555594	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
555595	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
555596	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Foundation Condition	Good	
555597	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9006	
555598	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
555599	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
555600	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
555601	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
555602	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
555603	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
555604	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	9 Month Operations	6	
555605	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
555606	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
555607	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
555608	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
555609	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
555610	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
555611	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
555612	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
555613	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
555614	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
555615	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
555616	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	General Comments		
555617	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
555618	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
555619	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
555620	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
555621	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
555622	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
555623	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
555624	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
555625	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
555626	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
555627	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
555628	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Amps A Ø	170.0	
555629	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
555630	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
555631	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
555632	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Min Tap Position	16L	
555633	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
555634	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
555635	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
555636	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
555637	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	121.0	volts
555638	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Regulator As Left Counter	62875	
555639	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
555640	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
555641	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Tank Leaks	None	
555642	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
555643	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
555644	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Amps B Ø	155.0	
555645	2/26/2019 13:13	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Amps C Ø	150.0	
555646	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC Operations Since Last Insp	1258	
555647	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
555648	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC Min Tap Position	8L	
555649	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC Max Tap Position	7R	
555650	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC Current Tap Position	1L	
555651	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
555652	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC As Left Counter	22968	
555653	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC As Found Counter	22968	
555654	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
555655	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
555656	2/26/2019 13:03	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
555657	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
555658	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
555659	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
555660	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
555661	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
555662	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
555663	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	General Comments		
555664	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Winding Temp Present	25	°C
555665	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
555666	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
555667	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
555668	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
555669	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	General Comments		
555670	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
555671	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
555672	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
555673	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
555674	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
555675	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Winding Temp Max	65	°C
555676	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Totalizer Meter Reading	.8904	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
555677	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
555678	2/26/2019 7:43	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
555679	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
555680	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Amps A Ø	80.0	
555681	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
555682	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
555683	2/26/2019 10:41	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
555684	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Top Oil Temperature Present	30	°C
555685	2/26/2019 13:56	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Top Oil Temperature Max	65	°C
555686	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	11.99	
555687	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	11.99	
555688	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
555689	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
555690	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	11.99	
555691	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
555692	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
555693	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	570.0	
555694	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
555695	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
555696	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	140	
555697	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	2	
555698	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	140	
555699	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
555700	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
555701	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	570.0	
555702	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
555703	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	570.0	
555704	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.89	%
555705	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	.89	%
555706	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.89	%
555707	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
555708	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
555709	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
555710	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
555711	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
555712	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
555713	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
555714	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
555715	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
555716	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
555717	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
555718	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
555719	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
555720	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
555721	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
555722	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	General Comments		
555723	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC As Found Counter	86395	
555724	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC As Left Counter	86395	
555725	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
555726	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC Current Tap Position	1R	
555727	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC Max Tap Position	16R	
555728	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC Min Tap Position	16L	
555729	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
555730	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Winding Temp Present	45	°C
555731	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Winding Temp Max	70	°C
555732	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Operations Ground	0	
555733	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
555734	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Totalizer Meter Reading	1.3518	
555735	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Follow-up Action Required?	n	
555736	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Follow-up Action Required?	n	
555737	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Operations Ground	0	
555738	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Operations C Ø	0	
555739	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
555740	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
555741	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Operations B Ø	0	
555742	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Operations A Ø	0	
555743	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
555744	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
555745	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Accumulated Fault Duty B Ph V	1.72	%
555746	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	General Comments		
555747	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Accumulated Fault Duty C Ph V	1.72	%
555748	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	General Comments		
555749	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
555750	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
555751	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Vegetation	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
555752	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Amps A Ø	0.0	
555753	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
555754	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
555755	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Follow-up Action Required?	n	
555756	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
555757	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
555758	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
555759	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Amps B Ø	0.0	
555760	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Amps C Ø	0.0	
555761	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
555762	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
555763	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
555764	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
555765	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
555766	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	9 Month Operations	0	
555767	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Accumulated Fault Duty A Ph V	1.13	%
555768	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Accumulated Fault Duty B Ph V	1.13	%
555769	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Accumulated Fault Duty C Ph V	1.13	%
555770	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Amps A Ø	0.0	
555771	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Amps B Ø	0.0	
555772	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	524	
555773	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	524	
555774	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
555775	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
555776	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
555777	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
555778	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
555779	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
555780	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
555781	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
555782	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
555783	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Operations A Ø	0	
555784	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Operations B Ø	0	
555785	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Operations C Ø	0	
555786	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCC000690	LTCControl	621-1	LTC Control Insp	General Comments		
555787	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCC000690	LTCControl	621-1	LTC Control Insp	LTC Operation Checked?	y	
555788	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Accumulated Fault Duty C Ph V	7.11	%
555789	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Accumulated Fault Duty B Ph V	4.27	%
555790	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Accumulated Fault Duty A Ph V	4.98	%
555791	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	9 Month Operations	8	
555792	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCC000690	LTCControl	621-1	LTC Control Insp	LTC Output Voltage Level	12.0	VAC
555793	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCC000690	LTCControl	621-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
555794	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCC000690	LTCControl	621-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
555795	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCC000690	LTCControl	621-1	LTC Control Insp	VRR Time Delay	30	Seconds
555796	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
555797	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
555798	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
555799	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
555800	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
555801	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
555802	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
555803	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
555804	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Follow-up Action Required?	n	
555805	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	General Comments		
555806	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Maintenance Operations	0	
555807	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Operations Counter AF	148	
555808	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Amps C Ø	0.0	
555809	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
555810	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
555811	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
555812	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
555813	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
555814	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
555815	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Operations A Ø	0	
555816	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Operations B Ø	0	
555817	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Operations C Ø	0	
555818	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
555819	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
555820	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
555821	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
555822	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
555823	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
555824	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	5.78	%
555825	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	5.78	%
555826	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
555827	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
555828	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
555829	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	5.78	%
555830	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
555831	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
555832	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	General Comments		
555833	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
555834	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
555835	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
555836	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
555837	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
555838	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
555839	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
555840	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Equipment Properly Labeled?	y	
555841	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Cabinet Paint Condition	Good	
555842	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	21	°C
555843	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	54	°C
555844	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
555845	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
555846	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC Operations Since Last Insp	5781	
555847	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
555848	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
555849	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
555850	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
555851	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
555852	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
555853	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Clear of Trash?	y	
555854	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
555855	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
555856	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
555857	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Bushings Connection/Risers	Good	
555858	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Bushing Condition	Good	
555859	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Amps C Ø	240.0	
555860	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Amps B Ø	240.0	
555861	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
555862	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
555863	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
555864	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
555865	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
555866	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
555867	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
555868	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	General Comments		
555869	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
555870	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
555871	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Amps A Ø	240.0	
555872	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
555873	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCC000690	LTCControl	621-1	LTC Control Insp	All Connections OK?	y	
555874	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCC000690	LTCControl	621-1	LTC Control Insp	Follow-up Action Required?	n	
555875	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Operations Counter AL	454	
555876	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
555877	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Switching Operations	0	
555878	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Tank Paint Condition	Good	
555879	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Unknown Operations	0	
555880	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Follow-up Action Required?	n	
555881	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
555882	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Winding Temp Present	57	°C
555883	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
555884	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
555885	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Winding Temp Max	63	°C
555886	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Totalizer Meter Reading	.9830	
555887	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Operations Ground	0	
555888	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
555889	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
555890	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
555891	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	General Comments		
555892	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
555893	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
555894	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
555895	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
555896	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
555897	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
555898	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
555899	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Oil Temp Present	33	°C
555900	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
555901	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
555902	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
555903	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Oil Temp Max	59	°C
555904	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
555905	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
555906	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
555907	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
555908	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Switching Operations	0	
555909	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Tank Paint Condition	Good	
555910	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Unknown Operations	0	
555911	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
555912	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
555913	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
555914	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
555915	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
555916	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
555917	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	LTC Totalizer Reading	9802.08	kw
555918	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
555919	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
555920	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
555921	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
555922	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
555923	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	Oil Temp Max	45	°C
555924	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	Oil Temp Present	30	°C
555925	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
555926	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
555927	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
555928	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
555929	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	Follow-up Action Required?	n	
555930	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Operations Counter AL	193	
555931	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
555932	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Operations Counter AF	193	
555933	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Maintenance Operations	0	
555934	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	General Comments		
555935	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	General Comments		
555936	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
555937	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
555938	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
555939	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
555940	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
555941	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
555942	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	General Comments	desicant needs Replaced ontop of LTC	
555943	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
555944	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
555945	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	General Comments		
555946	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	General Comments		
555947	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Grounds in Place?	y	
555948	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Heaters (All) Functioning?	y	
555949	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Maintenance Operations	0	
555950	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Moisture and Leak Free?	y	
555951	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
555952	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
555953	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
555954	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
555955	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
555956	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
555957	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
555958	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Switching Operations	0	
555959	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Unknown Operations	0	
555960	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Foundation Condition	Good	
555961	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Operations Counter AF	226	
555962	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	14	
555963	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Operations Counter AL	226	
555964	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
555965	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	13.46	%
555966	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	7.69	%
555967	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	9.61	%
555968	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
555969	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	General Comments		
555970	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
555971	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
555972	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
555973	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	80.0	
555974	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
555975	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
555976	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
555977	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
555978	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Operations Counter AF	454	
555979	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
555980	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
555981	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
555982	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	VRR Time Delay	30	Seconds
555983	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	31	
555984	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Foundation Condition	Good	
555985	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
555986	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
555987	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
555988	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
555989	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
555990	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	35.88	%
555991	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Trip-energy Supply Verified	y	LED lights?
555992	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
555993	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
555994	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
555995	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
555996	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
555997	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
555998	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
555999	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	125	
556000	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	125	
556001	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
556002	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
556003	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
556004	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	Follow-up Action Required?	n	
556005	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
556006	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
556007	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
556008	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
556009	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
556010	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
556011	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
556012	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
556013	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
556014	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
556015	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	43	°F
556016	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	26.58	%
556017	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	34.55	%
556018	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	104.0	
556019	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	9 Month Operations	2	
556020	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	LTC Totalizer Reading	14980.92	kw
556021	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
556022	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	General Comments		
556023	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	102.0	
556024	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	118.0	
556025	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
556026	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
556027	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
556028	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
556029	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
556030	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Accumulated Fault Duty A Ph V	1.72	%
556031	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
556032	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
556033	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
556034	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
556035	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
556036	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
556037	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
556038	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	Totalizer Meter Reading	1.3614	
556039	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
556040	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
556041	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Operations C Ø	0	
556042	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Operations B Ø	0	
556043	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Operations A Ø	0	
556044	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
556045	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
556046	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	General Comments		
556047	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000318	PowerFuse	SM-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
556048	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000318	PowerFuse	SM-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
556049	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
556050	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
556051	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
556052	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
556053	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
556054	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
556055	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
556056	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
556057	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	145	
556058	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	145	
556059	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
556060	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
556061	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
556062	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
556063	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
556064	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Amps C Ø	176.0	
556065	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Amps B Ø	179.0	
556066	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Amps A Ø	183.0	
556067	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Accumulated Fault Duty C Ph V	2.06	%
556068	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Accumulated Fault Duty B Ph V	1.47	%
556069	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Accumulated Fault Duty A Ph V	2.06	%
556070	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	9 Month Operations	9	
556071	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	All Connections OK?	y	
556072	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	Follow-up Action Required?	n	
556073	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	General Comments		
556074	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	LTC Operation Checked?	y	
556075	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	LTC Output Voltage Level	1224.0	VAC
556076	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
556077	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
556078	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
556079	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
556080	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
556081	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
556082	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0246	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
556083	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	Follow-up Action Required?	n	
556084	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
556085	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	General Comments		
556086	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	General Comments		
556087	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC As Found Counter	31082	
556088	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC As Left Counter	31082	
556089	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
556090	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
556091	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC Max Tap Position	10R	
556092	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Operations Counter AF	228	
556093	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC Operations Since Last Insp	701	
556094	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
556095	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
556096	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
556097	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
556098	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
556099	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
556100	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	126.0	volts
556101	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Regulator As Left Counter	25365	
556102	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
556103	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
556104	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Operations Counter AL	228	
556105	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Switching Operations	0	
556106	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Unknown Operations	0	
556107	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
556108	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
556109	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
556110	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
556111	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
556112	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
556113	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
556114	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
556115	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
556116	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
556117	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
556118	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
556119	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
556120	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
556121	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
556122	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
556123	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
556124	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
556125	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
556126	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
556127	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
556128	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC Min Tap Position	7L	
556129	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
556130	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC Operations Since Last Insp	790	
556131	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
556132	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
556133	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
556134	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
556135	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
556136	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	936	
556137	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	936	
556138	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	9 Month Operations	2	
556139	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Accumulated Fault Duty A Ph V	1.72	%
556140	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Accumulated Fault Duty B Ph V	1.72	%
556141	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Accumulated Fault Duty C Ph V	1.72	%
556142	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Moisture and Leak Free?	y	
556143	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Amps A Ø	0.0	
556144	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Amps B Ø	0.0	
556145	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Amps C Ø	0.0	
556146	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
556147	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
556148	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
556149	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	12.68	%
556150	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
556151	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	12176.64	kw
556152	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
556153	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
556154	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
556155	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
556156	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	General Comments		
556157	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	General Comments		
556158	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
556159	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
556160	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	13.95	%
556161	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	12.68	%
556162	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60	
556163	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
556164	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Operations A Ø	0	
556165	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Operations B Ø	0	
556166	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Operations C Ø	0	
556167	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Operations Ground	0	
556168	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Follow-up Action Required?	n	
556169	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	General Comments		
556170	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Maintenance Operations	0	
556171	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
556172	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
556173	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
556174	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
556175	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
556176	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
556177	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
556178	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
556179	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
556180	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60	
556181	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
556182	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
556183	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
556184	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
556185	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
556186	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	General Comments		
556187	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC As Found Counter	100297	
556188	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC As Left Counter	100297	
556189	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
556190	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
556191	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC Max Tap Position	10R	
556192	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC Min Tap Position	6L	
556193	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC Operations Since Last Insp	398	
556194	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
556195	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
556196	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
556197	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
556198	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
556199	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
556200	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
556201	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Tank Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
556202	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
556203	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
556204	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	138	
556205	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	138	
556206	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
556207	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
556208	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
556209	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
556210	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	5	
556211	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	9.3	%
556212	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	6.64	%
556213	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	9.3	%
556214	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	94.0	
556215	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	87.0	
556216	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	87.0	
556217	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
556218	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
556219	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
556220	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
556221	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
556222	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
556223	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	126.0	volts
556224	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
556225	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
556226	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
556227	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
556228	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Min Tap Position	10L	
556229	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Max Tap Position	6R	
556230	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
556231	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	General Comments		
556232	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
556233	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
556234	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
556235	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
556236	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
556237	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
556238	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
556239	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
556240	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Tank Leaks	None	
556241	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120	
556242	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
556243	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
556244	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
556245	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
556246	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
556247	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
556248	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
556249	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
556250	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
556251	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
556252	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	180.0	
556253	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	180.0	
556254	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.96	%
556255	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	.96	%
556256	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
556257	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
556258	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
556259	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
556260	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.92	%
556261	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
556262	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	Follow-up Action Required?	n	
556263	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
556264	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
556265	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
556266	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	General Comments		
556267	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
556268	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
556269	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
556270	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
556271	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
556272	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
556273	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
556274	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
556275	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Regulator As Left Counter	27888	
556276	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
556277	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
556278	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
556279	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
556280	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
556281	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
556282	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
556283	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
556284	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	256	
556285	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	260	
556286	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
556287	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
556288	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BB0248	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
556289	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
556290	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
556291	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	Follow-up Action Required?	n	
556292	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
556293	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
556294	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
556295	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
556296	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
556297	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Current Tap Position	2L	
556298	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
556299	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
556300	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Switching Operations	0	
556301	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Unknown Operations	0	
556302	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
556303	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
556304	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	General Comments		
556305	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
556306	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
556307	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
556308	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
556309	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
556310	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
556311	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Max Tap Position	2L	
556312	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
556313	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	General Comments		
556314	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	General Comments		
556315	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC As Found Counter	36421	
556316	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC As Left Counter	36421	
556317	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
556318	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC Current Tap Position	3L	
556319	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
556320	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC Min Tap Position	12L	
556321	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	20	°C
556322	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1355	
556323	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1355	
556324	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	22	
556325	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	318.0	
556326	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	333.0	
556327	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
556328	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Readings	General Comments		
556329	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
556330	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
556331	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Min Tap Position	10L	
556332	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
556333	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	110.0	
556334	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	110.0	
556335	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	110.0	
556336	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	Follow-up Action Required?	n	
556337	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
556338	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	General Comments		
556339	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
556340	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
556341	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
556342	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
556343	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
556344	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
556345	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
556346	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
556347	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	General Comments		
556348	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
556349	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Max Tap Position	6R	
556350	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Min Tap Position	10L	
556351	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
556352	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
556353	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
556354	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
556355	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
556356	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Regulator As Left Counter	27272	
556357	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
556358	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
556359	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
556360	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Tank Leaks	None	
556361	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
556362	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
556363	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
556364	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
556365	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
556366	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
556367	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
556368	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
556369	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Follow-up Action Required?	n	
556370	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
556371	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
556372	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	General Comments		
556373	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	General Comments		
556374	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
556375	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	LTC Totalizer Reading	14739.84	kw
556376	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
556377	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
556378	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	14400	psi
556379	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Oil Temp Max	20	°C
556380	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Oil Temp Present	15	°C
556381	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
556382	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
556383	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Follow-up Action Required?	n	
556384	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	General Comments		
556385	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Maintenance Operations	0	
556386	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Operations Counter AF	168	
556387	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Operations Counter AL	168	
556388	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
556389	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
556390	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
556391	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
556392	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Winding Temp Max	20	°C
556393	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Winding Temp Present	15	°C
556394	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
556395	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
556396	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
556397	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	9 Month Operations	2	
556398	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Accumulated Fault Duty A Ph V	5.52	%
556399	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Accumulated Fault Duty B Ph V	1.10	%
556400	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Accumulated Fault Duty C Ph V	1.10	%
556401	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Amps A Ø	220.0	
556402	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Amps B Ø	240.0	
556403	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Amps C Ø	190.0	
556404	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Bushing Condition	Good	
556405	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Bushings Connection/Risers	Good	
556406	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
556407	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
556408	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
556409	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Cabinet Paint Condition	Good	
556410	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
556411	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
556412	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
556413	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
556414	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
556415	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
556416	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Equipment Properly Labeled?	y	
556417	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
556418	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
556419	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
556420	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Operations A Ø	0	
556421	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Operations B Ø	0	
556422	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Operations C Ø	0	
556423	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Operations Ground	0	
556424	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Follow-up Action Required?	n	
556425	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Follow-up Action Required?	n	
556426	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
556427	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	General Comments		
556428	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	General Comments		
556429	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Grounds in Place?	y	
556430	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
556431	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	Desicant needs changed ontop of LTC	
556432	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
556433	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
556434	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
556435	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
556436	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	ok	
556437	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
556438	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Heaters (All) Functioning?	y	
556439	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Maintenance Operations	0	
556440	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
556441	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
556442	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0230	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
556443	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	General Comments		
556444	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC As Found Counter	45772	
556445	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC As Left Counter	45772	
556446	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
556447	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Operations Counter AL	148	
556448	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Switching Operations	0	
556449	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Unknown Operations	0	
556450	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
556451	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
556452	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
556453	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
556454	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
556455	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
556456	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC Current Tap Position	4L	
556457	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC Max Tap Position	4R	
556458	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC Min Tap Position	12L	
556459	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Foundation Condition	Good	
556460	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
556461	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
556462	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	General Comments		
556463	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
556464	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
556465	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
556466	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
556467	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
556468	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
556469	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
556470	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
556471	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
556472	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
556473	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
556474	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
556475	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
556476	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	10	°C
556477	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC Operations Since Last Insp	873	
556478	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
556479	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
556480	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
556481	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
556482	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Winding Temp Present	30	°C
556483	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Winding Temp Max	30	°C
556484	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Totalizer Meter Reading	1.2684	
556485	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
556486	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Top Oil Temperature Present	20	°C
556487	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Top Oil Temperature Max	20	°C
556488	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
556489	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
556490	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
556491	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
556492	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
556493	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
556494	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Totalizer Meter Reading	1.0236	
556495	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Winding Temp Present	50	°C
556496	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Accumulated Fault Duty C Ph V	1.72	%
556497	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Grounds in Place?	y	
556498	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Heaters (All) Functioning?	y	
556499	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Maintenance Operations	0	
556500	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Moisture and Leak Free?	y	
556501	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Operations Counter AF	33	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
556502	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Operations Counter AL	33	
556503	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
556504	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Switching Operations	0	
556505	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Tank Paint Condition	Good	
556506	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
556507	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
556508	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
556509	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Evidence of Insects	None	
556510	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
556511	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
556512	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
556513	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
556514	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
556515	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
556516	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
556517	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
556518	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
556519	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
556520	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	n	
556521	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
556522	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	378.0	
556523	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	304.0	
556524	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Foundation Condition	Good	
556525	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Follow-up Action Required?	n	
556526	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Follow-up Action Required?	n	
556527	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Operations Ground	0	
556528	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Operations C Ø	0	
556529	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Unknown Operations	0	
556530	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BCH001151	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
556531	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BCH001151	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
556532	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BCH001151	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
556533	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BCH001151	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
556534	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BCH001151	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
556535	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BCH001151	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
556536	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BCH001151	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
556537	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Operations B Ø	0	
556538	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Operations A Ø	0	
556539	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
556540	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
556541	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
556542	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
556543	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
556544	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
556545	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
556546	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
556547	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
556548	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	150.0	
556549	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	150.0	
556550	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	150.0	
556551	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
556552	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
556553	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
556554	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
556555	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
556556	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
556557	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
556558	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
556559	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
556560	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
556561	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
556562	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
556563	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
556564	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
556565	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
556566	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
556567	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
556568	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
556569	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	General Comments		
556570	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
556571	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
556572	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Foundation Condition	Good	
556573	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
556574	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
556575	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
556576	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
556577	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
556578	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
556579	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
556580	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
556581	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
556582	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
556583	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
556584	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
556585	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
556586	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
556587	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
556588	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
556589	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
556590	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
556591	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
556592	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Amps C Ø	0.0	
556593	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Amps B Ø	0.0	
556594	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Amps A Ø	0.0	
556595	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
556596	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Follow-up Action Required?	y	
556597	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
556598	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
556599	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	General Comments		
556600	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	General Comments	winding temp guage will not reset Fan group 2 not working	
556601	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
556602	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	LTC Totalizer Reading	15033.60	kw
556603	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
556604	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
556605	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1800	psi
556606	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Oil Temp Max	60	°C
556607	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Oil Temp Present	55	°C
556608	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
556609	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
556610	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
556611	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
556612	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
556613	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
556614	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
556615	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
556616	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Totalizer Meter Reading	1.0440	
556617	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Winding Temp Max	70	°C
556618	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
556619	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
556620	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
556621	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
556622	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
556623	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
556624	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
556625	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
556626	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
556627	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
556628	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
556629	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
556630	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
556631	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
556632	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
556633	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
556634	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
556635	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
556636	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
556637	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	9 Month Operations	0	
556638	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
556639	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
556640	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
556641	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Amps A Ø	470.0	
556642	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Amps B Ø	420.0	
556643	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Amps C Ø	420.0	
556644	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Bushing Condition	Good	
556645	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
556646	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
556647	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
556648	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
556649	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
556650	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
556651	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
556652	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	General Comments		
556653	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
556654	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
556655	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
556656	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
556657	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	371	
556658	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
556659	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
556660	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
556661	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
556662	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
556663	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	43	°F
556664	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
556665	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Accumulated Fault Duty B Ph V	1.72	%
556666	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Accumulated Fault Duty A Ph V	1.72	%
556667	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	9 Month Operations	2	
556668	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	371	
556669	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
556670	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
556671	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
556672	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
556673	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Unknown Operations	0	
556674	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Tank Paint Condition	Good	
556675	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Switching Operations	2	
556676	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Operations Counter AL	267	
556677	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Operations Counter AF	265	
556678	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Moisture and Leak Free?	y	
556679	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Maintenance Operations	0	
556680	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
556681	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
556682	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	310.0	
556683	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
556684	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
556685	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	General Comments		
556686	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
556687	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	General Comments		
556688	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
556689	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
556690	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
556691	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
556692	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
556693	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
556694	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
556695	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	43	°F
556696	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
556697	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
556698	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	1	
556699	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	923	
556700	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	923	
556701	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
556702	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
556703	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	15	
556704	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	6.28	%
556705	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	7.17	%
556706	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.69	%
556707	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	180.0	
556708	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	180.0	
556709	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	180.0	
556710	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
556711	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
556712	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
556713	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
556714	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
556715	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Bushing Condition	Good	
556716	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Amps C Ø	280.0	
556717	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Amps B Ø	280.0	
556718	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Amps A Ø	280.0	
556719	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
556720	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
556721	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
556722	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	9 Month Operations	0	
556723	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
556724	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
556725	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
556726	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
556727	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
556728	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
556729	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	General Comments		
556730	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
556731	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
556732	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
556733	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
556734	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
556735	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
556736	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
556737	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	4	
556738	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	4	
556739	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
556740	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
556741	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
556742	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
556743	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
556744	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
556745	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
556746	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
556747	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
556748	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
556749	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
556750	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	7.69	%
556751	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	9.61	%
556752	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	5.77	%
556753	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	35	
556754	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
556755	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
556756	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
556757	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
556758	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
556759	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
556760	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1223	
556761	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1223	
556762	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
556763	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	1223 is the correct VC	
556764	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
556765	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
556766	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
556767	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
556768	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
556769	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
556770	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
556771	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
556772	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
556773	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
556774	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
556775	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
556776	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	General Comments		
556777	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
556778	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
556779	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	LTCC000574	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
556780	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	LTCC000574	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
556781	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	LTCC000574	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
556782	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	LTCC000574	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
556783	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	LTCC000574	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
556784	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
556785	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
556786	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
556787	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
556788	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
556789	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
556790	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
556791	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
556792	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
556793	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
556794	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
556795	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
556796	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	°F
556797	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
556798	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	98.0	
556799	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	114.0	
556800	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	LTCC000574	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
556801	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
556802	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
556803	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
556804	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
556805	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
556806	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
556807	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
556808	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
556809	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
556810	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
556811	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
556812	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
556813	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
556814	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
556815	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
556816	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
556817	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
556818	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	314	
556819	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
556820	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Clear of Trash?	y	
556821	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
556822	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	LTCC000546	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
556823	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	LTCC000546	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124	VAC
556824	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	LTCC000546	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124	VAC
556825	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	LTCC000546	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125	VAC
556826	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	LTCC000546	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
556827	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	LTCC000546	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
556828	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	LTCC000546	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
556829	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	LTCC000546	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
556830	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
556831	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
556832	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
556833	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
556834	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	General Comments		
556835	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
556836	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
556837	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
556838	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	314	
556839	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
556840	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
556841	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
556842	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Vegetation	None	
556843	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
556844	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
556845	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
556846	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
556847	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
556848	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
556849	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
556850	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	Seeping	
556851	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
556852	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
556853	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
556854	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
556855	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	General Comments	minor leaks under radiators on TR	
556856	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
556857	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
556858	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
556859	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
556860	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
556861	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
556862	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	140.0	
556863	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0231	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	140.0	
556864	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
556865	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
556866	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
556867	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
556868	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
556869	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
556870	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	9 Month Operations	7	
556871	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Accumulated Fault Duty A Ph V	6.41	%
556872	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Accumulated Fault Duty B Ph V	2.85	%
556873	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Accumulated Fault Duty C Ph V	3.56	%
556874	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Amps A Ø	240.0	
556875	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Amps B Ø	240.0	
556876	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Amps C Ø	240.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
556877	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Bushing Condition	Good	
556878	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Bushings Connection/Risers	Good	
556879	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
556880	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
556881	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
556882	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Cabinet Paint Condition	Good	
556883	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Equipment Properly Labeled?	y	
556884	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
556885	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
556886	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
556887	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
556888	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
556889	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
556890	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Operations A Ø	0	
556891	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Operations B Ø	0	
556892	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Operations C Ø	0	
556893	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Operations Ground	0	
556894	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Follow-up Action Required?	n	
556895	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Follow-up Action Required?	n	
556896	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Foundation Condition	Good	
556897	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	General Comments		
556898	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	General Comments		
556899	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	General Comments		
556900	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
556901	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
556902	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Unknown Operations	0	
556903	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Switching Operations	0	
556904	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Operations Counter AL	226	
556905	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
556906	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
556907	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
556908	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Panels Dusted?	y	
556909	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
556910	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
556911	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	General Comments		
556912	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
556913	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Operations Counter AF	226	
556914	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Maintenance Operations	0	
556915	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	General Comments		
556916	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Follow-up Action Required?	n	
556917	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Operations Ground	0	
556918	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Operations C Ø	0	
556919	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Operations B Ø	0	
556920	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Operations A Ø	0	
556921	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
556922	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
556923	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Floor Swept?	y	
556924	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
556925	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
556926	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
556927	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
556928	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
556929	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	499	
556930	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	97.0	
556931	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	23.05	%
556932	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	27.91	%
556933	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	25.48	%
556934	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	33	
556935	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	LTCC000574	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
556936	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	LTCC000574	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
556937	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
556938	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	General Comments		
556939	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
556940	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
556941	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	General Comments		
556942	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
556943	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
556944	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.5	amps
556945	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
556946	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
556947	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
556948	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
556949	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
556950	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
556951	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
556952	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Unknown Operations	0	
556953	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	499	
556954	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
556955	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
556956	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
556957	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
556958	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments	Heator Strip in cabnite bad	
556959	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
556960	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
556961	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
556962	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
556963	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Readings	General Comments		
556964	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
556965	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Tank Paint Condition	Good	
556966	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Switching Operations	0	
556967	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
556968	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
556969	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	y	
556970	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
556971	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
556972	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
556973	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
556974	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Foundation Condition	Good	
556975	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
556976	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
556977	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
556978	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
556979	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
556980	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Operations Counter AL	163	
556981	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Operations Counter AF	163	
556982	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
556983	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Maintenance Operations	0	
556984	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
556985	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Grounds in Place?	y	
556986	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	General Comments		
556987	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	General Comments		
556988	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
556989	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	LTC Totalizer Reading	9826.56	kw
556990	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
556991	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
556992	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	Oil Temp Max	40	°C
556993	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	Oil Temp Present	30	°C
556994	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Operations C Ø	0	
556995	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Operations Ground	0	
556996	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Follow-up Action Required?	n	
556997	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	General Comments		
556998	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Maintenance Operations	0	
556999	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Operations Counter AF	124	
557000	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Operations Counter AL	124	
557001	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Switching Operations	0	
557002	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	13	
557003	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	23.92	%
557004	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	31.89	%
557005	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
557006	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
557007	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
557008	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
557009	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	14.62	%
557010	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	166.0	
557011	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	118.0	
557012	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	157.0	
557013	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
557014	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	33.54	
557015	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
557016	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Unknown Operations	0	
557017	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
557018	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
557019	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
557020	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
557021	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	Totalizer Meter Reading	1.0236	
557022	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
557023	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
557024	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
557025	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
557026	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
557027	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
557028	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
557029	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
557030	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
557031	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
557032	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
557033	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	140.0	
557034	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	99.0	
557035	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
557036	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
557037	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
557038	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
557039	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
557040	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
557041	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
557042	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
557043	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
557044	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
557045	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
557046	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
557047	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	120.0	
557048	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	120.0	
557049	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	120.0	
557050	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Operations A Ø	0	
557051	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Operations B Ø	0	
557052	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Operations C Ø	0	
557053	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Operations Ground	0	
557054	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Follow-up Action Required?	n	
557055	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	General Comments		
557056	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Maintenance Operations	0	
557057	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Operations Counter AF	157	
557058	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
557059	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
557060	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	General Comments	ok	
557061	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
557062	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
557063	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
557064	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
557065	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
557066	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
557067	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
557068	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
557069	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
557070	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Operations Counter AL	157	
557071	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
557072	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
557073	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
557074	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
557075	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Switching Operations	0	
557076	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Unknown Operations	0	
557077	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	9 Month Operations	3	
557078	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Accumulated Fault Duty A Ph V	4.78	%
557079	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Accumulated Fault Duty B Ph V	7.17	%
557080	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Accumulated Fault Duty C Ph V	1.59	%
557081	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Amps A Ø	240.0	
557082	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Amps B Ø	200.0	
557083	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
557084	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
557085	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	832	
557086	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	832	
557087	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
557088	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Amps C Ø	220.0	
557089	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
557090	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
557091	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
557092	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Operations A Ø	0	
557093	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Operations B Ø	0	
557094	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
557095	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
557096	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
557097	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
557098	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
557099	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
557100	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
557101	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
557102	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
557103	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
557104	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
557105	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
557106	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	Follow-up Action Required?	n	
557107	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
557108	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
557109	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	General Comments		
557110	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	General Comments		
557111	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
557112	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
557113	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
557114	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
557115	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
557116	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
557117	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Follow-up Action Required?	n	
557118	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
557119	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
557120	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	General Comments		
557121	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	General Comments		
557122	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
557123	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	LTC Totalizer Reading	19465.92	kw
557124	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
557125	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
557126	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1497	
557127	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1497	
557128	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
557129	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
557130	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	General Comments		
557131	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
557132	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
557133	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
557134	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
557135	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
557136	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
557137	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
557138	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
557139	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
557140	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
557141	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
557142	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
557143	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
557144	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
557145	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
557146	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
557147	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
557148	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
557149	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
557150	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
557151	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
557152	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Oil Temp Max	45	°C
557153	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Oil Temp Present	25	°C
557154	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
557155	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
557156	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	General Comments		
557157	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
557158	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
557159	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	339.0	
557160	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
557161	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
557162	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
557163	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
557164	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
557165	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	123.0	
557166	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
557167	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
557168	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
557169	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
557170	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	7.97	%
557171	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	9.3	%
557172	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	6.64	%
557173	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
557174	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
557175	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
557176	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1215	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
557177	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1215	
557178	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	5.38	%
557179	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	6.28	%
557180	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.69	%
557181	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
557182	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	B Phase IOC	
557183	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
557184	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
557185	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
557186	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	2	
557187	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
557188	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
557189	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	22.36	
557190	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
557191	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	147.0	
557192	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	129.0	
557193	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	118.0	
557194	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	14.56	%
557195	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	18.2	%
557196	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	24.27	%
557197	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	38	
557198	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	5	
557199	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
557200	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	3	
557201	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
557202	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
557203	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
557204	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	B Phase IOC	
557205	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
557206	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	879	
557207	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	879	
557208	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
557209	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
557210	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
557211	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
557212	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
557213	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
557214	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
557215	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
557216	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Ambient Temp	31	°F
557217	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
557218	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Clear of Trash?	y	
557219	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
557220	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
557221	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
557222	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
557223	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
557224	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
557225	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	General Comments		
557226	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
557227	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Vegetation	None	
557228	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
557229	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
557230	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
557231	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
557232	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
557233	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
557234	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
557235	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Foundation Condition	Good	
557236	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
557237	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
557238	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
557239	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
557240	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	General Comments		
557241	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
557242	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
557243	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
557244	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
557245	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Clear of Trash?	y	
557246	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
557247	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
557248	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
557249	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
557250	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
557251	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
557252	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
557253	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
557254	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
557255	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
557256	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
557257	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
557258	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Vegetation	None	
557259	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
557260	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
557261	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	2.89	%
557262	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	2.89	%
557263	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	2.89	%
557264	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	468.0	
557265	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	395.0	
557266	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
557267	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
557268	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	807	
557269	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	807	
557270	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
557271	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
557272	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
557273	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
557274	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
557275	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
557276	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
557277	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
557278	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
557279	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
557280	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
557281	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
557282	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	15.0	
557283	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
557284	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
557285	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
557286	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
557287	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
557288	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
557289	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
557290	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Amps A Ø	90	
557291	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	455.0	
557292	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
557293	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
557294	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
557295	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1604	
557296	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1604	
557297	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
557298	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Heaters (All) Functioning?	y	
557299	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Grounds in Place?	y	
557300	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	General Comments		
557301	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	General Comments		
557302	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Foundation Condition	Good	
557303	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Follow-up Action Required?	n	
557304	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Follow-up Action Required?	n	
557305	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Operations Ground	0	
557306	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Operations C Ø	0	
557307	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Operations B Ø	0	
557308	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Operations A Ø	0	
557309	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
557310	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
557311	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
557312	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Equipment Properly Labeled?	y	
557313	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Cabinet Paint Condition	Good	
557314	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
557315	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
557316	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
557317	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Bushings Connection/Risers	Good	
557318	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Bushing Condition	Good	
557319	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Amps C Ø	80	
557320	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Amps B Ø	60	
557321	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	9 Month Operations	5	
557322	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Accumulated Fault Duty A Ph V	9.57	%
557323	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Accumulated Fault Duty B Ph V	8.77	%
557324	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Accumulated Fault Duty C Ph V	8.77	%
557325	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
557326	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
557327	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Amps A Ø	360.0	
557328	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Amps B Ø	290.0	
557329	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Amps C Ø	340.0	
557330	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
557331	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
557332	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
557333	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Operations A Ø	0	
557334	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
557335	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
557336	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
557337	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
557338	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
557339	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
557340	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
557341	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
557342	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
557343	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
557344	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
557345	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
557346	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Operations B Ø	0	
557347	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Operations C Ø	0	
557348	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Operations Ground	0	
557349	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Follow-up Action Required?	n	
557350	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	General Comments		
557351	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Maintenance Operations	0	
557352	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Operations Counter AF	177	
557353	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Operations Counter AL	177	
557354	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
557355	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	395	
557356	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	395	
557357	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
557358	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
557359	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
557360	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	100.0	
557361	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	100.0	
557362	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC Current Tap Position	2R	
557363	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC Max Tap Position	7R	
557364	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC Min Tap Position	3L	
557365	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC Operations Since Last Insp	1223	
557366	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
557367	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
557368	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Maintenance Operations	0	
557369	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
557370	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Operations Counter AF	99740	
557371	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Operations Counter AL	99740	
557372	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
557373	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Switching Operations	0	
557374	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Tank Paint Condition	Good	
557375	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Unknown Operations	0	
557376	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	9 Month Operations	7	
557377	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Accumulated Fault Duty A Ph V	.80	%
557378	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Accumulated Fault Duty B Ph V	.80	%
557379	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
557380	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Amps A Ø	230.0	
557381	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Amps B Ø	100.0	
557382	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Amps C Ø	240.0	
557383	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
557384	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
557385	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
557386	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Operations A Ø	0	
557387	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Operations B Ø	0	
557388	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Operations C Ø	0	
557389	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Operations Ground	0	
557390	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Follow-up Action Required?	n	
557391	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	General Comments		
557392	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Maintenance Operations	0	
557393	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Operations Counter AF	85	
557394	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Operations Counter AL	85	
557395	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Switching Operations	0	
557396	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Unknown Operations	0	
557397	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	9 Month Operations	19	
557398	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
557399	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
557400	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Accumulated Fault Duty C Ph V	1.59	%
557401	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Amps A Ø	200.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
557402	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
557403	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	245	
557404	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	Oil Temp Present	50	°C
557405	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	Oil Temp Max	95	°C
557406	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	General Comments		
557407	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
557408	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
557409	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Amps B Ø	200.0	
557410	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
557411	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
557412	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
557413	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
557414	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
557415	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
557416	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
557417	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
557418	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Amps C Ø	200.0	
557419	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
557420	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
557421	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
557422	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
557423	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	General Comments		
557424	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
557425	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Accumulated Fault Duty C Ph V	3.24	%
557426	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Accumulated Fault Duty B Ph V	5.89	%
557427	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Accumulated Fault Duty A Ph V	5.3	%
557428	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	9 Month Operations	6	
557429	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Switching Operations	0	
557430	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Unknown Operations	0	
557431	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
557432	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
557433	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	11.0	
557434	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	17.0	
557435	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	6.07	%
557436	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	19.41	%
557437	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	16.99	%
557438	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	13	
557439	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
557440	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
557441	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Operations A Ø	0	
557442	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Operations B Ø	0	
557443	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Operations C Ø	0	
557444	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Operations Ground	0	
557445	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Follow-up Action Required?	n	
557446	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Follow-up Action Required?	n	
557447	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Foundation Condition	Good	
557448	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	General Comments		
557449	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	General Comments		
557450	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Grounds in Place?	y	
557451	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Vegetation	None	
557452	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
557453	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
557454	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	General Comments		
557455	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
557456	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
557457	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
557458	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
557459	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
557460	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
557461	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
557462	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
557463	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
557464	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
557465	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
557466	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
557467	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Clear of Trash?	y	
557468	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
557469	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
557470	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
557471	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	Follow-up Action Required?	n	
557472	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
557473	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	General Comments		
557474	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	General Comments		
557475	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC As Found Counter	3454	
557476	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC As Left Counter	3454	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
557477	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
557478	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
557479	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	643	
557480	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	643	
557481	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
557482	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
557483	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	100.0	
557484	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
557485	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
557486	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	General Comments		
557487	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
557488	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
557489	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
557490	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	General Comments		
557491	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
557492	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	LTC Totalizer Reading	9072	kw
557493	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
557494	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
557495	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	Oil Temp Max	25	°C
557496	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
557497	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
557498	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
557499	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
557500	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
557501	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
557502	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
557503	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
557504	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
557505	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
557506	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BCH000536	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
557507	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BCH000536	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
557508	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	General Comments		
557509	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Follow-up Action Required?	n	
557510	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC Operations Since Last Insp	1384	
557511	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
557512	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
557513	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
557514	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Operations Ground	0	
557515	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
557516	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
557517	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
557518	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
557519	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
557520	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
557521	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
557522	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
557523	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Operations Counter AF	172	
557524	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Operations Counter AL	172	
557525	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	Totalizer Meter Reading	1.26	
557526	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
557527	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
557528	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
557529	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
557530	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
557531	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
557532	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
557533	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
557534	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Operations C Ø	0	
557535	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Operations B Ø	0	
557536	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Operations A Ø	0	
557537	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
557538	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
557539	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
557540	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
557541	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Moisture and Leak Free?	y	
557542	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Operations Counter AF	286	
557543	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Operations Counter AL	286	
557544	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
557545	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Follow-up Action Required?	n	
557546	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
557547	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
557548	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
557549	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
557550	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
557551	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
557552	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
557553	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	8.65	%
557554	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Follow-up Action Required?	n	
557555	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Switching Operations	0	
557556	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Tank Paint Condition	Good	
557557	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Unknown Operations	0	
557558	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Foundation Condition	Good	
557559	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	15	
557560	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	27.88	%
557561	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	23.07	%
557562	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	22.11	%
557563	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	240.0	
557564	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	230.0	
557565	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	9.61	%
557566	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	3.84	%
557567	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	80.0	
557568	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
557569	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	y	
557570	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	80.0	
557571	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	General Comments		
557572	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Unknown Operations	0	
557573	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	General Comments		
557574	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Grounds in Place?	y	
557575	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Maintenance Operations	0	
557576	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	280.0	
557577	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
557578	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
557579	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Switching Operations	0	
557580	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Operations Counter AL	213	
557581	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Operations Counter AF	213	
557582	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Maintenance Operations	0	
557583	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BCH000536	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
557584	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BCH000536	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
557585	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BCH000536	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
557586	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BCH000536	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
557587	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BCH000536	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
557588	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
557589	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
557590	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
557591	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
557592	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
557593	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
557594	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
557595	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
557596	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	Follow-up Action Required?	n	
557597	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
557598	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Accumulated Fault Duty C Ph V	3.58	%
557599	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Amps A Ø	206.0	
557600	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Amps B Ø	203.0	
557601	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Amps C Ø	205.0	
557602	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
557603	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
557604	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
557605	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Operations Counter AF	163	
557606	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Maintenance Operations	0	
557607	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	General Comments		
557608	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Follow-up Action Required?	n	
557609	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Operations Ground	0	
557610	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Operations C Ø	0	
557611	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Operations B Ø	0	
557612	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Operations A Ø	0	
557613	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
557614	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
557615	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
557616	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Amps C Ø	123.0	
557617	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Amps B Ø	109.0	
557618	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Operations A Ø	0	
557619	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Operations B Ø	0	
557620	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
557621	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
557622	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
557623	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	37	
557624	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	37	
557625	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
557626	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
557627	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Operations Ground	0	
557628	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Follow-up Action Required?	n	
557629	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	General Comments		
557630	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Maintenance Operations	0	
557631	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
557632	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Operations Counter AF	198	
557633	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Operations Counter AL	198	
557634	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Switching Operations	0	
557635	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Unknown Operations	0	
557636	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
557637	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
557638	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
557639	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
557640	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
557641	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Equipment Properly Labeled?	y	
557642	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Cabinet Paint Condition	Good	
557643	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
557644	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
557645	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
557646	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Bushings Connection/Risers	Good	
557647	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Bushing Condition	Good	
557648	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Amps C Ø	40.0	
557649	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Amps B Ø	40.0	
557650	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Amps A Ø	40.0	
557651	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
557652	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
557653	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
557654	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Amps C Ø	167.0	
557655	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Amps B Ø	164.0	
557656	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Amps A Ø	167.0	
557657	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Accumulated Fault Duty C Ph V	15.5	%
557658	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Accumulated Fault Duty B Ph V	41.14	%
557659	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
557660	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
557661	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
557662	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
557663	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
557664	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
557665	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
557666	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
557667	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	2	
557668	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	790	
557669	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	790	
557670	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
557671	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
557672	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
557673	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
557674	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
557675	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
557676	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
557677	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
557678	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
557679	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
557680	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Accumulated Fault Duty A Ph V	23.85	%
557681	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	9 Month Operations	15	
557682	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Unknown Operations	0	
557683	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Switching Operations	0	
557684	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Operations Counter AL	163	
557685	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
557686	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
557687	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BCH000496	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
557688	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
557689	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
557690	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Switching Operations	0	
557691	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Tank Paint Condition	Good	
557692	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Unknown Operations	0	
557693	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BCH000496	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
557694	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Operations Ground	0	
557695	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Operations C Ø	0	
557696	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Operations B Ø	0	
557697	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Operations A Ø	0	
557698	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
557699	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
557700	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
557701	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
557702	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
557703	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
557704	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
557705	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	9 Month Operations	0	
557706	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Accumulated Fault Duty A Ph V	4.17	%
557707	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Accumulated Fault Duty B Ph V	5.37	%
557708	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
557709	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
557710	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Accumulated Fault Duty C Ph V	5.22	%
557711	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Amps A Ø	130.0	
557712	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
557713	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Bushings Connection/Risers	Good	
557714	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Bushing Condition	Good	
557715	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
557716	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
557717	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
557718	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
557719	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
557720	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
557721	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
557722	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	50.0	
557723	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Operations C Ø	0	
557724	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Amps C Ø	650.0	
557725	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Amps B Ø	650.0	
557726	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Amps A Ø	650.0	
557727	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	50.0	
557728	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	50.0	
557729	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
557730	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
557731	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	General Comments		
557732	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
557733	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
557734	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Accumulated Fault Duty B Ph V	.82	%
557735	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Accumulated Fault Duty A Ph V	1.64	%
557736	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	9 Month Operations	2	
557737	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
557738	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	26.92	%
557739	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Operations B Ø	0	
557740	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Operations A Ø	0	
557741	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
557742	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
557743	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
557744	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Amps C Ø	0.0	
557745	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
557746	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Amps B Ø	0.0	
557747	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Amps A Ø	0.0	
557748	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Accumulated Fault Duty C Ph V	1.72	%
557749	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
557750	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
557751	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
557752	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	Oil Temp Present	32	°C
557753	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
557754	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
557755	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
557756	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
557757	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
557758	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
557759	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
557760	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
557761	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	27.88	%
557762	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	17.30	%
557763	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	200.0	
557764	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	180.0	
557765	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	200.0	
557766	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Unknown Operations	0	
557767	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Tank Paint Condition	Good	
557768	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Switching Operations	0	
557769	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Operations Counter AL	187	
557770	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Unknown Operations	0	
557771	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Vegetation	None	
557772	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
557773	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
557774	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Switching Operations	0	
557775	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Operations Counter AL	179	
557776	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Operations Counter AF	179	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
557777	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	General Comments		
557778	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
557779	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
557780	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
557781	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
557782	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
557783	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
557784	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Clear of Trash?	y	
557785	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
557786	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
557787	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
557788	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	General Comments		
557789	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
557790	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
557791	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
557792	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Operations Counter AF	187	
557793	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Moisture and Leak Free?	y	
557794	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Maintenance Operations	0	
557795	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Grounds in Place?	y	
557796	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	General Comments		
557797	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	General Comments		
557798	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Foundation Condition	Good	
557799	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Follow-up Action Required?	n	
557800	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Follow-up Action Required?	n	
557801	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
557802	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Operations Ground	0	
557803	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Operations C Ø	0	
557804	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Operations B Ø	0	
557805	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Operations A Ø	0	
557806	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
557807	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Maintenance Operations	0	
557808	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
557809	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	General Comments		
557810	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Follow-up Action Required?	n	
557811	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Operations Ground	0	
557812	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
557813	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
557814	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
557815	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
557816	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Equipment Properly Labeled?	y	
557817	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Cabinet Paint Condition	Good	
557818	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
557819	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
557820	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	9 Month Operations	6	
557821	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Accumulated Fault Duty A Ph V	7.18	%
557822	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Accumulated Fault Duty B Ph V	5.88	%
557823	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	General Comments		
557824	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Amps B Ø	680.0	
557825	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Amps C Ø	680.0	
557826	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Moisture and Leak Free?	y	
557827	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Maintenance Operations	0	
557828	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Grounds in Place?	y	
557829	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	General Comments		
557830	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	General Comments		
557831	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Foundation Condition	Good	
557832	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Follow-up Action Required?	n	
557833	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Follow-up Action Required?	n	
557834	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	General Comments		
557835	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Grounds in Place?	y	
557836	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Heaters (All) Functioning?	y	
557837	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Maintenance Operations	0	
557838	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
557839	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
557840	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1219	
557841	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1219	
557842	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
557843	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
557844	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	General Comments		
557845	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
557846	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
557847	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
557848	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
557849	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	100.0	
557850	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	100.0	
557851	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	100.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
557852	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Bushing Condition	Good	
557853	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
557854	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
557855	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
557856	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
557857	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
557858	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
557859	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
557860	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
557861	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	Follow-up Action Required?	n	
557862	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
557863	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	General Comments		
557864	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	General Comments		
557865	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC As Found Counter	52139	
557866	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC As Left Counter	52139	
557867	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
557868	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC Current Tap Position	1L	
557869	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC Max Tap Position	4R	
557870	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC Min Tap Position	10L	
557871	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
557872	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Operations A Ø	0	
557873	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Operations B Ø	0	
557874	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Operations C Ø	0	
557875	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Operations Ground	0	
557876	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	General Comments	ok	
557877	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	General Comments	cylinder at 0psi needs nitro added	
557878	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
557879	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
557880	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
557881	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
557882	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
557883	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
557884	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
557885	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
557886	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
557887	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
557888	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0339	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
557889	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
557890	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
557891	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Accumulated Fault Duty B Ph V	1.72	%
557892	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Amps B Ø	130.0	
557893	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Amps C Ø	130.0	
557894	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Bushing Condition	Good	
557895	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Bushings Connection/Risers	Good	
557896	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
557897	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
557898	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
557899	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
557900	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Cabinet Paint Condition	Good	
557901	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Equipment Properly Labeled?	y	
557902	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
557903	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	General Comments		
557904	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
557905	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
557906	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
557907	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Operations A Ø	0	
557908	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Operations B Ø	0	
557909	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Operations C Ø	0	
557910	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Operations Ground	0	
557911	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
557912	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Follow-up Action Required?	n	
557913	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Unknown Operations	0	
557914	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
557915	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	767	
557916	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	767	
557917	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
557918	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Tank Paint Condition	Good	
557919	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Switching Operations	0	
557920	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Operations Counter AL	191	
557921	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Operations Counter AF	191	
557922	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	9 Month Operations	0	
557923	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
557924	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
557925	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
557926	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Amps A Ø	680.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
557927	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Follow-up Action Required?	n	
557928	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Foundation Condition	Good	
557929	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
557930	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
557931	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
557932	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
557933	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
557934	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
557935	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
557936	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
557937	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
557938	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
557939	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
557940	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
557941	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
557942	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	30	°F
557943	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
557944	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
557945	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
557946	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	9 Month Operations	3	
557947	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Accumulated Fault Duty A Ph V	26.63	%
557948	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Accumulated Fault Duty B Ph V	26.63	%
557949	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Accumulated Fault Duty C Ph V	22.33	%
557950	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Amps A Ø	310.0	
557951	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Amps B Ø	320.0	
557952	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Amps C Ø	272.0	
557953	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
557954	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
557955	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
557956	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Operations A Ø	0	
557957	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Operations B Ø	0	
557958	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
557959	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
557960	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
557961	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
557962	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
557963	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	General Comments		
557964	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
557965	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
557966	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
557967	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
557968	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	851	
557969	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	851	
557970	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
557971	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
557972	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
557973	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
557974	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
557975	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
557976	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
557977	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
557978	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
557979	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	VRR Time Delay	30	Seconds
557980	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
557981	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
557982	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
557983	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
557984	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
557985	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Operations C Ø	0	
557986	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Operations Ground	0	
557987	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	LTCC000376	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
557988	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	LTCC000376	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
557989	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
557990	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
557991	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	352	
557992	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	352	
557993	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
557994	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
557995	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
557996	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
557997	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
557998	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
557999	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
558000	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
558001	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
558002	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
558003	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
558004	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
558005	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
558006	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
558007	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	LTCC000376	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
558008	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	LTCC000376	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
558009	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	LTCC000376	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
558010	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	LTCC000376	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
558011	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	34	°F
558012	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
558013	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
558014	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
558015	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
558016	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
558017	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
558018	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
558019	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
558020	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	63.0	
558021	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	86.0	
558022	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	82.0	
558023	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	5.32	%
558024	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	14.62	%
558025	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	2.66	%
558026	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
558027	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
558028	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
558029	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
558030	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
558031	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
558032	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
558033	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
558034	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
558035	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
558036	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
558037	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
558038	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Operations B Ø	0	
558039	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Operations C Ø	0	
558040	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Operations Ground	0	
558041	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Ambient Temperature	65	°F
558042	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
558043	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
558044	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
558045	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
558046	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
558047	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Follow-up Action Required?	n	
558048	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Foundation Condition	Good	
558049	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
558050	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	General Comments	y	
558051	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Grounds in Place?	y	
558052	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
558053	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
558054	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1539	
558055	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
558056	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
558057	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
558058	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BCH000540	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
558059	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
558060	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
558061	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
558062	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Tank Paint Condition	Good	
558063	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Follow-up Action Required?	n	
558064	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Follow-up Action Required?	n	
558065	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BCH000540	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
558066	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BCH000540	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
558067	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BCH000540	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
558068	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BCH000540	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
558069	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Foundation Condition	Good	
558070	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	General Comments		
558071	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	General Comments		
558072	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Grounds in Place?	y	
558073	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Heaters (All) Functioning?	y	
558074	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	LTCC000376	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
558075	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BCH000540	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
558076	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
558077	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
558078	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
558079	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
558080	2/25/2019 10:56	Distribution	Rogers Gap Quarterly Inspection	BCH000540	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
558081	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Unknown Operations	0	
558082	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Tank Paint Condition	Good	
558083	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Switching Operations	0	
558084	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Maintenance Operations	0	
558085	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Moisture and Leak Free?	y	
558086	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Operations Counter AF	27	
558087	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Operations Counter AL	27	
558088	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
558089	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Follow-up Action Required?	n	
558090	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	General Comments		
558091	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Maintenance Operations	0	
558092	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Operations Counter AF	396	
558093	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Operations Counter AL	396	
558094	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Switching Operations	0	
558095	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Unknown Operations	0	
558096	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
558097	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
558098	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
558099	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
558100	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
558101	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	General Comments		
558102	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
558103	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
558104	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Foundation Condition	Good	
558105	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
558106	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
558107	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
558108	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
558109	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	LTC Operation Checked?	y	
558110	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	General Comments		
558111	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	Follow-up Action Required?	n	
558112	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	All Connections OK?	y	
558113	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
558114	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
558115	2/25/2019 15:36	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
558116	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
558117	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
558118	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
558119	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	9 Month Operations	9	
558120	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Accumulated Fault Duty A Ph V	2.61	%
558121	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Accumulated Fault Duty B Ph V	3.27	%
558122	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Accumulated Fault Duty C Ph V	3.27	%
558123	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Amps A Ø	100.0	
558124	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Amps B Ø	100.0	
558125	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Amps C Ø	100.0	
558126	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Bushing Condition	Good	
558127	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Bushings Connection/Risers	Good	
558128	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
558129	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
558130	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
558131	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Cabinet Paint Condition	Good	
558132	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
558133	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
558134	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1539	
558135	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Equipment Properly Labeled?	y	
558136	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
558137	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
558138	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
558139	2/25/2019 13:42	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Operations A Ø	0	
558140	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	VRR Time Delay	30	Seconds
558141	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	9 Month Operations	3	
558142	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
558143	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
558144	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
558145	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
558146	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
558147	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
558148	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
558149	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
558150	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	9 Month Operations	5	
558151	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Accumulated Fault Duty A Ph V	7.16	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
558152	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Accumulated Fault Duty B Ph V	11.93	%
558153	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Accumulated Fault Duty C Ph V	7.75	%
558154	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Amps A Ø	40.0	
558155	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
558156	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
558157	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
558158	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
558159	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
558160	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
558161	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	34.65	%
558162	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	34.65	%
558163	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	198	
558164	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	198	
558165	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	9 Month Operations	2	
558166	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Accumulated Fault Duty A Ph V	1.72	%
558167	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
558168	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
558169	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
558170	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
558171	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
558172	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Amps B Ø	39.0	
558173	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Amps C Ø	42.0	
558174	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
558175	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
558176	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
558177	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Operations A Ø	0	
558178	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BCH000496	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
558179	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BCH000496	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
558180	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BCH000496	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
558181	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BCH000496	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
558182	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Operations B Ø	0	
558183	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Operations C Ø	0	
558184	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Operations Ground	0	
558185	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Follow-up Action Required?	n	
558186	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	General Comments		
558187	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
558188	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
558189	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	34.65	%
558190	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
558191	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Maintenance Operations	0	
558192	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Operations Counter AF	189	
558193	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Operations Counter AL	189	
558194	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Switching Operations	0	
558195	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Unknown Operations	0	
558196	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	LTC Operation Checked?	y	
558197	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
558198	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	General Comments		
558199	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	Follow-up Action Required?	n	
558200	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	All Connections OK?	y	
558201	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BB0340	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
558202	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
558203	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
558204	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
558205	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
558206	2/25/2019 12:49	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	9 Month Operations	2	
558207	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
558208	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
558209	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
558210	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
558211	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
558212	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
558213	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
558214	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	183.0	
558215	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
558216	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
558217	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Accumulated Fault Duty C Ph V	4.17	%
558218	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Accumulated Fault Duty B Ph V	4.77	%
558219	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Accumulated Fault Duty A Ph V	5.37	%
558220	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
558221	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
558222	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	LTCC000376	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
558223	2/25/2019 11:38	Distribution	Alexander Quarterly Inspection	LTCC000376	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
558224	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	192.0	
558225	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	198.0	
558226	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	2.66	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
558227	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	6.64	%
558228	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	1.33	%
558229	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
558230	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Amps A Ø	124.0	
558231	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
558232	2/25/2019 15:03	Distribution	Versailles West Quarterly Inspection	BB0229	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
558233	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	General Comments		
558234	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	LTC Operation Checked?	y	
558235	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
558236	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	Follow-up Action Required?	n	
558237	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	All Connections OK?	y	
558238	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
558239	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
558240	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	VRR Time Delay	30	Seconds
558241	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	General Comments		
558242	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Equipment Properly Labeled?	y	
558243	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Cabinet Paint Condition	Good	
558244	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Cabinet Paint Condition	Good	
558245	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
558246	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	General Comments		
558247	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Min Tap Position	8L	
558248	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Max Tap Position	3L	
558249	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
558250	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
558251	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
558252	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
558253	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
558254	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
558255	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
558256	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
558257	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
558258	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
558259	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
558260	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
558261	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
558262	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
558263	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
558264	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
558265	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Bushings Connection/Risers	Good	
558266	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Bushing Condition	Good	
558267	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	General Comments		
558268	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
558269	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
558270	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
558271	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
558272	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
558273	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
558274	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Operations Ground	0	
558275	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Operations C Ø	0	
558276	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Operations B Ø	0	
558277	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
558278	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Equipment Properly Labeled?	y	
558279	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
558280	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
558281	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
558282	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Operations A Ø	0	
558283	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
558284	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
558285	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	LTC Operation Checked?	y	
558286	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	LTC Output Voltage Level	1123.7	VAC
558287	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Follow-up Action Required?	n	
558288	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Follow-up Action Required?	n	
558289	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
558290	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BCH000546	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
558291	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BCH000546	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
558292	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
558293	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BCH000546	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
558294	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BCH000546	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
558295	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BCH000546	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
558296	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	General Comments		
558297	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
558298	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BCH000546	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
558299	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BCH000546	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
558300	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
558301	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
558302	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
558303	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
558304	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
558305	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
558306	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
558307	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
558308	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Current Tap Position	8L	
558309	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
558310	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
558311	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
558312	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
558313	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
558314	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
558315	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
558316	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Foundation Condition	Good	
558317	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
558318	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
558319	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
558320	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	General Comments		
558321	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	Follow-up Action Required?	n	
558322	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
558323	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
558324	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Foundation Condition	Good	
558325	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
558326	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
558327	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
558328	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
558329	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Amps C Ø	132.0	
558330	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
558331	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
558332	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
558333	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
558334	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
558335	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
558336	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
558337	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
558338	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
558339	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
558340	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
558341	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Panels Dusted?	y	
558342	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
558343	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
558344	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	General Comments		
558345	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
558346	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
558347	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	General Comments		
558348	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
558349	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
558350	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Floor Swept?	y	
558351	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
558352	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
558353	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Evidence of Insects	None	
558354	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
558355	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
558356	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
558357	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
558358	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
558359	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
558360	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
558361	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	229	
558362	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	229	
558363	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
558364	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
558365	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
558366	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
558367	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
558368	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
558369	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
558370	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Current Tap Position	8L	
558371	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
558372	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
558373	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Clear of Trash?	y	
558374	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
558375	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
558376	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
558377	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
558378	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
558379	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
558380	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	General Comments		
558381	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
558382	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
558383	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
558384	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
558385	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
558386	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	8.63	
558387	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
558388	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
558389	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	2	
558390	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
558391	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
558392	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	All Connections OK?	y	
558393	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
558394	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Bushings Connection/Risers	Good	
558395	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Bushing Condition	Good	
558396	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
558397	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Amps C Ø	120.0	
558398	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Amps B Ø	40.0	
558399	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
558400	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Amps A Ø	40.0	
558401	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
558402	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.57	%
558403	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	.52	%
558404	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.52	%
558405	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	150.0	
558406	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Ambient Temp	41	°F
558407	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	150.0	
558408	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	125.0	
558409	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
558410	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
558411	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
558412	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
558413	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
558414	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
558415	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Regulator As Left Counter	35665	
558416	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
558417	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
558418	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
558419	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
558420	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
558421	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Tank Leaks	None	
558422	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
558423	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Accumulated Fault Duty C Ph V	6.23	%
558424	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
558425	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Accumulated Fault Duty B Ph V	3.46	%
558426	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
558427	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Vegetation	None	
558428	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Accumulated Fault Duty A Ph V	3.46	%
558429	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
558430	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	9 Month Operations	9	
558431	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
558432	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Tank Leaks	None	
558433	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
558434	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Regulator As Left Counter	37120	
558435	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
558436	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
558437	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
558438	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
558439	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
558440	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Min Tap Position	10L	
558441	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Max Tap Position	3L	
558442	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	9 Month Operations	3	
558443	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
558444	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
558445	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
558446	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
558447	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
558448	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
558449	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
558450	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
558451	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Amps A Ø	134.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
558452	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Amps B Ø	124.0	
558453	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
558454	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	General Comments		
558455	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
558456	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
558457	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	General Comments		
558458	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	General Comments		
558459	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
558460	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
558461	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	9 Months Operations	1	
558462	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
558463	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
558464	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
558465	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
558466	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Amps A Ø	180.0	
558467	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Amps B Ø	210.0	
558468	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Amps C Ø	240.0	
558469	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
558470	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
558471	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Foundation Condition	Good	
558472	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	General Comments		
558473	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
558474	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
558475	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Operations A Ø	0	
558476	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Operations B Ø	0	
558477	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Operations C Ø	0	
558478	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
558479	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	General Comments		
558480	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Grounds in Place?	y	
558481	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Heaters (All) Functioning?	y	
558482	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Follow-up Action Required?	n	
558483	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
558484	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
558485	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
558486	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
558487	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
558488	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
558489	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
558490	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
558491	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
558492	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
558493	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
558494	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
558495	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Maintenance Operations	0	
558496	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Moisture and Leak Free?	y	
558497	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
558498	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Vegetation	None	
558499	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
558500	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
558501	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
558502	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
558503	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	General Comments		
558504	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Operations Counter AF	159	
558505	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Operations Counter AL	159	
558506	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
558507	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Switching Operations	0	
558508	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Tank Paint Condition	Good	
558509	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Unknown Operations	0	
558510	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	25.7	VDC
558511	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.700	millivolts
558512	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
558513	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Amps B Ø	50.0	
558514	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Amps C Ø	80.0	
558515	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Bushing Condition	Good	
558516	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Bushings Connection/Risers	Good	
558517	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
558518	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
558519	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
558520	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
558521	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
558522	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
558523	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
558524	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	131	
558525	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	131	
558526	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
558527	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
558528	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Operations Counter AF	445	
558529	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Operations Counter AL	445	
558530	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Switching Operations	0	
558531	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Unknown Operations	0	
558532	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
558533	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Cabinet Paint Condition	Good	
558534	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
558535	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
558536	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Equipment Properly Labeled?	y	
558537	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
558538	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
558539	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
558540	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Operations A Ø	0	
558541	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Operations B Ø	0	
558542	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Operations C Ø	0	
558543	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Operations Ground	0	
558544	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Follow-up Action Required?	n	
558545	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Follow-up Action Required?	n	
558546	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC Operations Since Last Insp	1269	
558547	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC Min Tap Position	8L	
558548	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC Max Tap Position	3R	
558549	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
558550	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
558551	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Winding Temp Present	0	°C
558552	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Winding Temp Max	0	°C
558553	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Totalizer Meter Reading	.6594	
558554	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
558555	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
558556	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
558557	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
558558	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
558559	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
558560	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC Current Tap Position	1L	
558561	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
558562	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
558563	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Oil Temp Present	30	°C
558564	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Oil Temp Max	50	°C
558565	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
558566	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
558567	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	LTC Totalizer Reading	6330.24	kw
558568	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
558569	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	216813	
558570	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	216815	
558571	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
558572	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	4L	
558573	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	8L	
558574	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	Neutral	
558575	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0	psi
558576	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	476	
558577	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
558578	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
558579	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
558580	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	BCH000971	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
558581	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	BCH000971	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.5	VDC
558582	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	BCH000971	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.5	VDC
558583	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	BCH000971	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.5	amps
558584	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	BCH000971	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
558585	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	BCH000971	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
558586	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	BCH000971	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
558587	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	BCH000971	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
558588	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
558589	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Vegetation	None	
558590	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
558591	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
558592	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
558593	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	4.15	%
558594	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.77	%
558595	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
558596	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
558597	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
558598	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
558599	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
558600	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
558601	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
558602	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
558603	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	Follow-up Action Required?	n	
558604	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	4.15	%
558605	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
558606	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
558607	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
558608	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	General Comments		
558609	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	General Comments		
558610	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC As Found Counter	437	
558611	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC As Left Counter	437	
558612	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
558613	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC Current Tap Position	5L	
558614	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
558615	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC Min Tap Position	7L	
558616	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
558617	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC Operations Since Last Insp	434	
558618	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.08	%
558619	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
558620	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
558621	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
558622	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	.69	%
558623	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.69	%
558624	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
558625	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
558626	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Clear of Trash?	y	
558627	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
558628	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
558629	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
558630	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
558631	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
558632	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
558633	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Clear of Trash?	y	
558634	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
558635	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
558636	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
558637	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
558638	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
558639	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
558640	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
558641	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
558642	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
558643	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
558644	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	General Comments		
558645	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
558646	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
558647	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
558648	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
558649	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
558650	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
558651	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
558652	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
558653	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
558654	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
558655	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
558656	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
558657	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
558658	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
558659	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
558660	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
558661	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
558662	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
558663	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
558664	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
558665	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	400	
558666	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	400	
558667	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	400	
558668	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0	%
558669	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0	%
558670	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0	%
558671	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC As Left Counter	6594	
558672	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
558673	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC As Found Counter	6594	
558674	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	General Comments		
558675	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	General Comments		
558676	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
558677	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	Follow-up Action Required?	n	
558678	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
558679	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
558680	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
558681	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments		
558682	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	General Comments		
558683	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
558684	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
558685	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
558686	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
558687	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
558688	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
558689	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
558690	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
558691	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
558692	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
558693	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
558694	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
558695	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
558696	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
558697	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
558698	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
558699	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
558700	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
558701	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
558702	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
558703	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
558704	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
558705	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
558706	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Evidence of Insects	None	
558707	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
558708	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
558709	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Floor Swept?	y	
558710	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
558711	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
558712	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	General Comments		
558713	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
558714	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Panels Dusted?	y	
558715	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
558716	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
558717	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
558718	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
558719	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
558720	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
558721	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
558722	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
558723	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
558724	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
558725	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
558726	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
558727	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
558728	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
558729	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Unknown Operations	0	
558730	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
558731	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	VRR Time Delay	30	Seconds
558732	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Switching Operations	0	
558733	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Operations Counter AL	371	
558734	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Operations Counter AF	371	
558735	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Maintenance Operations	0	
558736	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	General Comments		
558737	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Patrol Inspection	General Comments		
558738	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
558739	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
558740	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
558741	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
558742	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
558743	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
558744	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	General Comments		
558745	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
558746	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
558747	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
558748	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
558749	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
558750	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	136	
558751	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	136	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
558752	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
558753	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
558754	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
558755	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
558756	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
558757	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
558758	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
558759	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
558760	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
558761	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
558762	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
558763	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
558764	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
558765	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
558766	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
558767	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
558768	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
558769	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
558770	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
558771	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
558772	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	69	°F
558773	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
558774	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
558775	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
558776	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
558777	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
558778	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
558779	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
558780	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
558781	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
558782	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
558783	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
558784	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
558785	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
558786	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
558787	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	240	
558788	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	240	
558789	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	240	
558790	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	19.53	%
558791	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	17.47	%
558792	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	17.47	%
558793	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
558794	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	212	
558795	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
558796	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Amps B Ø	90.0	
558797	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Amps C Ø	90.0	
558798	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Bushing Condition	Good	
558799	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Bushings Connection/Risers	Good	
558800	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
558801	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
558802	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
558803	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Cabinet Paint Condition	Good	
558804	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Equipment Properly Labeled?	y	
558805	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
558806	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
558807	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
558808	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Operations A Ø	0	
558809	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Operations B Ø	0	
558810	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Operations C Ø	0	
558811	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Operations Ground	0	
558812	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	9 Months Operations	0	
558813	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Accumulated Fault Duty A Ph AM	6.40	%
558814	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Accumulated Fault Duty B Ph AM	6.40	%
558815	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Accumulated Fault Duty C Ph AM	2.13	%
558816	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Amps A Ø	25.0	
558817	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Amps B Ø	25.0	
558818	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Amps C Ø	25.0	
558819	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
558820	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
558821	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
558822	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
558823	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Operations A Ø	0	
558824	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Operations B Ø	0	
558825	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Operations C Ø	0	
558826	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
558827	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Follow-up Action Required?	n	
558828	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Foundation Condition	Good	
558829	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	General Comments		
558830	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	General Comments		
558831	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Grounds in Place?	y	
558832	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Maintenance Operations	0	
558833	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Moisture and Leak Free?	y	
558834	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Operations Counter AF	158	
558835	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Operations Counter AL	159	
558836	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Switching Operations	1	
558837	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Tank Paint Condition	Good	
558838	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Unknown Operations	0	
558839	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	9 Month Operations	2	
558840	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Operations Ground	0	
558841	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
558842	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Follow-up Action Required?	n	
558843	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Patrol Inspection	General Comments		
558844	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	General Comments		
558845	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Maintenance Operations	0	
558846	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
558847	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
558848	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
558849	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Amps A Ø	50.0	
558850	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Follow-up Action Required?	n	
558851	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
558852	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Operations Ground	0	
558853	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
558854	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	35	°C
558855	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	35	°C
558856	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	35	°C
558857	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
558858	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
558859	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
558860	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
558861	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
558862	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
558863	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
558864	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
558865	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
558866	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
558867	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
558868	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	General Comments		
558869	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
558870	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
558871	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
558872	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
558873	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
558874	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
558875	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
558876	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	Oil Temp Max	35	°C
558877	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
558878	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
558879	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
558880	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	General Comments		
558881	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
558882	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
558883	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
558884	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
558885	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
558886	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
558887	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
558888	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
558889	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
558890	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
558891	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
558892	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
558893	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
558894	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
558895	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
558896	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	25.7	VDC
558897	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	9 Month Operations	11	
558898	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Accumulated Fault Duty A Ph V	.71	%
558899	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Accumulated Fault Duty B Ph V	.47	%
558900	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Accumulated Fault Duty C Ph V	.23	%
558901	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Amps A Ø	90.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
558902	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
558903	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
558904	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
558905	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
558906	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	212	
558907	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	LTC Totalizer Reading	6272.64	kw
558908	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
558909	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	General Comments		
558910	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	General Comments		
558911	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
558912	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
558913	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	Follow-up Action Required?	n	
558914	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
558915	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
558916	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
558917	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
558918	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
558919	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
558920	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
558921	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
558922	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
558923	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
558924	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
558925	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
558926	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
558927	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	6	
558928	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	BCH000329	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
558929	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	BCH000329	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	0	VDC
558930	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	BCH000329	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	0	VDC
558931	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	BCH000329	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	0	amps
558932	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	BCH000329	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
558933	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	BCH000329	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
558934	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
558935	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
558936	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
558937	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
558938	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	99941	
558939	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	99941	
558940	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
558941	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
558942	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
558943	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
558944	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
558945	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
558946	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
558947	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
558948	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
558949	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
558950	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
558951	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	Follow-up Action Required?	n	
558952	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	All Connections OK?	y	
558953	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	Follow-up Action Required?	n	
558954	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	General Comments		
558955	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	LTC Operation Checked?	y	
558956	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
558957	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
558958	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
558959	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	VRR Base Voltage AF	124	VAC
558960	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	VRR Base Voltage AL	124	VAC
558961	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	VRR Time Delay	30	Seconds
558962	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
558963	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
558964	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
558965	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
558966	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
558967	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
558968	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
558969	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
558970	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
558971	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
558972	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
558973	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
558974	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
558975	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
558976	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	19	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
558977	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
558978	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	821	
558979	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	844	
558980	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
558981	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
558982	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
558983	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
558984	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
558985	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
558986	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
558987	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
558988	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
558989	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Readings	Oil Temp Present	15	°C
558990	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Readings	Oil Temp Max	25	°C
558991	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
558992	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
558993	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
558994	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Readings	General Comments		
558995	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
558996	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
558997	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
558998	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
558999	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
559000	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
559001	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
559002	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
559003	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
559004	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
559005	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
559006	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
559007	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
559008	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
559009	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
559010	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	Totalizer Meter Reading	.8712	
559011	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
559012	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
559013	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
559014	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
559015	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
559016	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
559017	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
559018	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
559019	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
559020	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	Oil Temp Present	40	°C
559021	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	Oil Temp Max	65	°C
559022	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.2	psi
559023	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
559024	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
559025	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BCH000494	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
559026	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BCH000494	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
559027	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BCH000494	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
559028	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BCH000494	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
559029	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BCH000494	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
559030	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
559031	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	246	
559032	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	241	
559033	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
559034	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
559035	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
559036	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
559037	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
559038	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
559039	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
559040	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
559041	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
559042	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
559043	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
559044	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
559045	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BCH000494	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC
559046	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
559047	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
559048	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BCH000494	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
559049	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
559050	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
559051	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Fans Operational?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
559052	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
559053	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Follow-up Action Required?	n	
559054	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
559055	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
559056	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
559057	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
559058	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
559059	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10	
559060	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10	
559061	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10	
559062	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	8.22	%
559063	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	9.25	%
559064	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	7.19	%
559065	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
559066	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	General Comments		
559067	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
559068	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
559069	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	General Comments		
559070	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
559071	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	LTC Totalizer Reading	13208.4	kw
559072	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
559073	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
559074	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Oil Temp Max	80	°C
559075	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
559076	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
559077	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
559078	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
559079	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
559080	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Unknown Operations	0	
559081	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Tank Paint Condition	Good	
559082	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
559083	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
559084	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
559085	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
559086	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
559087	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
559088	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
559089	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
559090	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
559091	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
559092	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
559093	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
559094	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
559095	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
559096	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	General Comments		
559097	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	General Comments		
559098	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
559099	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
559100	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	LTC Totalizer Reading	7240.32	kw
559101	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
559102	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
559103	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	Oil Temp Max	50	°C
559104	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
559105	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
559106	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
559107	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
559108	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
559109	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
559110	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
559111	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
559112	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
559113	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	Oil Temp Present	15	°C
559114	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
559115	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
559116	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
559117	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
559118	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
559119	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
559120	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
559121	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
559122	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
559123	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
559124	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
559125	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
559126	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
559127	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
559128	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
559129	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
559130	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	All Connections OK?	y	
559131	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Bushing Condition	Good	
559132	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
559133	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
559134	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
559135	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
559136	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
559137	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
559138	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
559139	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
559140	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
559141	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
559142	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
559143	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
559144	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
559145	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
559146	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
559147	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
559148	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
559149	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	General Comments		
559150	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
559151	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
559152	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
559153	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
559154	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
559155	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	General Comments		
559156	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
559157	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Foundation Condition	Good	
559158	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
559159	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
559160	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
559161	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
559162	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
559163	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
559164	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
559165	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
559166	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
559167	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Vegetation	None	
559168	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
559169	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
559170	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	General Comments		
559171	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
559172	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
559173	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
559174	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
559175	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
559176	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Clear of Trash?	y	
559177	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
559178	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
559179	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
559180	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
559181	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
559182	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
559183	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
559184	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
559185	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
559186	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
559187	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
559188	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
559189	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
559190	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
559191	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
559192	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	General Comments		
559193	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
559194	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
559195	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
559196	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
559197	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
559198	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
559199	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
559200	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
559201	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
559202	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
559203	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC As Found Counter	334730	
559204	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC As Left Counter	334730	
559205	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
559206	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
559207	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5L	
559208	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
559209	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	134	
559210	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
559211	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
559212	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
559213	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
559214	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
559215	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
559216	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	General Comments		
559217	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
559218	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
559219	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
559220	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
559221	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
559222	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
559223	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
559224	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
559225	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
559226	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
559227	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
559228	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
559229	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
559230	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
559231	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
559232	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
559233	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
559234	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
559235	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
559236	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
559237	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
559238	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Clear of Trash?	y	
559239	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
559240	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	General Comments		
559241	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
559242	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
559243	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Vegetation	None	
559244	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
559245	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Ambient Temp	41	°F
559246	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
559247	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	General Comments		
559248	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
559249	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
559250	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
559251	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
559252	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
559253	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
559254	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
559255	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
559256	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
559257	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
559258	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Accumulated Fault Duty A Ph AM	5.34	%
559259	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
559260	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
559261	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
559262	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
559263	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
559264	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Amps A Ø	160.0	
559265	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Amps B Ø	210.0	
559266	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Amps C Ø	210.0	
559267	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
559268	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Battery 1 Pre-test Volts	12.6	VDC
559269	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
559270	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
559271	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
559272	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Adjusted Amps A Phase AM	9.55	
559273	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
559274	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
559275	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Operations A Ø	1	
559276	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
559277	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Operations C Ø	0	
559278	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Operations Ground	0	
559279	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
559280	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Follow-up Action Required?	y	
559281	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Patrol Inspection	General Comments		
559282	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	General Comments	VC did not change, counter needs to be checked.	
559283	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
559284	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Maintenance Operations	0	
559285	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Operations Counter AF	522	
559286	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Operations Counter AL	522	
559287	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Switching Operations	0	
559288	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Unknown Operations	0	
559289	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
559290	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
559291	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
559292	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
559293	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
559294	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
559295	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	25.0	
559296	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
559297	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
559298	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
559299	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
559300	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
559301	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
559302	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
559303	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
559304	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
559305	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
559306	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
559307	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
559308	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
559309	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
559310	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
559311	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
559312	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
559313	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
559314	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
559315	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
559316	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
559317	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Amps C Ø	200.0	
559318	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Amps B Ø	160.0	
559319	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
559320	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Amps A Ø	190.0	
559321	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Accumulated Fault Duty C Ph AM	2.13	%
559322	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Accumulated Fault Duty B Ph AM	2.13	%
559323	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Accumulated Fault Duty A Ph AM	2.13	%
559324	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	9 Months Operations	0	
559325	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
559326	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
559327	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Unknown Operations	0	
559328	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Tank Paint Condition	Good	
559329	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Switching Operations	6	
559330	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Operations Counter AL	370	
559331	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
559332	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
559333	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Operations Counter AF	370	
559334	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Moisture and Leak Free?	y	
559335	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Maintenance Operations	0	
559336	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Grounds in Place?	y	
559337	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	General Comments		
559338	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	General Comments		
559339	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Foundation Condition	Good	
559340	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Follow-up Action Required?	n	
559341	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Follow-up Action Required?	n	
559342	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Operations Ground	0	
559343	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Operations C Ø	0	
559344	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Operations B Ø	0	
559345	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Operations A Ø	0	
559346	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
559347	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
559348	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
559349	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Equipment Properly Labeled?	y	
559350	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Cabinet Paint Condition	Good	
559351	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
559352	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
559353	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
559354	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Bushings Connection/Risers	Good	
559355	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
559356	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	27	
559357	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
559358	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.75	%
559359	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.88	%
559360	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
559361	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Bushing Condition	Good	
559362	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Amps C Ø	0.0	
559363	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Amps B Ø	0.0	
559364	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Amps A Ø	0.0	
559365	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
559366	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
559367	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
559368	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	9 Month Operations	13	
559369	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
559370	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Battery 2 Pre-test Volts	12.5	VDC
559371	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Battery 2 Post-test Volts	13.8	VDC
559372	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Battery 2 Load Test Volts	10.4	VDC
559373	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Battery 1 Post-test Volts	13.8	VDC
559374	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Battery 1 Load Test Volts	10.6	VDC
559375	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	9 Months Operations	2	
559376	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
559377	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
559378	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
559379	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
559380	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
559381	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
559382	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
559383	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
559384	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
559385	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
559386	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
559387	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
559388	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
559389	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
559390	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
559391	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
559392	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
559393	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
559394	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	General Comments		
559395	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC As Left Counter	18429	
559396	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC As Found Counter	18429	
559397	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	General Comments		
559398	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	General Comments		
559399	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
559400	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	Follow-up Action Required?	n	
559401	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
559402	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Max Tap Position	3L	
559403	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Min Tap Position	9L	
559404	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
559405	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
559406	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
559407	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
559408	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
559409	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Regulator As Left Counter	36050	
559410	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
559411	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Tank Leaks	None	
559412	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
559413	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
559414	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
559415	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
559416	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
559417	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
559418	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
559419	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
559420	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
559421	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
559422	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
559423	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
559424	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
559425	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
559426	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
559427	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
559428	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
559429	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
559430	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
559431	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
559432	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
559433	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
559434	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
559435	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Operations Ground	0	
559436	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Operations C Ø	0	
559437	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Operations B Ø	0	
559438	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
559439	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Operations A Ø	0	
559440	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Operations B Ø	0	
559441	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Operations C Ø	0	
559442	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Operations Ground	0	
559443	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Follow-up Action Required?	n	
559444	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Follow-up Action Required?	n	
559445	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Foundation Condition	Good	
559446	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
559447	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
559448	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
559449	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Totalizer Meter Reading	.7338	
559450	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Winding Temp Max	35	°C
559451	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
559452	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
559453	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
559454	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
559455	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
559456	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
559457	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
559458	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
559459	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
559460	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
559461	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Operations A Ø	0	
559462	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
559463	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
559464	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
559465	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
559466	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	General Comments		
559467	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
559468	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC As Found Counter	483515	
559469	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC As Left Counter	483515	
559470	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
559471	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
559472	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6L	
559473	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
559474	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
559475	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	904	
559476	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
559477	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
559478	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
559479	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
559480	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
559481	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
559482	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
559483	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
559484	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
559485	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
559486	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
559487	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
559488	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
559489	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
559490	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
559491	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
559492	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Current Tap Position	8L	
559493	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
559494	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
559495	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Tank Paint Condition	Good	
559496	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Switching Operations	1	
559497	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Amps B Ø	25.0	
559498	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Amps C Ø	100.0	
559499	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
559500	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
559501	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
559502	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
559503	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Operations A Ø	0	
559504	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Operations B Ø	0	
559505	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
559506	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Operations Counter AL	503	
559507	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Operations C Ø	0	
559508	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Operations Ground	0	
559509	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
559510	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Follow-up Action Required?	n	
559511	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Patrol Inspection	General Comments		
559512	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Operations Counter AF	503	
559513	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	General Comments		
559514	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Maintenance Operations	0	
559515	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Operations Counter AF	411	
559516	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Operations Counter AL	411	
559517	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Moisture and Leak Free?	y	
559518	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Switching Operations	0	
559519	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
559520	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
559521	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
559522	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
559523	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
559524	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
559525	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
559526	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
559527	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
559528	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	General Comments		
559529	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
559530	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
559531	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
559532	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
559533	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
559534	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
559535	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
559536	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
559537	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
559538	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
559539	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
559540	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
559541	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	562	
559542	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	562	
559543	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
559544	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
559545	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
559546	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
559547	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
559548	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
559549	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
559550	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Unknown Operations	0	
559551	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Maintenance Operations	0	
559552	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Heaters (All) Functioning?	y	
559553	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Grounds in Place?	y	
559554	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	General Comments		
559555	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
559556	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
559557	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Foundation Condition	Good	
559558	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
559559	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
559560	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
559561	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
559562	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
559563	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
559564	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
559565	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	44	°F
559566	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
559567	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
559568	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
559569	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Winding Temp Present	25	°C
559570	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20	
559571	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	200	
559572	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	General Comments		
559573	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	General Comments		
559574	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Grounds in Place?	y	
559575	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Heaters (All) Functioning?	y	
559576	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
559577	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Moisture and Leak Free?	y	
559578	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Operations Counter AF	165	
559579	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Operations Counter AL	166	
559580	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
559581	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	110.0	
559582	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	110.0	
559583	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	110.0	
559584	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
559585	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	.88	%
559586	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.88	%
559587	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	23	
559588	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Switching Operations	1	
559589	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Tank Paint Condition	Good	
559590	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Unknown Operations	0	
559591	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Unknown Operations	0	
559592	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
559593	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	9 Months Operations	0	
559594	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
559595	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
559596	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
559597	2/22/2019 8:47	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Amps A Ø	120.0	
559598	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	8.22	%
559599	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	12.33	%
559600	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	7.19	%
559601	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	80	
559602	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120	
559603	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10	
559604	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
559605	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
559606	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
559607	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
559608	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
559609	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
559610	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
559611	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
559612	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
559613	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	CB0231	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
559614	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
559615	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Warning Signs OK?	y	
559616	2/22/2019 14:29	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
559617	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
559618	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
559619	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
559620	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
559621	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
559622	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
559623	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
559624	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
559625	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
559626	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
559627	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
559628	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
559629	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
559630	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
559631	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
559632	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
559633	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
559634	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Oil Temp Present	30	°C
559635	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
559636	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
559637	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
559638	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
559639	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
559640	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
559641	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
559642	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99986	
559643	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	999896	
559644	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
559645	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
559646	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
559647	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
559648	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
559649	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC Operations Since Last Insp	1466	
559650	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
559651	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC Min Tap Position	16R	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
559652	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	6	
559653	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
559654	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	165	
559655	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	146	
559656	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
559657	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	13	
559658	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
559659	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
559660	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	7	
559661	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	15.28	%
559662	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	9 Months Operations	0	
559663	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
559664	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
559665	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
559666	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
559667	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
559668	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	Totalizer Meter Reading	.7542	
559669	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
559670	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
559671	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Switching Operations	1	
559672	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Operations Counter AL	180	
559673	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
559674	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Operations Counter AF	179	
559675	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Moisture and Leak Free?	y	
559676	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	General Comments		
559677	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	General Comments		
559678	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
559679	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
559680	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
559681	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
559682	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
559683	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	6713.28	kw
559684	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
559685	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
559686	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
559687	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
559688	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
559689	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
559690	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
559691	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
559692	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
559693	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Top Oil Temperature Max	22	°C
559694	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
559695	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Capacitor Condition	Good	
559696	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
559697	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Top Oil Temperature Present	16	°C
559698	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
559699	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Totalizer Meter Reading	.9324	
559700	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Winding Temp Max	32	°C
559701	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Winding Temp Present	26	°C
559702	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
559703	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	3.06	%
559704	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	3.06	%
559705	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	3.06	%
559706	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
559707	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Follow-up Action Required?	n	
559708	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
559709	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
559710	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Foundation Condition	Good	
559711	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
559712	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
559713	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	General Comments		
559714	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Grounds in Place?	y	
559715	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
559716	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
559717	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Tank Leaks	None	
559718	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	15.28	%
559719	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
559720	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
559721	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
559722	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
559723	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
559724	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
559725	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
559726	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
559727	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
559728	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
559729	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
559730	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
559731	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
559732	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
559733	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	620	
559734	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	624	
559735	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	4	
559736	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
559737	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
559738	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
559739	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
559740	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
559741	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
559742	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Operations A Ø	0	
559743	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Operations B Ø	0	
559744	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Operations C Ø	0	
559745	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Operations Ground	0	
559746	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
559747	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Follow-up Action Required?	n	
559748	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Patrol Inspection	General Comments		
559749	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	General Comments		
559750	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
559751	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Maintenance Operations	0	
559752	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Operations Counter AF	376	
559753	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Operations Counter AL	376	
559754	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Switching Operations	0	
559755	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Unknown Operations	0	
559756	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
559757	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
559758	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
559759	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
559760	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Maintenance Operations	0	
559761	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Heaters (All) Functioning?	y	
559762	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Grounds in Place?	y	
559763	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	General Comments		
559764	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	General Comments		
559765	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	All Connections OK?	y	
559766	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	Follow-up Action Required?	n	
559767	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	General Comments		
559768	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	LTC Operation Checked?	y	
559769	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
559770	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
559771	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
559772	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	VRR Time Delay	30	Seconds
559773	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Foundation Condition	Good	
559774	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Follow-up Action Required?	n	
559775	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Follow-up Action Required?	n	
559776	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Operations C Ø	0	
559777	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Cabinet Paint Condition	Good	
559778	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Operations Ground	0	
559779	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
559780	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Amps B Ø	115.0	
559781	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Follow-up Action Required?	n	
559782	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Patrol Inspection	General Comments		
559783	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Equipment Properly Labeled?	y	
559784	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
559785	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	General Comments		
559786	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
559787	2/22/2019 13:40	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC Current Tap Position	8R	
559788	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Operations B Ø	0	
559789	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Maintenance Operations	0	
559790	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Amps C Ø	120.0	
559791	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Operations A Ø	0	
559792	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
559793	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Operations Counter AF	217	
559794	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Operations Counter AL	217	
559795	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
559796	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Switching Operations	0	
559797	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Unknown Operations	0	
559798	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
559799	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
559800	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
559801	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
559802	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Amps A Ø	110.0	
559803	2/22/2019 10:40	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
559804	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
559805	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Accumulated Fault Duty B Ph V	.81	%
559806	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	15.28	%
559807	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
559808	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Accumulated Fault Duty A Ph V	.41	%
559809	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	9 Month Operations	3	
559810	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Amps C Ø	120.0	
559811	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Amps B Ø	200.0	
559812	2/22/2019 10:15	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Amps A Ø	240.0	
559813	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Bushings Connection/Risers	Good	
559814	2/22/2019 12:10	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Bushing Condition	Good	
559815	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
559816	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Top Oil Temperature Present	20	°C
559817	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
559818	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Totalizer Meter Reading	1.2250	
559819	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Top Oil Temperature Max	60	°C
559820	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Operations Counter AL	286	
559821	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
559822	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Winding Temp Max	60	°C
559823	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
559824	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
559825	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Switching Operations	1	
559826	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
559827	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Operations Ground	0	
559828	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Operations C Ø	0	
559829	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Yard Lights Working?	n	
559830	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Vegetation	None	
559831	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
559832	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
559833	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Amps C Ø	0.0	
559834	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Amps B Ø	0.0	
559835	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Operations B Ø	0	
559836	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Operations A Ø	0	
559837	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Landscape Good Condition?	y	
559838	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	General Comments	All lights out, 4 110V incandecent fixtures with one bulb broke in socket. 3 ballasted fixtures out(250w-400w) need to be replaced. 1 c	
559839	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Follow-up Action Required?	y	
559840	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Follow-up Action Required?	n	
559841	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Foundation Condition	Good	
559842	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Operations Counter AF	285	
559843	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
559844	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	General Comments		
559845	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	General Comments		
559846	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Grounds in Place?	y	
559847	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Heaters (All) Functioning?	y	
559848	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Maintenance Operations	0	
559849	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Follow-up Action Required?	n	
559850	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
559851	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
559852	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Maintenance Operations	0	
559853	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
559854	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
559855	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	General Comments		
559856	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	General Comments		
559857	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
559858	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Follow-up Action Required?	n	
559859	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
559860	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Moisture and Leak Free?	y	
559861	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
559862	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Operations Counter AF	424	
559863	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Operations Counter AL	430	
559864	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
559865	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Amps A Ø	0.0	
559866	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
559867	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
559868	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
559869	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
559870	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
559871	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
559872	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Switching Operations	6	
559873	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Tank Paint Condition	Good	
559874	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Unknown Operations	0	
559875	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Unknown Operations	0	
559876	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	9 Month Operations	3	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
559877	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
559878	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
559879	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
559880	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Winding Temp Present	45	°C
559881	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Oil Temp Max	0	°C
559882	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Oil Temp Present	20	°C
559883	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
559884	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
559885	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
559886	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
559887	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
559888	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
559889	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
559890	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.5124	
559891	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
559892	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	none	
559893	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
559894	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1013	
559895	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1013	
559896	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
559897	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
559898	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
559899	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
559900	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
559901	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
559902	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
559903	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
559904	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
559905	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	General Comments		
559906	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Readings	General Comments	Max hand broke	
559907	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
559908	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
559909	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
559910	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
559911	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Readings	Oil Temp Max	0	°C
559912	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Readings	Oil Temp Present	20	°C
559913	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
559914	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
559915	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
559916	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
559917	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
559918	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
559919	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	9 Month Operations	5	
559920	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Accumulated Fault Duty A Ph V	1.70	%
559921	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Accumulated Fault Duty B Ph V	1.70	%
559922	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Accumulated Fault Duty C Ph V	.68	%
559923	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Amps A Ø	81.0	
559924	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Amps B Ø	121.0	
559925	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Amps C Ø	64.0	
559926	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Bushing Condition	Good	
559927	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Bushings Connection/Risers	Good	
559928	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
559929	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
559930	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Door Alarms OK?	y	
559931	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
559932	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
559933	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Evidence of Insects	None	
559934	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
559935	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
559936	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Follow-up Action Required?	n	
559937	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
559938	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	General Comments		
559939	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
559940	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
559941	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Panel Lights OK?	y	
559942	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Panels Dusted?	y	
559943	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
559944	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
559945	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
559946	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Vent Fans OK?	y	
559947	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
559948	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	5	
559949	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
559950	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
559951	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
559952	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
559953	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
559954	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
559955	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
559956	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
559957	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
559958	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
559959	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
559960	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
559961	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
559962	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
559963	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
559964	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
559965	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
559966	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
559967	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
559968	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
559969	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
559970	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
559971	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
559972	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	General Comments		
559973	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	General Comments	Max temp broke	
559974	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
559975	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
559976	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	614.88	kw
559977	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
559978	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
559979	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	General Comments		
559980	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
559981	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
559982	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
559983	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
559984	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
559985	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
559986	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Clear of Trash?	y	
559987	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
559988	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
559989	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
559990	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
559991	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
559992	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
559993	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
559994	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
559995	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
559996	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
559997	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
559998	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
559999	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
560000	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
560001	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
560002	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
560003	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
560004	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
560005	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	General Comments		
560006	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
560007	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
560008	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Foundation Condition	Good	
560009	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
560010	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
560011	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
560012	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
560013	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
560014	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
560015	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
560016	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	General Comments		
560017	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
560018	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
560019	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
560020	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
560021	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
560022	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
560023	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
560024	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
560025	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
560026	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
560027	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
560028	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
560029	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Cabinet Paint Condition	Good	
560030	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Equipment Properly Labeled?	y	
560031	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
560032	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
560033	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
560034	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Operations A Ø	0	
560035	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Operations B Ø	0	
560036	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Operations C Ø	0	
560037	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Operations Ground	0	
560038	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Follow-up Action Required?	n	
560039	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Follow-up Action Required?	n	
560040	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Foundation Condition	Good	
560041	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	General Comments		
560042	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	General Comments		
560043	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Grounds in Place?	y	
560044	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Heaters (All) Functioning?	y	
560045	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
560046	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
560047	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
560048	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
560049	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
560050	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
560051	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
560052	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	General Comments		
560053	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	General Comments		
560054	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
560055	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
560056	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
560057	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
560058	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	Oil Temp Max	45	°C
560059	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	Oil Temp Present	20	°C
560060	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
560061	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
560062	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
560063	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
560064	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
560065	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
560066	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Maintenance Operations	0	
560067	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Moisture and Leak Free?	y	
560068	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Operations Counter AF	283	
560069	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Operations Counter AL	284	
560070	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
560071	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Switching Operations	1	
560072	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Tank Paint Condition	Good	
560073	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Unknown Operations	0	
560074	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
560075	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Vegetation	None	
560076	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
560077	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Follow-up Action Required?	n	
560078	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Foundation Condition	Good	
560079	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	General Comments		
560080	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	General Comments		
560081	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Grounds in Place?	y	
560082	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
560083	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Maintenance Operations	0	
560084	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
560085	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Operations Counter AF	238	
560086	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Operations Counter AL	241	
560087	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Switching Operations	3	
560088	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Tank Paint Condition	Good	
560089	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Unknown Operations	0	
560090	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	9 Month Operations	2	
560091	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
560092	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
560093	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
560094	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Amps A Ø	340.0	
560095	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Amps B Ø	340.0	
560096	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Amps C Ø	340.0	
560097	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Bushing Condition	Good	
560098	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
560099	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
560100	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
560101	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
560102	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
560103	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
560104	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
560105	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
560106	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
560107	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Operations A Ø	0	
560108	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Operations B Ø	0	
560109	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Operations C Ø	0	
560110	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Operations Ground	0	
560111	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Follow-up Action Required?	n	
560112	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Follow-up Action Required?	n	
560113	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Foundation Condition	Good	
560114	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	General Comments		
560115	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	General Comments		
560116	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Grounds in Place?	y	
560117	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
560118	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Maintenance Operations	0	
560119	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
560120	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Operations Counter AF	245	
560121	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	All Connections OK?	y	
560122	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	Follow-up Action Required?	n	
560123	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	General Comments		
560124	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	LTC Operation Checked?	y	
560125	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
560126	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
560127	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
560128	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
560129	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
560130	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
560131	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
560132	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
560133	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Amps A Ø	300.0	
560134	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Amps B Ø	300.0	
560135	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Amps C Ø	300.0	
560136	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Bushing Condition	Good	
560137	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
560138	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
560139	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
560140	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
560141	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
560142	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
560143	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
560144	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
560145	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	LTC Totalizer Reading	17640.00	kw
560146	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
560147	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	General Comments		
560148	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	General Comments		
560149	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
560150	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCControl	647-1	LTC Control Insp	All Connections OK?	y	
560151	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCControl	647-1	LTC Control Insp	Follow-up Action Required?	n	
560152	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCControl	647-1	LTC Control Insp	General Comments		
560153	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCControl	647-1	LTC Control Insp	LTC Operation Checked?	y	
560154	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCControl	647-1	LTC Control Insp	LTC Output Voltage Level	125.1	VAC
560155	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
560156	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
560157	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
560158	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	9 Month Operations	3	
560159	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
560160	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
560161	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Follow-up Action Required?	n	
560162	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Operations A Ø	0	
560163	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Operations B Ø	0	
560164	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCControl	647-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
560165	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCControl	647-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
560166	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCControl	647-1	LTC Control Insp	VRR Time Delay	30	Seconds
560167	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
560168	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
560169	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
560170	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
560171	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
560172	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Operations C Ø	0	
560173	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Operations Ground	0	
560174	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Follow-up Action Required?	n	
560175	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Fault Operations A Ø	0	
560176	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
560177	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
560178	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
560179	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Equipment Properly Labeled?	y	
560180	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Cabinet Paint Condition	Good	
560181	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
560182	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
560183	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
560184	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Bushings Connection/Risers	Good	
560185	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Bushing Condition	Good	
560186	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Amps C Ø	70.0	
560187	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Amps B Ø	35.0	
560188	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Amps A Ø	34.0	
560189	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Accumulated Fault Duty C Ph V	.35	%
560190	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Accumulated Fault Duty B Ph V	.35	%
560191	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Accumulated Fault Duty A Ph V	.35	%
560192	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	9 Month Operations	5	
560193	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Steel Structures Rust Free?	y	
560194	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Site Service Trans Condition	OK	
560195	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
560196	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Operating Linkage OK?	y	
560197	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
560198	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Linkage Grounds in Place?	y	
560199	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
560200	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
560201	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	General Comments		
560202	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
560203	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Foundation Condition	Good	
560204	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
560205	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
560206	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
560207	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
560208	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
560209	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BCH000780	Charger	514-Battery Charger	Battery Charger Patrol Insp	General Comments		
560210	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BCH000780	Charger	514-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
560211	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BCH000780	Charger	514-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
560212	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BCH000780	Charger	514-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
560213	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
560214	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
560215	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
560216	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
560217	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
560218	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
560219	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
560220	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
560221	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
560222	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
560223	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
560224	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Operations Counter AL	246	
560225	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Switching Operations	2	
560226	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
560227	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
560228	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
560229	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Clear of Trash?	y	
560230	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
560231	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
560232	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
560233	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
560234	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
560235	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
560236	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	General Comments		
560237	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
560238	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
560239	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
560240	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Vegetation	None	
560241	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
560242	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Tank Paint Condition	Good	
560243	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Unknown Operations	0	
560244	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
560245	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
560246	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	VRR Time Delay	30	Seconds
560247	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
560248	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
560249	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
560250	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
560251	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
560252	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
560253	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
560254	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	PF000431	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
560255	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	PF000431	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	General Comments	none	
560256	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Unknown Operations	0	
560257	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Tank Paint Condition	Good	
560258	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Switching Operations	0	
560259	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Operations Counter AL	199	
560260	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Operations Counter AF	198	
560261	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Moisture and Leak Free?	y	
560262	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Maintenance Operations	1	
560263	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Heaters (All) Functioning?	y	
560264	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Grounds in Place?	y	
560265	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	General Comments		
560266	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	General Comments		
560267	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Foundation Condition	Good	
560268	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Follow-up Action Required?	n	
560269	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Follow-up Action Required?	n	
560270	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Fault Operations Ground	0	
560271	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Fault Operations C Ø	0	
560272	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Fault Operations B Ø	0	
560273	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
560274	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	General Comments		
560275	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Accumulated Fault Duty C Ph V	6.25	%
560276	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Accumulated Fault Duty B Ph V	5.81	%
560277	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Accumulated Fault Duty A Ph V	6.25	%
560278	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC Operations Since Last Insp	20543	
560279	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
560280	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
560281	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
560282	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
560283	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
560284	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
560285	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Vegetation	None	
560286	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
560287	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
560288	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
560289	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
560290	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
560291	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
560292	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
560293	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
560294	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
560295	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
560296	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
560297	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
560298	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
560299	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
560300	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
560301	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
560302	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
560303	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
560304	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
560305	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
560306	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
560307	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
560308	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
560309	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
560310	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
560311	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
560312	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
560313	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
560314	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
560315	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
560316	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
560317	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Amps B Ø	150.0	
560318	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Amps A Ø	150.0	
560319	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Moisture and Leak Free?	y	
560320	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
560321	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
560322	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
560323	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
560324	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
560325	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
560326	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
560327	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
560328	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
560329	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
560330	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
560331	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
560332	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
560333	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
560334	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	General Comments		
560335	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
560336	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
560337	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
560338	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
560339	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC Operations Since Last Insp	1105	
560340	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	15	°C
560341	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC Min Tap Position	15L	
560342	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC Max Tap Position	6L	
560343	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
560344	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
560345	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
560346	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Clear of Trash?	y	
560347	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
560348	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
560349	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
560350	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
560351	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
560352	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Operations Counter AF	290	
560353	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Operations Counter AL	290	
560354	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
560355	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Switching Operations	2	
560356	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Tank Paint Condition	Good	
560357	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Unknown Operations	0	
560358	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC Current Tap Position	7L	
560359	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	PF000430	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
560360	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	PF000430	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	General Comments	none	
560361	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
560362	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
560363	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
560364	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
560365	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
560366	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
560367	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
560368	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
560369	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
560370	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
560371	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
560372	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
560373	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
560374	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
560375	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	General Comments		
560376	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
560377	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
560378	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
560379	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
560380	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
560381	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
560382	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
560383	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
560384	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
560385	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
560386	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
560387	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
560388	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
560389	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
560390	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
560391	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
560392	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Unknown Operations	0	
560393	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Tank Paint Condition	Good	
560394	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Switching Operations	2	
560395	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Operations Counter AL	305	
560396	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Operations Counter AF	305	
560397	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Moisture and Leak Free?	y	
560398	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
560399	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Foundation Condition	Good	
560400	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
560401	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
560402	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	General Comments		
560403	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
560404	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
560405	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
560406	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
560407	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC As Left Counter	53246	
560408	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC As Found Counter	53246	
560409	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	General Comments		
560410	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	General Comments		
560411	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
560412	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	Follow-up Action Required?	n	
560413	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Foundation Condition	Good	
560414	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
560415	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
560416	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	General Comments		
560417	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
560418	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
560419	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
560420	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	General Comments		
560421	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
560422	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
560423	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
560424	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
560425	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
560426	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
560427	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
560428	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
560429	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Winding Temp Present	21	°C
560430	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Winding Temp Max	28	°C
560431	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
560432	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
560433	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
560434	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
560435	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
560436	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
560437	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
560438	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
560439	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Totalizer Meter Reading	.8772	
560440	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
560441	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
560442	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
560443	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
560444	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	9 Month Operations	5	
560445	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
560446	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	43	°F
560447	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
560448	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
560449	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
560450	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Operations A Ø	0	
560451	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Operations B Ø	0	
560452	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Operations C Ø	0	
560453	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Operations Ground	0	
560454	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Follow-up Action Required?	n	
560455	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Follow-up Action Required?	n	
560456	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Foundation Condition	Good	
560457	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	General Comments		
560458	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	General Comments		
560459	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	General Comments		
560460	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	General Comments		
560461	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC As Found Counter	42636	
560462	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
560463	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
560464	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	9 Month Operations	5	
560465	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
560466	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
560467	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
560468	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Amps A Ø	100.0	
560469	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Amps B Ø	100.0	
560470	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Amps C Ø	100.0	
560471	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Bushing Condition	Good	
560472	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Bushings Connection/Risers	Good	
560473	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
560474	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
560475	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
560476	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
560477	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Equipment Properly Labeled?	y	
560478	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
560479	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
560480	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
560481	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
560482	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
560483	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
560484	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
560485	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Grounds in Place?	y	
560486	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Heaters (All) Functioning?	y	
560487	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Maintenance Operations	0	
560488	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Moisture and Leak Free?	y	
560489	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Operations Counter AF	292	
560490	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Operations Counter AL	295	
560491	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Switching Operations	3	
560492	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Tank Paint Condition	Good	
560493	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
560494	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
560495	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
560496	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
560497	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC Current Tap Position	6L	
560498	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
560499	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC As Left Counter	623249	
560500	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC As Found Counter	623249	
560501	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	Wrong serial number in cascade	
560502	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	y	
560503	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
560504	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
560505	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Tank Leaks	None	
560506	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
560507	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Regulator As Left Counter	254343	
560508	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Equipment Properly Labeled?	y	
560509	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
560510	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
560511	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
560512	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
560513	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
560514	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
560515	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	General Comments		
560516	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
560517	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	General Comments		
560518	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
560519	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
560520	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
560521	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC Max Tap Position	4R	
560522	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
560523	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC Min Tap Position	16L	
560524	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	15	°C
560525	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Cabinet Paint Condition	Good	
560526	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
560527	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
560528	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	General Comments		
560529	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
560530	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
560531	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	Follow-up Action Required?	n	
560532	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
560533	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
560534	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
560535	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
560536	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
560537	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
560538	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
560539	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
560540	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Tank Leaks	None	
560541	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
560542	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Operations Counter	169	
560543	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
560544	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
560545	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	General Comments		
560546	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
560547	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Regulator As Left Counter	132713	
560548	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
560549	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
560550	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
560551	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
560552	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
560553	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
560554	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Tank Leaks	None	
560555	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
560556	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
560557	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Operations A Ø	0	
560558	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Operations B Ø	0	
560559	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Operations C Ø	0	
560560	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Operations Ground	0	
560561	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
560562	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
560563	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
560564	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
560565	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	Follow-up Action Required?	n	
560566	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
560567	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Amps C Ø	97.0	
560568	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Amps B Ø	82.0	
560569	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Follow-up Action Required?	n	
560570	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Follow-up Action Required?	n	
560571	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Foundation Condition	Good	
560572	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	General Comments		
560573	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	General Comments		
560574	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Grounds in Place?	y	
560575	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Heaters (All) Functioning?	y	
560576	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Maintenance Operations	0	
560577	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Bushings Connection/Risers	Good	
560578	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Bushing Condition	Good	
560579	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Amps C Ø	150.0	
560580	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Amps A Ø	114.0	
560581	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Unknown Operations	0	
560582	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
560583	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	General Comments		
560584	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
560585	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
560586	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
560587	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
560588	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
560589	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
560590	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
560591	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
560592	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
560593	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
560594	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
560595	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Tank Leaks	None	
560596	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC As Left Counter	42636	
560597	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
560598	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC Current Tap Position	4L	
560599	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC Max Tap Position	2R	
560600	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
560601	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Regulator As Left Counter	198452	
560602	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
560603	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
560604	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
560605	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC Min Tap Position	7L	
560606	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC Operations Since Last Insp	520	
560607	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
560608	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
560609	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
560610	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
560611	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
560612	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
560613	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
560614	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
560615	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
560616	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	General Comments	ok	
560617	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
560618	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
560619	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
560620	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
560621	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
560622	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
560623	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
560624	2/21/2019 9:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
560625	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Equipment Properly Labeled?	y	
560626	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
560627	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Accumulated Fault Duty A Ph V	1.37	%
560628	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
560629	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
560630	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Amps A Ø	250.0	
560631	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Amps B Ø	250.0	
560632	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Amps C Ø	250.0	
560633	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Bushing Condition	Good	
560634	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Bushings Connection/Risers	Good	
560635	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
560636	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
560637	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
560638	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
560639	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Follow-up Action Required?	n	
560640	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
560641	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
560642	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
560643	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
560644	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
560645	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
560646	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
560647	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	General Comments		
560648	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
560649	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	General Comments		
560650	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
560651	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	LTC Totalizer Reading	8421.12	kw
560652	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
560653	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	9 Month Operations	12	
560654	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Cabinet Paint Condition	Good	
560655	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Accumulated Fault Duty A Ph V	3.84	%
560656	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Equipment Properly Labeled?	y	
560657	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
560658	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
560659	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
560660	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
560661	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Accumulated Fault Duty B Ph V	8.65	%
560662	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
560663	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Oil Temp Max	28	°C
560664	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Oil Temp Present	21	°C
560665	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
560666	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
560667	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
560668	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
560669	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Operations A Ø	0	
560670	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Operations B Ø	0	
560671	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Operations C Ø	0	
560672	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Operations Ground	0	
560673	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Follow-up Action Required?	n	
560674	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Follow-up Action Required?	n	
560675	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Operations A Ø	0	
560676	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Foundation Condition	Good	
560677	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	General Comments		
560678	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	General Comments		
560679	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Grounds in Place?	y	
560680	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Heaters (All) Functioning?	y	
560681	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	Follow-up Action Required?	n	
560682	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	General Comments		
560683	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	LTC Operation Checked?	y	
560684	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
560685	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
560686	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
560687	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
560688	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Bushings Connection/Risers	Good	
560689	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	All Connections OK?	y	
560690	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Bushing Condition	Good	
560691	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Amps C Ø	120.0	
560692	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Amps B Ø	120.0	
560693	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Amps A Ø	120.0	
560694	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Accumulated Fault Duty C Ph V	3.13	%
560695	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
560696	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
560697	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Accumulated Fault Duty B Ph V	2.68	%
560698	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Accumulated Fault Duty A Ph V	2.23	%
560699	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	9 Month Operations	10	
560700	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Winding Temp Present	45	°C
560701	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Winding Temp Max	75	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
560702	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Totalizer Meter Reading	1.2740	
560703	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
560704	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Top Oil Temperature Present	40	°C
560705	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Top Oil Temperature Max	70	°C
560706	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
560707	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
560708	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
560709	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
560710	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
560711	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
560712	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
560713	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
560714	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Cabinet Paint Condition	Good	
560715	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	750	psi
560716	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
560717	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
560718	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
560719	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	LTC Totalizer Reading	18345.60	kw
560720	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
560721	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	General Comments		
560722	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	General Comments		
560723	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	VRR Time Delay	30	Seconds
560724	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
560725	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
560726	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
560727	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
560728	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Follow-up Action Required?	n	
560729	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
560730	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
560731	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
560732	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
560733	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
560734	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
560735	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
560736	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	9 Month Operations	4	
560737	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Equipment Properly Labeled?	y	
560738	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
560739	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
560740	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
560741	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
560742	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Tank Paint Condition	Good	
560743	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
560744	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
560745	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Unknown Operations	0	
560746	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
560747	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
560748	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
560749	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
560750	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
560751	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
560752	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
560753	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Operations A Ø	0	
560754	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
560755	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Operations B Ø	0	
560756	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Operations C Ø	0	
560757	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
560758	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
560759	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
560760	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
560761	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Operations Ground	0	
560762	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	BCH000393	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
560763	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BCH000531	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
560764	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BCH000531	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
560765	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BCH000531	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
560766	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BCH000531	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
560767	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BCH000531	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
560768	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
560769	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	BCH000393	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
560770	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	BCH000393	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
560771	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
560772	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	BCH000393	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
560773	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	BCH000393	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
560774	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	BCH000393	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
560775	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Ambient Temp	45	°F
560776	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
560777	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Clear of Trash?	y	
560778	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
560779	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
560780	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
560781	2/21/2019 11:22	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
560782	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
560783	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Maintenance Operations	0	
560784	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
560785	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Moisture and Leak Free?	y	
560786	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Operations Counter AF	331	
560787	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Operations Counter AL	337	
560788	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
560789	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Accumulated Fault Duty C Ph V	5.77	%
560790	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Operations B Ø	0	
560791	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Amps A Ø	180.0	
560792	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Amps B Ø	180.0	
560793	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Operations C Ø	0	
560794	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Operations Ground	0	
560795	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Amps C Ø	180.0	
560796	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Bushing Condition	Good	
560797	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Follow-up Action Required?	n	
560798	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Follow-up Action Required?	n	
560799	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Bushings Connection/Risers	Good	
560800	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
560801	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Switching Operations	6	
560802	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Foundation Condition	Good	
560803	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	General Comments		
560804	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	General Comments		
560805	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Grounds in Place?	y	
560806	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Heaters (All) Functioning?	y	
560807	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Maintenance Operations	0	
560808	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
560809	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
560810	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
560811	2/21/2019 9:37	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
560812	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
560813	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
560814	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BCH000531	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
560815	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BCH000531	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
560816	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
560817	2/21/2019 14:22	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Cabinet Paint Condition	Good	
560818	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
560819	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
560820	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
560821	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Operations A Ø	0	
560822	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Amps A Ø	200.0	
560823	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Amps B Ø	220.0	
560824	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Amps C Ø	170.0	
560825	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	9 Month Operations	0	
560826	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
560827	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	3.20	%
560828	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
560829	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
560830	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
560831	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Operations B Ø	0	
560832	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Operations C Ø	0	
560833	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Operations Ground	0	
560834	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
560835	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
560836	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
560837	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
560838	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
560839	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
560840	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
560841	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
560842	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	9 Months Operations	2	
560843	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
560844	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	General Comments		
560845	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
560846	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
560847	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Unknown Operations	0	
560848	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Follow-up Action Required?	n	
560849	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Patrol Inspection	General Comments		
560850	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	General Comments		
560851	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
560852	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Maintenance Operations	0	
560853	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
560854	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
560855	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Maintenance Operations	0	
560856	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Switching Operations	0	
560857	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
560858	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Amps A Ø	359.0	
560859	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Amps B Ø	356.0	
560860	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	-60	°C
560861	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Amps C Ø	349.0	
560862	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Patrol Inspection	Equipment Properly Labeled?	y	
560863	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	-60	°C
560864	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	-60	°C
560865	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	-60	°C
560866	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
560867	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
560868	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
560869	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
560870	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
560871	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
560872	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
560873	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
560874	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
560875	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
560876	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Operations Counter AL	578	
560877	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Operations Counter AF	578	
560878	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
560879	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
560880	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
560881	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
560882	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	General Comments		
560883	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Patrol Inspection	General Comments		
560884	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	42	°C
560885	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
560886	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
560887	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
560888	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Unknown Operations	0	
560889	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Switching Operations	0	
560890	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
560891	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
560892	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Operations Counter AL	122	
560893	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
560894	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
560895	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
560896	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
560897	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
560898	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
560899	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
560900	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
560901	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.72	%
560902	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.72	%
560903	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.72	%
560904	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Accumulated Fault Duty A Ph V	5.15	%
560905	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	9 Month Operations	4	
560906	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Winding Temp Max	30	°C
560907	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
560908	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
560909	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	9 Month Operations	0	
560910	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	General Comments		
560911	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
560912	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
560913	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
560914	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
560915	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
560916	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
560917	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
560918	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
560919	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
560920	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
560921	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
560922	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
560923	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
560924	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
560925	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	42	°C
560926	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
560927	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
560928	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
560929	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
560930	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Amps C Ø	233.0	
560931	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	Oil Temp Max	32	°C
560932	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	Oil Temp Present	32	°C
560933	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
560934	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Amps B Ø	230.0	
560935	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Unknown Operations	0	
560936	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Switching Operations	0	
560937	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Amps A Ø	236.0	
560938	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Operations Counter AL	130	
560939	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Operations Counter AF	130	
560940	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Maintenance Operations	0	
560941	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	General Comments		
560942	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
560943	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
560944	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Patrol Inspection	General Comments		
560945	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
560946	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Follow-up Action Required?	n	
560947	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
560948	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
560949	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Accumulated Fault Duty C Ph V	5.15	%
560950	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Accumulated Fault Duty B Ph V	5.15	%
560951	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Unknown Operations	0	
560952	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Switching Operations	0	
560953	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Operations Counter AL	179	
560954	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Patrol Inspection	Follow-up Action Required?	n	
560955	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Operations Ground	0	
560956	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Operations Counter AF	179	
560957	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Maintenance Operations	0	
560958	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Operations C Ø	0	
560959	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Operations B Ø	0	
560960	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	42	°C
560961	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
560962	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
560963	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
560964	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
560965	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	42	°C
560966	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	38	°C
560967	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Follow-up Action Required?	n	
560968	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
560969	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Patrol Inspection	Follow-up Action Required?	n	
560970	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Operations Ground	0	
560971	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LTCC000445	LTCControl	GL-TRANS 2	LTC Control Insp	VRR Base Voltage AF	116.6	VAC
560972	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LTCC000446	LTCControl	GL-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
560973	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LTCC000446	LTCControl	GL-TRANS 1	LTC Control Insp	General Comments		
560974	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LTCC000446	LTCControl	GL-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
560975	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LTCC000446	LTCControl	GL-TRANS 1	LTC Control Insp	VRR Base Voltage AF	116.4	VAC
560976	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
560977	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Operations A Ø	0	
560978	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Operations C Ø	0	
560979	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Operations B Ø	0	
560980	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Operations A Ø	0	
560981	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
560982	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
560983	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
560984	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
560985	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Operations A Ø	0	
560986	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
560987	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Patrol Inspection	Equipment Properly Labeled?	y	
560988	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Amps C Ø	0.0	
560989	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Amps B Ø	0.0	
560990	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Amps A Ø	0.0	
560991	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
560992	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
560993	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	PF000109	PowerFuse	GL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
560994	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	PF000109	PowerFuse	GL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
560995	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
560996	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Follow-up Action Required?	n	
560997	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Patrol Inspection	Follow-up Action Required?	n	
560998	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	9 Month Operations	0	
560999	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Operations B Ø	0	
561000	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Operations C Ø	0	
561001	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
561002	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Patrol Inspection	Follow-up Action Required?	n	
561003	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Follow-up Action Required?	n	
561004	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Patrol Inspection	General Comments		
561005	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
561006	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	9 Month Operations	0	
561007	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
561008	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
561009	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
561010	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	General Comments		
561011	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
561012	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Operations A Ø	0	
561013	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
561014	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
561015	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
561016	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
561017	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
561018	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
561019	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
561020	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
561021	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Unknown Operations	0	
561022	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Switching Operations	0	
561023	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Operations Counter AL	392	
561024	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Operations Counter AF	392	
561025	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LTCC000445	LTCControl	GL-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
561026	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Maintenance Operations	0	
561027	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
561028	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	General Comments		
561029	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
561030	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
561031	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	Oil Temp Max	35	°C
561032	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
561033	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
561034	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
561035	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
561036	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
561037	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Operations Counter AF	199	
561038	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Maintenance Operations	0	
561039	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Patrol Inspection	General Comments		
561040	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Follow-up Action Required?	n	
561041	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
561042	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	General Comments		
561043	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Patrol Inspection	General Comments		
561044	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Operations Ground	0	
561045	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Operations C Ø	0	
561046	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Operations B Ø	0	
561047	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
561048	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
561049	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LTCC000445	LTCControl	GL-TRANS 2	LTC Control Insp	General Comments		
561050	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Operations Counter AF	122	
561051	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Maintenance Operations	0	
561052	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	General Comments		
561053	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Patrol Inspection	General Comments		
561054	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Patrol Inspection	General Comments		
561055	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
561056	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
561057	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Operations Ground	0	
561058	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
561059	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
561060	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
561061	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
561062	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
561063	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
561064	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
561065	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
561066	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Amps C Ø	350.0	
561067	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Amps B Ø	350.0	
561068	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Amps A Ø	350.0	
561069	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
561070	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
561071	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
561072	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	9 Month Operations	0	
561073	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	9 Month Operations	0	
561074	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
561075	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
561076	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
561077	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Amps A Ø	0.0	
561078	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Amps B Ø	0.0	
561079	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Amps C Ø	0.0	
561080	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
561081	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
561082	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
561083	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
561084	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
561085	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
561086	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
561087	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
561088	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
561089	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
561090	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
561091	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
561092	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
561093	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
561094	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
561095	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
561096	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	9 Month Operations	0	
561097	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
561098	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
561099	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
561100	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
561101	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
561102	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
561103	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
561104	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
561105	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Patrol Inspection	General Comments		
561106	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
561107	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
561108	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
561109	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
561110	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
561111	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
561112	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
561113	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
561114	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
561115	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
561116	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
561117	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
561118	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
561119	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
561120	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	30	°C
561121	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
561122	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
561123	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Panels Dusted?	y	
561124	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
561125	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
561126	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Trash Emptied?	y	
561127	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
561128	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
561129	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
561130	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
561131	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
561132	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
561133	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Evidence of Insects	None	
561134	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
561135	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
561136	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Follow-up Action Required?	y	
561137	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
561138	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	General Comments	heater fan in switch gera not working, vent fan not working properly	
561139	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	n	
561140	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
561141	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
561142	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
561143	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Panels Dusted?	y	
561144	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
561145	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
561146	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Vent Fans OK?	n	
561147	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
561148	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Unknown Operations	0	
561149	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Switching Operations	0	
561150	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Operations Counter AL	234	
561151	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Operations Counter AF	234	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
561152	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Maintenance Operations	0	
561153	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	General Comments		
561154	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
561155	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
561156	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
561157	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
561158	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
561159	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
561160	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
561161	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Operations Ground	0	
561162	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
561163	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
561164	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
561165	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Amps C Ø	168.0	
561166	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Amps B Ø	163.0	
561167	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Amps A Ø	171.0	
561168	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
561169	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
561170	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
561171	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
561172	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	General Comments		
561173	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
561174	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
561175	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	9 Month Operations	0	
561176	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC As Found Counter	425895	
561177	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC As Left Counter	425895	
561178	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
561179	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
561180	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5L	
561181	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
561182	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
561183	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	153	
561184	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
561185	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
561186	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
561187	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
561188	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
561189	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	y	
561190	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
561191	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	General Comments	the counter is changing 2 times for every one opperation. 842 is how many times it actualy opperated.	
561192	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC As Found Counter	365318	
561193	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC As Left Counter	365318	
561194	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
561195	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
561196	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
561197	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
561198	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
561199	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1664	
561200	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
561201	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
561202	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
561203	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
561204	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
561205	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
561206	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	9 Month Operations	0	
561207	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
561208	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
561209	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
561210	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Amps A Ø	450.0	
561211	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Amps B Ø	427.0	
561212	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Operations A Ø	0	
561213	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Operations B Ø	0	
561214	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Operations C Ø	0	
561215	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Operations Ground	0	
561216	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
561217	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Amps C Ø	433.0	
561218	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
561219	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Follow-up Action Required?	n	
561220	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Patrol Inspection	General Comments		
561221	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	General Comments		
561222	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Maintenance Operations	0	
561223	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Operations Counter AF	131	
561224	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Operations Counter AL	131	
561225	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Switching Operations	0	
561226	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
561227	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Unknown Operations	0	
561228	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
561229	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
561230	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
561231	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	General Comments		
561232	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
561233	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
561234	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
561235	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
561236	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
561237	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
561238	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
561239	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
561240	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
561241	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
561242	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Switching Operations	0	
561243	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Operations Counter AL	167	
561244	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Operations Counter AF	167	
561245	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Maintenance Operations	0	
561246	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	General Comments		
561247	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Patrol Inspection	General Comments		
561248	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Follow-up Action Required?	n	
561249	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Patrol Inspection	Follow-up Action Required?	n	
561250	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Operations Ground	0	
561251	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Operations C Ø	0	
561252	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Operations B Ø	0	
561253	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Operations A Ø	0	
561254	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
561255	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	General Comments		
561256	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
561257	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
561258	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Operations Counter AF	283	
561259	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	9 Month Operations	0	
561260	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Operations Counter AL	199	
561261	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Unknown Operations	0	
561262	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Switching Operations	0	
561263	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Operations Counter AL	4	
561264	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Operations Counter AF	4	
561265	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Maintenance Operations	0	
561266	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	General Comments		
561267	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Operations Counter AL	283	
561268	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
561269	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
561270	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
561271	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
561272	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
561273	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
561274	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	General Comments		
561275	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
561276	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	186	
561277	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	186	
561278	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Switching Operations	0	
561279	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Patrol Inspection	General Comments		
561280	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Switching Operations	0	
561281	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Follow-up Action Required?	n	
561282	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Patrol Inspection	Follow-up Action Required?	n	
561283	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Operations Ground	0	
561284	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Operations C Ø	0	
561285	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Operations B Ø	0	
561286	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Operations A Ø	0	
561287	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
561288	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
561289	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Unknown Operations	0	
561290	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	20	°C
561291	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
561292	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Unknown Operations	0	
561293	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Switching Operations	0	
561294	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Operations Counter AL	181	
561295	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Operations Counter AF	181	
561296	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Maintenance Operations	0	
561297	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	General Comments		
561298	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Patrol Inspection	General Comments		
561299	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Follow-up Action Required?	n	
561300	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Patrol Inspection	Follow-up Action Required?	n	
561301	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
561302	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Operations C Ø	0	
561303	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Operations B Ø	0	
561304	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
561305	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Amps A Ø	0.0	
561306	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Amps B Ø	0.0	
561307	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Amps C Ø	0.0	
561308	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
561309	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
561310	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
561311	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
561312	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Fault Operations A Ø	0	
561313	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Fault Operations B Ø	0	
561314	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Fault Operations C Ø	0	
561315	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Fault Operations Ground	0	
561316	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
561317	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Follow-up Action Required?	n	
561318	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Patrol Inspection	General Comments		
561319	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	General Comments		
561320	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Maintenance Operations	0	
561321	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Operations Counter AF	106	
561322	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Operations Counter AL	106	
561323	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Switching Operations	0	
561324	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Unknown Operations	0	
561325	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Operations Counter AF	209	
561326	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Operations Counter AL	209	
561327	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
561328	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
561329	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
561330	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
561331	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Amps C Ø	0.0	
561332	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Amps B Ø	0.0	
561333	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Amps A Ø	0.0	
561334	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
561335	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
561336	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	52	°C
561337	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
561338	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Switching Operations	0	
561339	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Unknown Operations	0	
561340	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
561341	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
561342	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
561343	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
561344	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
561345	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
561346	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
561347	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
561348	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
561349	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
561350	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
561351	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
561352	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
561353	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
561354	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	20	°C
561355	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	36	°C
561356	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
561357	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	General Comments		
561358	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
561359	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
561360	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
561361	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
561362	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
561363	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
561364	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Unknown Operations	0	
561365	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Switching Operations	0	
561366	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Operations Counter AL	163	
561367	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Operations Counter AF	163	
561368	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
561369	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
561370	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
561371	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
561372	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
561373	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
561374	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
561375	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
561376	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
561377	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	Oil Temp Present	20	°C
561378	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	Oil Temp Max	36	°C
561379	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1100	psi
561380	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
561381	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
561382	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
561383	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	General Comments	one fan on bank one not working	
561384	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Maintenance Operations	0	
561385	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	General Comments		
561386	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
561387	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
561388	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Broom on Site?	y	
561389	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
561390	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
561391	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
561392	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
561393	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Evidence of Insects	None	
561394	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	General Comments		
561395	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
561396	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
561397	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
561398	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
561399	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Floor Swept?	y	
561400	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
561401	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
561402	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	General Comments		
561403	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
561404	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Operations A Ø	0	
561405	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
561406	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
561407	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
561408	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
561409	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Amps C Ø	0.0	
561410	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Amps B Ø	0.0	
561411	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Amps A Ø	0.0	
561412	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Accumulated Fault Duty C Ph V	6.01	%
561413	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Accumulated Fault Duty B Ph V	6.01	%
561414	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Accumulated Fault Duty A Ph V	6.01	%
561415	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	9 Month Operations	0	
561416	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	35	°C
561417	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	20	°C
561418	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	30	°C
561419	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	20	°C
561420	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
561421	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
561422	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
561423	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
561424	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
561425	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
561426	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
561427	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
561428	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
561429	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
561430	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
561431	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
561432	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
561433	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
561434	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
561435	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Winding Temp Max	60	°C
561436	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
561437	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
561438	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Amps C Ø	139.0	
561439	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Amps B Ø	144.0	
561440	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Amps A Ø	150.0	
561441	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Accumulated Fault Duty C Ph V	1.72	%
561442	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Accumulated Fault Duty B Ph V	1.72	%
561443	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Accumulated Fault Duty A Ph V	1.72	%
561444	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	9 Month Operations	0	
561445	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
561446	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Switching Operations	0	
561447	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	135	
561448	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	135	
561449	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
561450	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	20	°C
561451	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	36	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
561452	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	20	°C
561453	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	36	°C
561454	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
561455	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
561456	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
561457	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Amps C Ø	0.0	
561458	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Amps B Ø	0.0	
561459	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Amps A Ø	0.0	
561460	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Accumulated Fault Duty C Ph V	.86	%
561461	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Accumulated Fault Duty B Ph V	.86	%
561462	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Accumulated Fault Duty A Ph V	.86	%
561463	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	9 Month Operations	0	
561464	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
561465	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	9 Months Operations	4	
561466	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
561467	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Accumulated Fault Duty B Ph AM	2.13	%
561468	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
561469	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
561470	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Amps A Ø	0.0	
561471	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Amps B Ø	0.0	
561472	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	2.13	%
561473	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Amps A Ø	210.0	
561474	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Amps B Ø	160.0	
561475	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Amps C Ø	150.0	
561476	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
561477	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Amps C Ø	0.0	
561478	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Patrol Inspection	Equipment Properly Labeled?	y	
561479	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
561480	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
561481	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
561482	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Operations A Ø	0	
561483	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Operations B Ø	0	
561484	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Operations C Ø	0	
561485	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Operations Ground	0	
561486	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Patrol Inspection	Follow-up Action Required?	n	
561487	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Follow-up Action Required?	n	
561488	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Patrol Inspection	General Comments		
561489	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Operations B Ø	0	
561490	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	General Comments		
561491	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Maintenance Operations	0	
561492	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Operations Counter AF	138	
561493	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Operations Counter AL	138	
561494	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
561495	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
561496	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
561497	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Switching Operations	0	
561498	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Unknown Operations	0	
561499	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	9 Month Operations	0	
561500	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	23	°C
561501	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	23	°C
561502	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	21	°C
561503	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	38	°C
561504	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Accumulated Fault Duty B Ph V	.86	%
561505	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Accumulated Fault Duty A Ph V	.86	%
561506	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	9 Month Operations	0	
561507	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Unknown Operations	0	
561508	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Switching Operations	0	
561509	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Operations Counter AL	181	
561510	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Operations Counter AF	181	
561511	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Maintenance Operations	0	
561512	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	General Comments		
561513	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Patrol Inspection	General Comments		
561514	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Follow-up Action Required?	n	
561515	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
561516	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
561517	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Amps A Ø	0.0	
561518	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Amps B Ø	0.0	
561519	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Amps C Ø	0.0	
561520	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
561521	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
561522	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
561523	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
561524	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Operations A Ø	0	
561525	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Patrol Inspection	Follow-up Action Required?	n	
561526	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
561527	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Operations C Ø	0	
561528	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Operations B Ø	0	
561529	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Operations A Ø	0	
561530	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Unknown Operations	0	
561531	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Switching Operations	0	
561532	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Operations Counter AL	211	
561533	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Operations Counter AF	211	
561534	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Maintenance Operations	0	
561535	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	General Comments		
561536	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Patrol Inspection	General Comments		
561537	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Follow-up Action Required?	n	
561538	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Patrol Inspection	Follow-up Action Required?	n	
561539	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Operations Ground	0	
561540	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Operations C Ø	0	
561541	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Operations B Ø	0	
561542	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Operations A Ø	0	
561543	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
561544	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
561545	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
561546	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
561547	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Amps C Ø	234.0	
561548	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Amps B Ø	233.0	
561549	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Amps A Ø	239.0	
561550	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Accumulated Fault Duty C Ph V	5.15	%
561551	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Accumulated Fault Duty B Ph V	5.15	%
561552	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Accumulated Fault Duty A Ph V	5.15	%
561553	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	9 Month Operations	4	
561554	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
561555	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.900	millivolts
561556	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Patrol Inspection	General Comments		
561557	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	General Comments		
561558	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
561559	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Maintenance Operations	0	
561560	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Operations Counter AF	404	
561561	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LTCC000407	LTCControl	GL-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
561562	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LTCC000407	LTCControl	GL-TRANS 3	LTC Control Insp	General Comments		
561563	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LTCC000407	LTCControl	GL-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
561564	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
561565	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
561566	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
561567	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
561568	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
561569	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
561570	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
561571	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
561572	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Operations Counter AL	404	
561573	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Switching Operations	0	
561574	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Unknown Operations	0	
561575	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
561576	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
561577	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
561578	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
561579	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
561580	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
561581	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
561582	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
561583	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
561584	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
561585	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
561586	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	9 Month Operations	0	
561587	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Accumulated Fault Duty A Ph V	1.72	%
561588	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Accumulated Fault Duty B Ph V	2.58	%
561589	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Accumulated Fault Duty C Ph V	1.72	%
561590	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Amps A Ø	142.0	
561591	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Amps B Ø	134.0	
561592	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Amps C Ø	140.0	
561593	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
561594	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
561595	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
561596	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
561597	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Operations A Ø	0	
561598	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Operations B Ø	0	
561599	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
561600	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
561601	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
561602	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
561603	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
561604	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
561605	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
561606	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	28	°C
561607	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	40	°C
561608	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
561609	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
561610	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
561611	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
561612	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
561613	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
561614	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
561615	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
561616	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
561617	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	Oil Temp Present	25	°C
561618	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	Oil Temp Max	25	°C
561619	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
561620	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
561621	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	25	°C
561622	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	25	°C
561623	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
561624	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
561625	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Switching Operations	0	
561626	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Operations Counter AL	187	
561627	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Operations C Ø	0	
561628	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Operations Ground	0	
561629	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
561630	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Follow-up Action Required?	n	
561631	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Patrol Inspection	General Comments		
561632	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Operations Counter AF	187	
561633	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Maintenance Operations	0	
561634	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
561635	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	General Comments		
561636	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Maintenance Operations	0	
561637	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Operations Counter AF	125	
561638	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Operations Counter AL	125	
561639	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Switching Operations	0	
561640	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Unknown Operations	0	
561641	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
561642	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	General Comments		
561643	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
561644	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Operations A Ø	0	
561645	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Operations B Ø	0	
561646	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Operations C Ø	0	
561647	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Operations Ground	0	
561648	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LTCC000407	LTCControl	GL-TRANS 3	LTC Control Insp	VRR Base Voltage AF	116.2	VAC
561649	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
561650	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Follow-up Action Required?	n	
561651	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	General Comments		
561652	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
561653	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
561654	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
561655	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	27.2	VDC
561656	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	27.2	VDC
561657	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC Current Tap Position	8L	
561658	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
561659	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC As Left Counter	18943	
561660	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Maintenance Operations	0	
561661	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Operations Counter AF	110	
561662	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Operations Counter AL	110	
561663	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Switching Operations	0	
561664	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Unknown Operations	0	
561665	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
561666	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	47	°C
561667	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	23	°C
561668	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC As Found Counter	18943	
561669	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
561670	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	General Comments		
561671	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
561672	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	9 Month Operations	4	
561673	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Accumulated Fault Duty A Ph V	5.15	%
561674	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Accumulated Fault Duty B Ph V	5.15	%
561675	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Accumulated Fault Duty C Ph V	5.15	%
561676	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Amps A Ø	239.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
561677	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Amps B Ø	231.0	
561678	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Amps C Ø	238.0	
561679	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
561680	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
561681	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
561682	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
561683	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Operations A Ø	0	
561684	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Operations B Ø	0	
561685	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Operations C Ø	0	
561686	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	PF000111	PowerFuse	GL-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
561687	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	PF000111	PowerFuse	GL-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
561688	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Operations Ground	0	
561689	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
561690	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
561691	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Patrol Inspection	Follow-up Action Required?	n	
561692	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Follow-up Action Required?	n	
561693	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Patrol Inspection	General Comments		
561694	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	General Comments		
561695	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Maintenance Operations	0	
561696	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Operations Counter AF	198	
561697	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Operations Counter AL	198	
561698	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Switching Operations	0	
561699	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Unknown Operations	0	
561700	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	9 Months Operations	1	
561701	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
561702	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
561703	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
561704	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Amps A Ø	150.0	
561705	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Amps B Ø	190.0	
561706	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Amps C Ø	170.0	
561707	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
561708	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Vegetation	None	
561709	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
561710	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
561711	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
561712	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
561713	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
561714	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	General Comments		
561715	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
561716	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
561717	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
561718	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
561719	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
561720	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
561721	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC Max Tap Position	4L	
561722	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC Min Tap Position	9L	
561723	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	9 Month Operations	0	
561724	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
561725	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	General Comments		
561726	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
561727	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
561728	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
561729	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
561730	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
561731	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
561732	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
561733	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
561734	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
561735	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
561736	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
561737	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
561738	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
561739	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	9 Month Operations	0	
561740	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
561741	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
561742	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
561743	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
561744	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
561745	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
561746	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
561747	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
561748	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
561749	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
561750	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
561751	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
561752	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
561753	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
561754	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
561755	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
561756	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Patrol Inspection	General Comments		
561757	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	General Comments		
561758	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
561759	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
561760	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
561761	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
561762	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
561763	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
561764	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Winding Temp Max	46	°C
561765	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Accumulated Fault Duty A Ph AM	2.13	%
561766	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
561767	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Operations A Ø	0	
561768	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	9 Months Operations	12	
561769	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Operations B Ø	0	
561770	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Operations C Ø	0	
561771	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Operations Ground	0	
561772	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
561773	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Follow-up Action Required?	n	
561774	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	9 Month Operations	0	
561775	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
561776	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Patrol Inspection	General Comments		
561777	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	General Comments		
561778	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
561779	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Maintenance Operations	0	
561780	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Operations Counter AF	850	
561781	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Operations Counter AL	850	
561782	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Switching Operations	0	
561783	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Unknown Operations	0	
561784	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
561785	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
561786	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
561787	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
561788	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
561789	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
561790	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
561791	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
561792	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
561793	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
561794	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
561795	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
561796	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
561797	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
561798	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
561799	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
561800	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
561801	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
561802	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
561803	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
561804	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
561805	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Amps C Ø	0.0	
561806	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Amps B Ø	0.0	
561807	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Amps A Ø	0.0	
561808	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Accumulated Fault Duty C Ph V	.86	%
561809	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
561810	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
561811	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Unknown Operations	0	
561812	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Switching Operations	0	
561813	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
561814	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Operations Counter AL	379	
561815	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Operations Counter AF	379	
561816	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Maintenance Operations	0	
561817	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
561818	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	General Comments		
561819	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Patrol Inspection	General Comments		
561820	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Follow-up Action Required?	n	
561821	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
561822	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Operations Ground	0	
561823	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Operations C Ø	0	
561824	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Operations B Ø	0	
561825	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Operations A Ø	0	
561826	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
561827	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Operations B Ø	0	
561828	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
561829	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
561830	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
561831	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
561832	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Amps C Ø	50.0	
561833	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Amps B Ø	50.0	
561834	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Amps A Ø	110.0	
561835	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Accumulated Fault Duty C Ph AM	5.34	%
561836	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Accumulated Fault Duty B Ph AM	5.34	%
561837	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Operations C Ø	0	
561838	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Operations Ground	0	
561839	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Patrol Inspection	Follow-up Action Required?	n	
561840	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Follow-up Action Required?	n	
561841	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Patrol Inspection	General Comments		
561842	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	General Comments		
561843	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Maintenance Operations	0	
561844	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Operations Counter AF	184	
561845	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Operations Counter AL	184	
561846	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Switching Operations	0	
561847	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Unknown Operations	0	
561848	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	522	
561849	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
561850	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Unknown Operations	0	
561851	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
561852	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
561853	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
561854	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
561855	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
561856	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
561857	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
561858	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
561859	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Oil Temp Max	50	°C
561860	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
561861	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
561862	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
561863	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
561864	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	PF000113	PowerFuse	GL-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
561865	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
561866	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
561867	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
561868	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
561869	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
561870	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
561871	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
561872	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
561873	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
561874	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
561875	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
561876	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
561877	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Amps A Ø	0.0	
561878	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Accumulated Fault Duty C Ph V	2.58	%
561879	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Accumulated Fault Duty B Ph V	2.58	%
561880	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Accumulated Fault Duty A Ph V	2.58	%
561881	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	PF000113	PowerFuse	GL-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
561882	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	PF000112	PowerFuse	GL-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
561883	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
561884	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
561885	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	9 Months Operations	2	
561886	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Operations C Ø	0	
561887	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
561888	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	9 Month Operations	0	
561889	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	1.59	%
561890	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	1.59	%
561891	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	1.59	%
561892	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Switching Operations	0	
561893	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Operations Counter AL	197	
561894	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Amps A Ø	697.0	
561895	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Amps B Ø	675.0	
561896	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Amps C Ø	691.0	
561897	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
561898	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
561899	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
561900	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
561901	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
561902	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Operations Ground	0	
561903	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
561904	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
561905	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
561906	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
561907	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
561908	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
561909	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
561910	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
561911	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
561912	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
561913	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
561914	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
561915	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
561916	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Operations A Ø	0	
561917	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Operations B Ø	0	
561918	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
561919	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
561920	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	PF000114	PowerFuse	GL-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
561921	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	PF000114	PowerFuse	GL-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
561922	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
561923	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Operations C Ø	0	
561924	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
561925	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
561926	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
561927	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
561928	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Ambient Temp	29	°F
561929	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
561930	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
561931	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
561932	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
561933	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
561934	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
561935	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
561936	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
561937	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
561938	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
561939	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
561940	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
561941	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	59	
561942	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
561943	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
561944	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
561945	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
561946	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
561947	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
561948	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
561949	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
561950	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
561951	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	General Comments		
561952	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
561953	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC As Left Counter	31085	
561954	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC As Found Counter	31085	
561955	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
561956	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
561957	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
561958	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
561959	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
561960	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
561961	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
561962	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
561963	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
561964	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
561965	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
561966	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
561967	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Unknown Operations	0	
561968	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
561969	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
561970	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Operations B Ø	0	
561971	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	-60	°C
561972	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
561973	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	PF000112	PowerFuse	GL-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
561974	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
561975	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Operations Counter AF	195	
561976	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Operations Counter AL	195	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
561977	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
561978	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
561979	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Amps C Ø	0.0	
561980	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
561981	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	General Comments	on going construction on fence	
561982	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Switching Operations	0	
561983	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
561984	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
561985	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Amps B Ø	0.0	
561986	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
561987	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
561988	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Unknown Operations	0	
561989	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Operations Counter AF	197	
561990	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Maintenance Operations	0	
561991	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	General Comments		
561992	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Patrol Inspection	General Comments		
561993	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Vegetation	None	
561994	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
561995	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Follow-up Action Required?	n	
561996	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Patrol Inspection	Follow-up Action Required?	n	
561997	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Operations Ground	0	
561998	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Operations C Ø	0	
561999	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
562000	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
562001	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
562002	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
562003	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
562004	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	General Comments		
562005	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
562006	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
562007	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	General Comments		
562008	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
562009	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
562010	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
562011	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	light out in cabniet	
562012	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC As Found Counter	80760	
562013	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC As Left Counter	80760	
562014	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
562015	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
562016	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
562017	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
562018	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1124	
562019	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
562020	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
562021	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
562022	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	9 Month Operations	3	
562023	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
562024	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	PF000110	PowerFuse	GL-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
562025	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	PF000110	PowerFuse	GL-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
562026	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
562027	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Operations A Ø	0	
562028	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
562029	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
562030	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
562031	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
562032	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Operations Ground	0	
562033	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
562034	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
562035	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
562036	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
562037	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
562038	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Operations Ground	0	
562039	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
562040	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
562041	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
562042	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
562043	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Patrol Inspection	Follow-up Action Required?	n	
562044	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Follow-up Action Required?	n	
562045	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
562046	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
562047	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	General Comments		
562048	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
562049	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	General Comments		
562050	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Patrol Inspection	General Comments		
562051	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
562052	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Patrol Inspection	General Comments		
562053	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
562054	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
562055	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Maintenance Operations	0	
562056	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
562057	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
562058	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
562059	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	-60	°C
562060	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
562061	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
562062	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
562063	2/20/2019 9:47	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	General Comments		
562064	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	General Comments		
562065	2/20/2019 9:25	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
562066	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
562067	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Accumulated Fault Duty A Ph V	1.84	%
562068	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	9 Month Operations	0	
562069	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Operations Ground	0	
562070	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
562071	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
562072	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	General Comments		
562073	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54	VDC
562074	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54	VDC
562075	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3	millivolts
562076	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
562077	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
562078	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	VRR Time Delay	30	Seconds
562079	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
562080	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
562081	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
562082	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
562083	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Follow-up Action Required?	n	
562084	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	General Comments		
562085	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
562086	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
562087	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
562088	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
562089	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Operations Counter AF	207	
562090	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
562091	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
562092	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
562093	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
562094	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
562095	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
562096	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
562097	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
562098	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
562099	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
562100	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Operations C Ø	0	
562101	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
562102	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
562103	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Operations B Ø	0	
562104	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
562105	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Operations A Ø	0	
562106	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
562107	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
562108	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
562109	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Vegetation	None	
562110	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
562111	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
562112	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	General Comments	ok	
562113	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
562114	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	-60	°C
562115	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	-60	°C
562116	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
562117	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
562118	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
562119	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
562120	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
562121	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
562122	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Heaters (All) Functioning?	y	
562123	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Maintenance Operations	0	
562124	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
562125	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
562126	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
562127	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
562128	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
562129	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
562130	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
562131	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
562132	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
562133	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
562134	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	9.24	%
562135	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	7.51	%
562136	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	8.67	%
562137	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
562138	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
562139	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
562140	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
562141	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
562142	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
562143	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
562144	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
562145	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
562146	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
562147	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
562148	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
562149	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
562150	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	General Comments	had to adjust base voltage	
562151	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
562152	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
562153	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
562154	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Accumulated Fault Duty B Ph V	1.32	%
562155	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Accumulated Fault Duty C Ph V	1.32	%
562156	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Amps A Ø	50.0	
562157	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Amps B Ø	50.0	
562158	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Amps C Ø	50.0	
562159	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Bushing Condition	Good	
562160	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Bushings Connection/Risers	Good	
562161	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
562162	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
562163	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
562164	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
562165	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Bushing Condition	Good	
562166	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Cabinet Paint Condition	Good	
562167	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Equipment Properly Labeled?	y	
562168	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
562169	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
562170	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
562171	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Operations A Ø	0	
562172	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Operations B Ø	0	
562173	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Operations C Ø	0	
562174	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Operations Ground	0	
562175	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Operations Counter AL	207	
562176	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Follow-up Action Required?	n	
562177	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Follow-up Action Required?	n	
562178	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Foundation Condition	Good	
562179	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	General Comments	ok	
562180	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	General Comments	ok	
562181	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Grounds in Place?	y	
562182	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
562183	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Vegetation	None	
562184	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Switching Operations	0	
562185	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Unknown Operations	0	
562186	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
562187	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
562188	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
562189	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
562190	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
562191	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
562192	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
562193	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	General Comments	ok	
562194	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	General Comments	ok	
562195	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
562196	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
562197	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
562198	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Amps B Ø	0	
562199	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Foundation Condition	Good	
562200	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
562201	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
562202	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	General Comments		
562203	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Patrol Inspection	General Comments		
562204	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Follow-up Action Required?	n	
562205	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
562206	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
562207	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
562208	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
562209	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
562210	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
562211	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
562212	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Patrol Inspection	Follow-up Action Required?	n	
562213	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Fault Operations	0	
562214	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Patrol Inspection	Equipment Properly Labeled?	y	
562215	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
562216	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
562217	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
562218	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
562219	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
562220	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Amps C Ø	0	
562221	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
562222	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Unknown Operations	0	
562223	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Tank Paint Condition	Good	
562224	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
562225	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
562226	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Amps C Ø	0	
562227	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
562228	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
562229	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
562230	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
562231	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Amps B Ø	0	
562232	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
562233	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
562234	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	All Connections OK?	y	
562235	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	Follow-up Action Required?	n	
562236	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	General Comments		
562237	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
562238	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
562239	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
562240	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
562241	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
562242	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
562243	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
562244	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
562245	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	VRR Time Delay	30	Seconds
562246	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
562247	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
562248	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
562249	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
562250	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	LTC Operation Checked?	y	
562251	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	General Comments		
562252	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	Follow-up Action Required?	n	
562253	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	All Connections OK?	y	
562254	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	74	
562255	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
562256	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
562257	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
562258	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
562259	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	79	
562260	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
562261	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
562262	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
562263	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
562264	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
562265	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
562266	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
562267	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
562268	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
562269	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
562270	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
562271	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
562272	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
562273	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
562274	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	-28.3	VDC
562275	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
562276	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
562277	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
562278	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
562279	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
562280	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Amps A Ø	0	
562281	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
562282	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
562283	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
562284	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
562285	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
562286	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
562287	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
562288	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
562289	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
562290	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
562291	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
562292	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
562293	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
562294	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
562295	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
562296	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
562297	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Follow-up Action Required?	y	
562298	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	General Comments		
562299	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	General Comments	Amp reader not working, A Phase IOC	
562300	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
562301	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
562302	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
562303	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
562304	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
562305	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
562306	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
562307	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
562308	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
562309	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
562310	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Maintenance Operations	0	
562311	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Moisture and Leak Free?	y	
562312	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
562313	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
562314	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
562315	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
562316	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
562317	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
562318	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Switching Operations	0	
562319	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
562320	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Operations Counter AL	221	
562321	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Operations Counter AF	221	
562322	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
562323	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Maintenance Operations	0	
562324	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
562325	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Grounds in Place?	y	
562326	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	General Comments		
562327	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	General Comments		
562328	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Foundation Condition	Good	
562329	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Follow-up Action Required?	n	
562330	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
562331	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
562332	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
562333	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
562334	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
562335	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
562336	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
562337	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
562338	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Clear of Trash?	y	
562339	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
562340	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
562341	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
562342	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	34	°F
562343	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
562344	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
562345	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
562346	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
562347	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
562348	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
562349	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
562350	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Adjusted Amps A Phase V	0	
562351	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
562352	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
562353	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	4	
562354	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
562355	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	222	
562356	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	226	
562357	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
562358	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
562359	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
562360	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Adjusted Amps B Phase V	0	
562361	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
562362	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	General Comments		
562363	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Adjusted Amps C Phase V	0	
562364	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
562365	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
562366	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
562367	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
562368	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
562369	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
562370	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
562371	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
562372	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
562373	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Operations A Ø	0	
562374	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Operations B Ø	0	
562375	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Operations C Ø	0	
562376	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
562377	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
562378	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Operations Ground	0	
562379	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Follow-up Action Required?	n	
562380	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	General Comments		
562381	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Amps A Ø	0	
562382	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	LTC Operation Checked?	y	
562383	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
562384	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
562385	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
562386	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
562387	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
562388	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
562389	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Operations Counter	54	
562390	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
562391	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
562392	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
562393	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	General Comments	ok	
562394	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	General Comments	ok	
562395	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
562396	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
562397	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
562398	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
562399	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
562400	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
562401	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
562402	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
562403	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
562404	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
562405	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
562406	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
562407	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
562408	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
562409	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
562410	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	General Comments		
562411	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
562412	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
562413	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Foundation Condition	Good	
562414	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
562415	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
562416	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
562417	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
562418	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
562419	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Amps C Ø	485.0	
562420	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Amps B Ø	470.0	
562421	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Amps A Ø	470.0	
562422	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	BCH000520	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
562423	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	BCH000520	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
562424	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	BCH000520	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
562425	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
562426	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BCH001145	Charger	888-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
562427	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BCH001145	Charger	888-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
562428	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BCH001145	Charger	888-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
562429	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
562430	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
562431	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	9 Month Operations	2	
562432	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BCH001145	Charger	888-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
562433	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Maintenance Operations	0	
562434	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
562435	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
562436	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
562437	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ANN000008	Annunciator	BB-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
562438	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ANN000008	Annunciator	BB-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
562439	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
562440	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
562441	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
562442	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
562443	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
562444	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
562445	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
562446	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
562447	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
562448	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	1	
562449	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Foundation Condition	Good	
562450	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
562451	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
562452	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
562453	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
562454	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
562455	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
562456	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
562457	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
562458	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
562459	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
562460	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	193	
562461	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	197	
562462	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
562463	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
562464	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
562465	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
562466	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	-60	°C
562467	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
562468	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
562469	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
562470	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
562471	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
562472	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
562473	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
562474	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
562475	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
562476	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
562477	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
562478	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
562479	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	Oil Temp Present	30	°C
562480	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	Oil Temp Max	40	°C
562481	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
562482	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
562483	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
562484	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
562485	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
562486	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	General Comments	ok	
562487	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
562488	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
562489	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Operations Counter AL	177	
562490	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
562491	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	Oil Temp Max	30	°C
562492	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Switching Operations	0	
562493	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
562494	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
562495	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	General Comments		
562496	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
562497	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Unknown Operations	0	
562498	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
562499	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
562500	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
562501	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
562502	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
562503	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
562504	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
562505	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
562506	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
562507	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
562508	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	PF000034	PowerFuse	BB-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
562509	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
562510	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Unknown Operations	0	
562511	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Switching Operations	0	
562512	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Operations Counter AL	161	
562513	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Operations Counter AF	161	
562514	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Moisture and Leak Free?	y	
562515	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Maintenance Operations	0	
562516	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
562517	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	PF000034	PowerFuse	BB-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
562518	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Operations Ground	0	
562519	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Follow-up Action Required?	n	
562520	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Follow-up Action Required?	n	
562521	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	General Comments		
562522	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Unknown Operations	0	
562523	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Switching Operations	0	
562524	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Operations Counter AL	415	
562525	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Operations Counter AF	415	
562526	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Maintenance Operations	0	
562527	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	General Comments		
562528	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
562529	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
562530	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
562531	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
562532	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	General Comments	ok	
562533	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
562534	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
562535	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
562536	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
562537	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
562538	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
562539	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ANN000008	Annunciator	BB-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
562540	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BCH001145	Charger	888-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
562541	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ANN000008	Annunciator	BB-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
562542	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ANN000008	Annunciator	BB-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
562543	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
562544	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
562545	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
562546	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
562547	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
562548	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
562549	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	General Comments		
562550	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
562551	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
562552	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
562553	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
562554	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
562555	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Adjusted Amps A Phase V	0	
562556	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Adjusted Amps B Phase V	0	
562557	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Adjusted Amps C Phase V	0	
562558	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Operations A Ø	0	
562559	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
562560	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
562561	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Operations B Ø	0	
562562	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Operations C Ø	0	
562563	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
562564	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
562565	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
562566	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
562567	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
562568	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
562569	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
562570	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
562571	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Operations B Ø	0	
562572	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Operations C Ø	0	
562573	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Operations Ground	0	
562574	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
562575	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
562576	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
562577	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
562578	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
562579	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Patrol Inspection	General Comments		
562580	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	General Comments		
562581	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
562582	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
562583	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
562584	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
562585	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
562586	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
562587	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Moisture and Leak Free?	y	
562588	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Operations Counter AF	177	
562589	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Follow-up Action Required?	n	
562590	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Follow-up Action Required?	n	
562591	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	General Comments		
562592	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	General Comments		
562593	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Heaters (All) Functioning?	y	
562594	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
562595	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
562596	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
562597	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
562598	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
562599	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	General Comments		
562600	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
562601	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Clear of Trash?	y	
562602	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
562603	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
562604	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
562605	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
562606	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
562607	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	General Comments		
562608	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
562609	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	Oil Temp Max	45	°C
562610	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	Oil Temp Present	35	°C
562611	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
562612	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
562613	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
562614	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
562615	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
562616	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
562617	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Tank Leaks	None	
562618	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
562619	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Operations Counter	185	
562620	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
562621	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
562622	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	General Comments		
562623	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
562624	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
562625	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
562626	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
562627	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
562628	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	General Comments		
562629	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
562630	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	All Connections OK?	y	
562631	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
562632	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
562633	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
562634	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
562635	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
562636	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
562637	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
562638	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Amps C Ø	180.0	
562639	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
562640	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
562641	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Min Tap Position	16L	
562642	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
562643	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
562644	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
562645	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
562646	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.5	volts
562647	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Regulator As Left Counter	111230	
562648	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
562649	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
562650	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
562651	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Tank Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
562652	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
562653	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
562654	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
562655	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	9 Month Operations	0	
562656	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Accumulated Fault Duty A Ph V	2.06	%
562657	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Accumulated Fault Duty B Ph V	4.42	%
562658	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Accumulated Fault Duty C Ph V	0	%
562659	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Amps A Ø	66	
562660	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Amps B Ø	66	
562661	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Amps C Ø	57	
562662	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
562663	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
562664	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
562665	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Cabinet Paint Condition	Good	
562666	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Equipment Properly Labeled?	y	
562667	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Fault Adjusted Amps A Phase V	0	
562668	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Fault Adjusted Amps B Phase V	0	
562669	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Moisture and Leak Free?	y	
562670	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Operations Counter AF	53	
562671	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Operations Counter AL	53	
562672	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Switching Operations	0	
562673	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Tank Paint Condition	Good	
562674	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Fault Adjusted Amps C Phase V	0	
562675	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Fault Operations A Ø	0	
562676	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Unknown Operations	0	
562677	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
562678	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
562679	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
562680	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
562681	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
562682	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
562683	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
562684	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Fault Operations B Ø	0	
562685	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Fault Operations C Ø	0	
562686	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Fault Operations Ground	0	
562687	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
562688	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
562689	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
562690	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
562691	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
562692	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
562693	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	General Comments		
562694	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
562695	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
562696	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
562697	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
562698	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
562699	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
562700	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
562701	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
562702	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
562703	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
562704	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
562705	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
562706	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
562707	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	General Comments		
562708	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
562709	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
562710	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
562711	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
562712	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	9 Months Operations	0	
562713	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
562714	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
562715	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
562716	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Amps A Ø	200.0	
562717	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Amps B Ø	170.0	
562718	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Amps C Ø	150.0	
562719	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
562720	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
562721	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
562722	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
562723	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	Follow-up Action Required?	n	
562724	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	General Comments		
562725	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	LTC Operation Checked?	y	
562726	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
562727	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
562728	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
562729	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
562730	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	VRR Time Delay	30	Seconds
562731	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	-60	°C
562732	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	-60	°C
562733	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	-60	°C
562734	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Operations A Ø	0	
562735	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
562736	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
562737	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
562738	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Amps C Ø	104.0	
562739	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Amps B Ø	150.0	
562740	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Amps A Ø	130.0	
562741	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH000513	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
562742	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH000513	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
562743	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH000513	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
562744	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
562745	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH000513	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
562746	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH000513	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
562747	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH000513	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
562748	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
562749	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
562750	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	75.0	
562751	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	21.45	%
562752	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	9 Month Operations	0	
562753	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
562754	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
562755	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
562756	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Amps A Ø	158	
562757	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Amps B Ø	162	
562758	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Amps C Ø	165	
562759	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
562760	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	37	°F
562761	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
562762	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
562763	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
562764	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
562765	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
562766	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Maintenance Operations	0	
562767	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Number of Ops last 9 Months	0	
562768	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Operations Counter AF	515	
562769	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Operations Counter AL	515	
562770	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH000513	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
562771	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Amps A Ø	1120.0	
562772	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Amps B Ø	127.0	
562773	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
562774	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Switching Operations	0	
562775	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	20.38	%
562776	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	28.96	%
562777	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0214	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	24	
562778	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Patrol Inspection	Tank Leaks	None	
562779	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
562780	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Patrol Inspection	Tank Oil Level	Good	
562781	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Unknown Operations	0	
562782	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Cabinet Heaters Functioning?	n	
562783	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
562784	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
562785	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	General Comments		
562786	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
562787	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
562788	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
562789	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
562790	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
562791	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
562792	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
562793	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	82	
562794	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
562795	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
562796	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
562797	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
562798	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
562799	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC As Left Counter	326913	
562800	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC As Found Counter	326913	
562801	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
562802	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	General Comments		
562803	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
562804	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
562805	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
562806	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
562807	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
562808	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
562809	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	101	
562810	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
562811	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
562812	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC Max Tap Position	8L	
562813	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
562814	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
562815	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
562816	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
562817	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
562818	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
562819	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
562820	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
562821	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
562822	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
562823	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
562824	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
562825	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
562826	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
562827	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
562828	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
562829	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
562830	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	General Comments		
562831	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
562832	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Foundation Condition	Good	
562833	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
562834	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
562835	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
562836	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
562837	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
562838	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
562839	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
562840	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
562841	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC As Left Counter	377037	
562842	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC As Found Counter	377037	
562843	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
562844	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
562845	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Unknown Operations	0	
562846	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Tank Paint Condition	Good	
562847	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Switching Operations	0	
562848	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Operations Counter AL	78	
562849	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
562850	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
562851	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
562852	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
562853	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
562854	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
562855	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Totalizer Meter Reading	.8580	
562856	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
562857	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
562858	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
562859	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
562860	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
562861	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
562862	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
562863	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
562864	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
562865	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
562866	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
562867	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Vegetation	None	
562868	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
562869	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	General Comments	ok	
562870	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
562871	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
562872	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
562873	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
562874	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
562875	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
562876	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
562877	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
562878	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
562879	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
562880	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
562881	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
562882	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
562883	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
562884	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
562885	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	General Comments		
562886	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
562887	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
562888	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
562889	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
562890	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
562891	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
562892	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
562893	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
562894	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	36	°F
562895	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
562896	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Clear of Trash?	y	
562897	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
562898	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
562899	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
562900	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	General Comments	ok	
562901	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
562902	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
562903	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
562904	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
562905	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
562906	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
562907	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
562908	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
562909	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
562910	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	10293.12	kw
562911	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
562912	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
562913	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	55	°C
562914	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	20	°C
562915	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
562916	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
562917	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
562918	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
562919	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
562920	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
562921	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
562922	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
562923	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	1.0722	
562924	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
562925	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
562926	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
562927	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
562928	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
562929	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
562930	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
562931	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
562932	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
562933	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
562934	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
562935	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
562936	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
562937	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
562938	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
562939	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Follow-up Action Required?	n	
562940	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
562941	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	9 Month Operations	1	
562942	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
562943	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
562944	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
562945	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	General Comments		
562946	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	General Comments		
562947	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
562948	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	LTC Totalizer Reading	9871.20	kw
562949	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
562950	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
562951	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
562952	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
562953	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
562954	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
562955	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
562956	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
562957	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
562958	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
562959	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
562960	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
562961	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
562962	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
562963	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
562964	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
562965	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
562966	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
562967	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
562968	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
562969	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Operations Counter AF	78	
562970	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Moisture and Leak Free?	y	
562971	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Maintenance Operations	0	
562972	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Heaters (All) Functioning?	y	
562973	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Grounds in Place?	y	
562974	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	General Comments	ok	
562975	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	General Comments	ok	
562976	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Foundation Condition	Good	
562977	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Follow-up Action Required?	n	
562978	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Follow-up Action Required?	n	
562979	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Operations Ground	0	
562980	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Operations C Ø	0	
562981	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Ambient Temp	27	°F
562982	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
562983	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
562984	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Clear of Trash?	y	
562985	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
562986	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
562987	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
562988	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
562989	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
562990	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
562991	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	General Comments		
562992	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
562993	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
562994	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
562995	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	7.48	%
562996	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	6.54	%
562997	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
562998	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Vegetation	None	
562999	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
563000	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	8.88	%
563001	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	220.0	
563002	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	230.0	
563003	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	230.0	
563004	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Operations B Ø	0	
563005	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Operations A Ø	0	
563006	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
563007	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	PF000035	PowerFuse	BB-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
563008	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	PF000035	PowerFuse	BB-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
563009	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	General Comments		
563010	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
563011	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
563012	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
563013	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
563014	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
563015	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
563016	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
563017	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
563018	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
563019	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
563020	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
563021	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
563022	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
563023	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
563024	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
563025	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
563026	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
563027	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
563028	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
563029	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
563030	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
563031	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Operations Ground	0	
563032	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Operations C Ø	0	
563033	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Operations B Ø	0	
563034	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Operations A Ø	0	
563035	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
563036	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
563037	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
563038	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
563039	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.2	VDC
563040	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	-.2	VDC
563041	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
563042	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
563043	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
563044	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
563045	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
563046	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
563047	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
563048	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	32	°F
563049	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
563050	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
563051	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
563052	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
563053	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
563054	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
563055	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
563056	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
563057	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
563058	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Amps C Ø	75.0	
563059	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Amps B Ø	75.0	
563060	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Amps A Ø	100.0	
563061	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
563062	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
563063	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
563064	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	9 Months Operations	0	
563065	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Current Tap Position	1L	
563066	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
563067	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
563068	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
563069	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
563070	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	General Comments	ok	
563071	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
563072	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
563073	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
563074	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
563075	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
563076	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
563077	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Max Tap Position	1R	
563078	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Min Tap Position	4L	
563079	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
563080	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
563081	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
563082	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
563083	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
563084	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Regulator As Left Counter	72987	
563085	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
563086	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Tank Leaks	None	
563087	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
563088	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
563089	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	LTC Operation Checked?	y	
563090	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	General Comments		
563091	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	85.0	
563092	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
563093	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	10.03	%
563094	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	10.80	%
563095	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	18.52	%
563096	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
563097	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	Follow-up Action Required?	n	
563098	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	All Connections OK?	y	
563099	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
563100	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
563101	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
563102	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC Operations Since Last Insp	607	
563103	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
563104	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC Min Tap Position	9L	
563105	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC Max Tap Position	2R	
563106	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC Current Tap Position	3L	
563107	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
563108	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC As Left Counter	48343	
563109	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC As Found Counter	48341	
563110	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	General Comments		
563111	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	General Comments		
563112	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
563113	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	Follow-up Action Required?	n	
563114	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
563115	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
563116	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
563117	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
563118	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
563119	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
563120	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
563121	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
563122	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
563123	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
563124	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
563125	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
563126	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
563127	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	35	°F
563128	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
563129	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
563130	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	General Comments		
563131	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
563132	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
563133	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
563134	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
563135	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
563136	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
563137	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
563138	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
563139	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
563140	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
563141	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
563142	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
563143	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
563144	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
563145	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
563146	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
563147	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
563148	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
563149	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
563150	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
563151	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
563152	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
563153	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
563154	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
563155	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
563156	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	Totalizer Meter Reading	.2456	
563157	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
563158	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
563159	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
563160	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
563161	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
563162	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Vegetation	None	
563163	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
563164	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
563165	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	General Comments		
563166	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
563167	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
563168	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
563169	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
563170	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
563171	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
563172	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Clear of Trash?	y	
563173	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
563174	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
563175	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
563176	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
563177	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
563178	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Clear of Trash?	y	
563179	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
563180	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
563181	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
563182	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
563183	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
563184	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
563185	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
563186	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
563187	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
563188	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
563189	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
563190	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
563191	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	General Comments	ok	
563192	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	General Comments	ok	
563193	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
563194	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
563195	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
563196	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	2059.20	kw
563197	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
563198	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
563199	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
563200	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
563201	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
563202	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
563203	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
563204	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
563205	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Oil Temp Max	50	°C
563206	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Oil Temp Present	20	°C
563207	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
563208	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
563209	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
563210	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
563211	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
563212	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
563213	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Current Tap Position	2L	
563214	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
563215	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
563216	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
563217	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
563218	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	General Comments	ok	
563219	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
563220	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
563221	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Min Tap Position	6L	
563222	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
563223	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
563224	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
563225	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
563226	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
563227	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Regulator As Left Counter	67314	
563228	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
563229	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Tank Leaks	None	
563230	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
563231	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	Follow-up Action Required?	n	
563232	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
563233	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
563234	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	General Comments	ok	
563235	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	General Comments	ok	
563236	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
563237	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	LTC Totalizer Reading	1964.80	kw
563238	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
563239	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
563240	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	Oil Temp Max	80	°C
563241	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	Oil Temp Present	40	°C
563242	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
563243	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
563244	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
563245	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
563246	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
563247	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
563248	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
563249	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
563250	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
563251	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
563252	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
563253	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
563254	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
563255	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
563256	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
563257	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
563258	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
563259	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
563260	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
563261	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
563262	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
563263	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Vegetation	None	
563264	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2019-02-19 00:00:00.000000	
563265	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
563266	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
563267	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	General Comments		
563268	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
563269	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Winding Temp Max	80	°C
563270	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Totalizer Meter Reading	.6432	
563271	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
563272	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Top Oil Temperature Present	40	°C
563273	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Top Oil Temperature Max	70	°C
563274	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
563275	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
563276	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
563277	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
563278	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
563279	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
563280	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
563281	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
563282	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
563283	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
563284	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
563285	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
563286	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
563287	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Current Tap Position	1L	
563288	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
563289	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
563290	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
563291	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
563292	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	General Comments	ok	
563293	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
563294	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Max Tap Position	1R	
563295	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Min Tap Position	5L	
563296	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
563297	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
563298	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
563299	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	LTC Totalizer Reading	11577.60	kw
563300	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
563301	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	General Comments		
563302	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
563303	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
563304	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
563305	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Regulator As Left Counter	35014	
563306	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
563307	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Tank Leaks	None	
563308	2/19/2019 12:59	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
563309	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Ground Lead 1 Resistance Set 1	.3	Micro Ohms
563310	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Ground Lead 2 Resistance Set 1	.4	Micro Ohms
563311	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Ground Lead 3 Resistance Set 1	.3	Micro Ohms
563312	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Tank Paint Condition	Good	
563313	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Switching Operations	1	
563314	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
563315	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Operations Counter AL	183	
563316	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Operations Counter AF	182	
563317	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
563318	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Maintenance Operations	0	
563319	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
563320	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Grounds in Place?	y	
563321	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	General Comments		
563322	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
563323	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
563324	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	General Comments		
563325	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	General Comments		
563326	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
563327	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Follow-up Action Required?	n	
563328	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Follow-up Action Required?	n	
563329	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
563330	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Current Tap Position	2L	
563331	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
563332	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
563333	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
563334	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
563335	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	General Comments	ok	
563336	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
563337	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Max Tap Position	3R	
563338	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Min Tap Position	6L	
563339	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
563340	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
563341	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
563342	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
563343	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
563344	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Regulator As Left Counter	66199	
563345	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
563346	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Tank Leaks	None	
563347	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
563348	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
563349	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
563350	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
563351	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
563352	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
563353	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Current Tap Position	1L	
563354	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
563355	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
563356	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
563357	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
563358	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	General Comments	ok	
563359	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
563360	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Max Tap Position	4R	
563361	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Min Tap Position	4L	
563362	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
563363	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
563364	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
563365	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
563366	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
563367	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Regulator As Left Counter	61622	
563368	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
563369	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Tank Leaks	None	
563370	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
563371	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	General Comments		
563372	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
563373	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	Follow-up Action Required?	n	
563374	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
563375	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
563376	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
563377	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
563378	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
563379	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
563380	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Unknown Operations	0	
563381	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
563382	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
563383	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
563384	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
563385	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
563386	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
563387	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
563388	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Winding Temp Present	40	°C
563389	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
563390	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
563391	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	473	
563392	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
563393	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
563394	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
563395	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
563396	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC As Left Counter	50216	
563397	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Equipment Properly Labeled?	y	
563398	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
563399	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
563400	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
563401	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
563402	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC As Found Counter	50216	
563403	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
563404	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	General Comments		
563405	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
563406	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
563407	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Operations B Ø	0	
563408	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Operations C Ø	0	
563409	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Operations Ground	0	
563410	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Follow-up Action Required?	n	
563411	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Follow-up Action Required?	n	
563412	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Foundation Condition	Good	
563413	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	General Comments		
563414	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	General Comments		
563415	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Grounds in Place?	y	
563416	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Heaters (All) Functioning?	y	
563417	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
563418	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Operations Counter AL	66	
563419	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Operations Counter AF	66	
563420	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Moisture and Leak Free?	y	
563421	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Maintenance Operations	0	
563422	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Heaters (All) Functioning?	y	
563423	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Grounds in Place?	y	
563424	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	General Comments	ok	
563425	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	General Comments	ok	
563426	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Foundation Condition	Good	
563427	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	BCH000454	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
563428	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	BCH000454	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
563429	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	BCH000454	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
563430	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	BCH000454	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
563431	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	BCH000454	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
563432	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Maintenance Operations	0	
563433	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Moisture and Leak Free?	y	
563434	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Operations Counter AF	153	
563435	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Operations Counter AL	154	
563436	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
563437	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Switching Operations	1	
563438	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Tank Paint Condition	Good	
563439	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Unknown Operations	0	
563440	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Follow-up Action Required?	n	
563441	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Follow-up Action Required?	n	
563442	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Operations Ground	0	
563443	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Operations C Ø	0	
563444	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Operations B Ø	0	
563445	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Operations A Ø	0	
563446	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
563447	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
563448	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
563449	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
563450	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
563451	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
563452	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Operations Ground	0	
563453	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Operations C Ø	0	
563454	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Operations B Ø	0	
563455	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Operations A Ø	0	
563456	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
563457	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
563458	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
563459	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
563460	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
563461	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
563462	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
563463	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Follow-up Action Required?	n	
563464	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
563465	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
563466	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
563467	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
563468	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
563469	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
563470	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
563471	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
563472	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
563473	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
563474	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
563475	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
563476	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
563477	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
563478	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
563479	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
563480	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
563481	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
563482	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
563483	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
563484	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Bushing Condition	Good	
563485	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Amps C Ø	428.0	
563486	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	9 Month Operations	4	
563487	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Accumulated Fault Duty A Ph V	.50	%
563488	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
563489	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Amps B Ø	422.0	
563490	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Amps A Ø	420.0	
563491	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Accumulated Fault Duty C Ph V	1.20	%
563492	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Accumulated Fault Duty B Ph V	1.20	%
563493	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
563494	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Amps A Ø	200.0	
563495	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Amps B Ø	202.0	
563496	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Amps C Ø	191.0	
563497	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Bushing Condition	Good	
563498	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Bushings Connection/Risers	Good	
563499	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
563500	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
563501	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
563502	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Cabinet Paint Condition	Good	
563503	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Accumulated Fault Duty A Ph V	1.20	%
563504	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	9 Month Operations	1	
563505	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Unknown Operations	0	
563506	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Tank Paint Condition	Good	
563507	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Switching Operations	0	
563508	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
563509	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
563510	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
563511	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Amps A Ø	0.0	
563512	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Amps B Ø	0.0	
563513	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Amps C Ø	0.0	
563514	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Bushing Condition	Good	
563515	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Bushings Connection/Risers	Good	
563516	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
563517	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
563518	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
563519	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
563520	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
563521	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
563522	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
563523	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
563524	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
563525	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
563526	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
563527	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
563528	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	General Comments	ok	
563529	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	General Comments	ok	
563530	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
563531	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
563532	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Cabinet Paint Condition	Good	
563533	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Equipment Properly Labeled?	y	
563534	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
563535	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
563536	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
563537	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
563538	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC Operations Since Last Insp	344	
563539	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC Min Tap Position	8L	
563540	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC Max Tap Position	4R	
563541	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	2769.12	kw
563542	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
563543	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
563544	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Oil Temp Max	45	°C
563545	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Oil Temp Present	35	°C
563546	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
563547	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
563548	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
563549	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
563550	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
563551	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
563552	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
563553	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
563554	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.3846	
563555	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC Current Tap Position	1L	
563556	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
563557	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC As Left Counter	69750	
563558	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
563559	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
563560	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
563561	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
563562	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
563563	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
563564	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
563565	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
563566	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
563567	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
563568	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
563569	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
563570	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
563571	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
563572	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
563573	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
563574	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
563575	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Top Oil Temperature Max	40	°C
563576	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Top Oil Temperature Present	25	°C
563577	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
563578	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Totalizer Meter Reading	.5484	
563579	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
563580	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
563581	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
563582	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
563583	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
563584	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
563585	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
563586	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
563587	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	22	
563588	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	27	
563589	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
563590	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
563591	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
563592	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
563593	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
563594	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
563595	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
563596	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
563597	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Current Tap Position	2L	
563598	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
563599	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
563600	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
563601	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0168	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
563602	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Winding Temp Max	50	°C
563603	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
563604	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	General Comments	ok	
563605	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
563606	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Max Tap Position	3R	
563607	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Min Tap Position	6L	
563608	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
563609	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
563610	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
563611	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
563612	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
563613	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Regulator As Left Counter	65397	
563614	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
563615	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Tank Leaks	None	
563616	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
563617	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
563618	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
563619	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
563620	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
563621	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Winding Temp Present	35	°C
563622	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
563623	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
563624	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	35	
563625	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	31	
563626	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
563627	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
563628	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
563629	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
563630	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
563631	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
563632	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
563633	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
563634	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
563635	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Oil Temp Present	30	°C
563636	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Oil Temp Max	50	°C
563637	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
563638	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
563639	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	LTC Totalizer Reading	8352.00	kw
563640	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
563641	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	General Comments		
563642	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	General Comments		
563643	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
563644	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
563645	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Follow-up Action Required?	n	
563646	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
563647	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
563648	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
563649	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
563650	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
563651	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
563652	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
563653	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
563654	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
563655	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
563656	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
563657	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
563658	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Unknown Operations	0	
563659	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Switching Operations	0	
563660	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Operations Counter AL	193	
563661	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Operations Counter AF	193	
563662	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Maintenance Operations	0	
563663	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
563664	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	General Comments		
563665	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Patrol Inspection	General Comments		
563666	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Follow-up Action Required?	n	
563667	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
563668	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Operations Ground	0	
563669	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Operations C Ø	0	
563670	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Operations B Ø	0	
563671	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Operations A Ø	0	
563672	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC As Found Counter	69748	
563673	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
563674	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
563675	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
563676	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
563677	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Amps C Ø	110.0	
563678	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Amps B Ø	170.0	
563679	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Amps A Ø	120.0	
563680	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
563681	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
563682	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
563683	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	9 Months Operations	0	
563684	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	General Comments		
563685	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
563686	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
563687	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
563688	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
563689	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
563690	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
563691	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
563692	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
563693	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
563694	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
563695	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
563696	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
563697	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	255.0	
563698	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	240.0	
563699	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	230.0	
563700	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	3.27	%
563701	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	3.27	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
563702	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	7.94	%
563703	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	CB0169	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
563704	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	Follow-up Action Required?	n	
563705	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
563706	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	General Comments		
563707	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
563708	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Equipment Properly Labeled?	y	
563709	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Cabinet Paint Condition	Good	
563710	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
563711	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
563712	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
563713	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Bushings Connection/Risers	Good	
563714	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Bushing Condition	Good	
563715	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Amps C Ø	75.0	
563716	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Amps B Ø	75.0	
563717	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	General Comments		
563718	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC As Found Counter	37494	
563719	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC As Left Counter	37494	
563720	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
563721	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC Current Tap Position	2R	
563722	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC Max Tap Position	8R	
563723	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC Min Tap Position	2L	
563724	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	8	°C
563725	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC Operations Since Last Insp	678	
563726	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
563727	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
563728	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
563729	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Amps A Ø	75.0	
563730	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Accumulated Fault Duty C Ph V	.53	%
563731	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
563732	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
563733	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Winding Temp Present	40	°C
563734	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Winding Temp Max	56	°C
563735	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Totalizer Meter Reading	.8700	
563736	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
563737	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
563738	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Accumulated Fault Duty B Ph V	1.58	%
563739	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Accumulated Fault Duty A Ph V	1.32	%
563740	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	9 Month Operations	0	
563741	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	All Connections OK?	y	
563742	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	Follow-up Action Required?	n	
563743	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	General Comments	ok	
563744	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	LTC Operation Checked?	y	
563745	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	LTC Output Voltage Level	121.5	VAC
563746	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	VRR Base Voltage AF	121.5	VAC
563747	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	VRR Base Voltage AL	121.5	VAC
563748	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	VRR Time Delay	60	Seconds
563749	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	General Comments		
563750	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	General Comments		
563751	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
563752	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
563753	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Follow-up Action Required?	n	
563754	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
563755	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
563756	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
563757	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
563758	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
563759	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
563760	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
563761	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
563762	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
563763	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
563764	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
563765	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
563766	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	LTCC000138	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
563767	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	LTCC000138	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
563768	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	LTCC000138	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
563769	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	LTCC000138	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
563770	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	LTCC000138	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
563771	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	LTCC000138	LTCControl	930-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
563772	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
563773	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
563774	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
563775	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
563776	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
563777	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
563778	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
563779	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
563780	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
563781	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
563782	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	General Comments		
563783	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
563784	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
563785	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
563786	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
563787	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	LTCC000138	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
563788	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	LTCC000138	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
563789	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	LTCC000138	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
563790	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
563791	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
563792	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
563793	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
563794	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
563795	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
563796	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
563797	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
563798	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
563799	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
563800	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	General Comments	ok	
563801	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
563802	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Max Tap Position	5L	
563803	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
563804	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
563805	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
563806	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	Follow-up Action Required?	n	
563807	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
563808	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	General Comments	ok	
563809	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Mechanism Patrol Inspection	General Comments	ok	
563810	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC As Found Counter	203317	
563811	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC As Left Counter	203327	
563812	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
563813	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC Current Tap Position	4R	
563814	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC Max Tap Position	7R	
563815	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC Min Tap Position	2R	
563816	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
563817	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
563818	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
563819	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
563820	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0611	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
563821	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0611	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
563822	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0611	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
563823	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0611	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
563824	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0611	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	55491	
563825	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0611	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	121.9	volts
563826	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0611	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
563827	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0611	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
563828	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0611	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
563829	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0611	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
563830	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0611	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	12L	
563831	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0611	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	7L	
563832	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0611	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
563833	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0611	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	had to adjust base voltage	
563834	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0611	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
563835	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0611	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
563836	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0611	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
563837	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0611	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
563838	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0611	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	6L	
563839	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0611	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
563840	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0611	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
563841	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0611	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
563842	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0611	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
563843	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0611	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
563844	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
563845	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
563846	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Winding Temp Present	25	°C
563847	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Winding Temp Max	35	°C
563848	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Totalizer Meter Reading	.6410	
563849	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
563850	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
563851	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
563852	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
563853	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
563854	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
563855	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
563856	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
563857	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Oil Temp Present	15	°C
563858	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Oil Temp Max	25	°C
563859	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
563860	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
563861	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	LTC Totalizer Reading	6153.60	kw
563862	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
563863	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
563864	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
563865	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
563866	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
563867	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
563868	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
563869	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
563870	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
563871	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
563872	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
563873	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
563874	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
563875	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
563876	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
563877	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
563878	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
563879	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
563880	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
563881	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
563882	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
563883	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
563884	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
563885	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
563886	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
563887	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
563888	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
563889	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
563890	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
563891	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	General Comments	oi	
563892	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	General Comments	ok	
563893	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
563894	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
563895	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
563896	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	5351.04	kw
563897	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
563898	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
563899	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Oil Temp Max	40	°C
563900	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Oil Temp Present	30	°C
563901	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
563902	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
563903	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
563904	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
563905	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
563906	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
563907	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
563908	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
563909	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Totalizer Meter Reading	1.1148	
563910	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
563911	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
563912	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
563913	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	697	
563914	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	693	
563915	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
563916	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	4	
563917	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
563918	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.600	millivolts
563919	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	27.6	VDC
563920	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
563921	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
563922	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
563923	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Regulator As Left Counter	59050	
563924	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
563925	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Tank Leaks	None	
563926	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
563927	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
563928	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
563929	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
563930	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
563931	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
563932	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Switching Operations	4	
563933	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
563934	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
563935	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
563936	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
563937	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
563938	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
563939	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
563940	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
563941	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	General Comments	ok	
563942	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
563943	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
563944	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Foundation Condition	Good	
563945	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
563946	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
563947	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
563948	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
563949	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
563950	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
563951	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
563952	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Tank Paint Condition	Good	
563953	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Unknown Operations	0	
563954	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
563955	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	11.28	%
563956	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	11.01	%
563957	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	7.25	%
563958	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
563959	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
563960	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	130.0	
563961	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
563962	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
563963	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
563964	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	General Comments	ok	
563965	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
563966	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
563967	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
563968	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
563969	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
563970	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
563971	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
563972	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
563973	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
563974	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
563975	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
563976	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
563977	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Follow-up Action Required?	n	
563978	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Follow-up Action Required?	n	
563979	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Foundation Condition	Good	
563980	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	General Comments	ok	
563981	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	General Comments	ok	
563982	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
563983	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	519	
563984	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	8L	
563985	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	8R	
563986	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	2R	
563987	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
563988	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Grounds in Place?	y	
563989	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Heaters (All) Functioning?	y	
563990	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Maintenance Operations	0	
563991	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Moisture and Leak Free?	y	
563992	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Operations Counter AF	175	
563993	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
563994	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
563995	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
563996	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
563997	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Operations Counter AL	175	
563998	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Switching Operations	0	
563999	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Tank Paint Condition	Good	
564000	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Unknown Operations	0	
564001	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	11032	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
564002	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	11032	
564003	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
564004	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
564005	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
564006	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
564007	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
564008	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
564009	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
564010	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
564011	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
564012	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
564013	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
564014	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
564015	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	35	°F
564016	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
564017	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Amps A Ø	0.0	
564018	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Amps B Ø	0.0	
564019	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Amps C Ø	0.0	
564020	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
564021	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
564022	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
564023	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
564024	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
564025	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	30.00	
564026	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
564027	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
564028	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	General Comments		
564029	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	General Comments		
564030	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
564031	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
564032	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
564033	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
564034	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Accumulated Fault Duty C Ph V	5.01	%
564035	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Accumulated Fault Duty B Ph V	5.89	%
564036	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Accumulated Fault Duty A Ph V	6.78	%
564037	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
564038	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
564039	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
564040	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	9 Month Operations	11	
564041	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
564042	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
564043	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
564044	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
564045	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
564046	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
564047	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
564048	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
564049	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
564050	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
564051	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	9 Month Operations	4	
564052	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Accumulated Fault Duty A Ph V	4.10	%
564053	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Accumulated Fault Duty B Ph V	4.10	%
564054	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Accumulated Fault Duty C Ph V	4.10	%
564055	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Amps A Ø	359.0	
564056	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Amps B Ø	359.0	
564057	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	BCH000520	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
564058	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	BCH000520	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
564059	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	BCH000520	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
564060	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	BCH000520	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
564061	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	9 Month Operations	9	
564062	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
564063	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Accumulated Fault Duty B Ph V	.47	%
564064	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
564065	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Amps C Ø	419.0	
564066	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Bushing Condition	Good	
564067	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Bushings Connection/Risers	Good	
564068	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
564069	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
564070	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
564071	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Cabinet Paint Condition	Good	
564072	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Equipment Properly Labeled?	y	
564073	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
564074	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
564075	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
564076	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
564077	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
564078	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
564079	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
564080	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
564081	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Operations B Ø	0	
564082	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
564083	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
564084	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
564085	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
564086	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
564087	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
564088	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
564089	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Operations C Ø	0	
564090	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Operations Ground	0	
564091	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Bushings Connection/Risers	Good	
564092	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
564093	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
564094	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
564095	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Cabinet Paint Condition	Good	
564096	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Equipment Properly Labeled?	y	
564097	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
564098	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
564099	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
564100	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Operations A Ø	0	
564101	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Operations B Ø	0	
564102	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Operations C Ø	0	
564103	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Operations Ground	0	
564104	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Follow-up Action Required?	n	
564105	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
564106	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
564107	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	140.0	
564108	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Follow-up Action Required?	n	
564109	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Foundation Condition	Good	
564110	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	160.0	
564111	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	175.0	
564112	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
564113	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
564114	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
564115	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
564116	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
564117	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
564118	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
564119	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
564120	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
564121	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
564122	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
564123	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
564124	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
564125	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	General Comments	ok	
564126	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
564127	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.87	%
564128	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
564129	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Foundation Condition	Good	
564130	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
564131	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
564132	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
564133	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
564134	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
564135	2/19/2019 11:40	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
564136	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.87	%
564137	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	3.94	%
564138	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	8	
564139	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	General Comments		
564140	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	General Comments		
564141	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Grounds in Place?	y	
564142	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Heaters (All) Functioning?	y	
564143	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Maintenance Operations	0	
564144	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Moisture and Leak Free?	y	
564145	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Operations Counter AF	230	
564146	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Operations Counter AL	234	
564147	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
564148	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
564149	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
564150	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
564151	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC Operations Since Last Insp	677	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
564152	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
564153	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
564154	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
564155	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
564156	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
564157	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	15	°C
564158	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	20	°C
564159	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
564160	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC Max Tap Position	12L	
564161	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC Current Tap Position	10L	
564162	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
564163	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC As Left Counter	25916	
564164	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC As Found Counter	25916	
564165	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
564166	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Vegetation	None	
564167	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
564168	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
564169	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
564170	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
564171	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
564172	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	General Comments		
564173	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
564174	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
564175	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
564176	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Clear of Trash?	y	
564177	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
564178	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
564179	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
564180	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
564181	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
564182	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
564183	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
564184	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
564185	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	General Comments		
564186	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	General Comments		
564187	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
564188	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	Follow-up Action Required?	n	
564189	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	General Comments		
564190	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
564191	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
564192	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Operations Counter AF	272	
564193	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Operations Counter AL	272	
564194	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
564195	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
564196	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
564197	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
564198	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
564199	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
564200	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
564201	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Amps A Ø	180.0	
564202	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Amps B Ø	155.0	
564203	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Amps C Ø	150.0	
564204	2/19/2019 15:24	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Bushing Condition	Good	
564205	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Equipment Properly Labeled?	y	
564206	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Cabinet Paint Condition	Good	
564207	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
564208	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
564209	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
564210	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Bushings Connection/Risers	Good	
564211	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Bushing Condition	Good	
564212	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Amps C Ø	100.0	
564213	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Amps B Ø	110.0	
564214	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
564215	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
564216	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
564217	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	n	
564218	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
564219	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
564220	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
564221	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
564222	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Amps A Ø	110.0	
564223	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Accumulated Fault Duty C Ph V	.52	%
564224	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Accumulated Fault Duty B Ph V	.52	%
564225	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Accumulated Fault Duty A Ph V	.39	%
564226	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	9 Month Operations	4	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
564227	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
564228	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
564229	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
564230	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
564231	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0	psi
564232	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
564233	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
564234	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
564235	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
564236	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
564237	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
564238	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
564239	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
564240	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
564241	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	General Comments		
564242	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
564243	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
564244	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
564245	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
564246	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	General Comments	out of service	
564247	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	General Comments		
564248	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
564249	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
564250	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
564251	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
564252	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
564253	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
564254	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	General Comments		
564255	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs 20 amp fuse not replaced	
564256	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
564257	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
564258	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
564259	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
564260	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	Oil Temp Present	278	°C
564261	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Grounds in Place?	y	
564262	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	General Comments	ok	
564263	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
564264	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
564265	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
564266	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Amps A Ø	50.0	
564267	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Amps B Ø	70.0	
564268	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Amps C Ø	20.0	
564269	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
564270	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
564271	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
564272	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
564273	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
564274	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
564275	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
564276	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
564277	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
564278	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
564279	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	General Comments		
564280	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
564281	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
564282	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Operations Counter	196	
564283	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
564284	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
564285	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
564286	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
564287	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
564288	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
564289	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
564290	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
564291	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
564292	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
564293	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
564294	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
564295	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
564296	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
564297	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
564298	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	305	
564299	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	309	
564300	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
564301	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
564302	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
564303	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
564304	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	General Comments	ok	
564305	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
564306	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
564307	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Foundation Condition	Good	
564308	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Follow-up Action Required?	n	
564309	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Follow-up Action Required?	n	
564310	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Operations Ground	0	
564311	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Operations C Ø	0	
564312	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Operations B Ø	0	
564313	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Operations A Ø	0	
564314	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
564315	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
564316	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
564317	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
564318	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
564319	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
564320	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
564321	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Maintenance Operations	0	
564322	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
564323	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
564324	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	General Comments		
564325	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
564326	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
564327	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
564328	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
564329	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
564330	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
564331	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
564332	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
564333	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
564334	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	475	
564335	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	471	
564336	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
564337	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	4	
564338	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
564339	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	General Comments		
564340	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Patrol Inspection	General Comments		
564341	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Follow-up Action Required?	n	
564342	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
564343	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
564344	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
564345	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
564346	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
564347	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
564348	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
564349	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
564350	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
564351	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
564352	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
564353	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
564354	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
564355	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
564356	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
564357	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	VRR Time Delay	30	Seconds
564358	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
564359	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
564360	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
564361	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
564362	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
564363	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
564364	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
564365	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
564366	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
564367	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
564368	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
564369	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
564370	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
564371	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	70.0	
564372	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
564373	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
564374	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
564375	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
564376	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
564377	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
564378	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Follow-up Action Required?	n	
564379	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
564380	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
564381	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
564382	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
564383	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
564384	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
564385	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
564386	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
564387	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
564388	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
564389	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
564390	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
564391	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
564392	2/19/2019 13:55	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Foundation Condition	Good	
564393	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
564394	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
564395	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
564396	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
564397	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
564398	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
564399	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	1	
564400	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
564401	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
564402	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
564403	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
564404	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
564405	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
564406	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Unknown Operations	0	
564407	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Switching Operations	0	
564408	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Operations Counter AL	363	
564409	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Operations Counter AF	363	
564410	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
564411	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
564412	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
564413	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
564414	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
564415	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
564416	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
564417	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
564418	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
564419	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
564420	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
564421	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	110.0	
564422	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
564423	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	10.98	%
564424	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	10.40	%
564425	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	10.98	%
564426	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	14	
564427	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
564428	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
564429	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
564430	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
564431	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	17	
564432	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
564433	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
564434	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Clear of Trash?	y	
564435	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
564436	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
564437	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
564438	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
564439	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
564440	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
564441	2/19/2019 12:44	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	General Comments		
564442	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Oil Temp Present	10	°C
564443	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Percent Thermal Load H2 Max	0	%
564444	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Percent Thermal Load X2 Max	0	%
564445	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Percent Thermal Load Y2 Max	0	%
564446	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
564447	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
564448	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
564449	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
564450	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
564451	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
564452	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
564453	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	General Comments		
564454	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
564455	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
564456	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Foundation Condition	Good	
564457	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
564458	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
564459	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
564460	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
564461	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
564462	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
564463	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Unknown Operations	0	
564464	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
564465	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
564466	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
564467	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	9 Months Operations	1	
564468	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
564469	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
564470	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
564471	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Amps A Ø	75.0	
564472	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Amps B Ø	50.0	
564473	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Amps C Ø	75.0	
564474	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
564475	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
564476	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
564477	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
564478	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
564479	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Vegetation	None	
564480	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
564481	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
564482	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	General Comments		
564483	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
564484	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
564485	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
564486	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
564487	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
564488	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Clear of Trash?	y	
564489	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
564490	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
564491	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Operations A Ø	0	
564492	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Switching Operations	0	
564493	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Operations Counter AL	409	
564494	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Operations Counter AF	409	
564495	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Maintenance Operations	0	
564496	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
564497	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	General Comments		
564498	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Patrol Inspection	General Comments		
564499	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Follow-up Action Required?	n	
564500	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
564501	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Operations Ground	0	
564502	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Operations C Ø	0	
564503	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Operations B Ø	0	
564504	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
564505	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
564506	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
564507	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
564508	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
564509	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
564510	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	4	
564511	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
564512	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
564513	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
564514	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
564515	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
564516	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
564517	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	22	
564518	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	18	
564519	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
564520	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
564521	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
564522	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
564523	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
564524	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
564525	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
564526	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
564527	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
564528	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
564529	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Heaters (All) Functioning?	y	
564530	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Maintenance Operations	0	
564531	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Moisture and Leak Free?	y	
564532	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Operations Counter AF	148	
564533	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Operations Counter AL	148	
564534	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Switching Operations	0	
564535	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
564536	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
564537	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	135.0	
564538	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	150.0	
564539	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Tank Paint Condition	Good	
564540	2/19/2019 10:08	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Unknown Operations	0	
564541	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
564542	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	17.5	
564543	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10	
564544	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	27.6	VDC
564545	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
564546	2/19/2019 7:50	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Oil Temp Max	40	°C
564547	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
564548	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
564549	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
564550	2/19/2019 12:31	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
564551	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
564552	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
564553	2/19/2019 10:53	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	General Comments		
564554	2/19/2019 13:08	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
564555	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
564556	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	General Comments	barbwire rusty ,large gap in back of lot, and back right post is washed out.	
564557	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
564558	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
564559	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
564560	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
564561	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
564562	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
564563	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
564564	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
564565	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
564566	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	General Comments		
564567	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
564568	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
564569	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
564570	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Min Tap Position	15L	
564571	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
564572	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
564573	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
564574	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
564575	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
564576	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
564577	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Regulator As Left Counter	358686	
564578	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
564579	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
564580	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
564581	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
564582	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
564583	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
564584	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
564585	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Tank Leaks	None	
564586	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
564587	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
564588	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
564589	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Follow-up Action Required?	n	
564590	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
564591	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Foundation Condition	Good	
564592	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	General Comments		
564593	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	General Comments		
564594	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Grounds in Place?	y	
564595	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
564596	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
564597	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
564598	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
564599	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	General Comments		
564600	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
564601	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
564602	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
564603	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
564604	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
564605	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
564606	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
564607	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Amps A Ø	20.0	
564608	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Amps B Ø	20.0	
564609	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Amps C Ø	20.0	
564610	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
564611	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
564612	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Maintenance Operations	0	
564613	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Moisture and Leak Free?	y	
564614	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Operations Counter AF	168	
564615	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Operations Counter AL	168	
564616	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
564617	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Switching Operations	0	
564618	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Tank Paint Condition	Good	
564619	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
564620	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	VRR Time Delay	60	Seconds
564621	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
564622	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
564623	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
564624	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	LTC Operation Checked?	y	
564625	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	General Comments		
564626	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	Follow-up Action Required?	n	
564627	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	All Connections OK?	y	
564628	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Unknown Operations	0	
564629	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Operations A Ø	0	
564630	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Heaters (All) Functioning?	y	
564631	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Operations B Ø	0	
564632	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Operations C Ø	0	
564633	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Operations Ground	0	
564634	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Follow-up Action Required?	n	
564635	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Follow-up Action Required?	n	
564636	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Foundation Condition	Good	
564637	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	General Comments		
564638	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
564639	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
564640	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	General Comments		
564641	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
564642	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
564643	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
564644	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
564645	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
564646	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
564647	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
564648	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Grounds in Place?	y	
564649	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Heaters (All) Functioning?	y	
564650	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Maintenance Operations	0	
564651	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
564652	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
564653	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
564654	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
564655	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
564656	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
564657	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
564658	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Bushings Connection/Risers	Good	
564659	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Bushing Condition	Good	
564660	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Operations C Ø	0	
564661	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Operations Ground	0	
564662	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Follow-up Action Required?	n	
564663	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Amps A Ø	100.0	
564664	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Amps B Ø	141.0	
564665	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Amps C Ø	125.0	
564666	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
564667	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
564668	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
564669	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
564670	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
564671	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
564672	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
564673	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
564674	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
564675	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
564676	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
564677	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
564678	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
564679	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
564680	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
564681	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
564682	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
564683	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
564684	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
564685	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Follow-up Action Required?	n	
564686	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
564687	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
564688	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	General Comments		
564689	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
564690	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
564691	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
564692	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	General Comments		
564693	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
564694	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
564695	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Operations Counter	49	
564696	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
564697	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Tank Leaks	None	
564698	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
564699	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	9 Month Operations	1	
564700	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
564701	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
564702	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
564703	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
564704	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
564705	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	General Comments		
564706	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
564707	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
564708	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Foundation Condition	Good	
564709	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
564710	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
564711	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
564712	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
564713	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
564714	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
564715	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
564716	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Accumulated Fault Duty B Ph V	.22	%
564717	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
564718	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Amps A Ø	0.0	
564719	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Amps B Ø	0.0	
564720	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Amps C Ø	16.0	
564721	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Bushing Condition	Good	
564722	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Bushings Connection/Risers	Good	
564723	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
564724	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
564725	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
564726	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Cabinet Paint Condition	Good	
564727	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Equipment Properly Labeled?	y	
564728	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Unknown Operations	0	
564729	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
564730	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
564731	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
564732	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Operations A Ø	0	
564733	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Operations B Ø	0	
564734	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
564735	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
564736	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Cabinet Paint Condition	Good	
564737	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
564738	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
564739	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Tank Paint Condition	Good	
564740	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Switching Operations	4	
564741	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
564742	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
564743	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
564744	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Grounds in Place?	y	
564745	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	General Comments	Cap bank disconnected from buss	
564746	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
564747	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
564748	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Follow-up Action Required?	n	
564749	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
564750	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
564751	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Capacitor Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
564752	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
564753	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Bushing Condition	Good	
564754	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Amps A Ø	20.0	
564755	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Amps B Ø	20.0	
564756	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Amps C Ø	20.0	
564757	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
564758	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Vegetation	None	
564759	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
564760	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
564761	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	General Comments		
564762	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
564763	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
564764	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
564765	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
564766	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
564767	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
564768	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
564769	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
564770	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Clear of Trash?	y	
564771	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
564772	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	General Comments		
564773	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
564774	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
564775	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
564776	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
564777	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
564778	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
564779	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
564780	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	General Comments		
564781	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
564782	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Operations Counter	141	
564783	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
564784	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
564785	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	All Connections OK?	y	
564786	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Operations Counter AF	88	
564787	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Moisture and Leak Free?	y	
564788	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
564789	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
564790	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
564791	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
564792	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
564793	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Operations Counter	252	
564794	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
564795	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	General Comments		
564796	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
564797	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Amps C Ø	60.0	
564798	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Amps B Ø	60.0	
564799	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Amps A Ø	60.0	
564800	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
564801	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
564802	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
564803	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
564804	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
564805	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
564806	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
564807	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
564808	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
564809	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
564810	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
564811	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	9 Month Operations	27	
564812	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	General Comments	added 1 psi nitrogen	
564813	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
564814	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	LTC Totalizer Reading	4265.28	kw
564815	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
564816	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
564817	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Oil Temp Max	72	°C
564818	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Oil Temp Present	34	°C
564819	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
564820	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
564821	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
564822	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
564823	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
564824	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
564825	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
564826	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Totalizer Meter Reading	.8886	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
564827	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
564828	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
564829	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Operations Counter AL	92	
564830	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
564831	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Tank Leaks	None	
564832	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
564833	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	LTC Operation Checked?	y	
564834	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
564835	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
564836	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
564837	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
564838	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	VRR Time Delay	60	Seconds
564839	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
564840	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
564841	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
564842	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
564843	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
564844	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
564845	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
564846	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
564847	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
564848	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Panels Dusted?	y	
564849	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
564850	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
564851	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	General Comments		
564852	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
564853	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
564854	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Floor Swept?	y	
564855	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
564856	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
564857	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Evidence of Insects	None	
564858	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
564859	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
564860	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
564861	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
564862	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
564863	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
564864	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
564865	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
564866	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Panels Dusted?	y	
564867	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
564868	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	General Comments		
564869	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
564870	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
564871	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Floor Swept?	y	
564872	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	LTCC000186	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
564873	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	LTCC000186	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
564874	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	LTCC000186	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
564875	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	LTCC000186	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
564876	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	LTCC000186	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125.1	VAC
564877	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	LTCC000186	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
564878	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	LTCC000186	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
564879	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
564880	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
564881	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Evidence of Insects	None	
564882	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
564883	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
564884	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
564885	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	LTCC000186	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
564886	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BCH000533	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
564887	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BCH000533	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
564888	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BCH000533	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
564889	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BCH000533	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
564890	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BCH000533	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
564891	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BCH000533	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
564892	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BCH000533	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
564893	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Chipped	
564894	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
564895	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
564896	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
564897	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
564898	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
564899	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
564900	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
564901	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
564902	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
564903	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
564904	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
564905	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
564906	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
564907	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
564908	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
564909	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
564910	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
564911	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
564912	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
564913	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
564914	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
564915	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
564916	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
564917	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
564918	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
564919	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	General Comments	Barbed wire very rusty	
564920	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
564921	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
564922	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	Oil Temp Present	40	°C
564923	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	Oil Temp Max	60	°C
564924	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
564925	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
564926	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	LTC Totalizer Reading	4138.56	kw
564927	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
564928	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	General Comments		
564929	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	General Comments		
564930	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
564931	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
564932	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	Follow-up Action Required?	n	
564933	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
564934	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
564935	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
564936	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
564937	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
564938	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
564939	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
564940	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
564941	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC Operations Since Last Insp	1170	
564942	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
564943	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC Min Tap Position	6L	
564944	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC Max Tap Position	6R	
564945	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC Current Tap Position	3R	
564946	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
564947	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
564948	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
564949	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
564950	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC As Left Counter	43491	
564951	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC As Found Counter	43482	
564952	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	General Comments		
564953	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
564954	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	Follow-up Action Required?	n	
564955	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	All Connections OK?	y	
564956	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	Follow-up Action Required?	n	
564957	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	General Comments		
564958	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
564959	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Foundation Condition	Good	
564960	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Follow-up Action Required?	n	
564961	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Follow-up Action Required?	n	
564962	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Fault Operations	0	
564963	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
564964	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
564965	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
564966	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
564967	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
564968	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
564969	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
564970	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
564971	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
564972	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
564973	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	General Comments		
564974	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
564975	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
564976	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
564977	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
564978	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
564979	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
564980	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
564981	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
564982	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
564983	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
564984	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
564985	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
564986	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
564987	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
564988	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
564989	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
564990	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Bushing Oil Level	Good	
564991	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Bushing Condition	Good	
564992	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
564993	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
564994	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Air Pressure OK?	y	
564995	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Air Leaks	None	
564996	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
564997	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
564998	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
564999	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Clear of Trash?	y	
565000	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
565001	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
565002	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
565003	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
565004	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BAT000497	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
565005	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BAT000497	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
565006	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BAT000497	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
565007	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BAT000497	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
565008	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BAT000497	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
565009	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
565010	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
565011	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
565012	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
565013	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
565014	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
565015	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
565016	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
565017	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
565018	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
565019	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
565020	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Unknown Operations	0	
565021	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
565022	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
565023	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Tank Paint Condition	Good	
565024	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Tank Leaks	None	
565025	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
565026	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
565027	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
565028	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Switching Operations	0	
565029	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
565030	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
565031	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2019-02-18 00:00:00.000000	
565032	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
565033	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
565034	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
565035	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
565036	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Crumbling	
565037	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
565038	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	General Comments		
565039	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Operations Counter AL	55	
565040	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Operations Counter AF	55	
565041	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Number of Ops last 9 Months	2	
565042	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
565043	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Maintenance Operations	0	
565044	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Heaters (All) Functioning?	y	
565045	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Grounds in Place?	y	
565046	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	General Comments	High side bushing on back of the transformer is chipped.	
565047	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
565048	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
565049	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
565050	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	LTC Operations Since Last Insp	1035	
565051	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	LTC Min Tap Position	3L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
565052	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	LTC Max Tap Position	9R	
565053	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	LTC Current Tap Position	6R	
565054	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
565055	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	LTC As Left Counter	31544	
565056	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	LTC As Found Counter	31536	
565057	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Mechanism Patrol Inspection	General Comments		
565058	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	General Comments		
565059	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
565060	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	Follow-up Action Required?	n	
565061	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Unknown Operations	0	
565062	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Tank Paint Condition	Good	
565063	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Switching Operations	0	
565064	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
565065	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
565066	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
565067	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
565068	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
565069	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
565070	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
565071	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	General Comments		
565072	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
565073	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
565074	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	400	
565075	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
565076	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Vegetation	None	
565077	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	General Comments		
565078	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
565079	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
565080	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
565081	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
565082	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	General Comments		
565083	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
565084	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	General Comments		
565085	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
565086	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
565087	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
565088	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
565089	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
565090	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
565091	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Clear of Trash?	y	
565092	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
565093	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
565094	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
565095	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Accumulated Fault Duty B Ph V	.40	%
565096	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Accumulated Fault Duty A Ph V	.40	%
565097	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	9 Month Operations	7	
565098	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
565099	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
565100	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
565101	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
565102	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
565103	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Vegetation	None	
565104	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
565105	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
565106	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	General Comments		
565107	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
565108	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
565109	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
565110	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
565111	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
565112	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
565113	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Clear of Trash?	y	
565114	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
565115	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
565116	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
565117	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
565118	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
565119	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
565120	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Accumulated Fault Duty B Ph V	15.70	%
565121	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Accumulated Fault Duty C Ph V	12.45	%
565122	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Amps A Ø	130.0	
565123	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Amps B Ø	130.0	
565124	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Amps C Ø	120.0	
565125	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Bushing Condition	Good	
565126	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
565127	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
565128	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
565129	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
565130	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	BAT000431	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
565131	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	BAT000431	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
565132	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	BAT000431	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
565133	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	BAT000431	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
565134	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	BAT000431	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
565135	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	BAT000431	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
565136	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BCH000226	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
565137	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BCH000226	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
565138	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BCH000226	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
565139	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BCH000226	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
565140	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BCH000226	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
565141	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	BAT000431	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
565142	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	BAT000431	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
565143	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	BCH000222	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
565144	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	BCH000222	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
565145	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
565146	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
565147	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Accumulated Fault Duty A Ph V	17.86	%
565148	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	9 Month Operations	1	
565149	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	LTCC000559	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
565150	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	LTCC000559	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
565151	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	LTCC000559	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
565152	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	LTCC000559	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
565153	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	LTCC000559	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
565154	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	LTCC000559	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
565155	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	LTCC000559	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
565156	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	LTCC000559	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
565157	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	LTCC000559	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
565158	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Unknown Operations	0	
565159	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
565160	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC Operations Since Last Insp	133	
565161	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC Min Tap Position	5L	
565162	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
565163	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC Current Tap Position	2L	
565164	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
565165	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC As Left Counter	100133	
565166	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Tank Paint Condition	Good	
565167	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Switching Operations	4	
565168	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
565169	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Operations Counter AL	99	
565170	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Operations Counter AF	95	
565171	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Moisture and Leak Free?	y	
565172	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Maintenance Operations	0	
565173	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Heaters (All) Functioning?	y	
565174	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Grounds in Place?	y	
565175	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	General Comments		
565176	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	General Comments		
565177	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Foundation Condition	Good	
565178	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Follow-up Action Required?	n	
565179	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Follow-up Action Required?	n	
565180	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Fault Operations Ground	0	
565181	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Fault Operations C Ø	0	
565182	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Fault Operations B Ø	0	
565183	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Fault Operations A Ø	0	
565184	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
565185	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
565186	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
565187	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Equipment Properly Labeled?	y	
565188	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Cabinet Paint Condition	Good	
565189	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
565190	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
565191	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
565192	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Bushings Connection/Risers	Good	
565193	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Bushing Condition	Good	
565194	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Amps C Ø	60.0	
565195	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Amps B Ø	75.0	
565196	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Amps A Ø	120.0	
565197	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
565198	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
565199	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
565200	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
565201	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
565202	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
565203	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
565204	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Vegetation	None	
565205	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
565206	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
565207	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
565208	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	30	°C
565209	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Cabinet Paint Condition	Good	
565210	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	30.00	
565211	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
565212	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
565213	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
565214	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
565215	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
565216	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
565217	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
565218	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	General Comments		
565219	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
565220	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	37.50	
565221	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	21604.80	kw
565222	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
565223	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	875	psi
565224	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
565225	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
565226	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
565227	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
565228	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
565229	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
565230	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
565231	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
565232	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
565233	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
565234	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
565235	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
565236	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	Totalizer Meter Reading	.5748	
565237	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
565238	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
565239	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
565240	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
565241	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
565242	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
565243	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
565244	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
565245	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
565246	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	General Comments		
565247	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
565248	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
565249	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
565250	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
565251	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
565252	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Foundation Condition	Good	
565253	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
565254	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	General Comments		
565255	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
565256	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
565257	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
565258	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
565259	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
565260	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
565261	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
565262	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
565263	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
565264	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
565265	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
565266	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
565267	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
565268	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
565269	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
565270	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
565271	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	BCH000222	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
565272	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	BCH000222	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.7	VDC
565273	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	BCH000222	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.7	VDC
565274	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	BAT000431	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
565275	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	BAT000431	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
565276	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	BAT000431	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
565277	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	BAT000431	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
565278	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	BAT000431	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
565279	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	BAT000431	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
565280	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	BAT000431	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
565281	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Totalizer Meter Reading	.1644	
565282	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
565283	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
565284	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
565285	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
565286	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
565287	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
565288	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	Winding Temp Present	15	°C
565289	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	Winding Temp Max	0	°C
565290	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	1.5432	
565291	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	14000	
565292	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
565293	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
565294	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
565295	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
565296	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
565297	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Oil Temp Present	29	°C
565298	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Oil Temp Max	51	°C
565299	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
565300	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
565301	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	394.56	kw
565302	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
565303	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
565304	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
565305	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
565306	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	General Comments		
565307	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	General Comments		
565308	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
565309	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
565310	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
565311	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
565312	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
565313	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
565314	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
565315	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
565316	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
565317	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
565318	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
565319	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
565320	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
565321	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
565322	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
565323	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
565324	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
565325	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
565326	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
565327	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
565328	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
565329	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
565330	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
565331	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
565332	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
565333	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	15	°C
565334	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
565335	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
565336	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
565337	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
565338	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
565339	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
565340	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
565341	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Evidence of Insects	None	
565342	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
565343	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
565344	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Floor Swept?	y	
565345	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
565346	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
565347	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	General Comments		
565348	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
565349	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
565350	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Panels Dusted?	y	
565351	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
565352	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
565353	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Vegetation	None	
565354	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
565355	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	General Comments		
565356	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
565357	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
565358	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
565359	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
565360	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
565361	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Clear of Trash?	y	
565362	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
565363	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
565364	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
565365	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
565366	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
565367	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
565368	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
565369	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
565370	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
565371	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
565372	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
565373	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
565374	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
565375	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
565376	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
565377	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
565378	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
565379	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
565380	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	General Comments		
565381	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
565382	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
565383	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
565384	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Clear of Obstacles?	n	
565385	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Clear of Trash?	y	
565386	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Poor	
565387	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	n	
565388	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	n	
565389	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
565390	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
565391	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
565392	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
565393	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
565394	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
565395	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
565396	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
565397	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
565398	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
565399	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	Oil Temp Present	47	°C
565400	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	Oil Temp Max	60	°C
565401	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
565402	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
565403	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	LTC Totalizer Reading	4501.44	kw
565404	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
565405	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
565406	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	General Comments		
565407	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	General Comments		
565408	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Tank Leaks	None	
565409	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
565410	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
565411	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Regulator As Left Counter	189519	
565412	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
565413	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
565414	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
565415	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
565416	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
565417	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Min Tap Position	15L	
565418	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
565419	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
565420	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	General Comments		
565421	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
565422	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
565423	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
565424	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
565425	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
565426	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
565427	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
565428	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
565429	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
565430	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
565431	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
565432	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Tank Leaks	None	
565433	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
565434	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
565435	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Regulator As Left Counter	400219	
565436	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
565437	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
565438	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
565439	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
565440	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
565441	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
565442	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
565443	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
565444	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	General Comments		
565445	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
565446	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
565447	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
565448	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
565449	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
565450	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
565451	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
565452	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
565453	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
565454	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
565455	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
565456	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	BCH000493	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
565457	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	BCH000493	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
565458	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	BCH000493	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
565459	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	BCH000493	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
565460	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	BCH000493	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
565461	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
565462	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
565463	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
565464	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
565465	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	BCH000493	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
565466	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
565467	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
565468	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Totalizer Meter Reading	.0036	
565469	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
565470	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
565471	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
565472	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
565473	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Follow-up Action Required?	n	
565474	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
565475	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
565476	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	General Comments		
565477	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	General Comments	added nitrogen	
565478	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
565479	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
565480	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
565481	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
565482	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
565483	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Oil Temp Present	25	°C
565484	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Oil Temp Max	35	°C
565485	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
565486	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	LTC Totalizer Reading	17.28	kw
565487	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
565488	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	Follow-up Action Required?	n	
565489	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
565490	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
565491	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
565492	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
565493	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
565494	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
565495	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
565496	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
565497	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
565498	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
565499	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
565500	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
565501	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
565502	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
565503	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
565504	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
565505	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	General Comments	Drive has several ruts and potholes, also standing water in the station.	
565506	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Vegetation	None	
565507	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
565508	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
565509	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
565510	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
565511	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
565512	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
565513	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
565514	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
565515	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	General Comments		
565516	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
565517	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
565518	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
565519	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
565520	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
565521	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
565522	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
565523	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
565524	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
565525	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	Follow-up Action Required?	n	
565526	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
565527	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	General Comments		
565528	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	General Comments		
565529	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC As Found Counter	712600	
565530	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC As Left Counter	712608	
565531	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
565532	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC Current Tap Position	6L	
565533	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC Max Tap Position	1L	
565534	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC Min Tap Position	11L	
565535	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
565536	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC Operations Since Last Insp	636	
565537	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
565538	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
565539	2/18/2019 13:22	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
565540	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
565541	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
565542	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
565543	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
565544	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
565545	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
565546	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
565547	2/18/2019 11:48	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
565548	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
565549	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
565550	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
565551	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
565552	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
565553	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
565554	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	General Comments		
565555	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
565556	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Foundation Condition	Good	
565557	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
565558	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
565559	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
565560	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
565561	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
565562	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Operations Ground	0	
565563	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Operations C Ø	0	
565564	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Operations B Ø	0	
565565	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Operations A Ø	0	
565566	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
565567	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
565568	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
565569	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
565570	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Bushings Connection/Risers	Good	
565571	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Bushing Condition	Good	
565572	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Accumulated Fault Duty C Ph V	3.14	%
565573	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Accumulated Fault Duty B Ph V	4.89	%
565574	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
565575	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Equipment Properly Labeled?	y	
565576	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Accumulated Fault Duty A Ph V	6.64	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
565577	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	9 Month Operations	7	
565578	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
565579	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
565580	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Operations A Ø	0	
565581	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Operations B Ø	0	
565582	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
565583	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
565584	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
565585	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
565586	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
565587	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
565588	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
565589	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
565590	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	General Comments		
565591	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
565592	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
565593	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Cabinet Paint Condition	Good	
565594	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
565595	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
565596	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
565597	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Foundation Condition	Good	
565598	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
565599	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
565600	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
565601	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
565602	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
565603	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
565604	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
565605	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Vegetation	None	
565606	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
565607	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Bushings Connection/Risers	Good	
565608	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Bushing Condition	Good	
565609	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Amps C Ø	20.0	
565610	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Amps B Ø	12.0	
565611	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	General Comments		
565612	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
565613	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
565614	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
565615	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
565616	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
565617	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
565618	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
565619	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
565620	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
565621	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
565622	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
565623	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BAT000497	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
565624	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BAT000497	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
565625	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BAT000497	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
565626	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Operations Counter AL	26	
565627	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Operations Counter AF	26	
565628	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BAT000497	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
565629	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BAT000497	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
565630	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BAT000497	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
565631	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Unknown Operations	0	
565632	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Tank Paint Condition	Good	
565633	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Switching Operations	0	
565634	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
565635	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Operations Counter AL	143	
565636	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Operations Counter AF	143	
565637	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Moisture and Leak Free?	y	
565638	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Maintenance Operations	0	
565639	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BAT000497	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
565640	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BAT000497	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
565641	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BAT000497	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	33	°F
565642	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	BAT000497	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
565643	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Unknown Operations	0	
565644	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
565645	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
565646	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
565647	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
565648	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
565649	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
565650	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Heaters (All) Functioning?	y	
565651	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
565652	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	General Comments		
565653	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	General Comments		
565654	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Equipment Properly Labeled?	y	
565655	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Foundation Condition	Good	
565656	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Follow-up Action Required?	n	
565657	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Follow-up Action Required?	n	
565658	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Operations Ground	0	
565659	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Operations C Ø	0	
565660	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Operations B Ø	0	
565661	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Operations A Ø	0	
565662	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
565663	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
565664	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
565665	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Equipment Properly Labeled?	y	
565666	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
565667	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Cabinet Paint Condition	Good	
565668	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Moisture and Leak Free?	y	
565669	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Maintenance Operations	0	
565670	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
565671	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Heaters (All) Functioning?	y	
565672	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Grounds in Place?	y	
565673	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	General Comments		
565674	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	General Comments		
565675	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Foundation Condition	Good	
565676	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Follow-up Action Required?	n	
565677	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Follow-up Action Required?	n	
565678	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Heaters (All) Functioning?	y	
565679	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Maintenance Operations	0	
565680	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	General Comments		
565681	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
565682	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
565683	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
565684	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	47	
565685	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
565686	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
565687	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
565688	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Moisture and Leak Free?	y	
565689	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Operations Counter AF	35	
565690	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
565691	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
565692	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	36	
565693	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
565694	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
565695	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
565696	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
565697	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Clear of Trash?	y	
565698	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Amps C Ø	4.6	
565699	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Amps B Ø	1.3	
565700	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Amps A Ø	2.6	
565701	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	44	
565702	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
565703	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
565704	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
565705	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
565706	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
565707	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Tank Paint Condition	Good	
565708	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Switching Operations	0	
565709	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
565710	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	Follow-up Action Required?	n	
565711	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
565712	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	General Comments		
565713	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Mechanism Patrol Inspection	General Comments		
565714	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC As Found Counter	100133	
565715	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Operations Counter AL	35	
565716	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
565717	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
565718	2/18/2019 11:57	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
565719	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
565720	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Operations C Ø	0	
565721	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Operations Ground	0	
565722	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Follow-up Action Required?	n	
565723	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
565724	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	Totalizer Meter Reading	.6252	
565725	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
565726	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
565727	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
565728	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
565729	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
565730	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
565731	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
565732	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Amps A Ø	12.0	
565733	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
565734	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Accumulated Fault Duty C Ph V	25.98	%
565735	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Accumulated Fault Duty B Ph V	26.53	%
565736	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
565737	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
565738	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
565739	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Accumulated Fault Duty A Ph V	24.36	%
565740	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	9 Month Operations	4	
565741	2/18/2019 13:11	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
565742	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Follow-up Action Required?	n	
565743	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Foundation Condition	Good	
565744	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	General Comments		
565745	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	General Comments		
565746	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
565747	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
565748	2/18/2019 13:51	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
565749	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
565750	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
565751	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
565752	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
565753	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
565754	2/18/2019 15:10	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
565755	2/18/2019 12:44	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Grounds in Place?	y	
565756	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
565757	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
565758	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
565759	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	67.0	
565760	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	70.0	
565761	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	71.0	
565762	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
565763	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
565764	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
565765	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
565766	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
565767	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
565768	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
565769	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Operations Counter	1972	
565770	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
565771	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
565772	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
565773	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
565774	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	General Comments		
565775	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
565776	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	38	°F
565777	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
565778	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
565779	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
565780	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
565781	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
565782	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
565783	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
565784	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
565785	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	14.7	VDC
565786	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	14.6	VDC
565787	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
565788	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
565789	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
565790	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
565791	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
565792	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
565793	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
565794	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
565795	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
565796	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.6	VDC
565797	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.5	VDC
565798	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
565799	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
565800	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
565801	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
565802	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
565803	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	BCH000255	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.7	VDC
565804	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	BCH000255	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.7	VDC
565805	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	BCH000255	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
565806	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	BCH000255	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
565807	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	BCH000255	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
565808	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
565809	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
565810	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Amps A Ø	0.0	
565811	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Amps B Ø	0.0	
565812	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Amps C Ø	0.0	
565813	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
565814	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
565815	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
565816	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
565817	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Follow-up Action Required?	n	
565818	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
565819	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
565820	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
565821	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	General Comments		
565822	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
565823	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Patrol Inspection	General Comments		
565824	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	General Comments		
565825	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
565826	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	General Comments		
565827	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	9 Month Operations	1	
565828	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
565829	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
565830	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
565831	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
565832	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	General Comments		
565833	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
565834	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	LTC Totalizer Reading	12774.17	kw
565835	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
565836	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
565837	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Oil Temp Max	50	°C
565838	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
565839	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BAT001178	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
565840	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Oil Temp Present	35	°C
565841	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
565842	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
565843	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Switching Operations	0	
565844	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Unknown Operations	0	
565845	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
565846	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Follow-up Action Required?	n	
565847	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
565848	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Patrol Inspection	Follow-up Action Required?	n	
565849	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Operations Ground	0	
565850	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
565851	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BAT001178	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
565852	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BAT001178	Battery	Retired Distribution	Battery Patrol Inspection	Battery Bank Volts	53.2	VDC
565853	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BAT001178	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
565854	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BAT001178	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
565855	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Operations C Ø	0	
565856	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BAT001178	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
565857	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BAT001178	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
565858	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BAT001178	Battery	Retired Distribution	Battery Patrol Inspection	Dry Cell Battery Install Date	2016-02-17 00:00:00.000000	
565859	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BAT001178	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
565860	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BAT001178	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
565861	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BAT001178	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
565862	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BAT001178	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
565863	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BAT001178	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
565864	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BAT001178	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
565865	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
565866	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
565867	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
565868	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Follow-up Action Required?	n	
565869	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Patrol Inspection	Follow-up Action Required?	n	
565870	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
565871	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
565872	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
565873	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
565874	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
565875	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
565876	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
565877	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
565878	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
565879	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
565880	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
565881	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
565882	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
565883	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
565884	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
565885	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
565886	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
565887	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
565888	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	General Comments	ok	
565889	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
565890	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
565891	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
565892	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
565893	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
565894	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
565895	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
565896	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
565897	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Patrol Inspection	General Comments		
565898	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
565899	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	General Comments		
565900	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
565901	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Winding Temp Present	30	°C
565902	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Winding Temp Max	40	°C
565903	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Totalizer Meter Reading	.4500	
565904	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
565905	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Top Oil Temperature Present	30	°C
565906	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
565907	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
565908	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Operations Counter AL	209	
565909	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Maintenance Operations	0	
565910	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	Oil Temp Max	50	°C
565911	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
565912	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
565913	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Operations Counter AF	209	
565914	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Unknown Operations	0	
565915	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Switching Operations	0	
565916	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Operations Counter AL	168	
565917	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Operations Counter AF	168	
565918	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Maintenance Operations	0	
565919	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
565920	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
565921	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
565922	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
565923	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
565924	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
565925	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
565926	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
565927	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
565928	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
565929	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
565930	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Patrol Inspection	Equipment Properly Labeled?	y	
565931	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Patrol Inspection	Follow-up Action Required?	n	
565932	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Patrol Inspection	General Comments		
565933	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
565934	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
565935	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
565936	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
565937	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
565938	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
565939	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Foundation Condition	Good	
565940	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
565941	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
565942	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	General Comments	Isn't any spare fuses	
565943	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
565944	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
565945	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
565946	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
565947	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
565948	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
565949	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
565950	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
565951	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
565952	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
565953	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
565954	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
565955	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
565956	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
565957	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
565958	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
565959	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
565960	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
565961	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
565962	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
565963	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
565964	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
565965	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
565966	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
565967	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
565968	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
565969	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Follow-up Action Required?	n	
565970	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
565971	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
565972	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	General Comments		
565973	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	General Comments		
565974	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
565975	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	LTC Totalizer Reading	16541.50	kw
565976	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
565977	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
565978	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
565979	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
565980	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
565981	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
565982	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
565983	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
565984	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
565985	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	9 Month Operations	21	
565986	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
565987	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Bushings Connection/Risers	Good	
565988	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
565989	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
565990	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
565991	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
565992	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
565993	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
565994	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
565995	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
565996	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
565997	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
565998	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
565999	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
566000	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
566001	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
566002	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
566003	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
566004	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
566005	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
566006	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	General Comments		
566007	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Cabinet Paint Condition	Good	
566008	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
566009	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
566010	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
566011	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
566012	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Operations A Ø	0	
566013	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Operations B Ø	0	
566014	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Operations C Ø	0	
566015	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Operations Ground	0	
566016	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Follow-up Action Required?	n	
566017	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Follow-up Action Required?	n	
566018	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Foundation Condition	Good	
566019	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	General Comments		
566020	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
566021	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
566022	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
566023	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	13	
566024	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	3410	
566025	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	3410	
566026	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
566027	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
566028	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
566029	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
566030	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
566031	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
566032	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
566033	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
566034	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	General Comments		
566035	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Grounds in Place?	y	
566036	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Heaters (All) Functioning?	y	
566037	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Maintenance Operations	0	
566038	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Moisture and Leak Free?	y	
566039	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Operations Counter AF	124	
566040	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Operations Counter AL	124	
566041	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
566042	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Switching Operations	1	
566043	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Tank Paint Condition	Good	
566044	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Unknown Operations	0	
566045	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC Operations Since Last Insp	622	
566046	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
566047	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
566048	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
566049	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Winding Temp Max	60	°C
566050	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Winding Temp Present	45	°C
566051	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
566052	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
566053	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Tank Paint Condition	Good	
566054	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Switching Operations	0	
566055	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
566056	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Operations Counter AL	105	
566057	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Operations Counter AF	105	
566058	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Moisture and Leak Free?	y	
566059	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Maintenance Operations	0	
566060	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Heaters (All) Functioning?	y	
566061	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Grounds in Place?	y	
566062	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	General Comments		
566063	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	General Comments		
566064	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Foundation Condition	Good	
566065	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Follow-up Action Required?	n	
566066	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Follow-up Action Required?	n	
566067	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Operations Ground	0	
566068	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Operations C Ø	0	
566069	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Operations B Ø	0	
566070	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Amps A Ø	200.0	
566071	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Amps B Ø	200.0	
566072	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Amps C Ø	200.0	
566073	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Bushing Condition	Good	
566074	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Bushings Connection/Risers	Good	
566075	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
566076	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	Follow-up Action Required?	n	
566077	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
566078	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	General Comments		
566079	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	General Comments		
566080	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC As Found Counter	7590	
566081	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC As Left Counter	7612	
566082	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
566083	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC Current Tap Position	6L	
566084	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC Max Tap Position	1R	
566085	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC Min Tap Position	13L	
566086	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
566087	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
566088	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
566089	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
566090	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC Operations Since Last Insp	860	
566091	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
566092	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
566093	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
566094	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	-1.0	psi
566095	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
566096	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
566097	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Cabinet Paint Condition	Good	
566098	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Equipment Properly Labeled?	y	
566099	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
566100	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
566101	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
566102	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Operations A Ø	0	
566103	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
566104	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
566105	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Amps A Ø	182.0	
566106	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Amps B Ø	178.0	
566107	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Amps C Ø	179.0	
566108	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Bushing Condition	Good	
566109	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Bushings Connection/Risers	Good	
566110	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	Follow-up Action Required?	n	
566111	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
566112	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	General Comments		
566113	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	General Comments		
566114	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC As Found Counter	300069	
566115	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC As Left Counter	300069	
566116	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
566117	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC Current Tap Position	6L	
566118	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
566119	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
566120	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
566121	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
566122	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Cabinet Paint Condition	Good	
566123	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Equipment Properly Labeled?	y	
566124	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
566125	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
566126	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
566127	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Operations A Ø	0	
566128	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Operations B Ø	0	
566129	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Operations C Ø	0	
566130	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Operations Ground	0	
566131	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Follow-up Action Required?	n	
566132	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Follow-up Action Required?	n	
566133	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Foundation Condition	Good	
566134	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	General Comments		
566135	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	General Comments		
566136	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Grounds in Place?	y	
566137	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Heaters (All) Functioning?	y	
566138	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Maintenance Operations	0	
566139	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Moisture and Leak Free?	y	
566140	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Operations Counter AF	266	
566141	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Operations Counter AL	266	
566142	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Switching Operations	0	
566143	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Tank Paint Condition	Good	
566144	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Unknown Operations	0	
566145	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
566146	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
566147	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Top Oil Temperature Max	55	°C
566148	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Top Oil Temperature Present	40	°C
566149	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
566150	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	9 Month Operations	3	
566151	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Accumulated Fault Duty A Ph V	13.66	%
566152	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Accumulated Fault Duty B Ph V	13.66	%
566153	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Accumulated Fault Duty C Ph V	13.66	%
566154	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Unknown Operations	0	
566155	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Totalizer Meter Reading	1.0854	
566156	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Patrol Inspection	Equipment Properly Labeled?	y	
566157	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Patrol Inspection	Follow-up Action Required?	n	
566158	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Patrol Inspection	General Comments		
566159	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC Min Tap Position	10L	
566160	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.5	psi
566161	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Totalizer Meter Reading	.8382	
566162	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Winding Temp Max	50	°C
566163	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Winding Temp Present	35	°C
566164	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
566165	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
566166	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	Follow-up Action Required?	n	
566167	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
566168	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6258	
566169	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	General Comments		
566170	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	General Comments		
566171	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC As Found Counter	133929	
566172	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC As Left Counter	133929	
566173	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
566174	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC Current Tap Position	4L	
566175	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC Max Tap Position	2R	
566176	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC Min Tap Position	10L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
566177	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.5	psi
566178	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC Operations Since Last Insp	766	
566179	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
566180	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
566181	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
566182	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
566183	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
566184	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
566185	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
566186	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
566187	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
566188	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
566189	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
566190	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Oil Temp Present	27	°C
566191	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
566192	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
566193	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	227.50	
566194	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	375.48	kw
566195	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
566196	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
566197	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	General Comments		
566198	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	General Comments		
566199	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
566200	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
566201	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
566202	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
566203	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
566204	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
566205	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
566206	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
566207	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
566208	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	9 Month Operations	7	
566209	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
566210	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
566211	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
566212	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Amps A Ø	480.0	
566213	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Amps B Ø	480.0	
566214	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Amps C Ø	480.0	
566215	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Bushing Condition	Good	
566216	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Bushings Connection/Risers	Good	
566217	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
566218	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
566219	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1001	
566220	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1001	
566221	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	6	
566222	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
566223	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
566224	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Top Oil Temperature Max	40	°C
566225	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
566226	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
566227	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
566228	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
566229	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
566230	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
566231	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
566232	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
566233	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
566234	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
566235	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Readings	General Comments		
566236	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
566237	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
566238	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
566239	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
566240	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
566241	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
566242	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
566243	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
566244	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	LTC Totalizer Reading	6858.00	kw
566245	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
566246	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	General Comments		
566247	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	General Comments		
566248	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
566249	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
566250	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Follow-up Action Required?	n	
566251	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
566252	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
566253	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
566254	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
566255	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
566256	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
566257	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
566258	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
566259	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
566260	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
566261	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
566262	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
566263	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
566264	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	General Comments		
566265	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	Oil Temp Max	35	°C
566266	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
566267	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
566268	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
566269	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
566270	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
566271	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
566272	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
566273	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
566274	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
566275	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
566276	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Switching Operations	0	
566277	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Tank Paint Condition	Good	
566278	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Grounds in Place?	y	
566279	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Heaters (All) Functioning?	y	
566280	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Maintenance Operations	0	
566281	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Moisture and Leak Free?	y	
566282	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Operations Counter AF	192	
566283	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Operations Counter AL	192	
566284	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Switching Operations	0	
566285	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Tank Paint Condition	Good	
566286	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Unknown Operations	0	
566287	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
566288	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
566289	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Winding Temp Present	30	°C
566290	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Winding Temp Max	45	°C
566291	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Totalizer Meter Reading	.4392	
566292	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
566293	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Top Oil Temperature Present	25	°C
566294	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Top Oil Temperature Max	50	°C
566295	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
566296	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
566297	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Unknown Operations	0	
566298	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
566299	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
566300	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
566301	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
566302	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
566303	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
566304	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
566305	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
566306	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
566307	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	LTC Totalizer Reading	6693.41	kw
566308	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
566309	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	General Comments		
566310	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	General Comments		
566311	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
566312	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
566313	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Follow-up Action Required?	n	
566314	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
566315	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
566316	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
566317	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
566318	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
566319	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
566320	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
566321	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
566322	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
566323	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
566324	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
566325	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
566326	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	9 Month Operations	6	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
566327	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Accumulated Fault Duty A Ph V	1.37	%
566328	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Accumulated Fault Duty B Ph V	1.37	%
566329	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Accumulated Fault Duty C Ph V	1.37	%
566330	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Amps A Ø	0.0	
566331	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Amps B Ø	0.0	
566332	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Amps C Ø	0.0	
566333	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Bushing Condition	Good	
566334	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
566335	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
566336	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Cabinet Paint Condition	Good	
566337	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Equipment Properly Labeled?	y	
566338	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
566339	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
566340	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
566341	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Operations A Ø	0	
566342	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Operations B Ø	0	
566343	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Operations C Ø	0	
566344	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Operations Ground	0	
566345	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Follow-up Action Required?	n	
566346	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Follow-up Action Required?	n	
566347	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Foundation Condition	Good	
566348	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	General Comments		
566349	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	General Comments		
566350	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Grounds in Place?	y	
566351	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Heaters (All) Functioning?	y	
566352	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Maintenance Operations	0	
566353	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Moisture and Leak Free?	y	
566354	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
566355	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
566356	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
566357	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
566358	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
566359	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
566360	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	60.0	
566361	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	60.0	
566362	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	60.0	
566363	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Operations Counter AF	262	
566364	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Operations Counter AL	262	
566365	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
566366	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	9 Month Operations	4	
566367	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Accumulated Fault Duty A Ph V	3.18	%
566368	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Accumulated Fault Duty B Ph V	3.97	%
566369	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Accumulated Fault Duty C Ph V	3.18	%
566370	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Amps A Ø	98.0	
566371	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Amps B Ø	116.0	
566372	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Amps C Ø	104.0	
566373	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Bushing Condition	Good	
566374	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Bushings Connection/Risers	Good	
566375	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
566376	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
566377	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
566378	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Cabinet Paint Condition	Good	
566379	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Equipment Properly Labeled?	y	
566380	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
566381	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
566382	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
566383	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Operations A Ø	0	
566384	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Operations B Ø	0	
566385	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Operations C Ø	0	
566386	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Operations Ground	0	
566387	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Follow-up Action Required?	n	
566388	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Follow-up Action Required?	n	
566389	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Foundation Condition	Good	
566390	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	General Comments		
566391	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	General Comments		
566392	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Operations A Ø	0	
566393	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
566394	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
566395	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
566396	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	All Connections OK?	y	
566397	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	Follow-up Action Required?	n	
566398	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	General Comments		
566399	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	LTC Operation Checked?	y	
566400	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	LTC Output Voltage Level	121.0	VAC
566401	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
566402	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
566403	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
566404	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	VRR Time Delay	45	Seconds
566405	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	9 Month Operations	1	
566406	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Accumulated Fault Duty A Ph V	2.46	%
566407	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Accumulated Fault Duty B Ph V	2.46	%
566408	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Accumulated Fault Duty C Ph V	2.46	%
566409	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Amps A Ø	14.8	
566410	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Amps B Ø	14.5	
566411	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Amps C Ø	6.6	
566412	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Bushing Condition	Good	
566413	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Bushings Connection/Risers	Good	
566414	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
566415	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
566416	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
566417	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Cabinet Paint Condition	Good	
566418	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Equipment Properly Labeled?	y	
566419	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
566420	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
566421	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
566422	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Operations A Ø	0	
566423	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Operations B Ø	0	
566424	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Operations C Ø	0	
566425	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Operations Ground	0	
566426	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Follow-up Action Required?	n	
566427	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Follow-up Action Required?	n	
566428	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Foundation Condition	Good	
566429	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	General Comments		
566430	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	General Comments		
566431	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Grounds in Place?	y	
566432	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Heaters (All) Functioning?	y	
566433	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Maintenance Operations	0	
566434	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
566435	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Amps C Ø	0.0	
566436	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Amps B Ø	0.0	
566437	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Amps A Ø	0.0	
566438	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
566439	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
566440	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
566441	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	9 Month Operations	0	
566442	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Moisture and Leak Free?	y	
566443	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Operations Counter AF	51	
566444	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Operations Counter AL	51	
566445	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Switching Operations	0	
566446	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Tank Paint Condition	Good	
566447	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Unknown Operations	0	
566448	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
566449	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
566450	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
566451	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
566452	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
566453	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
566454	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
566455	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
566456	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Cabinet Paint Condition	Good	
566457	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
566458	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Follow-up Action Required?	n	
566459	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Foundation Condition	Good	
566460	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	General Comments		
566461	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Grounds in Place?	y	
566462	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Moisture and Leak Free?	y	
566463	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Tank Leaks	None	
566464	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Tank Oil Level	Good	
566465	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Tank Paint Condition	Good	
566466	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
566467	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
566468	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
566469	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
566470	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
566471	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
566472	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
566473	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Operations C Ø	0	
566474	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Operations B Ø	0	
566475	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Operations A Ø	0	
566476	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
566477	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
566478	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
566479	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
566480	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Cabinet Paint Condition	Good	
566481	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
566482	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
566483	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
566484	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Bushings Connection/Risers	Good	
566485	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Bushing Condition	Good	
566486	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Amps C Ø	200.0	
566487	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Amps B Ø	300.0	
566488	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Amps A Ø	200.0	
566489	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Accumulated Fault Duty C Ph V	4.64	%
566490	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Accumulated Fault Duty B Ph V	4.64	%
566491	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Accumulated Fault Duty A Ph V	4.64	%
566492	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	9 Month Operations	8	
566493	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Unknown Operations	0	
566494	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Switching Operations	0	
566495	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Operations Counter AL	141	
566496	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Operations Counter AF	141	
566497	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Maintenance Operations	0	
566498	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	General Comments		
566499	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Patrol Inspection	General Comments		
566500	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	All Connections OK?	y	
566501	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	Follow-up Action Required?	n	
566502	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	General Comments		
566503	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	LTC Operation Checked?	y	
566504	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	LTC Output Voltage Level	121.0	VAC
566505	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
566506	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
566507	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
566508	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	VRR Time Delay	45	Seconds
566509	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Follow-up Action Required?	n	
566510	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Patrol Inspection	Follow-up Action Required?	n	
566511	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Operations Ground	0	
566512	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Operations C Ø	0	
566513	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Operations B Ø	0	
566514	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
566515	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
566516	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
566517	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
566518	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
566519	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
566520	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
566521	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
566522	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Operations A Ø	0	
566523	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Operations B Ø	0	
566524	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Operations C Ø	0	
566525	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Operations Ground	0	
566526	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Follow-up Action Required?	n	
566527	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Follow-up Action Required?	n	
566528	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Foundation Condition	Good	
566529	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	General Comments		
566530	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	General Comments		
566531	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Grounds in Place?	y	
566532	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
566533	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Maintenance Operations	0	
566534	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
566535	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Operations Counter AF	48	
566536	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Operations Counter AL	48	
566537	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Switching Operations	0	
566538	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Tank Paint Condition	Good	
566539	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Unknown Operations	0	
566540	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
566541	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
566542	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	0	
566543	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
566544	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	Neutral	
566545	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
566546	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	13386	
566547	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	13386	
566548	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
566549	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LTCC000410	LTCControl	C-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
566550	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LTCC000410	LTCControl	C-TRANS 3	LTC Control Insp	General Comments		
566551	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
566552	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
566553	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Cabinet Paint Condition	Good	
566554	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Equipment Properly Labeled?	y	
566555	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
566556	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
566557	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
566558	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Operations A Ø	0	
566559	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Operations B Ø	0	
566560	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LTCC000410	LTCControl	C-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
566561	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	General Comments		
566562	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
566563	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
566564	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Operations C Ø	0	
566565	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Operations Ground	0	
566566	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Follow-up Action Required?	n	
566567	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Follow-up Action Required?	n	
566568	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Foundation Condition	Good	
566569	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	General Comments	ok	
566570	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	General Comments	ok	
566571	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Grounds in Place?	y	
566572	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Heaters (All) Functioning?	y	
566573	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Maintenance Operations	0	
566574	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Moisture and Leak Free?	y	
566575	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
566576	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
566577	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
566578	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
566579	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
566580	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
566581	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
566582	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
566583	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
566584	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	General Comments	ok	
566585	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
566586	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
566587	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Foundation Condition	Good	
566588	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
566589	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
566590	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
566591	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
566592	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
566593	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
566594	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
566595	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
566596	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
566597	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
566598	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
566599	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
566600	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
566601	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
566602	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
566603	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
566604	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
566605	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
566606	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	9 Month Operations	1	
566607	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Accumulated Fault Duty A Ph V	.49	%
566608	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Accumulated Fault Duty B Ph V	.49	%
566609	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Accumulated Fault Duty C Ph V	.49	%
566610	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Amps A Ø	130.0	
566611	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Amps B Ø	130.0	
566612	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Amps C Ø	150.0	
566613	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Bushing Condition	Good	
566614	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Bushings Connection/Risers	Good	
566615	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
566616	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
566617	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
566618	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectio	LTCC000669	LTCControl	733-1	LTC Control Insp	VRR Time Delay	30	Seconds
566619	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectio	LTCC000669	LTCControl	733-1	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
566620	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectio	LTCC000669	LTCControl	733-1	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
566621	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectio	LTCC000669	LTCControl	733-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
566622	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectio	LTCC000669	LTCControl	733-1	LTC Control Insp	LTC Output Voltage Level	120.5	VAC
566623	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectio	LTCC000669	LTCControl	733-1	LTC Control Insp	LTC Operation Checked?	y	
566624	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectio	LTCC000669	LTCControl	733-1	LTC Control Insp	General Comments		
566625	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectio	LTCC000669	LTCControl	733-1	LTC Control Insp	Follow-up Action Required?	n	
566626	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectio	LTCC000669	LTCControl	733-1	LTC Control Insp	All Connections OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
566627	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
566628	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	9 Month Operations	1	
566629	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Accumulated Fault Duty A Ph V	1.62	%
566630	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Accumulated Fault Duty B Ph V	1.62	%
566631	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Accumulated Fault Duty C Ph V	1.62	%
566632	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Amps A Ø	50.2	
566633	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Amps B Ø	46.2	
566634	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Amps C Ø	40.6	
566635	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Bushing Condition	Good	
566636	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
566637	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
566638	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
566639	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
566640	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Cabinet Paint Condition	Good	
566641	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Equipment Properly Labeled?	y	
566642	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
566643	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
566644	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
566645	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Tank Leaks	None	
566646	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
566647	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	Winding Temp Present	0	°C
566648	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	Winding Temp Max	16	°C
566649	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
566650	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
566651	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
566652	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
566653	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
566654	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
566655	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
566656	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	Oil Temp Present	22	°C
566657	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	Oil Temp Max	35	°C
566658	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	210.00	
566659	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	224.17	
566660	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
566661	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2100	psi
566662	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
566663	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
566664	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
566665	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	General Comments		
566666	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Patrol Inspection	Equipment Properly Labeled?	y	
566667	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Patrol Inspection	Follow-up Action Required?	n	
566668	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
566669	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
566670	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
566671	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
566672	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
566673	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
566674	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
566675	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Readings	Totalizer Meter Reading	.4668	
566676	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
566677	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
566678	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Patrol Inspection	General Comments		
566679	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
566680	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
566681	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
566682	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
566683	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
566684	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
566685	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
566686	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
566687	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	General Comments		
566688	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
566689	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
566690	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
566691	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
566692	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
566693	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
566694	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
566695	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
566696	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
566697	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
566698	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
566699	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
566700	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
566701	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
566702	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
566703	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
566704	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
566705	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
566706	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
566707	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Readings	Follow-up Action Required?	n	
566708	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
566709	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
566710	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	General Comments	ok	
566711	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
566712	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	General Comments		
566713	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Readings	General Comments		
566714	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
566715	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Readings	LTC Totalizer Reading	2800.80	kw
566716	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
566717	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
566718	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Readings	Oil Temp Max	32	°C
566719	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Readings	Oil Temp Present	32	°C
566720	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
566721	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
566722	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
566723	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
566724	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
566725	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	472	
566726	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
566727	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC Min Tap Position	14L	
566728	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC Max Tap Position	6L	
566729	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC Current Tap Position	9L	
566730	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
566731	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC As Left Counter	26747	
566732	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC As Found Counter	26747	
566733	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
566734	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	General Comments		
566735	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
566736	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
566737	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
566738	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
566739	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
566740	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
566741	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
566742	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
566743	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
566744	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
566745	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
566746	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
566747	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
566748	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
566749	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Regulator As Left Counter	101289	
566750	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
566751	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	9 Month Operations	1	
566752	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Accumulated Fault Duty A Ph V	1.95	%
566753	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Accumulated Fault Duty B Ph V	3.42	%
566754	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Accumulated Fault Duty C Ph V	2.93	%
566755	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Amps A Ø	130.0	
566756	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Amps B Ø	170.0	
566757	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Amps C Ø	140.0	
566758	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Bushing Condition	Good	
566759	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Bushings Connection/Risers	Good	
566760	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
566761	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
566762	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
566763	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	Totalizer Meter Reading	.7284	
566764	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
566765	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
566766	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Foundation Condition	Good	
566767	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
566768	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Follow-up Action Required?	n	
566769	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Follow-up Action Required?	n	
566770	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Operations Ground	0	
566771	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Vegetation	None	
566772	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
566773	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	General Comments	Drive way to gate needs some attention	
566774	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
566775	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
566776	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
566777	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
566778	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
566779	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
566780	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Clear of Trash?	y	
566781	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
566782	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
566783	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
566784	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Unknown Operations	0	
566785	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Tank Paint Condition	Good	
566786	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Switching Operations	0	
566787	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Operations Counter AL	151	
566788	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Operations Counter AF	151	
566789	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
566790	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Maintenance Operations	0	
566791	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
566792	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Grounds in Place?	y	
566793	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	General Comments		
566794	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Bushing Condition	Good	
566795	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Bushings Connection/Risers	Good	
566796	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	General Comments		
566797	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Foundation Condition	Good	
566798	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Follow-up Action Required?	n	
566799	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Follow-up Action Required?	n	
566800	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Operations Ground	0	
566801	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Operations C Ø	0	
566802	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Operations B Ø	0	
566803	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Operations A Ø	0	
566804	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
566805	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
566806	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
566807	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
566808	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
566809	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
566810	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
566811	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
566812	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
566813	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Bushing Condition	Good	
566814	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Amps C Ø	240.0	
566815	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Amps B Ø	245.0	
566816	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Amps A Ø	230.0	
566817	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Accumulated Fault Duty C Ph V	2.88	%
566818	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Accumulated Fault Duty B Ph V	1.92	%
566819	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Accumulated Fault Duty A Ph V	2.88	%
566820	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	9 Month Operations	3	
566821	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
566822	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
566823	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
566824	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
566825	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
566826	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
566827	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	Follow-up Action Required?	n	
566828	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Operations A Ø	0	
566829	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Operations B Ø	0	
566830	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Operations C Ø	0	
566831	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Operations Ground	0	
566832	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Follow-up Action Required?	n	
566833	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Follow-up Action Required?	n	
566834	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Foundation Condition	Good	
566835	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	General Comments	ok	
566836	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	General Comments	ok	
566837	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Grounds in Place?	y	
566838	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Heaters (All) Functioning?	y	
566839	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Maintenance Operations	0	
566840	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Moisture and Leak Free?	y	
566841	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Operations Counter AF	131	
566842	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Operations Counter AL	131	
566843	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Switching Operations	0	
566844	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Tank Paint Condition	Good	
566845	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Unknown Operations	0	
566846	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
566847	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
566848	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	General Comments		
566849	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	General Comments		
566850	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
566851	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	LTC Totalizer Reading	6992.64	kw

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
566852	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
566853	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
566854	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	Oil Temp Max	30	°C
566855	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	Oil Temp Present	30	°C
566856	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
566857	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
566858	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
566859	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
566860	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
566861	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
566862	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
566863	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
566864	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
566865	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
566866	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
566867	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Unknown Operations	0	
566868	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Tank Paint Condition	Good	
566869	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Switching Operations	0	
566870	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
566871	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Operations Counter AL	59	
566872	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Operations Counter AF	59	
566873	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Moisture and Leak Free?	y	
566874	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
566875	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
566876	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
566877	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Maintenance Operations	0	
566878	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Heaters (All) Functioning?	y	
566879	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Grounds in Place?	y	
566880	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	General Comments		
566881	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	General Comments		
566882	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
566883	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
566884	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	General Comments	ok	
566885	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
566886	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
566887	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
566888	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
566889	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
566890	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
566891	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
566892	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
566893	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
566894	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
566895	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
566896	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
566897	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
566898	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
566899	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
566900	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Clear of Trash?	y	
566901	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
566902	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
566903	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
566904	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
566905	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Panels Dusted?	y	
566906	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
566907	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
566908	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	General Comments		
566909	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
566910	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	9 Month Operations	0	
566911	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
566912	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
566913	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
566914	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Amps A Ø	0.0	
566915	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Amps B Ø	0.0	
566916	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Amps C Ø	0.0	
566917	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Patrol Inspection	Equipment Properly Labeled?	y	
566918	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
566919	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
566920	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
566921	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
566922	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	General Comments	ok	
566923	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
566924	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
566925	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
566926	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
566927	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Floor Swept?	y	
566928	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
566929	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
566930	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Evidence of Insects	None	
566931	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
566932	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
566933	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
566934	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
566935	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
566936	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
566937	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Fault Operations A Ø	0	
566938	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Fault Operations B Ø	0	
566939	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Fault Operations C Ø	0	
566940	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Fault Operations Ground	0	
566941	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Unknown Operations	0	
566942	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Switching Operations	0	
566943	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Operations Counter AL	161	
566944	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
566945	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Floor Swept?	y	
566946	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
566947	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
566948	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	General Comments		
566949	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
566950	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Panel Lights OK?	y	
566951	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
566952	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
566953	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Panels Dusted?	y	
566954	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Station Ground Set On Site?	y	
566955	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Switch Diagram Present/Current	y	
566956	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Trash Emptied?	y	
566957	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
566958	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
566959	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
566960	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
566961	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
566962	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
566963	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
566964	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
566965	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
566966	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
566967	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
566968	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
566969	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
566970	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
566971	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
566972	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
566973	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
566974	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
566975	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
566976	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
566977	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
566978	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
566979	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
566980	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Vegetation	None	
566981	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
566982	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
566983	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	General Comments		
566984	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
566985	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
566986	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
566987	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
566988	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
566989	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
566990	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
566991	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
566992	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
566993	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
566994	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
566995	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
566996	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
566997	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
566998	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
566999	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
567000	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
567001	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
567002	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
567003	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
567004	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
567005	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
567006	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
567007	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
567008	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	9 Month Operations	0	
567009	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
567010	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
567011	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
567012	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Amps A Ø	476.0	
567013	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Amps B Ø	483.0	
567014	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Amps C Ø	444.0	
567015	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
567016	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
567017	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
567018	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
567019	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
567020	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
567021	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
567022	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Operations Ground	0	
567023	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
567024	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
567025	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Patrol Inspection	General Comments		
567026	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
567027	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
567028	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
567029	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	General Comments		
567030	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Maintenance Operations	0	
567031	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Operations Counter AF	236	
567032	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Operations Counter AL	236	
567033	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Switching Operations	0	
567034	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Unknown Operations	0	
567035	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
567036	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
567037	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
567038	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
567039	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
567040	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
567041	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
567042	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
567043	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
567044	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
567045	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
567046	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Operations A Ø	0	
567047	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	9 Month Operations	0	
567048	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
567049	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
567050	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
567051	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Amps A Ø	0.0	
567052	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Amps B Ø	0.0	
567053	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Amps C Ø	0.0	
567054	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
567055	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
567056	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
567057	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
567058	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Operations A Ø	0	
567059	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Operations B Ø	0	
567060	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
567061	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
567062	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
567063	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
567064	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
567065	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
567066	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Operations Counter AF	161	
567067	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Maintenance Operations	0	
567068	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	General Comments		
567069	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Patrol Inspection	General Comments		
567070	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Follow-up Action Required?	n	
567071	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Patrol Inspection	Follow-up Action Required?	n	
567072	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
567073	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
567074	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
567075	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
567076	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
567077	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Operations Ground	0	
567078	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Operations C Ø	0	
567079	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Operations B Ø	0	
567080	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
567081	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
567082	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
567083	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
567084	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
567085	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
567086	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
567087	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Follow-up Action Required?	n	
567088	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
567089	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
567090	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	General Comments	ok	
567091	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	General Comments	top fan on left not working	
567092	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
567093	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
567094	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
567095	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	500	psi
567096	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	200.00	
567097	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.5	
567098	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0	
567099	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Oil Temp Max	50	°C
567100	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Oil Temp Present	10	°C
567101	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
567102	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
567103	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
567104	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
567105	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
567106	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
567107	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
567108	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
567109	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
567110	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Winding Temp Max	55	°C
567111	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Winding Temp Present	25	°C
567112	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
567113	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Tank Leaks	None	
567114	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Regulator As Left Counter	53233	
567115	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
567116	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
567117	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
567118	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
567119	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
567120	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
567121	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
567122	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
567123	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	General Comments	ok	
567124	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
567125	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
567126	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
567127	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
567128	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Follow-up Action Required?	n	
567129	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Patrol Inspection	Follow-up Action Required?	n	
567130	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Operations Ground	0	
567131	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Operations C Ø	0	
567132	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Operations B Ø	0	
567133	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Operations A Ø	0	
567134	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
567135	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
567136	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
567137	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
567138	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Amps C Ø	0.0	
567139	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Amps B Ø	0.0	
567140	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Amps A Ø	0.0	
567141	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
567142	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
567143	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
567144	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	9 Month Operations	1	
567145	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
567146	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
567147	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
567148	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
567149	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
567150	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
567151	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
567152	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
567153	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
567154	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
567155	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
567156	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
567157	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
567158	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
567159	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
567160	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
567161	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
567162	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
567163	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
567164	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
567165	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
567166	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
567167	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
567168	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
567169	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
567170	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
567171	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	General Comments	ok	
567172	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
567173	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
567174	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
567175	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
567176	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
567177	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
567178	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
567179	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
567180	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
567181	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
567182	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
567183	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
567184	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
567185	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
567186	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
567187	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
567188	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
567189	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Operations Counter AF	122	
567190	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Operations Counter AL	122	
567191	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Switching Operations	0	
567192	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Tank Paint Condition	Good	
567193	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Unknown Operations	0	
567194	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
567195	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
567196	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
567197	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
567198	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
567199	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
567200	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
567201	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
567202	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
567203	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
567204	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
567205	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
567206	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
567207	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
567208	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
567209	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
567210	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
567211	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
567212	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Follow-up Action Required?	n	
567213	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
567214	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
567215	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	General Comments		
567216	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	General Comments		
567217	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
567218	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	LTC Totalizer Reading	12454.13	kw
567219	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
567220	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
567221	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Oil Temp Max	50	°C
567222	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Oil Temp Present	45	°C
567223	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
567224	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
567225	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
567226	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
567227	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
567228	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
567229	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
567230	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
567231	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
567232	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
567233	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
567234	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
567235	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
567236	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
567237	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
567238	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
567239	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Totalizer Meter Reading	.8172	
567240	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Winding Temp Max	55	°C
567241	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Winding Temp Present	45	°C
567242	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
567243	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
567244	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Unknown Operations	0	
567245	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Switching Operations	0	
567246	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Operations Counter AL	140	
567247	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Operations Counter AF	140	
567248	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Maintenance Operations	0	
567249	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	General Comments		
567250	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Patrol Inspection	General Comments		
567251	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
567252	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
567253	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
567254	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	5L	
567255	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
567256	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
567257	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
567258	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
567259	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
567260	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
567261	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	Neutral	
567262	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
567263	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
567264	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
567265	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
567266	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
567267	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
567268	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	26951	
567269	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
567270	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
567271	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
567272	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
567273	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
567274	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
567275	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
567276	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	1.2148	
567277	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
567278	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
567279	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
567280	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
567281	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
567282	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
567283	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
567284	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
567285	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
567286	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	25	°C
567287	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	40	°C
567288	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
567289	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	55.00	
567290	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	2915.52	kw
567291	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
567292	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
567293	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
567294	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
567295	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
567296	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
567297	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
567298	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
567299	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Basement Condition Acceptible	y	
567300	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Broom on Site?	y	
567301	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
567302	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
567303	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
567304	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
567305	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Door Alarms OK?	y	
567306	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
567307	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Evidence of Insects	None	
567308	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
567309	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
567310	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
567311	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
567312	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
567313	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
567314	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	General Comments		
567315	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
567316	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
567317	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
567318	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
567319	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
567320	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
567321	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
567322	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
567323	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
567324	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	All Connections OK?	y	
567325	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
567326	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
567327	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
567328	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
567329	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
567330	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	2	
567331	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	813	
567332	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	813	
567333	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	3	
567334	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
567335	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
567336	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
567337	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	General Comments		
567338	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
567339	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
567340	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
567341	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
567342	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
567343	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
567344	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
567345	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
567346	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
567347	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
567348	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
567349	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
567350	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	400.0	
567351	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	400.0	
567352	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	400.0	
567353	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Foundation Condition	Good	
567354	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
567355	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
567356	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
567357	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
567358	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
567359	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
567360	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
567361	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
567362	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
567363	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
567364	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
567365	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
567366	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Patrol Inspection	Equipment Properly Labeled?	y	
567367	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Patrol Inspection	Follow-up Action Required?	n	
567368	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Patrol Inspection	General Comments		
567369	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCC000421	LTCControl	SM-TRANS 5	LTC Control Insp	Follow-up Action Required?	n	
567370	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCC000421	LTCControl	SM-TRANS 5	LTC Control Insp	General Comments		
567371	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCC000421	LTCControl	SM-TRANS 5	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
567372	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
567373	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
567374	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
567375	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
567376	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
567377	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
567378	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
567379	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
567380	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
567381	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
567382	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
567383	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
567384	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	General Comments		
567385	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
567386	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
567387	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
567388	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
567389	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000515	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
567390	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000515	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
567391	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000515	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
567392	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
567393	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000515	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
567394	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000515	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
567395	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000515	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
567396	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000515	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
567397	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000515	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
567398	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000515	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
567399	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000514	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
567400	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000514	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
567401	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000514	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
567402	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000514	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
567403	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000514	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	121.0	VAC
567404	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000514	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
567405	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000514	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
567406	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000514	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
567407	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000514	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
567408	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
567409	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
567410	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
567411	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
567412	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
567413	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
567414	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
567415	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
567416	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
567417	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	140.0	
567418	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	140.0	
567419	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	140.0	
567420	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	Follow-up Action Required?	n	
567421	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
567422	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	General Comments		
567423	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Clear of Trash?	y	
567424	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
567425	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	3961	
567426	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	14	
567427	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
567428	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	4	
567429	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
567430	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
567431	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
567432	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
567433	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
567434	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
567435	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
567436	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Accumulated Fault Duty C Ph V	7.32	%
567437	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Amps A Ø	80.0	
567438	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Amps B Ø	89.0	
567439	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Amps C Ø	118.0	
567440	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Bushing Condition	Good	
567441	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Bushings Connection/Risers	Good	
567442	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
567443	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
567444	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
567445	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
567446	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
567447	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
567448	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
567449	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
567450	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	3961	
567451	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
567452	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
567453	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
567454	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Cabinet Paint Condition	Good	
567455	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
567456	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
567457	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
567458	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Vegetation	None	
567459	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	General Comments	Mudhole in drive	
567460	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
567461	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
567462	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
567463	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
567464	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
567465	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Clear of Trash?	y	
567466	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
567467	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
567468	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
567469	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
567470	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
567471	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
567472	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
567473	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Tank Leaks	None	
567474	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
567475	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Regulator As Left Counter	61404	
567476	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
567477	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
567478	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Vegetation	None	
567479	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
567480	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	General Comments	ok	
567481	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
567482	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
567483	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
567484	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
567485	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
567486	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
567487	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
567488	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
567489	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
567490	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
567491	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
567492	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCC000832	LTCControl	SM-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
567493	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCC000832	LTCControl	SM-TRANS 2	LTC Control Insp	General Comments		
567494	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCC000832	LTCControl	SM-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
567495	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCC000831	LTCControl	SM-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
567496	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCC000831	LTCControl	SM-TRANS 1	LTC Control Insp	General Comments		
567497	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCC000831	LTCControl	SM-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
567498	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
567499	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
567500	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
567501	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
567502	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
567503	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	General Comments		
567504	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
567505	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
567506	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Foundation Condition	Good	
567507	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
567508	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
567509	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
567510	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
567511	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
567512	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
567513	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
567514	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	Vegetation	None	
567515	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Operations C Ø	0	
567516	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Operations Ground	0	
567517	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000325	PowerFuse	SM-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
567518	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000325	PowerFuse	SM-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
567519	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Follow-up Action Required?	n	
567520	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Follow-up Action Required?	n	
567521	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Foundation Condition	Good	
567522	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	General Comments		
567523	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	General Comments	51 A phase fault	
567524	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Grounds in Place?	y	
567525	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Heaters (All) Functioning?	y	
567526	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
567527	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
567528	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
567529	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	General Comments		
567530	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
567531	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
567532	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
567533	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
567534	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
567535	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
567536	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
567537	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000324	PowerFuse	SM-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	ok	
567538	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000324	PowerFuse	SM-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
567539	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000323	PowerFuse	SM-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
567540	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Tank Leaks	None	
567541	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
567542	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	General Comments		
567543	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
567544	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
567545	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
567546	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
567547	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
567548	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
567549	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
567550	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
567551	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
567552	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Mechanism Patrol Inspection	General Comments		
567553	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC As Found Counter	4858	
567554	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC As Left Counter	4867	
567555	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
567556	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC Current Tap Position	5R	
567557	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC Max Tap Position	3L	
567558	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
567559	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
567560	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
567561	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
567562	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
567563	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
567564	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
567565	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
567566	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
567567	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
567568	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
567569	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
567570	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
567571	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
567572	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Foundation Condition	Good	
567573	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
567574	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	General Comments		
567575	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
567576	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
567577	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Operations A Ø	1	
567578	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Operations B Ø	0	
567579	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
567580	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
567581	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
567582	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
567583	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
567584	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
567585	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
567586	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
567587	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
567588	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
567589	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
567590	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
567591	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
567592	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
567593	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC Min Tap Position	12L	
567594	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC Operations Since Last Insp	456	
567595	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
567596	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
567597	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
567598	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
567599	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
567600	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
567601	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
567602	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Patrol Inspection	Equipment Properly Labeled?	y	
567603	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Amps C Ø	0.0	
567604	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Amps B Ø	0.0	
567605	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
567606	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	General Comments		
567607	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Amps A Ø	0.0	
567608	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
567609	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
567610	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
567611	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	9 Month Operations	0	
567612	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Tank Paint Condition	Good	
567613	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
567614	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Moisture and Leak Free?	y	
567615	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Heaters (All) Functioning?	y	
567616	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Grounds in Place?	y	
567617	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	General Comments		
567618	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Foundation Condition	Good	
567619	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Follow-up Action Required?	n	
567620	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Equipment Properly Labeled?	y	
567621	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Cabinet Paint Condition	Good	
567622	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
567623	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
567624	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
567625	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Bushings Connection/Risers	Good	
567626	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Bushing Condition	Good	
567627	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	Follow-up Action Required?	n	
567628	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	All Connections OK?	y	
567629	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Amps C Ø	0.0	
567630	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Amps B Ø	0.0	
567631	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Amps A Ø	0.0	
567632	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
567633	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
567634	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
567635	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	9 Month Operations	0	
567636	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	VRR Time Delay	30	Seconds
567637	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
567638	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
567639	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
567640	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	LTC Output Voltage Level	121.0	VAC
567641	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	LTC Operation Checked?	y	
567642	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	General Comments		
567643	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	Follow-up Action Required?	n	
567644	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	All Connections OK?	y	
567645	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1315	
567646	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1315	
567647	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
567648	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
567649	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
567650	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
567651	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
567652	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
567653	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
567654	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
567655	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Heaters (All) Functioning?	y	
567656	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Grounds in Place?	y	
567657	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	General Comments		
567658	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Foundation Condition	Good	
567659	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Follow-up Action Required?	n	
567660	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Equipment Properly Labeled?	y	
567661	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Cabinet Paint Condition	Good	
567662	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
567663	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
567664	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
567665	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Bushings Connection/Risers	Good	
567666	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Bushing Condition	Good	
567667	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Tank Paint Condition	Good	
567668	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
567669	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Moisture and Leak Free?	y	
567670	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	LTC Operation Checked?	y	
567671	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	General Comments		
567672	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Heaters (All) Functioning?	y	
567673	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Grounds in Place?	y	
567674	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	General Comments		
567675	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Foundation Condition	Good	
567676	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
567677	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Equipment Properly Labeled?	y	
567678	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Cabinet Paint Condition	Good	
567679	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
567680	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
567681	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
567682	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Bushings Connection/Risers	Good	
567683	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Bushing Condition	Good	
567684	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Tank Paint Condition	Good	
567685	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
567686	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Moisture and Leak Free?	y	
567687	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Heaters (All) Functioning?	y	
567688	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Grounds in Place?	y	
567689	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	General Comments		
567690	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Foundation Condition	Good	
567691	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Follow-up Action Required?	n	
567692	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Equipment Properly Labeled?	y	
567693	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Cabinet Paint Condition	Good	
567694	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
567695	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
567696	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
567697	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Bushings Connection/Risers	Good	
567698	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Bushing Condition	Good	
567699	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Unknown Operations	0	
567700	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Switching Operations	0	
567701	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Operations Counter AL	143	
567702	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Operations Counter AF	143	
567703	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Maintenance Operations	0	
567704	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	General Comments		
567705	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Patrol Inspection	General Comments		
567706	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Follow-up Action Required?	n	
567707	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Patrol Inspection	Follow-up Action Required?	n	
567708	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Operations Ground	0	
567709	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Operations C Ø	0	
567710	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Operations B Ø	0	
567711	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Operations A Ø	0	
567712	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
567713	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
567714	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
567715	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
567716	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
567717	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
567718	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
567719	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
567720	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
567721	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
567722	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
567723	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
567724	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
567725	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
567726	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
567727	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
567728	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
567729	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
567730	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
567731	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
567732	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
567733	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Accumulated Fault Duty A Ph V	7.73	%
567734	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Accumulated Fault Duty B Ph V	7.73	%
567735	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
567736	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
567737	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
567738	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
567739	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
567740	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2159	
567741	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	300	
567742	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
567743	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
567744	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
567745	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
567746	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
567747	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
567748	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
567749	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
567750	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	PF000062	PowerFuse	C-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
567751	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
567752	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
567753	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	PF000062	PowerFuse	C-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
567754	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
567755	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
567756	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
567757	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	64.77	kw
567758	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
567759	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
567760	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
567761	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	General Comments		
567762	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
567763	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
567764	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
567765	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
567766	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
567767	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	General Comments	ok	
567768	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC Operations Since Last Insp	502	
567769	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	18	°C
567770	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
567771	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC Min Tap Position	12L	
567772	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC Max Tap Position	1L	
567773	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC Current Tap Position	6L	
567774	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
567775	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC As Left Counter	4382	
567776	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC As Found Counter	4382	
567777	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	General Comments		
567778	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	General Comments		
567779	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
567780	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	Follow-up Action Required?	n	
567781	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	9 Month Operations	6	
567782	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
567783	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
567784	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Panel Lights OK?	y	
567785	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Panels Dusted?	y	
567786	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
567787	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
567788	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Vent Fans OK?	y	
567789	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
567790	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
567791	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
567792	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
567793	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	General Comments	ok	
567794	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
567795	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
567796	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
567797	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	34	°C
567798	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	40	°C
567799	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	34	°C
567800	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	40	°C
567801	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	34	°C
567802	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	40	°C
567803	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
567804	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
567805	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
567806	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
567807	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
567808	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
567809	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
567810	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
567811	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
567812	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	Oil Temp Present	34	°C
567813	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	Oil Temp Max	40	°C
567814	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	200	psi
567815	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
567816	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
567817	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
567818	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	General Comments		
567819	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
567820	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
567821	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
567822	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
567823	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
567824	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
567825	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
567826	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps B Ø	50.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
567827	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
567828	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
567829	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
567830	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
567831	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
567832	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
567833	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
567834	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
567835	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
567836	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Regulator As Left Counter	17105	
567837	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
567838	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Tank Leaks	None	
567839	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
567840	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
567841	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
567842	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
567843	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
567844	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
567845	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
567846	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
567847	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
567848	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
567849	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000204	LTCControl	220-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
567850	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000204	LTCControl	220-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
567851	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000204	LTCControl	220-Offline-Distribution	LTC Control Insp	General Comments		
567852	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	General Comments		
567853	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Readings	General Comments		
567854	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
567855	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
567856	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Readings	Maintenance Operations	1	
567857	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
567858	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AF	389	
567859	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AL	390	
567860	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
567861	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
567862	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Tank Leaks	None	
567863	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
567864	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Grounds in Place?	y	
567865	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	General Comments		
567866	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
567867	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Foundation Condition	Good	
567868	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
567869	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
567870	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Bushing Condition	Good	
567871	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Amps A Ø	22.0	
567872	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Amps B Ø	16.0	
567873	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
567874	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Vegetation	None	
567875	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
567876	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
567877	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	General Comments		
567878	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
567879	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
567880	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
567881	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
567882	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
567883	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
567884	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2R	
567885	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
567886	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
567887	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
567888	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Tank Leaks	None	
567889	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
567890	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
567891	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
567892	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
567893	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Regulator As Left Counter	81641	
567894	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
567895	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
567896	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
567897	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
567898	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
567899	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
567900	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
567901	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	General Comments	ok	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
567902	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
567903	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
567904	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
567905	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
567906	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
567907	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
567908	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
567909	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
567910	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
567911	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
567912	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Switching Operations	0	
567913	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Tank Paint Condition	Good	
567914	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Unknown Operations	0	
567915	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Readings	9 Month Operations	2	
567916	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	4.98	%
567917	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
567918	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
567919	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
567920	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
567921	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
567922	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
567923	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
567924	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
567925	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
567926	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
567927	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	General Comments	ok	
567928	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
567929	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
567930	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
567931	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
567932	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
567933	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
567934	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
567935	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
567936	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.85	%
567937	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.85	%
567938	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
567939	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
567940	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
567941	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
567942	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	9 Month Operations	7	
567943	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
567944	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
567945	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
567946	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Amps A Ø	94.0	
567947	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Amps B Ø	87.0	
567948	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Amps C Ø	93.0	
567949	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Bushing Condition	Good	
567950	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Bushings Connection/Risers	Good	
567951	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
567952	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
567953	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
567954	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
567955	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Clear of Trash?	y	
567956	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
567957	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
567958	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Cabinet Paint Condition	Good	
567959	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Equipment Properly Labeled?	y	
567960	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
567961	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
567962	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
567963	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Operations A Ø	0	
567964	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Operations B Ø	0	
567965	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Operations C Ø	0	
567966	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Operations Ground	0	
567967	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Follow-up Action Required?	n	
567968	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Follow-up Action Required?	n	
567969	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Foundation Condition	Good	
567970	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	General Comments		
567971	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	General Comments		
567972	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Grounds in Place?	y	
567973	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Heaters (All) Functioning?	y	
567974	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
567975	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
567976	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
567977	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
567978	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	2L	
567979	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	9L	
567980	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
567981	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
567982	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
567983	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
567984	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
567985	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
567986	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Maintenance Operations	0	
567987	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Moisture and Leak Free?	y	
567988	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Operations Counter AF	268	
567989	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Operations Counter AL	268	
567990	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
567991	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Switching Operations	0	
567992	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Tank Paint Condition	Good	
567993	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Unknown Operations	0	
567994	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
567995	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Amps C Ø	17.0	
567996	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
567997	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
567998	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
567999	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
568000	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
568001	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
568002	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Readings	Switching Operations	0	
568003	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
568004	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Winding Temp Present	20	°C
568005	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Winding Temp Max	30	°C
568006	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Totalizer Meter Reading	.2742	
568007	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
568008	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
568009	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
568010	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Tank Leaks	None	
568011	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
568012	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
568013	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
568014	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
568015	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Oil Temp Present	20	°C
568016	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Oil Temp Max	29	°C
568017	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
568018	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
568019	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
568020	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	LTC Totalizer Reading	4178.81	kw
568021	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
568022	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	General Comments		
568023	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	General Comments		
568024	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
568025	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
568026	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Follow-up Action Required?	n	
568027	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
568028	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Fans Operational?	y	
568029	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Fans Condition	Good	
568030	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
568031	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
568032	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
568033	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
568034	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
568035	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
568036	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
568037	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
568038	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
568039	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
568040	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
568041	2/15/2019 14:57	Distribution	Madisonville East Quarterly Inspection	WB0105	BreakerVacuum	912-Offline-Distribution	VCB Readings	Unknown Operations	0	
568042	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
568043	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
568044	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
568045	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
568046	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	General Comments	ok	
568047	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
568048	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
568049	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	102056	
568050	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
568051	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
568052	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
568053	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Regulator As Left Counter	92198	
568054	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
568055	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
568056	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
568057	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
568058	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
568059	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
568060	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
568061	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
568062	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	General Comments	ok	
568063	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
568064	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
568065	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
568066	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
568067	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
568068	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
568069	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
568070	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
568071	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
568072	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
568073	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
568074	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
568075	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
568076	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
568077	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
568078	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
568079	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
568080	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
568081	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
568082	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
568083	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
568084	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
568085	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
568086	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
568087	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	General Comments		
568088	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
568089	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
568090	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
568091	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
568092	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
568093	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
568094	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
568095	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
568096	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
568097	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
568098	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
568099	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
568100	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
568101	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000086	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
568102	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000086	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
568103	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000086	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
568104	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000086	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
568105	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000086	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	121.0	VAC
568106	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000086	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
568107	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Regulator As Left Counter	99976	
568108	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
568109	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
568110	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
568111	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
568112	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
568113	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
568114	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
568115	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
568116	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	General Comments	ok	
568117	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
568118	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
568119	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
568120	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000323	PowerFuse	SM-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
568121	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000322	PowerFuse	SM-14KV TR 6 POT	Disconnect Powerfuse Inspection	General Comments	ok	
568122	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000322	PowerFuse	SM-14KV TR 6 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
568123	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000320	PowerFuse	SM-14KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
568124	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000320	PowerFuse	SM-14KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	y	
568125	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000319	PowerFuse	SM-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
568126	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000319	PowerFuse	SM-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
568127	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
568128	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
568129	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
568130	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
568131	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
568132	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
568133	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
568134	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
568135	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
568136	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
568137	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
568138	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
568139	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
568140	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
568141	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
568142	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
568143	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
568144	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
568145	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
568146	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	Clear of Trash?	y	
568147	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
568148	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
568149	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Tank Leaks	None	
568150	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
568151	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	General Comments		
568152	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
568153	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
568154	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
568155	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
568156	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
568157	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
568158	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
568159	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
568160	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
568161	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
568162	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
568163	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
568164	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
568165	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Foundation Condition	Good	
568166	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
568167	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
568168	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
568169	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
568170	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
568171	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000314	PowerFuse	SM-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
568172	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
568173	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
568174	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
568175	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
568176	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Tank Leaks	None	
568177	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
568178	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000313	PowerFuse	SM-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
568179	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000313	PowerFuse	SM-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
568180	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Regulator As Left Counter	83966	
568181	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
568182	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
568183	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
568184	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
568185	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
568186	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000312	PowerFuse	SM-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
568187	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
568188	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
568189	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	General Comments	ok	
568190	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
568191	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
568192	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
568193	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000312	PowerFuse	SM-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
568194	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
568195	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
568196	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
568197	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
568198	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
568199	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
568200	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
568201	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
568202	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
568203	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
568204	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Operations Counter AL	188	
568205	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
568206	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
568207	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
568208	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
568209	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	61399	
568210	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
568211	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
568212	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
568213	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
568214	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
568215	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	5L	
568216	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	4R	
568217	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
568218	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
568219	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
568220	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000086	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
568221	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000086	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
568222	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	LTCC000086	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
568223	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
568224	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
568225	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
568226	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
568227	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
568228	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
568229	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
568230	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
568231	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
568232	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
568233	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
568234	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
568235	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
568236	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
568237	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
568238	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
568239	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
568240	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
568241	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
568242	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
568243	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
568244	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
568245	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
568246	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Tank Leaks	None	
568247	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
568248	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Regulator As Left Counter	128552	
568249	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
568250	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
568251	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
568252	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
568253	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
568254	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
568255	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
568256	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	General Comments	ok	
568257	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
568258	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
568259	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Moisture and Leak Free?	y	
568260	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Operations Counter AF	188	
568261	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
568262	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
568263	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
568264	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
568265	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
568266	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
568267	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	General Comments		
568268	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LTCC000532	LTCControl	C-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
568269	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LTCC000532	LTCControl	C-TRANS 4	LTC Control Insp	General Comments		
568270	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LTCC000532	LTCControl	C-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
568271	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000317	PowerFuse	SM-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
568272	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000317	PowerFuse	SM-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
568273	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000315	PowerFuse	SM-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
568274	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000315	PowerFuse	SM-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
568275	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000314	PowerFuse	SM-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
568276	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
568277	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
568278	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Grounds in Place?	y	
568279	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	General Comments		
568280	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	General Comments		
568281	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Foundation Condition	Good	
568282	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
568283	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
568284	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Regulator As Left Counter	292099	
568285	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
568286	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
568287	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
568288	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
568289	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
568290	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
568291	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
568292	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Unknown Operations	0	
568293	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Tank Paint Condition	Good	
568294	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Switching Operations	0	
568295	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Operations Counter AL	131	
568296	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
568297	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
568298	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
568299	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	General Comments		
568300	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
568301	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
568302	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
568303	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
568304	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
568305	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
568306	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
568307	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
568308	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
568309	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
568310	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
568311	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
568312	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
568313	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
568314	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
568315	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
568316	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
568317	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
568318	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
568319	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
568320	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
568321	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
568322	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
568323	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
568324	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
568325	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
568326	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
568327	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
568328	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
568329	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
568330	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
568331	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
568332	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
568333	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
568334	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Cabinet Paint Condition	Good	
568335	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Equipment Properly Labeled?	y	
568336	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
568337	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
568338	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
568339	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
568340	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
568341	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
568342	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
568343	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
568344	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
568345	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
568346	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
568347	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
568348	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
568349	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Operations A Ø	0	
568350	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Operations B Ø	0	
568351	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
568352	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Operations Ground	0	
568353	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Follow-up Action Required?	n	
568354	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Follow-up Action Required?	n	
568355	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Foundation Condition	Good	
568356	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	General Comments		
568357	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	General Comments		
568358	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Grounds in Place?	y	
568359	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Heaters (All) Functioning?	y	
568360	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Maintenance Operations	0	
568361	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Moisture and Leak Free?	y	
568362	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Operations Counter AF	177	
568363	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Operations Counter AL	177	
568364	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Switching Operations	0	
568365	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Tank Paint Condition	Good	
568366	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Unknown Operations	0	
568367	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KX0081	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Operations Counter	116	
568368	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KX0081	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
568369	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KX0081	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
568370	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KX0081	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
568371	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
568372	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
568373	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
568374	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
568375	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Tank Leaks	None	
568376	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
568377	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
568378	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
568379	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
568380	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
568381	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
568382	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Unknown Operations	0	
568383	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Tank Paint Condition	Good	
568384	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Switching Operations	0	
568385	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
568386	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Operations Counter AL	99869	
568387	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Operations Counter AF	99869	
568388	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Moisture and Leak Free?	y	
568389	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Maintenance Operations	0	
568390	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Tank Leaks	None	
568391	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
568392	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Regulator As Left Counter	56901	
568393	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.6	volts
568394	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
568395	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
568396	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
568397	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
568398	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
568399	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
568400	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	General Comments	Cant see oil level through gauge. Previous inspector put wrong counter reading in cascade.	
568401	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
568402	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
568403	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
568404	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
568405	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
568406	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
568407	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
568408	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
568409	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
568410	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
568411	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
568412	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Tank Leaks	None	
568413	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
568414	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Regulator As Left Counter	45570	
568415	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
568416	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
568417	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
568418	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
568419	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
568420	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
568421	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
568422	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	General Comments	Oil level low	
568423	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
568424	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
568425	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
568426	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
568427	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Unknown Operations	0	
568428	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Tank Paint Condition	Good	
568429	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Operations C Ø	0	
568430	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Switching Operations	0	
568431	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
568432	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Operations Counter AL	51	
568433	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Operations Counter AF	51	
568434	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Operations B Ø	0	
568435	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Operations A Ø	0	
568436	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
568437	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
568438	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
568439	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Equipment Properly Labeled?	y	
568440	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Cabinet Paint Condition	Good	
568441	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
568442	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
568443	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
568444	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
568445	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
568446	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
568447	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
568448	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
568449	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
568450	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
568451	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Follow-up Action Required?	n	
568452	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Follow-up Action Required?	n	
568453	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Operations Ground	0	
568454	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Operations C Ø	0	
568455	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Operations B Ø	0	
568456	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Operations A Ø	0	
568457	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
568458	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
568459	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
568460	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
568461	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
568462	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
568463	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
568464	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
568465	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	General Comments	low oil level	
568466	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
568467	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
568468	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
568469	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
568470	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Patrol Inspection	General Comments		
568471	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Patrol Inspection	Follow-up Action Required?	n	
568472	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Patrol Inspection	Equipment Properly Labeled?	y	
568473	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
568474	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
568475	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
568476	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
568477	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.6	volts
568478	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Regulator As Left Counter	57159	
568479	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
568480	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Tank Leaks	None	
568481	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
568482	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Operations Counter AF	131	
568483	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Moisture and Leak Free?	y	
568484	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Maintenance Operations	0	
568485	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Heaters (All) Functioning?	y	
568486	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Grounds in Place?	y	
568487	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	General Comments		
568488	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	General Comments		
568489	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Bushings Connection/Risers	Good	
568490	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Bushing Condition	Good	
568491	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Amps C Ø	0.0	
568492	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Foundation Condition	Good	
568493	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Follow-up Action Required?	n	
568494	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Follow-up Action Required?	n	
568495	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Operations Ground	0	
568496	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Amps B Ø	0.0	
568497	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Amps A Ø	0.0	
568498	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
568499	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
568500	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
568501	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	9 Month Operations	4	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
568502	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
568503	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
568504	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
568505	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Operations A Ø	0	
568506	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
568507	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
568508	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	General Comments		
568509	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC As Found Counter	8525	
568510	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC As Left Counter	8525	
568511	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC Current Tap Position	6R	
568512	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC Max Tap Position	7R	
568513	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC Min Tap Position	5R	
568514	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	2	
568515	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
568516	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
568517	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
568518	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
568519	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
568520	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
568521	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KX0081	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	75.0	
568522	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KX0081	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	61.0	
568523	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KX0081	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
568524	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KX0081	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
568525	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KX0081	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
568526	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KX0081	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
568527	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	40.0	
568528	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	40.0	
568529	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	40.0	
568530	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KX0081	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
568531	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
568532	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KX0081	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
568533	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
568534	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
568535	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
568536	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	100.0	
568537	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	100.0	
568538	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	100.0	
568539	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
568540	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
568541	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
568542	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
568543	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
568544	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
568545	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
568546	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
568547	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
568548	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
568549	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
568550	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
568551	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
568552	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Readings	General Comments		
568553	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
568554	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	8	
568555	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
568556	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	9	
568557	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1096	
568558	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1096	
568559	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC Operations Since Last Insp	102	
568560	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
568561	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC Min Tap Position	2L	
568562	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC Max Tap Position	8L	
568563	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC Current Tap Position	6L	
568564	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
568565	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC As Left Counter	35409	
568566	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC As Found Counter	35409	
568567	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	General Comments	light out in LTC cabniet	
568568	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	General Comments		
568569	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
568570	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	Follow-up Action Required?	n	
568571	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
568572	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Bushings Connection/Risers	Good	
568573	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Bushing Condition	Good	
568574	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Amps C Ø	115.0	
568575	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Amps B Ø	120.0	
568576	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Amps A Ø	122.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
568577	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Accumulated Fault Duty C Ph V	3.18	%
568578	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Accumulated Fault Duty B Ph V	2.78	%
568579	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Accumulated Fault Duty A Ph V	2.78	%
568580	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	9 Month Operations	2	
568581	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KX0081	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	65.0	
568582	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
568583	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
568584	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
568585	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
568586	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
568587	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
568588	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
568589	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
568590	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1442	
568591	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BCH000893	Charger	733-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
568592	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BCH000893	Charger	733-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
568593	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BCH000893	Charger	733-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
568594	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BCH000893	Charger	733-Battery Charger	Battery Charger Patrol Insp	General Comments		
568595	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1442	
568596	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
568597	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
568598	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
568599	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
568600	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	General Comments		
568601	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
568602	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
568603	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Cabinet Paint Condition	Good	
568604	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Equipment Properly Labeled?	y	
568605	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
568606	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
568607	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
568608	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
568609	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
568610	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
568611	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
568612	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
568613	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
568614	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
568615	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
568616	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Switching Operations	0	
568617	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Tank Paint Condition	Good	
568618	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Unknown Operations	0	
568619	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	32	
568620	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3R	
568621	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	LTC As Left Counter	21863	
568622	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	LTC As Found Counter	21863	
568623	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
568624	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
568625	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
568626	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KX0081	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
568627	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KX0081	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
568628	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
568629	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	General Comments		
568630	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
568631	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
568632	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
568633	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
568634	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KX0081	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
568635	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	General Comments		
568636	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
568637	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
568638	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
568639	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Counter Readings	General Comments		
568640	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
568641	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
568642	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
568643	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Counter Readings	LTC As Found Counter	73455	
568644	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Counter Readings	LTC As Left Counter	73455	
568645	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
568646	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Counter Readings	LTC Current Tap Position	5R	
568647	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	935	
568648	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
568649	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
568650	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KX0081	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
568651	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KX0081	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
568652	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KX0081	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
568653	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	KX0081	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
568654	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
568655	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
568656	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
568657	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
568658	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	BCH000412	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.9	VDC
568659	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	BCH000412	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
568660	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	BCH000412	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
568661	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	9 Month Operations	1	
568662	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
568663	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
568664	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
568665	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Amps A Ø	42.0	
568666	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Amps B Ø	45.0	
568667	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Amps C Ø	63.0	
568668	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Bushing Condition	Good	
568669	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Bushings Connection/Risers	Good	
568670	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
568671	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
568672	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
568673	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
568674	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
568675	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
568676	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
568677	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
568678	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
568679	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
568680	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
568681	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
568682	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Tank Leaks	None	
568683	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
568684	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Regulator As Left Counter	164666	
568685	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
568686	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
568687	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
568688	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
568689	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
568690	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
568691	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
568692	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
568693	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
568694	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
568695	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
568696	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
568697	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
568698	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
568699	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
568700	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
568701	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
568702	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
568703	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	32	
568704	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3R	
568705	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	LTC As Left Counter	81293	
568706	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	LTC As Found Counter	81293	
568707	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Operations B Ø	0	
568708	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Operations C Ø	0	
568709	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Operations Ground	0	
568710	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Follow-up Action Required?	n	
568711	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Follow-up Action Required?	n	
568712	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Foundation Condition	Good	
568713	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	General Comments		
568714	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	General Comments		
568715	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	General Comments		
568716	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
568717	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
568718	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
568719	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
568720	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
568721	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
568722	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
568723	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Grounds in Place?	y	
568724	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Heaters (All) Functioning?	y	
568725	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Maintenance Operations	0	
568726	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
568727	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Operations Counter AF	102	
568728	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Operations Counter AL	102	
568729	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
568730	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
568731	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
568732	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
568733	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	General Comments	ok	
568734	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
568735	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
568736	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Foundation Condition	Good	
568737	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
568738	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
568739	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
568740	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
568741	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
568742	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
568743	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
568744	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
568745	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
568746	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
568747	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	LTCMechanism	733-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
568748	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	LTCMechanism	733-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
568749	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	LTCMechanism	733-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
568750	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	LTCMechanism	733-1	LTC Counter Readings	LTC Operations Since Last Insp	867	
568751	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	LTCMechanism	733-1	LTC Counter Readings	LTC Min Tap Position	2L	
568752	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	LTCMechanism	733-1	LTC Counter Readings	LTC Max Tap Position	9L	
568753	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	All Connections OK?	y	
568754	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000321	PowerFuse	SM-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
568755	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000321	PowerFuse	SM-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
568756	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	Follow-up Action Required?	n	
568757	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	General Comments		
568758	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000316	PowerFuse	SM-GND TR 2	Disconnect Powerfuse Inspection	General Comments	ok	
568759	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000316	PowerFuse	SM-GND TR 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
568760	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
568761	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	LTC Operation Checked?	y	
568762	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
568763	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
568764	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
568765	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	VRR Time Delay	30	Seconds
568766	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	LTCMechanism	733-1	LTC Counter Readings	LTC Current Tap Position	6L	
568767	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	LTCMechanism	733-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
568768	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	LTCMechanism	733-1	LTC Counter Readings	LTC As Left Counter	75676	
568769	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	LTCMechanism	733-1	LTC Counter Readings	LTC As Found Counter	75672	
568770	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	LTCMechanism	733-1	LTC Mechanism Patrol Inspection	General Comments		
568771	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	LTCMechanism	733-1	LTC Counter Readings	General Comments		
568772	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	LTCMechanism	733-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
568773	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	LTCMechanism	733-1	LTC Counter Readings	Follow-up Action Required?	n	
568774	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	VRR Time Delay	45	Seconds
568775	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
568776	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
568777	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
568778	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
568779	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
568780	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Vegetation	None	
568781	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
568782	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
568783	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
568784	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	General Comments	ok	
568785	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
568786	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
568787	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	1R	
568788	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
568789	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
568790	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
568791	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
568792	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
568793	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
568794	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	151703	
568795	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
568796	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
568797	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
568798	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	General Comments	ok	
568799	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
568800	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
568801	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
568802	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
568803	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
568804	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
568805	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
568806	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
568807	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
568808	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
568809	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
568810	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
568811	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Unknown Operations	0	
568812	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Switching Operations	0	
568813	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Operations Counter AL	171	
568814	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Operations Counter AF	171	
568815	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Maintenance Operations	0	
568816	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	General Comments		
568817	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Patrol Inspection	General Comments		
568818	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Follow-up Action Required?	n	
568819	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Patrol Inspection	Follow-up Action Required?	n	
568820	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Fault Operations Ground	0	
568821	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
568822	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Fault Operations C Ø	0	
568823	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Fault Operations B Ø	0	
568824	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Fault Operations A Ø	0	
568825	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
568826	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
568827	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
568828	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
568829	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
568830	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
568831	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
568832	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
568833	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
568834	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
568835	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
568836	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
568837	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	967	
568838	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	967	
568839	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
568840	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
568841	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
568842	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Grounds in Place?	y	
568843	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
568844	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
568845	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
568846	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
568847	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
568848	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
568849	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
568850	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
568851	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	General Comments		
568852	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	General Comments		
568853	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Foundation Condition	Good	
568854	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Follow-up Action Required?	n	
568855	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Follow-up Action Required?	n	
568856	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Operations Ground	0	
568857	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Operations C Ø	0	
568858	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Operations B Ø	0	
568859	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Operations A Ø	0	
568860	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
568861	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
568862	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
568863	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Equipment Properly Labeled?	y	
568864	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Cabinet Paint Condition	Good	
568865	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
568866	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
568867	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
568868	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Bushings Connection/Risers	Good	
568869	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Bushing Condition	Good	
568870	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Amps C Ø	250.0	
568871	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000311	PowerFuse	SM-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
568872	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	LTC Output Voltage Level	121.0	VAC
568873	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000311	PowerFuse	SM-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
568874	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Amps B Ø	260.0	
568875	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Amps A Ø	260.0	
568876	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
568877	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
568878	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
568879	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	9 Month Operations	0	
568880	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
568881	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Clear of Trash?	y	
568882	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
568883	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
568884	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
568885	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
568886	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
568887	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
568888	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Door Alarms OK?	y	
568889	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
568890	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
568891	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Evidence of Insects	None	
568892	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
568893	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
568894	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Follow-up Action Required?	n	
568895	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Tank Paint Condition	Good	
568896	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
568897	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Moisture and Leak Free?	y	
568898	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
568899	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
568900	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
568901	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
568902	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
568903	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
568904	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
568905	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
568906	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
568907	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	Oil Temp Present	40	°C
568908	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	Oil Temp Max	55	°C
568909	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
568910	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
568911	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
568912	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
568913	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	General Comments		
568914	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
568915	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
568916	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
568917	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
568918	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
568919	2/15/2019 14:56	Distribution	Walker Quarterly Inspection	BCH000174	Charger	005-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.0	VDC
568920	2/15/2019 14:56	Distribution	Walker Quarterly Inspection	BCH000174	Charger	005-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.0	VDC
568921	2/15/2019 14:56	Distribution	Walker Quarterly Inspection	BCH000174	Charger	005-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
568922	2/15/2019 14:56	Distribution	Walker Quarterly Inspection	BCH000174	Charger	005-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
568923	2/15/2019 14:56	Distribution	Walker Quarterly Inspection	BCH000174	Charger	005-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
568924	2/15/2019 14:56	Distribution	Walker Quarterly Inspection	BCH000174	Charger	005-Battery Charger	Battery Charger Patrol Insp	General Comments		
568925	2/15/2019 14:56	Distribution	Walker Quarterly Inspection	BCH000174	Charger	005-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
568926	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
568927	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
568928	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
568929	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
568930	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
568931	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
568932	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
568933	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
568934	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
568935	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
568936	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
568937	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
568938	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
568939	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
568940	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
568941	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
568942	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
568943	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
568944	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Unknown Operations	0	
568945	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Tank Paint Condition	Good	
568946	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Switching Operations	0	
568947	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
568948	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Operations Counter AL	122	
568949	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Operations Counter AF	122	
568950	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000326	PowerFuse	SM-14KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
568951	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	PF000326	PowerFuse	SM-14KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
568952	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Moisture and Leak Free?	y	
568953	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Maintenance Operations	0	
568954	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Heaters (All) Functioning?	y	
568955	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Grounds in Place?	y	
568956	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	General Comments		
568957	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	General Comments		
568958	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Foundation Condition	Good	
568959	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Follow-up Action Required?	n	
568960	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Follow-up Action Required?	n	
568961	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Operations Ground	0	
568962	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Operations C Ø	0	
568963	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Operations B Ø	0	
568964	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Operations A Ø	0	
568965	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
568966	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
568967	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
568968	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Equipment Properly Labeled?	y	
568969	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Cabinet Paint Condition	Good	
568970	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
568971	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
568972	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
568973	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Bushings Connection/Risers	Good	
568974	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Bushing Condition	Good	
568975	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Amps C Ø	480.0	
568976	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Amps B Ø	480.0	
568977	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Amps A Ø	480.0	
568978	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
568979	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
568980	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
568981	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	9 Month Operations	7	
568982	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Operations A Ø	0	
568983	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
568984	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
568985	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
568986	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Equipment Properly Labeled?	y	
568987	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Cabinet Paint Condition	Good	
568988	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
568989	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
568990	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
568991	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Bushings Connection/Risers	Good	
568992	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Bushing Condition	Good	
568993	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Amps C Ø	200.0	
568994	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Amps B Ø	200.0	
568995	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Amps A Ø	200.0	
568996	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
568997	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
568998	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
568999	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	9 Month Operations	5	
569000	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
569001	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
569002	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
569003	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
569004	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	40.0	
569005	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	40.0	
569006	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	40.0	
569007	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
569008	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
569009	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
569010	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
569011	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
569012	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
569013	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
569014	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
569015	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
569016	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Tank Leaks	None	
569017	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
569018	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Regulator As Left Counter	55199	
569019	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
569020	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
569021	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
569022	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
569023	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Moisture and Leak Free?	y	
569024	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
569025	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
569026	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Max Tap Position	5R	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
569027	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
569028	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	General Comments	ok	
569029	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
569030	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
569031	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
569032	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
569033	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
569034	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
569035	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
569036	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
569037	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
569038	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
569039	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Unknown Operations	0	
569040	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Tank Paint Condition	Good	
569041	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Switching Operations	0	
569042	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
569043	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Bushings Connection/Risers	Good	
569044	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Bushing Condition	Good	
569045	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Amps C Ø	310.0	
569046	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Amps B Ø	230.0	
569047	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Amps A Ø	245.0	
569048	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Accumulated Fault Duty C Ph V	1.91	%
569049	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Accumulated Fault Duty B Ph V	2.87	%
569050	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Accumulated Fault Duty A Ph V	2.87	%
569051	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	9 Month Operations	1	
569052	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Operations Counter AL	99917	
569053	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Operations Counter AF	99917	
569054	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Moisture and Leak Free?	y	
569055	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Maintenance Operations	0	
569056	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Heaters (All) Functioning?	y	
569057	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Grounds in Place?	y	
569058	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	General Comments		
569059	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	General Comments		
569060	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Foundation Condition	Good	
569061	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Follow-up Action Required?	n	
569062	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Follow-up Action Required?	n	
569063	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Operations Ground	0	
569064	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Operations C Ø	0	
569065	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Operations B Ø	0	
569066	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Maintenance Operations	0	
569067	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Heaters (All) Functioning?	y	
569068	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
569069	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
569070	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Readings	General Comments		
569071	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
569072	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
569073	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
569074	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
569075	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1093	
569076	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1093	
569077	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
569078	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
569079	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
569080	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
569081	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
569082	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
569083	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	General Comments		
569084	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
569085	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
569086	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
569087	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
569088	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
569089	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
569090	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
569091	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
569092	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Clear of Trash?	y	
569093	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
569094	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
569095	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
569096	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
569097	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5586	
569098	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
569099	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
569100	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
569101	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
569102	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
569103	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
569104	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
569105	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
569106	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
569107	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
569108	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
569109	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	5L	
569110	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
569111	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
569112	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
569113	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
569114	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
569115	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
569116	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Oil Temp Max	70	°C
569117	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
569118	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
569119	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1787.52	kw
569120	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
569121	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
569122	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
569123	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
569124	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
569125	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
569126	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
569127	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
569128	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
569129	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
569130	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
569131	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
569132	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
569133	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
569134	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	General Comments		
569135	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
569136	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Foundation Condition	Good	
569137	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
569138	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
569139	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
569140	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
569141	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
569142	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
569143	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
569144	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Vegetation	None	
569145	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
569146	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
569147	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
569148	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	General Comments		
569149	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
569150	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
569151	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
569152	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
569153	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
569154	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
569155	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
569156	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
569157	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
569158	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
569159	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	180.0	
569160	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	180.0	
569161	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	180.0	
569162	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
569163	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
569164	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
569165	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
569166	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
569167	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
569168	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
569169	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
569170	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
569171	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
569172	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
569173	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
569174	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
569175	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
569176	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
569177	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
569178	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
569179	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
569180	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
569181	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
569182	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
569183	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
569184	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
569185	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
569186	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
569187	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	9 Month Operations	1	
569188	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
569189	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
569190	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
569191	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
569192	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
569193	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Foundation Condition	Good	
569194	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
569195	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
569196	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
569197	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
569198	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
569199	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
569200	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
569201	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
569202	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
569203	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
569204	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Unknown Operations	0	
569205	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Tank Paint Condition	Good	
569206	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Switching Operations	0	
569207	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
569208	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Operations Counter AL	485	
569209	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Operations Counter AF	485	
569210	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Moisture and Leak Free?	y	
569211	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Maintenance Operations	0	
569212	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Grounds in Place?	y	
569213	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	General Comments		
569214	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	General Comments		
569215	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
569216	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
569217	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Foundation Condition	Good	
569218	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Follow-up Action Required?	n	
569219	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Follow-up Action Required?	n	
569220	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Fault Operations Ground	0	
569221	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Fault Operations C Ø	0	
569222	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Fault Operations B Ø	0	
569223	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Fault Operations A Ø	0	
569224	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
569225	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
569226	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
569227	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Equipment Properly Labeled?	y	
569228	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Cabinet Paint Condition	Good	
569229	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
569230	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
569231	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
569232	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Bushings Connection/Risers	Good	
569233	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Bushing Condition	Good	
569234	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Amps C Ø	630.0	
569235	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Amps B Ø	630.0	
569236	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Operations B Ø	0	
569237	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Operations A Ø	0	
569238	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
569239	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
569240	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
569241	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Equipment Properly Labeled?	y	
569242	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Foundation Condition	Good	
569243	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	General Comments		
569244	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	General Comments		
569245	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Grounds in Place?	y	
569246	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Heaters (All) Functioning?	y	
569247	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Maintenance Operations	0	
569248	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Moisture and Leak Free?	y	
569249	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Operations Counter AF	152	
569250	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Operations Counter AL	152	
569251	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
569252	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Switching Operations	0	
569253	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Tank Paint Condition	Good	
569254	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Cabinet Paint Condition	Good	
569255	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
569256	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
569257	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
569258	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Bushings Connection/Risers	Good	
569259	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Bushing Condition	Good	
569260	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Amps C Ø	100.0	
569261	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Amps B Ø	90.0	
569262	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Amps A Ø	100.0	
569263	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Unknown Operations	0	
569264	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
569265	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
569266	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
569267	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
569268	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
569269	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
569270	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
569271	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
569272	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
569273	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	General Comments		
569274	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Accumulated Fault Duty C Ph V	1.91	%
569275	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Accumulated Fault Duty B Ph V	1.91	%
569276	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Accumulated Fault Duty A Ph V	1.91	%
569277	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
569278	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
569279	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
569280	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
569281	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
569282	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
569283	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
569284	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
569285	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
569286	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
569287	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
569288	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
569289	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
569290	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
569291	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
569292	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Heaters (All) Functioning?	y	
569293	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Grounds in Place?	y	
569294	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	General Comments		
569295	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	General Comments		
569296	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Foundation Condition	Good	
569297	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Follow-up Action Required?	n	
569298	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Follow-up Action Required?	n	
569299	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Operations Ground	0	
569300	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Operations C Ø	0	
569301	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Operations B Ø	0	
569302	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Operations A Ø	0	
569303	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
569304	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
569305	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
569306	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
569307	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
569308	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Operations Counter	227	
569309	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
569310	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Equipment Properly Labeled?	y	
569311	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Cabinet Paint Condition	Good	
569312	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
569313	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
569314	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
569315	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Bushings Connection/Risers	Good	
569316	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Bushing Condition	Good	
569317	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Amps C Ø	480.0	
569318	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Amps B Ø	480.0	
569319	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Amps A Ø	480.0	
569320	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
569321	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
569322	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
569323	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	9 Month Operations	10	
569324	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Tank Paint Condition	Good	
569325	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
569326	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
569327	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Heaters (All) Functioning?	y	
569328	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Grounds in Place?	y	
569329	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	General Comments		
569330	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Foundation Condition	Good	
569331	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Follow-up Action Required?	n	
569332	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Equipment Properly Labeled?	y	
569333	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	General Comments	ok	
569334	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
569335	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
569336	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
569337	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
569338	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
569339	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Amps C Ø	57.5	
569340	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Amps B Ø	57.0	
569341	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Amps A Ø	58.0	
569342	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Switching Operations	0	
569343	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
569344	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
569345	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	General Comments		
569346	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
569347	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
569348	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	9 Month Operations	0	
569349	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
569350	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
569351	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Amps A Ø	630.0	
569352	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
569353	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
569354	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Accumulated Fault Duty A Ph V	1.52	%
569355	2/15/2019 14:06	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	9 Month Operations	7	
569356	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
569357	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Amps A Ø	0.0	
569358	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Amps B Ø	0.0	
569359	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Amps C Ø	0.0	
569360	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Patrol Inspection	Equipment Properly Labeled?	y	
569361	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
569362	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
569363	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
569364	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Operations A Ø	0	
569365	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments	Missing Parts	
569366	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
569367	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
569368	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
569369	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
569370	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
569371	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
569372	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Vegetation	None	
569373	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	General Comments		
569374	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
569375	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
569376	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
569377	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
569378	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
569379	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
569380	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Clear of Trash?	y	
569381	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
569382	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
569383	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
569384	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Operations B Ø	0	
569385	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Operations C Ø	0	
569386	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Operations Ground	0	
569387	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Patrol Inspection	Follow-up Action Required?	n	
569388	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Follow-up Action Required?	n	
569389	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Patrol Inspection	General Comments		
569390	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	General Comments		
569391	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Maintenance Operations	0	
569392	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Operations Counter AF	138	
569393	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Operations Counter AL	138	
569394	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Switching Operations	0	
569395	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Unknown Operations	0	
569396	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Unknown Operations	0	
569397	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Tank Paint Condition	Good	
569398	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Switching Operations	0	
569399	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
569400	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Operations Counter AL	267	
569401	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Operations Counter AF	267	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
569402	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Moisture and Leak Free?	y	
569403	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Maintenance Operations	0	
569404	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
569405	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
569406	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
569407	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Bushings Connection/Risers	Good	
569408	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Bushing Condition	Good	
569409	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Amps C Ø	150.0	
569410	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Amps B Ø	150.0	
569411	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Amps A Ø	150.0	
569412	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
569413	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
569414	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
569415	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	9 Month Operations	2	
569416	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
569417	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
569418	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
569419	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
569420	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Ambient Temp	47	°F
569421	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
569422	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
569423	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
569424	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
569425	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
569426	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
569427	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
569428	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
569429	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
569430	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
569431	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
569432	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Foundation Condition	Good	
569433	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Follow-up Action Required?	y	
569434	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
569435	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
569436	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Clear of Trash?	y	
569437	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
569438	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
569439	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
569440	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
569441	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
569442	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
569443	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	General Comments		
569444	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
569445	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
569446	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
569447	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
569448	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	General Comments		
569449	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
569450	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC As Found Counter	14611	
569451	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
569452	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
569453	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	9 Month Operations	5	
569454	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Accumulated Fault Duty A Ph V	3.33	%
569455	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Accumulated Fault Duty B Ph V	4.17	%
569456	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Accumulated Fault Duty C Ph V	1.67	%
569457	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Amps A Ø	107.0	
569458	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Amps B Ø	104.0	
569459	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Amps C Ø	100.0	
569460	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	Follow-up Action Required?	n	
569461	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
569462	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Wood Structures OK?	n	
569463	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
569464	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
569465	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
569466	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
569467	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
569468	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
569469	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
569470	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
569471	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
569472	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	General Comments	1st pole is marked to be replaced	
569473	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
569474	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
569475	2/15/2019 10:54	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	36	°F
569476	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
569477	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
569478	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Tank Leaks	None	
569479	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Unknown Operations	0	
569480	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Tank Paint Condition	Good	
569481	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
569482	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
569483	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
569484	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
569485	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
569486	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Switching Operations	0	
569487	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Operations Counter AL	165	
569488	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Operations Counter AF	165	
569489	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Moisture and Leak Free?	y	
569490	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Maintenance Operations	0	
569491	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Grounds in Place?	y	
569492	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	General Comments		
569493	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	General Comments		
569494	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Foundation Condition	Good	
569495	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Follow-up Action Required?	n	
569496	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Follow-up Action Required?	n	
569497	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Operations Ground	0	
569498	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Operations C Ø	0	
569499	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Operations B Ø	0	
569500	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
569501	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
569502	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
569503	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
569504	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
569505	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
569506	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
569507	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
569508	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	General Comments		
569509	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
569510	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Operations A Ø	0	
569511	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
569512	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
569513	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
569514	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Equipment Properly Labeled?	y	
569515	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Cabinet Paint Condition	Good	
569516	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Follow-up Action Required?	n	
569517	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Foundation Condition	Good	
569518	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	General Comments		
569519	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	General Comments		
569520	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Grounds in Place?	y	
569521	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Heaters (All) Functioning?	y	
569522	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Maintenance Operations	0	
569523	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Moisture and Leak Free?	y	
569524	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Operations Counter AF	164	
569525	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Operations Counter AL	164	
569526	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
569527	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Switching Operations	0	
569528	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Unknown Operations	0	
569529	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Tank Paint Condition	Good	
569530	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Switching Operations	0	
569531	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Operations Counter AL	168	
569532	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Operations Counter AF	168	
569533	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Tank Paint Condition	Good	
569534	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Unknown Operations	0	
569535	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	9 Month Operations	2	
569536	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Accumulated Fault Duty A Ph V	.83	%
569537	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
569538	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
569539	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
569540	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Accumulated Fault Duty B Ph V	.83	%
569541	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Accumulated Fault Duty C Ph V	.83	%
569542	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Amps A Ø	117.0	
569543	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Amps B Ø	100.0	
569544	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Amps C Ø	121.0	
569545	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Bushing Condition	Good	
569546	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Bushings Connection/Risers	Good	
569547	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
569548	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
569549	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
569550	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Cabinet Paint Condition	Good	
569551	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
569552	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
569553	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
569554	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
569555	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Operations A Ø	0	
569556	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Operations B Ø	0	
569557	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Operations C Ø	0	
569558	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Operations Ground	0	
569559	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Follow-up Action Required?	n	
569560	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Follow-up Action Required?	n	
569561	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Moisture and Leak Free?	y	
569562	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Maintenance Operations	0	
569563	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Heaters (All) Functioning?	y	
569564	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Grounds in Place?	y	
569565	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	General Comments	ok	
569566	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	General Comments		
569567	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Foundation Condition	Good	
569568	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Follow-up Action Required?	n	
569569	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Follow-up Action Required?	n	
569570	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Operations Ground	0	
569571	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Operations C Ø	0	
569572	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Bushing Condition	Good	
569573	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Bushings Connection/Risers	Good	
569574	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
569575	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
569576	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
569577	2/15/2019 8:27	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
569578	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
569579	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC As Left Counter	14611	
569580	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
569581	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
569582	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
569583	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Vegetation	None	
569584	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
569585	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	Oil Temp Present	33	°C
569586	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	Oil Temp Max	45	°C
569587	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
569588	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Cabinet Paint Condition	Good	
569589	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Equipment Properly Labeled?	y	
569590	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
569591	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
569592	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
569593	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	H2 Winding Temp Present	31	°C
569594	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	H2 Winding Temp Max	34	°C
569595	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Grounds in Place?	n	
569596	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	General Comments		
569597	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	General Comments		
569598	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
569599	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
569600	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	Follow-up Action Required?	n	
569601	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
569602	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Fans Operational?	y	
569603	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Fans Condition	Good	
569604	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
569605	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
569606	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
569607	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
569608	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
569609	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
569610	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
569611	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
569612	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
569613	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
569614	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC Current Tap Position	6L	
569615	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC Max Tap Position	3L	
569616	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC Min Tap Position	8L	
569617	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	92	
569618	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
569619	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
569620	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
569621	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
569622	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
569623	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Operations A Ø	0	
569624	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Operations B Ø	0	
569625	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Operations C Ø	0	
569626	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
569627	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Follow-up Action Required?	n	
569628	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Amps B Ø	71.0	
569629	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Amps A Ø	73.0	
569630	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
569631	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
569632	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
569633	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	9 Month Operations	0	
569634	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Unknown Operations	0	
569635	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Tank Paint Condition	Good	
569636	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Switching Operations	0	
569637	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Operations Counter AL	174	
569638	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Unknown Operations	0	
569639	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Tank Paint Condition	Good	
569640	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Tank Oil Level	Good	
569641	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Tank Leaks	None	
569642	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Operations Counter AF	174	
569643	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Moisture and Leak Free?	y	
569644	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Maintenance Operations	0	
569645	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Heaters (All) Functioning?	y	
569646	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Switching Operations	0	
569647	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Operations Counter AL	506	
569648	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Operations Counter AF	506	
569649	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Number of Ops last 9 Months	1	
569650	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Moisture and Leak Free?	y	
569651	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Maintenance Operations	0	
569652	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Grounds in Place?	y	
569653	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	General Comments		
569654	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	General Comments		
569655	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Foundation Condition	Good	
569656	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Follow-up Action Required?	n	
569657	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Follow-up Action Required?	n	
569658	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Fault Operations Ground	0	
569659	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Fault Operations C Ø	0	
569660	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Fault Operations B Ø	0	
569661	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Fault Operations A Ø	0	
569662	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
569663	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
569664	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
569665	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Equipment Properly Labeled?	y	
569666	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Cabinet Paint Condition	Good	
569667	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
569668	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
569669	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
569670	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Bushings Connection/Risers	Good	
569671	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Bushing Condition	Good	
569672	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Amps C Ø	32.1	
569673	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Amps B Ø	33.7	
569674	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Amps A Ø	35.1	
569675	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Accumulated Fault Duty C Ph V	.45	%
569676	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Accumulated Fault Duty B Ph V	.45	%
569677	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Grounds in Place?	y	
569678	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	General Comments		
569679	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	General Comments		
569680	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Foundation Condition	Good	
569681	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Follow-up Action Required?	n	
569682	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Follow-up Action Required?	n	
569683	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Fault Operations	0	
569684	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
569685	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC Min Tap Position	12L	
569686	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC Max Tap Position	1L	
569687	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC Current Tap Position	7L	
569688	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
569689	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC As Left Counter	128468	
569690	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC As Found Counter	128468	
569691	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	General Comments		
569692	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	General Comments		
569693	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
569694	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	Follow-up Action Required?	n	
569695	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
569696	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
569697	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
569698	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
569699	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Oil Temp Present	45	°C
569700	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Oil Temp Max	45	°C
569701	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
569702	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
569703	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	LTC Totalizer Reading	12508.99	kw
569704	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
569705	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	General Comments		
569706	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	General Comments		
569707	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
569708	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
569709	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Follow-up Action Required?	n	
569710	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
569711	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
569712	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
569713	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
569714	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
569715	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
569716	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
569717	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
569718	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
569719	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
569720	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
569721	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
569722	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Unknown Operations	0	
569723	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Switching Operations	0	
569724	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Operations Counter AL	234	
569725	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Operations Counter AF	234	
569726	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Maintenance Operations	0	
569727	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	General Comments		
569728	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Patrol Inspection	General Comments		
569729	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Follow-up Action Required?	n	
569730	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Patrol Inspection	Follow-up Action Required?	n	
569731	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Operations Ground	0	
569732	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Operations C Ø	0	
569733	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Operations B Ø	0	
569734	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Operations A Ø	0	
569735	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
569736	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
569737	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
569738	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Patrol Inspection	Equipment Properly Labeled?	y	
569739	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Amps C Ø	78.0	
569740	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCC000274	LTCControl	SM-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
569741	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCC000274	LTCControl	SM-TRANS 4	LTC Control Insp	General Comments		
569742	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCC000274	LTCControl	SM-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
569743	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
569744	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
569745	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
569746	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
569747	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
569748	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
569749	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
569750	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
569751	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
569752	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
569753	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
569754	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
569755	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
569756	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
569757	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
569758	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
569759	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
569760	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	Oil Temp Present	29	°C
569761	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	Oil Temp Max	40	°C
569762	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
569763	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
569764	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
569765	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	General Comments		
569766	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
569767	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
569768	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
569769	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
569770	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
569771	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
569772	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
569773	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
569774	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Bushings Connection/Risers	Good	
569775	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Bushing Condition	Good	
569776	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Amps C Ø	200.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
569777	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Amps B Ø	200.0	
569778	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Amps A Ø	200.0	
569779	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
569780	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
569781	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
569782	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	9 Month Operations	7	
569783	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
569784	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
569785	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Amps C Ø	0.0	
569786	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Amps B Ø	0.0	
569787	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Amps A Ø	0.0	
569788	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	PF000061	PowerFuse	C-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
569789	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	PF000061	PowerFuse	C-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
569790	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	PF000060	PowerFuse	C-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
569791	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	PF000060	PowerFuse	C-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
569792	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	PF000059	PowerFuse	C-GND TR 4	Disconnect Powerfuse Inspection	General Comments	ok	
569793	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	PF000059	PowerFuse	C-GND TR 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
569794	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	PF000058	PowerFuse	C-GND TR 3	Disconnect Powerfuse Inspection	General Comments	ok	
569795	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	PF000058	PowerFuse	C-GND TR 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
569796	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Equipment Properly Labeled?	y	
569797	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Cabinet Paint Condition	Good	
569798	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
569799	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
569800	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
569801	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Bushings Connection/Risers	Good	
569802	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Bushing Condition	Good	
569803	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Accumulated Fault Duty A Ph V	.45	%
569804	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	9 Month Operations	2	
569805	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
569806	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
569807	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
569808	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
569809	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
569810	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
569811	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
569812	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
569813	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
569814	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
569815	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	General Comments		
569816	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
569817	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
569818	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
569819	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
569820	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
569821	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
569822	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
569823	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
569824	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
569825	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
569826	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
569827	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
569828	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	38	°C
569829	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	44	°C
569830	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	39	°C
569831	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	45	°C
569832	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	40	°C
569833	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	45	°C
569834	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
569835	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
569836	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
569837	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
569838	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	LTC As Found Counter	82605	
569839	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	LTC As Left Counter	82605	
569840	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
569841	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
569842	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
569843	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
569844	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	LTC Current Tap Position	5R	
569845	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	900	
569846	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
569847	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
569848	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Operations Ground	0	
569849	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Operations C Ø	0	
569850	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Operations B Ø	0	
569851	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
569852	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
569853	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
569854	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
569855	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
569856	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Vegetation	None	
569857	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
569858	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	General Comments	ok	
569859	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
569860	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
569861	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
569862	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
569863	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
569864	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
569865	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
569866	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
569867	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
569868	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
569869	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
569870	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
569871	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
569872	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
569873	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
569874	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
569875	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
569876	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
569877	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
569878	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	General Comments	ok	
569879	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
569880	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Clear of Trash?	y	
569881	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
569882	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
569883	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
569884	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
569885	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
569886	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
569887	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
569888	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
569889	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
569890	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
569891	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
569892	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
569893	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
569894	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
569895	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	General Comments		
569896	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
569897	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
569898	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
569899	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
569900	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC Operations Since Last Insp	645	
569901	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
569902	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC Min Tap Position	11L	
569903	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
569904	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC Current Tap Position	6L	
569905	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
569906	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC As Left Counter	941383	
569907	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC As Found Counter	941383	
569908	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	Battery Charger Current	4.8	amps
569909	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
569910	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
569911	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	7.400	millivolts
569912	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Cabinet Paint Condition	Good	
569913	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
569914	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
569915	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
569916	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Bushings Connection/Risers	Good	
569917	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Bushing Condition	Good	
569918	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
569919	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	General Comments		
569920	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
569921	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
569922	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
569923	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
569924	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
569925	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
569926	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
569927	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Operations Counter AL	53	
569928	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Operations Counter AF	53	
569929	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Moisture and Leak Free?	y	
569930	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Maintenance Operations	0	
569931	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
569932	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Grounds in Place?	y	
569933	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	General Comments		
569934	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	General Comments		
569935	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Foundation Condition	Good	
569936	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Follow-up Action Required?	n	
569937	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Follow-up Action Required?	n	
569938	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
569939	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
569940	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
569941	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
569942	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
569943	2/15/2019 8:22	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
569944	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
569945	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
569946	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
569947	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
569948	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
569949	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
569950	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
569951	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
569952	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
569953	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
569954	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
569955	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
569956	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
569957	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
569958	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	General Comments	ok	
569959	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
569960	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
569961	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Foundation Condition	Good	
569962	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
569963	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
569964	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
569965	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
569966	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	General Comments		
569967	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
569968	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
569969	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
569970	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
569971	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
569972	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Operations Ground	0	
569973	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Follow-up Action Required?	n	
569974	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Follow-up Action Required?	n	
569975	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Foundation Condition	Good	
569976	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	General Comments		
569977	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	General Comments		
569978	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Grounds in Place?	y	
569979	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Heaters (All) Functioning?	y	
569980	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Maintenance Operations	0	
569981	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Moisture and Leak Free?	y	
569982	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Operations Counter AF	99893	
569983	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Operations Counter AL	99893	
569984	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
569985	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Switching Operations	0	
569986	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Tank Paint Condition	Good	
569987	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Unknown Operations	0	
569988	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
569989	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Wood Structures OK?	y	
569990	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
569991	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
569992	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
569993	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
569994	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
569995	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC Operations Since Last Insp	845	
569996	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
569997	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Winding Temp Present	40	°C
569998	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Winding Temp Max	40	°C
569999	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Totalizer Meter Reading	.8208	
570000	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
570001	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
570002	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
570003	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
570004	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
570005	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
570006	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC Min Tap Position	11L	
570007	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC Max Tap Position	Neutral	
570008	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC Current Tap Position	6L	
570009	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
570010	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC As Left Counter	91993	
570011	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC As Found Counter	91993	
570012	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	General Comments		
570013	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	General Comments		
570014	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
570015	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	Follow-up Action Required?	n	
570016	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
570017	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
570018	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
570019	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC Operations Since Last Insp	458	
570020	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	General Comments		
570021	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	General Comments		
570022	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
570023	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	Follow-up Action Required?	n	
570024	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
570025	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
570026	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
570027	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2711.52	kw
570028	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
570029	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
570030	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Oil Temp Max	68	°C
570031	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Oil Temp Present	28	°C
570032	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
570033	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
570034	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
570035	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
570036	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
570037	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
570038	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
570039	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
570040	2/15/2019 9:02	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1298	
570041	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
570042	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
570043	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
570044	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
570045	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
570046	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
570047	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	9 Month Operations	4	
570048	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
570049	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
570050	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
570051	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Amps A Ø	720.0	
570052	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Amps B Ø	720.0	
570053	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Amps C Ø	720.0	
570054	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Bushing Condition	Good	
570055	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Bushings Connection/Risers	Good	
570056	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
570057	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
570058	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
570059	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Cabinet Paint Condition	Good	
570060	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	VRR Time Delay	30	Seconds
570061	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
570062	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
570063	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
570064	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	LTC Operation Checked?	y	
570065	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	General Comments		
570066	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	Follow-up Action Required?	n	
570067	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	All Connections OK?	y	
570068	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Equipment Properly Labeled?	y	
570069	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
570070	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
570071	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
570072	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Operations A Ø	0	
570073	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Operations B Ø	0	
570074	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Operations C Ø	0	
570075	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Foundation Condition	Good	
570076	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
570077	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
570078	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
570079	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
570080	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
570081	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
570082	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
570083	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
570084	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
570085	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Operations A Ø	0	
570086	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Operations B Ø	0	
570087	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
570088	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Operations C Ø	0	
570089	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
570090	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
570091	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
570092	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	659.04	kw
570093	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
570094	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
570095	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
570096	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
570097	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
570098	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
570099	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
570100	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
570101	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
570102	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
570103	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
570104	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	685	
570105	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	685	
570106	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
570107	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Operations Ground	0	
570108	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
570109	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Follow-up Action Required?	n	
570110	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
570111	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
570112	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
570113	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	General Comments		
570114	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	HV Winding Temp Max	65	°C
570115	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	HV Winding Temp Present	26	°C
570116	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	Oil Temp Max	65	°C
570117	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	Oil Temp Present	30	°C
570118	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	60.00	
570119	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
570120	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
570121	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
570122	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
570123	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
570124	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
570125	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Foundation Condition	Good	
570126	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	General Comments		
570127	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	General Comments		
570128	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Grounds in Place?	y	
570129	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
570130	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Maintenance Operations	0	
570131	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
570132	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Operations Counter AF	101	
570133	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Operations Counter AL	101	
570134	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
570135	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
570136	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
570137	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
570138	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
570139	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	General Comments	ok	
570140	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	General Comments	no fans	
570141	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
570142	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
570143	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
570144	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	General Comments		
570145	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
570146	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
570147	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
570148	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
570149	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
570150	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
570151	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
570152	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
570153	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
570154	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
570155	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Positive DC Ground	54.1	VDC
570156	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	9 Month Operations	0	
570157	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
570158	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
570159	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
570160	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Amps A Ø	650.0	
570161	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Amps B Ø	600.0	
570162	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Amps C Ø	610.0	
570163	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Bushing Condition	Good	
570164	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
570165	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
570166	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
570167	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	9 Month Operations	0	
570168	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
570169	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
570170	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
570171	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Amps A Ø	95.0	
570172	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Amps B Ø	91.0	
570173	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Amps C Ø	93.0	
570174	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Patrol Inspection	Equipment Properly Labeled?	y	
570175	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
570176	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
570177	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
570178	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Operations A Ø	0	
570179	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Operations B Ø	0	
570180	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Operations C Ø	0	
570181	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Operations Ground	0	
570182	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Patrol Inspection	Follow-up Action Required?	n	
570183	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Follow-up Action Required?	n	
570184	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Patrol Inspection	General Comments		
570185	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	General Comments		
570186	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Maintenance Operations	0	
570187	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Operations Counter AF	351	
570188	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Operations Counter AL	351	
570189	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Switching Operations	0	
570190	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Unknown Operations	0	
570191	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8238	
570192	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	General Comments		
570193	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
570194	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
570195	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	56.5	VDC
570196	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Bushing Condition	Good	
570197	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
570198	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
570199	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
570200	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Foundation Condition	Good	
570201	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	56.5	VDC
570202	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.800	millivolts
570203	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
570204	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	General Comments		
570205	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Grounds in Place?	y	
570206	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
570207	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
570208	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
570209	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
570210	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Tank Leaks	None	
570211	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
570212	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
570213	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
570214	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
570215	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
570216	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
570217	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
570218	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
570219	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
570220	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
570221	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
570222	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
570223	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
570224	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
570225	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
570226	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	General Comments	ok	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
570227	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	General Comments	ok	
570228	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
570229	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
570230	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
570231	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Winding Temp Present	15	°C
570232	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1415.52	kw
570233	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	10.00	
570234	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
570235	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
570236	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
570237	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
570238	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
570239	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
570240	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
570241	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
570242	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
570243	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
570244	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
570245	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Unknown Operations	0	
570246	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Tank Paint Condition	Good	
570247	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Switching Operations	0	
570248	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	40.0	
570249	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Accumulated Fault Duty B Ph V	.29	%
570250	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Accumulated Fault Duty C Ph V	.29	%
570251	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Amps A Ø	118.0	
570252	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Amps B Ø	117.0	
570253	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Amps C Ø	118.0	
570254	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Bushing Condition	Good	
570255	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Bushings Connection/Risers	Good	
570256	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
570257	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
570258	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
570259	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Cabinet Paint Condition	Good	
570260	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Equipment Properly Labeled?	y	
570261	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
570262	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
570263	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
570264	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Operations A Ø	0	
570265	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Operations B Ø	0	
570266	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Operations C Ø	0	
570267	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Operations Ground	0	
570268	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Follow-up Action Required?	n	
570269	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Follow-up Action Required?	n	
570270	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Foundation Condition	Good	
570271	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	General Comments		
570272	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	General Comments		
570273	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Grounds in Place?	y	
570274	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Heaters (All) Functioning?	y	
570275	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Maintenance Operations	0	
570276	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Moisture and Leak Free?	y	
570277	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5898	
570278	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
570279	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Top Oil Temperature Present	25	°C
570280	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Top Oil Temperature Max	35	°C
570281	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	40.0	
570282	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
570283	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
570284	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
570285	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
570286	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
570287	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
570288	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Operations Counter AL	169	
570289	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Operations Counter AF	169	
570290	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
570291	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
570292	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
570293	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
570294	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	40.0	
570295	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
570296	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Fans Operational?	n	
570297	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
570298	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
570299	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
570300	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
570301	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
570302	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
570303	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	35	°C
570304	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	15	°C
570305	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
570306	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
570307	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Switching Operations	0	
570308	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
570309	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Unknown Operations	0	
570310	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
570311	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
570312	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
570313	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
570314	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Negative DC Ground	53.6	VDC
570315	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	General Comments		
570316	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
570317	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
570318	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
570319	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
570320	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
570321	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
570322	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
570323	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
570324	2/15/2019 11:51	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
570325	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
570326	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	0	
570327	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
570328	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Winding Temp Max	35	°C
570329	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
570330	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	9 Month Operations	0	
570331	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
570332	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
570333	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
570334	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
570335	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
570336	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
570337	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
570338	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
570339	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Amps A Ø	0.0	
570340	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Amps B Ø	0.0	
570341	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Amps C Ø	0.0	
570342	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Patrol Inspection	Equipment Properly Labeled?	n	
570343	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
570344	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
570345	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
570346	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Operations A Ø	0	
570347	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
570348	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Operations B Ø	0	
570349	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Operations C Ø	0	
570350	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
570351	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
570352	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Readings	General Comments		
570353	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
570354	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
570355	2/15/2019 19:00	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
570356	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Operations Ground	0	
570357	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Patrol Inspection	Follow-up Action Required?	n	
570358	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Follow-up Action Required?	n	
570359	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Patrol Inspection	General Comments		
570360	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	General Comments		
570361	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Maintenance Operations	0	
570362	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Operations Counter AF	131	
570363	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Operations Counter AL	131	
570364	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Switching Operations	0	
570365	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Unknown Operations	0	
570366	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	9 Month Operations	16	
570367	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
570368	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Operations Counter AL	203	
570369	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Switching Operations	0	
570370	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Unknown Operations	0	
570371	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
570372	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
570373	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
570374	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Follow-up Action Required?	n	
570375	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
570376	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
570377	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	General Comments		
570378	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	General Comments		
570379	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
570380	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	LTC Totalizer Reading	5175.36	kw
570381	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Maintenance Operations	0	
570382	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	X1 Winding Temp Present	30	°C
570383	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Operations C Ø	0	
570384	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Moisture and Leak Free?	y	
570385	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Operations Counter AF	140	
570386	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Operations Counter AL	140	
570387	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Operations B Ø	0	
570388	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Switching Operations	0	
570389	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
570390	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
570391	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Oil Temp Max	37	°C
570392	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Oil Temp Present	23	°C
570393	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
570394	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
570395	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
570396	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
570397	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
570398	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
570399	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
570400	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Operations A Ø	0	
570401	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
570402	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
570403	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
570404	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
570405	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Amps C Ø	0.0	
570406	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	5L	
570407	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
570408	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Amps B Ø	0.0	
570409	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Amps A Ø	0.0	
570410	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
570411	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
570412	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
570413	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	9 Month Operations	0	
570414	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
570415	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
570416	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	X1 Winding Temp Max	32	°C
570417	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
570418	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
570419	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
570420	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
570421	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
570422	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
570423	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
570424	2/15/2019 12:42	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
570425	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Equipment Properly Labeled?	y	
570426	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
570427	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
570428	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Tank Leaks	None	
570429	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Cabinet Paint Condition	Good	
570430	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
570431	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
570432	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Fault Operations A Ø	0	
570433	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Fault Operations B Ø	0	
570434	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Fault Operations C Ø	0	
570435	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Fault Operations Ground	0	
570436	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Follow-up Action Required?	n	
570437	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Follow-up Action Required?	n	
570438	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Foundation Condition	Good	
570439	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	General Comments		
570440	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	General Comments		
570441	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Grounds in Place?	y	
570442	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Patrol Inspection	Follow-up Action Required?	n	
570443	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Follow-up Action Required?	n	
570444	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
570445	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
570446	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
570447	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Operations Counter	302	
570448	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
570449	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	General Comments	ok	
570450	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
570451	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
570452	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
570453	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
570454	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
570455	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Amps C Ø	2.0	
570456	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Amps B Ø	1.9	
570457	2/15/2019 10:07	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Amps A Ø	8.5	
570458	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
570459	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
570460	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
570461	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
570462	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Bushings Connection/Risers	Good	
570463	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Bushing Condition	Good	
570464	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Amps C Ø	0.0	
570465	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Operations Ground	0	
570466	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Amps B Ø	0.0	
570467	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
570468	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Operations Counter	1018	
570469	2/15/2019 11:47	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
570470	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
570471	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	General Comments		
570472	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Amps A Ø	0.0	
570473	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
570474	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
570475	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
570476	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	9 Month Operations	4	
570477	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	X2 Winding Temp Max	42	°C
570478	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	General Comments		
570479	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Patrol Inspection	General Comments	ok	
570480	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Maintenance Operations	0	
570481	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Operations Counter AF	203	
570482	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
570483	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
570484	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
570485	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC As Left Counter	156127	
570486	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
570487	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
570488	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCC000477	LTCControl	SM-TRANS 3	LTC Control Insp	All Connections OK?	y	
570489	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCC000476	LTCControl	SM-TRANS 6	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
570490	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCC000476	LTCControl	SM-TRANS 6	LTC Control Insp	General Comments		
570491	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
570492	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC Current Tap Position	6L	
570493	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC Max Tap Position	Neutral	
570494	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC Min Tap Position	11L	
570495	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
570496	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCC000476	LTCControl	SM-TRANS 6	LTC Control Insp	Follow-up Action Required?	n	
570497	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
570498	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Unknown Operations	0	
570499	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Patrol Inspection	General Comments		
570500	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
570501	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC As Found Counter	156127	
570502	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
570503	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	General Comments		
570504	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Tank Paint Condition	Good	
570505	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	X3 Winding Temp Present	30	°C
570506	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	X3 Winding Temp Max	31	°C
570507	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	X2 Winding Temp Present	30	°C
570508	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Unknown Operations	0	
570509	2/15/2019 15:35	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Tank Paint Condition	Good	
570510	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC Operations Since Last Insp	840	
570511	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	General Comments		
570512	2/15/2019 11:05	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
570513	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
570514	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
570515	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCC000477	LTCControl	SM-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
570516	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
570517	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
570518	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Winding Temp Present	27	°C
570519	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Winding Temp Max	38	°C
570520	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Totalizer Meter Reading	.3594	
570521	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
570522	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
570523	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
570524	2/15/2019 9:51	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
570525	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LTCC000477	LTCControl	SM-TRANS 3	LTC Control Insp	General Comments		
570526	2/25/2019 7:40	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
570527	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
570528	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
570529	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
570530	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
570531	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
570532	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	General Comments	ok	
570533	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
570534	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
570535	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
570536	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1152	
570537	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
570538	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	6	
570539	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
570540	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
570541	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1152	
570542	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
570543	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
570544	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	7.89	
570545	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	7.89	
570546	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	7.89	
570547	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	3.16	%
570548	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.53	%
570549	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.53	%
570550	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
570551	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
570552	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	OK	
570553	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
570554	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
570555	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
570556	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments	ok	
570557	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
570558	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
570559	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
570560	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
570561	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
570562	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
570563	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
570564	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
570565	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
570566	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
570567	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Grounds in Place?	y	
570568	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Heaters (All) Functioning?	y	
570569	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Maintenance Operations	0	
570570	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
570571	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Amps B Ø	1.0	
570572	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Amps C Ø	1.0	
570573	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
570574	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
570575	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
570576	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Moisture and Leak Free?	y	
570577	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Operations Counter AF	1567	
570578	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Operations Counter AL	1574	
570579	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
570580	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
570581	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
570582	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
570583	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
570584	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
570585	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
570586	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
570587	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
570588	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
570589	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
570590	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
570591	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
570592	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Foundation Condition	Good	
570593	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
570594	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
570595	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	General Comments	ok	
570596	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
570597	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
570598	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Operations Counter	215	
570599	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
570600	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
570601	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
570602	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
570603	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
570604	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
570605	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
570606	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
570607	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
570608	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Vegetation	None	
570609	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	General Comments		
570610	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	General Comments		
570611	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Foundation Condition	Good	
570612	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Follow-up Action Required?	n	
570613	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Follow-up Action Required?	n	
570614	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations Ground	0	
570615	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations C Ø	0	
570616	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations B Ø	0	
570617	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations A Ø	0	
570618	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
570619	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
570620	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
570621	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	LTC Totalizer Reading	1296.00	kw
570622	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
570623	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	General Comments		
570624	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
570625	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
570626	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
570627	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
570628	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
570629	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
570630	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Equipment Properly Labeled?	y	
570631	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
570632	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
570633	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
570634	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
570635	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
570636	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
570637	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
570638	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
570639	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	General Comments		
570640	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
570641	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Oil Temp Max	50	°C
570642	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Oil Temp Present	50	°C
570643	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
570644	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
570645	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
570646	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
570647	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
570648	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
570649	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
570650	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
570651	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
570652	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
570653	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Follow-up Action Required?	n	
570654	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Bushing Condition	Good	
570655	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Bushings Connection/Risers	Good	
570656	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
570657	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
570658	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Ambient Temp	54	°F
570659	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
570660	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
570661	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Clear of Trash?	y	
570662	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Amps C Ø	0.0	
570663	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Amps B Ø	0.0	
570664	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Amps A Ø	0.0	
570665	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
570666	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
570667	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	General Comments		
570668	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
570669	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Paint Condition	Good	
570670	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
570671	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
570672	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
570673	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
570674	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
570675	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
570676	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
570677	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
570678	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	General Comments		
570679	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
570680	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Tank Leaks	None	
570681	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
570682	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	VRR Time Delay	30	Seconds
570683	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
570684	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
570685	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
570686	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	LTC Operation Checked?	y	
570687	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	General Comments		
570688	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	Follow-up Action Required?	n	
570689	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	All Connections OK?	y	
570690	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
570691	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Regulator As Left Counter	354912	
570692	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
570693	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
570694	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
570695	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
570696	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
570697	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
570698	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
570699	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
570700	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	General Comments	counter wrong on 1/2/19	
570701	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
570702	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
570703	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
570704	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
570705	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
570706	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
570707	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
570708	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
570709	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
570710	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
570711	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
570712	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
570713	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
570714	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	155	
570715	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Accumulated Fault Duty A Ph V	.28	%
570716	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations Ground	0	
570717	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations C Ø	0	
570718	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Amps C Ø	70.0	
570719	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Bushing Condition	Good	
570720	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	VRR Time Delay	30	Seconds
570721	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	VRR Base Voltage AL	127.0	VAC
570722	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	VRR Base Voltage AF	127.0	VAC
570723	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
570724	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	LTC Output Voltage Level	126.0	VAC
570725	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Follow-up Action Required?	n	
570726	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Foundation Condition	Good	
570727	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	General Comments		
570728	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	General Comments		
570729	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Grounds in Place?	y	
570730	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Heaters (All) Functioning?	y	
570731	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Maintenance Operations	0	
570732	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Moisture and Leak Free?	y	
570733	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Operations Counter AF	214	
570734	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Operations Counter AL	216	
570735	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
570736	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
570737	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
570738	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
570739	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
570740	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
570741	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
570742	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
570743	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
570744	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
570745	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
570746	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
570747	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
570748	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
570749	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
570750	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
570751	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
570752	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
570753	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
570754	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
570755	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
570756	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
570757	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	General Comments	need spare fuse barrels	
570758	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
570759	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
570760	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Foundation Condition	Good	
570761	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
570762	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
570763	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
570764	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Switching Operations	2	
570765	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
570766	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
570767	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
570768	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Follow-up Action Required?	n	
570769	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Tank Paint Condition	Good	
570770	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Unknown Operations	0	
570771	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
570772	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
570773	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
570774	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
570775	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Vegetation	None	
570776	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
570777	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Bushings Connection/Risers	Good	
570778	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Bushing Condition	Good	
570779	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
570780	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
570781	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
570782	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
570783	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
570784	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
570785	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
570786	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
570787	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
570788	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
570789	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
570790	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
570791	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
570792	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
570793	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
570794	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
570795	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
570796	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
570797	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
570798	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
570799	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Accumulated Fault Duty B Ph V	.28	%
570800	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Accumulated Fault Duty C Ph V	.28	%
570801	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Amps A Ø	90.0	
570802	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Amps B Ø	60.0	
570803	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
570804	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
570805	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
570806	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
570807	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
570808	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
570809	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	General Comments	ok	
570810	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
570811	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
570812	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Foundation Condition	Good	
570813	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
570814	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
570815	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
570816	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
570817	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BCH000549	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
570818	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BCH000549	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
570819	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BCH000549	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
570820	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BCH000549	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
570821	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BCH000549	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
570822	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BCH000549	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
570823	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
570824	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	General Comments	ok	
570825	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Amps A Ø	1.0	
570826	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	LTC Operation Checked?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
570827	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations B Ø	0	
570828	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Bushings Connection/Risers	Good	
570829	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
570830	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
570831	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
570832	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Cabinet Paint Condition	Good	
570833	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	9 Month Operations	1	
570834	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations A Ø	0	
570835	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
570836	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
570837	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
570838	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
570839	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
570840	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
570841	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
570842	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
570843	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
570844	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
570845	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
570846	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
570847	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
570848	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
570849	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	General Comments		
570850	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Equipment Properly Labeled?	y	
570851	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
570852	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
570853	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
570854	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
570855	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	General Comments		
570856	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	Follow-up Action Required?	n	
570857	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	All Connections OK?	y	
570858	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
570859	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
570860	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
570861	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
570862	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Equipment Properly Labeled?	y	
570863	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
570864	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Paint Condition	Good	
570865	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
570866	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
570867	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
570868	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
570869	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
570870	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
570871	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
570872	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
570873	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	General Comments		
570874	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
570875	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	9 Month Operations	16	
570876	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
570877	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
570878	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2069.28	kw
570879	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
570880	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
570881	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Oil Temp Max	25	°C
570882	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
570883	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
570884	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
570885	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
570886	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
570887	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
570888	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
570889	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
570890	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
570891	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8622	
570892	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Accumulated Fault Duty C Ph V	.07	%
570893	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Amps A Ø	222.0	
570894	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Amps B Ø	246.0	
570895	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Amps C Ø	225.0	
570896	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Bushing Condition	Good	
570897	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
570898	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
570899	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
570900	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
570901	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
570902	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
570903	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
570904	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
570905	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
570906	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Operations A Ø	0	
570907	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Operations B Ø	0	
570908	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Operations C Ø	0	
570909	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Operations Ground	0	
570910	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Follow-up Action Required?	n	
570911	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Follow-up Action Required?	n	
570912	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Foundation Condition	Good	
570913	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	General Comments	ok	
570914	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	General Comments	ok	
570915	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Grounds in Place?	y	
570916	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
570917	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Maintenance Operations	0	
570918	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
570919	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Operations Counter AF	146	
570920	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Operations Counter AL	146	
570921	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
570922	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
570923	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
570924	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
570925	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
570926	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
570927	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
570928	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
570929	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
570930	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Switching Operations	0	
570931	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Tank Paint Condition	Good	
570932	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Unknown Operations	0	
570933	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
570934	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
570935	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
570936	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
570937	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	9 Month Operations	4	
570938	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
570939	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
570940	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
570941	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
570942	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
570943	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
570944	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
570945	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
570946	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
570947	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
570948	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
570949	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
570950	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
570951	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Ambient Temp	56	°F
570952	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
570953	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
570954	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Clear of Trash?	y	
570955	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
570956	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
570957	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
570958	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
570959	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
570960	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	9 Month Operations	1	
570961	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Accumulated Fault Duty A Ph V	.07	%
570962	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
570963	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
570964	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	General Comments		
570965	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
570966	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Vegetation	None	
570967	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
570968	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
570969	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
570970	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
570971	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
570972	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
570973	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
570974	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Foundation Condition	Good	
570975	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
570976	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
570977	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	General Comments		
570978	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
570979	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
570980	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
570981	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
570982	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Accumulated Fault Duty B Ph V	.07	%
570983	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
570984	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
570985	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
570986	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
570987	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
570988	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
570989	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
570990	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
570991	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
570992	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
570993	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
570994	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	General Comments	OK	
570995	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	General Comments	OK	
570996	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
570997	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
570998	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
570999	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
571000	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Floor Swept?	y	
571001	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
571002	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
571003	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	General Comments		
571004	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
571005	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
571006	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Panels Dusted?	y	
571007	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
571008	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Trash Emptied?	y	
571009	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
571010	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
571011	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC Current Tap Position	3R	
571012	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
571013	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC As Left Counter	3823	
571014	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC As Found Counter	3823	
571015	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	General Comments		
571016	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	General Comments		
571017	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
571018	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	Follow-up Action Required?	n	
571019	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3168	
571020	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
571021	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Operations Counter AF	194	
571022	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Operations Counter AL	196	
571023	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
571024	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
571025	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
571026	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
571027	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
571028	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
571029	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Fans Operational?	n	
571030	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
571031	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
571032	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
571033	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
571034	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	General Comments		
571035	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	General Comments	ok	
571036	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
571037	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
571038	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
571039	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	253.44	kw
571040	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
571041	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
571042	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
571043	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
571044	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
571045	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
571046	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
571047	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
571048	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
571049	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
571050	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
571051	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	LTCC000820	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
571052	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	LTCC000820	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
571053	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	LTCC000820	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
571054	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	LTCC000820	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
571055	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	LTCC000820	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
571056	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	LTCC000820	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
571057	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	LTCC000820	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
571058	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	LTCC000820	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
571059	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
571060	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Follow-up Action Required?	n	
571061	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
571062	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
571063	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	General Comments		
571064	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	General Comments		
571065	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
571066	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	LTC Totalizer Reading	3651.84	kw
571067	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
571068	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
571069	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Oil Temp Max	50	°C
571070	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Oil Temp Present	40	°C
571071	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
571072	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
571073	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
571074	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
571075	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	BCH000242	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
571076	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	BCH000242	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
571077	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Operations A Ø	0	
571078	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Operations B Ø	0	
571079	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	BCH000242	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
571080	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	BCH000242	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
571081	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
571082	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
571083	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
571084	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
571085	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Totalizer Meter Reading	.3804	
571086	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
571087	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Operations C Ø	0	
571088	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Operations Ground	0	
571089	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Follow-up Action Required?	n	
571090	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	General Comments		
571091	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Maintenance Operations	0	
571092	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
571093	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
571094	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
571095	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
571096	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	40.0	
571097	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	40.0	
571098	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
571099	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	6.05	%
571100	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	10.76	%
571101	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	3.36	%
571102	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	17	
571103	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
571104	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
571105	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
571106	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
571107	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC Operations Since Last Insp	22	
571108	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	-.5	psi
571109	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
571110	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC Max Tap Position	4R	
571111	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
571112	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
571113	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Broom on Site?	y	
571114	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
571115	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
571116	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
571117	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
571118	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
571119	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Evidence of Insects	None	
571120	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	General Comments	ok	
571121	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
571122	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
571123	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
571124	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
571125	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
571126	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
571127	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
571128	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
571129	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
571130	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
571131	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
571132	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
571133	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Regulator As Left Counter	268793	
571134	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
571135	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Unknown Operations	0	
571136	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
571137	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
571138	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Tank Leaks	None	
571139	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
571140	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
571141	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
571142	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
571143	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
571144	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
571145	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
571146	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	All Connections OK?	y	
571147	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	Follow-up Action Required?	n	
571148	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	General Comments		
571149	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	LTC Operation Checked?	y	
571150	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
571151	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
571152	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
571153	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
571154	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
571155	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
571156	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
571157	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
571158	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
571159	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
571160	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	General Comments		
571161	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
571162	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
571163	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
571164	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
571165	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Operations Counter	256	
571166	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
571167	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
571168	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	General Comments	ok	
571169	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	VRR Time Delay	30	Seconds
571170	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
571171	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Foundation Condition	Good	
571172	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	159	
571173	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
571174	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
571175	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
571176	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
571177	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
571178	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
571179	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Unknown Operations	2	
571180	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Tank Paint Condition	Good	
571181	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
571182	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
571183	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
571184	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
571185	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Clear of Trash?	y	
571186	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
571187	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
571188	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
571189	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
571190	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	General Comments		
571191	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
571192	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
571193	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
571194	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
571195	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
571196	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
571197	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
571198	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
571199	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
571200	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Unknown Operations	0	
571201	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Switching Operations	2	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
571202	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
571203	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
571204	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
571205	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
571206	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Operations A Ø	0	
571207	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Operations B Ø	0	
571208	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Operations C Ø	0	
571209	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Operations Ground	0	
571210	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Follow-up Action Required?	n	
571211	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Follow-up Action Required?	n	
571212	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Foundation Condition	Good	
571213	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	General Comments		
571214	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	General Comments		
571215	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Grounds in Place?	y	
571216	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Heaters (All) Functioning?	y	
571217	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Maintenance Operations	1	
571218	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Moisture and Leak Free?	y	
571219	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Operations Counter AF	25	
571220	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Operations Counter AL	26	
571221	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Switching Operations	0	
571222	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Tank Paint Condition	Good	
571223	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
571224	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
571225	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Unknown Operations	0	
571226	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Switching Operations	7	
571227	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Tank Paint Condition	Good	
571228	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
571229	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
571230	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
571231	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
571232	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
571233	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
571234	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
571235	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
571236	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
571237	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
571238	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
571239	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
571240	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
571241	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
571242	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
571243	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
571244	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	General Comments	ok	
571245	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
571246	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
571247	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
571248	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
571249	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
571250	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
571251	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
571252	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
571253	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
571254	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Adjusted Amps B Phase V	9.12	
571255	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
571256	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
571257	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
571258	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
571259	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
571260	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Winding Temp Present	30	°C
571261	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Winding Temp Max	40	°C
571262	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Totalizer Meter Reading	.9460	
571263	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Totalizer Meter Multiplier	10160	
571264	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
571265	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
571266	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
571267	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
571268	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Adjusted Amps A Phase V	9.12	
571269	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Equipment Properly Labeled?	y	
571270	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Cabinet Paint Condition	Good	
571271	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
571272	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
571273	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
571274	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Bushings Connection/Risers	Good	
571275	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Bushing Condition	Good	
571276	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Amps C Ø	150.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
571277	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Amps B Ø	150.0	
571278	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Amps A Ø	150.0	
571279	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Accumulated Fault Duty C Ph V	9.52	%
571280	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
571281	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
571282	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
571283	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Oil Temp Present	25	°C
571284	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Oil Temp Max	25	°C
571285	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	950	psi
571286	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
571287	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
571288	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	LTC Totalizer Reading	9611.36	kw
571289	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
571290	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	General Comments		
571291	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Accumulated Fault Duty B Ph V	8.16	%
571292	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	General Comments		
571293	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
571294	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
571295	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Follow-up Action Required?	n	
571296	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
571297	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
571298	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
571299	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
571300	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
571301	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
571302	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Accumulated Fault Duty A Ph V	10.20	%
571303	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Switching Operations	0	
571304	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
571305	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Operations Counter AL	170	
571306	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Operations Counter AF	170	
571307	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Moisture and Leak Free?	y	
571308	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
571309	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
571310	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
571311	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
571312	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
571313	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Vegetation	None	
571314	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
571315	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
571316	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
571317	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	General Comments		
571318	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
571319	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
571320	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
571321	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
571322	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
571323	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
571324	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
571325	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
571326	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
571327	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
571328	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
571329	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
571330	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
571331	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
571332	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Amps C Ø	30.0	
571333	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Amps B Ø	16.0	
571334	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Amps A Ø	8.0	
571335	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
571336	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Clear of Trash?	y	
571337	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
571338	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
571339	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Ambient Temp	48	°F
571340	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
571341	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Tank Leaks	None	
571342	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
571343	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
571344	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Regulator As Left Counter	563856	
571345	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Maintenance Operations	0	
571346	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Heaters (All) Functioning?	y	
571347	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Grounds in Place?	y	
571348	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	General Comments	ok	
571349	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	General Comments	ok	
571350	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Foundation Condition	Good	
571351	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
571352	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Follow-up Action Required?	n	
571353	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Operations Ground	0	
571354	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Operations C Ø	0	
571355	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Operations B Ø	0	
571356	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Operations A Ø	0	
571357	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Adjusted Amps C Phase V	9.12	
571358	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
571359	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
571360	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
571361	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
571362	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
571363	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
571364	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Heaters (All) Functioning?	y	
571365	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Maintenance Operations	1	
571366	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Moisture and Leak Free?	y	
571367	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
571368	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Vegetation	None	
571369	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
571370	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	General Comments		
571371	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
571372	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
571373	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
571374	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
571375	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
571376	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
571377	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Clear of Trash?	y	
571378	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
571379	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
571380	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Ambient Temp	57	°F
571381	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
571382	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
571383	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
571384	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Operations Since Last Insp	133	
571385	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Min Tap Position	1R	
571386	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Max Tap Position	5R	
571387	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Current Tap Position	4R	
571388	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
571389	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC As Left Counter	8994	
571390	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC As Found Counter	8994	
571391	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	General Comments		
571392	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	General Comments		
571393	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
571394	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	Follow-up Action Required?	n	
571395	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Adjusted Amps B Phase V	0	
571396	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Adjusted Amps A Phase V	0	
571397	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Amps C Ø	100	
571398	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Amps B Ø	100	
571399	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Amps A Ø	100	
571400	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Accumulated Fault Duty C Ph V	.69	%
571401	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Accumulated Fault Duty B Ph V	0	%
571402	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Accumulated Fault Duty A Ph V	0	%
571403	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	9 Month Operations	9	
571404	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
571405	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC Operations Since Last Insp	713	
571406	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC Min Tap Position	12L	
571407	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
571408	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC Current Tap Position	8L	
571409	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC As Left Counter	229298	
571410	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC As Found Counter	229288	
571411	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	General Comments		
571412	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	Follow-up Action Required?	n	
571413	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	Follow-up Action Required?	n	
571414	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
571415	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	General Comments		
571416	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Mechanism Patrol Inspection	General Comments		
571417	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC As Found Counter	588	
571418	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC As Left Counter	597	
571419	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
571420	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC Current Tap Position	7L	
571421	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC Max Tap Position	5L	
571422	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC Min Tap Position	11L	
571423	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
571424	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
571425	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
571426	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
571427	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
571428	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	General Comments	ok	
571429	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
571430	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
571431	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Foundation Condition	Good	
571432	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
571433	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
571434	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
571435	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
571436	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
571437	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
571438	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
571439	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
571440	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
571441	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
571442	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
571443	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
571444	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
571445	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
571446	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
571447	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
571448	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations A Ø	0	
571449	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
571450	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
571451	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
571452	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Equipment Properly Labeled?	y	
571453	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Adjusted Amps C Phase V	4.31	
571454	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
571455	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
571456	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
571457	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
571458	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
571459	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
571460	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
571461	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	56	°F
571462	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
571463	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Paint Condition	Good	
571464	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
571465	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
571466	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
571467	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	General Comments	ok	
571468	2/14/2019 11:49	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
571469	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
571470	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
571471	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
571472	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Bushings Connection/Risers	Good	
571473	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Bushing Condition	Good	
571474	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Amps C Ø	180.0	
571475	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Amps B Ø	180.0	
571476	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Amps A Ø	180.0	
571477	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Accumulated Fault Duty C Ph V	.68	%
571478	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
571479	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
571480	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	9 Month Operations	6	
571481	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	General Comments		
571482	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Grounds in Place?	y	
571483	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
571484	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
571485	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	9 Month Operations	8	
571486	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
571487	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
571488	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
571489	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BCH000941	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
571490	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BCH000941	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
571491	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	General Comments		
571492	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
571493	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BCH000941	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
571494	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BCH000941	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
571495	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BCH000941	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
571496	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BCH000941	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
571497	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BCH000941	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
571498	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
571499	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
571500	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
571501	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
571502	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
571503	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
571504	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
571505	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
571506	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
571507	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
571508	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.300	millivolts
571509	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
571510	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
571511	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Follow-up Action Required?	n	
571512	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
571513	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
571514	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
571515	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
571516	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
571517	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
571518	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
571519	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
571520	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
571521	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
571522	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
571523	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
571524	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
571525	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	General Comments		
571526	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
571527	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
571528	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
571529	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
571530	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
571531	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
571532	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Amps A Ø	350.0	
571533	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
571534	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
571535	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
571536	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Amps B Ø	355.0	
571537	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Amps C Ø	350.0	
571538	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Bushing Condition	Good	
571539	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
571540	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC Operations Since Last Insp	540	
571541	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
571542	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
571543	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC Operations Since Last Insp	186	
571544	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
571545	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Operations Counter AF	1536	
571546	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Operations Counter AL	1537	
571547	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Switching Operations	0	
571548	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Tank Paint Condition	Good	
571549	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Unknown Operations	0	
571550	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
571551	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
571552	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Ambient Temperature	54	°F
571553	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Bushings Connection/Risers	Good	
571554	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
571555	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
571556	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Cabinet Paint Condition	Good	
571557	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Equipment Properly Labeled?	y	
571558	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Fault Operations	0	
571559	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Follow-up Action Required?	n	
571560	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Follow-up Action Required?	n	
571561	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Foundation Condition	Good	
571562	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Gauge(s) Condition	Good	
571563	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
571564	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
571565	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Winding Temp Present	0	°C
571566	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Winding Temp Max	0	°C
571567	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Totalizer Meter Reading	.7878	
571568	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Totalizer Meter Multiplier	3600	
571569	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
571570	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
571571	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
571572	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
571573	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
571574	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
571575	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
571576	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Oil Temp Present	30	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
571577	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Oil Temp Max	40	°C
571578	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
571579	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
571580	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	LTC Totalizer Reading	2836.08	kw
571581	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
571582	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	General Comments		
571583	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	General Comments		
571584	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	General Comments		
571585	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	General Comments		
571586	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Grounds in Place?	y	
571587	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Heaters (All) Functioning?	y	
571588	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Maintenance Operations	0	
571589	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Moisture and Leak Free?	y	
571590	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Num Operations Last 9 Months	1	
571591	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Operations Counter AF	15	
571592	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Operations Counter AL	15	
571593	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	SF6 Bushing Condition	Good	
571594	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	SF6 Pressure Indicator	good	
571595	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
571596	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Switching Operations	0	
571597	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Tank Paint Condition	Good	
571598	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
571599	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Tank Leaks	None	
571600	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
571601	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Regulator As Left Counter	25390	
571602	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
571603	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
571604	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC Min Tap Position	11L	
571605	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC Operations Since Last Insp	713	
571606	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
571607	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
571608	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
571609	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
571610	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
571611	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
571612	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
571613	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Tank Leaks	None	
571614	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
571615	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Regulator As Left Counter	27652	
571616	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
571617	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
571618	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
571619	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
571620	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
571621	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
571622	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
571623	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
571624	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
571625	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
571626	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
571627	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
571628	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
571629	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
571630	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Min Tap Position	3L	
571631	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
571632	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
571633	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	General Comments	OK	
571634	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
571635	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
571636	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
571637	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
571638	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
571639	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
571640	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
571641	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
571642	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
571643	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
571644	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
571645	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Tank Leaks	None	
571646	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
571647	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Regulator As Left Counter	29065	
571648	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Vegetation	None	
571649	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
571650	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	General Comments	ok	
571651	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
571652	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
571653	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
571654	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
571655	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
571656	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
571657	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
571658	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
571659	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
571660	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
571661	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	General Comments	OK	
571662	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
571663	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
571664	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
571665	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	59	°F
571666	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
571667	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
571668	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
571669	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
571670	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
571671	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.7	VDC
571672	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.6	VDC
571673	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
571674	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
571675	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BCH001096	Charger	869-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
571676	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BCH001096	Charger	869-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
571677	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BCH001096	Charger	869-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
571678	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BCH001096	Charger	869-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC
571679	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Unknown Operations	0	
571680	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Switching Operations	0	
571681	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Operations Counter AL	147	
571682	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Operations Counter AF	147	
571683	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Maintenance Operations	0	
571684	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
571685	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
571686	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
571687	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Equipment Properly Labeled?	y	
571688	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Cabinet Paint Condition	Good	
571689	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
571690	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
571691	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
571692	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Bushings Connection/Risers	Good	
571693	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Bushing Condition	Good	
571694	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Amps C Ø	30.0	
571695	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	General Comments		
571696	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Follow-up Action Required?	n	
571697	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Operations Ground	0	
571698	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Amps B Ø	40.0	
571699	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Amps A Ø	50.0	
571700	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Accumulated Fault Duty C Ph V	4.20	%
571701	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Accumulated Fault Duty B Ph V	4.20	%
571702	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Accumulated Fault Duty A Ph V	4.20	%
571703	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Operations C Ø	0	
571704	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Operations B Ø	2	
571705	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Operations A Ø	0	
571706	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
571707	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Adjusted Amps B Phase V	8.63	
571708	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
571709	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Amps C Ø	71.0	
571710	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Amps B Ø	92.0	
571711	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Amps A Ø	52.0	
571712	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Accumulated Fault Duty C Ph V	.32	%
571713	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Accumulated Fault Duty B Ph V	1.29	%
571714	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
571715	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	9 Month Operations	3	
571716	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
571717	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	Follow-up Action Required?	n	
571718	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	General Comments		
571719	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC As Found Counter	26960	
571720	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC As Left Counter	26960	
571721	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC Current Tap Position	7L	
571722	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Maintenance Operations	0	
571723	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Heaters (All) Functioning?	y	
571724	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Grounds in Place?	y	
571725	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	General Comments		
571726	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
571727	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Foundation Condition	Good	
571728	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Follow-up Action Required?	n	
571729	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Follow-up Action Required?	n	
571730	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations Ground	0	
571731	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations C Ø	0	
571732	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations B Ø	0	
571733	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
571734	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
571735	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Broom on Site?	y	
571736	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
571737	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
571738	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
571739	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
571740	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
571741	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
571742	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Evidence of Insects	Yes_needs_sprayed	
571743	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
571744	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
571745	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Floor Swept?	y	
571746	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
571747	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
571748	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
571749	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
571750	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
571751	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
571752	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
571753	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	53	°F
571754	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
571755	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
571756	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
571757	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	20.0	VDC
571758	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	21.0	VDC
571759	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	General Comments		
571760	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Follow-up Action Required?	n	
571761	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Operations Ground	0	
571762	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Operations C Ø	1	
571763	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Operations B Ø	0	
571764	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Operations A Ø	0	
571765	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
571766	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	General Comments		
571767	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
571768	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
571769	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Panels Dusted?	y	
571770	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
571771	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Trash Emptied?	y	
571772	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
571773	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
571774	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
571775	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
571776	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
571777	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
571778	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
571779	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
571780	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
571781	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
571782	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
571783	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
571784	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
571785	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
571786	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
571787	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
571788	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
571789	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
571790	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
571791	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
571792	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
571793	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
571794	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
571795	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
571796	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
571797	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Clear of Trash?	y	
571798	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
571799	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
571800	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Unknown Operations	0	
571801	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Switching Operations	4	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
571802	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Operations Counter AL	336	
571803	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Operations Counter AF	332	
571804	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Maintenance Operations	0	
571805	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	9 Month Operations	1	
571806	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Ambient Temp	56	°F
571807	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Operations A Ø	0	
571808	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Operations B Ø	0	
571809	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Operations C Ø	0	
571810	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Operations Ground	0	
571811	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Follow-up Action Required?	n	
571812	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Follow-up Action Required?	n	
571813	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Foundation Condition	Good	
571814	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	General Comments		
571815	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
571816	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
571817	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.6	VDC
571818	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.3	VDC
571819	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Unknown Operations	0	
571820	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Tank Paint Condition	Good	
571821	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Switching Operations	2	
571822	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
571823	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
571824	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
571825	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
571826	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
571827	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
571828	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
571829	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
571830	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
571831	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
571832	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
571833	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
571834	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
571835	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
571836	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	General Comments	ok	
571837	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
571838	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
571839	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Operations Counter AL	255	
571840	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Operations Counter AF	253	
571841	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Moisture and Leak Free?	y	
571842	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
571843	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
571844	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
571845	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Equipment Properly Labeled?	y	
571846	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Cabinet Paint Condition	Good	
571847	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
571848	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
571849	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
571850	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Bushings Connection/Risers	Good	
571851	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Bushing Condition	Good	
571852	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Amps C Ø	10.0	
571853	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	BCH000566	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
571854	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	BCH000566	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
571855	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	BCH000566	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
571856	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	BCH000566	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
571857	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	BCH000566	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
571858	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	BCH000566	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
571859	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Amps B Ø	10.0	
571860	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Amps A Ø	50.0	
571861	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Accumulated Fault Duty C Ph V	.34	%
571862	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Accumulated Fault Duty B Ph V	.34	%
571863	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Accumulated Fault Duty A Ph V	.68	%
571864	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	9 Month Operations	2	
571865	2/14/2019 12:29	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
571866	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
571867	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	General Comments		
571868	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
571869	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
571870	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
571871	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
571872	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
571873	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
571874	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
571875	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
571876	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	18	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
571877	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
571878	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
571879	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.67	%
571880	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	Follow-up Action Required?	n	
571881	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	General Comments	counter as left on previous QTR should have been 258374.	
571882	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC As Found Counter	258469	
571883	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC As Left Counter	258469	
571884	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC Current Tap Position	4L	
571885	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC Max Tap Position	1L	
571886	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC Min Tap Position	7L	
571887	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC Operations Since Last Insp	95	
571888	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
571889	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
571890	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
571891	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
571892	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10.0	
571893	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
571894	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
571895	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
571896	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
571897	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
571898	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
571899	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
571900	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
571901	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
571902	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
571903	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
571904	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
571905	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
571906	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
571907	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
571908	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
571909	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Operations C Ø	0	
571910	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Operations Ground	0	
571911	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Follow-up Action Required?	n	
571912	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Follow-up Action Required?	n	
571913	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Foundation Condition	Good	
571914	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	General Comments	ok	
571915	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	General Comments	ok	
571916	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Grounds in Place?	y	
571917	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Heaters (All) Functioning?	y	
571918	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Maintenance Operations	0	
571919	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
571920	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Foundation Condition	Good	
571921	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
571922	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	General Comments		
571923	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
571924	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
571925	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
571926	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
571927	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC Min Tap Position	1R	
571928	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC Max Tap Position	2R	
571929	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC Current Tap Position	1R	
571930	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
571931	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC As Left Counter	26205	
571932	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC As Found Counter	26205	
571933	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	General Comments	BROKEN MAX INDICATOR	
571934	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
571935	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
571936	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
571937	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Moisture and Leak Free?	y	
571938	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Operations Counter AF	186	
571939	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Operations Counter AL	186	
571940	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
571941	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Switching Operations	0	
571942	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Tank Paint Condition	Good	
571943	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Unknown Operations	0	
571944	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	General Comments		
571945	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
571946	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	9 Month Operations	4	
571947	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Accumulated Fault Duty A Ph V	1.29	%
571948	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Accumulated Fault Duty B Ph V	1.29	%
571949	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Unknown Operations	0	
571950	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Tank Paint Condition	Good	
571951	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
571952	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Accumulated Fault Duty C Ph V	1.29	%
571953	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Amps A Ø	0	
571954	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Amps B Ø	0	
571955	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Amps C Ø	0	
571956	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Adjusted Amps A Phase V	0	
571957	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Adjusted Amps B Phase V	0	
571958	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Adjusted Amps C Phase V	0	
571959	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Switching Operations	0	
571960	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
571961	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Operations Counter AL	209	
571962	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Operations Counter AF	209	
571963	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Moisture and Leak Free?	y	
571964	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Maintenance Operations	0	
571965	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Heaters (All) Functioning?	y	
571966	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Grounds in Place?	y	
571967	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	General Comments	ok	
571968	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	General Comments	ok	
571969	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Foundation Condition	Good	
571970	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Follow-up Action Required?	n	
571971	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Follow-up Action Required?	n	
571972	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Operations Ground	0	
571973	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Operations C Ø	0	
571974	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Operations B Ø	0	
571975	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Operations A Ø	0	
571976	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
571977	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
571978	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
571979	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
571980	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Follow-up Action Required?	n	
571981	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
571982	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
571983	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Winding Temp Present	29	°C
571984	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Winding Temp Max	30	°C
571985	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
571986	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
571987	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Totalizer Meter Reading	.5292	
571988	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
571989	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
571990	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
571991	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
571992	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
571993	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
571994	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
571995	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
571996	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
571997	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
571998	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
571999	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
572000	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
572001	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
572002	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
572003	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
572004	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
572005	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
572006	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
572007	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
572008	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
572009	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
572010	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
572011	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Oil Temp Present	27	°C
572012	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Oil Temp Max	30	°C
572013	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
572014	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
572015	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	LTC Totalizer Reading	7620.48	kw
572016	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
572017	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	General Comments	ok	
572018	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	General Comments	ok	
572019	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
572020	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
572021	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Vegetation	None	
572022	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
572023	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
572024	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Totalizer Meter Reading	.1350	
572025	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
572026	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
572027	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Follow-up Action Required?	n	
572028	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
572029	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
572030	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
572031	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
572032	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
572033	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	General Comments	ok	
572034	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
572035	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
572036	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
572037	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
572038	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
572039	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
572040	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Clear of Trash?	y	
572041	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
572042	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
572043	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
572044	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
572045	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
572046	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
572047	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
572048	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
572049	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
572050	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
572051	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
572052	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
572053	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
572054	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
572055	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
572056	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
572057	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
572058	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
572059	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	128	
572060	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	132	
572061	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
572062	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
572063	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Unknown Operations	0	
572064	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
572065	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
572066	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Leaks	None	
572067	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Pressure OK?	y	
572068	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
572069	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank Paint Condition	Good	
572070	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
572071	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
572072	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank Leaks	None	
572073	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
572074	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
572075	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
572076	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Switching Operations	4	
572077	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
572078	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2019-02-14 00:00:00.000000	
572079	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Operations Counter AL	334	
572080	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Operations Counter AF	331	
572081	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Number of Ops last 9 Months	5	
572082	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
572083	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Maintenance Operations	0	
572084	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Grounds in Place?	y	
572085	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
572086	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Bushing Condition	Good	
572087	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Bushing Oil Level	Good	
572088	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
572089	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
572090	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
572091	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
572092	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
572093	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
572094	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Fault Operations	0	
572095	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Follow-up Action Required?	n	
572096	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
572097	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	9 Month Operations	15	
572098	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
572099	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
572100	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
572101	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Amps A Ø	0.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
572102	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Amps B Ø	0.0	
572103	2/14/2019 13:35	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Amps C Ø	0.0	
572104	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	General Comments		
572105	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
572106	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	General Comments		
572107	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
572108	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Foundation Condition	Good	
572109	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
572110	2/14/2019 13:13	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
572111	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
572112	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
572113	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
572114	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
572115	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
572116	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Amps B Ø	95.0	
572117	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Amps C Ø	74.0	
572118	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
572119	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
572120	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Bushing Condition	Good	
572121	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Bushings Connection/Risers	Good	
572122	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
572123	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
572124	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
572125	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
572126	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Cabinet Paint Condition	Good	
572127	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Equipment Properly Labeled?	y	
572128	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Operations A Ø	0	
572129	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Operations B Ø	0	
572130	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Operations C Ø	0	
572131	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
572132	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
572133	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
572134	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Operations Ground	0	
572135	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Follow-up Action Required?	n	
572136	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC Min Tap Position	12L	
572137	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC Max Tap Position	3L	
572138	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC Current Tap Position	7L	
572139	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
572140	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC As Left Counter	7110	
572141	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC As Found Counter	7099	
572142	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	General Comments	ok	
572143	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	General Comments	ok	
572144	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
572145	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	Follow-up Action Required?	n	
572146	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
572147	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Follow-up Action Required?	n	
572148	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Foundation Condition	Good	
572149	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	General Comments		
572150	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	General Comments		
572151	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Grounds in Place?	y	
572152	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Heaters (All) Functioning?	y	
572153	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Maintenance Operations	0	
572154	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
572155	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
572156	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
572157	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
572158	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
572159	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	General Comments	OK	
572160	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
572161	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
572162	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
572163	2/14/2019 9:53	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
572164	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Moisture and Leak Free?	y	
572165	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
572166	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Operations Counter AL	162	
572167	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Operations Counter AF	162	
572168	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Operations A Ø	0	
572169	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Operations B Ø	0	
572170	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	9 Month Operations	3	
572171	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Accumulated Fault Duty A Ph V	.45	%
572172	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
572173	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC Operations Since Last Insp	791	
572174	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
572175	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
572176	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
572177	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Accumulated Fault Duty B Ph V	.52	%
572178	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Unknown Operations	0	
572179	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Tank Paint Condition	Good	
572180	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Switching Operations	0	
572181	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
572182	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Accumulated Fault Duty C Ph V	.52	%
572183	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Bushings Connection/Risers	Good	
572184	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
572185	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
572186	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
572187	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Cabinet Paint Condition	Good	
572188	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Equipment Properly Labeled?	y	
572189	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
572190	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
572191	2/14/2019 14:54	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Amps A Ø	74.0	
572192	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
572193	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
572194	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
572195	2/14/2019 14:33	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
572196	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
572197	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
572198	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
572199	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
572200	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
572201	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
572202	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
572203	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
572204	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
572205	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
572206	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
572207	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Ambient Temp	41	°F
572208	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Switching Operations	0	
572209	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Operations Counter AL	743	
572210	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Operations Counter AF	743	
572211	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Maintenance Operations	0	
572212	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
572213	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	General Comments		
572214	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	LTC Operation Checked?	y	
572215	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
572216	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
572217	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	General Comments		
572218	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Patrol Inspection	General Comments		
572219	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Follow-up Action Required?	n	
572220	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Patrol Inspection	Follow-up Action Required?	n	
572221	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Operations Ground	0	
572222	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Operations C Ø	0	
572223	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Operations B Ø	0	
572224	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Operations A Ø	0	
572225	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
572226	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
572227	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
572228	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
572229	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Amps C Ø	350.0	
572230	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Amps B Ø	370.0	
572231	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Amps A Ø	320.0	
572232	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
572233	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
572234	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
572235	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	9 Months Operations	11	
572236	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
572237	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
572238	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
572239	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
572240	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
572241	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
572242	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
572243	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
572244	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
572245	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
572246	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	LTCC000288	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
572247	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Oil Temp Present	45	°C
572248	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Follow-up Action Required?	n	
572249	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Follow-up Action Required?	n	
572250	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Foundation Condition	Good	
572251	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
572252	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
572253	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
572254	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Totalizer Meter Reading	.2850	
572255	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
572256	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
572257	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
572258	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
572259	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
572260	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
572261	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
572262	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
572263	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
572264	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
572265	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
572266	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
572267	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Oil Temp Max	70	°C
572268	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Oil Temp Present	45	°C
572269	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
572270	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
572271	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
572272	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
572273	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
572274	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
572275	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
572276	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
572277	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
572278	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
572279	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
572280	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
572281	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
572282	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
572283	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Totalizer Meter Reading	.6318	
572284	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
572285	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
572286	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
572287	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
572288	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Totalizer Meter Reading	.7720	
572289	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
572290	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
572291	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
572292	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
572293	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
572294	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
572295	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
572296	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
572297	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
572298	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
572299	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	All Connections OK?	y	
572300	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	Follow-up Action Required?	n	
572301	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Unknown Operations	0	
572302	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
572303	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	General Comments		
572304	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
572305	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
572306	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2019-05-09 00:00:00.000000000	
572307	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Vegetation	None	
572308	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
572309	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Amps A Ø	120.0	
572310	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Accumulated Fault Duty C Ph V	.98	%
572311	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
572312	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	General Comments		
572313	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
572314	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
572315	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Foundation Condition	Good	
572316	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
572317	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
572318	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
572319	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
572320	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
572321	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
572322	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
572323	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
572324	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
572325	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
572326	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
572327	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
572328	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
572329	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
572330	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	General Comments		
572331	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	9 Month Operations	4	
572332	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
572333	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
572334	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	LTC Operation Checked?	y	
572335	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	All Identified and Legible?	n	
572336	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
572337	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
572338	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
572339	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
572340	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
572341	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	VRR Time Delay	60	Seconds
572342	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
572343	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Foundation Condition	Good	
572344	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
572345	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
572346	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	General Comments		
572347	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
572348	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Vegetation	None	
572349	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
572350	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
572351	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	General Comments	out of service	
572352	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
572353	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
572354	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
572355	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
572356	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
572357	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
572358	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
572359	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
572360	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
572361	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
572362	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
572363	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
572364	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
572365	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
572366	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
572367	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
572368	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
572369	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
572370	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Clear of Trash?	y	
572371	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	General Comments		
572372	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
572373	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
572374	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
572375	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
572376	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	General Comments		
572377	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	General Comments		
572378	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Grounds in Place?	y	
572379	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
572380	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Maintenance Operations	0	
572381	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
572382	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Operations Counter AF	99953	
572383	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Operations Counter AL	99953	
572384	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
572385	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Switching Operations	1	
572386	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Tank Paint Condition	Good	
572387	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Unknown Operations	0	
572388	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
572389	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
572390	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
572391	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
572392	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
572393	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
572394	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
572395	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Oil Temp Present	20	°C
572396	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Oil Temp Max	40	°C
572397	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
572398	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
572399	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
572400	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	LTC Totalizer Reading	1368.00	kw
572401	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
572402	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	General Comments		
572403	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	General Comments		
572404	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
572405	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
572406	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Follow-up Action Required?	n	
572407	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
572408	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
572409	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
572410	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
572411	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
572412	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
572413	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
572414	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	VRR Time Delay	30	Seconds
572415	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
572416	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
572417	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
572418	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
572419	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
572420	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
572421	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
572422	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
572423	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
572424	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
572425	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
572426	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
572427	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
572428	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
572429	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
572430	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
572431	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
572432	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
572433	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
572434	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
572435	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
572436	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
572437	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
572438	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
572439	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
572440	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
572441	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
572442	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
572443	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
572444	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
572445	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
572446	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Bushing Condition	Good	
572447	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Amps C Ø	60.0	
572448	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	All Connections OK?	y	
572449	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Amps B Ø	110.0	
572450	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Ambient Temp	28	°F
572451	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
572452	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
572453	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
572454	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
572455	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
572456	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Bushings Connection/Risers	Good	
572457	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
572458	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
572459	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
572460	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Follow-up Action Required?	n	
572461	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
572462	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
572463	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	General Comments		
572464	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	General Comments		
572465	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
572466	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	LTC Totalizer Reading	7411.20	kw
572467	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
572468	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Amps A Ø	356.0	
572469	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Accumulated Fault Duty C Ph V	11.16	%
572470	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Accumulated Fault Duty B Ph V	16.74	%
572471	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Accumulated Fault Duty A Ph V	13.55	%
572472	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	9 Month Operations	4	
572473	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
572474	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
572475	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
572476	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
572477	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
572478	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
572479	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	9 Month Operations	1	
572480	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
572481	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
572482	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
572483	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Amps A Ø	460.0	
572484	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Amps B Ø	480.0	
572485	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
572486	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
572487	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
572488	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	Oil Temp Present	20	°C
572489	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	Oil Temp Max	20	°C
572490	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0	psi
572491	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
572492	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	LTC Totalizer Reading	2574.72	kw
572493	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
572494	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	General Comments		
572495	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
572496	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
572497	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
572498	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
572499	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
572500	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
572501	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
572502	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
572503	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
572504	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	General Comments		
572505	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
572506	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	General Comments		
572507	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
572508	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
572509	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
572510	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	Follow-up Action Required?	n	
572511	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	General Comments		
572512	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC Operations Since Last Insp	355	
572513	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
572514	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
572515	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
572516	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Clear of Trash?	y	
572517	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
572518	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
572519	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
572520	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Amps C Ø	440.0	
572521	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC Min Tap Position	2L	
572522	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC Max Tap Position	9L	
572523	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC Current Tap Position	6L	
572524	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
572525	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Ambient Temp	41	°F
572526	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
572527	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
572528	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Clear of Trash?	y	
572529	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
572530	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
572531	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Operations Counter AL	48	
572532	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Operations Counter AF	48	
572533	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Moisture and Leak Free?	y	
572534	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Maintenance Operations	0	
572535	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC As Left Counter	267881	
572536	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC As Found Counter	267875	
572537	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
572538	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65	
572539	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Heaters (All) Functioning?	y	
572540	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Grounds in Place?	y	
572541	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	General Comments		
572542	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	General Comments		
572543	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Foundation Condition	Good	
572544	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	Totalizer Meter Reading	.2682	
572545	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
572546	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Unknown Operations	0	
572547	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Switching Operations	0	
572548	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Operations Counter AL	231	
572549	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Operations Counter AF	231	
572550	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Maintenance Operations	0	
572551	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
572552	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Switching Operations	0	
572553	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Tank Paint Condition	Good	
572554	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Unknown Operations	0	
572555	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Patrol Inspection	General Comments		
572556	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Follow-up Action Required?	n	
572557	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Patrol Inspection	Follow-up Action Required?	n	
572558	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Operations Ground	0	
572559	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Operations C Ø	0	
572560	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Operations B Ø	0	
572561	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Operations A Ø	0	
572562	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
572563	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
572564	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
572565	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Patrol Inspection	Equipment Properly Labeled?	y	
572566	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Amps C Ø	306.0	
572567	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Amps B Ø	372.0	
572568	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
572569	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
572570	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
572571	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
572572	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
572573	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
572574	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
572575	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Follow-up Action Required?	n	
572576	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Follow-up Action Required?	n	
572577	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Operations Ground	0	
572578	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Operations C Ø	0	
572579	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Operations B Ø	0	
572580	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Operations A Ø	0	
572581	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
572582	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LTCC000576	LTCControl	TE-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
572583	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LTCC000576	LTCControl	TE-TRANS 1	LTC Control Insp	General Comments		
572584	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LTCC000576	LTCControl	TE-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
572585	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
572586	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
572587	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
572588	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
572589	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
572590	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Equipment Properly Labeled?	y	
572591	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Cabinet Paint Condition	Good	
572592	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
572593	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
572594	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC As Found Counter	477475	
572595	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	General Comments		
572596	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	General Comments		
572597	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
572598	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	Follow-up Action Required?	n	
572599	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
572600	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
572601	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	BCH000516	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
572602	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	BCH000516	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
572603	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
572604	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
572605	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
572606	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
572607	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
572608	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
572609	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
572610	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
572611	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
572612	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
572613	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
572614	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
572615	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
572616	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
572617	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
572618	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
572619	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
572620	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Foundation Condition	Good	
572621	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
572622	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Follow-up Action Required?	n	
572623	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
572624	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
572625	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
572626	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
572627	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
572628	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
572629	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
572630	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	General Comments		
572631	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
572632	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
572633	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
572634	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
572635	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
572636	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Clear of Trash?	y	
572637	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
572638	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	General Comments		
572639	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	General Comments		
572640	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
572641	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
572642	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
572643	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
572644	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Vegetation	None	
572645	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
572646	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
572647	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	LTCC000288	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
572648	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	LTCC000288	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
572649	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
572650	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
572651	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Clear of Trash?	y	
572652	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
572653	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
572654	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
572655	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Clear of Trash?	y	
572656	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
572657	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
572658	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
572659	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
572660	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
572661	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	LTC Totalizer Reading	11372.40	kw
572662	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
572663	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
572664	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Oil Temp Max	55	°C
572665	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Bushing Condition	Good	
572666	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
572667	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
572668	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
572669	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
572670	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
572671	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
572672	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
572673	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
572674	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
572675	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
572676	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
572677	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
572678	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
572679	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
572680	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
572681	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
572682	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	General Comments		
572683	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
572684	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
572685	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Vegetation	None	
572686	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
572687	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
572688	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
572689	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
572690	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
572691	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
572692	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
572693	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	General Comments	flood light out, ground off of utility pole	
572694	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
572695	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
572696	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
572697	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
572698	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
572699	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Vegetation	None	
572700	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
572701	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Yard Lights Working?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
572702	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
572703	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC Operations Since Last Insp	83	
572704	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
572705	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	115.00	
572706	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
572707	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	General Comments		
572708	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
572709	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
572710	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
572711	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Operations A Ø	0	
572712	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Operations B Ø	0	
572713	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Operations C Ø	0	
572714	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Operations Ground	0	
572715	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
572716	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
572717	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
572718	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
572719	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
572720	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
572721	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
572722	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC Min Tap Position	6L	
572723	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC Max Tap Position	4L	
572724	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC Current Tap Position	4L	
572725	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
572726	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC As Left Counter	477475	
572727	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
572728	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Vegetation	None	
572729	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
572730	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	General Comments		
572731	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
572732	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
572733	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
572734	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
572735	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
572736	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
572737	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Cabinet Paint Condition	Good	
572738	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Equipment Properly Labeled?	y	
572739	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
572740	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
572741	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
572742	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Operations A Ø	0	
572743	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Operations B Ø	0	
572744	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Operations C Ø	0	
572745	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Operations Ground	0	
572746	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Follow-up Action Required?	n	
572747	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
572748	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
572749	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	General Comments		
572750	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
572751	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
572752	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
572753	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	Oil Temp Max	42	°C
572754	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	Oil Temp Present	42	°C
572755	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
572756	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
572757	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
572758	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Follow-up Action Required?	n	
572759	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Foundation Condition	Good	
572760	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	General Comments		
572761	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	General Comments		
572762	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Grounds in Place?	y	
572763	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Maintenance Operations	0	
572764	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Moisture and Leak Free?	y	
572765	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Operations Counter AF	212	
572766	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Operations Counter AL	214	
572767	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Switching Operations	5	
572768	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Tank Paint Condition	Good	
572769	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Unknown Operations	0	
572770	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Unknown Operations	0	
572771	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Switching Operations	0	
572772	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Operations Counter AL	20	
572773	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Operations Counter AF	20	
572774	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Maintenance Operations	0	
572775	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
572776	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	General Comments	A/B/C phase IOC	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
572777	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Patrol Inspection	General Comments		
572778	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Follow-up Action Required?	n	
572779	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Patrol Inspection	Follow-up Action Required?	n	
572780	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Operations Ground	0	
572781	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Operations C Ø	4	
572782	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Operations B Ø	4	
572783	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Operations A Ø	4	
572784	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
572785	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	41	°F
572786	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
572787	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
572788	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
572789	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	25	°C
572790	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	25	°C
572791	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	47	°C
572792	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	47	°C
572793	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	40	°C
572794	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
572795	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
572796	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
572797	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Operations B Ø	1	
572798	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Operations C Ø	1	
572799	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Operations Ground	0	
572800	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Follow-up Action Required?	n	
572801	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Follow-up Action Required?	n	
572802	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Foundation Condition	Good	
572803	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	General Comments		
572804	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	General Comments		
572805	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Grounds in Place?	y	
572806	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Maintenance Operations	0	
572807	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Moisture and Leak Free?	y	
572808	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Operations Counter AF	193	
572809	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Operations Counter AL	193	
572810	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
572811	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
572812	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
572813	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
572814	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
572815	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
572816	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
572817	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
572818	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
572819	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
572820	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
572821	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
572822	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Switching Operations	1	
572823	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Tank Paint Condition	Good	
572824	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Unknown Operations	0	
572825	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	9 Month Operations	11	
572826	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
572827	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
572828	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
572829	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Amps A Ø	108.0	
572830	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Amps B Ø	116.0	
572831	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Amps C Ø	135.0	
572832	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Bushing Condition	Good	
572833	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Bushings Connection/Risers	Good	
572834	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
572835	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
572836	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
572837	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
572838	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Broom on Site?	n	
572839	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
572840	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
572841	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
572842	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
572843	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
572844	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
572845	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
572846	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
572847	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
572848	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
572849	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
572850	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
572851	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
572852	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Current Tap Position	10L	
572853	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
572854	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
572855	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
572856	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
572857	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	General Comments		
572858	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
572859	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
572860	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
572861	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
572862	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
572863	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
572864	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
572865	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
572866	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Regulator As Left Counter	299448	
572867	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
572868	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Tank Leaks	None	
572869	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Tank Paint Condition	Adequate	
572870	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	9 Month Operations	32	
572871	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Accumulated Fault Duty A Ph V	2.95	%
572872	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Accumulated Fault Duty B Ph V	5.90	%
572873	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Accumulated Fault Duty C Ph V	11.80	%
572874	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Amps A Ø	120.0	
572875	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Amps B Ø	170.0	
572876	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Amps C Ø	110.0	
572877	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Bushing Condition	Good	
572878	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Bushings Connection/Risers	Good	
572879	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
572880	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
572881	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
572882	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Cabinet Paint Condition	Good	
572883	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Equipment Properly Labeled?	y	
572884	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
572885	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
572886	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
572887	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
572888	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
572889	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
572890	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
572891	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
572892	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
572893	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
572894	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
572895	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Amps C Ø	390.0	
572896	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Amps B Ø	420.0	
572897	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Amps A Ø	410.0	
572898	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
572899	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
572900	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
572901	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	9 Months Operations	51	
572902	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Unknown Operations	0	
572903	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Switching Operations	0	
572904	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Operations Counter AL	293	
572905	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
572906	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Operations Counter AF	293	
572907	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Maintenance Operations	0	
572908	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
572909	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
572910	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
572911	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
572912	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
572913	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
572914	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	General Comments		
572915	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Patrol Inspection	General Comments		
572916	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Follow-up Action Required?	n	
572917	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	9 Months Operations	20	
572918	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
572919	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
572920	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
572921	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	47	°C
572922	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	47	°C
572923	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	47	°C
572924	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	47	°C
572925	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	40	°C
572926	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
572927	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Amps A Ø	94.0	
572928	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Amps B Ø	69.0	
572929	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Amps C Ø	78.0	
572930	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
572931	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
572932	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
572933	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
572934	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Operations A Ø	0	
572935	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Operations B Ø	0	
572936	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
572937	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
572938	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Operations A Ø	1	
572939	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Adjusted Amps C Phase V	4.31	
572940	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Adjusted Amps B Phase V	4.31	
572941	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Adjusted Amps A Phase V	4.31	
572942	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Equipment Properly Labeled?	y	
572943	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Cabinet Paint Condition	Good	
572944	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
572945	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	9 Month Operations	55	
572946	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
572947	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Accumulated Fault Duty B Ph V	.34	%
572948	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Unknown Operations	0	
572949	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
572950	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
572951	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
572952	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
572953	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1409	
572954	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1405	
572955	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
572956	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
572957	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
572958	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
572959	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
572960	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
572961	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
572962	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
572963	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
572964	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Bushings Connection/Risers	Good	
572965	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Bushing Condition	Good	
572966	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Amps C Ø	140.0	
572967	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Amps B Ø	120.0	
572968	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Amps A Ø	92.0	
572969	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Accumulated Fault Duty C Ph V	.32	%
572970	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Accumulated Fault Duty B Ph V	.32	%
572971	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Accumulated Fault Duty A Ph V	.32	%
572972	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	9 Month Operations	53	
572973	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Bushing Condition	Good	
572974	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
572975	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
572976	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Bushings Connection/Risers	Good	
572977	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
572978	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
572979	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
572980	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
572981	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
572982	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Cabinet Paint Condition	Good	
572983	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Foundation Condition	Good	
572984	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Follow-up Action Required?	n	
572985	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Follow-up Action Required?	n	
572986	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Operations Ground	0	
572987	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Operations C Ø	0	
572988	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Heaters (All) Functioning?	y	
572989	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Grounds in Place?	y	
572990	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	General Comments		
572991	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	General Comments		
572992	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Unknown Operations	0	
572993	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Tank Paint Condition	Good	
572994	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Switching Operations	1	
572995	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Operations Counter AL	188	
572996	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Operations Counter AF	188	
572997	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Moisture and Leak Free?	y	
572998	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Maintenance Operations	0	
572999	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Grounds in Place?	y	
573000	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
573001	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
573002	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
573003	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
573004	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
573005	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
573006	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Foundation Condition	Good	
573007	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
573008	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
573009	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	General Comments		
573010	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
573011	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Maintenance Operations	0	
573012	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Moisture and Leak Free?	y	
573013	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Operations Counter AF	265	
573014	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Operations Counter AL	267	
573015	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
573016	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Switching Operations	2	
573017	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Tank Paint Condition	Good	
573018	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
573019	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
573020	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
573021	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
573022	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
573023	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
573024	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
573025	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
573026	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
573027	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
573028	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
573029	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
573030	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	General Comments		
573031	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	General Comments		
573032	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Foundation Condition	Good	
573033	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Follow-up Action Required?	n	
573034	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Follow-up Action Required?	n	
573035	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Operations Ground	0	
573036	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Operations C Ø	1	
573037	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Operations B Ø	1	
573038	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
573039	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
573040	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
573041	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
573042	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Amps A Ø	60.0	
573043	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Amps B Ø	50.0	
573044	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Amps C Ø	80.0	
573045	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Bushing Condition	Good	
573046	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Bushings Connection/Risers	Good	
573047	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
573048	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
573049	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
573050	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Cabinet Paint Condition	Good	
573051	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
573052	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.44	%
573053	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.44	%
573054	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	4.88	%
573055	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	13	
573056	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Equipment Properly Labeled?	y	
573057	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
573058	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Adjusted Amps B Phase V	4.56	
573059	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
573060	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
573061	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
573062	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
573063	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
573064	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
573065	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Equipment Properly Labeled?	y	
573066	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Follow-up Action Required?	n	
573067	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
573068	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
573069	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	General Comments		
573070	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
573071	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
573072	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
573073	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
573074	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
573075	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
573076	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
573077	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
573078	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
573079	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
573080	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Foundation Condition	Good	
573081	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	General Comments		
573082	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Adjusted Amps C Phase V	4.56	
573083	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Operations A Ø	0	
573084	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
573085	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
573086	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
573087	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
573088	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Operations B Ø	0	
573089	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Operations A Ø	0	
573090	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
573091	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
573092	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
573093	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
573094	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
573095	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
573096	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
573097	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
573098	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Accumulated Fault Duty C Ph V	.34	%
573099	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
573100	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
573101	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
573102	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
573103	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Equipment Properly Labeled?	y	
573104	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Cabinet Paint Condition	Good	
573105	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
573106	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
573107	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
573108	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
573109	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
573110	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Bushings Connection/Risers	Good	
573111	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Bushing Condition	Good	
573112	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Amps C Ø	180.0	
573113	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Amps B Ø	180.0	
573114	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Amps A Ø	180.0	
573115	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
573116	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
573117	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
573118	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
573119	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
573120	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
573121	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
573122	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
573123	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
573124	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
573125	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
573126	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	9 Month Operations	10	
573127	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
573128	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
573129	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
573130	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
573131	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
573132	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
573133	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
573134	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	General Comments		
573135	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
573136	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	35	°C
573137	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	35	°C
573138	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
573139	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
573140	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
573141	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
573142	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
573143	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	needs paint	
573144	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
573145	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
573146	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
573147	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
573148	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	725	
573149	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	725	
573150	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
573151	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
573152	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
573153	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Operations Counter AF	109	
573154	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Operations Counter AL	109	
573155	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Switching Operations	0	
573156	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Unknown Operations	0	
573157	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
573158	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
573159	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
573160	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
573161	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Foundation Condition	Good	
573162	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
573163	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	24.1	
573164	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	49.6	
573165	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	37.1	
573166	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
573167	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
573168	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
573169	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
573170	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
573171	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
573172	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
573173	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	119	
573174	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
573175	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
573176	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	9 Months Operations	1	
573177	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
573178	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
573179	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
573180	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	General Comments		
573181	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
573182	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
573183	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
573184	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
573185	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
573186	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
573187	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
573188	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
573189	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
573190	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
573191	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
573192	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
573193	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
573194	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
573195	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
573196	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
573197	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
573198	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
573199	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	General Comments		
573200	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
573201	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
573202	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
573203	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
573204	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
573205	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
573206	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
573207	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
573208	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
573209	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
573210	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
573211	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
573212	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
573213	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
573214	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
573215	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
573216	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
573217	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	9 Months Operations	14	
573218	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
573219	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
573220	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
573221	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Amps A Ø	300.0	
573222	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Amps B Ø	300.0	
573223	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Amps C Ø	280.0	
573224	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
573225	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
573226	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
573227	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
573228	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Operations A Ø	0	
573229	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Operations B Ø	0	
573230	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Operations C Ø	0	
573231	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Operations Ground	0	
573232	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Patrol Inspection	Follow-up Action Required?	n	
573233	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Follow-up Action Required?	n	
573234	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Patrol Inspection	General Comments		
573235	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	General Comments		
573236	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
573237	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Maintenance Operations	0	
573238	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
573239	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
573240	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
573241	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
573242	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
573243	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
573244	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
573245	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
573246	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	50	°C
573247	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	20	°C
573248	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
573249	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
573250	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Patrol Inspection	Equipment Properly Labeled?	y	
573251	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Amps C Ø	333.0	
573252	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
573253	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Patrol Inspection	General Comments		
573254	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	General Comments	HSI A/B Phase	
573255	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Maintenance Operations	0	
573256	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Operations Counter AF	99978	
573257	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Operations Counter AL	99978	
573258	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Switching Operations	0	
573259	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Unknown Operations	0	
573260	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Amps B Ø	358.0	
573261	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Amps A Ø	340.0	
573262	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Accumulated Fault Duty C Ph V	31.09	%
573263	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Accumulated Fault Duty B Ph V	39.06	%
573264	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	Follow-up Action Required?	n	
573265	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Accumulated Fault Duty A Ph V	31.89	%
573266	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	9 Month Operations	4	
573267	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	65	°C
573268	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	30	°C
573269	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
573270	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	General Comments		
573271	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
573272	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
573273	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
573274	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
573275	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
573276	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
573277	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
573278	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
573279	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
573280	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
573281	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
573282	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
573283	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
573284	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	General Comments		
573285	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
573286	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
573287	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
573288	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
573289	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
573290	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
573291	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
573292	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
573293	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
573294	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
573295	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
573296	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
573297	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Amps A Ø	850.0	
573298	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Amps B Ø	700.0	
573299	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Amps C Ø	525.0	
573300	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
573301	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
573302	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
573303	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
573304	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
573305	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
573306	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
573307	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
573308	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
573309	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Patrol Inspection	Follow-up Action Required?	n	
573310	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Operations Ground	0	
573311	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Operations C Ø	0	
573312	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Operations B Ø	0	
573313	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Operations A Ø	0	
573314	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
573315	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
573316	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
573317	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
573318	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
573319	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
573320	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
573321	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
573322	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
573323	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
573324	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
573325	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
573326	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
573327	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
573328	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
573329	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
573330	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
573331	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
573332	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	General Comments		
573333	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
573334	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
573335	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
573336	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
573337	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
573338	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
573339	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
573340	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
573341	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
573342	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
573343	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
573344	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
573345	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
573346	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
573347	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
573348	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
573349	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Amps C Ø	20.0	
573350	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Amps B Ø	20.0	
573351	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Amps A Ø	15.0	
573352	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
573353	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
573354	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
573355	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
573356	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
573357	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
573358	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Vegetation	None	
573359	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
573360	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
573361	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
573362	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
573363	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
573364	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
573365	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	General Comments		
573366	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
573367	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
573368	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
573369	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
573370	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
573371	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
573372	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Clear of Trash?	y	
573373	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
573374	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
573375	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
573376	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	LTCC000353	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
573377	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	LTCC000353	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124	VAC
573378	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	LTCC000353	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124	VAC
573379	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	LTCC000353	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
573380	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	LTCC000353	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
573381	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	LTCC000353	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
573382	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Grounds in Place?	y	
573383	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Heaters (All) Functioning?	y	
573384	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Moisture and Leak Free?	y	
573385	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
573386	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Tank Paint Condition	Good	
573387	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	LTCC000353	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
573388	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	LTCC000353	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
573389	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
573390	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Operations A Ø	0	
573391	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Operations B Ø	0	
573392	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Operations C Ø	0	
573393	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Operations Ground	0	
573394	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Follow-up Action Required?	n	
573395	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Follow-up Action Required?	n	
573396	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Foundation Condition	Good	
573397	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	General Comments		
573398	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	General Comments		
573399	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Grounds in Place?	y	
573400	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Heaters (All) Functioning?	y	
573401	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Maintenance Operations	0	
573402	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Moisture and Leak Free?	y	
573403	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Operations Counter AF	149	
573404	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Operations Counter AL	149	
573405	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Switching Operations	5	
573406	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Tank Paint Condition	Good	
573407	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Unknown Operations	0	
573408	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Operations C Ø	0	
573409	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Operations Ground	0	
573410	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Patrol Inspection	Follow-up Action Required?	n	
573411	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Follow-up Action Required?	n	
573412	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Patrol Inspection	General Comments		
573413	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	General Comments		
573414	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Maintenance Operations	0	
573415	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Operations Counter AF	638	
573416	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Operations Counter AL	638	
573417	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Switching Operations	0	
573418	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Unknown Operations	0	
573419	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
573420	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
573421	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
573422	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Evidence of Insects	None	
573423	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
573424	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
573425	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Floor Swept?	n	
573426	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
573427	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
573428	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	General Comments		
573429	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
573430	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
573431	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
573432	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
573433	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
573434	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
573435	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Operations Counter	7	
573436	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
573437	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
573438	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	General Comments		
573439	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
573440	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
573441	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
573442	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	Follow-up Action Required?	n	
573443	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
573444	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	General Comments		
573445	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	General Comments		
573446	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC As Found Counter	85525	
573447	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Unknown Operations	0	
573448	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Switching Operations	0	
573449	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Operations Counter AL	99966	
573450	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Operations Counter AF	99966	
573451	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
573452	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	General Comments	this is correct counter	
573453	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Patrol Inspection	General Comments		
573454	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
573455	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
573456	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
573457	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
573458	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC As Left Counter	85529	
573459	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
573460	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC Current Tap Position	4L	
573461	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC Max Tap Position	6L	
573462	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC Min Tap Position	1L	
573463	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC Operations Since Last Insp	251	
573464	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
573465	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
573466	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
573467	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
573468	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
573469	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
573470	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	180.0	
573471	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	200.0	
573472	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	200.0	
573473	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
573474	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
573475	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
573476	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
573477	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
573478	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
573479	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
573480	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
573481	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Amps C Ø	315.0	
573482	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Amps B Ø	322.0	
573483	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Amps A Ø	334.0	
573484	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
573485	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
573486	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
573487	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	9 Months Operations	33	
573488	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
573489	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
573490	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
573491	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
573492	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
573493	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
573494	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
573495	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
573496	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
573497	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
573498	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
573499	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
573500	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
573501	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
573502	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
573503	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
573504	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Foundation Condition	Good	
573505	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
573506	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	General Comments		
573507	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
573508	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
573509	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
573510	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
573511	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
573512	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
573513	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
573514	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
573515	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
573516	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
573517	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
573518	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
573519	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
573520	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.98	%
573521	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
573522	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
573523	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
573524	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
573525	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
573526	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
573527	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
573528	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
573529	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
573530	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
573531	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
573532	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	General Comments	pole behind switch gear 2 bent	
573533	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
573534	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
573535	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Tank Leaks	None	
573536	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
573537	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Regulator As Left Counter	41733	
573538	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
573539	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
573540	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	General Comments		
573541	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
573542	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Unknown Operations	0	
573543	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Switching Operations	0	
573544	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
573545	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	General Comments		
573546	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
573547	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
573548	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
573549	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
573550	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
573551	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
573552	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
573553	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
573554	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
573555	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
573556	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
573557	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
573558	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
573559	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
573560	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
573561	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
573562	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC Operations Since Last Insp	1066	
573563	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Operations Counter AL	758	
573564	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Operations Counter AF	758	
573565	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Maintenance Operations	0	
573566	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	General Comments		
573567	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Patrol Inspection	General Comments		
573568	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Follow-up Action Required?	n	
573569	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Patrol Inspection	Follow-up Action Required?	n	
573570	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Operations Ground	0	
573571	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Operations C Ø	0	
573572	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Operations B Ø	0	
573573	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
573574	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
573575	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
573576	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
573577	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Amps C Ø	208.0	
573578	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Amps B Ø	223.0	
573579	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Amps A Ø	213.0	
573580	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
573581	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
573582	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
573583	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	9 Months Operations	16	
573584	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC Min Tap Position	8L	
573585	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
573586	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
573587	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
573588	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
573589	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
573590	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
573591	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Operations A Ø	0	
573592	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Operations B Ø	0	
573593	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Operations C Ø	0	
573594	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Operations Ground	0	
573595	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Patrol Inspection	Follow-up Action Required?	n	
573596	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Follow-up Action Required?	n	
573597	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Patrol Inspection	General Comments		
573598	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	General Comments		
573599	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Maintenance Operations	0	
573600	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Operations Counter AF	149	
573601	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Operations Counter AL	149	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
573602	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Switching Operations	0	
573603	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Unknown Operations	0	
573604	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Unknown Operations	0	
573605	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
573606	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Vegetation	None	
573607	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
573608	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
573609	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
573610	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
573611	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
573612	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	General Comments		
573613	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
573614	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
573615	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
573616	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
573617	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
573618	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
573619	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Clear of Trash?	y	
573620	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
573621	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
573622	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
573623	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	PF000380	PowerFuse	TE-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
573624	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	PF000380	PowerFuse	TE-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
573625	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
573626	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
573627	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
573628	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments		
573629	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	2551	
573630	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	2551	
573631	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
573632	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	Neutral	
573633	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	Neutral	
573634	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	1L	
573635	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	73	
573636	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
573637	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
573638	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
573639	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
573640	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
573641	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
573642	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
573643	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
573644	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
573645	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
573646	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
573647	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
573648	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
573649	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
573650	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
573651	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
573652	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
573653	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
573654	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	11	
573655	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	11	
573656	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
573657	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
573658	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Unknown Operations	0	
573659	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
573660	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
573661	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Switching Operations	0	
573662	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Operations Counter AL	635	
573663	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Operations Counter AF	635	
573664	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
573665	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
573666	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
573667	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
573668	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
573669	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
573670	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
573671	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
573672	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
573673	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
573674	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
573675	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
573676	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
573677	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
573678	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	12.0	
573679	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	12.0	
573680	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	12.0	
573681	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.49	%
573682	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
573683	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
573684	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
573685	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
573686	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Broom on Site?	y	
573687	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	34	°F
573688	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
573689	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
573690	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
573691	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
573692	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
573693	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
573694	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
573695	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
573696	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Foundation Condition	Good	
573697	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC Max Tap Position	5R	
573698	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
573699	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
573700	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
573701	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	General Comments		
573702	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Negative DC Ground	22.0	VDC
573703	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC Current Tap Position	2L	
573704	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
573705	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC As Left Counter	273817	
573706	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC As Found Counter	273828	
573707	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	General Comments		
573708	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	General Comments		
573709	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
573710	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	Follow-up Action Required?	n	
573711	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
573712	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
573713	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	General Comments		
573714	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
573715	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
573716	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Positive DC Ground	22.0	VDC
573717	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
573718	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
573719	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
573720	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
573721	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
573722	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
573723	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
573724	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
573725	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
573726	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
573727	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
573728	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
573729	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
573730	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
573731	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
573732	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
573733	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
573734	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	400	
573735	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	396	
573736	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
573737	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
573738	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
573739	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
573740	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
573741	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
573742	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	General Comments		
573743	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
573744	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
573745	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Foundation Condition	Good	
573746	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
573747	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
573748	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
573749	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
573750	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
573751	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
573752	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
573753	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
573754	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
573755	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
573756	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	General Comments		
573757	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
573758	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
573759	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
573760	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
573761	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
573762	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
573763	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
573764	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
573765	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
573766	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
573767	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	General Comments		
573768	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
573769	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
573770	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
573771	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
573772	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
573773	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
573774	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	9 Month Operations	2	
573775	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	3.85	%
573776	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	3.85	%
573777	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	3.85	%
573778	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Amps A Ø	950.0	
573779	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Amps B Ø	970.0	
573780	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Amps C Ø	930.0	
573781	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Amps A Ø	88.0	
573782	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
573783	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
573784	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
573785	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
573786	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
573787	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Evidence of Insects	None	
573788	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
573789	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
573790	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Floor Swept?	y	
573791	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
573792	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
573793	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	General Comments		
573794	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
573795	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
573796	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Panels Dusted?	y	
573797	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
573798	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
573799	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
573800	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Trash Emptied?	y	
573801	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
573802	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
573803	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
573804	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
573805	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
573806	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
573807	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
573808	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
573809	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
573810	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
573811	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
573812	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	General Comments		
573813	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
573814	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
573815	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
573816	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
573817	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
573818	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
573819	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
573820	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
573821	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
573822	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BCH001272	Charger	653-Battery Charger	Battery Charger Patrol Insp	General Comments		
573823	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BCH001272	Charger	653-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
573824	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BCH001272	Charger	653-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
573825	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BCH001272	Charger	653-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
573826	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BCH001272	Charger	653-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
573827	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
573828	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
573829	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
573830	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
573831	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
573832	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
573833	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
573834	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
573835	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
573836	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Operations A Ø	0	
573837	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Operations B Ø	0	
573838	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Operations C Ø	0	
573839	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Operations Ground	0	
573840	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Patrol Inspection	Follow-up Action Required?	n	
573841	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Follow-up Action Required?	n	
573842	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Patrol Inspection	General Comments		
573843	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	General Comments		
573844	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
573845	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Maintenance Operations	0	
573846	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	PF000379	PowerFuse	TE-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
573847	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	PF000379	PowerFuse	TE-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
573848	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Operations Counter AF	234	
573849	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Operations Counter AL	234	
573850	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Switching Operations	0	
573851	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
573852	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
573853	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
573854	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
573855	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
573856	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
573857	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
573858	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
573859	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
573860	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
573861	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
573862	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
573863	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	General Comments		
573864	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
573865	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
573866	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Foundation Condition	Good	
573867	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
573868	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
573869	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
573870	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
573871	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
573872	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
573873	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	9 Month Operations	0	
573874	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
573875	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
573876	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
573877	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Amps A Ø	0.0	
573878	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Amps B Ø	0.0	
573879	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Amps C Ø	0.0	
573880	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
573881	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
573882	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
573883	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
573884	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
573885	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
573886	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
573887	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
573888	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
573889	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
573890	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
573891	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
573892	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
573893	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Operations Ground	0	
573894	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
573895	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
573896	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
573897	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
573898	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Amps B Ø	97.0	
573899	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Amps C Ø	90.0	
573900	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
573901	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
573902	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
573903	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
573904	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
573905	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
573906	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
573907	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
573908	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
573909	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
573910	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	General Comments		
573911	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
573912	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
573913	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Operations Counter	35	
573914	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
573915	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Tank Leaks	None	
573916	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
573917	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
573918	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
573919	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
573920	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
573921	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
573922	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
573923	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	9 Months Operations	11	
573924	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Accumulated Fault Duty A Ph AM	6.02	%
573925	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Accumulated Fault Duty B Ph AM	3.61	%
573926	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Accumulated Fault Duty C Ph AM	4.82	%
573927	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Amps A Ø	480.0	
573928	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Amps B Ø	410.0	
573929	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Amps C Ø	415.0	
573930	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
573931	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	General Comments		
573932	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
573933	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2	psi
573934	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
573935	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
573936	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Amps B Ø	36	
573937	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Amps C Ø	65	
573938	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Bushing Condition	Good	
573939	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Bushings Connection/Risers	Good	
573940	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
573941	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
573942	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
573943	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCControl	722-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
573944	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCControl	722-1	LTC Control Insp	VRR Base Voltage AL	1241.0	VAC
573945	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCControl	722-1	LTC Control Insp	VRR Time Delay	30	Seconds
573946	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Cabinet Paint Condition	Good	
573947	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Equipment Properly Labeled?	y	
573948	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Adjusted Amps A Phase V	0	
573949	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Adjusted Amps B Phase V	0	
573950	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Adjusted Amps C Phase V	0	
573951	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Operations A Ø	0	
573952	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Operations B Ø	0	
573953	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Operations C Ø	0	
573954	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Operations Ground	0	
573955	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Follow-up Action Required?	n	
573956	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Follow-up Action Required?	n	
573957	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Foundation Condition	Good	
573958	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	General Comments		
573959	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
573960	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
573961	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
573962	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
573963	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	General Comments		
573964	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
573965	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
573966	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Grounds in Place?	y	
573967	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Heaters (All) Functioning?	y	
573968	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Maintenance Operations	1	
573969	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Moisture and Leak Free?	y	
573970	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Operations Counter AF	180	
573971	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Operations Counter AL	181	
573972	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Switching Operations	0	
573973	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Tank Paint Condition	Good	
573974	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Unknown Operations	0	
573975	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Tank Paint Condition	Good	
573976	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
573977	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
573978	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
573979	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
573980	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
573981	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
573982	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Cabinet Paint Condition	Good	
573983	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Equipment Properly Labeled?	y	
573984	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Follow-up Action Required?	n	
573985	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Foundation Condition	Good	
573986	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	General Comments		
573987	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Grounds in Place?	y	
573988	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Heaters (All) Functioning?	y	
573989	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Moisture and Leak Free?	y	
573990	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
573991	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Tank Paint Condition	Good	
573992	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Unknown Operations	0	
573993	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Switching Operations	0	
573994	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Operations Counter AL	192	
573995	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Operations Counter AF	192	
573996	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Maintenance Operations	0	
573997	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
573998	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	General Comments		
573999	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Patrol Inspection	General Comments		
574000	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Follow-up Action Required?	n	
574001	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Patrol Inspection	Follow-up Action Required?	n	
574002	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Operations Ground	0	
574003	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Operations C Ø	0	
574004	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Operations B Ø	0	
574005	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Operations A Ø	0	
574006	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
574007	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
574008	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
574009	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
574010	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Amps C Ø	300.0	
574011	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Amps B Ø	310.0	
574012	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Amps A Ø	300.0	
574013	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
574014	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
574015	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
574016	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	9 Months Operations	46	
574017	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCControl	722-1	LTC Control Insp	All Connections OK?	y	
574018	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCControl	722-1	LTC Control Insp	Follow-up Action Required?	n	
574019	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCControl	722-1	LTC Control Insp	General Comments		
574020	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCControl	722-1	LTC Control Insp	LTC Operation Checked?	y	
574021	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCControl	722-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
574022	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	9 Month Operations	2	
574023	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Accumulated Fault Duty A Ph V	.72	%
574024	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Accumulated Fault Duty B Ph V	.72	%
574025	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Accumulated Fault Duty C Ph V	.72	%
574026	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Amps A Ø	42	
574027	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
574028	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
574029	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
574030	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
574031	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
574032	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
574033	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Bushing Condition	Good	
574034	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Bushings Connection/Risers	Good	
574035	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
574036	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
574037	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
574038	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Cabinet Paint Condition	Good	
574039	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Equipment Properly Labeled?	y	
574040	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Fault Adjusted Amps A Phase V	0	
574041	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Fault Adjusted Amps B Phase V	0	
574042	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Fault Adjusted Amps C Phase V	0	
574043	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Fault Operations A Ø	0	
574044	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Fault Operations B Ø	0	
574045	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
574046	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
574047	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	Totalizer Meter Reading	.1892	
574048	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Fault Operations C Ø	0	
574049	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Fault Operations Ground	0	
574050	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Follow-up Action Required?	n	
574051	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
574052	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Foundation Condition	Good	
574053	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	General Comments		
574054	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	General Comments		
574055	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Grounds in Place?	y	
574056	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Heaters (All) Functioning?	y	
574057	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Maintenance Operations	1	
574058	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Moisture and Leak Free?	y	
574059	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Operations Counter AF	179	
574060	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Operations Counter AL	180	
574061	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Switching Operations	0	
574062	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Tank Paint Condition	Good	
574063	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Unknown Operations	0	
574064	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
574065	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
574066	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Operations Counter	124	
574067	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
574068	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	General Comments		
574069	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
574070	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
574071	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
574072	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
574073	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
574074	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
574075	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Amps B Ø	15.3	
574076	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Amps A Ø	1.1	
574077	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
574078	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	General Comments		
574079	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	General Comments		
574080	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
574081	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
574082	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	Non LTC Totalizer Reading	227.04	kw
574083	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Unknown Operations	0	
574084	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Switching Operations	1	
574085	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Operations Counter AL	165	
574086	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Operations Counter AF	165	
574087	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Moisture and Leak Free?	y	
574088	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Maintenance Operations	0	
574089	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Grounds in Place?	y	
574090	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	General Comments		
574091	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	General Comments		
574092	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Foundation Condition	Good	
574093	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Follow-up Action Required?	n	
574094	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Follow-up Action Required?	n	
574095	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Operations Ground	0	
574096	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Operations C Ø	0	
574097	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Operations B Ø	0	
574098	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Operations A Ø	0	
574099	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
574100	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
574101	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
574102	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Equipment Properly Labeled?	y	
574103	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Cabinet Paint Condition	Good	
574104	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
574105	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
574106	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
574107	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Bushings Connection/Risers	Good	
574108	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Bushing Condition	Good	
574109	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Amps C Ø	70.0	
574110	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Amps B Ø	55.0	
574111	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Amps A Ø	50.0	
574112	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
574113	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
574114	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
574115	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	9 Month Operations	49	
574116	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	9 Month Operations	7	
574117	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Accumulated Fault Duty A Ph V	1.43	%
574118	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Accumulated Fault Duty B Ph V	1.79	%
574119	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Accumulated Fault Duty C Ph V	1.79	%
574120	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Amps A Ø	67	
574121	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Amps B Ø	53	
574122	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Amps C Ø	65	
574123	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
574124	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
574125	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
574126	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BCH000387	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
574127	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
574128	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
574129	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
574130	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
574131	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
574132	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
574133	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
574134	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Tank Leaks	None	
574135	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
574136	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Regulator As Left Counter	14730	
574137	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	
574138	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	3.86	%
574139	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	5.40	%
574140	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
574141	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	3.09	%
574142	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
574143	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Amps C Ø	0.0	
574144	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Amps B Ø	0.0	
574145	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Amps A Ø	0.0	
574146	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
574147	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
574148	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
574149	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
574150	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
574151	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
574152	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
574153	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
574154	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
574155	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
574156	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	General Comments		
574157	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
574158	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
574159	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
574160	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
574161	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
574162	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
574163	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
574164	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
574165	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
574166	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
574167	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	General Comments	door lock not working properly, two four foot lights out	
574168	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
574169	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
574170	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Panels Dusted?	y	
574171	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
574172	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	9 Months Operations	35	
574173	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
574174	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Control House Lighting OK?	n	
574175	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
574176	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
574177	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Doors and Locks Secure?	n	
574178	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Evidence of Insects	None	
574179	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
574180	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
574181	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Floor Swept?	y	
574182	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
574183	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
574184	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LTCC000364	LTCControl	TE-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
574185	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LTCC000364	LTCControl	TE-TRANS 2	LTC Control Insp	General Comments		
574186	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LTCC000364	LTCControl	TE-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
574187	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
574188	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
574189	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
574190	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
574191	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
574192	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Maintenance Operations	0	
574193	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	General Comments		
574194	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Patrol Inspection	General Comments		
574195	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Follow-up Action Required?	n	
574196	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
574197	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations Ground	0	
574198	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations C Ø	0	
574199	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
574200	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations B Ø	0	
574201	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.000	millivolts

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
574202	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.8	VDC
574203	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.8	VDC
574204	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.8	amps
574205	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
574206	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
574207	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	General Comments		
574208	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
574209	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations A Ø	0	
574210	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
574211	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
574212	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
574213	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
574214	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
574215	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
574216	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
574217	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
574218	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BCH000387	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
574219	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BCH000387	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
574220	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BCH000387	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
574221	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BCH000387	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.7	VDC
574222	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BCH000387	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.7	VDC
574223	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
574224	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	550	
574225	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
574226	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
574227	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
574228	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
574229	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
574230	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC As Left Counter	144029	
574231	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC As Found Counter	144029	
574232	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Unknown Operations	0	
574233	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Tank Paint Condition	Good	
574234	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Switching Operations	0	
574235	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Operations Counter AL	179	
574236	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Operations Counter AF	179	
574237	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Moisture and Leak Free?	y	
574238	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Maintenance Operations	0	
574239	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Heaters (All) Functioning?	y	
574240	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Grounds in Place?	y	
574241	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	General Comments		
574242	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	General Comments		
574243	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Foundation Condition	Good	
574244	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Follow-up Action Required?	n	
574245	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Follow-up Action Required?	n	
574246	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Operations Ground	0	
574247	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Operations C Ø	0	
574248	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Operations B Ø	0	
574249	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Operations A Ø	0	
574250	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
574251	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
574252	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
574253	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Equipment Properly Labeled?	y	
574254	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Cabinet Paint Condition	Good	
574255	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
574256	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
574257	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
574258	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Bushings Connection/Risers	Good	
574259	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Bushing Condition	Good	
574260	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Amps C Ø	215.0	
574261	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Amps B Ø	227.0	
574262	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Amps A Ø	212.0	
574263	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
574264	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Accumulated Fault Duty B Ph V	.36	%
574265	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Accumulated Fault Duty A Ph V	1.08	%
574266	2/13/2019 14:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	9 Month Operations	1	
574267	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
574268	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	General Comments		
574269	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
574270	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
574271	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Bushings Connection/Risers	Good	
574272	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
574273	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
574274	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Clear of Trash?	y	
574275	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
574276	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
574277	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
574278	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
574279	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
574280	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
574281	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	General Comments		
574282	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
574283	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
574284	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
574285	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Vegetation	None	
574286	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
574287	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
574288	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Trash Emptied?	y	
574289	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
574290	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
574291	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
574292	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
574293	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
574294	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
574295	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
574296	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
574297	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
574298	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
574299	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	y	
574300	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
574301	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	door lights not working, vent fan not working	
574302	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
574303	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
574304	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
574305	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
574306	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
574307	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	n	
574308	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	n	
574309	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
574310	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Bushing Condition	Good	
574311	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Patrol Inspection	General Comments		
574312	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	General Comments		
574313	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Maintenance Operations	0	
574314	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Operations Counter AF	222	
574315	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Operations Counter AL	222	
574316	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Switching Operations	0	
574317	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Unknown Operations	0	
574318	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
574319	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
574320	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
574321	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
574322	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	Oil Temp Present	30	°C
574323	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	Oil Temp Max	30	°C
574324	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
574325	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC As Left Counter	188481	
574326	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
574327	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
574328	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6L	
574329	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
574330	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1479	
574331	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
574332	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
574333	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
574334	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
574335	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	LTC Totalizer Reading	5978.88	kw
574336	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
574337	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	General Comments		
574338	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	General Comments		
574339	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
574340	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
574341	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
574342	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
574343	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
574344	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
574345	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCControl	415-1	LTC Control Insp	VRR Time Delay	30	Seconds
574346	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
574347	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCControl	415-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
574348	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCControl	415-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
574349	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCControl	415-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
574350	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCControl	415-1	LTC Control Insp	LTC Operation Checked?	y	
574351	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCControl	415-1	LTC Control Insp	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
574352	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCControl	415-1	LTC Control Insp	Follow-up Action Required?	n	
574353	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCControl	415-1	LTC Control Insp	All Connections OK?	y	
574354	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	9 Month Operations	4	
574355	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Accumulated Fault Duty A Ph V	69.36	%
574356	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Accumulated Fault Duty B Ph V	89.28	%
574357	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
574358	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
574359	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
574360	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	1236.0	VAC
574361	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
574362	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
574363	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
574364	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
574365	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
574366	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
574367	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Accumulated Fault Duty C Ph V	72.54	%
574368	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Amps A Ø	166.0	
574369	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Amps B Ø	145.0	
574370	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Amps C Ø	171.0	
574371	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Patrol Inspection	Equipment Properly Labeled?	y	
574372	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
574373	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
574374	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
574375	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
574376	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
574377	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
574378	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
574379	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
574380	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Foundation Condition	Good	
574381	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
574382	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
574383	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	General Comments	(1) TOWER LEG FOUNDATION CRUMBLING	
574384	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
574385	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	PF000377	PowerFuse	TE-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
574386	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	PF000377	PowerFuse	TE-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
574387	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
574388	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
574389	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	PF000378	PowerFuse	TE-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
574390	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	PF000378	PowerFuse	TE-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
574391	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
574392	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
574393	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
574394	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
574395	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
574396	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
574397	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
574398	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
574399	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
574400	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	202.50	
574401	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Reading	.6420	
574402	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
574403	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Amps C Ø	60.0	
574404	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Amps B Ø	80.0	
574405	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Amps A Ø	75.0	
574406	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Accumulated Fault Duty C Ph V	1.75	%
574407	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Accumulated Fault Duty B Ph V	1.75	%
574408	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
574409	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Accumulated Fault Duty A Ph V	2.10	%
574410	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	9 Month Operations	326	
574411	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Readings	Top Oil Temperature Present	40	°C
574412	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Readings	Top Oil Temperature Max	40	°C
574413	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
574414	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	General Comments		
574415	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
574416	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC As Found Counter	188481	
574417	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
574418	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
574419	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
574420	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	PF000273	PowerFuse	PV-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
574421	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	PF000273	PowerFuse	PV-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
574422	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	PF000274	PowerFuse	PV-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
574423	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	PF000274	PowerFuse	PV-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
574424	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
574425	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
574426	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
574427	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
574428	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
574429	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
574430	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
574431	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
574432	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Readings	LTC Totalizer Reading	6163.20	kw
574433	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
574434	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
574435	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
574436	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
574437	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
574438	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
574439	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
574440	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
574441	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
574442	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
574443	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
574444	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
574445	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
574446	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
574447	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
574448	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
574449	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
574450	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
574451	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
574452	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
574453	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	Follow-up Action Required?	n	
574454	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
574455	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
574456	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
574457	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
574458	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
574459	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
574460	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
574461	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
574462	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
574463	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
574464	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
574465	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
574466	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
574467	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
574468	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
574469	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
574470	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
574471	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
574472	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
574473	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
574474	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
574475	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
574476	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
574477	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
574478	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
574479	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Operations A Ø	0	
574480	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Operations B Ø	0	
574481	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Operations C Ø	0	
574482	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Operations Ground	0	
574483	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
574484	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
574485	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
574486	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
574487	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Patrol Inspection	Follow-up Action Required?	n	
574488	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Follow-up Action Required?	n	
574489	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Patrol Inspection	General Comments		
574490	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	General Comments		
574491	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Maintenance Operations	0	
574492	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Operations Counter AF	553	
574493	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Operations Counter AL	553	
574494	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Switching Operations	0	
574495	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Unknown Operations	0	
574496	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
574497	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
574498	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
574499	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
574500	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
574501	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
574502	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
574503	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	BCH000516	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
574504	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	BCH000516	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
574505	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	BCH000516	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
574506	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	BCH000516	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
574507	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
574508	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Tank Leaks	None	
574509	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
574510	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Regulator As Left Counter	28441	
574511	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
574512	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
574513	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
574514	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
574515	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
574516	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
574517	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
574518	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
574519	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	General Comments		
574520	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
574521	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
574522	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
574523	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
574524	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
574525	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
574526	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
574527	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
574528	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
574529	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	Totalizer Meter Reading	1.2456	
574530	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
574531	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
574532	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Unknown Operations	0	
574533	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Switching Operations	0	
574534	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Operations Counter AL	390	
574535	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
574536	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
574537	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
574538	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
574539	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
574540	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Operations Counter AF	390	
574541	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
574542	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
574543	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
574544	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
574545	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
574546	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	General Comments		
574547	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	desiccant needs replaced	
574548	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	Totalizer Meter Reading	.7164	
574549	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
574550	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
574551	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
574552	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
574553	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Maintenance Operations	0	
574554	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	General Comments		
574555	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Patrol Inspection	General Comments		
574556	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Follow-up Action Required?	n	
574557	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Patrol Inspection	Follow-up Action Required?	n	
574558	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Operations Ground	0	
574559	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Operations C Ø	0	
574560	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Operations B Ø	0	
574561	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Operations A Ø	0	
574562	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
574563	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
574564	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
574565	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Patrol Inspection	Equipment Properly Labeled?	y	
574566	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Amps C Ø	124.0	
574567	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Amps B Ø	105.0	
574568	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Amps A Ø	107.0	
574569	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Accumulated Fault Duty C Ph V	52.61	%
574570	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Accumulated Fault Duty B Ph V	27.10	%
574571	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Accumulated Fault Duty A Ph V	56.60	%
574572	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	9 Month Operations	84	
574573	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Unknown Operations	0	
574574	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC As Found Counter	179860	
574575	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Tank Paint Condition	Good	
574576	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
574577	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	General Comments	barbed wire on front half of station is rusty	
574578	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
574579	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
574580	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
574581	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
574582	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
574583	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
574584	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
574585	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
574586	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
574587	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
574588	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
574589	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
574590	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
574591	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	Follow-up Action Required?	n	
574592	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
574593	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	General Comments		
574594	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Mechanism Patrol Inspection	General Comments		
574595	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC As Found Counter	94806	
574596	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC As Left Counter	94822	
574597	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
574598	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC Current Tap Position	2L	
574599	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
574600	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC Min Tap Position	10L	
574601	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC Operations Since Last Insp	493	
574602	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
574603	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
574604	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
574605	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
574606	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
574607	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
574608	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
574609	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
574610	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
574611	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
574612	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
574613	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
574614	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
574615	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	Follow-up Action Required?	n	
574616	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
574617	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
574618	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	General Comments		
574619	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	General Comments		
574620	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
574621	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	LTC Totalizer Reading	6877.44	kw
574622	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
574623	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
574624	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	Oil Temp Max	65	°C
574625	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	Oil Temp Present	40	°C
574626	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
574627	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
574628	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
574629	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	General Comments		
574630	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
574631	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Vegetation	None	
574632	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	General Comments		
574633	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Foundation Condition	Good	
574634	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Follow-up Action Required?	n	
574635	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Follow-up Action Required?	n	
574636	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Operations Ground	0	
574637	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Operations C Ø	1	
574638	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Operations B Ø	0	
574639	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Operations A Ø	0	
574640	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
574641	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
574642	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
574643	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Equipment Properly Labeled?	y	
574644	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Cabinet Paint Condition	Good	
574645	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
574646	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
574647	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
574648	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Bushings Connection/Risers	Good	
574649	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
574650	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
574651	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
574652	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Equipment Properly Labeled?	y	
574653	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
574654	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
574655	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
574656	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Operations A Ø	0	
574657	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Operations B Ø	0	
574658	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Operations C Ø	0	
574659	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Operations Ground	0	
574660	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Follow-up Action Required?	n	
574661	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Follow-up Action Required?	n	
574662	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Foundation Condition	Good	
574663	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	General Comments		
574664	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	General Comments		
574665	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Grounds in Place?	y	
574666	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Maintenance Operations	206	
574667	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Moisture and Leak Free?	y	
574668	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Operations Counter AF	204	
574669	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Operations Counter AL	206	
574670	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Switching Operations	5	
574671	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Tank Paint Condition	Good	
574672	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Unknown Operations	0	
574673	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Bushing Condition	Good	
574674	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
574675	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
574676	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
574677	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
574678	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
574679	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
574680	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
574681	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
574682	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
574683	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
574684	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Switching Operations	2	
574685	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
574686	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Operations Counter AL	320	
574687	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Operations Counter AF	318	
574688	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Moisture and Leak Free?	y	
574689	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Maintenance Operations	0	
574690	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	9 Month Operations	214	
574691	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
574692	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
574693	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
574694	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Amps A Ø	0.0	
574695	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Amps B Ø	0.0	
574696	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Amps C Ø	0.0	
574697	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Bushing Condition	Good	
574698	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Bushings Connection/Risers	Good	
574699	2/13/2019 14:17	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
574700	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
574701	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
574702	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
574703	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
574704	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
574705	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Current Tap Position	10L	
574706	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC As Left Counter	179860	
574707	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
574708	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
574709	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
574710	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
574711	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
574712	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
574713	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	General Comments		
574714	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
574715	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Max Tap Position	5L	
574716	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
574717	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
574718	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
574719	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
574720	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	12L	
574721	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	363	
574722	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
574723	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
574724	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
574725	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
574726	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
574727	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
574728	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
574729	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Regulator As Left Counter	283371	
574730	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
574731	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Tank Leaks	None	
574732	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
574733	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Heaters (All) Functioning?	y	
574734	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Grounds in Place?	y	
574735	2/13/2019 13:51	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	General Comments		
574736	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Tank Paint Condition	Good	
574737	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	LTCC000057	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124	VAC
574738	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	LTCC000057	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124	VAC
574739	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	LTCC000057	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
574740	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Amps C Ø	48.0	
574741	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Amps B Ø	47.0	
574742	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Amps A Ø	41.0	
574743	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
574744	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
574745	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
574746	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	9 Months Operations	30	
574747	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	General Comments		
574748	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
574749	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
574750	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
574751	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
574752	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
574753	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Tank Leaks	None	
574754	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
574755	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Regulator As Left Counter	2895	
574756	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
574757	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
574758	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
574759	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
574760	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
574761	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
574762	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
574763	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
574764	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
574765	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
574766	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
574767	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	General Comments		
574768	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
574769	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
574770	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	General Comments		
574771	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
574772	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
574773	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
574774	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
574775	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
574776	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
574777	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
574778	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
574779	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
574780	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
574781	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	General Comments		
574782	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
574783	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
574784	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
574785	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
574786	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
574787	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
574788	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
574789	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
574790	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
574791	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
574792	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
574793	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
574794	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
574795	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
574796	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
574797	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Operations Counter AL	1011	
574798	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Switching Operations	0	
574799	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Unknown Operations	0	
574800	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Negative DC Ground	12.5	VDC
574801	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Positive DC Ground	12.3	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
574802	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
574803	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
574804	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Cabinet Paint Condition	Good	
574805	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
574806	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
574807	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Operations Counter AF	1011	
574808	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Maintenance Operations	0	
574809	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	General Comments		
574810	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
574811	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Bushings Connection/Risers	Good	
574812	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Bushing Condition	Good	
574813	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	General Comments		
574814	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
574815	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
574816	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
574817	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
574818	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Patrol Inspection	General Comments		
574819	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Follow-up Action Required?	n	
574820	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Patrol Inspection	Follow-up Action Required?	n	
574821	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Operations Ground	0	
574822	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
574823	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
574824	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	LTCC000057	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
574825	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
574826	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
574827	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Positive DC Ground	0	VDC
574828	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Negative DC Ground	0	VDC
574829	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	General Comments		
574830	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
574831	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
574832	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
574833	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
574834	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
574835	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
574836	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
574837	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
574838	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	39	°F
574839	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	All Connections OK?	y	
574840	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	LTCC000057	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
574841	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	LTCC000057	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
574842	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	LTCC000057	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
574843	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	LTCC000057	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124	VAC
574844	2/14/2019 7:54	Distribution	Warsaw East Quarterly Inspection	LTCC000057	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
574845	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Operations C Ø	0	
574846	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Operations B Ø	0	
574847	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Operations A Ø	0	
574848	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
574849	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
574850	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
574851	2/13/2019 10:19	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
574852	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Equipment Properly Labeled?	y	
574853	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Follow-up Action Required?	n	
574854	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Foundation Condition	Good	
574855	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	General Comments		
574856	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Grounds in Place?	y	
574857	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Moisture and Leak Free?	y	
574858	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
574859	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
574860	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
574861	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1746.72	kw
574862	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	307.50	
574863	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	290.00	
574864	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Oil Temp Max	91	°C
574865	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
574866	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
574867	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
574868	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
574869	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
574870	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	46	°F
574871	2/13/2019 15:11	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
574872	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Oil Temp Present	22	°C
574873	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	General Comments		
574874	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
574875	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	BCH001022	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
574876	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	BCH001022	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
574877	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	BCH001022	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
574878	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	BCH001022	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
574879	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	BCH001022	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
574880	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	BCH001022	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.9	VDC
574881	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
574882	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	General Comments		
574883	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
574884	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
574885	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	BCH001022	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.9	VDC
574886	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
574887	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Broom on Site?	y	
574888	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	BCH001022	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.120	millivolts
574889	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
574890	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7278	
574891	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
574892	2/13/2019 9:42	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
574893	2/13/2019 14:24	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
574894	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Adequate	
574895	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
574896	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Bad	
574897	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
574898	2/13/2019 13:33	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
574899	2/13/2019 12:28	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
574900	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LTCC000544	LTCControl	MC-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
574901	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LTCC000544	LTCControl	MC-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
574902	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LTCC000544	LTCControl	MC-Offline-Distribution	LTC Control Insp	General Comments		
574903	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
574904	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
574905	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
574906	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
574907	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
574908	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
574909	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	150.0	
574910	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	150.0	
574911	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
574912	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
574913	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Bushings Connection/Risers	Good	
574914	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Bushing Condition	Good	
574915	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Unknown Operations	0	
574916	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Amps C Ø	12.0	
574917	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Amps B Ø	12.0	
574918	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Amps A Ø	12.0	
574919	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Accumulated Fault Duty C Ph V	9.02	%
574920	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
574921	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
574922	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Accumulated Fault Duty B Ph V	9.02	%
574923	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Accumulated Fault Duty A Ph V	8.27	%
574924	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
574925	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	9 Month Operations	7	
574926	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
574927	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
574928	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
574929	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
574930	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
574931	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
574932	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
574933	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
574934	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
574935	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
574936	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
574937	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
574938	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
574939	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
574940	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
574941	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
574942	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
574943	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
574944	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	General Comments		
574945	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
574946	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
574947	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
574948	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
574949	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
574950	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
574951	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
574952	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
574953	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
574954	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
574955	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
574956	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
574957	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
574958	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
574959	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
574960	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
574961	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
574962	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
574963	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	19	
574964	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC As Found Counter	215007	
574965	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC As Left Counter	215015	
574966	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
574967	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC Current Tap Position	1L	
574968	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC Max Tap Position	2R	
574969	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	19	
574970	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
574971	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
574972	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
574973	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC Min Tap Position	5L	
574974	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC Operations Since Last Insp	913	
574975	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
574976	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
574977	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
574978	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BAT000193	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
574979	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BAT000193	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
574980	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
574981	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
574982	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
574983	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
574984	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
574985	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Foundation Condition	Good	
574986	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
574987	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
574988	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	General Comments	Blown lightning arrester on circuit #302	
574989	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
574990	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
574991	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BAT000193	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
574992	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BAT000193	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
574993	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BAT000193	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
574994	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BAT000193	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	19.2	VDC
574995	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BAT000193	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	21.4	VDC
574996	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BAT000193	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
574997	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BAT000193	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
574998	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
574999	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
575000	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
575001	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
575002	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
575003	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
575004	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
575005	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
575006	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
575007	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	154	
575008	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	154	
575009	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	2	
575010	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
575011	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Unknown Operations	0	
575012	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Tank Paint Condition	Good	
575013	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Switching Operations	0	
575014	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
575015	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Operations Counter AL	798	
575016	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Operations Counter AF	798	
575017	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Moisture and Leak Free?	y	
575018	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Maintenance Operations	0	
575019	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Grounds in Place?	y	
575020	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
575021	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
575022	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	General Comments		
575023	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	General Comments		
575024	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Foundation Condition	Good	
575025	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Follow-up Action Required?	n	
575026	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
575027	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Operations Ground	0	
575028	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Operations C Ø	0	
575029	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Operations B Ø	0	
575030	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Operations A Ø	0	
575031	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
575032	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
575033	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
575034	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Operations A Ø	0	
575035	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Operations B Ø	0	
575036	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Operations C Ø	0	
575037	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Operations Ground	0	
575038	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Follow-up Action Required?	n	
575039	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Follow-up Action Required?	n	
575040	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Foundation Condition	Good	
575041	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	General Comments		
575042	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	General Comments		
575043	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
575044	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	7	
575045	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Moisture and Leak Free?	y	
575046	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Grounds in Place?	y	
575047	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Maintenance Operations	0	
575048	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
575049	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
575050	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
575051	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
575052	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
575053	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
575054	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
575055	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Cabinet Paint Condition	Good	
575056	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
575057	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
575058	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
575059	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
575060	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
575061	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	Oil Temp Max	59	°C
575062	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	Oil Temp Present	30	°C
575063	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BAT000193	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
575064	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BAT000193	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
575065	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
575066	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
575067	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
575068	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
575069	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
575070	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
575071	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
575072	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
575073	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
575074	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
575075	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
575076	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	Totalizer Meter Reading	.9066	
575077	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
575078	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
575079	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	150.0	
575080	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
575081	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
575082	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
575083	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BAT000193	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
575084	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BAT000193	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
575085	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BAT000193	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
575086	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
575087	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Operations Counter AF	242	
575088	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Mechanism Patrol Inspection	General Comments		
575089	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	General Comments		
575090	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
575091	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	243	
575092	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	243	
575093	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
575094	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Equipment Properly Labeled?	y	
575095	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
575096	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
575097	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
575098	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
575099	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	Follow-up Action Required?	n	
575100	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Operations Counter AL	242	
575101	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
575102	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Switching Operations	0	
575103	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Tank Paint Condition	Good	
575104	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Unknown Operations	0	
575105	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
575106	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
575107	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
575108	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
575109	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
575110	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
575111	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
575112	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Operations A Ø	0	
575113	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Operations B Ø	0	
575114	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Operations C Ø	0	
575115	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Operations Ground	0	
575116	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Follow-up Action Required?	n	
575117	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Follow-up Action Required?	n	
575118	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Foundation Condition	Good	
575119	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	General Comments		
575120	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	General Comments		
575121	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Grounds in Place?	y	
575122	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
575123	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
575124	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
575125	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
575126	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Foundation Condition	Good	
575127	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
575128	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
575129	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
575130	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
575131	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
575132	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
575133	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Maintenance Operations	0	
575134	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
575135	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Operations Counter AF	226	
575136	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Operations Counter AL	226	
575137	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
575138	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Switching Operations	0	
575139	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	Follow-up Action Required?	n	
575140	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
575141	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	General Comments		
575142	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	General Comments		
575143	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC As Found Counter	249135	
575144	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
575145	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
575146	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
575147	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC As Left Counter	249142	
575148	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
575149	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Tank Paint Condition	Good	
575150	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Unknown Operations	0	
575151	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BCH000219	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
575152	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
575153	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
575154	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC Current Tap Position	5L	
575155	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC Max Tap Position	2L	
575156	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC Min Tap Position	10L	
575157	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
575158	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC Operations Since Last Insp	1373	
575159	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
575160	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
575161	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	Oil Temp Present	34	°C
575162	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	Oil Temp Max	65	°C
575163	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
575164	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
575165	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BCH000219	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
575166	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	LTC Totalizer Reading	4816.80	kw
575167	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
575168	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	General Comments		
575169	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BCH000219	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
575170	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	18	
575171	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
575172	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Accumulated Fault Duty A Ph V	1.10	%
575173	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	9 Month Operations	0	
575174	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Accumulated Fault Duty B Ph V	1.10	%
575175	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Accumulated Fault Duty C Ph V	1.10	%
575176	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Amps A Ø	210.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
575177	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Amps B Ø	210.0	
575178	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Amps C Ø	240.0	
575179	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
575180	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments		
575181	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
575182	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Trash Emptied?	n	
575183	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
575184	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
575185	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
575186	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Swept?	y	
575187	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
575188	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
575189	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
575190	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
575191	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
575192	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
575193	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
575194	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
575195	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
575196	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
575197	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
575198	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
575199	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
575200	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
575201	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
575202	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Bushing Condition	Good	
575203	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
575204	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
575205	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
575206	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
575207	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
575208	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
575209	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
575210	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
575211	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Foundation Condition	Good	
575212	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
575213	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
575214	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	General Comments	Cir 277 has 1 blown lightning arrester.	
575215	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
575216	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
575217	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
575218	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
575219	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
575220	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
575221	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
575222	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
575223	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	Totalizer Meter Reading	.6690	
575224	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
575225	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
575226	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	General Comments		
575227	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
575228	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
575229	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
575230	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
575231	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
575232	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
575233	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
575234	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
575235	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
575236	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
575237	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
575238	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
575239	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
575240	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
575241	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
575242	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
575243	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
575244	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
575245	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
575246	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
575247	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
575248	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
575249	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
575250	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
575251	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
575252	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Operations A Ø	0	
575253	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Operations B Ø	0	
575254	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Operations C Ø	0	
575255	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Operations Ground	0	
575256	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Follow-up Action Required?	n	
575257	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Follow-up Action Required?	n	
575258	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Foundation Condition	Good	
575259	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	General Comments		
575260	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	General Comments		
575261	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Grounds in Place?	y	
575262	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Maintenance Operations	0	
575263	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Moisture and Leak Free?	y	
575264	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Operations Counter AF	676	
575265	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Operations Counter AL	676	
575266	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
575267	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Switching Operations	0	
575268	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Tank Paint Condition	Good	
575269	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	Follow-up Action Required?	n	
575270	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
575271	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
575272	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	General Comments		
575273	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	General Comments		
575274	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
575275	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	LTC Totalizer Reading	6527.52	kw
575276	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	428	
575277	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
575278	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
575279	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
575280	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
575281	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
575282	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
575283	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
575284	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
575285	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
575286	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
575287	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Amps A Ø	18.1	
575288	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Amps B Ø	23.2	
575289	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Amps C Ø	38.6	
575290	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	809	
575291	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
575292	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
575293	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	601	
575294	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
575295	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
575296	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
575297	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	General Comments		
575298	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
575299	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
575300	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
575301	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
575302	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
575303	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
575304	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
575305	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
575306	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
575307	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
575308	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
575309	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
575310	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	150.0	
575311	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	150.0	
575312	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	150.0	
575313	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
575314	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
575315	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
575316	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
575317	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
575318	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BCH000219	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
575319	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BCH000219	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
575320	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	9 Month Operations	4	
575321	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Accumulated Fault Duty A Ph V	2.95	%
575322	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Accumulated Fault Duty B Ph V	1.97	%
575323	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Accumulated Fault Duty C Ph V	1.97	%
575324	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
575325	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	General Comments		
575326	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
575327	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
575328	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
575329	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
575330	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
575331	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
575332	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
575333	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	Follow-up Action Required?	n	
575334	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
575335	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
575336	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
575337	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
575338	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
575339	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
575340	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
575341	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Amps A Ø	20.0	
575342	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Amps B Ø	20.0	
575343	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Amps C Ø	30.0	
575344	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Bushing Condition	Good	
575345	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Bushings Connection/Risers	Good	
575346	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
575347	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
575348	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
575349	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Cabinet Paint Condition	Good	
575350	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Equipment Properly Labeled?	y	
575351	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	9 Month Operations	4	
575352	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Accumulated Fault Duty A Ph V	19.67	%
575353	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Accumulated Fault Duty B Ph V	26.55	%
575354	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Accumulated Fault Duty C Ph V	15.73	%
575355	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Amps A Ø	80.0	
575356	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Amps B Ø	130.0	
575357	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Amps C Ø	120.0	
575358	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Bushing Condition	Good	
575359	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Bushings Connection/Risers	Good	
575360	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
575361	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
575362	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
575363	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Cabinet Paint Condition	Good	
575364	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Equipment Properly Labeled?	y	
575365	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
575366	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	General Comments		
575367	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
575368	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
575369	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
575370	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
575371	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
575372	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
575373	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
575374	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
575375	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
575376	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Grounds in Place?	y	
575377	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
575378	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
575379	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	Oil Temp Max	42	°C
575380	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	Oil Temp Present	42	°C
575381	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Pumps Condition	Good	
575382	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Pumps Operational?	y	
575383	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
575384	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Radiator Leaks	None	
575385	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
575386	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
575387	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Tank Leaks	None	
575388	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
575389	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
575390	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
575391	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
575392	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	X1 Winding Temp Present	40	°C
575393	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	X2 Winding Temp Max	40	°C
575394	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	X2 Winding Temp Present	40	°C
575395	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	X3 Winding Temp Max	40	°C
575396	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	X3 Winding Temp Present	40	°C
575397	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
575398	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	General Comments		
575399	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	Reset Tap Drag Hands	Reset	
575400	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
575401	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
575402	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC Operations Since Last Insp	2652	
575403	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
575404	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC Min Tap Position	9L	
575405	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC Max Tap Position	5R	
575406	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Maintenance Operations	0	
575407	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Operations Counter AF	139	
575408	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Operations Counter AL	139	
575409	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Switching Operations	0	
575410	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Unknown Operations	0	
575411	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC Current Tap Position	9L	
575412	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
575413	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC As Left Counter	215727	
575414	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC As Found Counter	215727	
575415	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	General Comments	needs 2 desicant filters ontop of LTC	
575416	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	General Comments		
575417	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
575418	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	Follow-up Action Required?	n	
575419	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	36	°C
575420	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	53	°C
575421	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	36	°C
575422	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	53	°C
575423	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	19	°C
575424	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	32	°C
575425	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
575426	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
575427	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
575428	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
575429	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
575430	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
575431	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
575432	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
575433	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
575434	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	Oil Temp Present	34	°C
575435	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	Oil Temp Max	49	°C
575436	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
575437	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
575438	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
575439	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
575440	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	General Comments		
575441	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
575442	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
575443	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Vegetation	None	
575444	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
575445	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	9 Months Operations	0	
575446	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
575447	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
575448	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
575449	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
575450	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
575451	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
575452	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
575453	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
575454	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
575455	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
575456	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
575457	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
575458	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
575459	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
575460	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
575461	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
575462	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Patrol Inspection	General Comments		
575463	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	General Comments		
575464	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
575465	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Operations Counter AF	188	
575466	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Operations Counter AL	188	
575467	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Switching Operations	0	
575468	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Unknown Operations	0	
575469	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
575470	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
575471	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
575472	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
575473	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
575474	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
575475	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
575476	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
575477	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
575478	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
575479	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
575480	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	General Comments		
575481	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
575482	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
575483	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
575484	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
575485	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Bushing Condition	Good	
575486	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
575487	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
575488	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
575489	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
575490	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
575491	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
575492	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Regulator As Left Counter	1694	
575493	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
575494	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
575495	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Tank Leaks	None	
575496	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
575497	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
575498	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
575499	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
575500	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
575501	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
575502	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
575503	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Fans Condition	Good	
575504	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Fans Operational?	y	
575505	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
575506	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	Follow-up Action Required?	n	
575507	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Foundation Condition	Good	
575508	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
575509	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	General Comments		
575510	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	General Comments		
575511	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Bushing Condition	Good	
575512	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Bushings Connection/Risers	Good	
575513	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
575514	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
575515	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Follow-up Action Required?	n	
575516	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Operations Ground	0	
575517	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
575518	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Cabinet Paint Condition	Good	
575519	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Equipment Properly Labeled?	y	
575520	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
575521	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
575522	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
575523	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Operations A Ø	0	
575524	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Operations B Ø	0	
575525	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Operations C Ø	0	
575526	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Operations Ground	0	
575527	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Follow-up Action Required?	n	
575528	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Follow-up Action Required?	n	
575529	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Foundation Condition	Good	
575530	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	General Comments		
575531	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	General Comments		
575532	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Grounds in Place?	y	
575533	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Heaters (All) Functioning?	y	
575534	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Maintenance Operations	0	
575535	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Moisture and Leak Free?	y	
575536	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Operations Counter AF	181	
575537	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Operations Counter AL	181	
575538	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Operations C Ø	0	
575539	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Operations B Ø	0	
575540	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Operations A Ø	0	
575541	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
575542	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Switching Operations	0	
575543	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
575544	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
575545	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Tank Paint Condition	Good	
575546	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Unknown Operations	0	
575547	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
575548	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Amps C Ø	100.0	
575549	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Amps B Ø	100.0	
575550	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Amps A Ø	100.0	
575551	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Accumulated Fault Duty C Ph V	.8	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
575552	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Accumulated Fault Duty B Ph V	.8	%
575553	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	PF000244	PowerFuse	MC-STA SER A 440V	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
575554	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	PF000244	PowerFuse	MC-STA SER A 440V	Disconnect Powerfuse Inspection	General Comments	ok	
575555	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
575556	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	9 Month Operations	2	
575557	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	PF000245	PowerFuse	MC-STA SER NO 9	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
575558	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	PF000245	PowerFuse	MC-STA SER NO 9	Disconnect Powerfuse Inspection	General Comments	ok	
575559	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
575560	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
575561	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Broom on Site?	y	
575562	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
575563	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
575564	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
575565	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
575566	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Evidence of Insects	None	
575567	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
575568	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
575569	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	9 Month Operations	0	
575570	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Accumulated Fault Duty A Ph V	2.39	%
575571	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	250.0	
575572	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	250.0	
575573	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	280.0	
575574	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
575575	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
575576	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
575577	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
575578	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
575579	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
575580	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
575581	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
575582	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
575583	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
575584	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
575585	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
575586	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	PF000247	PowerFuse	MC-208/120 STA SER A	Disconnect Powerfuse Inspection	General Comments	ok	
575587	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	PF000247	PowerFuse	MC-208/120 STA SER A	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
575588	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
575589	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
575590	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
575591	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
575592	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
575593	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
575594	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
575595	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Unknown Operations	2	
575596	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Switching Operations	0	
575597	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Operations Counter AL	160	
575598	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Operations Counter AF	160	
575599	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Maintenance Operations	0	
575600	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	General Comments		
575601	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Follow-up Action Required?	n	
575602	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Operations Ground	0	
575603	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Operations C Ø	0	
575604	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Operations B Ø	0	
575605	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Operations A Ø	0	
575606	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Adjusted Amps C Phase V	0	
575607	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Adjusted Amps B Phase V	0	
575608	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Adjusted Amps A Phase V	0	
575609	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Amps C Ø	400.0	
575610	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Amps B Ø	390.0	
575611	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
575612	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
575613	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	102	
575614	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	102	
575615	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
575616	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
575617	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
575618	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
575619	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
575620	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
575621	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
575622	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
575623	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
575624	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
575625	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
575626	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
575627	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
575628	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Amps A Ø	400.0	
575629	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Accumulated Fault Duty C Ph V	7.17	%
575630	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Accumulated Fault Duty B Ph V	8.77	%
575631	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Accumulated Fault Duty A Ph V	7.97	%
575632	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	9 Month Operations	29	
575633	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Unknown Operations	0	
575634	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Switching Operations	0	
575635	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Operations Counter AL	162	
575636	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Operations Counter AF	162	
575637	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Maintenance Operations	0	
575638	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	General Comments		
575639	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	9 Month Operations	1	
575640	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Accumulated Fault Duty A Ph V	2.28	%
575641	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Accumulated Fault Duty B Ph V	1.83	%
575642	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Accumulated Fault Duty C Ph V	.46	%
575643	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Amps A Ø	65.0	
575644	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Amps B Ø	82.0	
575645	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Amps C Ø	44.0	
575646	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
575647	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Follow-up Action Required?	n	
575648	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
575649	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
575650	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
575651	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
575652	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
575653	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
575654	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
575655	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
575656	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
575657	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
575658	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
575659	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
575660	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
575661	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
575662	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
575663	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
575664	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	Totalizer Meter Reading	.8112	
575665	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
575666	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
575667	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	LTCC000184	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	45	Seconds
575668	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	LTCC000184	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
575669	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	LTCC000184	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
575670	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	LTCC000184	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
575671	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	LTCC000184	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
575672	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	LTCC000184	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
575673	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	LTCC000184	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
575674	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	LTCC000184	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
575675	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	PF000264	PowerFuse	OH-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
575676	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	PF000264	PowerFuse	OH-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
575677	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	9 Month Operations	1	
575678	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Accumulated Fault Duty A Ph V	19.93	%
575679	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Accumulated Fault Duty B Ph V	17.54	%
575680	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Accumulated Fault Duty C Ph V	11.16	%
575681	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Amps A Ø	148.0	
575682	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Amps B Ø	150.0	
575683	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Amps C Ø	145.0	
575684	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Patrol Inspection	Equipment Properly Labeled?	y	
575685	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
575686	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
575687	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
575688	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Operations A Ø	0	
575689	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Operations B Ø	0	
575690	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Operations C Ø	0	
575691	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Operations Ground	0	
575692	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Patrol Inspection	Follow-up Action Required?	n	
575693	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Follow-up Action Required?	n	
575694	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Patrol Inspection	General Comments		
575695	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	General Comments		
575696	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Maintenance Operations	0	
575697	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Operations Counter AF	166	
575698	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	PF000265	PowerFuse	OH-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
575699	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	PF000265	PowerFuse	OH-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
575700	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
575701	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
575702	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
575703	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
575704	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
575705	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
575706	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Clear of Trash?	y	
575707	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
575708	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
575709	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
575710	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
575711	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
575712	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	General Comments		
575713	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
575714	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
575715	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
575716	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
575717	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
575718	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
575719	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
575720	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
575721	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
575722	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
575723	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
575724	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
575725	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Clear of Trash?	y	
575726	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
575727	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
575728	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
575729	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
575730	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
575731	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
575732	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	General Comments		
575733	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
575734	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
575735	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
575736	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
575737	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Vegetation	None	
575738	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
575739	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
575740	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
575741	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
575742	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	Follow-up Action Required?	n	
575743	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
575744	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
575745	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
575746	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Winding Temp Present	28	°C
575747	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Winding Temp Max	32	°C
575748	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Totalizer Meter Reading	.5016	
575749	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
575750	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
575751	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
575752	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
575753	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
575754	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
575755	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
575756	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
575757	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
575758	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
575759	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
575760	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	General Comments		
575761	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Oil Temp Present	30	°C
575762	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Oil Temp Max	54	°C
575763	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
575764	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
575765	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	LTC Totalizer Reading	7223.04	kw
575766	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
575767	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	General Comments		
575768	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
575769	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	LTC Totalizer Reading	7787.52	kw
575770	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
575771	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
575772	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	Oil Temp Max	16	°C
575773	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	Oil Temp Present	16	°C
575774	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
575775	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
575776	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
575777	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
575778	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	General Comments		
575779	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	General Comments		
575780	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
575781	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
575782	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
575783	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
575784	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
575785	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
575786	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
575787	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	9 Month Operations	0	
575788	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Accumulated Fault Duty A Ph V	21.52	%
575789	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Accumulated Fault Duty B Ph V	23.12	%
575790	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Accumulated Fault Duty C Ph V	14.35	%
575791	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Amps A Ø	75.0	
575792	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Amps B Ø	100.0	
575793	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Amps C Ø	85.0	
575794	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Patrol Inspection	Equipment Properly Labeled?	y	
575795	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
575796	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
575797	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
575798	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Operations A Ø	0	
575799	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Operations B Ø	0	
575800	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Operations C Ø	0	
575801	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Operations Ground	0	
575802	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Patrol Inspection	Follow-up Action Required?	n	
575803	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Follow-up Action Required?	n	
575804	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Patrol Inspection	General Comments		
575805	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	General Comments		
575806	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Maintenance Operations	0	
575807	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Operations Counter AF	233	
575808	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Operations Counter AL	233	
575809	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Switching Operations	0	
575810	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Unknown Operations	0	
575811	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	9 Month Operations	0	
575812	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	1.93	%
575813	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	1.93	%
575814	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	1.93	%
575815	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Amps A Ø	824.0	
575816	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Amps B Ø	820.0	
575817	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Amps C Ø	798.0	
575818	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
575819	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
575820	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
575821	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
575822	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
575823	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
575824	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
575825	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	General Comments		
575826	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
575827	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
575828	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
575829	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
575830	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
575831	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Operations Ground	0	
575832	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
575833	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
575834	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Patrol Inspection	General Comments		
575835	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
575836	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
575837	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
575838	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Clear of Trash?	y	
575839	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
575840	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
575841	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
575842	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
575843	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
575844	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
575845	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	General Comments		
575846	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
575847	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
575848	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
575849	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Vegetation	None	
575850	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
575851	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
575852	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
575853	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
575854	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
575855	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
575856	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	General Comments		
575857	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	General Comments		
575858	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
575859	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
575860	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
575861	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1643.76	kw
575862	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	9 Month Operations	0	
575863	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
575864	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
575865	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
575866	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Amps A Ø	0.0	
575867	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Amps B Ø	0.0	
575868	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Amps C Ø	0.0	
575869	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
575870	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
575871	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
575872	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
575873	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Fault Operations A Ø	0	
575874	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Fault Operations B Ø	0	
575875	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Fault Operations C Ø	0	
575876	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Fault Operations Ground	0	
575877	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
575878	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Follow-up Action Required?	n	
575879	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Patrol Inspection	General Comments		
575880	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	General Comments	R&C	
575881	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Maintenance Operations	0	
575882	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Operations Counter AF	153	
575883	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Operations Counter AL	153	
575884	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Switching Operations	0	
575885	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Unknown Operations	0	
575886	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	96.00	
575887	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
575888	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Oil Temp Max	57	°C
575889	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Oil Temp Present	26	°C
575890	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
575891	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
575892	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
575893	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
575894	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
575895	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
575896	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
575897	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.3698	
575898	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Operations Counter AL	166	
575899	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Switching Operations	0	
575900	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Unknown Operations	0	
575901	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
575902	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
575903	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
575904	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
575905	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
575906	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
575907	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
575908	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
575909	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
575910	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
575911	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
575912	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
575913	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	General Comments		
575914	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
575915	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
575916	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
575917	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BCH000268	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
575918	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BCH000268	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
575919	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BCH000268	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
575920	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BCH000268	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
575921	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	BCH000268	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
575922	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
575923	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Mechanism Patrol Inspection	General Comments		
575924	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
575925	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
575926	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	9 Month Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
575927	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Accumulated Fault Duty A Ph V	3.99	%
575928	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Accumulated Fault Duty B Ph V	7.97	%
575929	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	9 Month Operations	10	
575930	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Accumulated Fault Duty A Ph V	4.78	%
575931	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Accumulated Fault Duty C Ph V	3.99	%
575932	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Amps A Ø	200.0	
575933	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Amps B Ø	200.0	
575934	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Amps C Ø	170.0	
575935	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Patrol Inspection	Equipment Properly Labeled?	y	
575936	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
575937	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
575938	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
575939	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Operations A Ø	0	
575940	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Operations B Ø	0	
575941	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Operations C Ø	0	
575942	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Operations Ground	0	
575943	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Patrol Inspection	Follow-up Action Required?	n	
575944	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Follow-up Action Required?	n	
575945	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Patrol Inspection	General Comments		
575946	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	General Comments		
575947	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
575948	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Tank Leaks	None	
575949	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
575950	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
575951	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Regulator As Left Counter	1659	
575952	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
575953	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
575954	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
575955	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
575956	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
575957	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
575958	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Max Tap Position	8R	
575959	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
575960	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	General Comments		
575961	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
575962	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
575963	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
575964	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
575965	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
575966	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
575967	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
575968	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
575969	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
575970	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
575971	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Accumulated Fault Duty B Ph V	7.17	%
575972	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Accumulated Fault Duty C Ph V	3.99	%
575973	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Amps A Ø	220.0	
575974	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Amps B Ø	225.0	
575975	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Amps C Ø	218.0	
575976	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Patrol Inspection	Equipment Properly Labeled?	y	
575977	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
575978	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
575979	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
575980	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Operations A Ø	0	
575981	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Operations B Ø	0	
575982	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
575983	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Panels Dusted?	y	
575984	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Panel Lights OK?	y	
575985	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
575986	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
575987	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	General Comments		
575988	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
575989	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Follow-up Action Required?	n	
575990	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
575991	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
575992	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Evidence of Insects	None	
575993	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
575994	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
575995	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
575996	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
575997	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
575998	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC Current Tap Position	2L	
575999	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC Max Tap Position	15R	
576000	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
576001	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
576002	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
576003	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
576004	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
576005	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
576006	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
576007	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
576008	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
576009	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	18	°C
576010	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
576011	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
576012	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
576013	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments	turned heater down	
576014	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
576015	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
576016	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	443	
576017	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
576018	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
576019	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
576020	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
576021	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
576022	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
576023	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
576024	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
576025	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
576026	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
576027	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
576028	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
576029	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
576030	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
576031	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
576032	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
576033	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
576034	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
576035	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	General Comments		
576036	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
576037	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
576038	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
576039	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Clear of Trash?	y	
576040	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
576041	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
576042	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
576043	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
576044	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
576045	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	General Comments		
576046	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
576047	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
576048	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Vegetation	None	
576049	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
576050	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
576051	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Unknown Operations	0	
576052	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Tank Paint Condition	Good	
576053	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Switching Operations	0	
576054	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
576055	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Operations Counter AL	287	
576056	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Operations Counter AF	287	
576057	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Moisture and Leak Free?	y	
576058	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Amps A Ø	38.0	
576059	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Accumulated Fault Duty C Ph V	.6	%
576060	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Accumulated Fault Duty B Ph V	1.19	%
576061	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Maintenance Operations	0	
576062	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Grounds in Place?	y	
576063	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	General Comments		
576064	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	General Comments		
576065	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Foundation Condition	Good	
576066	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Follow-up Action Required?	n	
576067	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Follow-up Action Required?	n	
576068	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Operations Ground	0	
576069	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Operations C Ø	0	
576070	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Operations B Ø	0	
576071	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Operations A Ø	0	
576072	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Accumulated Fault Duty A Ph V	.6	%
576073	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	9 Month Operations	4	
576074	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
576075	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
576076	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
576077	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Equipment Properly Labeled?	y	
576078	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Cabinet Paint Condition	Good	
576079	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
576080	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
576081	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
576082	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Bushings Connection/Risers	Good	
576083	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Bushing Condition	Good	
576084	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Amps C Ø	90.0	
576085	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Amps B Ø	160.0	
576086	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Amps A Ø	130.0	
576087	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Accumulated Fault Duty C Ph V	18.79	%
576088	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Accumulated Fault Duty B Ph V	22.54	%
576089	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Accumulated Fault Duty A Ph V	10.52	%
576090	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	9 Month Operations	6	
576091	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
576092	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	VRR Time Delay	45	Seconds
576093	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	PF000246	PowerFuse	MC-12KV TR 9 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
576094	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	PF000246	PowerFuse	MC-12KV TR 9 POT	Disconnect Powerfuse Inspection	General Comments	ok	
576095	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Unknown Operations	0	
576096	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Switching Operations	0	
576097	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Operations Counter AL	129	
576098	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Operations Counter AF	129	
576099	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Maintenance Operations	0	
576100	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	General Comments		
576101	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Follow-up Action Required?	n	
576102	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Operations Ground	0	
576103	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Operations C Ø	0	
576104	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Operations B Ø	0	
576105	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Operations A Ø	0	
576106	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
576107	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
576108	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
576109	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Amps C Ø	32.0	
576110	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Amps B Ø	31.0	
576111	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Amps A Ø	32.0	
576112	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Accumulated Fault Duty C Ph V	2.39	%
576113	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Accumulated Fault Duty B Ph V	1.79	%
576114	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Accumulated Fault Duty A Ph V	1.19	%
576115	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	9 Month Operations	3	
576116	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Operations C Ø	0	
576117	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Operations Ground	0	
576118	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Patrol Inspection	Follow-up Action Required?	n	
576119	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Follow-up Action Required?	n	
576120	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Patrol Inspection	General Comments		
576121	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	General Comments		
576122	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Maintenance Operations	0	
576123	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Operations Counter AF	187	
576124	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Operations Counter AL	187	
576125	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Switching Operations	0	
576126	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Maintenance Operations	0	
576127	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Operations Counter AF	164	
576128	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Operations Counter AL	164	
576129	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Switching Operations	0	
576130	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Unknown Operations	0	
576131	2/28/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
576132	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
576133	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	General Comments		
576134	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Unknown Operations	0	
576135	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC As Found Counter	25535	
576136	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC As Left Counter	25535	
576137	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC Current Tap Position	6L	
576138	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC Max Tap Position	4R	
576139	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC Min Tap Position	3L	
576140	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	1064	
576141	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
576142	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	All Connections OK?	y	
576143	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	Follow-up Action Required?	n	
576144	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	General Comments		
576145	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Unknown Operations	1	
576146	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Switching Operations	0	
576147	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Operations Counter AL	100	
576148	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Operations Counter AF	100	
576149	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Maintenance Operations	0	
576150	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	General Comments		
576151	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
576152	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Operations Ground	0	
576153	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Operations C Ø	0	
576154	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Operations B Ø	0	
576155	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Operations A Ø	0	
576156	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Adjusted Amps C Phase V	0	
576157	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Adjusted Amps B Phase V	0	
576158	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Adjusted Amps A Phase V	0	
576159	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Amps C Ø	93.0	
576160	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Amps B Ø	48.0	
576161	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Amps A Ø	75.0	
576162	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Accumulated Fault Duty C Ph V	.6	%
576163	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Accumulated Fault Duty B Ph V	.6	%
576164	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Accumulated Fault Duty A Ph V	.6	%
576165	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	9 Month Operations	1	
576166	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Unknown Operations	2	
576167	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Switching Operations	0	
576168	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Operations Counter AL	133	
576169	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Operations Counter AF	133	
576170	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Maintenance Operations	0	
576171	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	General Comments		
576172	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Follow-up Action Required?	n	
576173	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Operations Ground	0	
576174	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Operations C Ø	0	
576175	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Operations B Ø	0	
576176	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Operations A Ø	0	
576177	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Adjusted Amps C Phase V	0	
576178	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Adjusted Amps B Phase V	0	
576179	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Adjusted Amps A Phase V	0	
576180	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Amps C Ø	44.0	
576181	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Amps B Ø	46.0	
576182	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	LTC Operation Checked?	y	
576183	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Panels Dusted?	y	
576184	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
576185	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Operations C Ø	0	
576186	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Operations Ground	0	
576187	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Patrol Inspection	Follow-up Action Required?	n	
576188	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Follow-up Action Required?	n	
576189	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Patrol Inspection	General Comments		
576190	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	General Comments		
576191	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Maintenance Operations	0	
576192	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Operations Counter AF	153	
576193	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Operations Counter AL	153	
576194	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Switching Operations	0	
576195	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Unknown Operations	0	
576196	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
576197	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
576198	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
576199	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
576200	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
576201	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
576202	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
576203	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
576204	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
576205	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
576206	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
576207	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
576208	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
576209	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC As Left Counter	33459	
576210	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC As Found Counter	33459	
576211	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
576212	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
576213	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
576214	2/12/2019 13:56	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
576215	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LTCC000488	LTCControl	OH-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
576216	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
576217	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Tank Leaks	None	
576218	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
576219	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
576220	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Regulator As Left Counter	2361	
576221	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
576222	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
576223	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
576224	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
576225	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
576226	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Min Tap Position	5L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
576227	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Max Tap Position	8R	
576228	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
576229	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
576230	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
576231	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
576232	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
576233	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
576234	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	General Comments		
576235	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
576236	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
576237	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Trash Emptied?	y	
576238	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
576239	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
576240	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
576241	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
576242	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
576243	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
576244	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
576245	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
576246	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
576247	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
576248	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
576249	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
576250	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
576251	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	General Comments		
576252	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
576253	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
576254	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
576255	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Accumulated Fault Duty B Ph V	2.39	%
576256	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Accumulated Fault Duty C Ph V	3.19	%
576257	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
576258	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
576259	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Amps A Ø	218.0	
576260	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Amps B Ø	200.0	
576261	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Amps C Ø	185.0	
576262	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Patrol Inspection	Equipment Properly Labeled?	y	
576263	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
576264	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
576265	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
576266	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Floor Swept?	y	
576267	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Operations A Ø	0	
576268	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Operations B Ø	0	
576269	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
576270	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LTCC000488	LTCControl	OH-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
576271	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	LTCC000488	LTCControl	OH-TRANS 1	LTC Control Insp	General Comments		
576272	2/12/2019 14:14	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
576273	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
576274	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Vent Fans OK?	y	
576275	2/12/2019 10:09	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
576276	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
576277	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
576278	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	General Comments		
576279	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
576280	2/12/2019 10:43	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
576281	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
576282	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	General Comments		
576283	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	22.0	
576284	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	38.0	
576285	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	46.0	
576286	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
576287	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
576288	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
576289	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
576290	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
576291	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
576292	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
576293	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Operations Counter	168	
576294	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
576295	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
576296	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
576297	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
576298	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
576299	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
576300	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
576301	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
576302	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
576303	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
576304	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
576305	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
576306	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	9 Month Operations	4	
576307	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Accumulated Fault Duty A Ph V	2.80	%
576308	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Amps A Ø	300.0	
576309	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Amps B Ø	315.0	
576310	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Amps C Ø	357.0	
576311	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	22.6	
576312	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	20.9	
576313	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	18.6	
576314	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	192	
576315	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
576316	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
576317	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
576318	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
576319	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	General Comments	Trip Check	
576320	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
576321	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
576322	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Operations Counter	16	
576323	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
576324	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Foundation Condition	Good	
576325	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Tank Leaks	None	
576326	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Bushing Condition	Good	
576327	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
576328	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
576329	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
576330	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Accumulated Fault Duty B Ph V	5.14	%
576331	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Accumulated Fault Duty C Ph V	.47	%
576332	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Amps A Ø	70.0	
576333	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
576334	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	13	
576335	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	9 Month Operations	4	
576336	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	9 Month Operations	6	
576337	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Accumulated Fault Duty A Ph V	38.26	%
576338	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Accumulated Fault Duty A Ph V	1.99	%
576339	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Accumulated Fault Duty B Ph V	1.5	%
576340	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Accumulated Fault Duty C Ph V	1.5	%
576341	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Amps A Ø	6.0	
576342	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Amps B Ø	7.0	
576343	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Amps C Ø	3.0	
576344	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
576345	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Amps A Ø	120	
576346	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Amps B Ø	120	
576347	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Amps C Ø	150	
576348	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Bushing Condition	Good	
576349	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Bushings Connection/Risers	Good	
576350	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
576351	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
576352	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
576353	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Cabinet Paint Condition	Good	
576354	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Equipment Properly Labeled?	y	
576355	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
576356	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
576357	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
576358	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
576359	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
576360	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Operations A Ø	0	
576361	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
576362	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
576363	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
576364	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	277	
576365	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
576366	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
576367	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
576368	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Operations B Ø	0	
576369	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Operations C Ø	0	
576370	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Operations Ground	0	
576371	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Follow-up Action Required?	n	
576372	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Follow-up Action Required?	n	
576373	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	9 Month Operations	0	
576374	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	LTCC000054	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
576375	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	LTCC000054	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
576376	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
576377	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
576378	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
576379	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
576380	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
576381	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	144	
576382	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
576383	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
576384	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	201	
576385	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	LTCC000054	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
576386	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	LTCC000054	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
576387	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
576388	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Operations Counter AF	269	
576389	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Maintenance Operations	0	
576390	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	General Comments		
576391	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Patrol Inspection	General Comments		
576392	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Follow-up Action Required?	n	
576393	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Patrol Inspection	Follow-up Action Required?	n	
576394	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Fault Operations Ground	0	
576395	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	Follow-up Action Required?	n	
576396	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
576397	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	General Comments		
576398	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	General Comments		
576399	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC As Found Counter	8058	
576400	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC As Left Counter	8060	
576401	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC Current Tap Position	10L	
576402	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC Max Tap Position	11L	
576403	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
576404	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC Min Tap Position	3L	
576405	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
576406	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC Operations Since Last Insp	652	
576407	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
576408	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
576409	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
576410	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
576411	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCControl	545-1	LTC Control Insp	Follow-up Action Required?	n	
576412	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCControl	545-1	LTC Control Insp	All Connections OK?	y	
576413	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
576414	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
576415	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
576416	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
576417	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
576418	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
576419	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
576420	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
576421	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
576422	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
576423	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
576424	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
576425	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
576426	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
576427	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
576428	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Totalizer Meter Reading	.3610	
576429	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
576430	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
576431	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
576432	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
576433	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
576434	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
576435	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
576436	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
576437	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Oil Temp Present	21	°C
576438	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Oil Temp Max	30	°C
576439	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
576440	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
576441	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	LTC Totalizer Reading	866.40	kw
576442	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
576443	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	General Comments		
576444	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	General Comments		
576445	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
576446	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
576447	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Follow-up Action Required?	n	
576448	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
576449	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
576450	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
576451	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
576452	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
576453	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
576454	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	305130	
576455	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
576456	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
576457	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
576458	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
576459	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
576460	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
576461	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	4R	
576462	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
576463	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
576464	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
576465	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
576466	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
576467	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
576468	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
576469	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
576470	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
576471	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
576472	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
576473	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
576474	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	LTC Operation Checked?	y	
576475	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
576476	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
576477	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
576478	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	VRR Time Delay	60	Seconds
576479	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
576480	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Accumulated Fault Duty B Ph V	36.67	%
576481	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Accumulated Fault Duty C Ph V	24.71	%
576482	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Amps A Ø	105.0	
576483	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Amps B Ø	111.0	
576484	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Amps C Ø	111.0	
576485	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Patrol Inspection	Equipment Properly Labeled?	y	
576486	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
576487	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
576488	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
576489	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
576490	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
576491	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
576492	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
576493	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
576494	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
576495	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
576496	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
576497	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
576498	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
576499	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
576500	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
576501	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
576502	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Fault Operations A Ø	0	
576503	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Fault Operations B Ø	0	
576504	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Fault Operations C Ø	0	
576505	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCControl	545-1	LTC Control Insp	VRR Time Delay	30	Seconds
576506	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCControl	545-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
576507	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCControl	545-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
576508	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCControl	545-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
576509	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCControl	545-1	LTC Control Insp	LTC Operation Checked?	y	
576510	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCControl	545-1	LTC Control Insp	General Comments		
576511	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
576512	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Unknown Operations	0	
576513	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Switching Operations	0	
576514	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Operations Counter AL	269	
576515	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
576516	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
576517	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	General Comments		
576518	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
576519	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
576520	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
576521	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
576522	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
576523	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	LTC Totalizer Reading	7395.84	kw
576524	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
576525	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
576526	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	Oil Temp Max	45	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
576527	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	Oil Temp Present	35	°C
576528	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
576529	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
576530	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
576531	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
576532	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
576533	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
576534	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
576535	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
576536	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
576537	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
576538	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
576539	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
576540	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
576541	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
576542	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
576543	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
576544	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
576545	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
576546	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
576547	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
576548	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
576549	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC Operations Since Last Insp	450	
576550	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC Min Tap Position	8L	
576551	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC Max Tap Position	6L	
576552	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC Current Tap Position	6L	
576553	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
576554	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC As Left Counter	4200	
576555	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC As Found Counter	5200	
576556	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Mechanism Patrol Inspection	General Comments		
576557	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	General Comments		
576558	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
576559	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
576560	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
576561	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
576562	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
576563	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
576564	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
576565	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
576566	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
576567	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
576568	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Unknown Operations	0	
576569	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Switching Operations	0	
576570	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	Follow-up Action Required?	n	
576571	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	General Comments		
576572	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
576573	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Operations Counter AL	288	
576574	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Operations Counter AF	288	
576575	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
576576	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
576577	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
576578	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
576579	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
576580	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Maintenance Operations	0	
576581	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
576582	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	General Comments		
576583	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Patrol Inspection	General Comments		
576584	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Follow-up Action Required?	n	
576585	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
576586	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Operations Ground	0	
576587	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Operations C Ø	0	
576588	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Operations B Ø	0	
576589	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	180.0	
576590	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	180.0	
576591	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.93	%
576592	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	195.0	
576593	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
576594	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	General Comments		
576595	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
576596	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
576597	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Vegetation	None	
576598	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
576599	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
576600	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.46	%
576601	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
576602	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
576603	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Operations Counter AF	268	
576604	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Operations Counter AL	268	
576605	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
576606	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Switching Operations	0	
576607	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Tank Paint Condition	Good	
576608	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Unknown Operations	0	
576609	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
576610	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
576611	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
576612	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
576613	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
576614	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
576615	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
576616	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	General Comments	some top rail and post showing signs of rust as well as fabric	
576617	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
576618	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
576619	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Winding Temp Present	32	°C
576620	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Winding Temp Max	32	°C
576621	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Totalizer Meter Reading	1.0584	
576622	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
576623	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
576624	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
576625	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
576626	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
576627	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
576628	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
576629	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
576630	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
576631	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
576632	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
576633	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
576634	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
576635	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
576636	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Oil Temp Present	30	°C
576637	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Oil Temp Max	35	°C
576638	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
576639	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
576640	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	LTC Totalizer Reading	19051.20	kw
576641	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
576642	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	General Comments	bottle1575	
576643	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
576644	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
576645	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
576646	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
576647	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
576648	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
576649	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
576650	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
576651	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
576652	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
576653	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
576654	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
576655	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	General Comments		
576656	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	General Comments		
576657	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
576658	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
576659	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Follow-up Action Required?	n	
576660	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	Follow-up Action Required?	n	
576661	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
576662	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
576663	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
576664	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5L	
576665	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
576666	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	368	
576667	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
576668	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
576669	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
576670	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
576671	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	All Connections OK?	y	
576672	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	Follow-up Action Required?	n	
576673	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
576674	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
576675	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	Totalizer Meter Reading	.7704	
576676	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
576677	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Moisture and Leak Free?	y	
576678	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	General Comments		
576679	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Maintenance Operations	0	
576680	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Heaters (All) Functioning?	y	
576681	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Maintenance Operations	0	
576682	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Heaters (All) Functioning?	y	
576683	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Grounds in Place?	y	
576684	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	General Comments		
576685	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	General Comments		
576686	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Foundation Condition	Good	
576687	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Follow-up Action Required?	n	
576688	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Follow-up Action Required?	n	
576689	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Operations Ground	0	
576690	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Operations C Ø	0	
576691	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Operations B Ø	0	
576692	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Operations A Ø	0	
576693	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
576694	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
576695	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
576696	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Grounds in Place?	y	
576697	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Equipment Properly Labeled?	y	
576698	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Cabinet Paint Condition	Good	
576699	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
576700	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	LTCC000054	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
576701	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	LTCC000054	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
576702	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	LTCC000054	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
576703	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	LTCC000054	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
576704	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
576705	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
576706	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Bushings Connection/Risers	Good	
576707	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Bushing Condition	Good	
576708	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Amps C Ø	115.0	
576709	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Amps B Ø	85.0	
576710	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	13	
576711	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
576712	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
576713	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
576714	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
576715	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
576716	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
576717	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
576718	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
576719	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
576720	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
576721	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
576722	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
576723	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
576724	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
576725	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
576726	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
576727	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
576728	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
576729	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
576730	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
576731	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
576732	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
576733	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	61	
576734	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	61	
576735	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	General Comments		
576736	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	General Comments		
576737	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Operations A Ø	0	
576738	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
576739	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
576740	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
576741	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
576742	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Amps C Ø	50.0	
576743	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Amps B Ø	100.0	
576744	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Amps A Ø	50.0	
576745	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Accumulated Fault Duty C Ph AM	3.20	%
576746	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Accumulated Fault Duty B Ph AM	3.20	%
576747	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
576748	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	669	
576749	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
576750	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
576751	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
576752	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
576753	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC As Left Counter	83067	
576754	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC As Found Counter	83067	
576755	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
576756	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	General Comments		
576757	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
576758	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
576759	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Unknown Operations	0	
576760	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Tank Paint Condition	Good	
576761	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Switching Operations	0	
576762	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
576763	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Operations Counter AL	154	
576764	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Operations Counter AF	154	
576765	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
576766	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Maintenance Operations	0	
576767	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
576768	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Grounds in Place?	y	
576769	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	General Comments		
576770	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	General Comments		
576771	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Foundation Condition	Good	
576772	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Follow-up Action Required?	n	
576773	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Follow-up Action Required?	n	
576774	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Operations Ground	0	
576775	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Operations C Ø	0	
576776	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Operations B Ø	0	
576777	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
576778	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
576779	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
576780	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Clear of Trash?	y	
576781	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
576782	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
576783	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
576784	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Operations A Ø	0	
576785	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
576786	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
576787	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
576788	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
576789	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
576790	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
576791	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
576792	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	277	
576793	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
576794	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
576795	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
576796	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
576797	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
576798	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Unknown Operations	0	
576799	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Tank Paint Condition	Good	
576800	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Switching Operations	0	
576801	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
576802	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Operations Counter AL	161	
576803	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Operations Counter AF	161	
576804	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
576805	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Moisture and Leak Free?	y	
576806	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
576807	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Accumulated Fault Duty A Ph AM	3.20	%
576808	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC As Found Counter	129090	
576809	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC As Left Counter	129090	
576810	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
576811	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	9 Months Operations	6	
576812	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC Max Tap Position	8R	
576813	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC Min Tap Position	7L	
576814	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Maintenance Operations	0	
576815	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	General Comments		
576816	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Follow-up Action Required?	n	
576817	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Operations Ground	0	
576818	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Operations C Ø	0	
576819	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Operations B Ø	0	
576820	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Operations A Ø	0	
576821	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
576822	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
576823	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
576824	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Amps C Ø	285.0	
576825	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Amps B Ø	250.0	
576826	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Amps A Ø	250.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
576827	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC Operations Since Last Insp	1310	
576828	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
576829	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
576830	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
576831	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Accumulated Fault Duty C Ph V	11.16	%
576832	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Accumulated Fault Duty B Ph V	34.28	%
576833	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Accumulated Fault Duty A Ph V	18.33	%
576834	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	9 Month Operations	6	
576835	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
576836	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
576837	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Operations Counter	279	
576838	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	9 Month Operations	3	
576839	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Accumulated Fault Duty A Ph V	.47	%
576840	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
576841	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Accumulated Fault Duty C Ph V	.47	%
576842	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
576843	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Amps B Ø	199.0	
576844	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Amps C Ø	186.0	
576845	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Patrol Inspection	Equipment Properly Labeled?	y	
576846	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	General Comments		
576847	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
576848	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
576849	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
576850	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
576851	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
576852	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Amps C Ø	72.0	
576853	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Amps B Ø	78.0	
576854	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Amps A Ø	222.0	
576855	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Amps B Ø	250.0	
576856	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Amps C Ø	268.0	
576857	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Bushing Condition	Good	
576858	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Bushings Connection/Risers	Good	
576859	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
576860	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
576861	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
576862	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Cabinet Paint Condition	Good	
576863	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Equipment Properly Labeled?	y	
576864	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
576865	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
576866	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
576867	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Operations A Ø	0	
576868	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Operations B Ø	0	
576869	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Operations C Ø	0	
576870	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Operations Ground	0	
576871	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Follow-up Action Required?	n	
576872	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	General Comments		
576873	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
576874	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	191	
576875	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	191	
576876	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
576877	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	12	
576878	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
576879	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
576880	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Amps A Ø	98.0	
576881	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Amps B Ø	71.0	
576882	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Amps C Ø	83.0	
576883	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
576884	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
576885	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
576886	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
576887	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
576888	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
576889	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
576890	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
576891	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
576892	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
576893	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	General Comments		
576894	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
576895	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
576896	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Operations Counter	482	
576897	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
576898	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Tank Leaks	None	
576899	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
576900	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
576901	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
576902	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
576903	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
576904	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
576905	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
576906	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
576907	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
576908	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
576909	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
576910	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
576911	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
576912	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
576913	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
576914	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	24	
576915	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
576916	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
576917	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
576918	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	9 Month Operations	4	
576919	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Accumulated Fault Duty A Ph V	10.36	%
576920	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Accumulated Fault Duty B Ph V	18.33	%
576921	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Accumulated Fault Duty C Ph V	6.38	%
576922	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Amps A Ø	202.0	
576923	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Operations Counter AL	474	
576924	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Operations Counter AF	474	
576925	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	Follow-up Action Required?	n	
576926	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
576927	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	General Comments		
576928	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Mechanism Patrol Inspection	General Comments	LTC cabinet door and drain valve leaking.	
576929	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC As Found Counter	366448	
576930	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC As Left Counter	366456	
576931	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
576932	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC Current Tap Position	5R	
576933	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
576934	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
576935	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
576936	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
576937	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
576938	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.0522	
576939	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Unknown Operations	0	
576940	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Operations A Ø	0	
576941	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Operations B Ø	0	
576942	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Operations C Ø	0	
576943	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Operations Ground	0	
576944	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
576945	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Follow-up Action Required?	n	
576946	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Patrol Inspection	General Comments		
576947	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	General Comments		
576948	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
576949	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Maintenance Operations	0	
576950	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Operations Counter AF	99955	
576951	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Tank Paint Condition	Good	
576952	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Switching Operations	0	
576953	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
576954	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Operations Counter AL	313	
576955	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Operations Counter AF	313	
576956	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Moisture and Leak Free?	y	
576957	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Maintenance Operations	0	
576958	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Heaters (All) Functioning?	y	
576959	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Grounds in Place?	y	
576960	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	General Comments		
576961	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	General Comments		
576962	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
576963	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
576964	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
576965	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
576966	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
576967	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
576968	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
576969	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Foundation Condition	Good	
576970	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Follow-up Action Required?	n	
576971	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
576972	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
576973	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
576974	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
576975	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
576976	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
576977	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Operations Ground	0	
576978	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Operations C Ø	0	
576979	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Operations B Ø	0	
576980	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Operations A Ø	0	
576981	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
576982	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
576983	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
576984	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Equipment Properly Labeled?	y	
576985	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Cabinet Paint Condition	Good	
576986	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
576987	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
576988	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
576989	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
576990	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
576991	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
576992	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
576993	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Follow-up Action Required?	n	
576994	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Foundation Condition	Good	
576995	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	General Comments		
576996	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	General Comments		
576997	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Grounds in Place?	y	
576998	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Maintenance Operations	0	
576999	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Moisture and Leak Free?	y	
577000	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Operations Counter AF	193	
577001	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Operations Counter AL	193	
577002	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Switching Operations	0	
577003	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Tank Paint Condition	Good	
577004	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Unknown Operations	0	
577005	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Amps A Ø	61.0	
577006	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
577007	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
577008	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
577009	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Operations A Ø	0	
577010	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Operations B Ø	0	
577011	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Operations C Ø	0	
577012	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Operations Ground	0	
577013	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Patrol Inspection	Follow-up Action Required?	n	
577014	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Follow-up Action Required?	n	
577015	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Patrol Inspection	General Comments		
577016	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	General Comments		
577017	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Maintenance Operations	0	
577018	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Operations Counter AF	195	
577019	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Operations Counter AL	195	
577020	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Switching Operations	0	
577021	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Unknown Operations	1	
577022	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
577023	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
577024	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
577025	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	9 Months Operations	8	
577026	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
577027	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
577028	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
577029	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
577030	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
577031	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
577032	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Amps A Ø	50.0	
577033	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Amps B Ø	50.0	
577034	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Amps C Ø	50.0	
577035	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
577036	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
577037	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
577038	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
577039	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
577040	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
577041	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
577042	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
577043	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
577044	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
577045	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
577046	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
577047	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	31.32	kw
577048	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
577049	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
577050	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	30	°C
577051	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	20	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
577052	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
577053	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
577054	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Mechanism Patrol Inspection	General Comments		
577055	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Counter Readings	General Comments		
577056	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
577057	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Counter Readings	Follow-up Action Required?	n	
577058	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
577059	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
577060	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	323	
577061	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
577062	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Operations Ground	0	
577063	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
577064	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
577065	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
577066	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
577067	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	287	
577068	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
577069	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
577070	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	323	
577071	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	7.5	
577072	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Follow-up Action Required?	n	
577073	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	General Comments		
577074	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Maintenance Operations	0	
577075	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Operations Counter AF	640	
577076	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Operations Counter AL	640	
577077	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Switching Operations	0	
577078	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Unknown Operations	0	
577079	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	240	
577080	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	180	
577081	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	180	
577082	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
577083	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
577084	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
577085	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
577086	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
577087	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
577088	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
577089	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
577090	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
577091	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
577092	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
577093	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Evidence of Insects	None	
577094	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	4.3	
577095	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	5.2	
577096	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	181	
577097	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Unknown Operations	0	
577098	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Switching Operations	0	
577099	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
577100	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
577101	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
577102	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Floor Swept?	y	
577103	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
577104	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
577105	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	General Comments		
577106	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
577107	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
577108	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Panels Dusted?	y	
577109	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
577110	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
577111	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
577112	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
577113	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
577114	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
577115	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
577116	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
577117	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Clear of Trash?	y	
577118	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
577119	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
577120	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
577121	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
577122	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
577123	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
577124	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	General Comments		
577125	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
577126	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
577127	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Vegetation	None	
577128	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
577129	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
577130	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
577131	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
577132	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
577133	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
577134	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
577135	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Counter Readings	LTC Operations Since Last Insp	94	
577136	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
577137	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Counter Readings	LTC Min Tap Position	Neutral	
577138	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
577139	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
577140	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
577141	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Foundation Condition	Good	
577142	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
577143	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
577144	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Counter Readings	LTC Max Tap Position	4R	
577145	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Counter Readings	LTC Current Tap Position	2R	
577146	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
577147	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Counter Readings	LTC As Left Counter	100363	
577148	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Counter Readings	LTC As Found Counter	100363	
577149	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	General Comments		
577150	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
577151	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
577152	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
577153	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
577154	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
577155	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
577156	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
577157	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
577158	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
577159	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
577160	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
577161	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
577162	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	9 Month Operations	21	
577163	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Accumulated Fault Duty A Ph V	7.17	%
577164	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Accumulated Fault Duty B Ph V	11.16	%
577165	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Accumulated Fault Duty C Ph V	6.38	%
577166	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Amps A Ø	100.0	
577167	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Amps B Ø	100.0	
577168	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Amps C Ø	95.0	
577169	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
577170	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
577171	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
577172	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Operations A Ø	0	
577173	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Operations B Ø	0	
577174	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Operations C Ø	0	
577175	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
577176	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
577177	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
577178	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
577179	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
577180	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
577181	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
577182	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
577183	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
577184	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
577185	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
577186	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
577187	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
577188	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
577189	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
577190	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	7.23	%
577191	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	4.82	%
577192	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	6.02	%
577193	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
577194	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Foundation Condition	Good	
577195	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
577196	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	General Comments		
577197	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
577198	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
577199	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
577200	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
577201	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
577202	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
577203	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
577204	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
577205	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
577206	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
577207	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
577208	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
577209	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
577210	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
577211	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
577212	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
577213	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
577214	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
577215	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
577216	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
577217	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
577218	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	15	
577219	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	40.43	%
577220	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	40.43	%
577221	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	40.43	%
577222	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
577223	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
577224	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
577225	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
577226	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	324.00	
577227	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	324.00	
577228	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	324.00	
577229	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
577230	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
577231	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
577232	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
577233	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
577234	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
577235	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
577236	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
577237	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
577238	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
577239	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
577240	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
577241	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
577242	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
577243	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	General Comments		
577244	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
577245	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
577246	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
577247	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
577248	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
577249	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	98	
577250	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	98	
577251	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
577252	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
577253	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
577254	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
577255	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
577256	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
577257	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
577258	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
577259	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
577260	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
577261	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
577262	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
577263	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
577264	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	General Comments		
577265	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
577266	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
577267	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
577268	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
577269	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Clear of Trash?	y	
577270	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
577271	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
577272	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
577273	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
577274	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
577275	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
577276	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
577277	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
577278	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
577279	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
577280	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
577281	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
577282	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Vegetation	None	
577283	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
577284	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
577285	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
577286	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
577287	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
577288	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
577289	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
577290	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
577291	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1118	
577292	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1095	
577293	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	13	
577294	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Repaired operation counter	
577295	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
577296	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
577297	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Operations Counter AF	426	
577298	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Maintenance Operations	0	
577299	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	General Comments		
577300	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Patrol Inspection	General Comments		
577301	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
577302	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
577303	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Operations Ground	0	
577304	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
577305	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
577306	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
577307	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
577308	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
577309	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
577310	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
577311	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Amps C Ø	750.0	
577312	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Amps B Ø	750.0	
577313	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Amps A Ø	750.0	
577314	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
577315	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	1.73	%
577316	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
577317	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	9 Month Operations	35	
577318	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
577319	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
577320	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
577321	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
577322	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
577323	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
577324	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
577325	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
577326	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
577327	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
577328	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
577329	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
577330	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
577331	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
577332	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
577333	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
577334	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
577335	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	General Comments		
577336	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
577337	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
577338	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
577339	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
577340	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	5	
577341	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	91	
577342	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	91	
577343	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
577344	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
577345	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
577346	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
577347	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
577348	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
577349	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
577350	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
577351	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
577352	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
577353	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Unknown Operations	0	
577354	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Switching Operations	0	
577355	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Operations Counter AL	902	
577356	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Operations Counter AF	902	
577357	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	General Comments		
577358	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
577359	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
577360	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	251.00	
577361	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	245.00	
577362	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	Oil Temp Max	38	°C
577363	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
577364	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	General Comments		
577365	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
577366	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
577367	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
577368	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
577369	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
577370	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
577371	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
577372	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
577373	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
577374	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
577375	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
577376	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
577377	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
577378	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
577379	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	Oil Temp Present	28	°C
577380	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
577381	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
577382	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Adequate	
577383	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
577384	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
577385	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
577386	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
577387	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	225.00	
577388	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
577389	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	22	°C
577390	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	18	°C
577391	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
577392	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
577393	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
577394	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
577395	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
577396	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
577397	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
577398	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
577399	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
577400	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
577401	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
577402	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	General Comments		
577403	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
577404	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
577405	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
577406	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
577407	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
577408	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
577409	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
577410	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
577411	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
577412	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
577413	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
577414	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
577415	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Unknown Operations	0	
577416	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Switching Operations	0	
577417	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Operations Counter AL	426	
577418	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Operations Ground	0	
577419	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Follow-up Action Required?	n	
577420	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	General Comments		
577421	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Maintenance Operations	0	
577422	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Operations Counter AF	221	
577423	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Operations Counter AL	221	
577424	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Switching Operations	0	
577425	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Unknown Operations	0	
577426	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
577427	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
577428	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
577429	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
577430	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
577431	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	General Comments		
577432	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
577433	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
577434	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
577435	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
577436	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
577437	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
577438	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
577439	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
577440	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
577441	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
577442	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
577443	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
577444	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
577445	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
577446	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
577447	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
577448	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
577449	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
577450	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
577451	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
577452	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
577453	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
577454	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
577455	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	6R	
577456	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	8L	
577457	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
577458	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
577459	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
577460	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
577461	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
577462	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
577463	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
577464	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
577465	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
577466	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
577467	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
577468	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
577469	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	320919	
577470	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
577471	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
577472	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
577473	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
577474	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
577475	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
577476	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
577477	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
577478	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Maintenance Operations	0	
577479	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	General Comments		
577480	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Patrol Inspection	General Comments		
577481	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Follow-up Action Required?	n	
577482	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Patrol Inspection	Follow-up Action Required?	n	
577483	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
577484	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
577485	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
577486	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
577487	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
577488	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
577489	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
577490	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
577491	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
577492	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
577493	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
577494	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
577495	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
577496	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
577497	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
577498	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
577499	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
577500	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
577501	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
577502	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
577503	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
577504	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
577505	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Operations Ground	0	
577506	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Operations C Ø	0	
577507	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Operations B Ø	0	
577508	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Operations A Ø	0	
577509	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
577510	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
577511	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
577512	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
577513	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Amps C Ø	0.0	
577514	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Amps B Ø	0.0	
577515	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Amps A Ø	0.0	
577516	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
577517	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
577518	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
577519	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	9 Months Operations	0	
577520	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
577521	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
577522	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
577523	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
577524	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
577525	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
577526	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	9 Month Operations	0	
577527	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Accumulated Fault Duty A Ph V	3.99	%
577528	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Accumulated Fault Duty B Ph V	3.99	%
577529	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Accumulated Fault Duty C Ph V	2.39	%
577530	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Amps A Ø	82.0	
577531	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Amps B Ø	74.0	
577532	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Amps C Ø	73.0	
577533	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
577534	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
577535	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
577536	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Operations A Ø	0	
577537	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Operations B Ø	0	
577538	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Operations C Ø	0	
577539	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Accumulated Fault Duty B Ph V	1.40	%
577540	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Accumulated Fault Duty C Ph V	.47	%
577541	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Amps A Ø	174.0	
577542	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Amps B Ø	177.0	
577543	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Amps C Ø	195.0	
577544	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Bushing Condition	Good	
577545	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Bushings Connection/Risers	Good	
577546	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
577547	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
577548	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
577549	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Cabinet Paint Condition	Good	
577550	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Equipment Properly Labeled?	y	
577551	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
577552	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
577553	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
577554	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Operations A Ø	0	
577555	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Operations B Ø	0	
577556	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Operations C Ø	0	
577557	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Operations Ground	0	
577558	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Follow-up Action Required?	n	
577559	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Follow-up Action Required?	n	
577560	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Foundation Condition	Good	
577561	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	General Comments		
577562	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	General Comments		
577563	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Grounds in Place?	y	
577564	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Heaters (All) Functioning?	y	
577565	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Maintenance Operations	0	
577566	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Moisture and Leak Free?	y	
577567	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Operations Counter AF	231	
577568	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Operations Counter AL	231	
577569	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
577570	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Switching Operations	0	
577571	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Tank Paint Condition	Good	
577572	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Unknown Operations	0	
577573	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
577574	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
577575	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
577576	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
577577	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
577578	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
577579	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
577580	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
577581	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
577582	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
577583	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
577584	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
577585	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	General Comments		
577586	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
577587	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
577588	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Foundation Condition	Significant Damage	
577589	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
577590	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
577591	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
577592	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
577593	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
577594	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
577595	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
577596	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
577597	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
577598	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
577599	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
577600	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
577601	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Operations Counter AL	99955	
577602	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Switching Operations	0	
577603	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Unknown Operations	0	
577604	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
577605	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Bushings Connection/Risers	Good	
577606	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Bushing Condition	Good	
577607	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Amps C Ø	0.0	
577608	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Amps B Ø	0.0	
577609	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Amps A Ø	0.0	
577610	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Accumulated Fault Duty C Ph V	3.27	%
577611	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Accumulated Fault Duty B Ph V	1.87	%
577612	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Accumulated Fault Duty A Ph V	1.87	%
577613	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	9 Month Operations	4	
577614	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
577615	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
577616	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
577617	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	497747	
577618	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
577619	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
577620	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
577621	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
577622	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	3L	
577623	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	2R	
577624	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
577625	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
577626	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
577627	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
577628	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
577629	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
577630	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
577631	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
577632	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
577633	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
577634	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
577635	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
577636	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
577637	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
577638	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
577639	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
577640	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
577641	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
577642	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Foundation Condition	Good	
577643	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
577644	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
577645	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	General Comments		
577646	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
577647	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
577648	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
577649	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
577650	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
577651	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
577652	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
577653	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
577654	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
577655	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
577656	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
577657	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
577658	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	9 Month Operations	2	
577659	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Accumulated Fault Duty A Ph V	.93	%
577660	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	General Comments		
577661	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
577662	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
577663	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
577664	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	299	
577665	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
577666	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
577667	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	205	
577668	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Amps C Ø	8.1	
577669	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Amps B Ø	7.2	
577670	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Amps A Ø	6.3	
577671	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	333	
577672	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
577673	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
577674	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
577675	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Patrol Inspection	General Comments		
577676	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
577677	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
577678	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
577679	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
577680	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
577681	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
577682	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
577683	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
577684	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
577685	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	General Comments		
577686	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
577687	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
577688	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
577689	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
577690	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
577691	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
577692	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
577693	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
577694	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Regulator As Left Counter	24886	
577695	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
577696	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
577697	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
577698	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Tank Leaks	None	
577699	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
577700	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
577701	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
577702	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
577703	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
577704	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
577705	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
577706	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
577707	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
577708	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
577709	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
577710	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
577711	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
577712	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
577713	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
577714	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
577715	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
577716	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
577717	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
577718	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
577719	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
577720	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	General Comments		
577721	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
577722	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	9 Month Operations	4	
577723	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Accumulated Fault Duty A Ph V	2.99	%
577724	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
577725	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
577726	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
577727	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
577728	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
577729	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	General Comments		
577730	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
577731	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
577732	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
577733	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Accumulated Fault Duty B Ph V	2.49	%
577734	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Accumulated Fault Duty C Ph V	2.49	%
577735	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Amps A Ø	180	
577736	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Amps B Ø	200	
577737	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Amps C Ø	180	
577738	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Bushing Condition	Good	
577739	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Bushings Connection/Risers	Good	
577740	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
577741	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
577742	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
577743	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Cabinet Paint Condition	Good	
577744	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Equipment Properly Labeled?	y	
577745	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
577746	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
577747	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
577748	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Operations A Ø	0	
577749	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Operations B Ø	0	
577750	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Operations C Ø	0	
577751	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Operations Ground	0	
577752	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Follow-up Action Required?	n	
577753	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Follow-up Action Required?	n	
577754	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Foundation Condition	Good	
577755	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	General Comments		
577756	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	General Comments		
577757	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Grounds in Place?	y	
577758	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Heaters (All) Functioning?	y	
577759	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Maintenance Operations	0	
577760	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Moisture and Leak Free?	y	
577761	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Operations Counter AF	238	
577762	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Operations Counter AL	238	
577763	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
577764	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Switching Operations	0	
577765	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Tank Paint Condition	Good	
577766	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Unknown Operations	0	
577767	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
577768	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
577769	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
577770	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
577771	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
577772	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Regulator As Left Counter	246290	
577773	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
577774	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
577775	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Tank Leaks	None	
577776	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
577777	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
577778	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
577779	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
577780	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
577781	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
577782	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Moisture and Leak Free?	y	
577783	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Operations Counter AF	287	
577784	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Operations Counter AL	287	
577785	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
577786	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Switching Operations	0	
577787	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Tank Paint Condition	Good	
577788	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Unknown Operations	0	
577789	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	30	°C
577790	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	60	°C
577791	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
577792	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
577793	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
577794	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
577795	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
577796	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
577797	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
577798	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
577799	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
577800	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
577801	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
577802	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
577803	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
577804	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
577805	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
577806	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
577807	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
577808	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
577809	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
577810	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	12.0	
577811	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
577812	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	General Comments		
577813	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
577814	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
577815	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
577816	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
577817	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
577818	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
577819	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
577820	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
577821	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
577822	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
577823	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
577824	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
577825	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
577826	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
577827	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
577828	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
577829	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	added nitrogen	
577830	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
577831	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
577832	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
577833	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
577834	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
577835	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
577836	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
577837	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
577838	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
577839	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
577840	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
577841	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
577842	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
577843	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
577844	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
577845	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
577846	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
577847	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
577848	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
577849	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
577850	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
577851	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
577852	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
577853	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
577854	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
577855	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
577856	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
577857	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
577858	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
577859	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
577860	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments	control bad	
577861	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
577862	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	1L	
577863	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	1L	
577864	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
577865	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
577866	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	n	
577867	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
577868	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	510222	
577869	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
577870	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
577871	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
577872	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Patrol Inspection	General Comments		
577873	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Patrol Inspection	Follow-up Action Required?	n	
577874	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
577875	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	200	
577876	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	200	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
577877	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
577878	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
577879	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
577880	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
577881	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
577882	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
577883	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Operations A Ø	0	
577884	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Operations B Ø	0	
577885	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Operations C Ø	0	
577886	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Operations Ground	0	
577887	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Follow-up Action Required?	n	
577888	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Follow-up Action Required?	n	
577889	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Foundation Condition	Good	
577890	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	General Comments		
577891	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	General Comments		
577892	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Grounds in Place?	y	
577893	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Heaters (All) Functioning?	y	
577894	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Maintenance Operations	0	
577895	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	9 Month Operations	2	
577896	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Accumulated Fault Duty A Ph V	22.96	%
577897	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Accumulated Fault Duty B Ph V	19.37	%
577898	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Accumulated Fault Duty C Ph V	17.22	%
577899	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Amps A Ø	220.0	
577900	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Amps B Ø	240.0	
577901	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Amps C Ø	220.0	
577902	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Patrol Inspection	Equipment Properly Labeled?	y	
577903	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
577904	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
577905	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
577906	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Operations A Ø	0	
577907	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Operations B Ø	0	
577908	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Operations C Ø	0	
577909	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Operations Ground	0	
577910	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Patrol Inspection	Follow-up Action Required?	n	
577911	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Follow-up Action Required?	n	
577912	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Patrol Inspection	General Comments		
577913	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	General Comments		
577914	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Maintenance Operations	0	
577915	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Operations Counter AF	790	
577916	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Operations Counter AL	790	
577917	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Switching Operations	0	
577918	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Unknown Operations	1	
577919	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	LTCC000686	LTCControl	951-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
577920	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
577921	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
577922	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	126.0	volts
577923	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Regulator As Left Counter	337681	
577924	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	LTCC000686	LTCControl	951-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
577925	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	LTCC000686	LTCControl	951-Offline-Distribution	LTC Control Insp	General Comments		
577926	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	LTCC000686	LTCControl	951-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
577927	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	LTCC000686	LTCControl	951-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
577928	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	LTCC000686	LTCControl	951-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
577929	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	LTCC000686	LTCControl	951-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
577930	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	LTCC000686	LTCControl	951-Offline-Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
577931	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	14.0	
577932	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	17.0	
577933	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
577934	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
577935	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
577936	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
577937	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
577938	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
577939	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
577940	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	16	
577941	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
577942	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Tank Leaks	None	
577943	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
577944	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
577945	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
577946	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	9 Month Operations	3	
577947	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	17.33	%
577948	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	17.33	%
577949	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	17.33	%
577950	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Amps A Ø	553.0	
577951	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Amps B Ø	529.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
577952	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
577953	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
577954	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
577955	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	579.60	kw
577956	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	205.00	
577957	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
577958	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	18	°C
577959	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	18	°C
577960	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
577961	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
577962	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
577963	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
577964	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	9 Month Operations	0	
577965	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Accumulated Fault Duty A Ph V	7.89	%
577966	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Accumulated Fault Duty B Ph V	5.74	%
577967	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Accumulated Fault Duty C Ph V	5.02	%
577968	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Amps A Ø	200.0	
577969	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Amps B Ø	200.0	
577970	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Amps C Ø	220.0	
577971	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
577972	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
577973	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
577974	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
577975	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.4830	
577976	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Patrol Inspection	Equipment Properly Labeled?	y	
577977	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
577978	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
577979	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
577980	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Operations A Ø	0	
577981	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Operations B Ø	0	
577982	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Operations C Ø	0	
577983	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Operations Ground	0	
577984	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Patrol Inspection	Follow-up Action Required?	n	
577985	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Follow-up Action Required?	n	
577986	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Patrol Inspection	General Comments		
577987	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	General Comments		
577988	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Maintenance Operations	0	
577989	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Operations Counter AF	662	
577990	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Operations Counter AL	662	
577991	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Switching Operations	0	
577992	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Unknown Operations	0	
577993	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
577994	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
577995	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
577996	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
577997	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
577998	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
577999	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
578000	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
578001	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
578002	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
578003	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	General Comments		
578004	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
578005	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
578006	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
578007	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
578008	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
578009	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	9 Months Operations	11	
578010	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
578011	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
578012	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
578013	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Amps A Ø	50.0	
578014	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Amps B Ø	150.0	
578015	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Amps C Ø	100.0	
578016	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
578017	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
578018	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
578019	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
578020	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Operations A Ø	0	
578021	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Operations B Ø	0	
578022	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Operations C Ø	0	
578023	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Operations Ground	0	
578024	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
578025	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Follow-up Action Required?	n	
578026	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
578027	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	General Comments		
578028	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
578029	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Maintenance Operations	0	
578030	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Operations Counter AF	372	
578031	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Operations Counter AL	372	
578032	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Switching Operations	0	
578033	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Unknown Operations	0	
578034	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
578035	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Tank Leaks	None	
578036	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
578037	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
578038	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Regulator As Left Counter	291567	
578039	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
578040	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
578041	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
578042	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
578043	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
578044	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
578045	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
578046	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
578047	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	General Comments		
578048	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
578049	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
578050	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
578051	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
578052	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
578053	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
578054	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
578055	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
578056	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
578057	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Tank Leaks	None	
578058	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
578059	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
578060	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Regulator As Left Counter	102441	
578061	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
578062	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
578063	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
578064	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
578065	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Accumulated Fault Duty C Ph V	1.43	%
578066	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Amps A Ø	0.0	
578067	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Amps B Ø	0.0	
578068	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Amps C Ø	0.0	
578069	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Patrol Inspection	Equipment Properly Labeled?	y	
578070	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
578071	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
578072	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
578073	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Operations A Ø	0	
578074	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Operations B Ø	0	
578075	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Operations C Ø	0	
578076	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Operations Ground	0	
578077	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Patrol Inspection	Follow-up Action Required?	n	
578078	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Follow-up Action Required?	n	
578079	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Patrol Inspection	General Comments		
578080	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	General Comments		
578081	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Maintenance Operations	0	
578082	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Operations Counter AF	667	
578083	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Operations Counter AL	667	
578084	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Switching Operations	0	
578085	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Unknown Operations	2	
578086	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
578087	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
578088	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	General Comments		
578089	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
578090	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
578091	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
578092	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
578093	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
578094	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
578095	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
578096	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
578097	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
578098	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
578099	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
578100	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Tank Leaks	None	
578101	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
578102	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Regulator As Left Counter	1897	
578103	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
578104	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
578105	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
578106	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
578107	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
578108	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
578109	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
578110	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
578111	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	General Comments		
578112	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
578113	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
578114	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
578115	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
578116	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
578117	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
578118	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
578119	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
578120	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
578121	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
578122	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
578123	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC As Left Counter	32717	
578124	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC As Found Counter	32715	
578125	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	General Comments		
578126	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	General Comments		
578127	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
578128	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	Follow-up Action Required?	n	
578129	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	9 Month Operations	5	
578130	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
578131	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
578132	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
578133	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Amps A Ø	0.0	
578134	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Amps B Ø	0.0	
578135	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Amps C Ø	0.0	
578136	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Bushing Condition	Good	
578137	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Bushings Connection/Risers	Good	
578138	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
578139	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
578140	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
578141	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	5.0	
578142	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	5.0	
578143	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
578144	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
578145	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
578146	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
578147	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
578148	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
578149	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
578150	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
578151	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
578152	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
578153	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	2L	
578154	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
578155	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
578156	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
578157	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
578158	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
578159	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
578160	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	1R	
578161	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	5L	
578162	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
578163	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
578164	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
578165	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
578166	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	539670	
578167	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
578168	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
578169	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
578170	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
578171	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
578172	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
578173	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
578174	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
578175	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Cabinet Paint Condition	Good	
578176	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
578177	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
578178	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
578179	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
578180	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
578181	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
578182	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
578183	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	General Comments		
578184	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
578185	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
578186	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Unknown Operations	0	
578187	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Switching Operations	0	
578188	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Operations Counter AL	235	
578189	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
578190	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
578191	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
578192	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
578193	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
578194	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
578195	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
578196	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
578197	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
578198	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
578199	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Operations Counter AF	235	
578200	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Maintenance Operations	0	
578201	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	General Comments		
578202	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Patrol Inspection	General Comments		
578203	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Follow-up Action Required?	n	
578204	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Patrol Inspection	Follow-up Action Required?	n	
578205	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Operations Ground	0	
578206	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Operations C Ø	0	
578207	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Operations B Ø	0	
578208	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Operations A Ø	0	
578209	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
578210	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
578211	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
578212	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Patrol Inspection	Equipment Properly Labeled?	y	
578213	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Amps C Ø	149.0	
578214	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Amps B Ø	127.0	
578215	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Amps A Ø	200.0	
578216	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Accumulated Fault Duty C Ph V	31.89	%
578217	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Accumulated Fault Duty B Ph V	43.05	%
578218	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Accumulated Fault Duty A Ph V	35.87	%
578219	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	9 Month Operations	15	
578220	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
578221	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
578222	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
578223	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
578224	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
578225	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC Operations Since Last Insp	681	
578226	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
578227	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	20	°C
578228	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
578229	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	19.75	%
578230	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	14.63	%
578231	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	15.36	%
578232	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	5.0	
578233	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC Min Tap Position	9L	
578234	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC Max Tap Position	14L	
578235	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC Current Tap Position	12L	
578236	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	8L	
578237	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Unknown Operations	0	
578238	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Tank Paint Condition	Good	
578239	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Switching Operations	0	
578240	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Oil Temp Max	50	°C
578241	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
578242	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
578243	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	1270.80	kw
578244	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
578245	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
578246	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
578247	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
578248	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
578249	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
578250	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125	volts
578251	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	96934	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
578252	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
578253	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
578254	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
578255	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
578256	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	General Comments		
578257	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	General Comments		
578258	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
578259	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
578260	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
578261	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
578262	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
578263	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
578264	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
578265	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
578266	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
578267	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
578268	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
578269	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Operations Counter AL	184	
578270	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Operations Counter AF	184	
578271	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Moisture and Leak Free?	y	
578272	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Maintenance Operations	0	
578273	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Heaters (All) Functioning?	y	
578274	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Grounds in Place?	y	
578275	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	General Comments		
578276	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	General Comments		
578277	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Foundation Condition	Good	
578278	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Follow-up Action Required?	n	
578279	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Follow-up Action Required?	n	
578280	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Operations Ground	0	
578281	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Operations C Ø	0	
578282	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Operations B Ø	0	
578283	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Operations A Ø	0	
578284	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
578285	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
578286	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
578287	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Equipment Properly Labeled?	y	
578288	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Cabinet Paint Condition	Good	
578289	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
578290	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
578291	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
578292	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125	volts
578293	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	9562	
578294	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
578295	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
578296	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
578297	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
578298	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Equipment Properly Labeled?	y	
578299	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Cabinet Paint Condition	Good	
578300	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
578301	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
578302	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Unknown Operations	2	
578303	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Switching Operations	0	
578304	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Operations Counter AL	13	
578305	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Operations Counter AF	13	
578306	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Maintenance Operations	0	
578307	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	General Comments		
578308	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Patrol Inspection	General Comments		
578309	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Follow-up Action Required?	n	
578310	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Patrol Inspection	Follow-up Action Required?	n	
578311	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Operations Ground	0	
578312	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
578313	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Bushings Connection/Risers	Good	
578314	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Bushing Condition	Good	
578315	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Amps C Ø	200.0	
578316	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Amps B Ø	190.0	
578317	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Amps A Ø	170.0	
578318	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
578319	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
578320	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
578321	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	9 Month Operations	20	
578322	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Operations C Ø	0	
578323	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Operations B Ø	0	
578324	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Operations A Ø	0	
578325	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
578326	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Adjusted Amps B Phase V	22.36	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
578327	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
578328	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Patrol Inspection	Equipment Properly Labeled?	y	
578329	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Amps C Ø	140.0	
578330	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Amps B Ø	160.0	
578331	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Amps A Ø	140.0	
578332	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Accumulated Fault Duty C Ph V	8.61	%
578333	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Accumulated Fault Duty B Ph V	15.07	%
578334	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Accumulated Fault Duty A Ph V	16.50	%
578335	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	9 Month Operations	8	
578336	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
578337	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
578338	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
578339	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
578340	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
578341	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	2L	
578342	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
578343	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
578344	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
578345	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
578346	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
578347	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
578348	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	1R	
578349	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
578350	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	General Comments		
578351	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
578352	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
578353	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
578354	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
578355	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
578356	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
578357	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
578358	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
578359	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Regulator As Left Counter	177842	
578360	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
578361	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Tank Leaks	None	
578362	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
578363	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Unknown Operations	0	
578364	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Switching Operations	0	
578365	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Operations Counter AL	641	
578366	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Operations Counter AF	641	
578367	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Maintenance Operations	0	
578368	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	General Comments		
578369	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Follow-up Action Required?	n	
578370	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Operations Ground	0	
578371	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Operations C Ø	0	
578372	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Operations B Ø	0	
578373	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Operations A Ø	0	
578374	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
578375	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
578376	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
578377	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Amps C Ø	70.0	
578378	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Amps B Ø	58.0	
578379	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Amps A Ø	54.0	
578380	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Accumulated Fault Duty C Ph V	31.89	%
578381	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Accumulated Fault Duty B Ph V	15.94	%
578382	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Accumulated Fault Duty A Ph V	35.08	%
578383	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	9 Month Operations	4	
578384	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
578385	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
578386	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
578387	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
578388	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
578389	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
578390	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Foundation Condition	Good	
578391	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
578392	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
578393	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	General Comments		
578394	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
578395	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
578396	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
578397	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
578398	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
578399	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
578400	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
578401	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
578402	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
578403	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
578404	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
578405	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
578406	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Bushings Connection/Risers	Good	
578407	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Bushing Condition	Good	
578408	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Amps C Ø	99.0	
578409	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Amps B Ø	112.0	
578410	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Amps A Ø	114.0	
578411	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Accumulated Fault Duty C Ph V	6.29	%
578412	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Accumulated Fault Duty B Ph V	6.98	%
578413	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Accumulated Fault Duty A Ph V	7.34	%
578414	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	9 Month Operations	3	
578415	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
578416	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
578417	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
578418	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
578419	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
578420	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
578421	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
578422	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
578423	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
578424	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
578425	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
578426	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
578427	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
578428	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	General Comments		
578429	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
578430	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	9 Month Operations	3	
578431	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
578432	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
578433	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
578434	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Amps A Ø	692.0	
578435	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Amps B Ø	629.0	
578436	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Amps C Ø	613.0	
578437	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
578438	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
578439	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
578440	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
578441	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
578442	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
578443	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
578444	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Operations Ground	0	
578445	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
578446	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
578447	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Patrol Inspection	General Comments		
578448	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	General Comments		
578449	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Maintenance Operations	0	
578450	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Operations Counter AF	171	
578451	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Operations Counter AL	171	
578452	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Switching Operations	0	
578453	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Unknown Operations	0	
578454	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
578455	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
578456	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
578457	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
578458	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
578459	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
578460	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
578461	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
578462	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
578463	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Grounds in Place?	y	
578464	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	General Comments		
578465	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	General Comments		
578466	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Foundation Condition	Good	
578467	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Follow-up Action Required?	n	
578468	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Follow-up Action Required?	n	
578469	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Operations Ground	0	
578470	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Operations C Ø	0	
578471	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Operations B Ø	0	
578472	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Operations A Ø	0	
578473	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
578474	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
578475	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
578476	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
578477	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Cabinet Paint Condition	Good	
578478	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
578479	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
578480	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
578481	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Bushings Connection/Risers	Good	
578482	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Bushing Condition	Good	
578483	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	LTCC000384	LTCControl	020-5	LTC Control Insp	All Connections OK?	y	
578484	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Amps C Ø	425.0	
578485	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Amps B Ø	425.0	
578486	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Amps A Ø	410.0	
578487	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
578488	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
578489	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
578490	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	9 Month Operations	1	
578491	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
578492	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	LTCC000384	LTCControl	020-5	LTC Control Insp	Follow-up Action Required?	n	
578493	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	LTCC000384	LTCControl	020-5	LTC Control Insp	General Comments	Downloaded settings	
578494	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	LTCC000384	LTCControl	020-5	LTC Control Insp	LTC Operation Checked?	y	
578495	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	LTCC000384	LTCControl	020-5	LTC Control Insp	LTC Output Voltage Level	125	VAC
578496	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	LTCC000384	LTCControl	020-5	LTC Control Insp	VRR Base Voltage AF	125	VAC
578497	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	LTCC000384	LTCControl	020-5	LTC Control Insp	VRR Base Voltage AL	125	VAC
578498	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	LTCC000384	LTCControl	020-5	LTC Control Insp	VRR Time Delay	30	Seconds
578499	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	Follow-up Action Required?	n	
578500	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
578501	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	General Comments		
578502	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	General Comments		
578503	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC As Found Counter	97281	
578504	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC As Left Counter	97290	
578505	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
578506	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC Current Tap Position	9L	
578507	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC Max Tap Position	5L	
578508	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC Min Tap Position	15L	
578509	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC Operations Since Last Insp	660	
578510	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
578511	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
578512	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
578513	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
578514	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
578515	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
578516	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
578517	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
578518	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	4L	
578519	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
578520	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Amps C Ø	588.0	
578521	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
578522	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
578523	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
578524	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
578525	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
578526	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
578527	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
578528	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
578529	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
578530	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
578531	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
578532	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
578533	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
578534	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
578535	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	General Comments		
578536	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
578537	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
578538	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Min Tap Position	13L	
578539	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
578540	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
578541	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
578542	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
578543	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
578544	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Regulator As Left Counter	80643	
578545	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
578546	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Tank Leaks	None	
578547	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
578548	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
578549	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
578550	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Operations Ground	0	
578551	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
578552	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	General Comments		
578553	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Maintenance Operations	0	
578554	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Operations Counter AF	186	
578555	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Operations Counter AL	186	
578556	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Switching Operations	0	
578557	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Unknown Operations	0	
578558	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5820	
578559	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	900	
578560	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
578561	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
578562	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
578563	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
578564	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
578565	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
578566	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
578567	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
578568	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
578569	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
578570	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Unknown Operations	0	
578571	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Tank Paint Condition	Good	
578572	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Switching Operations	0	
578573	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Operations Counter AL	170	
578574	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Operations Counter AF	170	
578575	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Moisture and Leak Free?	y	
578576	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Maintenance Operations	0	
578577	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Accumulated Fault Duty A Ph V	2.44	%
578578	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	9 Month Operations	3	
578579	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
578580	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
578581	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
578582	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
578583	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
578584	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
578585	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
578586	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
578587	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Totalizer Meter Reading	1.0590	
578588	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
578589	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Bad	
578590	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
578591	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
578592	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Bad	
578593	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
578594	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
578595	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Oil Temp Present	27	°C
578596	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Unknown Operations	0	
578597	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Tank Paint Condition	Good	
578598	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
578599	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
578600	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
578601	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
578602	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
578603	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	3L	
578604	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
578605	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
578606	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
578607	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
578608	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
578609	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Switching Operations	19	
578610	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Operations Counter AL	183	
578611	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Operations Counter AF	183	
578612	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Moisture and Leak Free?	y	
578613	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Maintenance Operations	0	
578614	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Grounds in Place?	y	
578615	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	General Comments		
578616	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	General Comments		
578617	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Foundation Condition	Good	
578618	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Follow-up Action Required?	n	
578619	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Follow-up Action Required?	n	
578620	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Operations Ground	0	
578621	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Operations C Ø	0	
578622	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Operations B Ø	0	
578623	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Operations A Ø	0	
578624	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
578625	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
578626	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
578627	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
578628	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	1L	
578629	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
578630	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
578631	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
578632	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
578633	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
578634	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
578635	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
578636	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
578637	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
578638	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
578639	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	2L	
578640	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Unknown Operations	0	
578641	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Tank Paint Condition	Good	
578642	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Switching Operations	0	
578643	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Operations Counter AL	181	
578644	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Operations Counter AF	181	
578645	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Moisture and Leak Free?	y	
578646	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Maintenance Operations	0	
578647	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Heaters (All) Functioning?	y	
578648	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Grounds in Place?	y	
578649	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	General Comments		
578650	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	General Comments		
578651	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Foundation Condition	Good	
578652	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Follow-up Action Required?	n	
578653	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Follow-up Action Required?	n	
578654	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Operations Ground	0	
578655	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Operations C Ø	0	
578656	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Operations B Ø	0	
578657	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Operations A Ø	0	
578658	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
578659	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
578660	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
578661	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Equipment Properly Labeled?	y	
578662	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Cabinet Paint Condition	Good	
578663	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
578664	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
578665	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
578666	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
578667	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
578668	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
578669	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	852	
578670	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
578671	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
578672	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
578673	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	523.80	kw
578674	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
578675	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
578676	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
578677	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	General Comments		
578678	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	General Comments		
578679	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
578680	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
578681	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
578682	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
578683	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
578684	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Bushings Connection/Risers	Good	
578685	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Bushing Condition	Good	
578686	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Amps C Ø	116.0	
578687	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Amps B Ø	93.0	
578688	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Amps A Ø	108.0	
578689	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Accumulated Fault Duty C Ph V	3.14	%
578690	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Accumulated Fault Duty B Ph V	1.75	%
578691	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	7L	
578692	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
578693	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
578694	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
578695	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
578696	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
578697	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
578698	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
578699	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
578700	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
578701	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
578702	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
578703	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
578704	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
578705	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
578706	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
578707	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	General Comments		
578708	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
578709	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Max Tap Position	7L	
578710	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
578711	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
578712	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
578713	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
578714	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
578715	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
578716	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Regulator As Left Counter	120151	
578717	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
578718	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
578719	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Tank Leaks	None	
578720	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
578721	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
578722	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	2L	
578723	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	11L	
578724	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
578725	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
578726	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
578727	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
578728	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
578729	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	223849	
578730	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
578731	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
578732	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
578733	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
578734	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Unknown Operations	0	
578735	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Tank Paint Condition	Good	
578736	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Switching Operations	2	
578737	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
578738	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Operations Counter AL	251	
578739	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Operations Counter AF	251	
578740	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Moisture and Leak Free?	y	
578741	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Maintenance Operations	0	
578742	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Heaters (All) Functioning?	y	
578743	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Grounds in Place?	y	
578744	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	General Comments		
578745	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	General Comments		
578746	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Foundation Condition	Good	
578747	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
578748	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
578749	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
578750	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
578751	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
578752	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
578753	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
578754	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
578755	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Vegetation	None	
578756	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
578757	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	General Comments		
578758	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
578759	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
578760	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
578761	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
578762	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
578763	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
578764	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Clear of Trash?	y	
578765	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
578766	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
578767	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
578768	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
578769	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
578770	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
578771	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	312365	
578772	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
578773	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
578774	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
578775	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
578776	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
578777	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	8L	
578778	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	4R	
578779	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
578780	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
578781	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
578782	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
578783	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
578784	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
578785	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
578786	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
578787	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
578788	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
578789	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
578790	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
578791	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	LTCC000393	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
578792	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	LTCC000393	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	125	VAC
578793	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	LTCC000393	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	125	VAC
578794	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	LTCC000393	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	125	VAC
578795	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	LTCC000393	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
578796	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	LTCC000393	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments	Downloaded beckwith settings	
578797	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	LTCC000393	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
578798	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	LTCC000393	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
578799	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
578800	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
578801	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
578802	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
578803	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
578804	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0726	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
578805	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3264	
578806	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
578807	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
578808	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
578809	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
578810	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
578811	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
578812	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
578813	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
578814	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
578815	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
578816	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
578817	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	391.68	kw
578818	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
578819	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
578820	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
578821	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	General Comments	added nitrogen	
578822	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	General Comments		
578823	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
578824	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
578825	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
578826	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
578827	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
578828	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
578829	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
578830	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
578831	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
578832	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	CS000014	CircuitSwitcher	591-1 Trans-Rupter	Circuit Switcher Inspection	SF6 Indicator Zone	Caution	
578833	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	CS000014	CircuitSwitcher	591-1 Trans-Rupter	Circuit Switcher Inspection	Follow-up Action Required?	y	
578834	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	CS000014	CircuitSwitcher	591-1 Trans-Rupter	Circuit Switcher Inspection	Equipment Properly Labeled?	y	
578835	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	CS000014	CircuitSwitcher	591-1 Trans-Rupter	Circuit Switcher Inspection	Comments	C phase is in the caution area	
578836	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	CS000014	CircuitSwitcher	591-1 Trans-Rupter	Circuit Switcher Inspection	Ambient Temp	42	°F
578837	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
578838	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
578839	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
578840	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
578841	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
578842	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
578843	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
578844	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
578845	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
578846	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
578847	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
578848	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
578849	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
578850	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	General Comments	Needs N2 cylinder refilled, alarm isolated. Leaks under radiators	
578851	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
578852	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
578853	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.2	psi
578854	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
578855	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
578856	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
578857	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
578858	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
578859	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
578860	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
578861	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Follow-up Action Required?	n	
578862	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Follow-up Action Required?	n	
578863	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Operations Ground	0	
578864	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Operations C Ø	0	
578865	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Operations B Ø	0	
578866	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Operations A Ø	0	
578867	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
578868	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
578869	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
578870	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Equipment Properly Labeled?	y	
578871	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Cabinet Paint Condition	Good	
578872	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
578873	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	DX0024	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
578874	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	DX0024	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	1.2	
578875	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	DX0024	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
578876	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	DX0024	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
578877	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	DX0024	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
578878	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	DX0024	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
578879	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
578880	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
578881	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Bushings Connection/Risers	Good	
578882	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	DX0024	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
578883	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	DX0024	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
578884	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	DX0024	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
578885	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	DX0024	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
578886	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	DX0024	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	2	
578887	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	DX0024	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
578888	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	DX0024	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
578889	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Bushing Condition	Good	
578890	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Amps C Ø	50.0	
578891	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Amps B Ø	48.0	
578892	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Amps A Ø	52.0	
578893	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Accumulated Fault Duty C Ph V	2.34	%
578894	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Accumulated Fault Duty B Ph V	3.27	%
578895	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Accumulated Fault Duty A Ph V	2.34	%
578896	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	9 Month Operations	3	
578897	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0726	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
578898	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0726	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
578899	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0726	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
578900	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0726	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
578901	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0726	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
578902	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0726	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
578903	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0726	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
578904	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0726	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
578905	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0726	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	9L	
578906	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0726	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	6L	
578907	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0726	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
578908	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0726	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
578909	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0726	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
578910	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0726	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
578911	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0726	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
578912	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0726	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
578913	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0726	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	7L	
578914	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0726	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
578915	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0726	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
578916	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0726	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
578917	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	R0726	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
578918	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
578919	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
578920	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
578921	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
578922	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
578923	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Needs Replaced	check oil cup
578924	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
578925	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
578926	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
578927	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
578928	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
578929	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
578930	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
578931	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
578932	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
578933	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
578934	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
578935	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
578936	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
578937	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
578938	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
578939	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
578940	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	167	
578941	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	167	
578942	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
578943	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
578944	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
578945	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
578946	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
578947	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
578948	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
578949	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
578950	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
578951	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
578952	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
578953	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	General Comments	GAP UNDER FENCE BACK OF STATION....some top rail and barb wire rusty	
578954	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
578955	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
578956	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
578957	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
578958	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
578959	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
578960	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
578961	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
578962	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
578963	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
578964	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
578965	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
578966	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
578967	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
578968	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
578969	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
578970	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
578971	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
578972	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
578973	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
578974	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
578975	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
578976	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
578977	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC Operations Since Last Insp	412	
578978	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
578979	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC Min Tap Position	9L	
578980	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC Max Tap Position	4L	
578981	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC Current Tap Position	7L	
578982	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
578983	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC As Left Counter	81445	
578984	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC As Found Counter	81445	
578985	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	General Comments		
578986	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	General Comments		
578987	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
578988	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	Follow-up Action Required?	n	
578989	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LTCC000404	LTCControl	BY-TRANS 1	LTC Control Insp	General Comments	ok	
578990	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LTCC000404	LTCControl	BY-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
578991	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
578992	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	General Comments	Fence rusty	
578993	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
578994	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
578995	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
578996	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
578997	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
578998	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
578999	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
579000	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
579001	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
579002	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
579003	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
579004	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
579005	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
579006	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
579007	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	55	°C
579008	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
579009	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	54	°C
579010	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
579011	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	54	°C
579012	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
579013	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
579014	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
579015	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
579016	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
579017	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
579018	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
579019	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
579020	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
579021	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	Oil Temp Present	29	°C
579022	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	Oil Temp Max	47	°C
579023	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	850	psi
579024	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
579025	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
579026	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
579027	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Desiccant needs replaced	
579028	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	General Comments		
579029	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
579030	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
579031	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
579032	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Cabinet Paint Condition	Good	
579033	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
579034	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
579035	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
579036	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Bushings Connection/Risers	Good	
579037	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Bushing Condition	Good	
579038	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Amps C Ø	60.0	
579039	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Amps B Ø	55.0	
579040	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Amps A Ø	65.0	
579041	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Accumulated Fault Duty C Ph V	.47	%
579042	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Accumulated Fault Duty B Ph V	.47	%
579043	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Accumulated Fault Duty A Ph V	.93	%
579044	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	9 Month Operations	1	
579045	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
579046	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
579047	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
579048	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
579049	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
579050	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
579051	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
579052	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
579053	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
579054	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
579055	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
579056	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
579057	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
579058	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	General Comments	recloser bypass fuses ok...highside fuse is frayed	
579059	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
579060	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
579061	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Foundation Condition	Good	
579062	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
579063	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
579064	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
579065	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
579066	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
579067	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
579068	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
579069	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Vegetation	None	
579070	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Exp Boom Corrected	
579071	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	General Comments		
579072	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
579073	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
579074	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
579075	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
579076	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
579077	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Clear of Trash?	y	
579078	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
579079	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
579080	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
579081	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
579082	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	General Comments	Fence is starting to show signs of getting rusty....lock on enterance gate at road was gone, put on new one	
579083	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
579084	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
579085	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
579086	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
579087	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
579088	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
579089	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
579090	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120	
579091	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	80	
579092	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120	
579093	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Amps A Ø	18.0	
579094	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Amps B Ø	4.0	
579095	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Amps C Ø	17.0	
579096	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
579097	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
579098	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
579099	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
579100	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	5.69	%
579101	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	8.94	%
579102	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	8.94	%
579103	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
579104	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	All Connections OK?	y	
579105	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	Follow-up Action Required?	n	
579106	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	General Comments		
579107	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	LTC Operation Checked?	y	
579108	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
579109	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
579110	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
579111	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	VRR Time Delay	30	Seconds
579112	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Unknown Operations	0	
579113	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Tank Paint Condition	Good	
579114	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Switching Operations	0	
579115	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Operations Counter AL	203	
579116	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Operations Counter AF	203	
579117	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
579118	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
579119	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
579120	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
579121	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
579122	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
579123	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	General Comments		
579124	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
579125	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
579126	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Operations Counter	103	
579127	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
579128	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Tank Leaks	None	
579129	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
579130	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Moisture and Leak Free?	y	
579131	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Maintenance Operations	0	
579132	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Grounds in Place?	y	
579133	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	General Comments		
579134	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	General Comments		
579135	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Foundation Condition	Good	
579136	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Follow-up Action Required?	n	
579137	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Follow-up Action Required?	n	
579138	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Fault Operations Ground	0	
579139	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Fault Operations C Ø	0	
579140	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Fault Operations B Ø	0	
579141	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Fault Operations A Ø	0	
579142	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
579143	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
579144	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
579145	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Equipment Properly Labeled?	y	
579146	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
579147	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
579148	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
579149	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
579150	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
579151	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
579152	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
579153	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
579154	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
579155	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
579156	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
579157	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	20	°C
579158	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	20	°C
579159	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
579160	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
579161	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
579162	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
579163	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
579164	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
579165	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
579166	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
579167	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
579168	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
579169	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
579170	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
579171	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
579172	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
579173	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
579174	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
579175	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	VRR Time Delay	30	Seconds
579176	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
579177	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
579178	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
579179	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	LTC Operation Checked?	y	
579180	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	General Comments		
579181	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	Follow-up Action Required?	n	
579182	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	All Connections OK?	y	
579183	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
579184	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Steel Structures Rust Free?	y	
579185	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
579186	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Site Service Trans Condition	OK	
579187	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
579188	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
579189	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
579190	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Operating Linkage OK?	y	
579191	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
579192	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Linkage Grounds in Place?	y	
579193	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
579194	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
579195	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	General Comments		
579196	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
579197	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
579198	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Foundation Condition	Good	
579199	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
579200	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
579201	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
579202	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
579203	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
579204	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
579205	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
579206	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Wood Structures OK?	n	
579207	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
579208	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Vegetation	None	
579209	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Exp Boom Corrected	
579210	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	General Comments		
579211	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
579212	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
579213	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
579214	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
579215	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
579216	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
579217	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Clear of Trash?	y	
579218	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
579219	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
579220	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
579221	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
579222	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	General Comments	the back right corner of fence is a foot off ground ....left corner post of station is washing out	
579223	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
579224	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
579225	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
579226	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
579227	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
579228	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
579229	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
579230	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
579231	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
579232	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
579233	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
579234	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
579235	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
579236	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	35	
579237	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
579238	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
579239	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Operations Counter	164	
579240	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
579241	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	General Comments		
579242	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
579243	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
579244	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
579245	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
579246	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
579247	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
579248	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
579249	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
579250	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	411	
579251	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
579252	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
579253	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
579254	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	431	
579255	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
579256	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
579257	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	408	
579258	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
579259	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	General Comments		
579260	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
579261	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
579262	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	Follow-up Action Required?	n	
579263	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
579264	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
579265	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
579266	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
579267	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
579268	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
579269	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
579270	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
579271	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
579272	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
579273	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
579274	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
579275	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
579276	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
579277	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Clear of Trash?	y	
579278	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
579279	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	9 Month Operations	2	
579280	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
579281	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
579282	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
579283	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
579284	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	General Comments		
579285	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
579286	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Vegetation	None	
579287	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
579288	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
579289	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
579290	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	General Comments		
579291	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
579292	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC As Found Counter	267580	
579293	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC As Left Counter	267580	
579294	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
579295	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC Current Tap Position	7L	
579296	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC Max Tap Position	4L	
579297	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC Min Tap Position	9L	
579298	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
579299	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	338	
579300	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
579301	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
579302	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
579303	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
579304	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
579305	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Tank Leaks	None	
579306	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
579307	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Regulator As Left Counter	263724	
579308	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
579309	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
579310	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
579311	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
579312	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
579313	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
579314	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Accumulated Fault Duty A Ph V	1.43	%
579315	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Accumulated Fault Duty B Ph V	1.43	%
579316	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
579317	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
579318	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
579319	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	YD000118	Yard	Retired Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
579320	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	YD000118	Yard	Retired Distribution	Yard Patrol Inspection	Vegetation	None	
579321	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	YD000118	Yard	Retired Distribution	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
579322	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	YD000118	Yard	Retired Distribution	Yard Patrol Inspection	General Comments		
579323	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	YD000118	Yard	Retired Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
579324	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	YD000118	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
579325	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	YD000118	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
579326	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	YD000118	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
579327	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	YD000118	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
579328	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	YD000118	Yard	Retired Distribution	Yard Patrol Inspection	Clear of Trash?	y	
579329	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	YD000118	Yard	Retired Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
579330	2/11/2019 12:45	Distribution	Black Creek 2 Quarterly Inspection	YD000118	Yard	Retired Distribution	Yard Patrol Inspection	Ambient Temp	42	°F
579331	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Unknown Operations	0	
579332	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Switching Operations	0	
579333	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Operations Counter AL	131	
579334	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Operations Counter AF	131	
579335	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Maintenance Operations	0	
579336	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	General Comments	R&C	
579337	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Patrol Inspection	General Comments		
579338	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Follow-up Action Required?	n	
579339	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Patrol Inspection	Follow-up Action Required?	n	
579340	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Operations Ground	0	
579341	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Operations C Ø	0	
579342	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Operations B Ø	0	
579343	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Operations A Ø	0	
579344	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
579345	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
579346	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
579347	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Patrol Inspection	Equipment Properly Labeled?	y	
579348	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Amps C Ø	0.0	
579349	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Amps B Ø	0.0	
579350	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Amps A Ø	0.0	
579351	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
579352	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
579353	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
579354	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	9 Month Operations	0	
579355	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
579356	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
579357	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	Totalizer Meter Reading	.8964	
579358	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
579359	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
579360	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
579361	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
579362	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
579363	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
579364	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
579365	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
579366	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	Oil Temp Present	40	°C
579367	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	Oil Temp Max	45	°C
579368	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
579369	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
579370	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	LTC Totalizer Reading	8605.44	kw
579371	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
579372	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	General Comments		
579373	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
579374	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Tank Leaks	None	
579375	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
579376	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LTCC000521	LTCControl	BY-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
579377	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LTCC000521	LTCControl	BY-TRANS 2	LTC Control Insp	General Comments		
579378	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LTCC000521	LTCControl	BY-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
579379	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
579380	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
579381	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
579382	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
579383	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	403	
579384	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	28	°C
579385	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	14	°C
579386	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
579387	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
579388	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
579389	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
579390	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
579391	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
579392	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
579393	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
579394	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
579395	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
579396	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	General Comments		
579397	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
579398	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
579399	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
579400	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
579401	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
579402	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
579403	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
579404	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
579405	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1R	
579406	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
579407	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
579408	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC As Left Counter	33873	
579409	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC As Found Counter	33873	
579410	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	Desiccant needs replaced	
579411	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	General Comments		
579412	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
579413	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
579414	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
579415	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	6	
579416	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
579417	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
579418	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
579419	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Regulator As Left Counter	105742	
579420	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
579421	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
579422	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Tank Leaks	None	
579423	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
579424	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	45	
579425	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	45	
579426	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
579427	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
579428	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
579429	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
579430	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
579431	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
579432	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
579433	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
579434	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC Operations Since Last Insp	586	
579435	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
579436	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC Min Tap Position	9L	
579437	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC Max Tap Position	5L	
579438	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC Current Tap Position	6L	
579439	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
579440	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC As Left Counter	184900	
579441	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC As Found Counter	184900	
579442	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	General Comments		
579443	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	General Comments		
579444	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
579445	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	Follow-up Action Required?	n	
579446	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Amps A Ø	130.0	
579447	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Amps B Ø	140.0	
579448	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Amps C Ø	140.0	
579449	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
579450	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
579451	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
579452	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
579453	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
579454	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
579455	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
579456	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
579457	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
579458	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
579459	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	General Comments		
579460	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
579461	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
579462	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Operations Counter	4	
579463	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
579464	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Tank Leaks	None	
579465	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
579466	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
579467	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
579468	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
579469	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
579470	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
579471	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Current Tap Position	2R	
579472	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
579473	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
579474	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
579475	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
579476	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	General Comments		
579477	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
579478	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
579479	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
579480	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
579481	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
579482	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
579483	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
579484	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
579485	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Regulator As Left Counter	121984	
579486	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
579487	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
579488	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
579489	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
579490	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
579491	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
579492	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
579493	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
579494	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99	
579495	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99	
579496	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
579497	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
579498	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Ambient Temp	42	°F
579499	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
579500	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Clear of Trash?	y	
579501	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Bad	
579502	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
579503	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
579504	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
579505	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
579506	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	General Comments	Standing water in station . Last few times weve been here there has been significant standing water in the sub.	
579507	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
579508	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Vegetation	None	
579509	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
579510	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
579511	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
579512	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
579513	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
579514	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
579515	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
579516	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
579517	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	General Comments	Crossarm rotten and 2 pole rotten at the bottom	
579518	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
579519	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
579520	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
579521	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
579522	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
579523	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
579524	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
579525	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
579526	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
579527	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
579528	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
579529	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
579530	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
579531	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
579532	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
579533	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
579534	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	General Comments		
579535	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
579536	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
579537	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
579538	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
579539	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
579540	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
579541	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
579542	2/11/2019 11:41	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
579543	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
579544	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	replace guy wire	
579545	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
579546	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
579547	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
579548	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
579549	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
579550	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
579551	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
579552	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
579553	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
579554	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
579555	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
579556	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
579557	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
579558	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
579559	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
579560	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
579561	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
579562	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
579563	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
579564	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
579565	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
579566	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	21.11	%
579567	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	18.10	%
579568	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	20.11	%
579569	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
579570	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
579571	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
579572	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
579573	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
579574	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
579575	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
579576	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
579577	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
579578	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
579579	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
579580	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
579581	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
579582	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
579583	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	General Comments		
579584	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
579585	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
579586	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
579587	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
579588	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
579589	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
579590	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
579591	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
579592	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	530.0	
579593	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	578.0	
579594	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	615.0	
579595	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
579596	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
579597	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
579598	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
579599	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
579600	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
579601	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Trash Emptied?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
579602	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
579603	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
579604	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
579605	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
579606	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
579607	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
579608	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
579609	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
579610	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
579611	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
579612	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
579613	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
579614	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	47	
579615	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Follow-up Action Required?	n	
579616	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
579617	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
579618	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	General Comments		
579619	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	General Comments		
579620	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
579621	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	LTC Totalizer Reading	4639.68	kw
579622	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
579623	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
579624	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Oil Temp Max	55	°C
579625	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Oil Temp Present	30	°C
579626	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
579627	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
579628	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
579629	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
579630	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
579631	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
579632	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
579633	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Operations Counter AF	148	
579634	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Patrol Inspection	General Comments		
579635	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	General Comments		
579636	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
579637	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Maintenance Operations	0	
579638	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Maintenance Operations	0	
579639	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	General Comments		
579640	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Patrol Inspection	General Comments		
579641	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Follow-up Action Required?	n	
579642	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Operations Counter AF	723	
579643	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Operations Counter AL	723	
579644	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Patrol Inspection	Follow-up Action Required?	n	
579645	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Operations Ground	0	
579646	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Operations C Ø	0	
579647	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Operations B Ø	0	
579648	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Operations A Ø	0	
579649	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
579650	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Totalizer Meter Reading	.3222	
579651	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
579652	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
579653	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
579654	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
579655	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC Max Tap Position	4R	
579656	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC Min Tap Position	11L	
579657	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC Operations Since Last Insp	608	
579658	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
579659	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
579660	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
579661	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Unknown Operations	1	
579662	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
579663	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	General Comments		
579664	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
579665	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
579666	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	9 Months Operations	11	
579667	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BAT000581	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
579668	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
579669	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Amps A Ø	250.0	
579670	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Amps B Ø	250.0	
579671	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Amps C Ø	350.0	
579672	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
579673	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
579674	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
579675	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
579676	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
579677	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
579678	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
579679	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
579680	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
579681	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
579682	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
579683	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
579684	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
579685	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
579686	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
579687	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
579688	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BCH000584	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
579689	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BCH000584	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
579690	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BCH000584	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
579691	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BCH000584	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
579692	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BCH000584	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
579693	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BCH000584	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
579694	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
579695	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
579696	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
579697	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
579698	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Regulator As Left Counter	166610	
579699	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
579700	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BCH000575	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
579701	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BCH000575	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
579702	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BCH000575	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
579703	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BCH000575	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
579704	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BCH000575	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
579705	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BCH000575	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
579706	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
579707	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
579708	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
579709	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
579710	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
579711	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
579712	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
579713	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Tank Leaks	None	
579714	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
579715	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
579716	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
579717	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	CAP000007	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
579718	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	5.65	%
579719	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	340.0	
579720	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	340.0	
579721	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	CAP000007	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments		
579722	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	CAP000007	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
579723	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	CAP000007	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
579724	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
579725	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
579726	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
579727	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
579728	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
579729	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	ANN000013	Annunciator	BY-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
579730	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	ANN000013	Annunciator	BY-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
579731	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
579732	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
579733	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
579734	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
579735	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	44	°F
579736	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
579737	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	CAP000007	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
579738	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	CAP000007	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Good	
579739	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
579740	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
579741	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
579742	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	6.02	%
579743	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
579744	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
579745	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
579746	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
579747	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
579748	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
579749	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
579750	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
579751	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
579752	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
579753	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
579754	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
579755	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
579756	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
579757	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
579758	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
579759	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Patrol Inspection	General Comments		
579760	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
579761	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
579762	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
579763	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
579764	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
579765	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
579766	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
579767	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
579768	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
579769	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Ambient Temp	42	°F
579770	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
579771	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
579772	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
579773	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
579774	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
579775	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
579776	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
579777	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	.	
579778	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
579779	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
579780	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.000	millivolts
579781	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
579782	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
579783	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
579784	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
579785	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
579786	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
579787	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
579788	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
579789	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BAT000581	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
579790	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BAT000581	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
579791	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Accumulated Fault Duty C Ph V	8.77	%
579792	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Accumulated Fault Duty B Ph V	8.77	%
579793	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Accumulated Fault Duty A Ph V	8.77	%
579794	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	9 Month Operations	2	
579795	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
579796	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
579797	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
579798	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	Oil Temp Max	47	°C
579799	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	Oil Temp Present	23	°C
579800	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
579801	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
579802	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
579803	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
579804	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
579805	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
579806	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	BCH000572	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
579807	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	BCH000572	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
579808	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	BCH000572	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.9	amps
579809	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	BCH000572	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
579810	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	BCH000572	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
579811	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	BCH000572	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
579812	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
579813	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
579814	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
579815	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
579816	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Amps A Ø	320.0	
579817	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Amps B Ø	320.0	
579818	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
579819	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	4	
579820	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	45	
579821	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	9 Months Operations	0	
579822	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
579823	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
579824	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
579825	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Amps A Ø	380.0	
579826	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
579827	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BAT000581	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
579828	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BAT000581	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
579829	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
579830	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
579831	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
579832	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
579833	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	71.00	
579834	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	3081.6	kw
579835	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	100.00	
579836	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
579837	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
579838	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
579839	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	General Comments		
579840	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	General Comments		
579841	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
579842	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
579843	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
579844	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	PF000420	PowerFuse	WT-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
579845	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	PF000420	PowerFuse	WT-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
579846	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
579847	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	General Comments		
579848	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
579849	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	40	°C
579850	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	35	°C
579851	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LTCC000342	LTCControl	WT-TRANS 5	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
579852	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LTCC000342	LTCControl	WT-TRANS 5	LTC Control Insp	General Comments		
579853	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LTCC000342	LTCControl	WT-TRANS 5	LTC Control Insp	Follow-up Action Required?	n	
579854	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LTCC000341	LTCControl	WT-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
579855	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LTCC000341	LTCControl	WT-TRANS 4	LTC Control Insp	General Comments		
579856	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LTCC000341	LTCControl	WT-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
579857	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
579858	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Follow-up Action Required?	n	
579859	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
579860	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
579861	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
579862	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Patrol Inspection	Follow-up Action Required?	n	
579863	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
579864	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
579865	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
579866	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
579867	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
579868	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
579869	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
579870	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
579871	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	47	
579872	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
579873	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.5	amps
579874	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	135.0	VDC
579875	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	135.0	VDC
579876	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Totalizer Meter Reading	.3066	
579877	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
579878	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
579879	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
579880	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
579881	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
579882	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
579883	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
579884	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
579885	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
579886	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
579887	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Vegetation	None	
579888	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
579889	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
579890	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
579891	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
579892	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
579893	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	°C
579894	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	General Comments		
579895	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
579896	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
579897	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
579898	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Clear of Trash?	y	
579899	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	50	°C
579900	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
579901	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	43	°F

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
579902	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
579903	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
579904	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Broom on Site?	y	
579905	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
579906	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
579907	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Panels Dusted?	y	
579908	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Switching Operations	0	
579909	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Accumulated Fault Duty A Ph V	50.22	%
579910	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Accumulated Fault Duty B Ph V	50.94	%
579911	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Accumulated Fault Duty C Ph V	43.76	%
579912	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
579913	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
579914	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
579915	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
579916	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
579917	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
579918	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
579919	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
579920	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
579921	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
579922	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
579923	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
579924	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
579925	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	General Comments		
579926	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
579927	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
579928	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
579929	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
579930	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	250.0	
579931	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	29	
579932	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
579933	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
579934	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
579935	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
579936	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
579937	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	VRR Time Delay	30	Seconds
579938	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
579939	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
579940	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
579941	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
579942	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
579943	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
579944	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
579945	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
579946	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
579947	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	LTC Operation Checked?	y	
579948	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Top Oil Temperature Max	60	°C
579949	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
579950	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	43	°F
579951	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
579952	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
579953	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
579954	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
579955	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
579956	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Foundation Condition	Good	
579957	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
579958	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
579959	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	General Comments		
579960	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	Follow-up Action Required?	n	
579961	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
579962	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
579963	2/11/2019 13:16	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	All Connections OK?	y	
579964	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	15.4	%
579965	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	15.4	%
579966	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	15.4	%
579967	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	General Comments		
579968	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC As Found Counter	81015	
579969	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	260.0	
579970	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC As Left Counter	81018	
579971	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
579972	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
579973	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
579974	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
579975	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
579976	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
579977	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
579978	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Oil Temp Present	20	°C
579979	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Oil Temp Max	20	°C
579980	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
579981	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
579982	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
579983	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BAT000581	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
579984	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BAT000581	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
579985	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BAT000581	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
579986	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BAT000581	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
579987	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BAT000581	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
579988	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BAT000581	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
579989	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BAT000581	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
579990	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	PF000418	PowerFuse	WT-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
579991	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	PF000418	PowerFuse	WT-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
579992	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	LTC Totalizer Reading	11646.72	kw
579993	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	9 Month Operations	3	
579994	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
579995	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
579996	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Totalizer Meter Reading	.963	
579997	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
579998	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Top Oil Temperature Present	40	°C
579999	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
580000	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	Oil Temp Max	44	°C
580001	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
580002	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
580003	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
580004	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
580005	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	Oil Temp Present	20	°C
580006	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Operations Counter AL	148	
580007	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
580008	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BAT000581	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
580009	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BAT000581	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
580010	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
580011	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
580012	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
580013	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
580014	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
580015	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
580016	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
580017	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
580018	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Evidence of Insects	None	
580019	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
580020	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
580021	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
580022	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
580023	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
580024	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
580025	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
580026	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	General Comments		
580027	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	General Comments		
580028	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
580029	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
580030	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Follow-up Action Required?	n	
580031	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
580032	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
580033	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	BAT000581	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
580034	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Floor Swept?	y	
580035	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
580036	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
580037	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
580038	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Totalizer Meter Reading	.8088	
580039	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Winding Temp Max	20	°C
580040	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Winding Temp Present	20	°C
580041	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
580042	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
580043	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	General Comments		
580044	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
580045	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
580046	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
580047	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	General Comments		
580048	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
580049	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
580050	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
580051	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
580052	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
580053	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
580054	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	General Comments		
580055	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
580056	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
580057	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
580058	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
580059	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
580060	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
580061	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
580062	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
580063	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
580064	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
580065	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
580066	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
580067	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	ANN000013	Annunciator	BY-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
580068	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	ANN000013	Annunciator	BY-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
580069	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	ANN000013	Annunciator	BY-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
580070	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
580071	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
580072	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
580073	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
580074	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
580075	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
580076	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
580077	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC Current Tap Position	5L	
580078	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	BAT000094	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
580079	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	BAT000094	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
580080	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	BAT000094	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
580081	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	BAT000094	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
580082	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	BAT000094	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
580083	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
580084	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	BAT000094	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
580085	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	BAT000094	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
580086	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	BAT000094	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
580087	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	BAT000094	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
580088	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	BAT000094	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
580089	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	BAT000094	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
580090	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	BAT000094	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
580091	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	BAT000094	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
580092	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
580093	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
580094	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
580095	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	Follow-up Action Required?	n	
580096	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
580097	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
580098	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
580099	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
580100	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
580101	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
580102	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
580103	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
580104	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
580105	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
580106	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	General Comments	.	
580107	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
580108	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
580109	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
580110	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	361	
580111	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	361	
580112	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	2	
580113	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
580114	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	CAP000007	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
580115	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	CAP000007	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
580116	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	CAP000007	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
580117	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	6.46	%
580118	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	CAP000007	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
580119	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	CAP000007	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
580120	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	5.65	%
580121	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
580122	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
580123	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
580124	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
580125	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
580126	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
580127	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
580128	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
580129	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
580130	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
580131	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
580132	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
580133	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
580134	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
580135	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
580136	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	General Comments		
580137	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	General Comments		
580138	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
580139	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
580140	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
580141	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
580142	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
580143	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
580144	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
580145	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
580146	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Trip-energy Supply Verified	y	LED lights?
580147	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
580148	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
580149	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
580150	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	260.0	
580151	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	10.84	%
580152	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	9.64	%
580153	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	9.64	%
580154	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	17	
580155	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
580156	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
580157	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
580158	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Amps A Ø	208.0	
580159	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Amps B Ø	207.0	
580160	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Amps C Ø	194.0	
580161	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Patrol Inspection	Equipment Properly Labeled?	y	
580162	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
580163	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
580164	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
580165	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Vegetation	None	
580166	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
580167	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
580168	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
580169	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	52.0	VDC
580170	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	5.0	VDC
580171	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
580172	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
580173	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
580174	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
580175	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
580176	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
580177	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
580178	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
580179	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
580180	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
580181	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
580182	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
580183	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	General Comments		
580184	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
580185	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
580186	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
580187	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
580188	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
580189	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
580190	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Clear of Trash?	y	
580191	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
580192	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
580193	2/11/2019 10:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Ambient Temp	42	°F
580194	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	General Comments		
580195	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
580196	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
580197	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
580198	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
580199	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
580200	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
580201	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
580202	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3693.60	kw
580203	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
580204	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
580205	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Amps B Ø	98.0	
580206	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Amps A Ø	105.0	
580207	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Accumulated Fault Duty C Ph V	6.38	%
580208	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Totalizer Meter Reading	1.0584	
580209	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Totalizer Meter Multiplier	1800	
580210	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
580211	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
580212	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	PF000424	PowerFuse	WT-12KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	OK	
580213	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	PF000424	PowerFuse	WT-12KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
580214	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Tank Leaks	Seeping	
580215	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
580216	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	PF000423	PowerFuse	WT-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	OK	
580217	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	PF000423	PowerFuse	WT-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
580218	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	PF000422	PowerFuse	WT-12KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	OK	
580219	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
580220	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	General Comments		
580221	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	General Comments		
580222	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
580223	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	PF000422	PowerFuse	WT-12KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
580224	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	PF000421	PowerFuse	WT-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	OK	
580225	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	PF000421	PowerFuse	WT-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
580226	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
580227	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
580228	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
580229	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
580230	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Accumulated Fault Duty A Ph V	2.39	%
580231	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Amps A Ø	66.0	
580232	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Amps B Ø	73.0	
580233	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Amps C Ø	60.0	
580234	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
580235	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
580236	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
580237	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
580238	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
580239	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
580240	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
580241	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
580242	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
580243	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
580244	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
580245	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
580246	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
580247	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
580248	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
580249	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Adequate	
580250	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
580251	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
580252	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
580253	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
580254	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
580255	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Oil Temp Present	29	°C
580256	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Oil Temp Max	50	°C
580257	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
580258	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Follow-up Action Required?	n	
580259	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Patrol Inspection	Follow-up Action Required?	n	
580260	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Operations Ground	0	
580261	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Operations C Ø	0	
580262	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Operations B Ø	0	
580263	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
580264	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	LTC Totalizer Reading	1905.12	kw
580265	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
580266	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	General Comments		
580267	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Patrol Inspection	Follow-up Action Required?	n	
580268	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Follow-up Action Required?	n	
580269	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Patrol Inspection	General Comments		
580270	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
580271	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
580272	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	General Comments		
580273	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
580274	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
580275	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Readings	Totalizer Meter Reading	.9624	
580276	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
580277	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
580278	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
580279	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
580280	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
580281	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC Max Tap Position	4L	
580282	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC Min Tap Position	11L	
580283	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	138	
580284	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
580285	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Switching Operations	0	
580286	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
580287	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Operations Ground	0	
580288	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Operations C Ø	0	
580289	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Operations B Ø	0	
580290	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Unknown Operations	0	
580291	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Operations A Ø	0	
580292	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
580293	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
580294	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
580295	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
580296	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
580297	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
580298	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
580299	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
580300	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
580301	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
580302	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
580303	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
580304	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
580305	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
580306	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
580307	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
580308	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	30	
580309	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60	
580310	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.81	%
580311	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.44	%
580312	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.81	%
580313	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
580314	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
580315	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
580316	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
580317	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
580318	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
580319	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
580320	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
580321	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
580322	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Readings	Follow-up Action Required?	n	
580323	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
580324	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Amps C Ø	99.0	
580325	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.5390	
580326	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
580327	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
580328	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	All Connections OK?	y	
580329	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	Follow-up Action Required?	n	
580330	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	General Comments		
580331	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
580332	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
580333	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
580334	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
580335	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	700	psi
580336	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
580337	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
580338	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
580339	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
580340	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
580341	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
580342	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
580343	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
580344	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
580345	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	VRR Time Delay	30	Seconds
580346	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
580347	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
580348	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
580349	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
580350	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
580351	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	45	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
580352	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
580353	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
580354	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	General Comments		
580355	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
580356	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Oil Temp Present	34	°C
580357	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Oil Temp Max	57	°C
580358	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
580359	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
580360	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1320	
580361	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Patrol Inspection	General Comments		
580362	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
580363	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
580364	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
580365	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
580366	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
580367	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
580368	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
580369	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
580370	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Oil Temp Max	44	°C
580371	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
580372	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
580373	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
580374	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	367.92	kw
580375	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
580376	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
580377	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	General Comments		
580378	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
580379	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
580380	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
580381	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
580382	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
580383	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
580384	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
580385	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
580386	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
580387	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Clear of Trash?	y	
580388	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
580389	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
580390	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
580391	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
580392	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
580393	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	General Comments		
580394	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
580395	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	9 Month Operations	23	
580396	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
580397	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Vegetation	None	
580398	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
580399	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Oil Temp Present	40	°C
580400	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Oil Temp Max	45	°C
580401	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
580402	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	71.00	
580403	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
580404	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
580405	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
580406	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
580407	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
580408	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	LTC Totalizer Reading	6518.40	kw
580409	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
580410	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	General Comments		
580411	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	General Comments		
580412	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
580413	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
580414	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
580415	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
580416	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
580417	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
580418	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
580419	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
580420	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
580421	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
580422	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
580423	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
580424	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
580425	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
580426	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
580427	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
580428	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
580429	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
580430	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
580431	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
580432	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Follow-up Action Required?	n	
580433	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
580434	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
580435	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	PF000033	PowerFuse	BY-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
580436	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	PF000033	PowerFuse	BY-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
580437	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	PF000032	PowerFuse	BY-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
580438	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	PF000032	PowerFuse	BY-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
580439	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
580440	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
580441	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
580442	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Readings	Oil Temp Present	25	°C
580443	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Readings	Oil Temp Max	65	°C
580444	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
580445	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
580446	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Readings	LTC Totalizer Reading	9239.04	kw
580447	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
580448	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Readings	General Comments		
580449	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	Oil Temp Max	42	°C
580450	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
580451	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
580452	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
580453	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	BCH000101	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
580454	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	BCH000101	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
580455	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
580456	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
580457	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
580458	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
580459	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
580460	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
580461	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
580462	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
580463	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	General Comments		
580464	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	General Comments		
580465	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
580466	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
580467	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
580468	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
580469	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
580470	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
580471	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	General Comments		
580472	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
580473	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	General Comments		
580474	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Oil Temp Present	19	°C
580475	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
580476	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	General Comments		
580477	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	General Comments		
580478	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
580479	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
580480	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
580481	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
580482	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
580483	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
580484	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
580485	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
580486	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	BCH000101	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
580487	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	BCH000101	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
580488	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	BCH000101	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	26.5	VDC
580489	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Switching Operations	0	
580490	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Unknown Operations	0	
580491	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
580492	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
580493	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
580494	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
580495	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
580496	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
580497	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	General Comments		
580498	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
580499	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
580500	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Operations Counter	12	
580501	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
580502	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Maintenance Operations	0	
580503	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Operations Counter AF	355	
580504	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
580505	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Tank Leaks	None	
580506	2/11/2019 15:10	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
580507	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Operations Counter AL	355	
580508	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
580509	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Switching Operations	0	
580510	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Unknown Operations	0	
580511	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1320	
580512	2/11/2019 12:40	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	350.0	
580513	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
580514	2/12/2019 7:31	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
580515	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
580516	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
580517	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
580518	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
580519	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	14	
580520	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
580521	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
580522	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	30	
580523	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Patrol Inspection	General Comments		
580524	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	General Comments		
580525	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	General Comments		
580526	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
580527	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
580528	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
580529	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Totalizer Meter Reading	1.3580	
580530	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Unknown Operations	0	
580531	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
580532	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
580533	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	50	°C
580534	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
580535	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Switching Operations	0	
580536	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
580537	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
580538	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
580539	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
580540	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
580541	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
580542	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
580543	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
580544	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
580545	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
580546	2/11/2019 10:06	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
580547	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
580548	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
580549	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
580550	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Maintenance Operations	0	
580551	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Operations Counter AF	38	
580552	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Operations Counter AL	284	
580553	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
580554	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
580555	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
580556	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
580557	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
580558	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
580559	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
580560	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
580561	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Operations Counter AL	38	
580562	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
580563	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
580564	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Operations A Ø	0	
580565	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
580566	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
580567	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Adequate	
580568	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
580569	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
580570	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
580571	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
580572	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
580573	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Operations Counter	450	
580574	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
580575	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	BCH000101	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.500	millivolts
580576	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
580577	2/11/2019 13:45	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	Oil Temp Present	32	°C
580578	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
580579	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
580580	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	BCH000101	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	26.5	VDC
580581	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
580582	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
580583	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
580584	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
580585	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	General Comments		
580586	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
580587	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
580588	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
580589	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
580590	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
580591	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
580592	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
580593	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
580594	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
580595	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
580596	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
580597	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
580598	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
580599	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
580600	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
580601	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Operations B Ø	0	
580602	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Operations C Ø	0	
580603	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Operations Ground	0	
580604	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Patrol Inspection	Follow-up Action Required?	n	
580605	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Follow-up Action Required?	n	
580606	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	14	
580607	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC Current Tap Position	8L	
580608	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
580609	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC As Left Counter	71683	
580610	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC As Found Counter	71683	
580611	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
580612	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	General Comments		
580613	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
580614	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
580615	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Follow-up Action Required?	n	
580616	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	General Comments	.	
580617	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
580618	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Maintenance Operations	0	
580619	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Amps B Ø	400.0	
580620	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
580621	2/11/2019 9:02	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	General Comments		
580622	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Amps C Ø	400.0	
580623	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
580624	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
580625	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
580626	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
580627	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
580628	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Operations Counter AF	284	
580629	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
580630	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
580631	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
580632	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Operations A Ø	0	
580633	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Operations B Ø	0	
580634	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
580635	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
580636	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
580637	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
580638	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
580639	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Operations C Ø	0	
580640	2/28/2019 8:54	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Operations Ground	0	
580641	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
580642	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Amps C Ø	360.0	
580643	2/11/2019 12:50	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Patrol Inspection	Equipment Properly Labeled?	y	
580644	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
580645	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
580646	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
580647	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
580648	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
580649	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
580650	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
580651	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
580652	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
580653	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Amps C Ø	42.0	
580654	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Amps B Ø	21.0	
580655	2/11/2019 10:34	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
580656	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
580657	2/11/2019 11:31	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Amps A Ø	29.0	
580658	2/8/2019 14:46	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
580659	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
580660	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
580661	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
580662	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
580663	2/11/2019 11:10	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
580664	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Operations A Ø	0	
580665	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
580666	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
580667	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Bushings Connection/Risers	Good	
580668	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
580669	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
580670	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
580671	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Equipment Properly Labeled?	y	
580672	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
580673	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Operations Ground	0	
580674	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
580675	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Follow-up Action Required?	n	
580676	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Follow-up Action Required?	n	
580677	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Foundation Condition	Good	
580678	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	General Comments		
580679	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	General Comments		
580680	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
580681	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Grounds in Place?	y	
580682	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Cabinet Paint Condition	Good	
580683	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
580684	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
580685	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
580686	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Clear of Trash?	y	
580687	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	Follow-up Action Required?	n	
580688	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
580689	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
580690	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Grounds in Place?	y	
580691	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
580692	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	General Comments		
580693	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
580694	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
580695	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Maintenance Operations	0	
580696	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
580697	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
580698	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
580699	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Ambient Temp	27	°F
580700	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	441	
580701	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
580702	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	General Comments		
580703	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	32	°C
580704	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	17	°C
580705	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
580706	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
580707	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
580708	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
580709	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
580710	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC As Found Counter	10514	
580711	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
580712	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC As Left Counter	10514	
580713	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
580714	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
580715	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
580716	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
580717	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
580718	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Maintenance Operations	3	
580719	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
580720	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
580721	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
580722	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
580723	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
580724	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
580725	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
580726	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
580727	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Heaters (All) Functioning?	y	
580728	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
580729	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Amps A Ø	160.0	
580730	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
580731	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
580732	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
580733	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
580734	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Moisture and Leak Free?	y	
580735	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Operations Counter AF	253	
580736	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Operations Counter AL	261	
580737	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Maintenance Operations	0	
580738	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Moisture and Leak Free?	y	
580739	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Operations Counter AF	288	
580740	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Operations Counter AL	292	
580741	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Switching Operations	2	
580742	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Tank Paint Condition	Good	
580743	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Unknown Operations	0	
580744	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
580745	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Unknown Operations	0	
580746	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Tank Paint Condition	Good	
580747	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Switching Operations	2	
580748	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
580749	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
580750	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
580751	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	159	
580752	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Amps C Ø	31.0	
580753	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Amps B Ø	30.0	
580754	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Operations Counter AL	184	
580755	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Operations Counter AF	184	
580756	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
580757	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Maintenance Operations	0	
580758	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
580759	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
580760	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
580761	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
580762	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
580763	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Operations C Ø	0	
580764	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Operations B Ø	0	
580765	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Switching Operations	4	
580766	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Tank Paint Condition	Good	
580767	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Unknown Operations	0	
580768	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
580769	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Amps A Ø	26.0	
580770	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	143	
580771	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Operations C Ø	0	
580772	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Operations B Ø	0	
580773	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Operations C Ø	0	
580774	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
580775	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
580776	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
580777	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
580778	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Heaters (All) Functioning?	y	
580779	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
580780	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Operations Ground	0	
580781	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Follow-up Action Required?	n	
580782	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
580783	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
580784	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC Operations Since Last Insp	1146	
580785	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCControl	602-1	LTC Control Insp	All Connections OK?	y	
580786	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCControl	602-1	LTC Control Insp	Follow-up Action Required?	n	
580787	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCControl	602-1	LTC Control Insp	General Comments		
580788	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCControl	602-1	LTC Control Insp	LTC Operation Checked?	y	
580789	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCControl	602-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
580790	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCControl	602-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
580791	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCControl	602-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
580792	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCControl	602-1	LTC Control Insp	VRR Time Delay	30	Seconds
580793	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Follow-up Action Required?	n	
580794	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Foundation Condition	Good	
580795	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	General Comments		
580796	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	General Comments		
580797	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	BFTC	
580798	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
580799	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC Min Tap Position	12L	
580800	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC Max Tap Position	3R	
580801	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC Current Tap Position	6L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
580802	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
580803	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC As Left Counter	108198	
580804	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC As Found Counter	108194	
580805	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
580806	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
580807	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	General Comments		
580808	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	General Comments		
580809	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
580810	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	Follow-up Action Required?	n	
580811	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
580812	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
580813	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
580814	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Grounds in Place?	y	
580815	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	General Comments		
580816	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
580817	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
580818	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
580819	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
580820	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	175	
580821	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
580822	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
580823	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
580824	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	9 Month Operations	62	
580825	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Follow-up Action Required?	n	
580826	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Operations Ground	0	
580827	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
580828	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
580829	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
580830	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
580831	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
580832	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
580833	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
580834	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
580835	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
580836	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Amps C Ø	287.0	
580837	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
580838	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
580839	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
580840	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	General Comments		
580841	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
580842	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2927	
580843	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4200	
580844	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
580845	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
580846	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
580847	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
580848	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
580849	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
580850	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
580851	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
580852	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Unknown Operations	0	
580853	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
580854	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
580855	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
580856	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
580857	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
580858	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
580859	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
580860	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
580861	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
580862	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
580863	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	General Comments		
580864	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	Dessicant needs to be replaced. Its the style with the oil cup at the bottom.	
580865	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
580866	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC As Found Counter	10686	
580867	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC As Left Counter	10686	
580868	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
580869	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC Current Tap Position	4L	
580870	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
580871	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Winding Temp Max	32	°C
580872	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Winding Temp Present	17	°C
580873	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
580874	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
580875	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	35	°C
580876	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	18	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
580877	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	35	°C
580878	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	18	°C
580879	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	35	°C
580880	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	18	°C
580881	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1R	
580882	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
580883	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
580884	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
580885	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	13.0	
580886	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
580887	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
580888	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Oil Temp Present	17	°C
580889	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Oil Temp Max	34	°C
580890	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
580891	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	17.0	
580892	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	15.0	
580893	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
580894	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
580895	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
580896	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	General Comments	ok	
580897	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Operations Counter AL	41	
580898	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
580899	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Operations Counter AF	41	
580900	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
580901	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Maintenance Operations	0	
580902	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Heaters (All) Functioning?	y	
580903	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Grounds in Place?	y	
580904	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Nitrogen Bottle is at O psi. Needs Nitrogen added. Changed cooling bank to Bank 1.	
580905	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	General Comments		
580906	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	General Comments		
580907	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Foundation Condition	Good	
580908	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Follow-up Action Required?	n	
580909	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	9 Month Operations	8	
580910	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
580911	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	9 Month Operations	5	
580912	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Accumulated Fault Duty A Ph V	91.86	%
580913	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Accumulated Fault Duty B Ph V	93.23	%
580914	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
580915	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Accumulated Fault Duty C Ph V	92.32	%
580916	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Amps A Ø	282.0	
580917	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
580918	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Amps B Ø	264.0	
580919	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
580920	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
580921	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Operations Counter	2679	
580922	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
580923	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
580924	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
580925	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
580926	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
580927	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
580928	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	General Comments		
580929	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
580930	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Tank Leaks	None	
580931	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
580932	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Regulator As Left Counter	50978	
580933	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
580934	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
580935	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
580936	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
580937	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
580938	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
580939	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Switching Operations	0	
580940	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
580941	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
580942	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
580943	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
580944	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
580945	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
580946	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps A Ø	120.0	
580947	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps B Ø	140.0	
580948	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Bushing Condition	Good	
580949	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Bushings Connection/Risers	Good	
580950	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
580951	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
580952	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
580953	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
580954	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
580955	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
580956	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
580957	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
580958	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
580959	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	9 Month Operations	12	
580960	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
580961	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
580962	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
580963	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
580964	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
580965	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
580966	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
580967	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
580968	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
580969	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Accumulated Fault Duty A Ph V	10.28	%
580970	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Accumulated Fault Duty B Ph V	10.28	%
580971	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
580972	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Tank Paint Condition	Good	
580973	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Unknown Operations	0	
580974	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
580975	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
580976	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	General Comments		
580977	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
580978	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	General Comments		
580979	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Foundation Condition	Good	
580980	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Follow-up Action Required?	n	
580981	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Follow-up Action Required?	n	
580982	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Operations Ground	0	
580983	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Operations C Ø	0	
580984	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Operations B Ø	0	
580985	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
580986	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Amps A Ø	10.0	
580987	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
580988	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Amps B Ø	10.0	
580989	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Amps C Ø	10.0	
580990	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Bushing Condition	Good	
580991	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
580992	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
580993	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
580994	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
580995	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	14	°C
580996	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
580997	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	400	
580998	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
580999	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
581000	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
581001	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	General Comments		
581002	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
581003	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Heaters (All) Functioning?	y	
581004	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Tank Paint Condition	Good	
581005	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Switching Operations	0	
581006	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Operations Counter AL	195	
581007	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Grounds in Place?	y	
581008	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	General Comments	BFTC	
581009	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	General Comments		
581010	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Foundation Condition	Good	
581011	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Follow-up Action Required?	n	
581012	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
581013	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
581014	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
581015	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
581016	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
581017	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
581018	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Operations Counter AF	195	
581019	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Moisture and Leak Free?	y	
581020	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
581021	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
581022	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Follow-up Action Required?	n	
581023	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Operations Ground	0	
581024	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Operations C Ø	0	
581025	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	1	
581026	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
581027	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
581028	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
581029	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Operations B Ø	0	
581030	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	9 Month Operations	13	
581031	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
581032	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Operations A Ø	0	
581033	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
581034	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
581035	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	566.0	
581036	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	490.0	
581037	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	530.0	
581038	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
581039	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
581040	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
581041	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.34	%
581042	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
581043	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
581044	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	General Comments		
581045	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
581046	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
581047	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	Follow-up Action Required?	n	
581048	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Unknown Operations	0	
581049	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Tank Paint Condition	Good	
581050	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Switching Operations	1	
581051	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Operations Counter AL	171	
581052	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Operations Counter AF	170	
581053	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
581054	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Maintenance Operations	0	
581055	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
581056	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Grounds in Place?	y	
581057	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	General Comments		
581058	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	General Comments		
581059	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Foundation Condition	Good	
581060	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Follow-up Action Required?	n	
581061	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Follow-up Action Required?	n	
581062	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Operations Ground	0	
581063	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Operations C Ø	0	
581064	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Operations B Ø	0	
581065	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Operations A Ø	0	
581066	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
581067	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
581068	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
581069	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
581070	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
581071	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
581072	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
581073	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
581074	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
581075	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
581076	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
581077	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
581078	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
581079	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
581080	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
581081	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
581082	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Bushing Condition	Good	
581083	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Amps C Ø	335.0	
581084	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
581085	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
581086	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
581087	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	General Comments		
581088	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
581089	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
581090	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Min Tap Position	3R	
581091	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Amps B Ø	370.0	
581092	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Amps A Ø	341.0	
581093	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Accumulated Fault Duty C Ph V	1.10	%
581094	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	138	
581095	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
581096	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
581097	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Bushings Connection/Risers	Good	
581098	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Bushing Condition	Good	
581099	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Amps C Ø	122.0	
581100	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
581101	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
581102	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
581103	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
581104	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
581105	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
581106	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
581107	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
581108	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
581109	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
581110	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
581111	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
581112	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
581113	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
581114	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
581115	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
581116	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Amps B Ø	92.0	
581117	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Amps A Ø	111.0	
581118	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Accumulated Fault Duty C Ph V	3.95	%
581119	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Accumulated Fault Duty B Ph V	4.86	%
581120	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Accumulated Fault Duty A Ph V	4.55	%
581121	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	9 Month Operations	9	
581122	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
581123	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
581124	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
581125	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
581126	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
581127	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
581128	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
581129	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
581130	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
581131	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
581132	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
581133	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
581134	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC Min Tap Position	13L	
581135	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC Max Tap Position	1L	
581136	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC As Found Counter	95397	
581137	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
581138	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
581139	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	General Comments		
581140	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
581141	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	General Comments		
581142	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	General Comments		
581143	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BCH000978	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
581144	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BCH000978	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
581145	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
581146	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
581147	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
581148	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
581149	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
581150	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
581151	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
581152	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
581153	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
581154	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
581155	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
581156	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
581157	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
581158	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
581159	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
581160	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
581161	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Regulator As Left Counter	78411	
581162	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
581163	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Tank Leaks	None	
581164	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
581165	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
581166	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
581167	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
581168	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
581169	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
581170	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Current Tap Position	2R	
581171	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
581172	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
581173	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
581174	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
581175	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
581176	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
581177	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
581178	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
581179	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
581180	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
581181	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
581182	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	General Comments		
581183	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
581184	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
581185	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
581186	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
581187	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
581188	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
581189	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
581190	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
581191	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Regulator As Left Counter	76505	
581192	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Accumulated Fault Duty B Ph V	1.10	%
581193	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Accumulated Fault Duty A Ph V	1.10	%
581194	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	9 Month Operations	1	
581195	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
581196	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
581197	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
581198	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
581199	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
581200	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Regulator As Left Counter	88801	
581201	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
581202	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
581203	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Tank Leaks	None	
581204	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
581205	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
581206	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
581207	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
581208	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
581209	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
581210	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
581211	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
581212	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
581213	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BCH000978	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
581214	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BCH000978	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
581215	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BCH000978	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
581216	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
581217	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
581218	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
581219	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
581220	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
581221	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1005.12	kw
581222	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
581223	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
581224	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
581225	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	General Comments	added nitrogen	
581226	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	General Comments		
581227	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
581228	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
581229	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
581230	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Current Tap Position	3R	
581231	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
581232	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
581233	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
581234	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
581235	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	General Comments		
581236	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
581237	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
581238	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
581239	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BCH000978	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
581240	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BCH000978	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
581241	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	General Comments		
581242	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
581243	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Max Tap Position	6R	
581244	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Min Tap Position	16L	
581245	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
581246	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
581247	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
581248	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
581249	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
581250	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Regulator As Left Counter	0	
581251	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
581252	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Tank Leaks	None	
581253	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
581254	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
581255	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
581256	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Tank Leaks	None	
581257	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
581258	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
581259	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Regulator As Left Counter	158350	
581260	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
581261	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
581262	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
581263	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
581264	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
581265	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
581266	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
581267	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	All Connections OK?	y	
581268	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	Follow-up Action Required?	n	
581269	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	General Comments		
581270	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	LTC Operation Checked?	y	
581271	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
581272	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
581273	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
581274	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	VRR Time Delay	30	Seconds
581275	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
581276	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
581277	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
581278	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
581279	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC Operations Since Last Insp	669	
581280	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
581281	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
581282	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
581283	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
581284	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
581285	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	138	
581286	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
581287	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
581288	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
581289	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
581290	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	BCH000402	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
581291	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
581292	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
581293	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
581294	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
581295	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
581296	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
581297	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
581298	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
581299	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
581300	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
581301	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
581302	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
581303	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
581304	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
581305	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	160	
581306	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	160	
581307	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
581308	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
581309	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
581310	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
581311	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	WX0190	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	28.1	
581312	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	WX0190	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
581313	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	WX0190	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
581314	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	WX0190	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
581315	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	WX0190	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
581316	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	WX0190	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
581317	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	WX0190	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
581318	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	WX0190	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	221	
581319	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	WX0190	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
581320	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	WX0190	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
581321	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	VRR Time Delay	30	Seconds
581322	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
581323	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
581324	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
581325	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	LTC Operation Checked?	y	
581326	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
581327	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	Follow-up Action Required?	n	
581328	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	All Connections OK?	y	
581329	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
581330	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
581331	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
581332	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
581333	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
581334	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Current Tap Position	16L	
581335	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
581336	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
581337	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
581338	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
581339	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Operations Ground	0	
581340	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.28	%
581341	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
581342	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Operations C Ø	0	
581343	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4188	
581344	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Operations B Ø	0	
581345	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Operations A Ø	0	
581346	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
581347	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
581348	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
581349	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Equipment Properly Labeled?	y	
581350	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
581351	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
581352	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
581353	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
581354	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
581355	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Foundation Condition	Good	
581356	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
581357	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
581358	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
581359	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
581360	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
581361	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
581362	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
581363	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Foundation Condition	Good	
581364	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
581365	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
581366	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	General Comments		
581367	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
581368	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
581369	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
581370	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
581371	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
581372	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
581373	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
581374	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
581375	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
581376	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
581377	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
581378	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
581379	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
581380	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	General Comments		
581381	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
581382	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
581383	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
581384	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
581385	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Cabinet Paint Condition	Good	
581386	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
581387	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
581388	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
581389	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
581390	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
581391	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
581392	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Current Tap Position	2R	
581393	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
581394	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
581395	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
581396	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
581397	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	General Comments		
581398	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
581399	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
581400	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
581401	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
581402	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
581403	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
581404	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
581405	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
581406	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
581407	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
581408	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
581409	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Unknown Operations	0	
581410	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Tank Paint Condition	Good	
581411	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Switching Operations	6	
581412	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Operations Counter AL	256	
581413	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Operations Counter AF	256	
581414	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	General Comments		
581415	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
581416	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
581417	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
581418	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
581419	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
581420	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Regulator As Left Counter	80386	
581421	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
581422	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Tank Leaks	None	
581423	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
581424	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
581425	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
581426	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	General Comments		
581427	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
581428	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
581429	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Moisture and Leak Free?	y	
581430	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Maintenance Operations	0	
581431	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Grounds in Place?	y	
581432	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	General Comments	Cleaned and tightened buss side disconnect and BFTC	
581433	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	General Comments		
581434	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Foundation Condition	Good	
581435	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Follow-up Action Required?	n	
581436	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Follow-up Action Required?	n	
581437	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
581438	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
581439	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
581440	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
581441	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	157	
581442	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	157	
581443	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
581444	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
581445	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	General Comments		
581446	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
581447	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
581448	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
581449	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	General Comments		
581450	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
581451	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
581452	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
581453	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
581454	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
581455	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
581456	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
581457	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
581458	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
581459	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
581460	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
581461	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
581462	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
581463	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
581464	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
581465	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
581466	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
581467	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
581468	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
581469	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Readings	General Comments	ok	
581470	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
581471	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
581472	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
581473	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
581474	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
581475	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
581476	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
581477	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	General Comments		
581478	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
581479	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Amps B Ø	47.0	
581480	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Amps C Ø	30.0	
581481	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Bushing Condition	Good	
581482	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Bushings Connection/Risers	Good	
581483	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
581484	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
581485	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Amps A Ø	120.0	
581486	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
581487	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
581488	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
581489	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
581490	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
581491	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	Totalizer Meter Reading	.2676	
581492	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
581493	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
581494	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
581495	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
581496	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
581497	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
581498	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
581499	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
581500	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
581501	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
581502	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
581503	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
581504	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
581505	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
581506	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
581507	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
581508	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
581509	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
581510	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
581511	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0332	
581512	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
581513	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	Oil Temp Present	30	°C
581514	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	Oil Temp Max	30	°C
581515	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
581516	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
581517	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
581518	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	LTC Totalizer Reading	2568.96	kw
581519	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
581520	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	General Comments		
581521	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	General Comments		
581522	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
581523	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
581524	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	Follow-up Action Required?	n	
581525	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
581526	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Amps B Ø	120.0	
581527	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
581528	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
581529	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC As Left Counter	93001	
581530	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC As Found Counter	93001	
581531	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	General Comments		
581532	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	9 Month Operations	2	
581533	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
581534	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Accumulated Fault Duty B Ph V	.46	%
581535	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
581536	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
581537	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
581538	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
581539	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Winding Temp Max	37	°C
581540	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Winding Temp Present	21	°C
581541	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
581542	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
581543	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	37	°C
581544	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	21	°C
581545	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	37	°C
581546	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	21	°C
581547	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	37	°C
581548	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	21	°C
581549	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
581550	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
581551	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
581552	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
581553	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
581554	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	343	
581555	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	342	
581556	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
581557	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
581558	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
581559	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
581560	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
581561	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
581562	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
581563	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
581564	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
581565	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
581566	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
581567	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
581568	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
581569	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
581570	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
581571	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
581572	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
581573	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
581574	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
581575	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
581576	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
581577	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
581578	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
581579	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
581580	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
581581	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
581582	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Operations A Ø	0	
581583	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Operations B Ø	0	
581584	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Accumulated Fault Duty C Ph V	16.44	%
581585	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	HV Winding Temp Max	30	°C
581586	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	HV Winding Temp Present	15	°C
581587	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
581588	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
581589	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
581590	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
581591	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1229.34	kw
581592	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
581593	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
581594	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
581595	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Oil Temp Present	15	°C
581596	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
581597	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
581598	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
581599	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
581600	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
581601	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Cabinet Paint Condition	Good	
581602	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Equipment Properly Labeled?	y	
581603	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
581604	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
581605	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
581606	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
581607	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
581608	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
581609	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
581610	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
581611	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
581612	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
581613	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
581614	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
581615	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
581616	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
581617	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
581618	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
581619	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
581620	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	General Comments		
581621	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Changed cooling bank to Bank 1. Dry out system hooked up to this TR.	
581622	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
581623	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
581624	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
581625	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
581626	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Oil Temp Max	35	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
581627	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
581628	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
581629	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
581630	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
581631	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
581632	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
581633	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
581634	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
581635	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
581636	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Operations A Ø	0	
581637	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Operations B Ø	0	
581638	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Operations C Ø	0	
581639	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Operations Ground	0	
581640	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Follow-up Action Required?	n	
581641	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Follow-up Action Required?	n	
581642	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Foundation Condition	Good	
581643	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	General Comments		
581644	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	General Comments		
581645	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Grounds in Place?	y	
581646	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Heaters (All) Functioning?	y	
581647	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Maintenance Operations	0	
581648	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Moisture and Leak Free?	y	
581649	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Operations Counter AF	150	
581650	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Operations Counter AL	150	
581651	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
581652	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Switching Operations	0	
581653	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Tank Paint Condition	Good	
581654	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Unknown Operations	0	
581655	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
581656	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
581657	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
581658	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
581659	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
581660	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
581661	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
581662	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
581663	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Amps A Ø	28.0	
581664	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
581665	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
581666	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
581667	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
581668	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
581669	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
581670	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC Current Tap Position	9L	
581671	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	9 Month Operations	1	
581672	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Accumulated Fault Duty A Ph V	2.21	%
581673	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Accumulated Fault Duty B Ph V	2.21	%
581674	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Accumulated Fault Duty C Ph V	2.21	%
581675	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Amps A Ø	152.0	
581676	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Amps B Ø	204.0	
581677	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Amps C Ø	181.0	
581678	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Bushing Condition	Good	
581679	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Bushings Connection/Risers	Good	
581680	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
581681	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
581682	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
581683	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Tank Leaks	None	
581684	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
581685	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
581686	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
581687	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
581688	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Operations Counter	13	
581689	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
581690	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
581691	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	General Comments		
581692	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
581693	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
581694	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
581695	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
581696	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
581697	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
581698	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
581699	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
581700	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
581701	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
581702	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
581703	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
581704	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
581705	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
581706	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
581707	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
581708	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
581709	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
581710	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
581711	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	9 Month Operations	60	
581712	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
581713	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	General Comments		
581714	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	General Comments		
581715	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
581716	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
581717	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	9 Month Operations	1	
581718	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Accumulated Fault Duty A Ph V	2.94	%
581719	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Accumulated Fault Duty B Ph V	2.94	%
581720	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Accumulated Fault Duty C Ph V	2.94	%
581721	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Amps A Ø	143.0	
581722	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Amps B Ø	150.0	
581723	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Amps C Ø	96.0	
581724	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Bushing Condition	Good	
581725	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Bushings Connection/Risers	Good	
581726	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
581727	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
581728	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
581729	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Cabinet Paint Condition	Good	
581730	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Equipment Properly Labeled?	y	
581731	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
581732	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
581733	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
581734	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
581735	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
581736	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
581737	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
581738	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
581739	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
581740	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
581741	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
581742	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Equipment Properly Labeled?	y	
581743	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2479.68	kw
581744	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	71.00	
581745	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
581746	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
581747	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
581748	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
581749	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
581750	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Cabinet Paint Condition	Good	
581751	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Amps A Ø	25.5	
581752	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Amps B Ø	59.6	
581753	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Amps C Ø	63.8	
581754	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
581755	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
581756	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
581757	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
581758	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
581759	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	General Comments		
581760	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
581761	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Operations Counter	240	
581762	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
581763	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
581764	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Oil Temp Present	38	°C
581765	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
581766	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
581767	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
581768	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Bushings Connection/Risers	Good	
581769	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Bushing Condition	Good	
581770	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Amps C Ø	120.0	
581771	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	General Comments		
581772	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	General Comments		
581773	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC As Found Counter	267019	
581774	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC As Left Counter	267026	
581775	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
581776	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC Current Tap Position	2L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
581777	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC Max Tap Position	4R	
581778	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC Min Tap Position	12L	
581779	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC Operations Since Last Insp	961	
581780	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
581781	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Cabinet Paint Condition	Good	
581782	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Equipment Properly Labeled?	y	
581783	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
581784	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
581785	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
581786	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Operations A Ø	0	
581787	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Operations B Ø	0	
581788	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Operations C Ø	0	
581789	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Operations Ground	0	
581790	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Follow-up Action Required?	n	
581791	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Follow-up Action Required?	n	
581792	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Foundation Condition	Good	
581793	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	General Comments		
581794	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	General Comments		
581795	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Grounds in Place?	y	
581796	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Heaters (All) Functioning?	y	
581797	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Maintenance Operations	0	
581798	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Moisture and Leak Free?	y	
581799	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Operations Counter AF	159	
581800	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Operations Counter AL	159	
581801	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
581802	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Switching Operations	0	
581803	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Tank Paint Condition	Good	
581804	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Unknown Operations	0	
581805	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Moisture and Leak Free?	y	
581806	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Maintenance Operations	0	
581807	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Heaters (All) Functioning?	y	
581808	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
581809	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Grounds in Place?	y	
581810	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	General Comments		
581811	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	General Comments		
581812	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	Follow-up Action Required?	n	
581813	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
581814	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
581815	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
581816	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
581817	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Foundation Condition	Good	
581818	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Follow-up Action Required?	n	
581819	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Follow-up Action Required?	n	
581820	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Operations Ground	0	
581821	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Operations C Ø	0	
581822	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Operations B Ø	0	
581823	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Operations A Ø	0	
581824	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
581825	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
581826	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
581827	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
581828	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
581829	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Amps A Ø	19.0	
581830	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Amps B Ø	38.0	
581831	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Follow-up Action Required?	n	
581832	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Amps C Ø	14.0	
581833	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Bushing Condition	Good	
581834	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Bushings Connection/Risers	Good	
581835	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
581836	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
581837	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
581838	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Cabinet Paint Condition	Good	
581839	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Equipment Properly Labeled?	y	
581840	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
581841	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
581842	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
581843	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Operations A Ø	0	
581844	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Operations B Ø	1	
581845	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Operations C Ø	0	
581846	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Operations Ground	0	
581847	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Follow-up Action Required?	n	
581848	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Follow-up Action Required?	n	
581849	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
581850	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
581851	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
581852	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
581853	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Foundation Condition	Good	
581854	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	General Comments		
581855	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	General Comments		
581856	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
581857	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
581858	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
581859	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	422	
581860	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	10L	
581861	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Grounds in Place?	y	
581862	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Heaters (All) Functioning?	y	
581863	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Totalizer Meter Reading	.5406	
581864	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
581865	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
581866	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
581867	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
581868	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
581869	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
581870	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
581871	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
581872	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Oil Temp Present	30	°C
581873	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Maintenance Operations	0	
581874	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Moisture and Leak Free?	y	
581875	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Operations Counter AF	170	
581876	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Operations Counter AL	170	
581877	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
581878	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.10	%
581879	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.10	%
581880	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.10	%
581881	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
581882	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	180.0	
581883	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	200.0	
581884	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
581885	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
581886	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
581887	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
581888	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
581889	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
581890	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
581891	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
581892	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
581893	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
581894	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
581895	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
581896	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
581897	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
581898	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
581899	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
581900	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Regulator As Left Counter	79495	
581901	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
581902	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Tank Leaks	None	
581903	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
581904	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Operations Counter AL	267	
581905	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Operations Counter AF	260	
581906	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Moisture and Leak Free?	y	
581907	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Maintenance Operations	5	
581908	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Heaters (All) Functioning?	y	
581909	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Grounds in Place?	y	
581910	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	General Comments		
581911	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	General Comments		
581912	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Foundation Condition	Good	
581913	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Follow-up Action Required?	n	
581914	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Follow-up Action Required?	n	
581915	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
581916	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
581917	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	1124.0	VAC
581918	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
581919	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
581920	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
581921	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
581922	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	9 Month Operations	54	
581923	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
581924	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
581925	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
581926	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
581927	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
581928	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Bushings Connection/Risers	Good	
581929	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
581930	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
581931	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
581932	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	General Comments		
581933	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
581934	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
581935	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
581936	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Operations Ground	0	
581937	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Operations C Ø	0	
581938	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Operations B Ø	0	
581939	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Operations A Ø	0	
581940	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
581941	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
581942	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
581943	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Equipment Properly Labeled?	y	
581944	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Cabinet Paint Condition	Good	
581945	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
581946	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
581947	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
581948	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Bushings Connection/Risers	Good	
581949	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
581950	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
581951	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
581952	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
581953	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
581954	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
581955	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
581956	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
581957	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Follow-up Action Required?	n	
581958	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
581959	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
581960	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	General Comments		
581961	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	General Comments	replaced bottle	
581962	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
581963	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Bushing Condition	Good	
581964	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Unknown Operations	0	
581965	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Tank Paint Condition	Good	
581966	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Switching Operations	0	
581967	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
581968	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Operations Counter AL	367	
581969	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Operations Counter AF	367	
581970	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Moisture and Leak Free?	y	
581971	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Maintenance Operations	0	
581972	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Grounds in Place?	y	
581973	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Amps C Ø	164.0	
581974	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Amps B Ø	127.0	
581975	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
581976	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Switching Operations	1	
581977	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Tank Paint Condition	Good	
581978	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Unknown Operations	0	
581979	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Oil Temp Max	55	°C
581980	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
581981	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Unknown Operations	0	
581982	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Tank Paint Condition	Good	
581983	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Switching Operations	1	
581984	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
581985	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Operations Counter AL	226	
581986	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Operations Counter AF	225	
581987	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Moisture and Leak Free?	y	
581988	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Maintenance Operations	0	
581989	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Heaters (All) Functioning?	y	
581990	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Grounds in Place?	y	
581991	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	General Comments		
581992	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Operations Ground	0	
581993	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Operations C Ø	0	
581994	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
581995	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	LTC Totalizer Reading	9730.80	kw
581996	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
581997	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Operations B Ø	0	
581998	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Operations A Ø	0	
581999	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
582000	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
582001	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
582002	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Equipment Properly Labeled?	y	
582003	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Cabinet Paint Condition	Good	
582004	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
582005	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
582006	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
582007	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	General Comments		
582008	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	General Comments		
582009	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
582010	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
582011	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
582012	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
582013	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	20	
582014	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Follow-up Action Required?	n	
582015	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
582016	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
582017	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Unknown Operations	0	
582018	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Tank Paint Condition	Good	
582019	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Switching Operations	4	
582020	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
582021	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
582022	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
582023	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
582024	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	LTC Operation Checked?	y	
582025	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
582026	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
582027	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
582028	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
582029	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
582030	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	VRR Time Delay	30	Seconds
582031	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
582032	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
582033	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Winding Temp Present	35	°C
582034	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
582035	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
582036	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
582037	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
582038	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	General Comments		
582039	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
582040	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
582041	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
582042	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
582043	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
582044	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
582045	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
582046	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
582047	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Unknown Operations	0	
582048	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Tank Paint Condition	Good	
582049	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Switching Operations	2	
582050	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
582051	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
582052	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
582053	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
582054	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	Vegetation	None	
582055	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	General Comments		
582056	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
582057	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
582058	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
582059	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
582060	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
582061	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
582062	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
582063	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	General Comments		
582064	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	General Comments		
582065	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
582066	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
582067	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	432.00	kw
582068	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
582069	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
582070	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	Oil Temp Present	25	°C
582071	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
582072	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
582073	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
582074	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
582075	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
582076	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
582077	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Unknown Operations	0	
582078	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
582079	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
582080	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
582081	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
582082	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	229025	
582083	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
582084	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
582085	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
582086	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
582087	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	General Comments		
582088	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
582089	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
582090	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
582091	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
582092	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
582093	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
582094	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	General Comments	BFTC	
582095	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Clear of Trash?	y	
582096	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
582097	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
582098	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
582099	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
582100	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	1.2516	
582101	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
582102	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
582103	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
582104	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
582105	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
582106	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
582107	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
582108	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
582109	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
582110	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
582111	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
582112	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
582113	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
582114	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
582115	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
582116	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
582117	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
582118	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
582119	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	All Connections OK?	y	
582120	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	Follow-up Action Required?	n	
582121	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	General Comments		
582122	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
582123	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
582124	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
582125	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
582126	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
582127	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
582128	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
582129	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
582130	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
582131	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
582132	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
582133	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
582134	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
582135	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
582136	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
582137	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
582138	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
582139	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.7200	
582140	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Operations Counter AF	362	
582141	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Moisture and Leak Free?	y	
582142	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Maintenance Operations	0	
582143	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Heaters (All) Functioning?	y	
582144	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Grounds in Place?	y	
582145	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	General Comments		
582146	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	General Comments		
582147	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Foundation Condition	Good	
582148	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
582149	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
582150	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Winding Temp Present	20	°C
582151	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
582152	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
582153	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
582154	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
582155	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
582156	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
582157	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
582158	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
582159	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Winding Temp Max	20	°C
582160	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Follow-up Action Required?	n	
582161	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
582162	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
582163	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	General Comments		
582164	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
582165	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
582166	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
582167	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
582168	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
582169	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
582170	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
582171	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
582172	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
582173	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
582174	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
582175	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
582176	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
582177	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	35	°C
582178	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Winding Temp Max	15	°C
582179	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Totalizer Meter Reading	.5514	
582180	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
582181	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
582182	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
582183	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
582184	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
582185	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
582186	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
582187	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
582188	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Oil Temp Present	25	°C
582189	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Oil Temp Max	35	°C
582190	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
582191	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
582192	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	LTC Totalizer Reading	9925.20	kw
582193	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
582194	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	General Comments		
582195	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	General Comments		
582196	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
582197	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
582198	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Follow-up Action Required?	n	
582199	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
582200	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
582201	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
582202	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
582203	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
582204	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
582205	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
582206	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
582207	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
582208	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
582209	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
582210	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
582211	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	62	°C
582212	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
582213	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
582214	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	4005.12	kw
582215	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
582216	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
582217	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
582218	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
582219	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
582220	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Amps C Ø	143.0	
582221	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Amps B Ø	132.0	
582222	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Amps A Ø	149.0	
582223	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
582224	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
582225	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
582226	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
582227	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	4L	
582228	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
582229	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
582230	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
582231	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
582232	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
582233	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
582234	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
582235	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
582236	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
582237	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
582238	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	Follow-up Action Required?	n	
582239	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
582240	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
582241	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
582242	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
582243	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
582244	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
582245	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
582246	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
582247	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
582248	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
582249	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
582250	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
582251	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
582252	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
582253	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
582254	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
582255	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
582256	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
582257	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	Follow-up Action Required?	n	
582258	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
582259	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
582260	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	9 Month Operations	0	
582261	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
582262	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
582263	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	General Comments		
582264	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	General Comments		
582265	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
582266	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	LTC Totalizer Reading	4354.56	kw
582267	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
582268	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
582269	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Accumulated Fault Duty B Ph V	1.03	%
582270	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Accumulated Fault Duty A Ph V	2.06	%
582271	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	9 Month Operations	6	
582272	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
582273	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
582274	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
582275	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
582276	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
582277	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
582278	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
582279	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
582280	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
582281	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
582282	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Operations C Ø	0	
582283	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
582284	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
582285	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Operations B Ø	0	
582286	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Operations A Ø	0	
582287	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
582288	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
582289	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
582290	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Equipment Properly Labeled?	y	
582291	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Cabinet Paint Condition	Good	
582292	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
582293	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
582294	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
582295	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
582296	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2000	psi
582297	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Oil Temp Max	40	°C
582298	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Oil Temp Present	20	°C
582299	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
582300	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
582301	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
582302	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
582303	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
582304	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
582305	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
582306	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
582307	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
582308	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Totalizer Meter Reading	1.1370	
582309	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Winding Temp Max	65	°C
582310	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Winding Temp Present	20	°C
582311	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
582312	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
582313	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
582314	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
582315	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Bushings Connection/Risers	Good	
582316	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Bushing Condition	Good	
582317	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
582318	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Bushings Connection/Risers	Good	
582319	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Accumulated Fault Duty B Ph V	.69	%
582320	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Accumulated Fault Duty C Ph V	3.46	%
582321	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Amps A Ø	40.0	
582322	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Bushing Condition	Good	
582323	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Amps C Ø	60.0	
582324	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Amps B Ø	130.0	
582325	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Amps A Ø	100.0	
582326	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Accumulated Fault Duty C Ph V	2.77	%
582327	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Accumulated Fault Duty B Ph V	5.53	%
582328	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Accumulated Fault Duty A Ph V	3.46	%
582329	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	9 Month Operations	18	
582330	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Vegetation	None	
582331	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
582332	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	General Comments	Berm is exposed, but is in the process of being removed	
582333	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
582334	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
582335	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
582336	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
582337	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
582338	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Clear of Trash?	y	
582339	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
582340	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Ambient Temp	38	°F
582341	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Amps B Ø	40.0	
582342	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Amps C Ø	40.0	
582343	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Bushing Condition	Good	
582344	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
582345	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
582346	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
582347	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
582348	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
582349	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
582350	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
582351	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	224543	
582352	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
582353	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
582354	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
582355	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
582356	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
582357	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
582358	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
582359	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
582360	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
582361	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
582362	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
582363	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	General Comments	Fence grounds were found cut, we replaced and reported. Fence fabric and some raill are getting rusty as well as barbwire...fence is 6	
582364	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
582365	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
582366	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-2.0	psi
582367	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	Oil Temp Max	34	°C
582368	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	Oil Temp Present	34	°C
582369	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
582370	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
582371	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
582372	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
582373	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
582374	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
582375	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
582376	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
582377	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
582378	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
582379	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
582380	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
582381	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Current Tap Position	8L	
582382	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
582383	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
582384	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
582385	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
582386	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	General Comments		
582387	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
582388	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Max Tap Position	5L	
582389	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	9 Month Operations	8	
582390	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Accumulated Fault Duty A Ph V	4.15	%
582391	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Min Tap Position	14L	
582392	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
582393	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
582394	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
582395	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
582396	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
582397	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
582398	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	Totalizer Meter Reading	.9072	
582399	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
582400	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
582401	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
582402	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
582403	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
582404	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Regulator As Left Counter	119923	
582405	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
582406	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Tank Leaks	None	
582407	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
582408	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
582409	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
582410	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
582411	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
582412	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
582413	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
582414	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments	Indicator does not work	
582415	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
582416	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
582417	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
582418	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Clear of Trash?	y	
582419	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
582420	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	n	
582421	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	n	
582422	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
582423	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
582424	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	General Comments	Drive is washed out on coal road	
582425	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
582426	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Vegetation	None	
582427	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
582428	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
582429	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
582430	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	25.3	VDC
582431	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.2	VDC
582432	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
582433	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
582434	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations Counter AL	652	
582435	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
582436	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Switching Operations	4	
582437	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
582438	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Operations Counter AL	290	
582439	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Operations Counter AF	284	
582440	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Moisture and Leak Free?	y	
582441	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Maintenance Operations	0	
582442	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	LTC Totalizer Reading	20466.00	kw
582443	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
582444	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	Follow-up Action Required?	n	
582445	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
582446	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	General Comments		
582447	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	General Comments		
582448	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC As Found Counter	30225	
582449	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC As Left Counter	30237	
582450	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
582451	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC Current Tap Position	1L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
582452	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC Max Tap Position	2R	
582453	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC Min Tap Position	10L	
582454	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
582455	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
582456	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
582457	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC Operations Since Last Insp	806	
582458	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
582459	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
582460	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
582461	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
582462	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
582463	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
582464	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Amps A Ø	186.0	
582465	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
582466	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Accumulated Fault Duty B Ph V	.47	%
582467	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Accumulated Fault Duty A Ph V	.47	%
582468	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	9 Month Operations	7	
582469	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
582470	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
582471	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	General Comments		
582472	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	General Comments		
582473	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	4R	
582474	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Foundation Condition	Good	
582475	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Follow-up Action Required?	n	
582476	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Follow-up Action Required?	n	
582477	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Operations Ground	0	
582478	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Operations C Ø	0	
582479	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Operations B Ø	0	
582480	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	2L	
582481	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Operations A Ø	0	
582482	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
582483	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
582484	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
582485	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Equipment Properly Labeled?	y	
582486	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Cabinet Paint Condition	Good	
582487	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
582488	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
582489	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	2780	
582490	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	2779	
582491	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
582492	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
582493	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
582494	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
582495	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LT0079	LTCMechanism	FD-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments	ok	
582496	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LT0079	LTCMechanism	FD-Offline Distribution	LTC Counter Readings	General Comments	ok	
582497	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LT0079	LTCMechanism	FD-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
582498	2/8/2019 12:03	Distribution	Ford Quarterly Inspection	LT0079	LTCMechanism	FD-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
582499	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
582500	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
582501	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
582502	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	20	
582503	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
582504	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
582505	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Maintenance Operations	0	
582506	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
582507	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations Counter AF	652	
582508	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
582509	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
582510	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
582511	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
582512	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
582513	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	Oil Temp Present	41	°C
582514	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	Oil Temp Max	42	°C
582515	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
582516	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
582517	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Foundation Condition	Good	
582518	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Follow-up Action Required?	n	
582519	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
582520	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	
582521	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
582522	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	80.0	
582523	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Follow-up Action Required?	n	
582524	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Fault Operations Ground	0	
582525	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Fault Operations C Ø	0	
582526	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	LTC Totalizer Reading	2462.40	kw

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
582527	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
582528	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	General Comments		
582529	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
582530	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Fault Operations B Ø	0	
582531	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Fault Operations A Ø	2	
582532	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
582533	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
582534	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
582535	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Equipment Properly Labeled?	y	
582536	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Cabinet Paint Condition	Good	
582537	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
582538	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
582539	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	General Comments		
582540	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	General Comments		
582541	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
582542	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
582543	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
582544	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
582545	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
582546	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
582547	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
582548	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Bushings Connection/Risers	Good	
582549	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Bushing Condition	Good	
582550	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Amps C Ø	160.0	
582551	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
582552	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Foundation Condition	Good	
582553	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Amps B Ø	120.0	
582554	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Amps A Ø	115.0	
582555	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
582556	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Follow-up Action Required?	n	
582557	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Follow-up Action Required?	n	
582558	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Operations Ground	0	
582559	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
582560	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
582561	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
582562	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
582563	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
582564	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
582565	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.000	millivolts
582566	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
582567	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Unknown Operations	1	
582568	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
582569	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
582570	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
582571	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
582572	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	General Comments		
582573	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
582574	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
582575	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
582576	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
582577	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
582578	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
582579	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
582580	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
582581	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
582582	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Heaters (All) Functioning?	y	
582583	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Grounds in Place?	y	
582584	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	General Comments		
582585	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	General Comments		
582586	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
582587	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
582588	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
582589	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
582590	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	General Comments		
582591	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
582592	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
582593	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Foundation Condition	Good	
582594	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
582595	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
582596	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
582597	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
582598	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
582599	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Grounds in Place?	n	
582600	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
582601	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
582602	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	Totalizer Meter Reading	.3420	
582603	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
582604	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
582605	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Tank Oil Level	Low	
582606	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
582607	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
582608	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
582609	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
582610	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
582611	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
582612	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
582613	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
582614	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	9 Month Operations	10	
582615	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
582616	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
582617	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
582618	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
582619	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
582620	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
582621	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
582622	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
582623	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
582624	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
582625	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Totalizer Meter Reading	.3768	
582626	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Winding Temp Max	40	°C
582627	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	All Connections OK?	y	
582628	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	Follow-up Action Required?	n	
582629	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	General Comments		
582630	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	LTC Operation Checked?	y	
582631	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
582632	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
582633	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
582634	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
582635	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
582636	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
582637	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Vegetation	None	
582638	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
582639	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	General Comments		
582640	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
582641	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
582642	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
582643	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
582644	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
582645	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
582646	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
582647	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	VRR Time Delay	30	Seconds
582648	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
582649	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
582650	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Clear of Trash?	y	
582651	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
582652	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
582653	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
582654	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	General Comments		
582655	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
582656	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
582657	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
582658	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
582659	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000569	LTCControl	951-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
582660	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000569	LTCControl	951-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
582661	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000569	LTCControl	951-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
582662	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
582663	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	General Comments		
582664	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	General Comments		
582665	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
582666	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	LTC Totalizer Reading	6782.40	kw
582667	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
582668	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
582669	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Oil Temp Max	45	°C
582670	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Oil Temp Present	30	°C
582671	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
582672	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
582673	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
582674	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
582675	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
582676	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
582677	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
582678	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
582679	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	General Comments		
582680	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
582681	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
582682	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Accumulated Fault Duty A Ph V	.96	%
582683	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
582684	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Foundation Condition	Good	
582685	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
582686	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
582687	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
582688	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	BAT000560	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
582689	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	General Comments		
582690	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
582691	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	BAT000560	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
582692	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	BAT000560	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
582693	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	BAT000560	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
582694	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	BAT000560	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
582695	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	LTCC000528	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
582696	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	LTCC000528	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
582697	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	LTCC000528	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
582698	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	LTCC000528	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
582699	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	LTCC000528	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
582700	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	LTCC000528	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
582701	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	LTCC000528	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
582702	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	LTCC000528	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
582703	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
582704	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Foundation Condition	Good	
582705	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
582706	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
582707	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
582708	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Cabinet Paint Condition	Good	
582709	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Equipment Properly Labeled?	y	
582710	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
582711	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
582712	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
582713	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Operations A Ø	0	
582714	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Operations B Ø	0	
582715	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Operations C Ø	0	
582716	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Operations Ground	0	
582717	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Follow-up Action Required?	n	
582718	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Follow-up Action Required?	n	
582719	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Foundation Condition	Good	
582720	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	General Comments		
582721	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	General Comments		
582722	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Grounds in Place?	y	
582723	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Heaters (All) Functioning?	y	
582724	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Maintenance Operations	0	
582725	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Moisture and Leak Free?	y	
582726	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Operations Counter AF	218	
582727	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Operations Counter AL	219	
582728	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
582729	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
582730	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
582731	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Switching Operations	1	
582732	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
582733	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Vegetation	None	
582734	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
582735	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	General Comments		
582736	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Winding Temp Present	30	°C
582737	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
582738	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
582739	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
582740	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
582741	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
582742	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
582743	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
582744	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
582745	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
582746	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
582747	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
582748	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
582749	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
582750	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
582751	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
582752	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
582753	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
582754	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Clear of Trash?	y	
582755	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
582756	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
582757	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.74	%
582758	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.37	%
582759	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.83	%
582760	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	139.0	
582761	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	143.0	
582762	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
582763	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
582764	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BCH001149	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
582765	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BCH001149	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
582766	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BCH001149	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
582767	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BCH001149	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
582768	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
582769	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
582770	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
582771	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
582772	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BCH001149	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
582773	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BCH001149	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
582774	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BCH001149	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
582775	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	152.0	
582776	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
582777	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
582778	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
582779	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
582780	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
582781	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
582782	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
582783	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
582784	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
582785	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
582786	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
582787	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
582788	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
582789	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
582790	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
582791	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
582792	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
582793	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
582794	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
582795	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
582796	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
582797	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
582798	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
582799	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	223	
582800	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
582801	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
582802	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
582803	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	224	
582804	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
582805	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
582806	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
582807	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	BAT000560	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
582808	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	BAT000560	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	27	°F
582809	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	BAT000560	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
582810	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	BAT000560	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
582811	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps C Ø	120.0	
582812	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
582813	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
582814	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Broom on Site?	y	
582815	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
582816	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
582817	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
582818	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
582819	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Bushings Connection/Risers	Good	
582820	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Bushing Condition	Good	
582821	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Amps C Ø	162.0	
582822	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Amps B Ø	208.0	
582823	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Amps A Ø	163.0	
582824	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Accumulated Fault Duty C Ph V	.93	%
582825	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Accumulated Fault Duty B Ph V	2.80	%
582826	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
582827	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
582828	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
582829	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
582830	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Accumulated Fault Duty A Ph V	2.34	%
582831	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	9 Month Operations	4	
582832	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Accumulated Fault Duty A Ph V	11.30	%
582833	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Accumulated Fault Duty B Ph V	7.19	%
582834	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Accumulated Fault Duty C Ph V	13.36	%
582835	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Amps A Ø	115.0	
582836	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Amps B Ø	120.0	
582837	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Amps C Ø	120.0	
582838	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Bushing Condition	Good	
582839	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Bushings Connection/Risers	Good	
582840	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
582841	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
582842	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
582843	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Cabinet Paint Condition	Good	
582844	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Equipment Properly Labeled?	y	
582845	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
582846	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
582847	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
582848	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Operations A Ø	0	
582849	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Operations B Ø	0	
582850	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Operations C Ø	0	
582851	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Operations Ground	0	
582852	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
582853	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
582854	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
582855	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
582856	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
582857	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Current Tap Position	10L	
582858	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
582859	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
582860	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
582861	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
582862	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	General Comments		
582863	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
582864	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Max Tap Position	5L	
582865	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Min Tap Position	14L	
582866	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
582867	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
582868	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
582869	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
582870	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
582871	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Regulator As Left Counter	154901	
582872	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
582873	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Tank Leaks	None	
582874	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
582875	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Operations A Ø	0	
582876	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
582877	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
582878	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
582879	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Equipment Properly Labeled?	y	
582880	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Cabinet Paint Condition	Good	
582881	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
582882	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
582883	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	General Comments		
582884	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
582885	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
582886	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
582887	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Vegetation	None	
582888	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
582889	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
582890	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
582891	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
582892	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Follow-up Action Required?	n	
582893	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
582894	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
582895	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Trash Emptied?	n	
582896	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
582897	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	General Comments		
582898	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
582899	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
582900	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Floor Swept?	y	
582901	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
582902	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
582903	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Evidence of Insects	None	
582904	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Accumulated Fault Duty C Ph V	1.29	%
582905	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Accumulated Fault Duty B Ph V	.64	%
582906	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Broom on Site?	y	
582907	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Control House Lighting OK?	y	
582908	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
582909	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Doors and Locks Secure?	y	
582910	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Evidence of Insects	None	
582911	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
582912	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Floor Condition Acceptable?	y	
582913	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
582914	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Floor Swept?	y	
582915	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Follow-up Action Required?	n	
582916	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
582917	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	General Comments		
582918	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Moisture and Leak Free?	y	
582919	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Trash Emptied?	y	
582920	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Ventilation Free of Debris?	y	
582921	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
582922	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
582923	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
582924	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
582925	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
582926	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
582927	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
582928	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
582929	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
582930	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
582931	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
582932	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
582933	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
582934	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
582935	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
582936	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
582937	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
582938	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
582939	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	General Comments		
582940	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
582941	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
582942	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
582943	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Foundation Condition	Good	
582944	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
582945	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
582946	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
582947	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
582948	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000569	LTCControl	951-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
582949	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000569	LTCControl	951-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
582950	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000569	LTCControl	951-Offline-Distribution	LTC Control Insp	General Comments		
582951	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000569	LTCControl	951-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
582952	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000569	LTCControl	951-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
582953	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
582954	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
582955	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
582956	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
582957	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
582958	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
582959	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
582960	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
582961	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
582962	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
582963	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
582964	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
582965	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
582966	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Follow-up Action Required?	n	
582967	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Follow-up Action Required?	n	
582968	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Foundation Condition	Good	
582969	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	General Comments		
582970	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	General Comments		
582971	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Grounds in Place?	y	
582972	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Heaters (All) Functioning?	y	
582973	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Maintenance Operations	0	
582974	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Moisture and Leak Free?	y	
582975	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Operations Counter AF	278	
582976	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Operations Counter AL	278	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
582977	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
582978	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Switching Operations	0	
582979	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Tank Paint Condition	Good	
582980	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Unknown Operations	0	
582981	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	9 Month Operations	9	
582982	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
582983	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
582984	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
582985	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
582986	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
582987	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	All Connections OK?	y	
582988	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	Follow-up Action Required?	n	
582989	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	General Comments		
582990	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	LTC Operation Checked?	y	
582991	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
582992	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
582993	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
582994	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
582995	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	VRR Time Delay	30	Seconds
582996	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
582997	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
582998	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Bushing Condition	Good	
582999	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Amps C Ø	156.0	
583000	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Amps B Ø	153.0	
583001	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Amps A Ø	140.0	
583002	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
583003	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	28	°F
583004	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
583005	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
583006	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
583007	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
583008	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
583009	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
583010	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
583011	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
583012	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Amps C Ø	80.0	
583013	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Amps B Ø	116.0	
583014	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
583015	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Vegetation	None	
583016	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Amps A Ø	107.0	
583017	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
583018	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
583019	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	General Comments		
583020	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
583021	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	LTC Totalizer Reading	8184.96	kw
583022	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
583023	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
583024	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	42	°C
583025	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	39	°C
583026	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
583027	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
583028	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
583029	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
583030	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
583031	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	General Comments		
583032	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-2.0	psi
583033	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Unknown Operations	0	
583034	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Tank Paint Condition	Good	
583035	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Switching Operations	4	
583036	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
583037	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Operations Counter AL	366	
583038	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
583039	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Mechanism Patrol Inspection	General Comments		
583040	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC As Found Counter	11714	
583041	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC As Left Counter	11725	
583042	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
583043	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BAT000182	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
583044	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BAT000182	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	n	If no, which cells in comments
583045	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BAT000182	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
583046	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BAT000182	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
583047	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BAT000182	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	cell # 21 post seal leak and bad corrosion.	
583048	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BAT000182	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
583049	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BAT000182	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
583050	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BAT000182	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
583051	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
583052	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
583053	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
583054	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
583055	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
583056	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
583057	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
583058	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
583059	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
583060	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
583061	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Amps A Ø	45.2	
583062	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Regulator As Left Counter	104548	
583063	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
583064	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Tank Leaks	None	
583065	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
583066	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
583067	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
583068	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
583069	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
583070	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
583071	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Operations Counter	22	
583072	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
583073	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
583074	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	General Comments		
583075	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
583076	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
583077	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
583078	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
583079	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
583080	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
583081	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
583082	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
583083	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	Follow-up Action Required?	n	
583084	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
583085	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	General Comments		
583086	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
583087	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
583088	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
583089	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
583090	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Positive DC Ground	21.0	VDC
583091	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Negative DC Ground	21.0	VDC
583092	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	General Comments		
583093	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
583094	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
583095	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
583096	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
583097	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
583098	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
583099	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
583100	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
583101	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
583102	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
583103	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
583104	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Reading	.8526	
583105	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
583106	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
583107	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
583108	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
583109	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
583110	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
583111	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
583112	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Current Tap Position	10L	
583113	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
583114	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BAT000177	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	26.8	VDC
583115	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BAT000177	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
583116	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BAT000177	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
583117	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
583118	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BAT000177	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
583119	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BAT000177	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
583120	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BAT000177	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
583121	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BAT000177	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
583122	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BAT000177	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
583123	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BAT000177	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
583124	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BAT000177	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
583125	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BAT000177	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
583126	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
583127	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
583128	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	General Comments		
583129	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
583130	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Max Tap Position	6L	
583131	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
583132	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
583133	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Min Tap Position	14L	
583134	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
583135	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
583136	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
583137	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
583138	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
583139	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
583140	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
583141	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
583142	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
583143	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
583144	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
583145	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Regulator As Left Counter	189838	
583146	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
583147	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Tank Leaks	None	
583148	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
583149	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BAT000182	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
583150	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BAT000182	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
583151	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BAT000182	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
583152	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC Current Tap Position	4L	
583153	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BAT000182	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
583154	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BAT000182	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
583155	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BAT000182	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
583156	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC Max Tap Position	4R	
583157	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC Min Tap Position	9L	
583158	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC Operations Since Last Insp	736	
583159	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
583160	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
583161	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
583162	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
583163	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
583164	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
583165	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
583166	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	286	
583167	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
583168	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	286	
583169	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
583170	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
583171	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
583172	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	BFTC	
583173	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
583174	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
583175	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
583176	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
583177	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
583178	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	General Comments		
583179	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
583180	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
583181	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
583182	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
583183	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BAT000177	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
583184	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BAT000177	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
583185	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BAT000177	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	28.3	VDC
583186	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
583187	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
583188	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	3R	
583189	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
583190	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
583191	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
583192	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
583193	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments	Indicator does not work	
583194	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
583195	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
583196	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
583197	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
583198	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
583199	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Operations A Ø	0	
583200	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
583201	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
583202	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
583203	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
583204	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
583205	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
583206	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
583207	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
583208	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
583209	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
583210	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	Oil Temp Present	45	°C
583211	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	Oil Temp Max	50	°C
583212	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
583213	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
583214	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	LTC Totalizer Reading	4164.48	kw
583215	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
583216	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	General Comments		
583217	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	General Comments		
583218	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
583219	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
583220	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
583221	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
583222	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Bushing Condition	Good	
583223	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Amps C Ø	330.0	
583224	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Amps B Ø	320.0	
583225	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Amps A Ø	320.0	
583226	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
583227	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
583228	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
583229	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
583230	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
583231	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Vegetation	None	
583232	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
583233	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
583234	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
583235	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
583236	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
583237	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
583238	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0028	
583239	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Amps B Ø	120.0	
583240	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Amps C Ø	160.0	
583241	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Bushing Condition	Good	
583242	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Bushings Connection/Risers	Good	
583243	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
583244	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
583245	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
583246	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Cabinet Paint Condition	Good	
583247	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Tank Paint Condition	Good	
583248	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Unknown Operations	0	
583249	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BCH001051	Charger	689-Battery Charger	Battery Charger Patrol Insp	General Comments		
583250	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BCH001051	Charger	689-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
583251	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
583252	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
583253	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
583254	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
583255	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
583256	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	General Comments		
583257	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	General Comments		
583258	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
583259	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
583260	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
583261	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
583262	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	7220.16	kw
583263	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
583264	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
583265	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BCH001051	Charger	689-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
583266	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BCH001051	Charger	689-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
583267	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BCH001051	Charger	689-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
583268	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	BAT000560	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
583269	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	BAT000560	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
583270	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	BAT000560	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	16.0	VDC
583271	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	BAT000560	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
583272	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	BAT000560	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
583273	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	BAT000560	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
583274	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
583275	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
583276	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	Totalizer Meter Reading	.4338	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
583277	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
583278	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
583279	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
583280	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
583281	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
583282	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
583283	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Oil Temp Max	33	°C
583284	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Oil Temp Present	10	°C
583285	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
583286	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
583287	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.2	VDC
583288	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
583289	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
583290	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
583291	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
583292	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
583293	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
583294	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
583295	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
583296	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
583297	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
583298	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
583299	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
583300	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
583301	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
583302	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
583303	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
583304	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Max Tap Position	16R	
583305	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	General Comments		
583306	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	General Comments		
583307	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
583308	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
583309	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
583310	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
583311	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4576.32	kw
583312	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	71.00	
583313	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
583314	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Oil Temp Max	65	°C
583315	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Oil Temp Present	38	°C
583316	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
583317	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
583318	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
583319	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
583320	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
583321	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
583322	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
583323	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
583324	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
583325	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.9068	
583326	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
583327	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
583328	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
583329	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
583330	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Min Tap Position	16L	
583331	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
583332	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
583333	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
583334	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
583335	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Operations Counter	105	
583336	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
583337	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	General Comments		
583338	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
583339	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
583340	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
583341	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
583342	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
583343	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Amps C Ø	39.5	
583344	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Amps B Ø	1.1	
583345	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Equipment Properly Labeled?	y	
583346	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
583347	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
583348	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
583349	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Operations A Ø	0	
583350	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Operations B Ø	0	
583351	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
583352	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Operations Ground	0	
583353	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Follow-up Action Required?	n	
583354	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
583355	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	General Comments		
583356	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
583357	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Follow-up Action Required?	n	
583358	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Foundation Condition	Good	
583359	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	General Comments		
583360	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	General Comments		
583361	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Grounds in Place?	y	
583362	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Maintenance Operations	0	
583363	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Moisture and Leak Free?	y	
583364	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Operations Counter AF	194	
583365	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Operations Counter AL	194	
583366	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Switching Operations	0	
583367	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
583368	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	Follow-up Action Required?	n	
583369	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
583370	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
583371	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
583372	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
583373	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
583374	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
583375	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
583376	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
583377	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
583378	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
583379	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
583380	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Clear of Trash?	y	
583381	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
583382	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
583383	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Ambient Temp	25	°F
583384	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
583385	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	General Comments		
583386	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
583387	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
583388	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
583389	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
583390	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
583391	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
583392	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
583393	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
583394	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	CX0126	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	262	
583395	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	CX0126	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	20.0	
583396	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	CX0126	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	22.0	
583397	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	CX0126	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	18.0	
583398	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	CX0126	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	109	
583399	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	CX0126	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
583400	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	CX0126	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
583401	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	CX0126	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	323	
583402	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	CX0126	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
583403	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	CX0126	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
583404	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	CX0126	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
583405	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	CX0126	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
583406	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	CX0126	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
583407	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
583408	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	General Comments		
583409	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
583410	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
583411	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
583412	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
583413	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
583414	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
583415	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
583416	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
583417	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
583418	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
583419	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
583420	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	
583421	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.5730	
583422	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
583423	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
583424	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Clear of Trash?	y	
583425	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	3.34	%
583426	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
583427	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
583428	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
583429	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
583430	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
583431	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
583432	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
583433	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
583434	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
583435	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
583436	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
583437	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
583438	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
583439	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
583440	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	3.34	%
583441	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	3.34	%
583442	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
583443	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
583444	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
583445	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
583446	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
583447	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
583448	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
583449	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
583450	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
583451	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	BFTC	
583452	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
583453	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
583454	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
583455	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	519	
583456	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	9 Month Operations	1	
583457	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
583458	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
583459	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Operations Counter AL	407	
583460	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Operations Counter AF	407	
583461	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Moisture and Leak Free?	y	
583462	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Maintenance Operations	0	
583463	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Grounds in Place?	y	
583464	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	General Comments	BFTC	
583465	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	General Comments		
583466	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Foundation Condition	Good	
583467	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Follow-up Action Required?	n	
583468	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	Follow-up Action Required?	n	
583469	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Follow-up Action Required?	n	
583470	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Operations Ground	2	
583471	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Operations C Ø	0	
583472	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Operations B Ø	0	
583473	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Operations A Ø	0	
583474	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
583475	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
583476	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
583477	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
583478	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
583479	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	General Comments		
583480	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
583481	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
583482	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Foundation Condition	Good	
583483	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
583484	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
583485	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Equipment Properly Labeled?	y	
583486	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Cabinet Paint Condition	Good	
583487	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
583488	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
583489	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
583490	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
583491	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
583492	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
583493	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
583494	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	190294	
583495	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.4	volts
583496	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
583497	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
583498	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	All Connections OK?	y	
583499	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	BFTC	
583500	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
583501	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
583502	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
583503	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Vegetation	None	
583504	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
583505	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	296	
583506	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	296	
583507	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
583508	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
583509	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
583510	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
583511	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC As Left Counter	21788	
583512	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
583513	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC Current Tap Position	5L	
583514	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC Max Tap Position	2R	
583515	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC Min Tap Position	12L	
583516	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	°C
583517	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC Operations Since Last Insp	666	
583518	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
583519	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
583520	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	13	
583521	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
583522	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
583523	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
583524	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
583525	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
583526	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
583527	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
583528	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
583529	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
583530	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
583531	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
583532	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
583533	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
583534	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	General Comments		
583535	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
583536	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Vegetation	None	
583537	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
583538	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
583539	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
583540	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
583541	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Operations A Ø	0	
583542	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Operations B Ø	0	
583543	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Operations C Ø	0	
583544	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Operations Ground	0	
583545	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Follow-up Action Required?	n	
583546	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Follow-up Action Required?	n	
583547	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Foundation Condition	Good	
583548	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	General Comments		
583549	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	General Comments		
583550	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Grounds in Place?	y	
583551	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
583552	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Maintenance Operations	0	
583553	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
583554	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
583555	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
583556	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
583557	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
583558	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Operations Counter AF	231	
583559	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
583560	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
583561	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
583562	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
583563	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Operations Counter AL	232	
583564	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Switching Operations	1	
583565	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Tank Paint Condition	Good	
583566	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Unknown Operations	0	
583567	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	Follow-up Action Required?	n	
583568	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Amps C Ø	0.0	
583569	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
583570	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
583571	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
583572	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
583573	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Bushings Connection/Risers	Good	
583574	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	General Comments		
583575	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
583576	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
583577	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Amps C Ø	160.0	
583578	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Amps B Ø	120.0	
583579	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Amps A Ø	120.0	
583580	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
583581	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
583582	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
583583	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
583584	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
583585	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
583586	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
583587	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Max Tap Position	3L	
583588	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Min Tap Position	16L	
583589	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
583590	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Amps A Ø	352.0	
583591	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Amps B Ø	325.0	
583592	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Amps C Ø	335.0	
583593	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
583594	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
583595	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
583596	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
583597	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
583598	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
583599	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
583600	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	CX0126	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
583601	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
583602	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
583603	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
583604	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	Oil Temp Present	29	°C
583605	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	Follow-up Action Required?	n	
583606	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
583607	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	General Comments		
583608	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	General Comments		
583609	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC As Found Counter	108721	
583610	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	CX0126	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
583611	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
583612	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
583613	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
583614	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
583615	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
583616	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Current Tap Position	6L	
583617	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
583618	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
583619	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
583620	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
583621	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
583622	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
583623	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
583624	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
583625	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
583626	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC As Left Counter	108721	
583627	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
583628	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC Current Tap Position	8L	
583629	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC Max Tap Position	1L	
583630	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC Min Tap Position	12L	
583631	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC Operations Since Last Insp	753	
583632	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
583633	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
583634	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
583635	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
583636	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
583637	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
583638	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
583639	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
583640	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
583641	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
583642	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
583643	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Clear of Trash?	y	
583644	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
583645	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
583646	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
583647	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
583648	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
583649	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
583650	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
583651	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
583652	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Bushing Condition	Good	
583653	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
583654	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
583655	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
583656	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
583657	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Max Tap Position	9L	
583658	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
583659	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
583660	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
583661	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
583662	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
583663	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
583664	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
583665	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Regulator As Left Counter	105890	
583666	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
583667	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Tank Leaks	None	
583668	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
583669	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
583670	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Regulator As Left Counter	46446	
583671	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
583672	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
583673	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
583674	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
583675	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Counter Readings	General Comments		
583676	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
583677	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	15058	
583678	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	15068	
583679	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Tank Leaks	None	
583680	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
583681	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
583682	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC As Left Counter	2900	
583683	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC As Found Counter	2896	
583684	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
583685	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000591	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
583686	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000591	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
583687	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
583688	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
583689	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Mechanism Patrol Inspection	General Comments		
583690	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	General Comments		
583691	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
583692	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
583693	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
583694	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
583695	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
583696	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
583697	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	BFTC	
583698	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
583699	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
583700	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
583701	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
583702	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Broom on Site?	n	
583703	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Control House Lighting OK?	y	
583704	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
583705	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Doors and Locks Secure?	y	
583706	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Evidence of Insects	None	
583707	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
583708	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	367	
583709	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	367	
583710	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
583711	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
583712	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
583713	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
583714	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000591	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
583715	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000591	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
583716	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000591	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
583717	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000591	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
583718	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000591	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
583719	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
583720	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
583721	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
583722	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
583723	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
583724	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
583725	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Regulator As Left Counter	119558	
583726	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
583727	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
583728	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
583729	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	LTC Operation Checked?	y	
583730	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	General Comments		
583731	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
583732	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	Follow-up Action Required?	n	
583733	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
583734	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
583735	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
583736	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
583737	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
583738	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
583739	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
583740	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
583741	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
583742	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	General Comments		
583743	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
583744	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
583745	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
583746	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
583747	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
583748	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
583749	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
583750	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
583751	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	General Comments		
583752	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	14	
583753	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	20.17	%
583754	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	19.50	%
583755	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	18.83	%
583756	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
583757	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	
583758	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
583759	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
583760	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
583761	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
583762	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
583763	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
583764	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
583765	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
583766	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
583767	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
583768	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
583769	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
583770	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
583771	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
583772	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
583773	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
583774	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
583775	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
583776	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Tank Leaks	None	
583777	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
583778	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
583779	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
583780	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
583781	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
583782	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
583783	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	General Comments		
583784	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
583785	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
583786	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
583787	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
583788	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
583789	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
583790	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
583791	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
583792	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
583793	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
583794	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
583795	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
583796	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
583797	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Foundation Condition	Good	
583798	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
583799	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
583800	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
583801	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
583802	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
583803	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
583804	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
583805	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
583806	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
583807	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
583808	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
583809	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	General Comments		
583810	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
583811	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
583812	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
583813	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
583814	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	2L	
583815	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	3R	
583816	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	12L	
583817	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	9 Month Operations	2	
583818	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
583819	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
583820	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
583821	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Amps A Ø	0.0	
583822	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
583823	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
583824	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Amps B Ø	0.0	
583825	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
583826	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
583827	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
583828	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
583829	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC Operations Since Last Insp	588	
583830	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	18	°C
583831	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	°C
583832	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC Min Tap Position	11L	
583833	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC Max Tap Position	1L	
583834	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC Current Tap Position	1L	
583835	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
583836	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC As Left Counter	41648	
583837	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC As Found Counter	41648	
583838	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	General Comments		
583839	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	General Comments		
583840	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
583841	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
583842	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
583843	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
583844	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
583845	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Unknown Operations	0	
583846	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Tank Paint Condition	Good	
583847	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Switching Operations	4	
583848	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
583849	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000591	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
583850	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
583851	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
583852	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
583853	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
583854	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
583855	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
583856	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
583857	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
583858	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
583859	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
583860	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
583861	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	n	
583862	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
583863	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
583864	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Current Tap Position	6R	
583865	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
583866	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
583867	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
583868	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
583869	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
583870	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	General Comments		
583871	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
583872	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Max Tap Position	15R	
583873	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
583874	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
583875	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
583876	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
583877	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
583878	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
583879	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Regulator As Left Counter	106031	
583880	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
583881	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Tank Leaks	None	
583882	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
583883	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
583884	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
583885	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
583886	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Floor Condition Acceptable?	y	
583887	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Floor Swept?	n	
583888	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	Follow-up Action Required?	n	
583889	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
583890	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	General Comments		
583891	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	General Comments		
583892	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC As Found Counter	21780	
583893	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
583894	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
583895	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	General Comments		
583896	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
583897	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
583898	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
583899	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
583900	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
583901	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	140.0	
583902	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
583903	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
583904	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
583905	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
583906	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
583907	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
583908	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
583909	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
583910	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
583911	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
583912	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
583913	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
583914	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
583915	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
583916	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
583917	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
583918	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
583919	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
583920	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Moisture and Leak Free?	y	
583921	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Operations Counter AF	181	
583922	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Operations Counter AL	181	
583923	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Switching Operations	0	
583924	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Tank Paint Condition	Good	
583925	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Unknown Operations	0	
583926	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
583927	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
583928	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
583929	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
583930	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
583931	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
583932	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
583933	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
583934	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
583935	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
583936	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
583937	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
583938	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
583939	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
583940	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
583941	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
583942	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
583943	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
583944	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
583945	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Cabinet Paint Condition	Good	
583946	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Follow-up Action Required?	n	
583947	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
583948	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	General Comments	House needs new heater	
583949	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Moisture and Leak Free?	y	
583950	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Ventilation Free of Debris?	y	
583951	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
583952	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
583953	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
583954	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
583955	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
583956	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
583957	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
583958	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
583959	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
583960	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
583961	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
583962	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
583963	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
583964	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
583965	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
583966	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
583967	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
583968	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	39.83	%
583969	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	39.08	%
583970	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	39.83	%
583971	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
583972	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
583973	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
583974	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
583975	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
583976	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
583977	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Operations A Ø	0	
583978	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Operations B Ø	0	
583979	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	General Comments		
583980	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
583981	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
583982	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
583983	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
583984	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
583985	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
583986	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
583987	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
583988	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	313	
583989	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	313	
583990	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
583991	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
583992	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
583993	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
583994	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
583995	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
583996	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
583997	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
583998	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	General Comments		
583999	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
584000	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
584001	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
584002	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
584003	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
584004	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
584005	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Foundation Condition	Good	
584006	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
584007	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
584008	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
584009	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	9 Month Operations	6	
584010	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Accumulated Fault Duty A Ph V	1.52	%
584011	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Accumulated Fault Duty B Ph V	1.05	%
584012	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Accumulated Fault Duty C Ph V	1.17	%
584013	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Amps A Ø	136.0	
584014	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Amps B Ø	148.0	
584015	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
584016	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
584017	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
584018	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	BFTC	
584019	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
584020	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Amps C Ø	120.0	
584021	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Bushing Condition	Good	
584022	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Bushings Connection/Risers	Good	
584023	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
584024	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
584025	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
584026	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
584027	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Equipment Properly Labeled?	y	
584028	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
584029	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
584030	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
584031	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Operations A Ø	0	
584032	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Operations B Ø	0	
584033	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Operations C Ø	0	
584034	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Operations Ground	0	
584035	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Follow-up Action Required?	n	
584036	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Follow-up Action Required?	n	
584037	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Foundation Condition	Good	
584038	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	General Comments		
584039	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	General Comments		
584040	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Grounds in Place?	y	
584041	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Heaters (All) Functioning?	y	
584042	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Maintenance Operations	1	
584043	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
584044	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Tank Paint Condition	Good	
584045	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Switching Operations	0	
584046	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Operations Counter AL	160	
584047	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Operations Counter AF	160	
584048	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Moisture and Leak Free?	y	
584049	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Maintenance Operations	0	
584050	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
584051	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	16	
584052	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Heaters (All) Functioning?	y	
584053	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Grounds in Place?	y	
584054	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	General Comments		
584055	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	General Comments		
584056	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Foundation Condition	Good	
584057	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Follow-up Action Required?	n	
584058	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Follow-up Action Required?	n	
584059	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Operations Ground	0	
584060	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Operations C Ø	0	
584061	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Operations B Ø	0	
584062	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Operations A Ø	0	
584063	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
584064	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
584065	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
584066	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Equipment Properly Labeled?	y	
584067	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Cabinet Paint Condition	Good	
584068	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
584069	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
584070	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
584071	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Bushings Connection/Risers	Good	
584072	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Bushing Condition	Good	
584073	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Amps C Ø	172.0	
584074	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
584075	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
584076	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
584077	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
584078	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments	Indicator does not work	
584079	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
584080	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
584081	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
584082	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
584083	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
584084	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Amps B Ø	90.0	
584085	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Amps A Ø	139.0	
584086	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Accumulated Fault Duty C Ph V	.96	%
584087	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
584088	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	General Comments		
584089	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
584090	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Accumulated Fault Duty B Ph V	.96	%
584091	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Accumulated Fault Duty A Ph V	.96	%
584092	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	9 Month Operations	2	
584093	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Unknown Operations	0	
584094	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
584095	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Switching Operations	1	
584096	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Operations Counter AL	179	
584097	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Operations Counter AF	178	
584098	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
584099	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Maintenance Operations	0	
584100	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
584101	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
584102	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	General Comments		
584103	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
584104	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
584105	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
584106	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
584107	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
584108	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
584109	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Operations C Ø	0	
584110	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
584111	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
584112	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Vegetation	None	
584113	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
584114	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
584115	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
584116	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
584117	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
584118	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
584119	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
584120	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	3R	
584121	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	3R	
584122	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
584123	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Operations Ground	0	
584124	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Follow-up Action Required?	n	
584125	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Follow-up Action Required?	n	
584126	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Foundation Condition	Good	
584127	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
584128	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	General Comments	Barb wire rusty and some fabric as well	
584129	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
584130	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
584131	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
584132	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
584133	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
584134	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
584135	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
584136	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
584137	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
584138	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
584139	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
584140	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
584141	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
584142	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
584143	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
584144	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
584145	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
584146	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
584147	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
584148	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	99984	
584149	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	99984	
584150	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Tank Leaks	None	
584151	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
584152	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
584153	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Regulator As Left Counter	117137	
584154	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
584155	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
584156	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
584157	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
584158	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
584159	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
584160	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
584161	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
584162	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
584163	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
584164	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
584165	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
584166	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
584167	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	125.0	
584168	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
584169	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	118.0	
584170	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
584171	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
584172	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
584173	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Unknown Operations	0	
584174	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Follow-up Action Required?	n	
584175	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Follow-up Action Required?	n	
584176	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
584177	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	General Comments		
584178	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	General Comments	BFTC	
584179	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Grounds in Place?	y	
584180	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.1824	
584181	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
584182	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
584183	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
584184	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
584185	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
584186	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
584187	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
584188	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Present	35	°C
584189	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Max	55	°C
584190	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
584191	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
584192	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Maintenance Operations	0	
584193	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Moisture and Leak Free?	y	
584194	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Operations Counter AF	187	
584195	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Operations Counter AL	187	
584196	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
584197	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Switching Operations	1	
584198	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Tank Paint Condition	Good	
584199	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Unknown Operations	0	
584200	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
584201	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
584202	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	LTC Operation Checked?	y	
584203	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Tank Leaks	None	
584204	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
584205	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
584206	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Regulator As Left Counter	142825	
584207	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
584208	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
584209	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
584210	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Unknown Operations	0	
584211	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Tank Paint Condition	Good	
584212	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Switching Operations	0	
584213	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Operations Counter AL	171	
584214	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Operations Counter AF	171	
584215	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Moisture and Leak Free?	y	
584216	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Maintenance Operations	0	
584217	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Heaters (All) Functioning?	y	
584218	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Grounds in Place?	y	
584219	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	General Comments		
584220	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	General Comments		
584221	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Foundation Condition	Good	
584222	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Follow-up Action Required?	n	
584223	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Follow-up Action Required?	n	
584224	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Operations Ground	0	
584225	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Operations C Ø	0	
584226	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	General Comments		
584227	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	Follow-up Action Required?	n	
584228	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	All Connections OK?	y	
584229	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
584230	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Operations B Ø	0	
584231	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Operations A Ø	0	
584232	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
584233	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
584234	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
584235	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	60	°C
584236	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	Oil Temp Max	65	°C
584237	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
584238	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
584239	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
584240	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Accumulated Fault Duty C Ph V	14.53	%
584241	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Accumulated Fault Duty B Ph V	15.22	%
584242	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Accumulated Fault Duty A Ph V	14.53	%
584243	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	9 Month Operations	17	
584244	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
584245	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Operations A Ø	0	
584246	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Operations B Ø	0	
584247	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Operations C Ø	0	
584248	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Operations Ground	0	
584249	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
584250	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
584251	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
584252	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
584253	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
584254	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Regulator As Left Counter	96349	
584255	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
584256	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Tank Leaks	None	
584257	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
584258	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	9 Month Operations	6	
584259	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BCH001134	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
584260	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BCH001134	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
584261	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
584262	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Follow-up Action Required?	n	
584263	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	9 Month Operations	12	
584264	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Accumulated Fault Duty A Ph V	50.34	%
584265	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Accumulated Fault Duty B Ph V	51.85	%
584266	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BCH001134	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
584267	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BCH001134	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
584268	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	BCH001134	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
584269	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Accumulated Fault Duty A Ph V	.62	%
584270	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Accumulated Fault Duty C Ph V	53.35	%
584271	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC Max Tap Position	1R	
584272	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC Min Tap Position	12L	
584273	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
584274	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
584275	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
584276	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Amps A Ø	70.0	
584277	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Amps B Ø	68.0	
584278	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
584279	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
584280	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
584281	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
584282	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
584283	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Amps C Ø	58.0	
584284	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Bushing Condition	Good	
584285	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Bushings Connection/Risers	Good	
584286	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
584287	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
584288	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
584289	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
584290	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
584291	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Cabinet Paint Condition	Good	
584292	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Equipment Properly Labeled?	y	
584293	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
584294	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	VRR Time Delay	30	Seconds
584295	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
584296	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
584297	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
584298	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
584299	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
584300	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Operations A Ø	0	
584301	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Operations B Ø	1	
584302	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Operations C Ø	0	
584303	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Operations Ground	0	
584304	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	LTC Operation Checked?	y	
584305	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	General Comments		
584306	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	Follow-up Action Required?	n	
584307	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	All Connections OK?	y	
584308	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
584309	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC Operations Since Last Insp	745	
584310	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
584311	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
584312	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
584313	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
584314	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
584315	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	General Comments		
584316	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
584317	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
584318	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
584319	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
584320	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
584321	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
584322	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
584323	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
584324	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
584325	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
584326	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
584327	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
584328	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Foundation Condition	Good	
584329	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
584330	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
584331	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	General Comments		
584332	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
584333	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
584334	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
584335	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
584336	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
584337	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
584338	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Ambient Temp	27	°F
584339	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
584340	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
584341	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
584342	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
584343	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
584344	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	General Comments		
584345	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
584346	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
584347	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
584348	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
584349	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
584350	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
584351	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
584352	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
584353	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	224	
584354	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	224	
584355	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
584356	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
584357	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
584358	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
584359	2/8/2019 12:37	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
584360	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
584361	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Clear of Trash?	y	
584362	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
584363	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
584364	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
584365	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
584366	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
584367	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
584368	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
584369	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	LTC Totalizer Reading	6050.88	kw
584370	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
584371	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Equipment Properly Labeled?	y	
584372	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Cabinet Paint Condition	Good	
584373	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
584374	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
584375	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
584376	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Bushings Connection/Risers	Good	
584377	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
584378	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
584379	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Bushing Condition	Good	
584380	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Amps C Ø	163.0	
584381	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
584382	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
584383	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
584384	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
584385	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
584386	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
584387	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
584388	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
584389	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
584390	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
584391	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
584392	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	BFTC	
584393	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Amps B Ø	93.0	
584394	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Amps A Ø	77.0	
584395	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Accumulated Fault Duty C Ph V	.48	%
584396	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Accumulated Fault Duty B Ph V	1.43	%
584397	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Accumulated Fault Duty A Ph V	1.43	%
584398	2/8/2019 10:52	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	9 Month Operations	5	
584399	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	6	
584400	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
584401	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	11	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
584402	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	11	
584403	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
584404	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	10	
584405	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
584406	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
584407	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
584408	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
584409	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
584410	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
584411	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
584412	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
584413	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
584414	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	General Comments		
584415	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Amps A Ø	180.0	
584416	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
584417	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	328.32	kw
584418	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Amps B Ø	240.0	
584419	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
584420	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
584421	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Amps C Ø	200.0	
584422	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Bushing Condition	Good	
584423	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Bushings Connection/Risers	Good	
584424	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
584425	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
584426	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
584427	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	General Comments		
584428	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
584429	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
584430	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	Follow-up Action Required?	n	
584431	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	VRR Time Delay	60	Seconds
584432	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
584433	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
584434	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
584435	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
584436	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
584437	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
584438	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
584439	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
584440	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
584441	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
584442	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC As Found Counter	3483	
584443	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
584444	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
584445	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Operations C Ø	0	
584446	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
584447	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Operations Ground	0	
584448	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Follow-up Action Required?	n	
584449	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
584450	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
584451	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
584452	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Follow-up Action Required?	n	
584453	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Foundation Condition	Good	
584454	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
584455	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	General Comments		
584456	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	General Comments		
584457	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
584458	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
584459	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Switching Operations	4	
584460	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
584461	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
584462	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
584463	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
584464	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	9 Month Operations	4	
584465	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	VRR Time Delay	30	Seconds
584466	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
584467	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	Totalizer Meter Reading	1.2606	
584468	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
584469	2/8/2019 14:24	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
584470	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
584471	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	General Comments	Work order has been made to add oil	
584472	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	General Comments		
584473	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
584474	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	Follow-up Action Required?	n	
584475	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
584476	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
584477	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
584478	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Accumulated Fault Duty B Ph V	.32	%
584479	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Accumulated Fault Duty C Ph V	.32	%
584480	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Amps A Ø	64.0	
584481	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
584482	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
584483	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
584484	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
584485	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
584486	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Amps B Ø	50.0	
584487	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Amps C Ø	44.0	
584488	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Bushing Condition	Good	
584489	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
584490	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
584491	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
584492	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
584493	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Grounds in Place?	y	
584494	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Heaters (All) Functioning?	y	
584495	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Maintenance Operations	3	
584496	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Moisture and Leak Free?	y	
584497	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
584498	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
584499	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
584500	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Max Tap Position	8R	
584501	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Operations A Ø	0	
584502	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Operations B Ø	0	
584503	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
584504	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Unknown Operations	0	
584505	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Ambient Temp	27	°F
584506	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
584507	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Tank Paint Condition	Good	
584508	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Switching Operations	5	
584509	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
584510	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Accumulated Fault Duty A Ph V	5.47	%
584511	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	9 Month Operations	21	
584512	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	General Comments		
584513	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	General Comments	BFTC	
584514	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Follow-up Action Required?	n	
584515	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
584516	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
584517	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Operations Counter AL	836	
584518	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Operations Counter AF	831	
584519	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
584520	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Grounds in Place?	y	
584521	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
584522	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
584523	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Maintenance Operations	0	
584524	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Moisture and Leak Free?	y	
584525	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC Max Tap Position	3R	
584526	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Operations Counter AF	37	
584527	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Regulator As Left Counter	118228	
584528	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	BCH000402	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
584529	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	BCH000402	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
584530	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	BCH000402	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
584531	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	BCH000402	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.5	VDC
584532	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
584533	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Operations Counter AL	37	
584534	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
584535	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
584536	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
584537	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
584538	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
584539	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Present	36	°C
584540	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Max	65	°C
584541	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC Current Tap Position	3L	
584542	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
584543	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	General Comments		
584544	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	General Comments		
584545	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
584546	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
584547	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
584548	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
584549	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	2750.40	kw
584550	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
584551	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
584552	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
584553	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
584554	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	General Comments		
584555	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
584556	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
584557	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
584558	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
584559	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2476.80	kw
584560	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
584561	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	Totalizer Meter Reading	.1764	
584562	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC As Left Counter	3493	
584563	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
584564	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
584565	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
584566	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
584567	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	General Comments		
584568	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	General Comments		
584569	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Grounds in Place?	y	
584570	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	General Comments		
584571	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	General Comments		
584572	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
584573	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Operations Counter AF	521	
584574	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Operations Counter AL	521	
584575	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
584576	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
584577	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Switching Operations	1	
584578	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Foundation Condition	Good	
584579	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Tank Paint Condition	Good	
584580	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
584581	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
584582	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
584583	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
584584	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Totalizer Meter Reading	.7990	
584585	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
584586	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
584587	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
584588	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
584589	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
584590	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
584591	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
584592	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Follow-up Action Required?	n	
584593	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Follow-up Action Required?	n	
584594	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Fault Operations Ground	0	
584595	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
584596	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
584597	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
584598	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
584599	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
584600	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
584601	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
584602	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Oil Temp Present	35	°C
584603	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Oil Temp Max	59	°C
584604	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
584605	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
584606	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	LTC Totalizer Reading	5752.80	kw
584607	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
584608	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	General Comments		
584609	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	General Comments		
584610	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
584611	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Unknown Operations	0	
584612	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
584613	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
584614	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
584615	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
584616	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	General Comments		
584617	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
584618	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
584619	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
584620	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
584621	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Fault Operations A Ø	0	
584622	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Fault Operations B Ø	0	
584623	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Fault Operations C Ø	0	
584624	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
584625	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
584626	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
584627	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	Follow-up Action Required?	n	
584628	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
584629	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	General Comments		
584630	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
584631	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
584632	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	99960	
584633	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	99960	
584634	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
584635	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
584636	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
584637	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
584638	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Bushings Connection/Risers	Good	
584639	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
584640	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Min Tap Position	13L	
584641	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Max Tap Position	4L	
584642	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
584643	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
584644	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
584645	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Cabinet Paint Condition	Good	
584646	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	General Comments		
584647	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
584648	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Unknown Operations	0	
584649	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Tank Paint Condition	Good	
584650	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
584651	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
584652	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
584653	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
584654	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
584655	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
584656	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
584657	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Equipment Properly Labeled?	y	
584658	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
584659	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
584660	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
584661	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Tank Paint Condition	Good	
584662	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
584663	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
584664	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
584665	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
584666	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
584667	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
584668	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
584669	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
584670	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC Current Tap Position	7L	
584671	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC Max Tap Position	2R	
584672	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
584673	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Current Tap Position	7L	
584674	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
584675	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Unknown Operations	0	
584676	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
584677	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
584678	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
584679	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC Min Tap Position	10L	
584680	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC Operations Since Last Insp	707	
584681	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
584682	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	LTC Totalizer Reading	1693.44	kw
584683	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
584684	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
584685	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	3R	
584686	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
584687	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Switching Operations	1	
584688	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
584689	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Operations Counter AL	168	
584690	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Operations Counter AF	168	
584691	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Moisture and Leak Free?	y	
584692	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Maintenance Operations	0	
584693	2/8/2019 14:57	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Heaters (All) Functioning?	y	
584694	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0320	
584695	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
584696	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
584697	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
584698	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
584699	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
584700	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
584701	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
584702	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
584703	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Current Tap Position	3R	
584704	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
584705	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
584706	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
584707	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	12.0	
584708	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
584709	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
584710	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Vegetation	None	
584711	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
584712	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
584713	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
584714	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
584715	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
584716	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
584717	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
584718	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
584719	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
584720	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	12.0	
584721	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
584722	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Tank Leaks	None	
584723	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
584724	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Regulator As Left Counter	65599	
584725	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
584726	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
584727	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
584728	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
584729	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
584730	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
584731	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
584732	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
584733	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
584734	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Follow-up Action Required?	n	
584735	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
584736	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.64	%
584737	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
584738	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	General Comments		
584739	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	General Comments		
584740	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
584741	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	LTC Totalizer Reading	12279.60	kw
584742	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
584743	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
584744	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
584745	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
584746	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
584747	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Oil Temp Max	20	°C
584748	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
584749	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
584750	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Oil Temp Present	40	°C
584751	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
584752	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
584753	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
584754	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Tank Leaks	None	
584755	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
584756	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
584757	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
584758	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
584759	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC Operations Since Last Insp	513	
584760	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
584761	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
584762	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
584763	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC Min Tap Position	13L	
584764	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC Max Tap Position	1L	
584765	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC Current Tap Position	6L	
584766	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
584767	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
584768	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
584769	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
584770	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
584771	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
584772	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
584773	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
584774	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
584775	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC As Left Counter	35445	
584776	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
584777	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC As Found Counter	35437	
584778	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	General Comments		
584779	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	General Comments		
584780	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
584781	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
584782	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	130.0	
584783	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	Follow-up Action Required?	n	
584784	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
584785	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	General Comments		
584786	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	3.08	%
584787	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
584788	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
584789	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
584790	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
584791	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
584792	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
584793	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
584794	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
584795	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
584796	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
584797	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
584798	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
584799	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
584800	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	12.0	
584801	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
584802	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
584803	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
584804	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
584805	2/8/2019 13:56	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
584806	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
584807	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
584808	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
584809	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
584810	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
584811	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	General Comments		
584812	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
584813	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
584814	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
584815	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
584816	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
584817	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
584818	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
584819	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
584820	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
584821	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
584822	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
584823	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
584824	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
584825	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
584826	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
584827	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	Oil Temp Max	49	°C
584828	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
584829	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
584830	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
584831	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Bushings Connection/Risers	Good	
584832	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC As Left Counter	95402	
584833	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
584834	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
584835	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
584836	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
584837	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
584838	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Bushing Condition	Good	
584839	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Amps C Ø	77.0	
584840	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
584841	2/8/2019 14:56	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
584842	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
584843	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
584844	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Amps B Ø	78.0	
584845	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Amps A Ø	71.0	
584846	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	13	
584847	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
584848	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Totalizer Meter Reading	.6822	
584849	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Winding Temp Max	20	°C
584850	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
584851	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
584852	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Winding Temp Present	30	°C
584853	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
584854	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
584855	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC Operations Since Last Insp	881	
584856	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
584857	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
584858	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
584859	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC Min Tap Position	10L	
584860	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Clear of Trash?	y	
584861	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Accumulated Fault Duty C Ph V	4.10	%
584862	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
584863	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
584864	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
584865	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Accumulated Fault Duty B Ph V	9.91	%
584866	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
584867	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
584868	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
584869	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
584870	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
584871	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
584872	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
584873	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
584874	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Regulator As Left Counter	98997	
584875	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
584876	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
584877	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
584878	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
584879	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
584880	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
584881	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
584882	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
584883	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	Oil Temp Present	25	°C
584884	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
584885	2/8/2019 10:34	Distribution	Mount Vernon Quarterly Inspection	BCH000402	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.5	VDC
584886	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
584887	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	320.0	
584888	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
584889	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	320.0	
584890	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
584891	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
584892	2/8/2019 12:00	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
584893	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
584894	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
584895	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
584896	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
584897	2/8/2019 11:43	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
584898	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
584899	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Equipment Properly Labeled?	y	
584900	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
584901	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
584902	2/8/2019 15:26	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Cabinet Paint Condition	Good	
584903	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
584904	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
584905	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
584906	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
584907	2/8/2019 16:19	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	315.0	
584908	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
584909	2/8/2019 13:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
584910	2/8/2019 11:48	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Tank Leaks	None	
584911	2/8/2019 13:05	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
584912	2/8/2019 11:52	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
584913	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	PF000122	PowerFuse	ET-12KV TR 6 POT	Disconnect Powerfuse Inspection	General Comments	ok	
584914	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
584915	2/7/2019 12:20	Distribution	International Quarterly Inspection	LTCC000040	LTCControl	IN-TRANS 1	LTC Control Insp	General Comments		
584916	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
584917	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
584918	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
584919	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
584920	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
584921	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
584922	2/7/2019 12:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
584923	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Unknown Operations	0	
584924	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Switching Operations	0	
584925	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Operations Counter AL	339	
584926	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Operations Counter AF	339	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
584927	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Amps C Ø	66.0	
584928	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	Oil Temp Present	27	°C
584929	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Amps B Ø	66.0	
584930	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Amps A Ø	66.0	
584931	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Accumulated Fault Duty C Ph V	.80	%
584932	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	PF000122	PowerFuse	ET-12KV TR 6 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
584933	2/7/2019 12:20	Distribution	International Quarterly Inspection	LTCC000040	LTCControl	IN-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
584934	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
584935	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	Oil Temp Max	30	°C
584936	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Accumulated Fault Duty B Ph V	11.96	%
584937	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Unknown Operations	0	
584938	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Accumulated Fault Duty A Ph V	11.96	%
584939	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	9 Month Operations	1	
584940	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	31	°C
584941	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	27	°C
584942	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	31	°C
584943	2/7/2019 12:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
584944	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Moisture and Leak Free?	y	
584945	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Tank Leaks	None	
584946	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
584947	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
584948	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Operations Counter AF	340	
584949	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Operations Counter AL	341	
584950	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Switching Operations	3	
584951	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Tank Paint Condition	Good	
584952	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Unknown Operations	0	
584953	2/7/2019 12:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
584954	2/7/2019 12:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
584955	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1100	psi
584956	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Operations Counter AF	210	
584957	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Maintenance Operations	0	
584958	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Operations Counter AL	210	
584959	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
584960	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	27	°C
584961	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	31	°C
584962	2/7/2019 12:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
584963	2/7/2019 12:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
584964	2/7/2019 12:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
584965	2/7/2019 12:20	Distribution	International Quarterly Inspection	LTCC000040	LTCControl	IN-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
584966	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Switching Operations	0	
584967	2/7/2019 12:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
584968	2/7/2019 12:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
584969	2/7/2019 12:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
584970	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	General Comments		
584971	2/7/2019 12:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
584972	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	9 Month Operations	11	
584973	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	27	°C
584974	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Accumulated Fault Duty A Ph V	6.73	%
584975	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Patrol Inspection	Equipment Properly Labeled?	y	
584976	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
584977	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Adjusted Amps A Phase V	33.54	
584978	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Adjusted Amps B Phase V	33.54	
584979	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Adjusted Amps C Phase V	33.54	
584980	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Operations A Ø	3	
584981	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Operations B Ø	3	
584982	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Operations C Ø	3	
584983	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Operations Ground	0	
584984	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Patrol Inspection	Follow-up Action Required?	n	
584985	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Follow-up Action Required?	n	
584986	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Patrol Inspection	General Comments		
584987	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	General Comments	NO TARGETS BUT DCC SAID STORM HIT AND RELAYED CIRCUIT	
584988	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Maintenance Operations	0	
584989	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Operations Counter AF	681	
584990	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Operations Counter AL	681	
584991	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Switching Operations	0	
584992	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Unknown Operations	0	
584993	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	9 Month Operations	0	
584994	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
584995	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LTCC000219	LTCControl	CW-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
584996	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LTCC000219	LTCControl	CW-TRANS 1	LTC Control Insp	General Comments		
584997	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LTCC000219	LTCControl	CW-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
584998	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
584999	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
585000	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
585001	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
585002	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
585003	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
585004	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
585005	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
585006	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
585007	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
585008	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
585009	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
585010	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
585011	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
585012	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
585013	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
585014	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	General Comments		
585015	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
585016	2/7/2019 12:20	Distribution	International Quarterly Inspection	PF000174	PowerFuse	IN-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
585017	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
585018	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
585019	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
585020	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0907	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps B Ø	80.0	
585021	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
585022	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
585023	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
585024	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
585025	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
585026	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
585027	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
585028	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Fans Condition	Good	
585029	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Fans Operational?	y	
585030	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Moisture and Leak Free?	y	
585031	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
585032	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
585033	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	9 Month Operations	15	
585034	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Accumulated Fault Duty A Ph V	57.40	%
585035	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Accumulated Fault Duty B Ph V	63.77	%
585036	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Accumulated Fault Duty C Ph V	38.26	%
585037	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Amps A Ø	114.0	
585038	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Amps B Ø	122.0	
585039	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Amps C Ø	120.0	
585040	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
585041	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC Operations Since Last Insp	302	
585042	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC Min Tap Position	12L	
585043	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC Max Tap Position	3R	
585044	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC Current Tap Position	7L	
585045	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
585046	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC As Left Counter	9182	
585047	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC As Found Counter	9182	
585048	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Mechanism Patrol Inspection	General Comments		
585049	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	General Comments		
585050	2/7/2019 12:20	Distribution	International Quarterly Inspection	PF000176	PowerFuse	IN-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
585051	2/7/2019 12:20	Distribution	International Quarterly Inspection	PF000176	PowerFuse	IN-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
585052	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Amps B Ø	100.0	
585053	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Amps A Ø	70.0	
585054	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Accumulated Fault Duty C Ph V	5.77	%
585055	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LTCC000120	LTCControl	ET-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
585056	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LTCC000120	LTCControl	ET-TRANS 2	LTC Control Insp	General Comments		
585057	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LTCC000120	LTCControl	ET-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
585058	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
585059	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
585060	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
585061	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
585062	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	80	°C
585063	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Accumulated Fault Duty B Ph V	8.65	%
585064	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Operations Counter AF	232	
585065	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Operations Counter AL	233	
585066	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
585067	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
585068	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
585069	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
585070	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
585071	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.050	millivolts
585072	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
585073	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
585074	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
585075	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
585076	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
585077	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Unknown Operations	0	
585078	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
585079	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
585080	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	45	°C
585081	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	80	°C
585082	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	45	°C
585083	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	80	°C
585084	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	45	°C
585085	2/7/2019 12:20	Distribution	International Quarterly Inspection	PF000174	PowerFuse	IN-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
585086	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
585087	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
585088	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
585089	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Amps C Ø	0.0	
585090	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Patrol Inspection	Equipment Properly Labeled?	y	
585091	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
585092	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Switching Operations	1	
585093	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Tank Paint Condition	Good	
585094	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Unknown Operations	0	
585095	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
585096	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
585097	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
585098	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
585099	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
585100	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
585101	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
585102	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
585103	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
585104	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
585105	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
585106	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
585107	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
585108	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
585109	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
585110	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Operations A Ø	0	
585111	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Operations B Ø	0	
585112	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Operations C Ø	0	
585113	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Operations Ground	0	
585114	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Follow-up Action Required?	n	
585115	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Follow-up Action Required?	n	
585116	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Foundation Condition	Good	
585117	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	General Comments		
585118	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	General Comments		
585119	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Grounds in Place?	y	
585120	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Maintenance Operations	0	
585121	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
585122	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Operations Counter AF	267	
585123	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Operations Counter AL	267	
585124	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
585125	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Operations A Ø	0	
585126	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Operations B Ø	0	
585127	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Operations C Ø	0	
585128	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Operations Ground	0	
585129	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Patrol Inspection	Follow-up Action Required?	n	
585130	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
585131	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
585132	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Follow-up Action Required?	n	
585133	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	Follow-up Action Required?	n	
585134	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Switching Operations	3	
585135	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
585136	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
585137	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Tank Paint Condition	Good	
585138	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Unknown Operations	0	
585139	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	10	
585140	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Patrol Inspection	General Comments		
585141	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
585142	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	Follow-up Action Required?	n	
585143	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
585144	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
585145	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	General Comments		
585146	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	General Comments		
585147	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
585148	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0907	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps C Ø	60.0	
585149	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0907	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
585150	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0907	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
585151	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
585152	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0907	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
585153	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0907	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
585154	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	NO MOUSE POISON ON TRUCK, WILL NEED PUT DOWN AT LATER TIME	
585155	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Switching Operations	0	
585156	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Operations Counter AL	239	
585157	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Operations Counter AF	239	
585158	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Maintenance Operations	0	
585159	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	General Comments		
585160	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Patrol Inspection	General Comments		
585161	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Follow-up Action Required?	n	
585162	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Patrol Inspection	Follow-up Action Required?	n	
585163	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
585164	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
585165	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
585166	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	General Comments		
585167	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
585168	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
585169	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0907	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
585170	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Amps A Ø	0.0	
585171	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Amps B Ø	0.0	
585172	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
585173	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
585174	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Operations Ground	0	
585175	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Operations C Ø	0	
585176	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Operations B Ø	0	
585177	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Operations A Ø	0	
585178	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
585179	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
585180	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
585181	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Patrol Inspection	Equipment Properly Labeled?	y	
585182	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	9 Month Operations	3	
585183	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
585184	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
585185	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
585186	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Amps A Ø	18.0	
585187	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Amps B Ø	19.0	
585188	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Amps C Ø	18.0	
585189	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Bushing Condition	Good	
585190	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Amps A Ø	0.0	
585191	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
585192	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
585193	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
585194	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	9 Month Operations	0	
585195	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
585196	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	y	
585197	2/7/2019 12:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
585198	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	General Comments		
585199	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	General Comments		
585200	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	120.0	
585201	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	103.0	
585202	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Grounds in Place?	y	
585203	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
585204	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Maintenance Operations	0	
585205	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
585206	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Operations Counter AF	17	
585207	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Operations Counter AL	17	
585208	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	24.09	%
585209	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	25.29	%
585210	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
585211	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	9.64	%
585212	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
585213	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
585214	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
585215	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
585216	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
585217	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
585218	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
585219	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
585220	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
585221	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
585222	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
585223	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Switching Operations	0	
585224	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Tank Paint Condition	Good	
585225	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Unknown Operations	0	
585226	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
585227	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
585228	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
585229	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
585230	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
585231	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	Oil Temp Max	70	°C
585232	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
585233	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
585234	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
585235	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	General Comments		
585236	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
585237	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
585238	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
585239	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
585240	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
585241	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
585242	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
585243	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
585244	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	413	
585245	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	413	
585246	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
585247	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
585248	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
585249	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
585250	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
585251	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
585252	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
585253	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
585254	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
585255	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Clear of Trash?	y	
585256	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
585257	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
585258	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
585259	2/7/2019 12:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
585260	2/7/2019 12:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
585261	2/7/2019 12:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Vegetation	None	
585262	2/7/2019 12:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
585263	2/7/2019 12:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
585264	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Operations Counter AF	20	
585265	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Moisture and Leak Free?	y	
585266	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Maintenance Operations	0	
585267	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Heaters (All) Functioning?	y	
585268	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Grounds in Place?	y	
585269	2/7/2019 12:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
585270	2/7/2019 12:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
585271	2/7/2019 12:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	General Comments		
585272	2/7/2019 12:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
585273	2/7/2019 12:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
585274	2/7/2019 12:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
585275	2/7/2019 12:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
585276	2/7/2019 12:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
585277	2/7/2019 12:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
585278	2/7/2019 12:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Clear of Trash?	y	
585279	2/7/2019 12:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
585280	2/7/2019 12:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
585281	2/7/2019 12:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
585282	2/7/2019 12:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
585283	2/7/2019 12:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	General Comments		
585284	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
585285	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Unknown Operations	0	
585286	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Accumulated Fault Duty C Ph V	2.23	%
585287	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Accumulated Fault Duty B Ph V	1.79	%
585288	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
585289	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
585290	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
585291	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	127.0	
585292	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Accumulated Fault Duty A Ph V	2.23	%
585293	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	9 Month Operations	5	
585294	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
585295	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
585296	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
585297	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
585298	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	146	
585299	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
585300	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
585301	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
585302	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC As Found Counter	92397	
585303	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC As Left Counter	92397	
585304	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
585305	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
585306	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
585307	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
585308	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
585309	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
585310	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
585311	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
585312	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
585313	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
585314	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
585315	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
585316	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
585317	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
585318	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0907	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AF	498	
585319	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0907	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AL	497	
585320	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
585321	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
585322	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
585323	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
585324	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
585325	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
585326	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
585327	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Bushing Condition	Good	
585328	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Amps C Ø	0.0	
585329	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	18.07	%
585330	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Amps B Ø	0.0	
585331	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Amps A Ø	0.0	
585332	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
585333	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
585334	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
585335	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
585336	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
585337	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
585338	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	9 Month Operations	14	
585339	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
585340	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	18.07	%
585341	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	34	
585342	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Operations Ground	0	
585343	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
585344	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
585345	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Patrol Inspection	General Comments		
585346	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	General Comments		
585347	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Maintenance Operations	0	
585348	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Operations Counter AF	157	
585349	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Operations Counter AL	157	
585350	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Switching Operations	0	
585351	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Operations Counter AL	150	
585352	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Operations Counter AF	154	
585353	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Operations Counter AL	154	
585354	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Operations Counter AF	150	
585355	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0907	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Switching Operations	1	
585356	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC As Left Counter	55841	
585357	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC As Found Counter	55841	
585358	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
585359	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	General Comments		
585360	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0907	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Unknown Operations	0	
585361	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Unknown Operations	0	
585362	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
585363	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Switching Operations	0	
585364	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Maintenance Operations	0	
585365	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
585366	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
585367	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
585368	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
585369	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
585370	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
585371	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
585372	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	11	
585373	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	11	
585374	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	11	
585375	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	88.00	
585376	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	88.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
585377	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
585378	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0907	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
585379	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0907	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
585380	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0907	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
585381	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0907	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
585382	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0907	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
585383	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0907	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	General Comments		
585384	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0907	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	General Comments		
585385	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0907	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Maintenance Operations	0	
585386	2/7/2019 12:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
585387	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	88.00	
585388	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
585389	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	15.21	%
585390	2/7/2019 12:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
585391	2/7/2019 12:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
585392	2/7/2019 12:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
585393	2/7/2019 12:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
585394	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
585395	2/7/2019 12:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
585396	2/7/2019 12:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
585397	2/7/2019 12:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
585398	2/7/2019 12:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
585399	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	PF000080	PowerFuse	CW-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
585400	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	PF000080	PowerFuse	CW-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
585401	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	PF000077	PowerFuse	CW-STA SET NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
585402	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	PF000077	PowerFuse	CW-STA SET NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
585403	2/7/2019 12:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
585404	2/7/2019 12:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
585405	2/7/2019 12:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
585406	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	General Comments		
585407	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	General Comments		
585408	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Foundation Condition	Good	
585409	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Follow-up Action Required?	n	
585410	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Follow-up Action Required?	n	
585411	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Operations Ground	0	
585412	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
585413	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
585414	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
585415	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
585416	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
585417	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
585418	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Operations C Ø	0	
585419	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Operations B Ø	0	
585420	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Operations A Ø	0	
585421	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	General Comments		
585422	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
585423	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
585424	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	General Comments		
585425	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Grounds in Place?	y	
585426	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Maintenance Operations	0	
585427	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Moisture and Leak Free?	y	
585428	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Amps A Ø	400.0	
585429	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Amps B Ø	430.0	
585430	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Amps C Ø	430.0	
585431	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Bushing Condition	Good	
585432	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
585433	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
585434	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
585435	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
585436	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
585437	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Operations Counter AF	204	
585438	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Operations Counter AL	205	
585439	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Switching Operations	2	
585440	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Tank Paint Condition	Good	
585441	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Unknown Operations	0	
585442	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Tank Paint Condition	Good	
585443	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Unknown Operations	0	
585444	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Switching Operations	0	
585445	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
585446	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Operations Counter AL	20	
585447	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	PF000079	PowerFuse	CW-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
585448	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	PF000079	PowerFuse	CW-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
585449	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
585450	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
585451	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
585452	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
585453	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Fault Operations A Ø	0	
585454	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Fault Operations B Ø	0	
585455	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Fault Operations C Ø	0	
585456	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Fault Operations Ground	0	
585457	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	9 Month Operations	1	
585458	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	5.78	%
585459	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	5.78	%
585460	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Maintenance Operations	0	
585461	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Heaters (All) Functioning?	y	
585462	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Grounds in Place?	y	
585463	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	General Comments		
585464	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	General Comments		
585465	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Foundation Condition	Good	
585466	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	5.78	%
585467	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Amps A Ø	230.0	
585468	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Amps B Ø	230.0	
585469	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Amps C Ø	230.0	
585470	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
585471	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
585472	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Follow-up Action Required?	n	
585473	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Follow-up Action Required?	n	
585474	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Fault Operations Ground	0	
585475	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
585476	2/7/2019 12:20	Distribution	International Quarterly Inspection	LTCC000039	LTCControl	IN-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
585477	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Maintenance Operations	0	
585478	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	General Comments	CIRCUIT RELAYED DURING STORM,NO TARGETS SHOWING	
585479	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Patrol Inspection	General Comments		
585480	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Follow-up Action Required?	n	
585481	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Patrol Inspection	Follow-up Action Required?	n	
585482	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Operations Ground	0	
585483	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Operations C Ø	2	
585484	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Operations B Ø	2	
585485	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Operations A Ø	2	
585486	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Adjusted Amps C Phase AM	22.36	
585487	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Adjusted Amps B Phase AM	22.36	
585488	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Adjusted Amps A Phase AM	22.36	
585489	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
585490	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Amps C Ø	205.0	
585491	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Amps B Ø	200.0	
585492	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Amps A Ø	190.0	
585493	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Accumulated Fault Duty C Ph AM	13.25	%
585494	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Accumulated Fault Duty B Ph AM	13.25	%
585495	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Accumulated Fault Duty A Ph AM	10.84	%
585496	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	9 Months Operations	9	
585497	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	9 Month Operations	30	
585498	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Accumulated Fault Duty A Ph V	4.19	%
585499	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
585500	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
585501	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
585502	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
585503	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	General Comments		
585504	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Accumulated Fault Duty B Ph V	.84	%
585505	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Accumulated Fault Duty C Ph V	7.54	%
585506	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
585507	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
585508	2/7/2019 12:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	General Comments	Foundation on one A frame is crumbling. Photo sent to T. Goodner.	
585509	2/7/2019 12:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
585510	2/7/2019 12:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Foundation Condition	Crumbling	
585511	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	9 Month Operations	0	
585512	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
585513	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Amps A Ø	18.0	
585514	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Amps B Ø	17.0	
585515	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Amps C Ø	17.0	
585516	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Bushing Condition	Good	
585517	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Bushings Connection/Risers	Good	
585518	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
585519	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
585520	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
585521	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Cabinet Paint Condition	Good	
585522	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Equipment Properly Labeled?	y	
585523	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
585524	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
585525	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Adjusted Amps C Phase V	15.70	
585526	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
585527	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Operations B Ø	0	
585528	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Operations C Ø	2	
585529	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Operations Ground	0	
585530	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Follow-up Action Required?	n	
585531	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Follow-up Action Required?	n	
585532	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Foundation Condition	Good	
585533	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
585534	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
585535	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
585536	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Bushings Connection/Risers	Good	
585537	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Bushing Condition	Good	
585538	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Amps C Ø	233.0	
585539	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Amps B Ø	252.0	
585540	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Amps A Ø	235.0	
585541	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
585542	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
585543	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
585544	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
585545	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
585546	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
585547	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
585548	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
585549	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
585550	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
585551	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
585552	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
585553	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
585554	2/7/2019 12:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Follow-up Action Required?	y	
585555	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Switching Operations	0	
585556	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Unknown Operations	0	
585557	2/7/2019 12:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
585558	2/7/2019 12:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
585559	2/7/2019 12:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
585560	2/7/2019 12:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
585561	2/7/2019 12:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
585562	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
585563	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
585564	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99993	
585565	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99993	
585566	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
585567	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	IOC on A Phase/ Operation counter did not operate	
585568	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
585569	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	y	
585570	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
585571	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
585572	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Follow-up Action Required?	n	
585573	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Follow-up Action Required?	n	
585574	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Foundation Condition	Good	
585575	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
585576	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
585577	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	1	
585578	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
585579	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
585580	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Vegetation	None	
585581	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
585582	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
585583	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
585584	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	General Comments		
585585	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
585586	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
585587	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
585588	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
585589	2/7/2019 12:20	Distribution	International Quarterly Inspection	LTCC000039	LTCControl	IN-TRANS 2	LTC Control Insp	General Comments		
585590	2/7/2019 12:20	Distribution	International Quarterly Inspection	LTCC000039	LTCControl	IN-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
585591	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Fault Operations C Ø	0	
585592	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
585593	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Operations Counter	95	
585594	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
585595	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
585596	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	General Comments		
585597	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
585598	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
585599	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
585600	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
585601	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	Oil Temp Max	45	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
585602	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	Oil Temp Present	40	°C
585603	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
585604	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
585605	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
585606	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Patrol Inspection	General Comments		
585607	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	General Comments		
585608	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Maintenance Operations	0	
585609	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
585610	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
585611	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Tank Leaks	None	
585612	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
585613	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Operations Counter AF	199	
585614	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Operations Counter AL	199	
585615	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
585616	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
585617	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
585618	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
585619	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
585620	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
585621	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X1 Winding Temp Max	80	°C
585622	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X1 Winding Temp Present	60	°C
585623	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X2 Winding Temp Max	70	°C
585624	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X2 Winding Temp Present	50	°C
585625	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X3 Winding Temp Max	70	°C
585626	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X3 Winding Temp Present	50	°C
585627	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	General Comments		
585628	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
585629	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	10	
585630	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
585631	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
585632	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
585633	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Fault Operations B Ø	0	
585634	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Fault Operations A Ø	0	
585635	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
585636	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
585637	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
585638	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Equipment Properly Labeled?	y	
585639	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Cabinet Paint Condition	Good	
585640	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
585641	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
585642	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
585643	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
585644	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
585645	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	7.28	%
585646	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	13.35	%
585647	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	12.13	%
585648	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	23	
585649	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
585650	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
585651	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
585652	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
585653	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
585654	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Follow-up Action Required?	n	
585655	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Operations Counter AL	269	
585656	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Operations Counter AF	269	
585657	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Maintenance Operations	0	
585658	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	General Comments		
585659	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Patrol Inspection	General Comments		
585660	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Follow-up Action Required?	n	
585661	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Patrol Inspection	Follow-up Action Required?	n	
585662	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Operations Ground	0	
585663	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Operations C Ø	0	
585664	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Operations B Ø	0	
585665	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Operations A Ø	0	
585666	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
585667	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
585668	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
585669	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
585670	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
585671	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
585672	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
585673	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
585674	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
585675	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
585676	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
585677	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
585678	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
585679	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
585680	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations	4	
585681	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	30.80	%
585682	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	30.80	%
585683	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Operations C Ø	5	
585684	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Operations Ground	0	
585685	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Follow-up Action Required?	n	
585686	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Follow-up Action Required?	n	
585687	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
585688	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
585689	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	960	
585690	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	960	
585691	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	30.80	%
585692	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
585693	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
585694	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
585695	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
585696	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
585697	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
585698	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
585699	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	9 Month Operations	1	
585700	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.15	%
585701	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
585702	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.15	%
585703	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.15	%
585704	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps A Ø	25.0	
585705	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
585706	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	General Comments		
585707	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Patrol Inspection	General Comments		
585708	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Follow-up Action Required?	n	
585709	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Patrol Inspection	Follow-up Action Required?	n	
585710	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Operations Ground	0	
585711	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Operations C Ø	0	
585712	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Operations B Ø	0	
585713	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Operations A Ø	0	
585714	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
585715	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
585716	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
585717	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
585718	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Operations A Ø	0	
585719	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	9 Month Operations	66	
585720	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Accumulated Fault Duty A Ph V	83.70	%
585721	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Accumulated Fault Duty B Ph V	65.37	%
585722	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Accumulated Fault Duty C Ph V	70.15	%
585723	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Amps A Ø	106.0	
585724	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Amps B Ø	78.0	
585725	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Amps C Ø	83.0	
585726	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Patrol Inspection	Equipment Properly Labeled?	y	
585727	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Adjusted Amps A Phase V	145.34	
585728	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Adjusted Amps B Phase V	145.34	
585729	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Adjusted Amps C Phase V	145.34	
585730	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Operations A Ø	13	
585731	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Operations B Ø	13	
585732	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Operations C Ø	13	
585733	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Operations Ground	0	
585734	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Patrol Inspection	Follow-up Action Required?	n	
585735	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Follow-up Action Required?	n	
585736	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Patrol Inspection	General Comments		
585737	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	General Comments	NO TARGETS ON RELAYS BUT DCC FOUND MULTIPLE RELAY OPPS BETWEEN LAST RECORDED OC CHANGE	
585738	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Maintenance Operations	0	
585739	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Operations Counter AF	601	
585740	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Operations Counter AL	601	
585741	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Switching Operations	0	
585742	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Unknown Operations	0	
585743	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Operations B Ø	0	
585744	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
585745	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
585746	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	204	
585747	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Operations C Ø	0	
585748	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Operations Ground	0	
585749	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Follow-up Action Required?	n	
585750	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	196	
585751	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
585752	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	General Comments		
585753	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
585754	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
585755	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
585756	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
585757	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
585758	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.900	millivolts
585759	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	33.54	
585760	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	33.54	
585761	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
585762	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	90.0	
585763	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	80.0	
585764	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	85.0	
585765	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Amps B Ø	5.0	
585766	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Amps C Ø	5.0	
585767	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
585768	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
585769	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
585770	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
585771	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Accumulated Fault Duty A Ph V	1.59	%
585772	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	9 Month Operations	1	
585773	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	16	
585774	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
585775	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
585776	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	13.12	%
585777	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	13.12	%
585778	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
585779	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
585780	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	13.12	%
585781	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
585782	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
585783	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	12.0	
585784	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
585785	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10.0	
585786	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	General Comments		
585787	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
585788	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
585789	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	3.0	
585790	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Operations Counter	1766	
585791	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
585792	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Tank Leaks	None	
585793	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
585794	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Foundation Condition	Good	
585795	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	General Comments		
585796	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
585797	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
585798	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
585799	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	General Comments		
585800	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Grounds in Place?	y	
585801	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
585802	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	30	°C
585803	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	40	°C
585804	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
585805	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
585806	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
585807	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	35	°C
585808	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Foundation Condition	Good	
585809	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	General Comments		
585810	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
585811	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
585812	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
585813	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
585814	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
585815	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Heaters (All) Functioning?	y	
585816	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Maintenance Operations	0	
585817	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Moisture and Leak Free?	y	
585818	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Operations Counter AF	300	
585819	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Operations Counter AL	300	
585820	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
585821	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Switching Operations	2	
585822	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Tank Paint Condition	Good	
585823	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Unknown Operations	0	
585824	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	100.0	
585825	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
585826	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
585827	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Patrol Inspection	Equipment Properly Labeled?	y	
585828	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps B Ø	25.0	
585829	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Amps C Ø	0.0	
585830	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Amps B Ø	0.0	
585831	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
585832	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
585833	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
585834	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
585835	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
585836	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
585837	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
585838	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
585839	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
585840	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
585841	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Amps C Ø	50.0	
585842	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Amps B Ø	50.0	
585843	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Amps A Ø	50.0	
585844	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
585845	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Accumulated Fault Duty C Ph AM	30.11	%
585846	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Accumulated Fault Duty B Ph AM	48.18	%
585847	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
585848	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	General Comments		
585849	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	General Comments		
585850	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
585851	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
585852	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
585853	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
585854	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
585855	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
585856	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
585857	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	8104.32	kw
585858	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
585859	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
585860	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
585861	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
585862	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
585863	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Accumulated Fault Duty A Ph AM	45.77	%
585864	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
585865	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
585866	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
585867	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC Operations Since Last Insp	1049	
585868	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC Min Tap Position	6L	
585869	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC Max Tap Position	4R	
585870	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	9 Months Operations	30	
585871	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
585872	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
585873	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
585874	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
585875	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
585876	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
585877	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8442	
585878	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Winding Temp Max	35	°C
585879	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Winding Temp Present	30	°C
585880	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps C Ø	25.0	
585881	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
585882	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
585883	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
585884	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Amps A Ø	5.0	
585885	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
585886	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	LTC Operation Checked?	y	
585887	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	General Comments		
585888	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	Follow-up Action Required?	n	
585889	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	All Connections OK?	y	
585890	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Amps B Ø	76.0	
585891	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Amps C Ø	83.0	
585892	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Patrol Inspection	Equipment Properly Labeled?	y	
585893	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
585894	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
585895	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
585896	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Operations A Ø	1	
585897	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Operations B Ø	1	
585898	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Operations C Ø	1	
585899	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Operations Ground	0	
585900	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Patrol Inspection	Follow-up Action Required?	n	
585901	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
585902	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
585903	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
585904	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Follow-up Action Required?	n	
585905	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Patrol Inspection	General Comments		
585906	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	General Comments	NO TARGETS BUT DCC SAID RELAYED DURING STORM.	
585907	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Maintenance Operations	0	
585908	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Operations Counter AF	405	
585909	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Operations Counter AL	405	
585910	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Switching Operations	0	
585911	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0907	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	9 Month Operations	3	
585912	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Unknown Operations	0	
585913	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
585914	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
585915	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Vent Fans OK?	y	
585916	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
585917	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
585918	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Panels Dusted?	y	
585919	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	3	
585920	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	3	
585921	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
585922	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
585923	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
585924	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Panel Lights OK?	y	
585925	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Moisture and Leak Free?	n	
585926	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
585927	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	General Comments	roof leaks above 1170 and bus pot fuses. pictures sent to tom, brian, jim	
585928	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
585929	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Foundation Condition	Good	
585930	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
585931	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	General Comments		
585932	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
585933	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
585934	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
585935	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	33.54	
585936	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
585937	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
585938	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
585939	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
585940	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
585941	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	9 Month Operations	17	
585942	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
585943	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Follow-up Action Required?	y	
585944	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Switching Operations	0	
585945	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Accumulated Fault Duty B Ph V	1.59	%
585946	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Accumulated Fault Duty C Ph V	1.59	%
585947	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	Follow-up Action Required?	n	
585948	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
585949	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
585950	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
585951	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
585952	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
585953	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	General Comments		
585954	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0907	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps A Ø	80.0	
585955	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
585956	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0907	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	9.33	%
585957	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
585958	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
585959	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
585960	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
585961	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0907	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	7.89	%
585962	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0907	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	9.33	%
585963	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
585964	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	36	°C
585965	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
585966	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC Operations Since Last Insp	466	
585967	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
585968	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
585969	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
585970	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
585971	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
585972	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
585973	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
585974	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
585975	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
585976	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
585977	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	General Comments		
585978	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
585979	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	LTC Totalizer Reading	8501.76	kw
585980	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
585981	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
585982	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	Oil Temp Max	45	°C
585983	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	Oil Temp Present	40	°C
585984	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
585985	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
585986	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
585987	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
585988	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
585989	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
585990	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
585991	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
585992	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	Totalizer Meter Reading	1.1808	
585993	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
585994	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
585995	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
585996	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	3	
585997	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
585998	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
585999	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
586000	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Amps C Ø	283.0	
586001	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Amps B Ø	283.0	
586002	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	VRR Time Delay	60	Seconds
586003	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
586004	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
586005	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Amps A Ø	2.5	
586006	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
586007	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
586008	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
586009	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
586010	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
586011	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC Max Tap Position	11L	
586012	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC Current Tap Position	4L	
586013	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
586014	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC As Left Counter	62640	
586015	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC As Found Counter	62638	
586016	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	General Comments		
586017	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	General Comments		
586018	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
586019	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	Follow-up Action Required?	n	
586020	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
586021	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
586022	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Amps B Ø	.6	
586023	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Amps C Ø	1.6	
586024	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Bushing Condition	Good	
586025	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Bushings Connection/Risers	Good	
586026	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
586027	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
586028	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
586029	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Oil Temp Present	32	°C
586030	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Cabinet Paint Condition	Good	
586031	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Equipment Properly Labeled?	y	
586032	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Adjusted Amps A Phase V	28.62	
586033	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
586034	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Adjusted Amps B Phase V	28.62	
586035	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Oil Temp Max	36	°C
586036	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
586037	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
586038	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	LTC Totalizer Reading	2962.08	kw
586039	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
586040	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Adjusted Amps C Phase V	28.62	
586041	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
586042	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
586043	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Operations A Ø	5	
586044	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	General Comments		
586045	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	General Comments		
586046	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
586047	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Follow-up Action Required?	n	
586048	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
586049	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
586050	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
586051	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
586052	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
586053	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Operations B Ø	5	
586054	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
586055	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	A,B&C Phase IOC and B&C Phase TOC	
586056	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
586057	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	902	
586058	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	902	
586059	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
586060	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
586061	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
586062	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
586063	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
586064	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
586065	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Unknown Operations	0	
586066	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
586067	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
586068	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Evidence of Insects	None	
586069	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
586070	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
586071	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	32	°C
586072	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
586073	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
586074	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Amps A Ø	420.0	
586075	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Amps B Ø	380.0	
586076	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Amps C Ø	380.0	
586077	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Bushing Condition	Good	
586078	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
586079	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
586080	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
586081	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
586082	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
586083	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Amps A Ø	286.0	
586084	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
586085	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
586086	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
586087	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	9 Month Operations	1	
586088	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
586089	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
586090	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
586091	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
586092	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Door Alarms OK?	y	
586093	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
586094	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
586095	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Amps A Ø	70.0	
586096	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Accumulated Fault Duty C Ph V	30.29	%
586097	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Accumulated Fault Duty B Ph V	42.25	%
586098	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Accumulated Fault Duty A Ph V	39.86	%
586099	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
586100	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
586101	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
586102	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	General Comments		
586103	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Amps A Ø	168.0	
586104	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Winding Temp Present	32	°C
586105	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Winding Temp Max	32	°C
586106	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Totalizer Meter Reading	.4114	
586107	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
586108	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
586109	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
586110	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	9 Month Operations	13	
586111	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
586112	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
586113	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
586114	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
586115	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
586116	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Amps B Ø	180.0	
586117	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Amps C Ø	160.0	
586118	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Patrol Inspection	Equipment Properly Labeled?	y	
586119	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	n	
586120	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
586121	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	9 Month Operations	17	
586122	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Accumulated Fault Duty A Ph V	15.26	%
586123	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Accumulated Fault Duty B Ph V	7.63	%
586124	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Accumulated Fault Duty C Ph V	7.94	%
586125	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	y	
586126	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
586127	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
586128	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
586129	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
586130	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
586131	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
586132	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
586133	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Accumulated Fault Duty C Ph V	1.59	%
586134	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Accumulated Fault Duty B Ph V	1.59	%
586135	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Accumulated Fault Duty A Ph V	1.59	%
586136	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LTCC000543	LTCControl	CW-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
586137	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LTCC000543	LTCControl	CW-TRANS 2	LTC Control Insp	General Comments		
586138	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LTCC000543	LTCControl	CW-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
586139	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	9 Month Operations	1	
586140	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
586141	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
586142	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
586143	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
586144	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
586145	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
586146	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
586147	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
586148	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
586149	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
586150	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
586151	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
586152	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
586153	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
586154	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
586155	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
586156	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
586157	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
586158	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
586159	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
586160	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
586161	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	PF000120	PowerFuse	ET-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
586162	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	PF000120	PowerFuse	ET-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
586163	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
586164	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
586165	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
586166	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
586167	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	General Comments		
586168	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Grounds in Place?	y	
586169	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Heaters (All) Functioning?	y	
586170	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Maintenance Operations	0	
586171	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
586172	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
586173	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Moisture and Leak Free?	y	
586174	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Operations Counter AF	164	
586175	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Operations Counter AL	169	
586176	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
586177	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Switching Operations	6	
586178	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Tank Paint Condition	Good	
586179	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
586180	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	General Comments	AMPS IS READING HIGH, ON CHARGER IT SAYS IT SHOULD BE 2.2 AMPS	
586181	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
586182	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
586183	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
586184	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
586185	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	Follow-up Action Required?	n	
586186	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	All Connections OK?	y	
586187	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	3.59	%
586188	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps A Ø	200.0	
586189	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps B Ø	210.0	
586190	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps C Ø	200.0	
586191	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
586192	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
586193	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
586194	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
586195	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
586196	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
586197	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
586198	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
586199	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
586200	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
586201	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
586202	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	General Comments		
586203	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	General Comments		
586204	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Maintenance Operations	0	
586205	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AF	22	
586206	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AL	22	
586207	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Switching Operations	2	
586208	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Unknown Operations	0	
586209	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
586210	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Unknown Operations	0	
586211	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Switching Operations	0	
586212	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Operations Counter AL	158	
586213	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Operations Counter AF	158	
586214	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Maintenance Operations	0	
586215	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	General Comments		
586216	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Patrol Inspection	General Comments		
586217	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	General Comments		
586218	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	General Comments		
586219	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
586220	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Follow-up Action Required?	n	
586221	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Patrol Inspection	Follow-up Action Required?	n	
586222	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Operations Ground	0	
586223	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Operations C Ø	0	
586224	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Operations B Ø	0	
586225	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
586226	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Follow-up Action Required?	n	
586227	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
586228	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	General Comments		
586229	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
586230	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
586231	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
586232	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
586233	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
586234	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Operations A Ø	0	
586235	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
586236	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
586237	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
586238	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Patrol Inspection	Equipment Properly Labeled?	y	
586239	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Amps C Ø	0.0	
586240	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Amps B Ø	0.0	
586241	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	General Comments	NEED 2 4 FOOT BI PIN BULBS ------NO MOUSE POISON ON TRUCK, WILL NEED PUT DOWN AT LATER DATE	
586242	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
586243	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
586244	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Amps A Ø	0.0	
586245	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Bushing Condition	Good	
586246	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
586247	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
586248	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
586249	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
586250	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
586251	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
586252	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
586253	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
586254	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
586255	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
586256	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
586257	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	375.0	
586258	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	350.0	
586259	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
586260	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	350.0	
586261	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
586262	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
586263	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
586264	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
586265	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
586266	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
586267	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Amps C Ø	100.0	
586268	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
586269	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
586270	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
586271	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
586272	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
586273	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
586274	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	9 Month Operations	2	
586275	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Accumulated Fault Duty A Ph V	.94	%
586276	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
586277	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
586278	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Amps A Ø	15.0	
586279	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Amps B Ø	18.0	
586280	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Amps C Ø	17.0	
586281	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Bushing Condition	Good	
586282	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Bushings Connection/Risers	Good	
586283	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
586284	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
586285	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	PF000119	PowerFuse	ET-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
586286	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	PF000119	PowerFuse	ET-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
586287	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
586288	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Cabinet Paint Condition	Good	
586289	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Equipment Properly Labeled?	y	
586290	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
586291	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
586292	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
586293	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Operations A Ø	0	
586294	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Operations B Ø	0	
586295	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Operations C Ø	0	
586296	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Operations Ground	0	
586297	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Follow-up Action Required?	n	
586298	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Follow-up Action Required?	n	
586299	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Foundation Condition	Good	
586300	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	General Comments		
586301	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	General Comments		
586302	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Grounds in Place?	y	
586303	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Heaters (All) Functioning?	y	
586304	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Maintenance Operations	0	
586305	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Unknown Operations	0	
586306	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
586307	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
586308	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
586309	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
586310	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
586311	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
586312	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
586313	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	General Comments		
586314	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
586315	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
586316	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
586317	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
586318	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
586319	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
586320	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
586321	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
586322	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Regulator As Left Counter	44999	
586323	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
586324	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
586325	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Tank Leaks	None	
586326	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
586327	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
586328	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	y	
586329	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	186	
586330	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Bushings Connection/Risers	Good	
586331	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Bushing Condition	Good	
586332	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
586333	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	6.0	amps
586334	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
586335	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
586336	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
586337	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
586338	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	2	
586339	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
586340	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
586341	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
586342	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
586343	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
586344	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
586345	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
586346	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	287	
586347	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	287	
586348	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
586349	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
586350	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
586351	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
586352	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	2	
586353	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
586354	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
586355	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
586356	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
586357	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Breaker is Open. IOC on C Phase	
586358	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
586359	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
586360	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
586361	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
586362	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
586363	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
586364	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	1	
586365	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
586366	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
586367	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
586368	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
586369	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	505	
586370	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
586371	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
586372	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
586373	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
586374	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
586375	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
586376	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
586377	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	505	
586378	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
586379	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
586380	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
586381	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
586382	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Operations Ground	0	
586383	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
586384	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Grounds in Place?	y	
586385	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Heaters (All) Functioning?	y	
586386	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Maintenance Operations	0	
586387	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Moisture and Leak Free?	y	
586388	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
586389	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	PF000078	PowerFuse	CW-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
586390	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
586391	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
586392	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	PF000078	PowerFuse	CW-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
586393	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
586394	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
586395	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
586396	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
586397	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
586398	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC Operations Since Last Insp	511	
586399	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Operations Counter AF	21	
586400	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Operations Counter AL	21	
586401	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
586402	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC Min Tap Position	1L	
586403	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC Max Tap Position	9L	
586404	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
586405	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC Current Tap Position	4L	
586406	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC As Left Counter	292534	
586407	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC As Found Counter	292531	
586408	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Mechanism Patrol Inspection	General Comments		
586409	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	General Comments		
586410	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
586411	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	Follow-up Action Required?	n	
586412	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
586413	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Operations A Ø	0	
586414	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Operations B Ø	0	
586415	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
586416	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Operations C Ø	0	
586417	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Operations Ground	0	
586418	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Follow-up Action Required?	n	
586419	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Follow-up Action Required?	n	
586420	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Foundation Condition	Good	
586421	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC As Left Counter	215317	
586422	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC As Found Counter	215317	
586423	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
586424	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
586425	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
586426	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
586427	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	2.85	%
586428	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	4.75	%
586429	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	4.75	%
586430	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
586431	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
586432	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	General Comments		
586433	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	5	
586434	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
586435	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
586436	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
586437	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
586438	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
586439	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
586440	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
586441	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
586442	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	General Comments		
586443	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
586444	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
586445	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
586446	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
586447	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
586448	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
586449	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
586450	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
586451	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
586452	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
586453	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
586454	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	241	
586455	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	PF000303	PowerFuse	SK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
586456	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	PF000303	PowerFuse	SK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
586457	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
586458	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
586459	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
586460	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
586461	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
586462	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
586463	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
586464	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
586465	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
586466	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	241	
586467	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
586468	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
586469	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Switching Operations	0	
586470	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
586471	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
586472	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
586473	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Readings	TV Winding Temp Present	35	°C
586474	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Readings	TV Winding Temp Max	78	°C
586475	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
586476	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
586477	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
586478	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
586479	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
586480	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
586481	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	Oil Temp Max	30	°C
586482	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
586483	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
586484	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
586485	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
586486	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
586487	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
586488	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
586489	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
586490	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
586491	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
586492	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
586493	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
586494	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
586495	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
586496	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
586497	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
586498	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
586499	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
586500	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
586501	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
586502	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
586503	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
586504	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
586505	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
586506	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Unknown Operations	0	
586507	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	General Comments		
586508	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
586509	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
586510	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
586511	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
586512	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
586513	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	General Comments		
586514	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
586515	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
586516	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
586517	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2000	psi
586518	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	Oil Temp Max	70	°C
586519	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	Oil Temp Present	45	°C
586520	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
586521	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
586522	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
586523	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Operations A Ø	0	
586524	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Operations B Ø	0	
586525	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	n	
586526	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	LTC Totalizer Reading	8259.84	kw
586527	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Operations C Ø	0	
586528	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Operations Ground	0	
586529	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Patrol Inspection	Follow-up Action Required?	n	
586530	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Follow-up Action Required?	n	
586531	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
586532	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Patrol Inspection	General Comments		
586533	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	General Comments		
586534	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Maintenance Operations	0	
586535	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
586536	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
586537	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
586538	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Unknown Operations	0	
586539	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	VRR Time Delay	30	Seconds
586540	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
586541	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
586542	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
586543	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	LTC Operation Checked?	y	
586544	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	General Comments		
586545	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
586546	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
586547	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
586548	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
586549	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Equipment Properly Labeled?	y	
586550	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
586551	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	General Comments		
586552	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	General Comments		
586553	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Maintenance Operations	0	
586554	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AF	99959	
586555	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AL	99959	
586556	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	178	
586557	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	General Comments		
586558	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
586559	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Switching Operations	0	
586560	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	Follow-up Action Required?	n	
586561	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
586562	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
586563	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
586564	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Switching Operations	0	
586565	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Tank Paint Condition	Good	
586566	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Winding Temp Present	30	°C
586567	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
586568	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
586569	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
586570	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	35	°C
586571	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	37	°C
586572	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
586573	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	205.00	
586574	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Winding Temp Max	32	°C
586575	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Totalizer Meter Reading	.8604	
586576	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
586577	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
586578	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	700	psi
586579	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Top Oil Temperature Present	32	°C
586580	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Top Oil Temperature Max	36	°C
586581	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
586582	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
586583	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
586584	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
586585	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
586586	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Readings	LV Winding Temp Present	35	°C
586587	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Readings	LV Winding Temp Max	95	°C
586588	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Readings	HV Winding Temp Present	37	°C
586589	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Readings	HV Winding Temp Max	157	°C
586590	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
586591	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
586592	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
586593	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
586594	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
586595	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
586596	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
586597	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
586598	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
586599	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
586600	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	T0374	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
586601	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	9 Month Operations	3	
586602	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	3.59	%
586603	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	6.46	%
586604	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Cabinet Paint Condition	Good	
586605	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
586606	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
586607	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
586608	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	39.35	%
586609	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	32.41	%
586610	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	42.44	%
586611	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	21	
586612	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
586613	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Clear of Trash?	y	
586614	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
586615	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
586616	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
586617	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	820	
586618	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	General Comments		
586619	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	General Comments		
586620	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Grounds in Place?	y	
586621	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
586622	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Heaters (All) Functioning?	y	
586623	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Maintenance Operations	40	
586624	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Moisture and Leak Free?	y	
586625	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Operations Counter AF	295	
586626	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Operations Counter AL	296	
586627	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Switching Operations	3	
586628	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
586629	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
586630	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
586631	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
586632	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
586633	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
586634	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
586635	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
586636	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	9 Month Operations	1	
586637	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
586638	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
586639	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	General Comments		
586640	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	General Comments		
586641	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Maintenance Operations	0	
586642	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AF	130	
586643	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AL	130	
586644	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Switching Operations	0	
586645	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Unknown Operations	0	
586646	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
586647	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
586648	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Tank Paint Condition	Good	
586649	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Unknown Operations	0	
586650	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
586651	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
586652	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
586653	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
586654	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	General Comments		
586655	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
586656	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
586657	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
586658	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Accumulated Fault Duty B Ph V	7.17	%
586659	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Accumulated Fault Duty C Ph V	3.19	%
586660	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Amps A Ø	285.0	
586661	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Amps B Ø	270.0	
586662	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Amps C Ø	270.0	
586663	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Bushing Condition	Good	
586664	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Bushings Connection/Risers	Good	
586665	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
586666	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
586667	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
586668	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Cabinet Paint Condition	Good	
586669	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
586670	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
586671	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
586672	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Operations B Ø	0	
586673	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Operations C Ø	0	
586674	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
586675	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
586676	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
586677	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
586678	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
586679	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
586680	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Operations Ground	0	
586681	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
586682	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
586683	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Follow-up Action Required?	n	
586684	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	General Comments	DCC SAYS RELAYED DURING STORM	
586685	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR Base Voltage AF	125.0	VAC
586686	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR Base Voltage AL	125.0	VAC
586687	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Follow-up Action Required?	n	
586688	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
586689	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
586690	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Foundation Condition	Good	
586691	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR Time Delay	30	Seconds
586692	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR X Compensation AF	0	Position
586693	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Maintenance Operations	0	
586694	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Operations Counter AF	417	
586695	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LTCC000602	LTCControl	ET-TRANS 6	LTC Control Insp	Follow-up Action Required?	n	
586696	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1467	
586697	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1467	
586698	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
586699	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
586700	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Operations Counter AL	417	
586701	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Switching Operations	0	
586702	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Unknown Operations	0	
586703	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LTCC000602	LTCControl	ET-TRANS 6	LTC Control Insp	General Comments		
586704	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LTCC000602	LTCControl	ET-TRANS 6	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
586705	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	General Comments		
586706	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
586707	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
586708	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	General Comments		
586709	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
586710	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
586711	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
586712	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
586713	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
586714	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
586715	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
586716	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
586717	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Regulator As Left Counter	42743	
586718	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
586719	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
586720	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	General Comments		
586721	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
586722	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
586723	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
586724	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR X Compensation AL	0	Position
586725	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	4	
586726	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	23.10	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
586727	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	23.10	%
586728	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	23.10	%
586729	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
586730	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
586731	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
586732	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
586733	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
586734	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
586735	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
586736	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
586737	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
586738	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
586739	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
586740	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
586741	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
586742	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Switching Operations	0	
586743	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
586744	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Operations A Ø	0	
586745	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Operations B Ø	0	
586746	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Operations C Ø	0	
586747	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Maintenance Operations	0	
586748	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	General Comments		
586749	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	General Comments		
586750	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
586751	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Operations Counter AL	116	
586752	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	General Comments		
586753	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
586754	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
586755	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
586756	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
586757	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
586758	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
586759	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
586760	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
586761	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
586762	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
586763	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps C Ø	200.0	
586764	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps B Ø	210.0	
586765	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps A Ø	200.0	
586766	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	3.59	%
586767	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	10.76	%
586768	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Operations Ground	0	
586769	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Follow-up Action Required?	n	
586770	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Operations Counter AF	116	
586771	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Moisture and Leak Free?	y	
586772	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
586773	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	20.0	
586774	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
586775	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	20.0	
586776	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	20.0	
586777	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
586778	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	186	
586779	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	186	
586780	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
586781	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
586782	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	.95	%
586783	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	.95	%
586784	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	.95	%
586785	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	9	
586786	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Vegetation	None	
586787	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Follow-up Action Required?	n	
586788	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Foundation Condition	Good	
586789	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	General Comments		
586790	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	General Comments		
586791	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Grounds in Place?	y	
586792	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Heaters (All) Functioning?	y	
586793	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	8.61	%
586794	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	9 Month Operations	4	
586795	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Maintenance Operations	0	
586796	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
586797	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
586798	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
586799	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
586800	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
586801	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
586802	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
586803	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
586804	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
586805	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
586806	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
586807	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	35	°C
586808	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	35	°C
586809	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Equipment Properly Labeled?	y	
586810	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
586811	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	40	°C
586812	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	40	°C
586813	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	50	°C
586814	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
586815	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
586816	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
586817	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
586818	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
586819	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
586820	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
586821	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
586822	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
586823	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
586824	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	Oil Temp Present	15	°C
586825	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	Oil Temp Max	20	°C
586826	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
586827	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
586828	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
586829	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	General Comments		
586830	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
586831	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	General Comments		
586832	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
586833	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
586834	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
586835	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
586836	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AL	481	
586837	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AF	481	
586838	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
586839	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
586840	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
586841	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
586842	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
586843	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
586844	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
586845	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
586846	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
586847	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
586848	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
586849	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
586850	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
586851	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Unknown Operations	0	
586852	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Tank Paint Condition	Good	
586853	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
586854	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
586855	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
586856	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
586857	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
586858	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
586859	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
586860	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
586861	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
586862	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Adjusted Amps C Phase V	39.25	
586863	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
586864	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
586865	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Operations A Ø	5	
586866	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Operations B Ø	0	
586867	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Amps B Ø	160.0	
586868	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Amps C Ø	90.0	
586869	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Bushing Condition	Good	
586870	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Bushings Connection/Risers	Good	
586871	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
586872	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
586873	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Operations C Ø	5	
586874	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Operations Ground	0	
586875	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Follow-up Action Required?	n	
586876	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
586877	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
586878	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
586879	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
586880	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
586881	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
586882	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Foundation Condition	Good	
586883	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	General Comments		
586884	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	General Comments		
586885	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Maintenance Operations	0	
586886	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Operations Counter AF	245	
586887	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Operations A Ø	3	
586888	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Operations B Ø	3	
586889	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Operations C Ø	3	
586890	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Operations Ground	0	
586891	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	General Comments		
586892	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Operations Counter AL	245	
586893	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Grounds in Place?	y	
586894	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Maintenance Operations	0	
586895	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Moisture and Leak Free?	y	
586896	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Operations Counter AF	122	
586897	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Operations Counter AL	122	
586898	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Switching Operations	0	
586899	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Tank Paint Condition	Good	
586900	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Switching Operations	0	
586901	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Unknown Operations	0	
586902	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
586903	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Cabinet Paint Condition	Good	
586904	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Equipment Properly Labeled?	y	
586905	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
586906	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
586907	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
586908	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Fault Operations A Ø	0	
586909	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Fault Operations B Ø	0	
586910	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Fault Operations C Ø	0	
586911	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Fault Operations Ground	0	
586912	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Follow-up Action Required?	n	
586913	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Unknown Operations	0	
586914	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
586915	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
586916	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
586917	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	9 Month Operations	0	
586918	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
586919	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	3.47	%
586920	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	5.20	%
586921	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Clear of Trash?	y	
586922	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	3.47	%
586923	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps A Ø	550.0	
586924	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps B Ø	550.0	
586925	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
586926	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
586927	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
586928	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
586929	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
586930	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
586931	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	PF000117	PowerFuse	ET-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
586932	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
586933	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
586934	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
586935	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
586936	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	General Comments		
586937	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
586938	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
586939	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
586940	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
586941	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
586942	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
586943	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
586944	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
586945	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
586946	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
586947	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
586948	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	All Connections OK?	y	
586949	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
586950	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
586951	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
586952	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
586953	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
586954	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
586955	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
586956	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
586957	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
586958	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
586959	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
586960	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
586961	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
586962	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
586963	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Operations B Ø	0	
586964	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Operations C Ø	0	
586965	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Operations Ground	0	
586966	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Patrol Inspection	Follow-up Action Required?	n	
586967	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Follow-up Action Required?	n	
586968	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Patrol Inspection	General Comments		
586969	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Unknown Operations	0	
586970	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Switching Operations	0	
586971	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	9 Month Operations	32	
586972	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Accumulated Fault Duty A Ph V	12.75	%
586973	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Accumulated Fault Duty B Ph V	12.75	%
586974	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Accumulated Fault Duty C Ph V	10.36	%
586975	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Amps A Ø	200.0	
586976	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC Min Tap Position	12L	
586977	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC Max Tap Position	9L	
586978	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
586979	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
586980	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC As Left Counter	209029	
586981	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC As Found Counter	209029	
586982	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
586983	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	PF000117	PowerFuse	ET-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
586984	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	PF000116	PowerFuse	ET-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
586985	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	PF000116	PowerFuse	ET-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
586986	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Adjusted Amps A Phase V	39.25	
586987	2/7/2019 12:20	Distribution	International Quarterly Inspection	PF000193	PowerFuse	IN-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
586988	2/7/2019 12:20	Distribution	International Quarterly Inspection	PF000193	PowerFuse	IN-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
586989	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Patrol Inspection	General Comments		
586990	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
586991	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
586992	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Bushing Condition	Good	
586993	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
586994	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
586995	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
586996	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
586997	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
586998	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
586999	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
587000	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
587001	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
587002	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
587003	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
587004	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
587005	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	8.49	%
587006	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	20.63	%
587007	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
587008	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
587009	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
587010	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
587011	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
587012	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
587013	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
587014	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	9 Month Operations	47	
587015	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Accumulated Fault Duty A Ph V	5.29	%
587016	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Accumulated Fault Duty B Ph V	9.06	%
587017	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Accumulated Fault Duty C Ph V	3.78	%
587018	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Amps A Ø	118.0	
587019	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Amps B Ø	100.0	
587020	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Amps C Ø	109.0	
587021	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Bushing Condition	Good	
587022	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Bushings Connection/Risers	Good	
587023	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
587024	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
587025	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
587026	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
587027	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
587028	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
587029	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Operations Counter AL	82	
587030	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
587031	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Switching Operations	0	
587032	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
587033	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
587034	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
587035	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
587036	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Cabinet Paint Condition	Good	
587037	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Equipment Properly Labeled?	y	
587038	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
587039	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
587040	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
587041	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Tank Paint Condition	Good	
587042	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Unknown Operations	0	
587043	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
587044	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	9.71	%
587045	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	7.28	%
587046	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	12.13	%
587047	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
587048	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
587049	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Operations A Ø	0	
587050	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
587051	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
587052	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
587053	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps C Ø	550.0	
587054	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
587055	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
587056	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
587057	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Patrol Inspection	Follow-up Action Required?	n	
587058	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Follow-up Action Required?	n	
587059	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Follow-up Action Required?	n	
587060	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Foundation Condition	Good	
587061	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	General Comments		
587062	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	General Comments		
587063	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Grounds in Place?	y	
587064	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	General Comments		
587065	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
587066	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
587067	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Unknown Operations	0	
587068	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Tank Paint Condition	Good	
587069	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Switching Operations	1	
587070	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Operations Counter AL	87	
587071	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Operations Counter AF	86	
587072	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Moisture and Leak Free?	y	
587073	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Maintenance Operations	0	
587074	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Grounds in Place?	y	
587075	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	General Comments		
587076	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	General Comments		
587077	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
587078	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
587079	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
587080	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
587081	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Foundation Condition	Good	
587082	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Follow-up Action Required?	n	
587083	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Follow-up Action Required?	n	
587084	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Operations Ground	0	
587085	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Operations C Ø	0	
587086	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Operations B Ø	0	
587087	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Operations A Ø	0	
587088	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
587089	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
587090	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	General Comments		
587091	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
587092	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
587093	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Foundation Condition	Good	
587094	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
587095	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
587096	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Equipment Properly Labeled?	y	
587097	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Cabinet Paint Condition	Good	
587098	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
587099	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
587100	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
587101	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
587102	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Bushing Condition	Good	
587103	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Amps C Ø	2.0	
587104	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Amps B Ø	2.0	
587105	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Amps A Ø	2.0	
587106	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Accumulated Fault Duty C Ph V	2.09	%
587107	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
587108	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Accumulated Fault Duty A Ph V	4.19	%
587109	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	9 Month Operations	1	
587110	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
587111	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Heaters (All) Functioning?	y	
587112	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Maintenance Operations	0	
587113	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Moisture and Leak Free?	y	
587114	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Operations Counter AF	82	
587115	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
587116	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
587117	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0506	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
587118	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
587119	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0506	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	12.20	%
587120	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0506	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	15.78	%
587121	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0506	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	7.17	%
587122	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
587123	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
587124	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
587125	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
587126	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
587127	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Vegetation	None	
587128	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
587129	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Operations B Ø	0	
587130	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Operations C Ø	0	
587131	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Operations Ground	0	
587132	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Follow-up Action Required?	n	
587133	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Follow-up Action Required?	n	
587134	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Foundation Condition	Good	
587135	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	General Comments		
587136	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	General Comments		
587137	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Grounds in Place?	y	
587138	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Heaters (All) Functioning?	y	
587139	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Maintenance Operations	0	
587140	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Moisture and Leak Free?	y	
587141	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Operations Counter AF	163	
587142	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Operations Counter AL	163	
587143	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
587144	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Switching Operations	0	
587145	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Tank Paint Condition	Good	
587146	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Unknown Operations	0	
587147	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
587148	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
587149	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
587150	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
587151	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	820	
587152	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.000	millivolts
587153	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
587154	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
587155	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
587156	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
587157	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
587158	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
587159	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
587160	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
587161	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
587162	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
587163	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
587164	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Broom on Site?	y	
587165	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
587166	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
587167	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
587168	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
587169	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0506	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	140.0	
587170	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0506	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	140.0	
587171	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0506	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	140.0	
587172	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0506	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
587173	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
587174	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
587175	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
587176	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
587177	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
587178	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
587179	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
587180	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
587181	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
587182	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
587183	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
587184	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
587185	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
587186	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
587187	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	74.07	%
587188	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	70.21	%
587189	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
587190	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
587191	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Evidence of Insects	None	
587192	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
587193	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
587194	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
587195	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	67.90	%
587196	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	84.0	
587197	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	84.0	
587198	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	96.0	
587199	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
587200	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
587201	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
587202	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
587203	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
587204	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
587205	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	General Comments		
587206	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Accumulated Fault Duty B Ph V	.94	%
587207	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
587208	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
587209	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
587210	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
587211	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Accumulated Fault Duty A Ph V	1.17	%
587212	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	9 Month Operations	2	
587213	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
587214	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
587215	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
587216	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
587217	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99954	
587218	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99954	
587219	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
587220	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
587221	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
587222	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
587223	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
587224	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
587225	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
587226	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
587227	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
587228	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
587229	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
587230	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
587231	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
587232	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
587233	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
587234	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	19.25	
587235	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
587236	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	19.25	
587237	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	19.25	
587238	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	4	
587239	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	4	
587240	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	4	
587241	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
587242	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
587243	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
587244	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
587245	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
587246	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
587247	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	220.0	
587248	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	220.0	
587249	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	220.0	
587250	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Cabinet Paint Condition	Good	
587251	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
587252	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Door Alarms OK?	y	
587253	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
587254	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Evidence of Insects	None	
587255	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
587256	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
587257	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Floor Swept?	y	
587258	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
587259	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
587260	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
587261	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
587262	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
587263	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
587264	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
587265	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
587266	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
587267	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
587268	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
587269	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
587270	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	General Comments		
587271	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
587272	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
587273	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
587274	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
587275	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
587276	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
587277	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Unknown Operations	0	
587278	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
587279	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
587280	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Patrol Inspection	General Comments		
587281	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	General Comments		
587282	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
587283	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
587284	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
587285	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	General Comments		
587286	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Unknown Operations	0	
587287	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Equipment Properly Labeled?	y	
587288	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
587289	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
587290	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
587291	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC Operations Since Last Insp	861	
587292	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC Min Tap Position	12L	
587293	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
587294	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
587295	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
587296	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
587297	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Maintenance Operations	0	
587298	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Operations Counter AF	2007	
587299	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	64	°F
587300	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
587301	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
587302	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
587303	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
587304	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
587305	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Regulator As Left Counter	44967	
587306	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
587307	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Switching Operations	0	
587308	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Operations Counter AL	2007	
587309	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
587310	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
587311	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	Follow-up Action Required?	n	
587312	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
587313	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	General Comments		
587314	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Mechanism Patrol Inspection	General Comments		
587315	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC As Found Counter	242921	
587316	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC As Left Counter	242926	
587317	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
587318	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC Current Tap Position	9L	
587319	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC Max Tap Position	4L	
587320	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
587321	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	General Comments		
587322	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
587323	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
587324	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Foundation Condition	Good	
587325	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
587326	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
587327	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
587328	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
587329	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
587330	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	6	
587331	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	12.13	%
587332	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
587333	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
587334	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
587335	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	305	
587336	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	313	
587337	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0506	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
587338	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0506	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
587339	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0506	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
587340	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0506	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
587341	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0506	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
587342	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0506	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
587343	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0506	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
587344	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0506	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
587345	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0506	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
587346	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0506	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
587347	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0506	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
587348	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0506	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
587349	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0506	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	544	
587350	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0506	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	544	
587351	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0506	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
587352	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0506	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
587353	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
587354	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	9 Month Operations	0	
587355	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
587356	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
587357	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
587358	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
587359	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Amps A Ø	230.0	
587360	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
587361	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Amps B Ø	300.0	
587362	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Amps C Ø	280.0	
587363	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
587364	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
587365	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
587366	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Broom on Site?	y	
587367	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
587368	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Bushing Condition	Good	
587369	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Bushings Connection/Risers	Good	
587370	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
587371	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
587372	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
587373	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
587374	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
587375	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
587376	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Amps B Ø	265.0	
587377	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Amps C Ø	260.0	
587378	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Bushing Condition	Good	
587379	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Bushings Connection/Risers	Good	
587380	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
587381	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
587382	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
587383	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
587384	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
587385	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
587386	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
587387	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
587388	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
587389	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
587390	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
587391	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
587392	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
587393	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
587394	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	9 Months Operations	1	
587395	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Accumulated Fault Duty A Ph AM	1.20	%
587396	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Accumulated Fault Duty B Ph AM	1.20	%
587397	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Accumulated Fault Duty C Ph AM	1.20	%
587398	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	General Comments		
587399	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
587400	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
587401	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
587402	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
587403	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
587404	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
587405	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
587406	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
587407	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
587408	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
587409	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
587410	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
587411	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Trash Emptied?	y	
587412	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
587413	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
587414	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
587415	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
587416	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
587417	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Follow-up Action Required?	n	
587418	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Operations Ground	0	
587419	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Operations C Ø	0	
587420	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Operations B Ø	0	
587421	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	VRR Time Delay	30	Seconds
587422	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Operations A Ø	0	
587423	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
587424	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
587425	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Panels Dusted?	y	
587426	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
587427	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
587428	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
587429	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
587430	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
587431	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
587432	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Amps A Ø	0.0	
587433	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Amps B Ø	0.0	
587434	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Amps C Ø	0.0	
587435	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
587436	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
587437	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Maintenance Operations	0	
587438	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Heaters (All) Functioning?	y	
587439	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Grounds in Place?	y	
587440	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	General Comments		
587441	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	General Comments		
587442	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Unknown Operations	0	
587443	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Tank Paint Condition	Good	
587444	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Foundation Condition	Good	
587445	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
587446	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	General Comments		
587447	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
587448	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
587449	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Follow-up Action Required?	n	
587450	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
587451	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
587452	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	All Connections OK?	y	
587453	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	Follow-up Action Required?	n	
587454	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	General Comments		
587455	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	LTC Operation Checked?	y	
587456	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Moisture and Leak Free?	y	
587457	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Operations Counter AF	66	
587458	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Operations Counter AL	66	
587459	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
587460	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Switching Operations	0	
587461	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Tank Paint Condition	Good	
587462	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Unknown Operations	0	
587463	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
587464	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
587465	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
587466	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
587467	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
587468	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
587469	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
587470	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
587471	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
587472	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
587473	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
587474	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Tank Leaks	None	
587475	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
587476	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
587477	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
587478	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
587479	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
587480	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	9 Month Operations	9	
587481	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Accumulated Fault Duty A Ph V	3.19	%
587482	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Accumulated Fault Duty B Ph V	2.39	%
587483	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
587484	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Amps A Ø	300.0	
587485	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Switching Operations	1	
587486	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Operations Counter AL	209	
587487	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Operations Counter AF	208	
587488	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Moisture and Leak Free?	y	
587489	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Maintenance Operations	0	
587490	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Heaters (All) Functioning?	y	
587491	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Grounds in Place?	y	
587492	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	General Comments		
587493	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	General Comments		
587494	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Foundation Condition	Good	
587495	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Follow-up Action Required?	n	
587496	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Follow-up Action Required?	n	
587497	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Operations Ground	0	
587498	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Operations C Ø	0	
587499	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Operations B Ø	0	
587500	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Operations A Ø	0	
587501	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	General Comments		
587502	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
587503	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
587504	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
587505	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Vegetation	None	
587506	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
587507	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
587508	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
587509	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
587510	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
587511	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
587512	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
587513	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Foundation Condition	Good	
587514	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
587515	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Winding Temp Present	24	°C
587516	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
587517	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	General Comments		
587518	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
587519	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
587520	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
587521	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
587522	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
587523	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
587524	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
587525	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
587526	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
587527	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
587528	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
587529	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
587530	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Tank Leaks	None	
587531	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Winding Temp Max	26	°C
587532	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
587533	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
587534	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
587535	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
587536	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Trash Emptied?	y	
587537	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Panels Dusted?	y	
587538	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Panel Lights OK?	y	
587539	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0282	
587540	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
587541	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	10500	
587542	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
587543	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
587544	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	General Comments		
587545	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
587546	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	47	
587547	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
587548	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
587549	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
587550	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
587551	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
587552	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
587553	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Oil Temp Present	26	°C
587554	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
587555	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Oil Temp Max	29	°C
587556	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
587557	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
587558	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	296.10	kw
587559	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
587560	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
587561	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
587562	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
587563	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	General Comments		
587564	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	General Comments		
587565	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
587566	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
587567	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
587568	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
587569	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Operations A Ø	0	
587570	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
587571	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
587572	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	General Comments	NO MOUSE POISON ON TRUCK, WILL NEED TO BE PUT DOWN AT LATER DATE	
587573	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
587574	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
587575	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Operations B Ø	0	
587576	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Operations C Ø	0	
587577	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Operations Ground	0	
587578	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Patrol Inspection	Follow-up Action Required?	n	
587579	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Follow-up Action Required?	n	
587580	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
587581	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
587582	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
587583	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
587584	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
587585	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Cabinet Paint Condition	Good	
587586	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Equipment Properly Labeled?	y	
587587	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
587588	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
587589	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
587590	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
587591	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
587592	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
587593	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Patrol Inspection	General Comments		
587594	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	General Comments		
587595	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Maintenance Operations	0	
587596	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Operations Counter AF	110	
587597	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Operations A Ø	0	
587598	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Operations Counter AL	110	
587599	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Switching Operations	0	
587600	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Floor Swept?	y	
587601	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Equipment Properly Labeled?	y	
587602	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Cabinet Paint Condition	Good	
587603	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
587604	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
587605	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
587606	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Bushings Connection/Risers	Good	
587607	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Bushing Condition	Good	
587608	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
587609	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Amps C Ø	114.0	
587610	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Amps B Ø	107.0	
587611	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Amps A Ø	101.0	
587612	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Accumulated Fault Duty C Ph V	.47	%
587613	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
587614	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
587615	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
587616	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
587617	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
587618	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	General Comments		
587619	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
587620	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Ambient Temp	63	°F
587621	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
587622	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
587623	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Clear of Trash?	y	
587624	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
587625	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
587626	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
587627	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
587628	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
587629	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
587630	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
587631	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
587632	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
587633	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
587634	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	General Comments		
587635	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
587636	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	9 Month Operations	1	
587637	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Accumulated Fault Duty A Ph V	.80	%
587638	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Accumulated Fault Duty B Ph V	.80	%
587639	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Accumulated Fault Duty C Ph V	.80	%
587640	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Amps A Ø	1.0	
587641	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Amps B Ø	1.0	
587642	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Amps C Ø	1.0	
587643	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Patrol Inspection	Equipment Properly Labeled?	y	
587644	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
587645	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
587646	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
587647	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
587648	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Max Tap Position	6R	
587649	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Grounds in Place?	y	
587650	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	General Comments		
587651	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
587652	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Foundation Condition	Good	
587653	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
587654	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Operations A Ø	0	
587655	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
587656	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
587657	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Tank Leaks	None	
587658	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
587659	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
587660	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	General Comments		
587661	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
587662	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	LTC Totalizer Reading	13186.80	kw
587663	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
587664	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
587665	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
587666	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Oil Temp Max	50	°C
587667	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Oil Temp Present	45	°C
587668	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
587669	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
587670	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
587671	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
587672	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
587673	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
587674	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Foundation Condition	Good	
587675	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
587676	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	General Comments		
587677	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
587678	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
587679	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	812	
587680	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
587681	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
587682	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
587683	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
587684	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
587685	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
587686	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BCH000401	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
587687	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
587688	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
587689	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
587690	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Reg Oil Level	Good	
587691	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
587692	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
587693	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Regulator As Left Counter	44378	
587694	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
587695	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
587696	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
587697	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
587698	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
587699	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
587700	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
587701	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
587702	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
587703	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
587704	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
587705	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	General Comments		
587706	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
587707	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC As Found Counter	98710	
587708	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
587709	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
587710	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
587711	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC As Left Counter	98710	
587712	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
587713	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC Current Tap Position	12L	
587714	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6L	
587715	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC Min Tap Position	14L	
587716	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
587717	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
587718	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
587719	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
587720	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
587721	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
587722	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
587723	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1150	
587724	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1150	
587725	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
587726	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
587727	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
587728	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BCH000401	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
587729	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BCH000401	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
587730	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BCH000401	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.7	VDC
587731	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BCH000401	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.7	VDC
587732	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BCH000401	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
587733	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
587734	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
587735	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
587736	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
587737	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	63	°F
587738	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
587739	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
587740	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Min Tap Position	2L	
587741	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Amps C Ø	12.0	
587742	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
587743	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
587744	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
587745	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
587746	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
587747	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
587748	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
587749	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
587750	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
587751	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
587752	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
587753	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	Oil Temp Max	38	°C
587754	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
587755	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
587756	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
587757	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
587758	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
587759	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	General Comments		
587760	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
587761	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
587762	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
587763	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	PF000118	PowerFuse	ET-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
587764	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	751	
587765	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC Min Tap Position	16L	
587766	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6L	
587767	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC Current Tap Position	12L	
587768	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
587769	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC As Left Counter	3878	
587770	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC As Found Counter	3878	
587771	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	PF000118	PowerFuse	ET-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
587772	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
587773	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
587774	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
587775	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
587776	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
587777	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Current Tap Position	2R	
587778	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
587779	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
587780	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
587781	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
587782	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
587783	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
587784	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Regulator As Left Counter	4281	
587785	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	NO OIL CUP	
587786	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	General Comments	CAN NOT READ OC, NEEDS REPLACED, I AM GUESSING AT READING.	
587787	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	Follow-up Action Required?	y	
587788	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
587789	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
587790	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
587791	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	PF000302	PowerFuse	SK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
587792	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
587793	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	569	
587794	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
587795	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
587796	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	569	
587797	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
587798	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
587799	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
587800	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
587801	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
587802	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
587803	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Bushing Condition	Good	
587804	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
587805	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
587806	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
587807	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
587808	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Current Tap Position	1R	
587809	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
587810	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
587811	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
587812	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
587813	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	9 Months Operations	27	
587814	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Accumulated Fault Duty A Ph AM	20.48	%
587815	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Accumulated Fault Duty B Ph AM	33.73	%
587816	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Accumulated Fault Duty C Ph AM	26.50	%
587817	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Amps A Ø	12.0	
587818	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Amps B Ø	12.0	
587819	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
587820	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	108.0	
587821	2/7/2019 12:20	Distribution	International Quarterly Inspection	PF000175	PowerFuse	IN-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
587822	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
587823	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
587824	2/7/2019 12:20	Distribution	International Quarterly Inspection	PF000175	PowerFuse	IN-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
587825	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Totalizer Meter Reading	.7326	
587826	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
587827	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
587828	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
587829	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Winding Temp Max	55	°C
587830	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Winding Temp Present	50	°C
587831	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
587832	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
587833	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
587834	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
587835	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
587836	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
587837	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
587838	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
587839	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
587840	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
587841	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
587842	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	General Comments		
587843	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	General Comments	NITRO NEEDS ADDED	
587844	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
587845	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	41	°C
587846	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	33	°C
587847	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
587848	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
587849	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
587850	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	132.0	
587851	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	96.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
587852	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
587853	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
587854	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
587855	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
587856	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
587857	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	Percent Thermal Load Y2 Max	70	%
587858	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	Percent Thermal Load X2 Max	70	%
587859	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
587860	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
587861	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
587862	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
587863	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
587864	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
587865	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
587866	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
587867	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
587868	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
587869	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
587870	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
587871	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
587872	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
587873	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
587874	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
587875	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Amps C Ø	65.0	
587876	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Amps B Ø	65.0	
587877	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Amps A Ø	61.0	
587878	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
587879	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
587880	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1800	psi
587881	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
587882	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
587883	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
587884	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
587885	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Clear of Trash?	y	
587886	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
587887	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
587888	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
587889	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
587890	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
587891	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
587892	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	General Comments		
587893	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
587894	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
587895	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
587896	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
587897	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Vegetation	None	
587898	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
587899	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
587900	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
587901	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	22.0	VDC
587902	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	23.0	VDC
587903	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
587904	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
587905	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
587906	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
587907	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
587908	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
587909	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Switching Operations	0	
587910	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
587911	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	General Comments		
587912	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
587913	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
587914	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
587915	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
587916	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
587917	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
587918	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
587919	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
587920	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
587921	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	6	
587922	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
587923	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	847	
587924	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	842	
587925	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
587926	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
587927	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
587928	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
587929	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
587930	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
587931	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
587932	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
587933	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
587934	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
587935	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
587936	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
587937	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
587938	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
587939	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
587940	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
587941	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1032	
587942	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
587943	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	21	°C
587944	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
587945	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
587946	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
587947	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
587948	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC As Left Counter	46297	
587949	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
587950	2/7/2019 12:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Unknown Operations	0	
587951	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
587952	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
587953	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
587954	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
587955	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
587956	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
587957	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC As Found Counter	46297	
587958	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
587959	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	General Comments		
587960	2/7/2019 12:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
587961	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
587962	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
587963	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
587964	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BCH000194	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	134.4	VDC
587965	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BCH000194	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	3.0	amps
587966	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
587967	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
587968	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
587969	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	3	
587970	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
587971	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
587972	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	General Comments	TRUCK PARKED IN DRIVE AND FRONT GATE CHAIN HAS BEEN BROKE TO GAIN ACCESS	
587973	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
587974	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
587975	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BCH000194	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
587976	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
587977	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	BCH000596	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
587978	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	BCH000596	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
587979	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	BCH000596	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
587980	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	BCH000596	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
587981	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	BCH000596	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
587982	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	BCH000596	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
587983	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
587984	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	51.0	VDC
587985	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	9 Months Operations	2	
587986	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	1.2	VDC
587987	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
587988	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BCH000194	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
587989	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BCH000194	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
587990	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	1	
587991	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	4.81	
587992	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
587993	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Reg Oil Level	Good	
587994	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
587995	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
587996	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
587997	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Amps A Ø	380.0	
587998	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	4.81	
587999	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
588000	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
588001	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
588002	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
588003	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
588004	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
588005	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
588006	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
588007	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Foundation Condition	Good	
588008	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
588009	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	General Comments		
588010	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Grounds in Place?	y	
588011	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Max Tap Position	7R	
588012	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Min Tap Position	3L	
588013	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Amps B Ø	380.0	
588014	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Amps C Ø	420.0	
588015	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
588016	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
588017	2/7/2019 11:51	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
588018	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Vegetation	None	
588019	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
588020	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	General Comments		
588021	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
588022	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
588023	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
588024	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
588025	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
588026	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
588027	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
588028	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
588029	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
588030	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
588031	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
588032	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
588033	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
588034	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
588035	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
588036	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
588037	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
588038	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
588039	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
588040	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	255.0	
588041	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	270.0	
588042	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	255.0	
588043	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
588044	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
588045	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
588046	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
588047	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	.96	%
588048	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.96	%
588049	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
588050	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
588051	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
588052	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
588053	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
588054	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	635	
588055	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
588056	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
588057	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
588058	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	
588059	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
588060	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
588061	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	100.0	
588062	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
588063	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
588064	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
588065	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
588066	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	33.54	
588067	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
588068	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
588069	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
588070	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
588071	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
588072	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	1	
588073	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
588074	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BCH000194	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
588075	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BCH000194	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	134.4	VDC
588076	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Accumulated Fault Duty C Ph V	5.86	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
588077	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
588078	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Reg Oil Level	Good	
588079	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
588080	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
588081	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
588082	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Min Tap Position	1L	
588083	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Max Tap Position	7R	
588084	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Amps A Ø	2.5	
588085	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Grounds in Place?	y	
588086	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	General Comments		
588087	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
588088	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
588089	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
588090	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	4.82	%
588091	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	5	
588092	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Amps B Ø	2.4	
588093	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Foundation Condition	Good	
588094	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
588095	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
588096	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
588097	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
588098	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
588099	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
588100	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
588101	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
588102	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
588103	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Amps C Ø	2.6	
588104	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Bushing Condition	Good	
588105	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
588106	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Bushings Connection/Risers	Good	
588107	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
588108	2/7/2019 12:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
588109	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
588110	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
588111	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
588112	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
588113	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
588114	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
588115	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
588116	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	PF000121	PowerFuse	ET-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	ok	
588117	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	PF000121	PowerFuse	ET-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
588118	2/7/2019 12:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
588119	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
588120	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
588121	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
588122	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
588123	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	173	
588124	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
588125	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
588126	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
588127	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
588128	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
588129	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
588130	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
588131	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	PF000302	PowerFuse	SK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
588132	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
588133	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
588134	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
588135	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
588136	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
588137	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
588138	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
588139	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	33	°C
588140	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	40	°C
588141	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
588142	2/7/2019 12:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Broom on Site?	y	
588143	2/7/2019 12:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
588144	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
588145	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
588146	2/7/2019 12:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
588147	2/7/2019 12:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
588148	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
588149	2/7/2019 12:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
588150	2/7/2019 12:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Evidence of Insects	None	
588151	2/7/2019 12:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
588152	2/7/2019 12:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
588153	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
588154	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
588155	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
588156	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
588157	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
588158	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
588159	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
588160	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	y	
588161	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
588162	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	One leg on aisle heater had a 30A fuse blown. Replaced fuse. Heater is working now. Vent fan motor is burnt up. Being sent out to ge	
588163	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
588164	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
588165	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
588166	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
588167	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
588168	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
588169	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
588170	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
588171	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	n	
588172	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
588173	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
588174	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
588175	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
588176	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
588177	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
588178	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
588179	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	4.85	%
588180	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	60.0	
588181	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	60.0	
588182	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
588183	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	n	
588184	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	33	°C
588185	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	41	°C
588186	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	33	°C
588187	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	42	°C
588188	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
588189	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
588190	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	Rust on floor of both swgrs. Photo sent to Tom.	
588191	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
588192	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
588193	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
588194	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	y	
588195	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
588196	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
588197	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
588198	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
588199	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
588200	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	80.0	
588201	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
588202	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
588203	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
588204	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
588205	2/7/2019 12:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
588206	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
588207	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
588208	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
588209	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
588210	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
588211	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Tank Leaks	None	
588212	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
588213	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
588214	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	12.05	%
588215	2/7/2019 11:49	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	6.02	%
588216	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
588217	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
588218	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
588219	2/7/2019 13:19	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
588220	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	4.85	%
588221	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	6.07	%
588222	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
588223	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	9 Month Operations	18	
588224	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
588225	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
588226	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Regulator As Left Counter	36203	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
588227	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
588228	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Accumulated Fault Duty A Ph V	4.19	%
588229	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Accumulated Fault Duty B Ph V	3.77	%
588230	2/7/2019 12:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
588231	2/7/2019 12:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	General Comments	got pulled out	
588232	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	FCP Block Raise AF	0.0	VAC
588233	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
588234	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	LTC As Left Counter	43892	
588235	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
588236	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
588237	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
588238	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Operations Counter	1932	
588239	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	FCP Block Raise AL	0.0	VAC
588240	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	FCP Lower AF	0.0	VAC
588241	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
588242	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
588243	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
588244	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
588245	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Amps C Ø	120.0	
588246	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	FCP Lower AL	0.0	VAC
588247	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
588248	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
588249	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
588250	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
588251	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	Follow-up Action Required?	n	
588252	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	Oil Temp Present	32	°C
588253	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
588254	2/7/2019 12:59	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	General Comments		
588255	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
588256	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
588257	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
588258	2/7/2019 12:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
588259	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Tank Leaks	None	
588260	2/7/2019 12:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
588261	2/7/2019 12:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Trash Emptied?	y	
588262	2/7/2019 12:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
588263	2/7/2019 12:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
588264	2/7/2019 12:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Restroom Clean & OK?	n	
588265	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
588266	2/7/2019 12:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
588267	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Amps B Ø	120.0	
588268	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Amps A Ø	120.0	
588269	2/7/2019 12:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
588270	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Tank Leaks	None	
588271	2/7/2019 12:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Panels Dusted?	y	
588272	2/7/2019 13:33	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
588273	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
588274	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
588275	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
588276	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	41	
588277	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
588278	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
588279	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Cabinet Paint Condition	Good	
588280	2/7/2019 14:45	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Equipment Properly Labeled?	y	
588281	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
588282	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
588283	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
588284	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
588285	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
588286	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
588287	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
588288	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
588289	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
588290	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Adjusted Amps A Phase AM	33.54	
588291	2/7/2019 12:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Floor Swept?	y	
588292	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
588293	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
588294	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	General Comments		
588295	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6R	
588296	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Adjusted Amps B Phase AM	33.54	
588297	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Adjusted Amps C Phase AM	33.54	
588298	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
588299	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
588300	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
588301	2/7/2019 13:46	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	LTC As Found Counter	43892	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
588302	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
588303	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
588304	2/7/2019 15:11	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
588305	2/7/2019 12:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
588306	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
588307	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AL	548	
588308	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
588309	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Unknown Operations	0	
588310	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
588311	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AF	548	
588312	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Maintenance Operations	0	
588313	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	General Comments	OK	
588314	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
588315	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps C Ø	75.0	
588316	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps B Ø	50.0	
588317	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Switching Operations	0	
588318	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
588319	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
588320	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps A Ø	50.0	
588321	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	.28	%
588322	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
588323	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
588324	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	9 Month Operations	2	
588325	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
588326	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
588327	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.96	%
588328	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	9 Month Operations	5	
588329	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.96	%
588330	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
588331	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
588332	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
588333	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Unknown Operations	0	
588334	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps C Ø	75.0	
588335	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
588336	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
588337	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Switching Operations	0	
588338	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.68	%
588339	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
588340	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps A Ø	50.0	
588341	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps B Ø	50.0	
588342	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AL	512	
588343	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AF	512	
588344	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Maintenance Operations	0	
588345	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
588346	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
588347	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	General Comments	OK	
588348	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
588349	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	General Comments		
588350	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.0	amps
588351	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Amps B Ø	0	
588352	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	General Comments		
588353	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	General Comments		
588354	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
588355	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Amps C Ø	0	
588356	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Adjusted Amps B Phase V	0	
588357	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Adjusted Amps A Phase V	0	
588358	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Equipment Properly Labeled?	y	
588359	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	Follow-up Action Required?	y	
588360	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	Replaced Desicant Filter	
588361	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
588362	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
588363	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	General Comments	VC is still not operating.	
588364	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
588365	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
588366	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
588367	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Tank Leaks	None	
588368	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
588369	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
588370	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
588371	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
588372	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
588373	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
588374	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC As Found Counter	50882	
588375	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC As Left Counter	50882	
588376	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
588377	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Amps B Ø	220.0	
588378	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
588379	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
588380	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
588381	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
588382	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
588383	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
588384	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
588385	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
588386	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
588387	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	General Comments		
588388	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
588389	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
588390	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
588391	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
588392	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BCH000141	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133	VDC
588393	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
588394	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Amps C Ø	100.0	
588395	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
588396	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
588397	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
588398	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
588399	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
588400	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
588401	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
588402	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Switching Operations	0	
588403	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
588404	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Unknown Operations	0	
588405	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Amps A Ø	100.0	
588406	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
588407	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Patrol Inspection	General Comments		
588408	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
588409	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
588410	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
588411	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
588412	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Operations A Ø	0	
588413	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Operations B Ø	0	
588414	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.5	VDC
588415	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
588416	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
588417	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
588418	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	General Comments		
588419	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
588420	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
588421	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
588422	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
588423	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
588424	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
588425	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
588426	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
588427	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
588428	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
588429	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BCH000141	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
588430	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
588431	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Adjusted Amps C Phase V	0	
588432	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
588433	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
588434	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
588435	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
588436	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
588437	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Regulator As Left Counter	80640	
588438	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
588439	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
588440	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
588441	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Operations C Ø	0	
588442	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Operations Ground	0	
588443	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
588444	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Follow-up Action Required?	n	
588445	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Patrol Inspection	General Comments		
588446	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
588447	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Vegetation	None	
588448	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
588449	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
588450	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
588451	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
588452	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
588453	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
588454	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
588455	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
588456	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
588457	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
588458	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
588459	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
588460	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	General Comments		
588461	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
588462	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
588463	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	40	°C
588464	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
588465	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.200	millivolts
588466	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
588467	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	45	°C
588468	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
588469	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	ANN000107	Annunciator	FH-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
588470	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	ANN000107	Annunciator	FH-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
588471	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	9 Months Operations	32	
588472	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
588473	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
588474	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
588475	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	ANN000107	Annunciator	FH-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
588476	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	ANN000107	Annunciator	FH-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
588477	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	ANN000107	Annunciator	FH-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
588478	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
588479	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
588480	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
588481	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	40	°C
588482	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	°C
588483	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
588484	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
588485	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
588486	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
588487	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
588488	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
588489	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
588490	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
588491	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
588492	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
588493	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Switching Operations	0	
588494	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
588495	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
588496	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
588497	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
588498	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
588499	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
588500	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Vegetation	None	
588501	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
588502	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
588503	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
588504	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	General Comments		
588505	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
588506	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
588507	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
588508	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
588509	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Readings	General Comments		
588510	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Grounds in Place?	y	
588511	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
588512	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
588513	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	General Comments		
588514	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
588515	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Clear of Trash?	y	
588516	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
588517	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
588518	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
588519	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
588520	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
588521	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	General Comments		
588522	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
588523	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
588524	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
588525	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
588526	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
588527	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
588528	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
588529	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
588530	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
588531	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
588532	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Clear of Trash?	y	
588533	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
588534	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
588535	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
588536	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
588537	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
588538	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
588539	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
588540	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	General Comments		
588541	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Cabinet Paint Condition	Good	
588542	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
588543	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Bushing Condition	Good	
588544	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Bushings Connection/Risers	Good	
588545	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
588546	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
588547	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
588548	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
588549	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Unknown Operations	0	
588550	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
588551	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Operations Ground	0	
588552	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Follow-up Action Required?	n	
588553	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
588554	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BAT000558	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
588555	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
588556	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
588557	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
588558	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
588559	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
588560	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
588561	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
588562	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	General Comments		
588563	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
588564	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
588565	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	General Comments		
588566	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
588567	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
588568	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
588569	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
588570	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
588571	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
588572	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Maintenance Operations	0	
588573	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
588574	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Operations Counter AF	183	
588575	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
588576	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
588577	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
588578	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
588579	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	301.0	
588580	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
588581	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
588582	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Operations Counter AL	183	
588583	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
588584	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
588585	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
588586	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
588587	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
588588	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
588589	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
588590	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
588591	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	705	
588592	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	705	
588593	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
588594	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
588595	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
588596	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
588597	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
588598	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Operations B Ø	0	
588599	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Operations C Ø	0	
588600	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Operations Ground	0	
588601	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
588602	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
588603	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
588604	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Follow-up Action Required?	n	
588605	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Grounds in Place?	y	
588606	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Maintenance Operations	0	
588607	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
588608	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
588609	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Not Good Replaced	check oil cup
588610	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
588611	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
588612	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
588613	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Tank Leaks	None	
588614	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
588615	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
588616	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
588617	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
588618	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
588619	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
588620	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
588621	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Max Tap Position	10R	
588622	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Regulator As Left Counter	93428	
588623	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
588624	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	315.0	
588625	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Regulator As Left Counter	205422	
588626	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123	volts
588627	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	1.44	%
588628	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	9 Month Operations	0	
588629	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
588630	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
588631	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
588632	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
588633	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
588634	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
588635	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
588636	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Totalizer Meter Reading	1.1394	
588637	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Clear of Trash?	y	
588638	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
588639	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Operations Ground	0	
588640	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Patrol Inspection	Follow-up Action Required?	n	
588641	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Follow-up Action Required?	n	
588642	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Patrol Inspection	General Comments		
588643	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	General Comments		
588644	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Maintenance Operations	0	
588645	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
588646	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
588647	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	General Comments		
588648	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
588649	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
588650	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
588651	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
588652	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
588653	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
588654	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.4	VDC
588655	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
588656	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
588657	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
588658	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
588659	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.700	millivolts
588660	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
588661	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Vegetation	None	
588662	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	335.0	
588663	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Unknown Operations	0	
588664	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Switching Operations	0	
588665	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
588666	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
588667	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
588668	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
588669	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
588670	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	0	
588671	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
588672	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
588673	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
588674	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Tank Leaks	None	
588675	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
588676	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
588677	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Regulator As Left Counter	33004	
588678	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
588679	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Operations A Ø	0	
588680	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
588681	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Operations Ground	0	
588682	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Follow-up Action Required?	n	
588683	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
588684	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
588685	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
588686	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
588687	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	40	
588688	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	40	
588689	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	40	
588690	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
588691	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
588692	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
588693	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
588694	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Tank Paint Condition	Good	
588695	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Unknown Operations	0	
588696	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Follow-up Action Required?	n	
588697	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Foundation Condition	Good	
588698	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	General Comments		
588699	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	General Comments		
588700	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Grounds in Place?	y	
588701	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Maintenance Operations	0	
588702	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Moisture and Leak Free?	y	
588703	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Operations Counter AF	123	
588704	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Operations Counter AL	123	
588705	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
588706	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
588707	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Switching Operations	1	
588708	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Tank Paint Condition	Good	
588709	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Unknown Operations	0	
588710	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
588711	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
588712	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
588713	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
588714	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	General Comments		
588715	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
588716	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
588717	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
588718	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
588719	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
588720	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
588721	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
588722	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
588723	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
588724	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
588725	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Operations Counter AL	691	
588726	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
588727	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Tank Leaks	None	
588728	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Heaters (All) Functioning?	y	
588729	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BAT000558	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
588730	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BAT000558	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
588731	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BAT000558	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0	VDC
588732	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Moisture and Leak Free?	y	
588733	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Operations Counter AF	438	
588734	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Switching Operations	0	
588735	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Unknown Operations	0	
588736	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Operations Counter AL	439	
588737	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Switching Operations	1	
588738	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BAT000558	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0	VDC
588739	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
588740	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
588741	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
588742	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
588743	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
588744	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
588745	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
588746	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
588747	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
588748	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
588749	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
588750	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
588751	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
588752	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	9 Month Operations	3	
588753	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
588754	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
588755	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
588756	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Amps A Ø	0.0	
588757	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Amps B Ø	0.0	
588758	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Amps C Ø	0.0	
588759	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
588760	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
588761	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
588762	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Cabinet Paint Condition	Good	
588763	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Equipment Properly Labeled?	y	
588764	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
588765	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
588766	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
588767	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Operations A Ø	0	
588768	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Operations B Ø	0	
588769	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Operations C Ø	0	
588770	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BAT000558	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
588771	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
588772	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
588773	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
588774	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
588775	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
588776	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
588777	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
588778	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
588779	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
588780	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
588781	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Regulator As Left Counter	9323	
588782	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
588783	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
588784	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
588785	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Operations Counter AL	158	
588786	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Operations Counter AF	158	
588787	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Maintenance Operations	0	
588788	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
588789	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
588790	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
588791	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
588792	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LTCC000442	LTCControl	FH-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
588793	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LTCC000442	LTCControl	FH-TRANS 2	LTC Control Insp	General Comments		
588794	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LTCC000442	LTCControl	FH-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
588795	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	General Comments	drag hands stuck together	
588796	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
588797	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Max Tap Position	6L	
588798	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
588799	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
588800	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
588801	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
588802	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
588803	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	9 Month Operations	5	
588804	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
588805	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
588806	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
588807	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Amps A Ø	0.0	
588808	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Amps B Ø	0.0	
588809	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Amps C Ø	0.0	
588810	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
588811	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
588812	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
588813	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
588814	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
588815	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
588816	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
588817	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
588818	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BCH000141	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133	VDC
588819	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BCH000141	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
588820	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Clear of Trash?	y	
588821	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
588822	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
588823	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
588824	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Ambient Temp	61	°F
588825	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
588826	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
588827	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Amps A Ø	0	
588828	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Accumulated Fault Duty C Ph V	0	%
588829	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Accumulated Fault Duty B Ph V	0	%
588830	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
588831	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
588832	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
588833	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
588834	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
588835	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
588836	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
588837	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Accumulated Fault Duty A Ph V	0	%
588838	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	9 Month Operations	9	
588839	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Operations A Ø	0	
588840	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123	volts
588841	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
588842	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
588843	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
588844	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Totalizer Meter Reading	1.3524	
588845	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
588846	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Top Oil Temperature Present	40	°C
588847	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Top Oil Temperature Max	60	°C
588848	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BCH000141	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
588849	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BCH000141	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
588850	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
588851	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
588852	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
588853	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
588854	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
588855	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
588856	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
588857	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
588858	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
588859	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
588860	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
588861	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Operations A Ø	0	
588862	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
588863	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Amps B Ø	54.0	
588864	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Amps A Ø	52.0	
588865	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	1.44	%
588866	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	1.44	%
588867	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
588868	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC Current Tap Position	15L	
588869	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	General Comments		
588870	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC Max Tap Position	9L	
588871	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	General Comments		
588872	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
588873	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC Min Tap Position	16L	
588874	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0	VDC
588875	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0	VDC
588876	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	General Comments		
588877	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
588878	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
588879	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
588880	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
588881	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Grounds in Place?	y	
588882	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Maintenance Operations	0	
588883	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Moisture and Leak Free?	y	
588884	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AF	136	
588885	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AL	136	
588886	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
588887	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
588888	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Switching Operations	2	
588889	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Tank Paint Condition	Good	
588890	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Unknown Operations	0	
588891	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
588892	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BCH001268	Charger	977-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
588893	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BCH001268	Charger	977-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.6	VDC
588894	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BCH001268	Charger	977-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.6	VDC
588895	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BCH001268	Charger	977-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
588896	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BCH001268	Charger	977-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
588897	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
588898	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
588899	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BCH001268	Charger	977-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
588900	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
588901	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
588902	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
588903	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Operations C Ø	0	
588904	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
588905	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
588906	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
588907	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BCH001268	Charger	977-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
588908	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	6	
588909	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
588910	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Operations A Ø	0	
588911	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Amps C Ø	54.0	
588912	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
588913	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Operations Counter AF	691	
588914	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
588915	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Operations B Ø	0	
588916	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Operations C Ø	0	
588917	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
588918	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
588919	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110	
588920	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
588921	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Tank Leaks	None	
588922	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
588923	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	General Comments		
588924	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Operations B Ø	0	
588925	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Operations C Ø	0	
588926	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Operations Ground	0	
588927	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Patrol Inspection	General Comments		
588928	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Follow-up Action Required?	n	
588929	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
588930	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
588931	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
588932	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
588933	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
588934	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Current Tap Position	3R	
588935	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
588936	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
588937	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
588938	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
588939	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	General Comments		
588940	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	General Comments		
588941	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
588942	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
588943	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
588944	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
588945	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
588946	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Follow-up Action Required?	n	
588947	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	General Comments		
588948	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Operations B Ø	0	
588949	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
588950	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
588951	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Foundation Condition	Good	
588952	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
588953	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
588954	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
588955	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	Top Oil Temperature Present	30	°C
588956	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	Top Oil Temperature Max	35	°C
588957	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
588958	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
588959	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
588960	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
588961	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
588962	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
588963	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
588964	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
588965	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
588966	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
588967	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
588968	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
588969	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	General Comments		
588970	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	General Comments		
588971	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
588972	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
588973	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
588974	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
588975	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
588976	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
588977	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
588978	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
588979	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
588980	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
588981	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
588982	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
588983	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
588984	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
588985	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
588986	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
588987	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	General Comments		
588988	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
588989	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
588990	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
588991	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
588992	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
588993	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
588994	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
588995	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
588996	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	General Comments		
588997	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	General Comments		
588998	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
588999	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
589000	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
589001	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
589002	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Unknown Operations	0	
589003	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Tank Paint Condition	Good	
589004	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Switching Operations	0	
589005	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
589006	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
589007	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
589008	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
589009	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
589010	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
589011	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	9 Month Operations	0	
589012	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
589013	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
589014	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
589015	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Amps A Ø	0.0	
589016	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Amps B Ø	0.0	
589017	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Amps C Ø	0.0	
589018	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
589019	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
589020	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
589021	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Cabinet Paint Condition	Good	
589022	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Operations Counter AL	247	
589023	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Equipment Properly Labeled?	y	
589024	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Grounds in Place?	y	
589025	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Moisture and Leak Free?	y	
589026	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
589027	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
589028	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	Battery Charger Current	6.7	amps
589029	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Tank Paint Condition	Good	
589030	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	General Comments		
589031	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
589032	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
589033	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
589034	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
589035	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
589036	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
589037	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
589038	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
589039	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
589040	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Winding Temp Present	40	°C
589041	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
589042	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
589043	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Amps C Ø	55.0	
589044	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Amps B Ø	55.0	
589045	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Amps A Ø	55.0	
589046	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
589047	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
589048	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
589049	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	General Comments		
589050	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	Ground Lights	None	
589051	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
589052	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Foundation Condition	Good	
589053	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
589054	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	General Comments		
589055	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
589056	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
589057	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
589058	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
589059	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
589060	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
589061	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
589062	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
589063	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
589064	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
589065	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
589066	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
589067	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
589068	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
589069	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
589070	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
589071	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
589072	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
589073	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
589074	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	General Comments		
589075	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
589076	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
589077	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
589078	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
589079	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
589080	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
589081	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Winding Temp Max	40	°C
589082	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Top Oil Temperature Present	40	°C
589083	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Top Oil Temperature Max	40	°C
589084	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
589085	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
589086	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
589087	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
589088	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
589089	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
589090	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	10	°C
589091	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	40	°C
589092	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	20	°C
589093	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	40	°C
589094	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	20	°C
589095	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	40	°C
589096	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
589097	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	220.00	
589098	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
589099	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
589100	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
589101	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
589102	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
589103	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
589104	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
589105	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
589106	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	Totalizer Meter Reading	.9492	
589107	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
589108	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
589109	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
589110	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
589111	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
589112	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
589113	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
589114	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Oil Temp Present	35	°C
589115	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Oil Temp Max	35	°C
589116	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
589117	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
589118	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
589119	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
589120	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	General Comments		
589121	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
589122	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
589123	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Unknown Operations	0	
589124	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
589125	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Switching Operations	0	
589126	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Operations Counter AL	177	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
589127	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Operations Counter AF	177	
589128	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
589129	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
589130	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
589131	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
589132	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
589133	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
589134	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
589135	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
589136	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
589137	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
589138	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
589139	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
589140	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
589141	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
589142	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	50	psi
589143	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
589144	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
589145	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
589146	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
589147	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
589148	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
589149	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
589150	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
589151	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H3 Winding Temp Present	40	°C
589152	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Maintenance Operations	2	
589153	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	General Comments	ok	
589154	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Follow-up Action Required?	n	
589155	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H3 Winding Temp Max	40	°C
589156	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H2 Winding Temp Present	40	°C
589157	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Operations Ground	0	
589158	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Operations C Ø	0	
589159	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Operations B Ø	0	
589160	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Operations A Ø	0	
589161	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
589162	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
589163	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
589164	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Operations Counter AF	247	
589165	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Moisture and Leak Free?	y	
589166	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Maintenance Operations	0	
589167	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Heaters (All) Functioning?	y	
589168	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Grounds in Place?	y	
589169	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	General Comments		
589170	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	General Comments		
589171	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Foundation Condition	Good	
589172	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Follow-up Action Required?	n	
589173	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Follow-up Action Required?	n	
589174	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Operations Ground	0	
589175	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Operations C Ø	0	
589176	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Operations B Ø	0	
589177	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
589178	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
589179	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
589180	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
589181	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
589182	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
589183	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
589184	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
589185	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
589186	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
589187	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
589188	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
589189	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
589190	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	General Comments		
589191	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	General Comments		
589192	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Operations A Ø	0	
589193	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
589194	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
589195	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
589196	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Equipment Properly Labeled?	y	
589197	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Cabinet Paint Condition	Good	
589198	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
589199	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
589200	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
589201	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
589202	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Bushing Condition	Good	
589203	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Amps C Ø	0.0	
589204	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Amps B Ø	0.0	
589205	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Amps A Ø	0.0	
589206	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Accumulated Fault Duty C Ph V	3.58	%
589207	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
589208	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
589209	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Operations A Ø	0	
589210	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Accumulated Fault Duty B Ph V	.60	%
589211	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Accumulated Fault Duty A Ph V	7.16	%
589212	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	9 Month Operations	0	
589213	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Operations B Ø	0	
589214	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Operations C Ø	0	
589215	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Operations Ground	0	
589216	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Follow-up Action Required?	n	
589217	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Follow-up Action Required?	n	
589218	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Foundation Condition	Good	
589219	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	General Comments		
589220	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	General Comments	CARDED OUT	
589221	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Grounds in Place?	y	
589222	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Maintenance Operations	0	
589223	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Moisture and Leak Free?	y	
589224	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Operations Counter AF	141	
589225	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Operations Counter AL	141	
589226	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
589227	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Switching Operations	0	
589228	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Tank Paint Condition	Good	
589229	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Unknown Operations	0	
589230	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
589231	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
589232	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
589233	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
589234	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	9 Month Operations	0	
589235	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123	volts
589236	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Regulator As Left Counter	154345	
589237	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
589238	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
589239	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Tank Leaks	None	
589240	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
589241	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
589242	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
589243	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
589244	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Amps A Ø	0.0	
589245	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Amps B Ø	0.0	
589246	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Amps C Ø	0.0	
589247	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
589248	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
589249	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
589250	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
589251	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
589252	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
589253	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
589254	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Floor Swept?	y	
589255	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
589256	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
589257	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Evidence of Insects	None	
589258	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
589259	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
589260	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
589261	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
589262	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Cabinet Paint Condition	Good	
589263	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Equipment Properly Labeled?	y	
589264	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
589265	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
589266	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
589267	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	General Comments		
589268	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
589269	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
589270	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
589271	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
589272	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
589273	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Operations A Ø	0	
589274	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Operations B Ø	0	
589275	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
589276	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
589277	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
589278	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
589279	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
589280	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
589281	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Foundation Condition	Good	
589282	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
589283	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
589284	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
589285	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
589286	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
589287	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
589288	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	General Comments		
589289	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
589290	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
589291	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
589292	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
589293	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
589294	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
589295	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
589296	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
589297	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
589298	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
589299	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
589300	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
589301	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
589302	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Accumulated Fault Duty C Ph V	11.18	%
589303	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	PF000150	PowerFuse	FH-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
589304	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	PF000150	PowerFuse	FH-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
589305	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
589306	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
589307	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
589308	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
589309	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
589310	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
589311	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
589312	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
589313	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
589314	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
589315	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
589316	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Panels Dusted?	y	
589317	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
589318	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
589319	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	General Comments		
589320	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
589321	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
589322	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Tank Leaks	None	
589323	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
589324	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Regulator As Left Counter	99864	
589325	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
589326	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
589327	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
589328	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
589329	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
589330	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
589331	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
589332	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
589333	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
589334	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
589335	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
589336	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
589337	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	General Comments		
589338	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
589339	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
589340	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
589341	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
589342	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Patrol Inspection	Equipment Properly Labeled?	y	
589343	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Patrol Inspection	Follow-up Action Required?	n	
589344	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Patrol Inspection	General Comments		
589345	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
589346	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
589347	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
589348	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
589349	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
589350	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	General Comments		
589351	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
589352	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
589353	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
589354	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
589355	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
589356	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
589357	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
589358	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
589359	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Foundation Condition	Good	
589360	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
589361	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
589362	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
589363	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
589364	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
589365	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
589366	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
589367	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
589368	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
589369	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
589370	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
589371	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
589372	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	All Connections OK?	y	
589373	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
589374	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
589375	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
589376	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
589377	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
589378	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
589379	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
589380	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
589381	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	General Comments		
589382	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Negative DC Ground	0	VDC
589383	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Positive DC Ground	0	VDC
589384	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
589385	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
589386	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Unknown Operations	0	
589387	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Switching Operations	0	
589388	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Operations Counter AL	153	
589389	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Operations Counter AF	153	
589390	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Maintenance Operations	0	
589391	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	General Comments		
589392	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Patrol Inspection	General Comments		
589393	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Follow-up Action Required?	n	
589394	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Patrol Inspection	Follow-up Action Required?	n	
589395	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Operations Ground	0	
589396	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Operations C Ø	0	
589397	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Operations B Ø	0	
589398	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Operations A Ø	0	
589399	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
589400	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
589401	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
589402	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Patrol Inspection	Equipment Properly Labeled?	y	
589403	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Amps C Ø	2.0	
589404	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Amps B Ø	2.0	
589405	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Amps A Ø	3.0	
589406	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
589407	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
589408	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
589409	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	9 Month Operations	0	
589410	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
589411	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
589412	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Foundation Condition	Good	
589413	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
589414	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
589415	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
589416	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
589417	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.872	
589418	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
589419	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
589420	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	General Comments		
589421	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
589422	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
589423	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
589424	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
589425	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
589426	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
589427	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
589428	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
589429	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
589430	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Operations Counter	68	
589431	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
589432	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
589433	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
589434	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
589435	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
589436	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Cabinet Paint Condition	Good	
589437	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Equipment Properly Labeled?	y	
589438	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Follow-up Action Required?	n	
589439	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Foundation Condition	Good	
589440	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	General Comments		
589441	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
589442	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
589443	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
589444	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	General Comments		
589445	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Operations C Ø	0	
589446	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Operations Ground	0	
589447	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Follow-up Action Required?	n	
589448	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
589449	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
589450	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
589451	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
589452	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Vegetation	None	
589453	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
589454	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
589455	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
589456	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	General Comments		
589457	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
589458	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
589459	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
589460	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
589461	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
589462	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
589463	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
589464	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
589465	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
589466	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
589467	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
589468	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
589469	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Clear of Trash?	y	
589470	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
589471	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
589472	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
589473	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
589474	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
589475	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
589476	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Follow-up Action Required?	n	
589477	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Foundation Condition	Good	
589478	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	General Comments		
589479	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	General Comments		
589480	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Grounds in Place?	y	
589481	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
589482	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
589483	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
589484	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
589485	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
589486	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
589487	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	General Comments		
589488	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
589489	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
589490	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Operations Counter AF	306	
589491	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Operations Counter AL	306	
589492	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Maintenance Operations	0	
589493	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Amps A Ø	112.0	
589494	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Moisture and Leak Free?	y	
589495	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Operations Counter AF	133	
589496	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
589497	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
589498	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Operations Counter AL	133	
589499	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
589500	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Switching Operations	0	
589501	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
589502	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
589503	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Unknown Operations	0	
589504	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
589505	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
589506	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	General Comments	ok	
589507	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
589508	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
589509	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
589510	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
589511	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
589512	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
589513	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
589514	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
589515	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	General Comments		
589516	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	General Comments		
589517	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
589518	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	63	
589519	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
589520	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
589521	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	Follow-up Action Required?	n	
589522	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
589523	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	9 Month Operations	3	
589524	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
589525	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
589526	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
589527	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	84	
589528	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Amps C Ø	11	
589529	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Amps B Ø	6	
589530	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Amps A Ø	27	
589531	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	87	
589532	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
589533	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
589534	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
589535	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Amps A Ø	139.0	
589536	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Amps B Ø	126.0	
589537	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Amps C Ø	159.0	
589538	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
589539	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Unknown Operations	0	
589540	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
589541	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
589542	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
589543	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
589544	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	3245.76	kw
589545	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
589546	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
589547	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
589548	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
589549	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
589550	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Fault Operations A Ø	0	
589551	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Fault Operations B Ø	0	
589552	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Fault Operations C Ø	0	
589553	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Fault Operations Ground	0	
589554	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	117.5	
589555	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
589556	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
589557	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
589558	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	General Comments	OK	
589559	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
589560	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Vegetation	None	
589561	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
589562	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
589563	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
589564	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
589565	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
589566	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
589567	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Follow-up Action Required?	n	
589568	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Follow-up Action Required?	n	
589569	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Foundation Condition	Good	
589570	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
589571	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
589572	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	General Comments		
589573	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
589574	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
589575	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
589576	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
589577	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Tank Paint Condition	Good	
589578	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
589579	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
589580	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
589581	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
589582	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	General Comments		
589583	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Heaters (All) Functioning?	y	
589584	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Grounds in Place?	y	
589585	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	General Comments		
589586	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	General Comments		
589587	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Foundation Condition	Good	
589588	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Follow-up Action Required?	n	
589589	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	General Comments		
589590	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	Oil Temp Present	30	°C
589591	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Follow-up Action Required?	n	
589592	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Follow-up Action Required?	n	
589593	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Foundation Condition	Good	
589594	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
589595	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
589596	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
589597	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
589598	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	General Comments		
589599	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
589600	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
589601	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
589602	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
589603	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
589604	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	Oil Temp Max	35	°C
589605	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
589606	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
589607	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
589608	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	LTC Totalizer Reading	2278.08	kw
589609	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	9 Months Operations	3	
589610	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
589611	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
589612	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
589613	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
589614	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Amps A Ø	130.0	
589615	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Amps B Ø	120.0	
589616	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Amps C Ø	140.0	
589617	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	9 Month Operations	8	
589618	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
589619	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
589620	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
589621	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
589622	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	General Comments		
589623	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
589624	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
589625	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
589626	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Ambient Temp	56	°F
589627	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
589628	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Clear of Trash?	y	
589629	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
589630	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
589631	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
589632	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
589633	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
589634	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Accumulated Fault Duty A Ph V	0	%
589635	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Accumulated Fault Duty B Ph V	0	%
589636	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
589637	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
589638	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
589639	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
589640	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
589641	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
589642	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
589643	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
589644	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
589645	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
589646	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
589647	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
589648	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
589649	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
589650	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	General Comments		
589651	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
589652	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
589653	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
589654	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	2897.28	kw
589655	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	115.00	
589656	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
589657	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
589658	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
589659	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90	
589660	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
589661	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
589662	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Oil Temp Max	50	°C
589663	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Oil Temp Present	30	°C
589664	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
589665	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
589666	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
589667	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
589668	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
589669	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
589670	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
589671	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
589672	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
589673	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
589674	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
589675	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
589676	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
589677	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
589678	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	Top Oil Temperature Max	35	°C
589679	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	Top Oil Temperature Present	30	°C
589680	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
589681	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	1.2072	
589682	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Moisture and Leak Free?	y	
589683	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Accumulated Fault Duty C Ph V	0	%
589684	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Amps A Ø	100	
589685	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Amps B Ø	120	
589686	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Amps C Ø	120	
589687	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Patrol Inspection	Equipment Properly Labeled?	y	
589688	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Patrol Inspection	Follow-up Action Required?	n	
589689	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BAT000558	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
589690	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BAT000558	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
589691	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BAT000558	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
589692	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Bushing Condition	Good	
589693	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
589694	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
589695	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BAT000558	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
589696	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BAT000558	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
589697	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BAT000558	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
589698	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BAT000558	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
589699	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BAT000558	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
589700	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
589701	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
589702	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
589703	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Bushings Connection/Risers	Good	
589704	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Maintenance Operations	5	
589705	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BAT000558	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
589706	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
589707	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
589708	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
589709	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
589710	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
589711	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
589712	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	17	
589713	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	13	
589714	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
589715	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
589716	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
589717	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
589718	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
589719	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	General Comments		
589720	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	General Comments		
589721	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Grounds in Place?	y	
589722	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Maintenance Operations	0	
589723	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
589724	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Moisture and Leak Free?	y	
589725	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Switching Operations	0	
589726	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
589727	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	PF000236	PowerFuse	KC-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
589728	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	PF000236	PowerFuse	KC-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
589729	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	9 Month Operations	2	
589730	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Accumulated Fault Duty A Ph V	10.96	%
589731	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Operations Counter AF	118	
589732	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Operations Counter AL	118	
589733	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
589734	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Accumulated Fault Duty B Ph V	12.52	%
589735	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Switching Operations	1	
589736	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Tank Paint Condition	Good	
589737	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Unknown Operations	0	
589738	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
589739	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
589740	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
589741	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
589742	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
589743	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
589744	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
589745	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
589746	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
589747	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
589748	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
589749	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
589750	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
589751	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	General Comments		
589752	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
589753	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Adjusted Amps A Phase V	0	
589754	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Adjusted Amps B Phase V	0	
589755	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Adjusted Amps C Phase V	0	
589756	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Operations A Ø	0	
589757	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Operations B Ø	0	
589758	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Operations C Ø	0	
589759	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Operations Ground	0	
589760	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Follow-up Action Required?	n	
589761	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Follow-up Action Required?	n	
589762	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Foundation Condition	Good	
589763	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	General Comments		
589764	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
589765	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
589766	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
589767	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
589768	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
589769	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Operations Counter AL	375	
589770	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Operations Counter AF	370	
589771	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
589772	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
589773	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
589774	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
589775	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
589776	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
589777	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
589778	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	5469.12	kw
589779	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95	
589780	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	General Comments		
589781	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
589782	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
589783	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
589784	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
589785	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
589786	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
589787	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
589788	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
589789	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
589790	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
589791	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
589792	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
589793	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
589794	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
589795	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
589796	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
589797	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
589798	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
589799	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
589800	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
589801	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
589802	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Cabinet Paint Condition	Good	
589803	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Equipment Properly Labeled?	y	
589804	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Follow-up Action Required?	n	
589805	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Foundation Condition	Good	
589806	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	General Comments		
589807	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Grounds in Place?	y	
589808	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Moisture and Leak Free?	y	
589809	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
589810	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Tank Paint Condition	Good	
589811	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
589812	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	General Comments		
589813	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	General Comments		
589814	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
589815	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	LTC Totalizer Reading	7499.52	kw
589816	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
589817	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
589818	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
589819	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
589820	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Unknown Operations	0	
589821	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
589822	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
589823	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
589824	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H1 Winding Temp Max	40	°C
589825	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Tank Paint Condition	Good	
589826	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	Oil Temp Max	69	°C
589827	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	Top Oil Temperature Max	50	°C
589828	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	Top Oil Temperature Present	20	°C
589829	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
589830	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1952	
589831	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Switching Operations	4	
589832	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
589833	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Operations Counter AL	93	
589834	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
589835	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
589836	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
589837	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
589838	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
589839	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
589840	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
589841	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
589842	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
589843	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
589844	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
589845	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
589846	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
589847	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45	
589848	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51	
589849	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
589850	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
589851	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
589852	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	General Comments		
589853	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
589854	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	General Comments	needs nitrogen bottle filled	
589855	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	General Comments		
589856	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
589857	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
589858	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
589859	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
589860	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
589861	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
589862	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
589863	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
589864	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
589865	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
589866	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
589867	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
589868	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
589869	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
589870	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
589871	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
589872	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
589873	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
589874	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
589875	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
589876	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
589877	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
589878	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
589879	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
589880	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
589881	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
589882	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H2 Winding Temp Max	40	°C
589883	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H1 Winding Temp Present	40	°C
589884	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
589885	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
589886	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
589887	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
589888	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
589889	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
589890	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
589891	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
589892	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
589893	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	General Comments		
589894	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	General Comments	NITROGEN BOTTLE 300 PSI NEEDS FILLED	
589895	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
589896	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
589897	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
589898	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	Oil Temp Max	80	°C
589899	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	Oil Temp Present	60	°C
589900	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
589901	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
589902	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
589903	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
589904	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
589905	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
589906	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	Seeping	
589907	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
589908	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
589909	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
589910	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
589911	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	80	°C
589912	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	70	°C
589913	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
589914	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
589915	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2151.36	kw
589916	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	206	
589917	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200	
589918	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
589919	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
589920	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	Follow-up Action Required?	n	
589921	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
589922	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
589923	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
589924	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
589925	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
589926	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
589927	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
589928	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
589929	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
589930	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
589931	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	9 Month Operations	2	
589932	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Cabinet Paint Condition	Good	
589933	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
589934	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
589935	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	70	°C
589936	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	70	°C
589937	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	70	°C
589938	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	70	°C
589939	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	70	°C
589940	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	70	°C
589941	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
589942	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Vegetation	None	
589943	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Equipment Properly Labeled?	y	
589944	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
589945	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
589946	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	Totalizer Meter Reading	.7812	
589947	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
589948	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
589949	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
589950	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
589951	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
589952	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
589953	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
589954	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Fault Operations A Ø	0	
589955	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
589956	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
589957	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	General Comments		
589958	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
589959	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
589960	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
589961	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
589962	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
589963	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Fault Operations B Ø	0	
589964	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Fault Operations C Ø	0	
589965	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
589966	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Clear of Trash?	y	
589967	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
589968	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
589969	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
589970	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
589971	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
589972	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4492.8	kw
589973	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Cabinet Paint Condition	Good	
589974	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Equipment Properly Labeled?	y	
589975	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
589976	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Follow-up Action Required?	n	
589977	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Foundation Condition	Good	
589978	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	General Comments		
589979	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Grounds in Place?	y	
589980	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
589981	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
589982	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
589983	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Moisture and Leak Free?	y	
589984	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
589985	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Tank Paint Condition	Good	
589986	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
589987	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Operations Counter AF	89	
589988	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Moisture and Leak Free?	y	
589989	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
589990	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123	volts
589991	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Regulator As Left Counter	100150	
589992	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
589993	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
589994	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Tank Leaks	None	
589995	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
589996	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Maintenance Operations	0	
589997	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Fault Operations Ground	0	
589998	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Equipment Properly Labeled?	y	
589999	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Cabinet Paint Condition	Good	
590000	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
590001	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
590002	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
590003	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	General Comments		
590004	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
590005	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
590006	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
590007	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
590008	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
590009	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
590010	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
590011	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
590012	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
590013	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Amps B Ø	103.0	
590014	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Amps C Ø	104.0	
590015	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Bushing Condition	Good	
590016	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Bushings Connection/Risers	Good	
590017	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
590018	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
590019	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
590020	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
590021	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
590022	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
590023	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Amps C Ø	60.0	
590024	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
590025	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
590026	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
590027	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
590028	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
590029	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
590030	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
590031	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
590032	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
590033	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
590034	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	Oil Temp Present	51	°C
590035	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
590036	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
590037	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
590038	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
590039	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
590040	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
590041	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
590042	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
590043	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
590044	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
590045	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	General Comments		
590046	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
590047	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
590048	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
590049	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
590050	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
590051	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
590052	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
590053	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
590054	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	Oil Temp Max	35	°C
590055	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	Oil Temp Present	20	°C
590056	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
590057	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
590058	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
590059	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Amps B Ø	60.0	
590060	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Amps A Ø	60.0	
590061	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Accumulated Fault Duty C Ph V	2.32	%
590062	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Accumulated Fault Duty B Ph V	2.74	%
590063	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Accumulated Fault Duty A Ph V	2.32	%
590064	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
590065	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
590066	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
590067	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
590068	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BAT000439	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	n	If no, which cells in comments
590069	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
590070	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
590071	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Floor Swept?	y	
590072	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BAT000439	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
590073	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
590074	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
590075	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Evidence of Insects	None	
590076	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
590077	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
590078	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
590079	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
590080	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
590081	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
590082	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
590083	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
590084	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
590085	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
590086	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
590087	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Adjusted Amps B Phase V	0	
590088	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Adjusted Amps A Phase V	0	
590089	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Equipment Properly Labeled?	y	
590090	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Cabinet Paint Condition	Good	
590091	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
590092	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
590093	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
590094	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
590095	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
590096	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
590097	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	General Comments		
590098	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Follow-up Action Required?	n	
590099	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
590100	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
590101	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
590102	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
590103	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
590104	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Battery Overall Condition	Good	
590105	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Battery Area Ambient Temp	78	°F
590106	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	All Connections OK?	y	
590107	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	General Comments		
590108	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
590109	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
590110	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
590111	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
590112	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
590113	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
590114	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
590115	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Bushings Connection/Risers	Good	
590116	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	General Comments		
590117	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
590118	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
590119	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.0	VDC
590120	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.0	VDC
590121	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
590122	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
590123	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Tank Leaks	None	
590124	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
590125	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
590126	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Regulator As Left Counter	13448	
590127	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123	volts
590128	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Follow-up Action Required?	n	
590129	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Patrol Inspection	Follow-up Action Required?	n	
590130	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Operations Ground	0	
590131	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Operations C Ø	0	
590132	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Operations B Ø	0	
590133	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Operations A Ø	0	
590134	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
590135	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
590136	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
590137	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
590138	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Amps C Ø	50.0	
590139	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Amps B Ø	50.0	
590140	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Amps A Ø	50.0	
590141	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Accumulated Fault Duty C Ph AM	1.20	%
590142	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Accumulated Fault Duty B Ph AM	1.20	%
590143	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
590144	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	9 Months Operations	1	
590145	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	PF000194	PowerFuse	KC-34KV WEST BUS POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
590146	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	PF000194	PowerFuse	KC-34KV WEST BUS POT	Disconnect Powerfuse Inspection	General Comments	ok	
590147	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
590148	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
590149	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
590150	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
590151	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Unknown Operations	0	
590152	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Tank Paint Condition	Good	
590153	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Switching Operations	1	
590154	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Operations Counter AL	189	
590155	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Operations Counter AF	189	
590156	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Moisture and Leak Free?	y	
590157	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Maintenance Operations	0	
590158	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Grounds in Place?	y	
590159	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	General Comments		
590160	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	General Comments		
590161	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Foundation Condition	Good	
590162	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Follow-up Action Required?	n	
590163	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Follow-up Action Required?	n	
590164	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Operations Ground	0	
590165	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Operations C Ø	0	
590166	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Operations B Ø	0	
590167	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Operations A Ø	0	
590168	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Adjusted Amps C Phase V	0	
590169	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
590170	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
590171	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Trash Emptied?	n	
590172	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
590173	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	General Comments		
590174	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
590175	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
590176	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
590177	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BAT000439	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
590178	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BAT000439	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
590179	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BAT000439	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
590180	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BAT000439	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
590181	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BAT000439	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
590182	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BAT000439	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
590183	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BAT000439	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Water Added	If low,note cell #~'s
590184	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BAT000439	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
590185	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BAT000439	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
590186	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BAT000439	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	added water to cell #1, 7,10,13,16,28,40,44,48	
590187	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BAT000439	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
590188	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BAT000439	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
590189	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
590190	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Amps C Ø	15	
590191	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Amps B Ø	19	
590192	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Amps A Ø	13	
590193	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Accumulated Fault Duty C Ph V	0	%
590194	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Accumulated Fault Duty B Ph V	0	%
590195	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Accumulated Fault Duty A Ph V	0	%
590196	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
590197	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
590198	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
590199	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
590200	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	9 Month Operations	59	
590201	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
590202	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
590203	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
590204	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Mechanism Patrol Inspection	General Comments		
590205	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
590206	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Unknown Operations	0	
590207	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Tank Paint Condition	Good	
590208	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Switching Operations	3	
590209	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Operations Counter AL	182	
590210	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Operations Counter AF	179	
590211	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Moisture and Leak Free?	y	
590212	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Maintenance Operations	0	
590213	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Grounds in Place?	y	
590214	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	General Comments		
590215	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	General Comments		
590216	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Foundation Condition	Good	
590217	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Follow-up Action Required?	n	
590218	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Follow-up Action Required?	n	
590219	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Operations Ground	0	
590220	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Operations C Ø	0	
590221	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Operations B Ø	0	
590222	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Operations A Ø	0	
590223	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Adjusted Amps C Phase V	0	
590224	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Adjusted Amps B Phase V	0	
590225	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Adjusted Amps A Phase V	0	
590226	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Equipment Properly Labeled?	y	
590227	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Cabinet Paint Condition	Good	
590228	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
590229	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
590230	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
590231	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
590232	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
590233	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
590234	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
590235	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
590236	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
590237	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
590238	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
590239	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
590240	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
590241	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
590242	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
590243	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
590244	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
590245	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
590246	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
590247	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
590248	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	General Comments		
590249	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
590250	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	PF000197	PowerFuse	LY-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
590251	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	PF000197	PowerFuse	LY-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
590252	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
590253	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
590254	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
590255	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
590256	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
590257	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	PF000198	PowerFuse	LY-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
590258	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	PF000198	PowerFuse	LY-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
590259	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
590260	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
590261	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
590262	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
590263	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Patrol Inspection	General Comments		
590264	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Patrol Inspection	Follow-up Action Required?	n	
590265	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Bushing Condition	Good	
590266	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	PF000152	PowerFuse	FH-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
590267	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	PF000152	PowerFuse	FH-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
590268	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCControl	592-1	LTC Control Insp	VRR Time Delay	30	Seconds
590269	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCControl	592-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
590270	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Patrol Inspection	Equipment Properly Labeled?	y	
590271	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCControl	592-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
590272	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCControl	592-1	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
590273	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCControl	592-1	LTC Control Insp	LTC Operation Checked?	y	
590274	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCControl	592-1	LTC Control Insp	General Comments		
590275	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCControl	592-1	LTC Control Insp	Follow-up Action Required?	n	
590276	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCControl	592-1	LTC Control Insp	All Connections OK?	y	
590277	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Unknown Operations	0	
590278	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Tank Paint Condition	Good	
590279	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Switching Operations	2	
590280	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Operations Counter AL	189	
590281	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Operations Counter AF	187	
590282	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Moisture and Leak Free?	y	
590283	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Maintenance Operations	0	
590284	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Grounds in Place?	y	
590285	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	General Comments		
590286	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	General Comments		
590287	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Foundation Condition	Good	
590288	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Follow-up Action Required?	n	
590289	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Follow-up Action Required?	n	
590290	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Operations Ground	0	
590291	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Operations C Ø	0	
590292	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Operations B Ø	0	
590293	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Operations A Ø	0	
590294	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Adjusted Amps C Phase V	0	
590295	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Adjusted Amps B Phase V	0	
590296	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Adjusted Amps A Phase V	0	
590297	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Equipment Properly Labeled?	y	
590298	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Cabinet Paint Condition	Good	
590299	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
590300	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
590301	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
590302	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Bushings Connection/Risers	Good	
590303	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Bushing Condition	Good	
590304	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Amps C Ø	65	
590305	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Amps B Ø	95	
590306	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Amps A Ø	48	
590307	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Accumulated Fault Duty C Ph V	0	%
590308	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Accumulated Fault Duty B Ph V	0	%
590309	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Accumulated Fault Duty A Ph V	0	%
590310	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	9 Month Operations	4	
590311	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
590312	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
590313	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Current Tap Position	6L	
590314	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
590315	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
590316	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
590317	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
590318	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	General Comments		
590319	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
590320	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Max Tap Position	3L	
590321	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
590322	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
590323	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	113	
590324	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	113	
590325	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
590326	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	NOT IN SERVICE	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
590327	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
590328	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
590329	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
590330	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
590331	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
590332	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Min Tap Position	6L	
590333	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
590334	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
590335	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
590336	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
590337	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
590338	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Regulator As Left Counter	23898	
590339	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
590340	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
590341	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Tank Leaks	None	
590342	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	9 Month Operations	8	
590343	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Accumulated Fault Duty A Ph V	0	%
590344	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
590345	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
590346	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
590347	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
590348	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Accumulated Fault Duty B Ph V	0	%
590349	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Accumulated Fault Duty C Ph V	0	%
590350	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Amps A Ø	120	
590351	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Amps B Ø	140	
590352	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Amps C Ø	140	
590353	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Bushing Condition	Good	
590354	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Bushings Connection/Risers	Good	
590355	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
590356	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
590357	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
590358	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Cabinet Paint Condition	Good	
590359	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Equipment Properly Labeled?	y	
590360	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Adjusted Amps A Phase V	0	
590361	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Adjusted Amps B Phase V	0	
590362	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Adjusted Amps C Phase V	0	
590363	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Operations A Ø	0	
590364	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Operations B Ø	0	
590365	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
590366	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
590367	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
590368	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
590369	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
590370	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
590371	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
590372	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
590373	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
590374	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
590375	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
590376	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
590377	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	General Comments		
590378	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
590379	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
590380	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
590381	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
590382	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
590383	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
590384	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
590385	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
590386	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
590387	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
590388	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
590389	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
590390	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Panels Dusted?	y	
590391	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
590392	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
590393	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	General Comments		
590394	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
590395	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
590396	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Floor Swept?	y	
590397	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
590398	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
590399	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Evidence of Insects	None	
590400	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
590401	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
590402	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
590403	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
590404	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Broom on Site?	y	
590405	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
590406	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
590407	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
590408	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
590409	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Amps C Ø	200.0	
590410	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Amps B Ø	25.0	
590411	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Amps A Ø	220.0	
590412	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
590413	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
590414	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
590415	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	9 Months Operations	0	
590416	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
590417	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
590418	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
590419	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
590420	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
590421	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	50	°C
590422	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
590423	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	55	°C
590424	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
590425	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
590426	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	4R	
590427	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
590428	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
590429	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
590430	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
590431	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
590432	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
590433	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
590434	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
590435	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Foundation Condition	Good	
590436	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
590437	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
590438	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	General Comments		
590439	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
590440	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
590441	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
590442	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
590443	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
590444	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
590445	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
590446	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
590447	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
590448	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
590449	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
590450	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
590451	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
590452	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Ambient Temp	62	°F
590453	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
590454	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Clear of Trash?	y	
590455	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
590456	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
590457	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
590458	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	General Comments		
590459	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
590460	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
590461	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
590462	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
590463	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
590464	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Vegetation	None	
590465	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
590466	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BCH000400	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
590467	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
590468	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Vegetation	None	
590469	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
590470	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	General Comments		
590471	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
590472	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
590473	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
590474	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
590475	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
590476	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Clear of Trash?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
590477	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
590478	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BCH000400	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
590479	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BCH000400	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
590480	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BCH000400	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
590481	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BCH000400	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
590482	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BCH000400	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
590483	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	VRR Time Delay	45	Seconds
590484	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
590485	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
590486	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
590487	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
590488	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	LTC Operation Checked?	y	
590489	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	General Comments		
590490	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	Follow-up Action Required?	n	
590491	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
590492	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
590493	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	All Connections OK?	y	
590494	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
590495	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
590496	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
590497	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
590498	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
590499	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
590500	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
590501	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
590502	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
590503	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
590504	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
590505	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	General Comments		
590506	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
590507	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
590508	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Foundation Condition	Good	
590509	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
590510	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
590511	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Operations C Ø	0	
590512	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Operations Ground	0	
590513	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Follow-up Action Required?	n	
590514	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Follow-up Action Required?	n	
590515	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Foundation Condition	Good	
590516	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	General Comments		
590517	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	General Comments		
590518	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Grounds in Place?	y	
590519	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Heaters (All) Functioning?	y	
590520	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Maintenance Operations	0	
590521	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Moisture and Leak Free?	y	
590522	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Operations Counter AF	329	
590523	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Operations Counter AL	332	
590524	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
590525	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Switching Operations	4	
590526	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Tank Paint Condition	Good	
590527	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Unknown Operations	0	
590528	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
590529	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
590530	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
590531	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
590532	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
590533	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
590534	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
590535	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
590536	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
590537	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
590538	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
590539	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	10R	
590540	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	3R	
590541	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
590542	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
590543	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
590544	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
590545	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
590546	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	65398	
590547	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
590548	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
590549	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
590550	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
590551	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
590552	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
590553	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
590554	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
590555	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
590556	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC As Found Counter	99975	
590557	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	9 Month Operations	12	
590558	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Accumulated Fault Duty A Ph V	18.48	%
590559	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Accumulated Fault Duty B Ph V	17.89	%
590560	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Accumulated Fault Duty C Ph V	16.70	%
590561	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Amps A Ø	35.0	
590562	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Amps B Ø	39.0	
590563	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Amps C Ø	39.0	
590564	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Bushing Condition	Good	
590565	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Bushings Connection/Risers	Good	
590566	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
590567	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
590568	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
590569	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Cabinet Paint Condition	Good	
590570	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Equipment Properly Labeled?	y	
590571	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
590572	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
590573	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
590574	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Operations A Ø	0	
590575	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Operations B Ø	0	
590576	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Operations C Ø	0	
590577	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Operations Ground	0	
590578	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Follow-up Action Required?	n	
590579	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Follow-up Action Required?	n	
590580	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Foundation Condition	Good	
590581	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	General Comments		
590582	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	General Comments		
590583	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Grounds in Place?	y	
590584	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Heaters (All) Functioning?	y	
590585	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Maintenance Operations	0	
590586	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Moisture and Leak Free?	y	
590587	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Operations Counter AF	247	
590588	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Operations Counter AL	246	
590589	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
590590	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Switching Operations	0	
590591	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Tank Paint Condition	Good	
590592	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Unknown Operations	0	
590593	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC As Left Counter	99975	
590594	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
590595	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC Current Tap Position	11L	
590596	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC Max Tap Position	Neutral	
590597	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC Min Tap Position	16L	
590598	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	563	
590599	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	BX0174	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
590600	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	BX0174	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
590601	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	BX0174	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
590602	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	BX0174	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
590603	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	BX0174	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
590604	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	BX0174	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
590605	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	BX0174	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
590606	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	BX0174	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	110	
590607	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	BX0174	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
590608	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	BX0174	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
590609	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	BX0174	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	110	
590610	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	BX0174	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	36	
590611	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	BX0174	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	41	
590612	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	BX0174	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	39	
590613	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	BX0174	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	95	
590614	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	9 Month Operations	0	
590615	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Accumulated Fault Duty A Ph V	.60	%
590616	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
590617	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
590618	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
590619	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Cabinet Paint Condition	Good	
590620	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Equipment Properly Labeled?	y	
590621	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Adjusted Amps A Phase V	0	
590622	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Adjusted Amps B Phase V	0	
590623	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Adjusted Amps C Phase V	0	
590624	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Operations A Ø	0	
590625	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Operations B Ø	0	
590626	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
590627	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Operations Ground	0	
590628	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Follow-up Action Required?	n	
590629	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Follow-up Action Required?	n	
590630	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Foundation Condition	Good	
590631	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	General Comments		
590632	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	General Comments		
590633	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Tank Paint Condition	Good	
590634	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Moisture and Leak Free?	y	
590635	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Grounds in Place?	y	
590636	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	All Connections OK?	y	
590637	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	Follow-up Action Required?	n	
590638	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Grounds in Place?	y	
590639	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Heaters (All) Functioning?	y	
590640	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Maintenance Operations	0	
590641	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	General Comments		
590642	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	LTC Operation Checked?	y	
590643	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
590644	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
590645	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
590646	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	General Comments		
590647	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Foundation Condition	Good	
590648	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Follow-up Action Required?	n	
590649	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	VRR Time Delay	30	Seconds
590650	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Equipment Properly Labeled?	y	
590651	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Cabinet Paint Condition	Good	
590652	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Moisture and Leak Free?	y	
590653	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
590654	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
590655	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
590656	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Bushings Connection/Risers	Good	
590657	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Bushing Condition	Good	
590658	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Operations Counter AF	412	
590659	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Operations Counter AL	416	
590660	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
590661	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
590662	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
590663	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Tank Paint Condition	Good	
590664	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Moisture and Leak Free?	y	
590665	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Grounds in Place?	y	
590666	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	General Comments		
590667	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Foundation Condition	Good	
590668	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Follow-up Action Required?	n	
590669	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Equipment Properly Labeled?	y	
590670	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Cabinet Paint Condition	Good	
590671	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
590672	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
590673	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
590674	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Bushings Connection/Risers	Good	
590675	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Bushing Condition	Good	
590676	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	General Comments		
590677	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	General Comments		
590678	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	General Comments		
590679	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Foundation Condition	Good	
590680	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Follow-up Action Required?	n	
590681	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Follow-up Action Required?	n	
590682	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Operations Ground	0	
590683	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Operations C Ø	0	
590684	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Operations B Ø	0	
590685	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Operations A Ø	0	
590686	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
590687	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
590688	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
590689	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
590690	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
590691	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	120	
590692	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	120	
590693	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	120	
590694	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
590695	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
590696	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
590697	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
590698	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
590699	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
590700	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
590701	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
590702	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Bushing Condition	Good	
590703	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Amps C Ø	101.0	
590704	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Amps B Ø	103.0	
590705	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Amps A Ø	116.0	
590706	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
590707	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
590708	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
590709	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
590710	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
590711	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
590712	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	9 Month Operations	0	
590713	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
590714	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
590715	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2R	
590716	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
590717	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
590718	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
590719	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
590720	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
590721	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
590722	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	8R	
590723	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
590724	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
590725	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
590726	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
590727	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
590728	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
590729	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	31526	
590730	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
590731	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
590732	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
590733	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
590734	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
590735	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
590736	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
590737	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
590738	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Accumulated Fault Duty B Ph V	.60	%
590739	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Accumulated Fault Duty C Ph V	.60	%
590740	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Amps A Ø	13.0	
590741	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Amps B Ø	14.0	
590742	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Amps C Ø	13.0	
590743	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Bushing Condition	Good	
590744	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Bushings Connection/Risers	Good	
590745	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
590746	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
590747	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
590748	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Cabinet Paint Condition	Good	
590749	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Equipment Properly Labeled?	y	
590750	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
590751	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
590752	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
590753	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Operations A Ø	0	
590754	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Operations B Ø	0	
590755	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Operations C Ø	0	
590756	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Operations Ground	0	
590757	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Follow-up Action Required?	n	
590758	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Follow-up Action Required?	y	
590759	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Foundation Condition	Good	
590760	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	General Comments		
590761	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	General Comments	mech flag indicator close is still not labeled. This was also noted in previous inspedtion.	
590762	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Grounds in Place?	y	
590763	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Heaters (All) Functioning?	y	
590764	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Maintenance Operations	0	
590765	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Moisture and Leak Free?	y	
590766	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Operations Counter AF	180	
590767	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Operations Counter AL	180	
590768	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
590769	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Switching Operations	0	
590770	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Tank Paint Condition	Good	
590771	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Unknown Operations	0	
590772	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Operations Counter AL	359	
590773	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Operations Counter AF	359	
590774	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Maintenance Operations	0	
590775	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
590776	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
590777	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Patrol Inspection	General Comments		
590778	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Follow-up Action Required?	n	
590779	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
590780	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Operations Ground	0	
590781	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Operations C Ø	0	
590782	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Operations B Ø	0	
590783	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Operations A Ø	0	
590784	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
590785	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
590786	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
590787	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
590788	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Amps C Ø	120.0	
590789	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Amps B Ø	250.0	
590790	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Amps A Ø	120.0	
590791	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Unknown Operations	0	
590792	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Tank Paint Condition	Good	
590793	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Switching Operations	0	
590794	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Operations Counter AL	176	
590795	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Operations Counter AF	176	
590796	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
590797	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Maintenance Operations	0	
590798	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Grounds in Place?	y	
590799	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
590800	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
590801	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
590802	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
590803	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
590804	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
590805	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
590806	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
590807	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
590808	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
590809	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
590810	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	General Comments		
590811	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
590812	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Foundation Condition	Good	
590813	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
590814	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
590815	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
590816	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
590817	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
590818	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
590819	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
590820	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	General Comments	fence section not properly secured, and leaning. Broken ground strap at back of staton.	
590821	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
590822	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
590823	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
590824	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
590825	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
590826	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
590827	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
590828	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
590829	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
590830	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
590831	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
590832	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	Follow-up Action Required?	n	
590833	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
590834	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
590835	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
590836	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Vegetation	None	
590837	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
590838	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
590839	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	General Comments		
590840	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
590841	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
590842	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
590843	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
590844	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
590845	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
590846	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
590847	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
590848	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Clear of Trash?	y	
590849	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
590850	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
590851	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Ambient Temp	55	°F

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
590852	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
590853	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
590854	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
590855	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
590856	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Grounds in Place?	n	
590857	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
590858	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
590859	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
590860	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Bushings Connection/Risers	Good	
590861	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Bushing Condition	Good	
590862	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Amps C Ø	42	
590863	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Amps B Ø	44	
590864	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Amps A Ø	28	
590865	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Accumulated Fault Duty C Ph V	1.96	%
590866	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Accumulated Fault Duty B Ph V	1.96	%
590867	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Accumulated Fault Duty A Ph V	1.96	%
590868	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	9 Month Operations	8	
590869	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
590870	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	General Comments		
590871	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
590872	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
590873	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
590874	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
590875	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
590876	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
590877	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	General Comments		
590878	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
590879	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
590880	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
590881	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
590882	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
590883	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
590884	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
590885	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
590886	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
590887	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
590888	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
590889	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	General Comments		
590890	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Panel Lights OK?	y	
590891	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
590892	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
590893	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
590894	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	30	°C
590895	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	30	°C
590896	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
590897	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
590898	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
590899	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
590900	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
590901	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
590902	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
590903	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
590904	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
590905	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
590906	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
590907	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
590908	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
590909	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	30	°C
590910	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
590911	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	30	°C
590912	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
590913	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	30	°C
590914	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
590915	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
590916	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
590917	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
590918	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
590919	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
590920	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
590921	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Operations B Ø	0	
590922	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
590923	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Operations C Ø	0	
590924	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Operations Ground	0	
590925	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Patrol Inspection	Follow-up Action Required?	n	
590926	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
590927	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Patrol Inspection	General Comments		
590928	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	General Comments		
590929	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Maintenance Operations	0	
590930	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Operations Counter AF	638	
590931	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Operations Counter AL	638	
590932	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Switching Operations	0	
590933	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Unknown Operations	0	
590934	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
590935	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
590936	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
590937	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
590938	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
590939	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
590940	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
590941	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
590942	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
590943	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
590944	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
590945	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
590946	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	General Comments		
590947	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
590948	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
590949	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Foundation Condition	Good	
590950	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
590951	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
590952	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
590953	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
590954	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
590955	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
590956	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Unknown Operations	0	
590957	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Switching Operations	0	
590958	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Tank Paint Condition	Good	
590959	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
590960	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Grounds in Place?	y	
590961	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	General Comments		
590962	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Foundation Condition	Good	
590963	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Follow-up Action Required?	n	
590964	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
590965	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
590966	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
590967	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
590968	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
590969	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Bushing Condition	Good	
590970	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LTCC000285	LTCControl	FH-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
590971	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LTCC000285	LTCControl	FH-TRANS 1	LTC Control Insp	General Comments		
590972	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LTCC000285	LTCControl	FH-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
590973	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	9 Month Operations	8	
590974	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Accumulated Fault Duty A Ph V	0	%
590975	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Accumulated Fault Duty B Ph V	0	%
590976	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Accumulated Fault Duty C Ph V	0	%
590977	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Amps A Ø	60	
590978	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Amps B Ø	60	
590979	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Amps C Ø	60	
590980	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Bushing Condition	Good	
590981	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Bushings Connection/Risers	Good	
590982	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
590983	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
590984	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
590985	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
590986	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
590987	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
590988	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
590989	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
590990	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
590991	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
590992	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
590993	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
590994	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
590995	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
590996	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
590997	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
590998	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
590999	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	PF001219	PowerFuse	585-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
591000	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	PF001219	PowerFuse	585-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
591001	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
591002	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	General Comments		
591003	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	General Comments		
591004	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
591005	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
591006	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
591007	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
591008	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
591009	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	H2 Winding Temp Max	40	°C
591010	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	H2 Winding Temp Present	40	°C
591011	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
591012	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
591013	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	226.00	
591014	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
591015	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	Oil Temp Max	35	°C
591016	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	Oil Temp Present	35	°C
591017	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
591018	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
591019	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
591020	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
591021	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
591022	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
591023	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
591024	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
591025	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
591026	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	X2 Winding Temp Max	35	°C
591027	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	X2 Winding Temp Present	35	°C
591028	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
591029	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
591030	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
591031	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	9 Month Operations	13	
591032	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Accumulated Fault Duty A Ph V	23.29	%
591033	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Accumulated Fault Duty B Ph V	45.77	%
591034	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Accumulated Fault Duty C Ph V	25.70	%
591035	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Amps A Ø	172.0	
591036	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Amps B Ø	181.0	
591037	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Amps C Ø	176.0	
591038	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Patrol Inspection	Equipment Properly Labeled?	y	
591039	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
591040	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
591041	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
591042	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Operations A Ø	0	
591043	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
591044	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
591045	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
591046	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
591047	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
591048	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
591049	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
591050	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Follow-up Action Required?	n	
591051	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
591052	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
591053	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	General Comments		
591054	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	General Comments		
591055	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
591056	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	LTC Totalizer Reading	6249.6	kw
591057	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
591058	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Operations A Ø	0	
591059	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Adjusted Amps C Phase V	0	
591060	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1200	psi
591061	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Oil Temp Max	30	°C
591062	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Oil Temp Present	28	°C
591063	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
591064	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
591065	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
591066	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
591067	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
591068	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
591069	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
591070	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Current Tap Position	2L	
591071	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
591072	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
591073	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
591074	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
591075	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	General Comments		
591076	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
591077	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Max Tap Position	1L	
591078	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Min Tap Position	5L	
591079	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
591080	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
591081	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
591082	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
591083	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
591084	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
591085	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
591086	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
591087	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
591088	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
591089	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Regulator As Left Counter	61744	
591090	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
591091	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
591092	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Bushings Connection/Risers	Good	
591093	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Bushing Condition	Good	
591094	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Amps C Ø	.5	
591095	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Amps B Ø	.1	
591096	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Amps A Ø	.6	
591097	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Accumulated Fault Duty C Ph V	4.25	%
591098	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Accumulated Fault Duty B Ph V	4.25	%
591099	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
591100	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Tank Leaks	None	
591101	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
591102	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Accumulated Fault Duty A Ph V	5.37	%
591103	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
591104	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	21000	
591105	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3744	
591106	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Winding Temp Max	32	°C
591107	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Winding Temp Present	8	°C
591108	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
591109	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
591110	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
591111	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
591112	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
591113	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
591114	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
591115	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
591116	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Amps C Ø	200.0	
591117	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
591118	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
591119	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
591120	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
591121	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
591122	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
591123	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
591124	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
591125	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
591126	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
591127	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Patrol Inspection	General Comments		
591128	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	General Comments		
591129	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
591130	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
591131	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
591132	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
591133	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
591134	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
591135	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
591136	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
591137	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
591138	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
591139	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
591140	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
591141	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Maintenance Operations	0	
591142	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Operations Counter AF	34	
591143	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Operations Counter AL	34	
591144	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Switching Operations	0	
591145	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Unknown Operations	0	
591146	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LTCC000020	LTCControl	LY-TRANS 2	LTC Control Insp	General Comments	OK	
591147	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LTCC000020	LTCControl	LY-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
591148	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	General Comments		
591149	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
591150	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	PF000200	PowerFuse	LS-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
591151	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	PF000200	PowerFuse	LS-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
591152	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	General Comments		
591153	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Foundation Condition	Good	
591154	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Follow-up Action Required?	n	
591155	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Follow-up Action Required?	n	
591156	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
591157	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
591158	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
591159	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
591160	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Operations Ground	0	
591161	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Operations C Ø	0	
591162	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Operations B Ø	0	
591163	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
591164	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Follow-up Action Required?	n	
591165	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Follow-up Action Required?	n	
591166	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Foundation Condition	Good	
591167	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
591168	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
591169	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	General Comments		
591170	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	General Comments		
591171	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Grounds in Place?	y	
591172	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Maintenance Operations	0	
591173	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Moisture and Leak Free?	y	
591174	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Operations Counter AF	188	
591175	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Operations Counter AL	188	
591176	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Switching Operations	1	
591177	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
591178	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
591179	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	All Connections OK?	y	
591180	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	Follow-up Action Required?	n	
591181	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	General Comments		
591182	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	LTC Operation Checked?	y	
591183	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
591184	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	VRR Base Voltage AF	124	VAC
591185	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	VRR Base Voltage AL	124	VAC
591186	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	VRR Time Delay	30	Seconds
591187	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Operations B Ø	0	
591188	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Operations C Ø	0	
591189	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
591190	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
591191	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
591192	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
591193	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
591194	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
591195	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
591196	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
591197	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
591198	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
591199	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
591200	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
591201	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Operations Ground	0	
591202	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
591203	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Follow-up Action Required?	n	
591204	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Patrol Inspection	General Comments		
591205	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	General Comments		
591206	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
591207	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
591208	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
591209	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Maintenance Operations	0	
591210	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Operations Counter AF	509	
591211	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
591212	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
591213	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
591214	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
591215	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
591216	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
591217	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
591218	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
591219	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
591220	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
591221	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
591222	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
591223	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	General Comments		
591224	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
591225	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	9 Month Operations	10	
591226	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
591227	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
591228	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
591229	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
591230	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
591231	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
591232	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Totalizer Meter Reading	.434	
591233	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Winding Temp Max	32	°C
591234	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Winding Temp Present	30	°C
591235	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
591236	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
591237	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
591238	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
591239	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
591240	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
591241	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
591242	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
591243	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Adjusted Amps B Phase V	0	
591244	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Adjusted Amps A Phase V	0	
591245	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Equipment Properly Labeled?	y	
591246	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
591247	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
591248	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
591249	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
591250	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
591251	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
591252	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
591253	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
591254	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
591255	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Cabinet Paint Condition	Good	
591256	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	9 Month Operations	43	
591257	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Accumulated Fault Duty A Ph V	0	%
591258	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Accumulated Fault Duty B Ph V	0	%
591259	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Accumulated Fault Duty C Ph V	0	%
591260	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Amps A Ø	4	
591261	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
591262	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
591263	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
591264	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
591265	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Amps B Ø	2	
591266	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Amps C Ø	6	
591267	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Bushing Condition	Good	
591268	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Bushings Connection/Risers	Good	
591269	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
591270	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
591271	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
591272	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Cabinet Paint Condition	Good	
591273	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Equipment Properly Labeled?	y	
591274	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Adjusted Amps A Phase V	0	
591275	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Adjusted Amps B Phase V	0	
591276	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Adjusted Amps C Phase V	0	
591277	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Operations A Ø	0	
591278	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Operations B Ø	0	
591279	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
591280	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
591281	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Operations C Ø	0	
591282	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
591283	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
591284	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
591285	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Operations Ground	0	
591286	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
591287	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
591288	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Operations B Ø	0	
591289	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Operations C Ø	0	
591290	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Operations Ground	0	
591291	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Follow-up Action Required?	n	
591292	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Follow-up Action Required?	n	
591293	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Foundation Condition	Good	
591294	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	General Comments		
591295	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	General Comments		
591296	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
591297	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Current Tap Position	2L	
591298	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
591299	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
591300	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
591301	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
591302	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	General Comments		
591303	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Grounds in Place?	y	
591304	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Maintenance Operations	0	
591305	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Moisture and Leak Free?	y	
591306	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
591307	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
591308	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Broom on Site?	y	
591309	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
591310	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
591311	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
591312	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
591313	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Evidence of Insects	None	
591314	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
591315	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
591316	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	General Comments		
591317	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
591318	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
591319	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
591320	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
591321	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
591322	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
591323	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
591324	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
591325	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Operations Counter AF	220	
591326	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Operations Counter AL	225	
591327	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Switching Operations	5	
591328	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Tank Paint Condition	Good	
591329	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
591330	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
591331	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
591332	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
591333	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
591334	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
591335	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Moisture and Leak Free?	y	
591336	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Maintenance Operations	0	
591337	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Heaters (All) Functioning?	y	
591338	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Grounds in Place?	y	
591339	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Floor Swept?	y	
591340	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
591341	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
591342	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	General Comments		
591343	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Unknown Operations	0	
591344	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
591345	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
591346	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	General Comments		
591347	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Unknown Operations	0	
591348	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Tank Paint Condition	Good	
591349	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Switching Operations	1	
591350	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Operations Counter AL	221	
591351	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Operations Counter AF	221	
591352	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
591353	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Tank Leaks	None	
591354	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
591355	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Tank Paint Condition	Good	
591356	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Unknown Operations	0	
591357	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Switching Operations	4	
591358	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
591359	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Operations Counter AL	311	
591360	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Operations Counter AF	307	
591361	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
591362	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Regulator As Left Counter	3611	
591363	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
591364	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
591365	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
591366	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
591367	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
591368	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
591369	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
591370	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
591371	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
591372	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Min Tap Position	4L	
591373	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Max Tap Position	4R	
591374	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
591375	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	General Comments		
591376	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
591377	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
591378	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
591379	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Moisture and Leak Free?	y	
591380	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Maintenance Operations	0	
591381	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Grounds in Place?	y	
591382	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
591383	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
591384	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
591385	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Foundation Condition	Good	
591386	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
591387	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
591388	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	General Comments		
591389	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
591390	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
591391	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
591392	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
591393	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
591394	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
591395	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
591396	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
591397	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
591398	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
591399	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
591400	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Cabinet Paint Condition	Good	
591401	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Equipment Properly Labeled?	y	
591402	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
591403	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
591404	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
591405	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Operations A Ø	0	
591406	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
591407	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
591408	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
591409	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
591410	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
591411	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
591412	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
591413	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
591414	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
591415	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
591416	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
591417	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
591418	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
591419	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
591420	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
591421	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Amps C Ø	200.0	
591422	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
591423	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
591424	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Amps B Ø	190.0	
591425	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Amps A Ø	170.0	
591426	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
591427	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
591428	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
591429	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Accumulated Fault Duty B Ph AM	2.14	%
591430	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
591431	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	9 Months Operations	1	
591432	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
591433	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	General Comments		
591434	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
591435	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
591436	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
591437	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
591438	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
591439	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
591440	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
591441	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
591442	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
591443	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
591444	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
591445	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
591446	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
591447	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
591448	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
591449	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
591450	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
591451	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
591452	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	General Comments		
591453	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
591454	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
591455	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
591456	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
591457	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
591458	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	7862.40	kw
591459	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
591460	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
591461	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Oil Temp Max	32	°C
591462	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Oil Temp Present	32	°C
591463	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
591464	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
591465	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
591466	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
591467	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
591468	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
591469	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	General Comments		
591470	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Foundation Condition	Good	
591471	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Follow-up Action Required?	n	
591472	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Follow-up Action Required?	n	
591473	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Operations Ground	0	
591474	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Operations C Ø	0	
591475	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
591476	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
591477	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
591478	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
591479	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
591480	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
591481	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	4R	
591482	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
591483	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
591484	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
591485	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
591486	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
591487	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
591488	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	10R	
591489	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	2R	
591490	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
591491	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
591492	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
591493	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
591494	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
591495	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	70497	
591496	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
591497	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
591498	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Panels Dusted?	y	
591499	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
591500	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
591501	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Trash Emptied?	y	
591502	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
591503	2/6/2019 11:13	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
591504	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
591505	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
591506	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
591507	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
591508	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Vegetation	None	
591509	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
591510	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
591511	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	General Comments		
591512	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
591513	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
591514	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
591515	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
591516	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
591517	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Clear of Trash?	y	
591518	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	9 Months Operations	0	
591519	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	10.40	%
591520	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	10.40	%
591521	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	10.40	%
591522	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Amps A Ø	300.0	
591523	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Amps B Ø	200.0	
591524	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
591525	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
591526	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
591527	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
591528	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
591529	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
591530	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Moisture and Leak Free?	y	
591531	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Operations Counter AF	156	
591532	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Operations Counter AL	156	
591533	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
591534	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Switching Operations	1	
591535	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Tank Paint Condition	Good	
591536	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Unknown Operations	0	
591537	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
591538	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
591539	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
591540	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
591541	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
591542	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
591543	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
591544	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
591545	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
591546	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
591547	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
591548	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
591549	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
591550	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
591551	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
591552	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
591553	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
591554	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
591555	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
591556	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Bushing Condition	Good	
591557	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Bushings Connection/Risers	Good	
591558	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
591559	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
591560	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
591561	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Cabinet Paint Condition	Good	
591562	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Equipment Properly Labeled?	y	
591563	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Follow-up Action Required?	n	
591564	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Foundation Condition	Good	
591565	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	General Comments		
591566	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Grounds in Place?	y	
591567	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Heaters (All) Functioning?	y	
591568	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Moisture and Leak Free?	y	
591569	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
591570	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Tank Paint Condition	Good	
591571	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	9 Month Operations	0	
591572	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
591573	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
591574	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
591575	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Amps A Ø	0.0	
591576	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Amps B Ø	0.0	
591577	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Amps C Ø	0.0	
591578	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Bushing Condition	Good	
591579	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Bushings Connection/Risers	Good	
591580	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
591581	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
591582	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
591583	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Cabinet Paint Condition	Good	
591584	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Equipment Properly Labeled?	y	
591585	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
591586	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
591587	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
591588	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Fault Operations A Ø	0	
591589	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Fault Operations B Ø	0	
591590	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Adjusted Amps B Phase V	0	
591591	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
591592	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
591593	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
591594	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
591595	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45	
591596	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51	
591597	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2825.28	kw
591598	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
591599	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
591600	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
591601	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
591602	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	General Comments		
591603	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	General Comments		
591604	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
591605	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
591606	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	General Comments		
591607	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	General Comments		
591608	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Grounds in Place?	y	
591609	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
591610	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Maintenance Operations	0	
591611	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
591612	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Operations Counter AF	136	
591613	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Unknown Operations	0	
591614	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
591615	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Operations Counter AL	136	
591616	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
591617	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Switching Operations	1	
591618	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
591619	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Unknown Operations	0	
591620	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Operations B Ø	0	
591621	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Operations A Ø	0	
591622	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Adjusted Amps C Phase V	0	
591623	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	9 Month Operations	1	
591624	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
591625	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
591626	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
591627	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Amps A Ø	250.0	
591628	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Amps B Ø	300.0	
591629	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Amps C Ø	300.0	
591630	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Bushing Condition	Good	
591631	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Bushings Connection/Risers	Good	
591632	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
591633	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
591634	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
591635	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Cabinet Paint Condition	Good	
591636	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Equipment Properly Labeled?	y	
591637	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
591638	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
591639	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
591640	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Operations A Ø	0	
591641	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Operations B Ø	0	
591642	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Operations C Ø	0	
591643	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Operations Ground	0	
591644	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Follow-up Action Required?	n	
591645	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Follow-up Action Required?	n	
591646	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Foundation Condition	Good	
591647	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	General Comments		
591648	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	General Comments		
591649	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Grounds in Place?	y	
591650	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Heaters (All) Functioning?	y	
591651	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Maintenance Operations	0	
591652	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	General Comments		
591653	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Patrol Inspection	General Comments		
591654	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Follow-up Action Required?	n	
591655	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
591656	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
591657	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
591658	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
591659	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
591660	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
591661	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
591662	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	General Comments		
591663	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
591664	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
591665	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
591666	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
591667	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
591668	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
591669	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
591670	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Clear of Trash?	y	
591671	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
591672	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
591673	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
591674	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
591675	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
591676	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
591677	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
591678	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
591679	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
591680	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
591681	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
591682	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	General Comments		
591683	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
591684	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
591685	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
591686	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	Oil Temp Max	35	°C
591687	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
591688	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Operations Ground	0	
591689	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Operations C Ø	0	
591690	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Operations B Ø	0	
591691	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Operations A Ø	0	
591692	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
591693	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
591694	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
591695	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
591696	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
591697	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
591698	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
591699	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
591700	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
591701	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
591702	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	30	°C
591703	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	20	°C
591704	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
591705	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
591706	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
591707	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
591708	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
591709	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
591710	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
591711	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
591712	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
591713	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Adjusted Amps A Phase V	0	
591714	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Equipment Properly Labeled?	y	
591715	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Cabinet Paint Condition	Good	
591716	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
591717	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
591718	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
591719	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Bushings Connection/Risers	Good	
591720	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Bushing Condition	Good	
591721	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Amps C Ø	120	
591722	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Amps B Ø	120	
591723	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Amps A Ø	120	
591724	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Fault Operations C Ø	0	
591725	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Fault Operations Ground	0	
591726	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Follow-up Action Required?	n	
591727	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Follow-up Action Required?	n	
591728	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Foundation Condition	Good	
591729	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	General Comments		
591730	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	General Comments	CARDED OUT	
591731	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Grounds in Place?	y	
591732	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Heaters (All) Functioning?	y	
591733	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Maintenance Operations	0	
591734	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Moisture and Leak Free?	y	
591735	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Operations Counter AF	135	
591736	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Operations Counter AL	135	
591737	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
591738	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Switching Operations	0	
591739	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Tank Paint Condition	Good	
591740	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Unknown Operations	0	
591741	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
591742	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
591743	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
591744	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
591745	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
591746	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
591747	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	General Comments		
591748	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Accumulated Fault Duty C Ph V	0	%
591749	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
591750	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Accumulated Fault Duty B Ph V	0	%
591751	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Accumulated Fault Duty A Ph V	0	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
591752	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	9 Month Operations	8	
591753	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Bushing Condition	Good	
591754	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Bushings Connection/Risers	Good	
591755	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
591756	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
591757	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
591758	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Cabinet Paint Condition	Good	
591759	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Equipment Properly Labeled?	y	
591760	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Follow-up Action Required?	n	
591761	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Foundation Condition	Good	
591762	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	General Comments		
591763	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Grounds in Place?	y	
591764	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Heaters (All) Functioning?	y	
591765	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Moisture and Leak Free?	y	
591766	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
591767	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Tank Paint Condition	Good	
591768	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Unknown Operations	0	
591769	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Switching Operations	0	
591770	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Operations Counter AL	372	
591771	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Operations Counter AF	372	
591772	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Maintenance Operations	0	
591773	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
591774	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
591775	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	General Comments		
591776	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
591777	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
591778	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Foundation Condition	Good	
591779	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
591780	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
591781	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
591782	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
591783	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
591784	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
591785	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Amps B Ø	40.0	
591786	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Amps C Ø	40.0	
591787	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
591788	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
591789	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
591790	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
591791	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Operations A Ø	0	
591792	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Operations B Ø	0	
591793	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	Follow-up Action Required?	n	
591794	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
591795	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	General Comments		
591796	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	General Comments		
591797	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC As Found Counter	500	
591798	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC As Left Counter	504	
591799	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
591800	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC Current Tap Position	10L	
591801	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC Max Tap Position	15L	
591802	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC Min Tap Position	3L	
591803	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1	psi
591804	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC Operations Since Last Insp	450	
591805	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
591806	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
591807	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
591808	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
591809	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Operations C Ø	0	
591810	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Operations Ground	0	
591811	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
591812	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Accumulated Fault Duty A Ph V	0	%
591813	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	9 Month Operations	36	
591814	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Follow-up Action Required?	n	
591815	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Patrol Inspection	General Comments		
591816	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
591817	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
591818	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
591819	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	General Comments		
591820	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
591821	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Maintenance Operations	0	
591822	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
591823	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
591824	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Operations Counter AF	621	
591825	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Operations Counter AL	621	
591826	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Switching Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
591827	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Unknown Operations	0	
591828	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
591829	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
591830	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
591831	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
591832	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
591833	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
591834	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
591835	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
591836	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
591837	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
591838	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Operations Counter AL	509	
591839	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Switching Operations	0	
591840	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
591841	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
591842	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
591843	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
591844	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
591845	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
591846	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Unknown Operations	0	
591847	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Switching Operations	0	
591848	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Operations Counter AL	630	
591849	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Operations Counter AF	630	
591850	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Maintenance Operations	0	
591851	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	General Comments		
591852	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Patrol Inspection	General Comments		
591853	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
591854	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
591855	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	General Comments		
591856	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
591857	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
591858	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
591859	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
591860	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
591861	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
591862	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	Top Oil Temperature Max	35	°C
591863	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	Top Oil Temperature Present	30	°C
591864	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Unknown Operations	0	
591865	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	9 Months Operations	0	
591866	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
591867	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
591868	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
591869	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Amps A Ø	40.0	
591870	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
591871	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
591872	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
591873	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
591874	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
591875	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
591876	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
591877	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
591878	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Bushings Connection/Risers	Good	
591879	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Bushing Condition	Good	
591880	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
591881	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Amps C Ø	8	
591882	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Amps B Ø	7	
591883	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Amps A Ø	8	
591884	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Accumulated Fault Duty C Ph V	0	%
591885	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Accumulated Fault Duty B Ph V	0	%
591886	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
591887	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
591888	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
591889	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
591890	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
591891	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
591892	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
591893	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
591894	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
591895	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
591896	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
591897	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
591898	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
591899	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
591900	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
591901	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
591902	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
591903	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
591904	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
591905	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
591906	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
591907	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
591908	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Clear of Trash?	y	
591909	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Vegetation	None	
591910	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
591911	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
591912	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	General Comments		
591913	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
591914	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
591915	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
591916	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
591917	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
591918	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
591919	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Clear of Trash?	y	
591920	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
591921	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
591922	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
591923	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	9 Month Operations	3	
591924	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
591925	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
591926	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
591927	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Amps A Ø	400.0	
591928	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Amps B Ø	400.0	
591929	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Amps C Ø	400.0	
591930	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
591931	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
591932	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
591933	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Bushing Condition	Good	
591934	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
591935	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
591936	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
591937	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
591938	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
591939	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
591940	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
591941	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
591942	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
591943	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
591944	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
591945	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
591946	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Operations Ground	0	
591947	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
591948	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
591949	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Foundation Condition	Good	
591950	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1772	
591951	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
591952	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Top Oil Temperature Present	40	°C
591953	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Top Oil Temperature Max	60	°C
591954	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
591955	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
591956	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
591957	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments		
591958	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
591959	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
591960	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
591961	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
591962	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
591963	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
591964	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
591965	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
591966	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
591967	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
591968	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
591969	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
591970	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
591971	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
591972	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
591973	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
591974	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
591975	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
591976	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
591977	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
591978	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
591979	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
591980	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
591981	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
591982	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
591983	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
591984	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Vegetation	None	
591985	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
591986	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
591987	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	General Comments		
591988	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
591989	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
591990	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
591991	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
591992	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
591993	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
591994	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Tank Paint Condition	Good	
591995	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
591996	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Vegetation	None	
591997	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
591998	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
591999	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
592000	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	DX0096	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
592001	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	DX0096	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
592002	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	DX0096	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	547	
592003	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	DX0096	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
592004	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	DX0096	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
592005	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	DX0096	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
592006	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	DX0096	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
592007	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	DX0096	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
592008	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	DX0096	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
592009	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
592010	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
592011	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
592012	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
592013	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
592014	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	General Comments		
592015	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
592016	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
592017	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Foundation Condition	Good	
592018	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Equipment Properly Labeled?	y	
592019	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
592020	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
592021	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
592022	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
592023	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
592024	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Operations A Ø	0	
592025	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Operations B Ø	0	
592026	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Operations C Ø	0	
592027	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Operations Ground	0	
592028	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Follow-up Action Required?	n	
592029	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Follow-up Action Required?	n	
592030	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Foundation Condition	Good	
592031	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	General Comments		
592032	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	General Comments		
592033	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Grounds in Place?	y	
592034	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Heaters (All) Functioning?	y	
592035	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
592036	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	General Comments		
592037	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
592038	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
592039	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
592040	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
592041	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
592042	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
592043	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
592044	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	57990	
592045	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
592046	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
592047	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Regulator As Left Counter	47058	
592048	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
592049	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
592050	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Patrol Inspection	Equipment Properly Labeled?	y	
592051	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
592052	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
592053	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
592054	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
592055	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Patrol Inspection	Follow-up Action Required?	n	
592056	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Patrol Inspection	General Comments		
592057	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
592058	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Tank Leaks	None	
592059	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
592060	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
592061	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Maintenance Operations	0	
592062	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Moisture and Leak Free?	y	
592063	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Operations Counter AF	183	
592064	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Operations Counter AL	183	
592065	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
592066	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Switching Operations	0	
592067	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Tank Paint Condition	Good	
592068	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Unknown Operations	0	
592069	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
592070	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
592071	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
592072	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
592073	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
592074	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Min Tap Position	1R	
592075	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Max Tap Position	4R	
592076	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
592077	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	General Comments		
592078	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
592079	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
592080	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
592081	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
592082	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
592083	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
592084	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Tank Leaks	None	
592085	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
592086	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
592087	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
592088	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Regulator As Left Counter	30800	
592089	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
592090	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	9 Month Operations	1	
592091	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
592092	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
592093	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
592094	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC Operations Since Last Insp	889	
592095	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC Min Tap Position	3L	
592096	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
592097	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC Max Tap Position	13L	
592098	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC Current Tap Position	8L	
592099	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
592100	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	9 Month Operations	2	
592101	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	BCH000361	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
592102	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	BCH000361	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
592103	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
592104	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC As Left Counter	76241	
592105	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC As Found Counter	76239	
592106	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Mechanism Patrol Inspection	General Comments		
592107	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	General Comments		
592108	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
592109	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	Follow-up Action Required?	n	
592110	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	9 Month Operations	2	
592111	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
592112	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Accumulated Fault Duty B Ph V	.22	%
592113	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Accumulated Fault Duty C Ph V	.44	%
592114	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Amps A Ø	320.0	
592115	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
592116	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Amps B Ø	313.0	
592117	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Amps C Ø	353.0	
592118	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
592119	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Amps A Ø	0.0	
592120	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Amps B Ø	0.0	
592121	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Amps C Ø	0.0	
592122	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
592123	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Bushing Condition	Good	
592124	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
592125	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
592126	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
592127	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
592128	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Bushings Connection/Risers	Good	
592129	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
592130	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
592131	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
592132	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Cabinet Paint Condition	Good	
592133	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
592134	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
592135	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
592136	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
592137	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
592138	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Operations A Ø	0	
592139	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Operations B Ø	0	
592140	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Operations C Ø	0	
592141	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Operations Ground	0	
592142	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
592143	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Follow-up Action Required?	n	
592144	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
592145	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	General Comments		
592146	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	General Comments	BFTC	
592147	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
592148	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Maintenance Operations	0	
592149	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
592150	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Operations Counter AF	162	
592151	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Operations Counter AL	162	
592152	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Switching Operations	1	
592153	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	BCH000361	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
592154	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	BCH000361	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
592155	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	BCH000361	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
592156	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	BCH000361	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
592157	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
592158	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Unknown Operations	0	
592159	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Patrol Inspection	Equipment Properly Labeled?	y	
592160	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Patrol Inspection	Follow-up Action Required?	n	
592161	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	General Comments		
592162	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
592163	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
592164	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Patrol Inspection	General Comments		
592165	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
592166	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
592167	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC As Left Counter	408009	
592168	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
592169	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
592170	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
592171	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
592172	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
592173	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
592174	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
592175	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
592176	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
592177	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
592178	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
592179	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	General Comments		
592180	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
592181	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
592182	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
592183	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
592184	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
592185	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
592186	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
592187	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123	volts
592188	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Regulator As Left Counter	51915	
592189	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
592190	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
592191	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Tank Leaks	None	
592192	2/6/2019 8:58	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
592193	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3L	
592194	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
592195	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
592196	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Mechanism Patrol Inspection	General Comments		
592197	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC As Found Counter	238608	
592198	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC As Left Counter	238619	
592199	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
592200	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC Current Tap Position	7R	
592201	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC Max Tap Position	10R	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
592202	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC Min Tap Position	7L	
592203	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC Operations Since Last Insp	1043	
592204	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
592205	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC Min Tap Position	5L	
592206	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
592207	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
592208	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
592209	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
592210	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
592211	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
592212	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
592213	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
592214	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
592215	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
592216	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
592217	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
592218	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
592219	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
592220	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
592221	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
592222	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
592223	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
592224	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	291	
592225	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
592226	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
592227	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
592228	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
592229	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
592230	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
592231	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	General Comments		
592232	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
592233	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC As Found Counter	317824	
592234	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC As Left Counter	317824	
592235	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
592236	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
592237	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
592238	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
592239	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
592240	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
592241	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
592242	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
592243	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
592244	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Amps A Ø	0.0	
592245	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Amps B Ø	0.0	
592246	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Amps C Ø	0.0	
592247	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Bushing Condition	Good	
592248	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Bushings Connection/Risers	Good	
592249	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
592250	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
592251	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
592252	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Cabinet Paint Condition	Good	
592253	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Equipment Properly Labeled?	y	
592254	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
592255	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
592256	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
592257	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Operations A Ø	0	
592258	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Operations B Ø	0	
592259	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Operations C Ø	0	
592260	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Operations Ground	0	
592261	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Follow-up Action Required?	n	
592262	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Follow-up Action Required?	n	
592263	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Foundation Condition	Good	
592264	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	General Comments		
592265	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	General Comments		
592266	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Grounds in Place?	y	
592267	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
592268	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
592269	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.700	millivolts
592270	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.7	VDC
592271	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.7	VDC
592272	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.7	amps
592273	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
592274	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Heaters (All) Functioning?	y	
592275	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Maintenance Operations	0	
592276	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
592277	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Operations Counter AF	185	
592278	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Operations Counter AL	185	
592279	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
592280	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Switching Operations	0	
592281	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Tank Paint Condition	Good	
592282	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Unknown Operations	0	
592283	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
592284	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	General Comments		
592285	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
592286	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
592287	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Tank Leaks	None	
592288	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
592289	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Follow-up Action Required?	n	
592290	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
592291	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Operations Ground	0	
592292	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Operations C Ø	0	
592293	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
592294	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Operations Counter	1440	
592295	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
592296	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
592297	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	General Comments		
592298	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
592299	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
592300	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
592301	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
592302	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
592303	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
592304	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
592305	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
592306	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
592307	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
592308	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
592309	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Amps C Ø	7	
592310	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Amps B Ø	20	
592311	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Amps A Ø	11	
592312	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
592313	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	General Comments		
592314	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	Needs Screw on dessicant filter	
592315	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC As Found Counter	408009	
592316	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	General Comments		
592317	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Panels Dusted?	y	
592318	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
592319	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
592320	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	General Comments		
592321	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
592322	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
592323	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Floor Swept?	y	
592324	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
592325	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
592326	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Evidence of Insects	None	
592327	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
592328	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
592329	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
592330	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
592331	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
592332	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
592333	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
592334	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
592335	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
592336	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Broom on Site?	y	
592337	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
592338	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
592339	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
592340	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	Follow-up Action Required?	n	
592341	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	9 Month Operations	2	
592342	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
592343	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
592344	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
592345	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Amps A Ø	0.0	
592346	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Amps B Ø	0.0	
592347	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Amps C Ø	0.0	
592348	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Bushing Condition	Good	
592349	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Bushings Connection/Risers	Good	
592350	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
592351	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
592352	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
592353	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Cabinet Paint Condition	Good	
592354	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
592355	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
592356	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
592357	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
592358	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Operations A Ø	0	
592359	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Operations B Ø	0	
592360	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Operations C Ø	0	
592361	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Operations Ground	0	
592362	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Follow-up Action Required?	n	
592363	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Follow-up Action Required?	n	
592364	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Foundation Condition	Good	
592365	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	General Comments		
592366	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	General Comments	BFTC	
592367	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Grounds in Place?	y	
592368	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Maintenance Operations	0	
592369	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Moisture and Leak Free?	y	
592370	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Operations Counter AF	188	
592371	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Operations Counter AL	188	
592372	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Switching Operations	1	
592373	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Tank Paint Condition	Good	
592374	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Unknown Operations	0	
592375	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
592376	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
592377	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
592378	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
592379	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
592380	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
592381	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	PF000153	PowerFuse	FH-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
592382	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	PF000153	PowerFuse	FH-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
592383	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	General Comments		
592384	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
592385	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Tank Paint Condition	Good	
592386	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Switching Operations	0	
592387	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
592388	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	SF6 Pressure Pole 3	60	psi
592389	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	SF6 Pressure Pole 2	60	psi
592390	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	SF6 Pressure Pole 1	59	psi
592391	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Min Tap Position	7L	
592392	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
592393	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
592394	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
592395	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
592396	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
592397	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Regulator As Left Counter	67605	
592398	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
592399	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
592400	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Operations C Ø	0	
592401	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Operations Ground	0	
592402	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
592403	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
592404	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
592405	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Operations B Ø	0	
592406	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Operations A Ø	0	
592407	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
592408	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
592409	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
592410	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Follow-up Action Required?	n	
592411	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Patrol Inspection	General Comments		
592412	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	General Comments		
592413	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
592414	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
592415	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Tank Leaks	None	
592416	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
592417	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Maintenance Operations	0	
592418	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Operations Counter AF	486	
592419	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Operations Counter AL	486	
592420	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Switching Operations	0	
592421	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
592422	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Max Tap Position	1R	
592423	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
592424	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	General Comments		
592425	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
592426	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
592427	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
592428	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
592429	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Current Tap Position	2L	
592430	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Amps C Ø	0.0	
592431	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Amps B Ø	0.0	
592432	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Unknown Operations	0	
592433	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Amps A Ø	0.0	
592434	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
592435	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
592436	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
592437	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	9 Months Operations	2	
592438	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	y	
592439	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
592440	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	Switchgear roof is leaking and dripping down wall near pop up desk.	
592441	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
592442	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
592443	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
592444	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
592445	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
592446	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
592447	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	n	
592448	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
592449	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
592450	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
592451	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
592452	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
592453	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
592454	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
592455	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
592456	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
592457	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
592458	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
592459	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
592460	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
592461	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
592462	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
592463	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Trash Emptied?	y	
592464	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
592465	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
592466	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Grounds in Place?	y	
592467	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Maintenance Operations	0	
592468	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Moisture and Leak Free?	y	
592469	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Operations Counter AF	178	
592470	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
592471	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
592472	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
592473	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Operations Counter AL	178	
592474	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Switching Operations	1	
592475	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Tank Paint Condition	Good	
592476	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Unknown Operations	0	
592477	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
592478	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
592479	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
592480	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
592481	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
592482	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
592483	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
592484	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	346	
592485	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
592486	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
592487	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
592488	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
592489	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
592490	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC As Left Counter	583030	
592491	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC As Found Counter	583030	
592492	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
592493	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
592494	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
592495	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
592496	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	Needs Dessicant. Screw on filter	
592497	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Winding Temp Present	27	°C
592498	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Winding Temp Max	30	°C
592499	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
592500	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
592501	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
592502	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
592503	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
592504	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
592505	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
592506	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
592507	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
592508	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
592509	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
592510	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Oil Temp Present	28	°C
592511	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
592512	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	General Comments		
592513	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Oil Temp Max	33	°C
592514	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
592515	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
592516	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
592517	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
592518	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1450	psi
592519	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
592520	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
592521	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
592522	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	General Comments		
592523	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	General Comments		
592524	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
592525	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
592526	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
592527	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
592528	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
592529	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
592530	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
592531	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
592532	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
592533	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
592534	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
592535	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
592536	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
592537	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
592538	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
592539	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
592540	2/6/2019 14:25	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
592541	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
592542	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Operations Counter AL	76	
592543	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Operations Counter AF	76	
592544	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Num Operations Last 9 Months	1	
592545	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
592546	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Maintenance Operations	0	
592547	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
592548	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Grounds in Place?	y	
592549	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	General Comments	y	
592550	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	General Comments		
592551	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
592552	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Foundation Condition	Good	
592553	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Follow-up Action Required?	n	
592554	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Follow-up Action Required?	n	
592555	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Fault Operations	0	
592556	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
592557	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
592558	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	9 Month Operations	2	
592559	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
592560	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
592561	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
592562	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
592563	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Ambient Temperature	65	°F
592564	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
592565	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
592566	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
592567	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
592568	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	292	
592569	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
592570	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC Min Tap Position	16L	
592571	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC Max Tap Position	9L	
592572	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC Current Tap Position	14L	
592573	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
592574	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC As Left Counter	103034	
592575	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC As Found Counter	103034	
592576	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	ok	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
592577	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
592578	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
592579	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Amps A Ø	0.0	
592580	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	General Comments		
592581	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Amps B Ø	0.0	
592582	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Amps C Ø	0.0	
592583	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Bushing Condition	Good	
592584	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Bushings Connection/Risers	Good	
592585	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
592586	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
592587	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
592588	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
592589	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
592590	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Cabinet Paint Condition	Good	
592591	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
592592	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
592593	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
592594	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
592595	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Operations A Ø	0	
592596	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Operations B Ø	0	
592597	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Operations C Ø	0	
592598	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Operations Ground	0	
592599	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Follow-up Action Required?	n	
592600	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Follow-up Action Required?	n	
592601	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Foundation Condition	Good	
592602	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	General Comments		
592603	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
592604	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
592605	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
592606	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
592607	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
592608	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
592609	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	General Comments		
592610	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
592611	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
592612	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
592613	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
592614	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
592615	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	General Comments	BFTC	
592616	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Max Tap Position	3R	
592617	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
592618	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	General Comments		
592619	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
592620	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
592621	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
592622	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Current Tap Position	1L	
592623	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
592624	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
592625	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
592626	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
592627	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	9 Months Operations	0	
592628	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
592629	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Vegetation	None	
592630	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
592631	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
592632	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
592633	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
592634	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
592635	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
592636	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
592637	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
592638	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
592639	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	General Comments		
592640	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
592641	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC As Found Counter	77814	
592642	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC As Left Counter	77814	
592643	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
592644	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
592645	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
592646	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC Current Tap Position	8L	
592647	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC Max Tap Position	12R	
592648	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC Min Tap Position	10L	
592649	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
592650	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	49	
592651	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
592652	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
592653	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
592654	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
592655	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
592656	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
592657	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
592658	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
592659	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	General Comments		
592660	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
592661	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
592662	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
592663	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Current Tap Position	1R	
592664	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	BAT000134	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	62	°F
592665	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Amps B Ø	50.0	
592666	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Regulator As Left Counter	4226	
592667	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
592668	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
592669	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Tank Leaks	None	
592670	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
592671	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
592672	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
592673	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
592674	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Foundation Condition	Good	
592675	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
592676	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
592677	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
592678	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
592679	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
592680	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
592681	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
592682	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	General Comments		
592683	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Patrol Inspection	General Comments		
592684	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Amps A Ø	60.0	
592685	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Operations B Ø	0	
592686	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Operations A Ø	0	
592687	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
592688	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Tank Leaks	None	
592689	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
592690	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
592691	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
592692	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Regulator As Left Counter	4459	
592693	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
592694	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
592695	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
592696	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
592697	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
592698	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
592699	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
592700	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
592701	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
592702	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
592703	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
592704	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
592705	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	207	
592706	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	211	
592707	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
592708	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
592709	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
592710	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
592711	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
592712	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
592713	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Min Tap Position	9L	
592714	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
592715	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	X0102	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
592716	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
592717	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
592718	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	General Comments		
592719	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	General Comments		
592720	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
592721	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Max Tap Position	3R	
592722	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	X0102	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
592723	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	X0102	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	201	
592724	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	X0102	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
592725	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	X0102	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
592726	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	X0102	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
592727	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	X0102	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
592728	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	X0102	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
592729	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Min Tap Position	1R	
592730	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
592731	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
592732	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
592733	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
592734	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
592735	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Regulator As Left Counter	131098	
592736	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
592737	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	94	
592738	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
592739	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Tank Leaks	None	
592740	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
592741	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
592742	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
592743	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	9 Months Operations	0	
592744	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
592745	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
592746	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	X0102	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
592747	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	X0102	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
592748	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	X0102	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	0	
592749	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	X0102	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	0	
592750	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
592751	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
592752	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
592753	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	X0102	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	0	
592754	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
592755	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Amps A Ø	100.0	
592756	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Amps B Ø	100.0	
592757	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Amps C Ø	140.0	
592758	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Current Tap Position	4L	
592759	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
592760	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
592761	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
592762	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
592763	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	BAT000134	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
592764	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	BAT000134	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
592765	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	BAT000134	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
592766	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	BAT000134	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
592767	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	BAT000134	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
592768	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	BAT000134	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
592769	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	BAT000134	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
592770	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	BAT000134	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
592771	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	BAT000134	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
592772	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	BAT000134	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
592773	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	BAT000134	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
592774	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	PF000151	PowerFuse	FH-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
592775	2/6/2019 14:26	Distribution	Freys Hill Quarterly Inspection	PF000151	PowerFuse	FH-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
592776	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
592777	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
592778	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
592779	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
592780	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
592781	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3L	
592782	2/6/2019 9:12	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
592783	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
592784	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
592785	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
592786	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	3R	
592787	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
592788	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
592789	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
592790	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
592791	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
592792	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
592793	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
592794	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
592795	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
592796	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
592797	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
592798	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Tank Leaks	None	
592799	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
592800	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
592801	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Regulator As Left Counter	3912	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
592802	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
592803	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
592804	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
592805	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
592806	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
592807	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
592808	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Min Tap Position	9L	
592809	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Max Tap Position	4R	
592810	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
592811	2/6/2019 9:04	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
592812	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	BAT000134	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
592813	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
592814	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
592815	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
592816	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
592817	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	General Comments		
592818	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
592819	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
592820	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
592821	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Min Tap Position	8L	
592822	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
592823	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
592824	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Unknown Operations	0	
592825	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	General Comments		
592826	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
592827	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
592828	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
592829	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
592830	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
592831	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Operations Counter	72	
592832	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	General Comments		
592833	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
592834	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
592835	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
592836	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
592837	2/6/2019 10:18	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
592838	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
592839	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
592840	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
592841	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	2R	
592842	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	8R	
592843	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
592844	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
592845	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
592846	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
592847	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Switching Operations	4	
592848	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	General Comments		
592849	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
592850	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
592851	2/6/2019 7:47	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Tank Paint Condition	Good	
592852	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
592853	2/6/2019 15:36	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
592854	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
592855	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
592856	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
592857	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Current Tap Position	2L	
592858	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
592859	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
592860	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Readings	General Comments		
592861	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
592862	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
592863	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
592864	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
592865	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
592866	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
592867	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
592868	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
592869	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	General Comments		
592870	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
592871	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
592872	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
592873	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Operations Counter AL	465	
592874	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
592875	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
592876	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
592877	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
592878	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
592879	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
592880	2/6/2019 9:26	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
592881	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
592882	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
592883	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
592884	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
592885	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Amps C Ø	60.0	
592886	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Operations Counter AF	465	
592887	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
592888	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Max Tap Position	4R	
592889	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
592890	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
592891	2/6/2019 8:48	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
592892	2/6/2019 9:17	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
592893	2/6/2019 11:58	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Maintenance Operations	0	
592894	2/6/2019 13:50	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
592895	2/6/2019 15:32	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
592896	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
592897	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
592898	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
592899	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
592900	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
592901	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Tank Leaks	None	
592902	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
592903	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Regulator As Left Counter	10703	
592904	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
592905	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
592906	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
592907	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
592908	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
592909	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Min Tap Position	5L	
592910	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Max Tap Position	1R	
592911	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
592912	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	General Comments	ok	
592913	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
592914	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
592915	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
592916	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
592917	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
592918	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Current Tap Position	2L	
592919	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
592920	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
592921	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
592922	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	10351	
592923	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
592924	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
592925	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
592926	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
592927	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
592928	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
592929	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	1R	
592930	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
592931	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments	ok	
592932	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
592933	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
592934	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
592935	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
592936	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	3L	
592937	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
592938	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
592939	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
592940	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
592941	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
592942	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Unknown Operations	0	
592943	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Switching Operations	0	
592944	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	General Comments		
592945	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Maintenance Operations	2	
592946	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Follow-up Action Required?	n	
592947	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Operations Ground	0	
592948	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Operations C Ø	0	
592949	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Operations B Ø	0	
592950	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Operations A Ø	0	
592951	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
592952	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
592953	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
592954	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Amps C Ø	140	
592955	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Operations Counter AF	373	
592956	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Operations Counter AL	375	
592957	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	9 Month Operations	6	
592958	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Accumulated Fault Duty A Ph V	9.6	%
592959	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Accumulated Fault Duty B Ph V	10.05	%
592960	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Accumulated Fault Duty C Ph V	8.68	%
592961	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Amps A Ø	135	
592962	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Amps B Ø	160	
592963	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Tank Paint Condition	Good	
592964	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
592965	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
592966	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Cabinet Paint Condition	Good	
592967	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Equipment Properly Labeled?	y	
592968	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Follow-up Action Required?	n	
592969	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
592970	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Moisture and Leak Free?	y	
592971	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Heaters (All) Functioning?	y	
592972	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Bushings Connection/Risers	Good	
592973	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Bushing Condition	Good	
592974	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Grounds in Place?	y	
592975	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	General Comments		
592976	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
592977	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Foundation Condition	Good	
592978	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	140	
592979	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
592980	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
592981	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	General Comments		
592982	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	4	
592983	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	140	
592984	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	282	
592985	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	140	
592986	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	287	
592987	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	19	
592988	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
592989	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
592990	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
592991	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
592992	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
592993	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
592994	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
592995	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
592996	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
592997	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
592998	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
592999	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
593000	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
593001	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
593002	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
593003	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
593004	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
593005	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
593006	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
593007	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
593008	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
593009	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
593010	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Unknown Operations	0	
593011	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
593012	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	General Comments	ok	
593013	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	General Comments	ok	
593014	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
593015	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
593016	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
593017	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
593018	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
593019	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
593020	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
593021	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Tank Leaks	None	
593022	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
593023	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
593024	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Regulator As Left Counter	18249	
593025	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
593026	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
593027	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
593028	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
593029	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
593030	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
593031	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Min Tap Position	12L	
593032	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
593033	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
593034	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Tank Leaks	None	
593035	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
593036	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
593037	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
593038	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Max Tap Position	1L	
593039	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
593040	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	General Comments		
593041	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
593042	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
593043	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
593044	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
593045	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
593046	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
593047	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
593048	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
593049	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
593050	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Regulator As Left Counter	32063	
593051	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
593052	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
593053	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
593054	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
593055	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
593056	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
593057	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
593058	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	Top Oil Temperature Max	34	°C
593059	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	Top Oil Temperature Present	22	°C
593060	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Vegetation	None	
593061	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
593062	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
593063	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
593064	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	299	
593065	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
593066	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
593067	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
593068	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	9 Month Operations	7	
593069	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Accumulated Fault Duty A Ph V	37.47	%
593070	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	999	
593071	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Max Tap Position	13L	
593072	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
593073	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	999	
593074	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
593075	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Min Tap Position	1L	
593076	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
593077	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
593078	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
593079	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
593080	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
593081	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	9 Month Operations	2	
593082	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
593083	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
593084	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
593085	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
593086	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
593087	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
593088	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
593089	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
593090	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
593091	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
593092	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
593093	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
593094	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
593095	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
593096	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
593097	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	General Comments		
593098	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
593099	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	General Comments		
593100	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
593101	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
593102	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
593103	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.600	millivolts
593104	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
593105	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
593106	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
593107	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.0438	
593108	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
593109	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
593110	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
593111	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
593112	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
593113	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
593114	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Top Oil Temperature Present	54	°C
593115	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Top Oil Temperature Max	55	°C
593116	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
593117	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Regulator As Left Counter	20269	
593118	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
593119	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
593120	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
593121	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
593122	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
593123	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
593124	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
593125	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
593126	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
593127	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
593128	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Tank Leaks	None	
593129	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	General Comments	ok	
593130	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	General Comments	ok	
593131	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
593132	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
593133	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
593134	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
593135	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	650	psi
593136	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
593137	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
593138	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
593139	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
593140	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
593141	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
593142	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	35.04	kw
593143	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
593144	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
593145	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
593146	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
593147	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Winding Temp Present	40	°C
593148	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
593149	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
593150	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
593151	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
593152	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
593153	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
593154	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
593155	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
593156	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
593157	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	All Connections OK?	y	
593158	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	Follow-up Action Required?	n	
593159	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	General Comments		
593160	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	LTC Operation Checked?	y	
593161	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
593162	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
593163	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
593164	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	VRR Time Delay	30	Seconds
593165	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
593166	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
593167	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
593168	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
593169	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
593170	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
593171	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Patrol Inspection	Follow-up Action Required?	n	
593172	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
593173	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
593174	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Operations Ground	0	
593175	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Operations C Ø	0	
593176	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
593177	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Operations A Ø	0	
593178	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
593179	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
593180	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
593181	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Current Tap Position	6L	
593182	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
593183	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
593184	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
593185	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
593186	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
593187	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
593188	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Patrol Inspection	Equipment Properly Labeled?	y	
593189	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
593190	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
593191	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
593192	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Foundation Condition	Good	
593193	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
593194	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
593195	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Tank Paint Condition	Good	
593196	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
593197	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
593198	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Accumulated Fault Duty B Ph V	52.61	%
593199	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
593200	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	n	
593201	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
593202	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	General Comments		
593203	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
593204	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
593205	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
593206	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Accumulated Fault Duty C Ph V	37.47	%
593207	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Amps A Ø	75.0	
593208	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Amps B Ø	75.0	
593209	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Amps C Ø	75.0	
593210	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.9	amps
593211	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
593212	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
593213	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
593214	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
593215	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Ambient Temp	47	°F
593216	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
593217	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
593218	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
593219	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
593220	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
593221	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	9 Month Operations	18	
593222	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
593223	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
593224	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
593225	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
593226	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
593227	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	General Comments	One neutral pulled away from station. Line Crew to repair today.	
593228	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
593229	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
593230	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
593231	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
593232	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
593233	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
593234	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
593235	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
593236	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
593237	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
593238	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
593239	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	PF000263	PowerFuse	OK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
593240	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	PF000263	PowerFuse	OK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
593241	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
593242	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
593243	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
593244	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
593245	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
593246	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
593247	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Foundation Condition	Good	
593248	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
593249	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
593250	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	General Comments		
593251	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
593252	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
593253	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
593254	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
593255	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	9 Month Operations	2	
593256	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
593257	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
593258	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
593259	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Amps A Ø	180.0	
593260	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Amps B Ø	190.0	
593261	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Amps C Ø	184.0	
593262	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Bushing Condition	Good	
593263	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Bushings Connection/Risers	Good	
593264	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
593265	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
593266	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
593267	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
593268	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	General Comments		
593269	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
593270	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
593271	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Vegetation	None	
593272	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
593273	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
593274	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
593275	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
593276	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
593277	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	9998	
593278	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	9998	
593279	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
593280	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
593281	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
593282	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
593283	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
593284	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	General Comments		
593285	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
593286	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Accumulated Fault Duty A Ph V	2.44	%
593287	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
593288	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
593289	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
593290	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
593291	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
593292	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
593293	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
593294	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
593295	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
593296	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
593297	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
593298	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
593299	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
593300	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
593301	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
593302	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
593303	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	General Comments		
593304	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
593305	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
593306	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
593307	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
593308	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
593309	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
593310	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
593311	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
593312	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
593313	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
593314	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
593315	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	40	
593316	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	5.70	%
593317	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
593318	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Ambient Temp	47	°F
593319	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	5.70	%
593320	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	5.70	%
593321	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	89.0	
593322	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	1	
593323	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	91.0	
593324	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Clear of Trash?	y	
593325	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
593326	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
593327	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
593328	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
593329	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
593330	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	PF000262	PowerFuse	OK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
593331	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
593332	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	PF000262	PowerFuse	OK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
593333	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
593334	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
593335	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	General Comments		
593336	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
593337	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
593338	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
593339	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	103	
593340	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
593341	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
593342	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
593343	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Winding Temp Present	21	°C
593344	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Winding Temp Max	25	°C
593345	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
593346	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Totalizer Meter Reading	.4398	
593347	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
593348	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
593349	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
593350	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
593351	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
593352	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
593353	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
593354	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Amps C Ø	8.4	
593355	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
593356	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
593357	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
593358	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
593359	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Foundation Condition	Good	
593360	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	General Comments		
593361	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	General Comments		
593362	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
593363	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
593364	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Grounds in Place?	y	
593365	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Amps B Ø	8.3	
593366	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Amps A Ø	7.4	
593367	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Heaters (All) Functioning?	y	
593368	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Maintenance Operations	0	
593369	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	141	
593370	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Moisture and Leak Free?	y	
593371	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Operations Counter AF	171	
593372	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Operations Counter AL	172	
593373	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Switching Operations	1	
593374	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Tank Paint Condition	Good	
593375	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Unknown Operations	0	
593376	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Amps A Ø	115.0	
593377	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
593378	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Regulator As Left Counter	17856	
593379	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
593380	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
593381	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
593382	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
593383	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
593384	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
593385	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
593386	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
593387	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
593388	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
593389	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
593390	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Max Tap Position	11L	
593391	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
593392	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8706	
593393	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
593394	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Winding Temp Max	40	°C
593395	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	General Comments		
593396	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
593397	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC As Found Counter	101653	
593398	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC As Left Counter	101656	
593399	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
593400	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
593401	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
593402	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
593403	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Unknown Operations	0	
593404	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Tank Paint Condition	Good	
593405	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Switching Operations	1	
593406	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Operations Counter AL	191	
593407	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
593408	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
593409	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Operations Counter AF	190	
593410	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
593411	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
593412	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
593413	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
593414	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
593415	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	General Comments	ok	
593416	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	General Comments	ok	
593417	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
593418	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
593419	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
593420	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	227.50	
593421	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
593422	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
593423	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
593424	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
593425	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
593426	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Amps A Ø	160.0	
593427	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
593428	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
593429	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
593430	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	591	
593431	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
593432	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	Totalizer Meter Reading	.5652	
593433	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
593434	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
593435	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
593436	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
593437	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
593438	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
593439	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
593440	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
593441	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
593442	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
593443	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	Oil Temp Present	42	°C
593444	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
593445	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	Oil Temp Max	55	°C
593446	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
593447	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Cabinet Paint Condition	Good	
593448	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Equipment Properly Labeled?	y	
593449	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
593450	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	LTC Totalizer Reading	2712.96	kw
593451	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
593452	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	General Comments		
593453	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	General Comments		
593454	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
593455	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
593456	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	Follow-up Action Required?	n	
593457	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
593458	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
593459	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
593460	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
593461	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
593462	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
593463	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
593464	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Fault Operations A Ø	0	
593465	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Fault Operations B Ø	0	
593466	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Fault Operations C Ø	0	
593467	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Fault Operations Ground	0	
593468	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Follow-up Action Required?	n	
593469	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Follow-up Action Required?	n	
593470	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
593471	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
593472	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
593473	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
593474	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
593475	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
593476	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
593477	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
593478	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
593479	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
593480	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	Follow-up Action Required?	n	
593481	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
593482	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	General Comments		
593483	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	General Comments		
593484	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC As Found Counter	8355	
593485	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC As Left Counter	8355	
593486	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
593487	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC Current Tap Position	8L	
593488	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
593489	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC Min Tap Position	9L	
593490	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Tank Leaks	None	
593491	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
593492	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	28	°C
593493	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC Operations Since Last Insp	376	
593494	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
593495	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
593496	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
593497	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
593498	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
593499	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
593500	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
593501	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Amps C Ø	4.0	
593502	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Amps B Ø	9.0	
593503	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
593504	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Tank Leaks	None	
593505	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	8.49	
593506	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
593507	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
593508	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	8.49	
593509	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	3	
593510	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	3	
593511	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
593512	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
593513	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Regulator As Left Counter	19747	
593514	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Amps A Ø	12.0	
593515	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
593516	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
593517	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
593518	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
593519	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
593520	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
593521	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
593522	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
593523	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
593524	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
593525	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	32	
593526	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
593527	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
593528	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
593529	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
593530	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
593531	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
593532	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
593533	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	17	
593534	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	23	
593535	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	15.54	%
593536	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	17.37	%
593537	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Foundation Condition	Good	
593538	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Operations Counter AF	205	
593539	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
593540	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	12.70	%
593541	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	10.44	%
593542	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
593543	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
593544	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
593545	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10.0	
593546	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
593547	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
593548	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
593549	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Amps B Ø	255.0	
593550	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
593551	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
593552	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
593553	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
593554	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
593555	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
593556	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
593557	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
593558	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
593559	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
593560	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	8.49	
593561	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Grounds in Place?	y	
593562	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Amps C Ø	255.0	
593563	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
593564	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
593565	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	General Comments		
593566	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	General Comments		
593567	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Foundation Condition	Good	
593568	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Follow-up Action Required?	n	
593569	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Follow-up Action Required?	n	
593570	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
593571	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
593572	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
593573	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
593574	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
593575	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
593576	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
593577	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
593578	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
593579	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
593580	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
593581	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
593582	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
593583	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	323.0	
593584	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	308.0	
593585	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
593586	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	342.0	
593587	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
593588	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
593589	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Operations Ground	0	
593590	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
593591	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
593592	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
593593	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
593594	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
593595	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
593596	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
593597	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
593598	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Patrol Inspection	General Comments		
593599	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	General Comments		
593600	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Maintenance Operations	0	
593601	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Operations Counter AF	50	
593602	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Operations Counter AL	50	
593603	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Switching Operations	0	
593604	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Unknown Operations	0	
593605	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
593606	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Operations Ground	0	
593607	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Operations C Ø	0	
593608	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
593609	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
593610	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
593611	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	3	
593612	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
593613	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
593614	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
593615	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Operations B Ø	0	
593616	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Operations A Ø	0	
593617	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
593618	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
593619	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
593620	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
593621	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
593622	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.9080	
593623	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
593624	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
593625	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
593626	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
593627	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
593628	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
593629	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
593630	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
593631	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
593632	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
593633	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
593634	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
593635	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
593636	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
593637	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
593638	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
593639	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
593640	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
593641	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
593642	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
593643	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	15.08	%
593644	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	8	
593645	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	BCH001061	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.000	millivolts
593646	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	BCH001061	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
593647	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	BCH001061	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
593648	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	BCH001061	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
593649	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	BCH001061	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
593650	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
593651	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
593652	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
593653	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
593654	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
593655	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
593656	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	BCH001061	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
593657	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
593658	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
593659	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
593660	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
593661	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Nitrogen Bottle 0 PSI, Alarm was isolated at Annuciator	
593662	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	General Comments		
593663	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
593664	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	8	
593665	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
593666	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
593667	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LTCC000434	LTCControl	FA-TRANS 1	LTC Control Insp	General Comments		
593668	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LTCC000434	LTCControl	FA-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
593669	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
593670	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
593671	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
593672	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
593673	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
593674	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
593675	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
593676	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
593677	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
593678	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
593679	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
593680	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	2	
593681	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
593682	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	254	
593683	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	5R	
593684	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	5L	
593685	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	256	
593686	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
593687	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
593688	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
593689	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
593690	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
593691	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
593692	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
593693	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
593694	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	43890	
593695	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LTCC000435	LTCControl	FA-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
593696	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LTCC000435	LTCControl	FA-TRANS 2	LTC Control Insp	General Comments		
593697	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LTCC000435	LTCControl	FA-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
593698	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
593699	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
593700	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
593701	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
593702	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
593703	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
593704	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
593705	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
593706	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
593707	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
593708	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
593709	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
593710	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	9 Month Operations	3	
593711	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	3.85	%
593712	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	1.93	%
593713	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
593714	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Amps A Ø	255.0	
593715	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
593716	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
593717	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
593718	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
593719	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
593720	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
593721	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
593722	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
593723	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
593724	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
593725	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
593726	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
593727	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	General Comments		
593728	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
593729	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
593730	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
593731	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
593732	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
593733	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
593734	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
593735	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
593736	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
593737	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
593738	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
593739	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
593740	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
593741	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
593742	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
593743	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
593744	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	88.0	
593745	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
593746	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
593747	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
593748	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments	ok	
593749	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
593750	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
593751	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
593752	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LTCC000434	LTCControl	FA-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
593753	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
593754	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
593755	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
593756	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
593757	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
593758	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
593759	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
593760	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
593761	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
593762	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
593763	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
593764	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	General Comments		
593765	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	General Comments		
593766	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
593767	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	General Comments		
593768	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
593769	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
593770	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
593771	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	General Comments	RFTC	
593772	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
593773	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Max Tap Position	9L	
593774	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Min Tap Position	Neutral	
593775	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
593776	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
593777	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
593778	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
593779	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
593780	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
593781	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
593782	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
593783	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
593784	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
593785	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Regulator As Left Counter	22142	
593786	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
593787	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
593788	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Tank Leaks	None	
593789	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
593790	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	22	
593791	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Unknown Operations	0	
593792	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Tank Paint Condition	Good	
593793	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	13.16	%
593794	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Switching Operations	1	
593795	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Operations Counter AL	206	
593796	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
593797	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
593798	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
593799	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
593800	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
593801	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
593802	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
593803	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
593804	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
593805	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
593806	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
593807	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	General Comments		
593808	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
593809	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
593810	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	General Comments		
593811	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
593812	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
593813	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
593814	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
593815	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
593816	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
593817	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Ambient Temp	47	°F
593818	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
593819	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
593820	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Clear of Trash?	y	
593821	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
593822	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
593823	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
593824	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
593825	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
593826	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
593827	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
593828	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	General Comments		
593829	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
593830	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
593831	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
593832	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
593833	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
593834	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Vegetation	None	
593835	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
593836	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
593837	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
593838	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	40	°C
593839	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Amps A Ø	30.0	
593840	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Amps B Ø	32.0	
593841	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Amps C Ø	31.0	
593842	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Bushing Condition	Good	
593843	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Amps C Ø	9.4	
593844	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	248	
593845	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
593846	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
593847	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	228	
593848	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
593849	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
593850	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	LTCC000078	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
593851	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	LTCC000078	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125.4	VAC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
593852	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	LTCC000078	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
593853	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	LTCC000078	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
593854	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Bushings Connection/Risers	Good	
593855	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
593856	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
593857	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
593858	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Cabinet Paint Condition	Good	
593859	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Equipment Properly Labeled?	y	
593860	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
593861	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
593862	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	LTCC000078	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
593863	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	LTCC000078	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
593864	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Trash Emptied?	n	
593865	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
593866	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	General Comments		
593867	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
593868	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
593869	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Floor Swept?	y	
593870	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
593871	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
593872	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Evidence of Insects	None	
593873	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
593874	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
593875	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
593876	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
593877	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	General Comments	ok	
593878	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Switching Operations	0	
593879	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Operations Counter AL	146	
593880	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Operations Counter AF	146	
593881	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Maintenance Operations	0	
593882	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
593883	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
593884	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
593885	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
593886	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
593887	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
593888	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Amps B Ø	0.0	
593889	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	42	
593890	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	42	
593891	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
593892	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
593893	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Tank Leaks	None	
593894	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Amps A Ø	0.0	
593895	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
593896	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
593897	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	BCH000562	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
593898	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	BCH000562	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
593899	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	BCH000562	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
593900	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	BCH000562	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
593901	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	BCH000562	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
593902	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	BCH000562	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
593903	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
593904	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
593905	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
593906	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
593907	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	232	
593908	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Amps A Ø	12.4	
593909	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	LTCC000078	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
593910	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	LTCC000078	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
593911	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Amps B Ø	12.0	
593912	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Unknown Operations	0	
593913	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LTCC000491	LTCControl	DE-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
593914	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LTCC000491	LTCControl	DE-TRANS 1	LTC Control Insp	General Comments		
593915	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LTCC000491	LTCControl	DE-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
593916	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	BCH001130	Charger	977-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
593917	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	BCH001130	Charger	977-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
593918	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	BCH001130	Charger	977-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
593919	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	BCH001130	Charger	977-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
593920	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	BCH001130	Charger	977-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
593921	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	9 Month Operations	18	
593922	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Accumulated Fault Duty A Ph V	8.73	%
593923	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Accumulated Fault Duty B Ph V	8.73	%
593924	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Accumulated Fault Duty C Ph V	8.73	%
593925	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Operations Counter AF	200	
593926	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Operations Counter AL	208	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
593927	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2200	psi
593928	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
593929	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
593930	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
593931	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
593932	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2395.20	kw
593933	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
593934	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
593935	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
593936	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
593937	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
593938	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
593939	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
593940	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Switching Operations	8	
593941	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
593942	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
593943	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
593944	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
593945	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
593946	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9980	
593947	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
593948	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
593949	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
593950	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
593951	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
593952	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	5	
593953	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	5	
593954	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
593955	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
593956	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
593957	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
593958	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
593959	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
593960	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
593961	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
593962	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	General Comments	ok	
593963	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
593964	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
593965	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
593966	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
593967	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	General Comments		
593968	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	General Comments		
593969	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Patrol Inspection	General Comments		
593970	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Follow-up Action Required?	n	
593971	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
593972	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Broom on Site?	y	
593973	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
593974	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
593975	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
593976	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
593977	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
593978	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Fault Operations A Ø	0	
593979	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Fault Operations B Ø	0	
593980	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Fault Operations C Ø	0	
593981	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Fault Operations Ground	0	
593982	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Follow-up Action Required?	n	
593983	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Follow-up Action Required?	n	
593984	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Foundation Condition	Good	
593985	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	General Comments		
593986	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	General Comments	ok	
593987	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
593988	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
593989	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
593990	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
593991	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
593992	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	Top Oil Temperature Present	25	°C
593993	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
593994	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
593995	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
593996	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	Top Oil Temperature Max	25	°C
593997	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
593998	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
593999	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
594000	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
594001	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
594002	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Grounds in Place?	y	
594003	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Maintenance Operations	0	
594004	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
594005	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
594006	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
594007	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
594008	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
594009	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
594010	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Moisture and Leak Free?	y	
594011	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
594012	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
594013	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
594014	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
594015	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
594016	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
594017	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
594018	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
594019	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
594020	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	9 Month Operations	1	
594021	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Max Tap Position	2R	
594022	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
594023	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	General Comments		
594024	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
594025	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
594026	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
594027	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
594028	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
594029	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Amps A Ø	140.0	
594030	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Amps B Ø	140.0	
594031	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Amps C Ø	140.0	
594032	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Fault Operations	0	
594033	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Patrol Inspection	Follow-up Action Required?	n	
594034	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Follow-up Action Required?	n	
594035	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Patrol Inspection	General Comments		
594036	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
594037	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
594038	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
594039	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
594040	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Vegetation	None	
594041	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
594042	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
594043	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
594044	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
594045	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	General Comments		
594046	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Maintenance Operations	0	
594047	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Num Operations Last 9 Months	0	
594048	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Operations Counter AF	526	
594049	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Operations Counter AL	526	
594050	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
594051	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
594052	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
594053	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Current Tap Position	5L	
594054	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
594055	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
594056	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
594057	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
594058	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
594059	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
594060	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
594061	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
594062	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
594063	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
594064	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
594065	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
594066	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
594067	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
594068	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
594069	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
594070	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Min Tap Position	12L	
594071	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Bushing Condition	Good	
594072	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Oil Temp Present	38	°C
594073	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Oil Temp Max	42	°C
594074	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
594075	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	205.00	
594076	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	9158.40	kw

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
594077	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
594078	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
594079	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
594080	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
594081	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
594082	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
594083	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	General Comments		
594084	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	General Comments		
594085	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
594086	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
594087	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Amps C Ø	274.0	
594088	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
594089	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Amps B Ø	267.0	
594090	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Amps A Ø	262.0	
594091	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
594092	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
594093	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
594094	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
594095	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
594096	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
594097	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
594098	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	General Comments		
594099	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
594100	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
594101	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Follow-up Action Required?	n	
594102	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
594103	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
594104	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Fault Operations Ground	0	
594105	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Fault Operations C Ø	0	
594106	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Fault Operations B Ø	0	
594107	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Fault Operations A Ø	0	
594108	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
594109	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
594110	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
594111	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
594112	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Patrol Inspection	Equipment Properly Labeled?	y	
594113	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Amps C Ø	120.0	
594114	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Amps B Ø	120.0	
594115	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Amps A Ø	120.0	
594116	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Accumulated Fault Duty C Ph V	22.32	%
594117	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Accumulated Fault Duty B Ph V	27.10	%
594118	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Accumulated Fault Duty A Ph V	26.31	%
594119	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	9 Month Operations	1	
594120	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
594121	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
594122	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
594123	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
594124	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
594125	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
594126	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
594127	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
594128	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
594129	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
594130	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
594131	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
594132	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
594133	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
594134	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
594135	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
594136	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
594137	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Amps C Ø	0.0	
594138	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
594139	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
594140	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
594141	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
594142	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Switching Operations	0	
594143	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
594144	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Unknown Operations	0	
594145	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
594146	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
594147	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
594148	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
594149	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
594150	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
594151	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
594152	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
594153	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
594154	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
594155	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
594156	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
594157	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
594158	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Operations Counter	51	
594159	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Unknown Operations	0	
594160	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
594161	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	LTC Operations Since Last Insp	488	
594162	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	LTC Min Tap Position	6L	
594163	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	LTC Max Tap Position	4R	
594164	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	LTC Current Tap Position	4L	
594165	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
594166	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	LTC As Left Counter	101443	
594167	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	LTC As Found Counter	101437	
594168	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	General Comments		
594169	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	General Comments		
594170	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
594171	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	Follow-up Action Required?	n	
594172	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
594173	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Switching Operations	1	
594174	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Operations Counter AL	162	
594175	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Operations Counter AF	161	
594176	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
594177	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Maintenance Operations	0	
594178	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
594179	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
594180	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
594181	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
594182	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	General Comments		
594183	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
594184	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
594185	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	General Comments		
594186	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	General Comments		
594187	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
594188	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
594189	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
594190	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
594191	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
594192	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
594193	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Tank Paint Condition	Good	
594194	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Switching Operations	9	
594195	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
594196	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Operations Counter AL	30	
594197	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Operations Counter AF	21	
594198	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Moisture and Leak Free?	y	
594199	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Maintenance Operations	0	
594200	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Grounds in Place?	y	
594201	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	General Comments		
594202	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	General Comments		
594203	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Foundation Condition	Good	
594204	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Unknown Operations	0	
594205	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Tank Paint Condition	Good	
594206	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Switching Operations	1	
594207	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
594208	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Operations Counter AL	166	
594209	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
594210	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
594211	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	General Comments		
594212	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
594213	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
594214	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
594215	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
594216	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
594217	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
594218	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
594219	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Trash Emptied?	y	
594220	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
594221	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	General Comments		
594222	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
594223	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
594224	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
594225	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
594226	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
594227	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Floor Swept?	y	
594228	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
594229	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
594230	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
594231	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC Operations Since Last Insp	290	
594232	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC Min Tap Position	9L	
594233	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Evidence of Insects	None	
594234	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
594235	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
594236	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
594237	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
594238	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
594239	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
594240	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
594241	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
594242	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	General Comments	ok	
594243	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
594244	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
594245	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
594246	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
594247	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Tank Leaks	None	
594248	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
594249	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Regulator As Left Counter	446241	
594250	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
594251	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
594252	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
594253	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
594254	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
594255	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
594256	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
594257	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	General Comments		
594258	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
594259	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
594260	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
594261	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
594262	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
594263	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
594264	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
594265	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
594266	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
594267	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
594268	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
594269	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
594270	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
594271	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
594272	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
594273	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
594274	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
594275	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
594276	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
594277	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
594278	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
594279	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	General Comments		
594280	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
594281	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
594282	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
594283	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
594284	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
594285	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Amps B Ø	14.0	
594286	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Amps C Ø	12.0	
594287	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Bushing Condition	Good	
594288	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Bushings Connection/Risers	Good	
594289	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
594290	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
594291	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
594292	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC Current Tap Position	6L	
594293	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
594294	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC As Left Counter	67775	
594295	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
594296	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Tank Leaks	None	
594297	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
594298	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
594299	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Regulator As Left Counter	17102	
594300	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
594301	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC As Found Counter	67775	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
594302	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Mechanism Patrol Inspection	General Comments		
594303	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	General Comments		
594304	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
594305	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Tank Paint Condition	Good	
594306	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Switching Operations	0	
594307	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
594308	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Operations Counter AL	118	
594309	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Operations Counter AF	118	
594310	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
594311	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Operations Counter AF	165	
594312	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Moisture and Leak Free?	y	
594313	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Maintenance Operations	0	
594314	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
594315	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
594316	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Moisture and Leak Free?	y	
594317	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Maintenance Operations	0	
594318	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Heaters (All) Functioning?	y	
594319	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Grounds in Place?	y	
594320	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	General Comments	ok	
594321	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	General Comments	ok	
594322	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Foundation Condition	Good	
594323	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Follow-up Action Required?	n	
594324	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Follow-up Action Required?	n	
594325	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Operations Ground	0	
594326	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Operations C Ø	0	
594327	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
594328	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	727	
594329	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	727	
594330	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
594331	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
594332	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
594333	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
594334	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
594335	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
594336	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
594337	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
594338	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
594339	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
594340	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC Max Tap Position	2L	
594341	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
594342	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
594343	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
594344	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
594345	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
594346	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
594347	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
594348	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
594349	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
594350	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
594351	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
594352	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
594353	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
594354	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
594355	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
594356	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
594357	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
594358	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
594359	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
594360	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
594361	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
594362	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
594363	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
594364	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
594365	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	General Comments		
594366	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
594367	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
594368	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Foundation Condition	Good	
594369	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
594370	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
594371	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
594372	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
594373	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
594374	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
594375	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
594376	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
594377	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	9 Month Operations	3	
594378	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Accumulated Fault Duty A Ph V	.37	%
594379	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1288	
594380	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1296	
594381	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
594382	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
594383	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
594384	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
594385	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Accumulated Fault Duty B Ph V	.74	%
594386	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
594387	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Amps A Ø	10.0	
594388	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Patrol Inspection	Follow-up Action Required?	n	
594389	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Fault Operations	0	
594390	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Patrol Inspection	Equipment Properly Labeled?	y	
594391	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Amps C Ø	130.0	
594392	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Amps B Ø	130.0	
594393	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Amps A Ø	130.0	
594394	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
594395	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	General Comments		
594396	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
594397	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
594398	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
594399	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
594400	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
594401	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
594402	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
594403	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
594404	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
594405	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
594406	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
594407	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
594408	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
594409	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
594410	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
594411	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
594412	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Ambient Temperature	60	°F
594413	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
594414	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
594415	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
594416	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.7652	
594417	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
594418	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
594419	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5L	
594420	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	16L	
594421	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	225	
594422	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
594423	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
594424	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
594425	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
594426	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
594427	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
594428	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Fault Operations	0	
594429	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Follow-up Action Required?	n	
594430	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Follow-up Action Required?	n	
594431	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Foundation Condition	Good	
594432	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
594433	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	General Comments		
594434	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	ANN000027	Annunciator	DE-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
594435	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	ANN000027	Annunciator	DE-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	y	
594436	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	ANN000027	Annunciator	DE-Annunciator Panel	Annunciator Patrol Inspection	General Comments	New SEL annunciator doesnt send alarm to TCC Disp, please remove this from Insp if Josh/James agree to this.	
594437	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Unknown Operations	0	
594438	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	General Comments	y	
594439	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
594440	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
594441	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
594442	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
594443	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
594444	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
594445	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
594446	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
594447	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
594448	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC Current Tap Position	2R	
594449	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC Max Tap Position	3R	
594450	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC Min Tap Position	7L	
594451	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	55	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
594452	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
594453	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC Operations Since Last Insp	870	
594454	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
594455	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Tank Leaks	None	
594456	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
594457	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Regulator As Left Counter	72877	
594458	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
594459	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
594460	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
594461	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
594462	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
594463	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Min Tap Position	2R	
594464	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Max Tap Position	8R	
594465	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
594466	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	General Comments	ok	
594467	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
594468	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
594469	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
594470	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
594471	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
594472	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
594473	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
594474	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Current Tap Position	5R	
594475	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
594476	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
594477	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
594478	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
594479	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
594480	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
594481	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
594482	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Unknown Operations	0	
594483	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Switching Operations	0	
594484	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Operations Counter AL	347	
594485	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Operations Counter AF	347	
594486	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Num Operations Last 9 Months	0	
594487	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Maintenance Operations	0	
594488	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	General Comments		
594489	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Patrol Inspection	General Comments		
594490	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Follow-up Action Required?	n	
594491	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	Oil Temp Max	40	°C
594492	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.900	millivolts
594493	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
594494	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
594495	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
594496	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
594497	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
594498	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	General Comments		
594499	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
594500	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
594501	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
594502	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
594503	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
594504	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	4.82	%
594505	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	30.0	
594506	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	30.0	
594507	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
594508	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	30.0	
594509	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
594510	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Unknown Operations	0	
594511	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
594512	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
594513	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
594514	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
594515	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
594516	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
594517	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
594518	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
594519	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
594520	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
594521	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
594522	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
594523	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
594524	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
594525	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
594526	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Oil Temp Max	80	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
594527	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
594528	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	227.50	
594529	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2824.32	kw
594530	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
594531	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
594532	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
594533	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
594534	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
594535	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
594536	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
594537	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
594538	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
594539	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
594540	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
594541	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
594542	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Grounds in Place?	y	
594543	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
594544	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Maintenance Operations	0	
594545	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
594546	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Num Operations Last 9 Months	2	
594547	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Operations Counter AF	39	
594548	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Operations Counter AL	39	
594549	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
594550	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
594551	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
594552	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Switching Operations	0	
594553	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Tank Paint Condition	Good	
594554	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
594555	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
594556	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	16	
594557	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
594558	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Tank Leaks	None	
594559	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
594560	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Regulator As Left Counter	898579	
594561	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
594562	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
594563	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
594564	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
594565	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
594566	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
594567	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
594568	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.08	%
594569	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.08	%
594570	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.08	%
594571	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	24.0	
594572	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	General Comments		
594573	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
594574	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
594575	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
594576	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
594577	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
594578	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
594579	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
594580	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
594581	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
594582	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
594583	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
594584	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
594585	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
594586	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	36.0	
594587	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	24.0	
594588	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
594589	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
594590	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
594591	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
594592	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
594593	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	Oil Temp Present	38	°C
594594	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
594595	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
594596	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
594597	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Equipment Properly Labeled?	y	
594598	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Cabinet Paint Condition	Good	
594599	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
594600	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
594601	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
594602	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
594603	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
594604	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
594605	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
594606	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	72.0	
594607	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	75.0	
594608	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	75.0	
594609	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	.57	%
594610	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	.57	%
594611	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	.57	%
594612	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	7	
594613	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Operations B Ø	0	
594614	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Operations A Ø	0	
594615	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
594616	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
594617	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
594618	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Equipment Properly Labeled?	y	
594619	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Cabinet Paint Condition	Good	
594620	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
594621	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
594622	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
594623	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
594624	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
594625	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Amps C Ø	18.0	
594626	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Unknown Operations	0	
594627	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Tank Paint Condition	Good	
594628	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Switching Operations	1	
594629	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
594630	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Operations Counter AL	199	
594631	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Operations Counter AF	198	
594632	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Moisture and Leak Free?	y	
594633	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Maintenance Operations	0	
594634	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Amps B Ø	31.0	
594635	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Amps A Ø	20.0	
594636	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	PF000098	PowerFuse	DE-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
594637	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	PF000098	PowerFuse	DE-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
594638	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Heaters (All) Functioning?	y	
594639	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Grounds in Place?	y	
594640	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	General Comments		
594641	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	General Comments		
594642	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Foundation Condition	Good	
594643	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Vegetation	None	
594644	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
594645	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BAT000406	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
594646	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BAT000406	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
594647	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BAT000406	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
594648	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BAT000406	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
594649	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BAT000406	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
594650	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BAT000406	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
594651	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BAT000406	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
594652	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BAT000406	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
594653	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
594654	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	2	
594655	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	9	
594656	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	9	
594657	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Fault Operations A Ø	0	
594658	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
594659	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
594660	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
594661	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
594662	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
594663	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
594664	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	General Comments		
594665	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
594666	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
594667	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
594668	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
594669	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
594670	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
594671	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
594672	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
594673	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	106	
594674	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
594675	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Tank Leaks	None	
594676	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
594677	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Operations Counter	52	
594678	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
594679	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
594680	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	General Comments	RFTC	
594681	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
594682	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
594683	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
594684	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
594685	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
594686	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Amps A Ø	8.5	
594687	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Amps B Ø	7.2	
594688	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Amps C Ø	8.5	
594689	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	137	
594690	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
594691	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
594692	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	113	
594693	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
594694	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
594695	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	General Comments	ok	
594696	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
594697	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
594698	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
594699	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
594700	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
594701	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
594702	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	84	
594703	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	84	
594704	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
594705	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
594706	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
594707	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
594708	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
594709	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
594710	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
594711	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
594712	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
594713	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
594714	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
594715	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
594716	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
594717	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
594718	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
594719	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
594720	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
594721	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
594722	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
594723	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	200	
594724	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC Min Tap Position	16L	
594725	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6L	
594726	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC Current Tap Position	13L	
594727	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
594728	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC As Left Counter	8521	
594729	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
594730	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
594731	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	PF000131	PowerFuse	FA-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
594732	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
594733	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	PF000131	PowerFuse	FA-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
594734	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
594735	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC As Found Counter	8521	
594736	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
594737	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
594738	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
594739	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Clear of Trash?	y	
594740	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
594741	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
594742	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
594743	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
594744	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
594745	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
594746	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	General Comments		
594747	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
594748	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
594749	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
594750	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
594751	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
594752	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	General Comments		
594753	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
594754	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
594755	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
594756	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
594757	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
594758	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Clear of Trash?	y	
594759	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
594760	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Follow-up Action Required?	n	
594761	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Follow-up Action Required?	n	
594762	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Fault Operations Ground	0	
594763	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Fault Operations C Ø	0	
594764	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Fault Operations B Ø	0	
594765	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
594766	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
594767	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
594768	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	550.0	
594769	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	550.0	
594770	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	550.0	
594771	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
594772	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
594773	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
594774	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	7	
594775	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Fault Operations A Ø	0	
594776	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
594777	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
594778	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
594779	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Equipment Properly Labeled?	y	
594780	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Cabinet Paint Condition	Good	
594781	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
594782	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
594783	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
594784	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Bushings Connection/Risers	Good	
594785	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Bushing Condition	Good	
594786	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Amps C Ø	171.0	
594787	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	PF000099	PowerFuse	DE-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
594788	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	PF000099	PowerFuse	DE-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
594789	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Amps B Ø	169.0	
594790	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Amps A Ø	172.0	
594791	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Accumulated Fault Duty C Ph V	2.74	%
594792	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Accumulated Fault Duty B Ph V	4.11	%
594793	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Accumulated Fault Duty A Ph V	3.20	%
594794	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
594795	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3L	
594796	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	9 Month Operations	2	
594797	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
594798	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
594799	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	2901	
594800	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Bushing Condition	Good	
594801	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Amps C Ø	40.0	
594802	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Amps B Ø	90.0	
594803	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Grounds in Place?	y	
594804	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	General Comments		
594805	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Amps A Ø	50.0	
594806	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Accumulated Fault Duty C Ph V	8.17	%
594807	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Accumulated Fault Duty B Ph V	11.44	%
594808	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	General Comments		
594809	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Accumulated Fault Duty A Ph V	8.17	%
594810	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	9 Month Operations	2	
594811	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
594812	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Current Tap Position	7L	
594813	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
594814	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
594815	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
594816	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
594817	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
594818	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Foundation Condition	Good	
594819	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Follow-up Action Required?	n	
594820	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC As Found Counter	391648	
594821	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC As Left Counter	391648	
594822	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Follow-up Action Required?	n	
594823	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Operations Ground	0	
594824	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Operations C Ø	0	
594825	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
594826	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
594827	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	45	°C
594828	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
594829	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Follow-up Action Required?	n	
594830	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Follow-up Action Required?	n	
594831	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Fault Operations Ground	0	
594832	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Fault Operations C Ø	0	
594833	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
594834	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1021	
594835	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1021	
594836	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
594837	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
594838	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
594839	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Fault Operations B Ø	0	
594840	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
594841	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
594842	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
594843	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
594844	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
594845	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
594846	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
594847	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
594848	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
594849	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
594850	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
594851	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
594852	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
594853	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
594854	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
594855	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
594856	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
594857	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
594858	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
594859	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Min Tap Position	13L	
594860	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Max Tap Position	2L	
594861	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
594862	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	General Comments		
594863	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	28.0	
594864	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	29.0	
594865	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	27.0	
594866	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
594867	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Operations B Ø	0	
594868	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Operations A Ø	0	
594869	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
594870	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
594871	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
594872	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Equipment Properly Labeled?	y	
594873	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Cabinet Paint Condition	Good	
594874	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
594875	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
594876	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Vegetation	None	
594877	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
594878	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
594879	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
594880	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
594881	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
594882	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	16	
594883	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
594884	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
594885	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
594886	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
594887	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
594888	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	General Comments		
594889	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
594890	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
594891	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
594892	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
594893	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
594894	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
594895	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Clear of Trash?	y	
594896	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
594897	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
594898	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
594899	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
594900	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
594901	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Heaters (All) Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
594902	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Bushings Connection/Risers	Good	
594903	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	160.0	
594904	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	40	°C
594905	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	20	°C
594906	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	25	°C
594907	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
594908	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	6.02	%
594909	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	7.23	%
594910	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	8.43	%
594911	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	8	
594912	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BAT000406	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.5	VDC
594913	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BAT000406	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	26.5	VDC
594914	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BAT000406	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
594915	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
594916	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
594917	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	363	
594918	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	363	
594919	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
594920	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
594921	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	Follow-up Action Required?	n	
594922	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
594923	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
594924	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
594925	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
594926	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	General Comments	ok	
594927	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
594928	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
594929	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
594930	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
594931	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	50	°C
594932	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
594933	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
594934	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
594935	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
594936	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
594937	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
594938	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
594939	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
594940	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
594941	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
594942	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
594943	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
594944	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
594945	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
594946	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
594947	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
594948	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
594949	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
594950	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
594951	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
594952	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
594953	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BAT000406	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
594954	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	General Comments	ok	
594955	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
594956	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
594957	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Foundation Condition	Good	
594958	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
594959	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
594960	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
594961	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
594962	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
594963	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
594964	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
594965	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
594966	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Clear of Trash?	y	
594967	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
594968	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
594969	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
594970	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
594971	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
594972	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
594973	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	General Comments		
594974	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
594975	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Vegetation	None	
594976	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
594977	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
594978	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Vegetation	None	
594979	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
594980	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	General Comments	ok	
594981	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
594982	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
594983	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
594984	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
594985	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
594986	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
594987	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Clear of Trash?	y	
594988	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
594989	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
594990	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
594991	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
594992	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
594993	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
594994	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
594995	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
594996	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
594997	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
594998	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BAT000406	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
594999	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BAT000406	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
595000	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
595001	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
595002	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
595003	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
595004	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	130.0	
595005	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	130.0	
595006	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	33.2	
595007	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	31.3	
595008	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	383	
595009	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	Oil Temp Present	20	°C
595010	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	Oil Temp Max	35	°C
595011	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
595012	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
595013	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	LTC Totalizer Reading	3978.00	kw
595014	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
595015	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	General Comments	ok	
595016	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	General Comments	ok	
595017	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
595018	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
595019	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	Follow-up Action Required?	n	
595020	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
595021	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
595022	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
595023	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
595024	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
595025	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
595026	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
595027	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
595028	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
595029	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
595030	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
595031	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
595032	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Maintenance Operations	0	
595033	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Num Operations Last 9 Months	0	
595034	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Operations Counter AF	625	
595035	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Operations Counter AL	625	
595036	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Switching Operations	0	
595037	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Unknown Operations	0	
595038	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	9 Month Operations	0	
595039	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
595040	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
595041	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
595042	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
595043	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
595044	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
595045	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	693	
595046	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	693	
595047	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
595048	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
595049	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
595050	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
595051	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
595052	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
595053	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
595054	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
595055	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
595056	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
595057	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Patrol Inspection	General Comments		
595058	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	General Comments		
595059	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
595060	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
595061	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
595062	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
595063	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
595064	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	General Comments		
595065	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	General Comments		
595066	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
595067	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
595068	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
595069	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
595070	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
595071	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
595072	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
595073	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
595074	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
595075	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
595076	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
595077	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	Follow-up Action Required?	n	
595078	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
595079	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
595080	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	General Comments		
595081	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	General Comments		
595082	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
595083	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	LTC Totalizer Reading	9947.52	kw
595084	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
595085	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
595086	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	Oil Temp Max	58	°C
595087	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
595088	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
595089	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Clear of Trash?	y	
595090	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
595091	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
595092	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
595093	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
595094	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
595095	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
595096	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	General Comments	ok	
595097	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
595098	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Vegetation	None	
595099	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
595100	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	411	
595101	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	Oil Temp Present	38	°C
595102	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
595103	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
595104	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
595105	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
595106	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
595107	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
595108	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	28.9	
595109	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	6L	
595110	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	11L	
595111	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
595112	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	777352	
595113	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	777352	
595114	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments	ok	
595115	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Counter Readings	General Comments	ok	
595116	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
595117	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
595118	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
595119	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	103.0	
595120	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
595121	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	General Comments		
595122	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
595123	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
595124	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
595125	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
595126	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
595127	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
595128	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
595129	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
595130	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
595131	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
595132	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
595133	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
595134	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Foundation Condition	Good	
595135	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
595136	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
595137	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
595138	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
595139	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
595140	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
595141	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	Follow-up Action Required?	n	
595142	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
595143	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
595144	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	General Comments		
595145	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	General Comments		
595146	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
595147	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	LTC Totalizer Reading	4544.64	kw
595148	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
595149	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
595150	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
595151	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
595152	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Fault Operations A Ø	0	
595153	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Fault Operations B Ø	0	
595154	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Fault Operations C Ø	0	
595155	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Fault Operations Ground	0	
595156	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Follow-up Action Required?	n	
595157	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Follow-up Action Required?	n	
595158	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
595159	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	General Comments		
595160	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
595161	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
595162	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	458	
595163	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
595164	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
595165	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	PF000130	PowerFuse	FA-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
595166	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	PF000130	PowerFuse	FA-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
595167	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments	ok	
595168	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
595169	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
595170	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
595171	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
595172	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
595173	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
595174	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Amps A Ø	290.0	
595175	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Amps B Ø	296.0	
595176	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Amps C Ø	310.0	
595177	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	67.0	
595178	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	70.0	
595179	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Bushing Condition	Good	
595180	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	10	
595181	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
595182	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
595183	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
595184	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
595185	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
595186	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
595187	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
595188	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
595189	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
595190	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
595191	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
595192	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
595193	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
595194	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
595195	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
595196	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
595197	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
595198	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
595199	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
595200	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	126	
595201	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
595202	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	68.0	
595203	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
595204	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
595205	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
595206	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	20	
595207	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	11L	
595208	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
595209	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
595210	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
595211	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
595212	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
595213	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
595214	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
595215	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
595216	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
595217	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
595218	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
595219	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
595220	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
595221	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
595222	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	9.05	%
595223	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	5.03	%
595224	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	7.04	%
595225	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
595226	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
595227	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
595228	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Oil Temp Present	27	°C
595229	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Oil Temp Max	30	°C
595230	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
595231	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
595232	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
595233	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
595234	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
595235	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
595236	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
595237	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
595238	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
595239	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
595240	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
595241	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
595242	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	General Comments	ok	
595243	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
595244	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
595245	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
595246	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Min Tap Position	2L	
595247	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
595248	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
595249	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
595250	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
595251	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
595252	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
595253	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Regulator As Left Counter	140749	
595254	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
595255	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Operations A Ø	0	
595256	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
595257	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
595258	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
595259	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
595260	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
595261	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
595262	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
595263	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Moisture and Leak Free?	y	
595264	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Maintenance Operations	0	
595265	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Grounds in Place?	y	
595266	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
595267	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
595268	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
595269	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
595270	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
595271	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
595272	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
595273	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
595274	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
595275	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
595276	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
595277	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
595278	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	1.57	
595279	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	1.57	
595280	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	General Comments		
595281	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	General Comments		
595282	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Foundation Condition	Good	
595283	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Follow-up Action Required?	n	
595284	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Follow-up Action Required?	n	
595285	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Operations Ground	0	
595286	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Operations C Ø	0	
595287	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Operations B Ø	0	
595288	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	1.57	
595289	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
595290	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
595291	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
595292	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
595293	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	873	
595294	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	868	
595295	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
595296	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
595297	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
595298	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
595299	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
595300	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
595301	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
595302	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
595303	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
595304	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
595305	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
595306	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
595307	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
595308	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
595309	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
595310	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
595311	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
595312	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
595313	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
595314	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
595315	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
595316	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	Totalizer Meter Reading	.6630	
595317	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
595318	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
595319	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	All Connections OK?	y	
595320	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	Follow-up Action Required?	n	
595321	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	General Comments		
595322	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	LTC Operation Checked?	y	
595323	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
595324	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
595325	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
595326	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
595327	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
595328	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
595329	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
595330	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
595331	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
595332	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
595333	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
595334	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
595335	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
595336	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	VRR Time Delay	60	Seconds
595337	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Amps C Ø	160.0	
595338	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Patrol Inspection	Equipment Properly Labeled?	y	
595339	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
595340	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Foundation Condition	Good	
595341	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
595342	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
595343	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
595344	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	General Comments		
595345	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
595346	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
595347	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
595348	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
595349	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	ANN000027	Annunciator	DE-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
595350	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
595351	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
595352	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
595353	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
595354	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
595355	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
595356	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
595357	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
595358	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
595359	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	2111.04	kw
595360	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
595361	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
595362	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
595363	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Fault Operations	0	
595364	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Patrol Inspection	Follow-up Action Required?	n	
595365	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Follow-up Action Required?	n	
595366	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
595367	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
595368	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
595369	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
595370	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	General Comments	Barb Wire rusted in places	
595371	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
595372	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Tank Leaks	None	
595373	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
595374	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
595375	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
595376	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
595377	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
595378	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Equipment Properly Labeled?	y	
595379	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Cabinet Paint Condition	Good	
595380	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
595381	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
595382	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	40.0	
595383	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	40.0	
595384	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	40.0	
595385	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	6.04	%
595386	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	7.55	%
595387	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	4.28	%
595388	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	19	
595389	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	All Connections OK?	y	
595390	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	Follow-up Action Required?	n	
595391	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	General Comments		
595392	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
595393	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
595394	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Bushings Connection/Risers	Good	
595395	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Bushing Condition	Good	
595396	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Amps C Ø	175.0	
595397	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Amps B Ø	166.0	
595398	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	LTC Operation Checked?	y	
595399	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
595400	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
595401	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
595402	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	VRR Time Delay	30	Seconds
595403	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Amps A Ø	172.0	
595404	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	All Connections OK?	y	
595405	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	Follow-up Action Required?	n	
595406	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	General Comments		
595407	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	LTC Operation Checked?	y	
595408	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
595409	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
595410	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
595411	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	VRR Time Delay	30	Seconds
595412	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
595413	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
595414	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Accumulated Fault Duty A Ph V	.46	%
595415	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	9 Month Operations	2	
595416	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Amps B Ø	160.0	
595417	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
595418	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	8357.76	kw
595419	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
595420	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
595421	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
595422	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
595423	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
595424	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
595425	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	Oil Temp Max	35	°C
595426	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	Oil Temp Present	30	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
595427	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
595428	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
595429	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
595430	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
595431	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
595432	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
595433	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
595434	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	Totalizer Meter Multiplier	3600	
595435	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	Totalizer Meter Reading	1.2624	
595436	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
595437	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
595438	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Ambient Temperature	60	°F
595439	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
595440	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
595441	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
595442	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
595443	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
595444	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Fault Operations	0	
595445	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Follow-up Action Required?	n	
595446	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Follow-up Action Required?	n	
595447	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	General Comments		
595448	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	General Comments		
595449	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
595450	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
595451	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
595452	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
595453	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
595454	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
595455	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
595456	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
595457	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
595458	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
595459	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
595460	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	PF000146	PowerFuse	FL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
595461	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	PF000146	PowerFuse	FL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
595462	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Foundation Condition	Good	
595463	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
595464	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	General Comments		
595465	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	General Comments	y	
595466	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Grounds in Place?	y	
595467	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
595468	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
595469	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Accumulated Fault Duty A Ph V	43.57	%
595470	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Accumulated Fault Duty B Ph V	43.57	%
595471	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Accumulated Fault Duty C Ph V	44.42	%
595472	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Amps A Ø	84.0	
595473	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
595474	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
595475	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
595476	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
595477	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	LTC Totalizer Reading	14940.00	kw
595478	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
595479	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	General Comments		
595480	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	General Comments		
595481	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
595482	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
595483	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	2	
595484	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	2	
595485	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Follow-up Action Required?	n	
595486	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
595487	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
595488	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
595489	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
595490	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
595491	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
595492	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Amps B Ø	96.0	
595493	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Amps C Ø	120.0	
595494	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Bushing Condition	Good	
595495	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Bushings Connection/Risers	Good	
595496	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
595497	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
595498	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
595499	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
595500	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
595501	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
595502	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
595503	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
595504	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
595505	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
595506	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
595507	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
595508	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
595509	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
595510	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
595511	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
595512	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Oil Temp Present	42	°C
595513	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Oil Temp Max	42	°C
595514	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
595515	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
595516	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
595517	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
595518	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
595519	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
595520	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	205.00	
595521	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
595522	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Unknown Operations	0	
595523	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Tank Leaks	None	
595524	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
595525	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
595526	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
595527	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
595528	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
595529	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
595530	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
595531	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
595532	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
595533	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99987	
595534	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99987	
595535	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
595536	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
595537	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
595538	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
595539	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
595540	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
595541	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
595542	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
595543	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
595544	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
595545	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
595546	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
595547	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
595548	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
595549	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
595550	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
595551	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
595552	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	635.0	
595553	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	589.0	
595554	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	614.0	
595555	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	.49	%
595556	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	.49	%
595557	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	.49	%
595558	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
595559	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	Follow-up Action Required?	n	
595560	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
595561	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	General Comments		
595562	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	General Comments		
595563	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC As Found Counter	47200	
595564	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC As Left Counter	47200	
595565	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
595566	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
595567	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	General Comments		
595568	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
595569	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
595570	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
595571	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
595572	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
595573	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
595574	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
595575	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	920	
595576	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	928	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
595577	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
595578	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
595579	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Maintenance Operations	0	
595580	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
595581	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Num Operations Last 9 Months	0	
595582	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
595583	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
595584	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
595585	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
595586	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Operations Counter AF	25	
595587	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Operations Counter AL	25	
595588	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
595589	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
595590	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
595591	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
595592	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
595593	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
595594	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
595595	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	General Comments		
595596	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
595597	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
595598	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
595599	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
595600	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
595601	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
595602	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
595603	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
595604	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Regulator As Left Counter	33743	
595605	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
595606	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Switching Operations	0	
595607	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Tank Paint Condition	Good	
595608	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
595609	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	PF000147	PowerFuse	FL-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
595610	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	PF000147	PowerFuse	FL-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
595611	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
595612	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
595613	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
595614	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	General Comments	ok	
595615	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	General Comments	ok	
595616	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
595617	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
595618	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Maintenance Operations	0	
595619	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
595620	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AF	242	
595621	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AL	0	
595622	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springdischarged	
595623	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Switching Operations	0	
595624	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BCH001158	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
595625	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BCH001158	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
595626	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BCH001158	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
595627	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BCH001158	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
595628	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BCH001158	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	4.2	amps
595629	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BCH001158	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
595630	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BCH001158	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
595631	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BCH001158	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
595632	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
595633	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
595634	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	General Comments		
595635	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
595636	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
595637	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
595638	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
595639	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
595640	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
595641	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Switching Operations	0	
595642	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Tank Paint Condition	Good	
595643	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Unknown Operations	0	
595644	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
595645	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
595646	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
595647	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Foundation Condition	Good	
595648	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
595649	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
595650	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	General Comments		
595651	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
595652	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
595653	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
595654	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
595655	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
595656	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
595657	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
595658	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
595659	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	94.0	
595660	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	92.0	
595661	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
595662	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
595663	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
595664	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
595665	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments	LTC overhaul and new fiber for fault board	
595666	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	35730	
595667	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	35746	
595668	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
595669	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	8L	
595670	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	2R	
595671	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	10L	
595672	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
595673	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
595674	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	765	
595675	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Foundation Condition	Good	
595676	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	General Comments		
595677	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
595678	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
595679	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
595680	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
595681	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
595682	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
595683	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
595684	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	22	
595685	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	General Comments		
595686	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Grounds in Place?	y	
595687	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Maintenance Operations	0	
595688	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	7.61	%
595689	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	8.30	%
595690	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	7.61	%
595691	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	108.0	
595692	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
595693	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
595694	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
595695	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
595696	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
595697	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
595698	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
595699	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
595700	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
595701	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Operations Counter AF	122	
595702	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Operations Counter AL	122	
595703	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
595704	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
595705	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
595706	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
595707	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
595708	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
595709	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
595710	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
595711	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
595712	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	8.63	
595713	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	8.63	
595714	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
595715	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
595716	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
595717	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
595718	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
595719	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
595720	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
595721	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
595722	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
595723	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
595724	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
595725	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
595726	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
595727	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
595728	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	General Comments		
595729	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
595730	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
595731	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
595732	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
595733	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
595734	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Broom on Site?	y	
595735	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
595736	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
595737	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
595738	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99973	
595739	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	9 Month Operations	1	
595740	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.90	%
595741	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	.90	%
595742	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.90	%
595743	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
595744	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99973	
595745	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
595746	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
595747	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
595748	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Winding Temp Present	30	°C
595749	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Winding Temp Max	35	°C
595750	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Totalizer Meter Reading	.8300	
595751	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
595752	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
595753	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
595754	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
595755	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
595756	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
595757	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	9 Month Operations	17	
595758	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
595759	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
595760	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
595761	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
595762	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
595763	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
595764	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
595765	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
595766	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Oil Temp Present	31	°C
595767	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Oil Temp Max	35	°C
595768	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1650	psi
595769	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
595770	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
595771	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
595772	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
595773	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
595774	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
595775	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
595776	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
595777	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
595778	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
595779	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
595780	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
595781	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
595782	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
595783	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
595784	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
595785	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
595786	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
595787	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
595788	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
595789	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
595790	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
595791	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
595792	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
595793	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
595794	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
595795	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
595796	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
595797	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
595798	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Panels Dusted?	y	
595799	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
595800	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
595801	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	HVAC Filter Replaced?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
595802	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	General Comments		
595803	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
595804	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
595805	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Floor Swept?	y	
595806	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
595807	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
595808	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
595809	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Evidence of Insects	None	
595810	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
595811	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
595812	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
595813	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
595814	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
595815	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	10.84	%
595816	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	13.25	%
595817	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
595818	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
595819	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
595820	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
595821	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	Totalizer Meter Reading	1.0362	
595822	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	220.00	
595823	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
595824	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	General Comments		
595825	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	T.C. filter is off do to low press alarm.	
595826	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC As Found Counter	8687	
595827	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC As Left Counter	8687	
595828	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
595829	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	14L	
595830	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	BAT000274	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
595831	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	BAT000274	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
595832	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	BAT000274	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
595833	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	BAT000274	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
595834	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	BAT000274	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
595835	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	BAT000274	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
595836	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	BAT000274	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	Has been disconnected	
595837	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	BAT000274	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
595838	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	BAT000274	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
595839	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
595840	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
595841	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
595842	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	BAT000274	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
595843	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	60.0	
595844	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	60.0	
595845	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
595846	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
595847	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
595848	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	General Comments		
595849	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
595850	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Foundation Condition	Good	
595851	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
595852	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
595853	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
595854	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
595855	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
595856	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
595857	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
595858	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
595859	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Unknown Operations	0	
595860	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
595861	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
595862	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
595863	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
595864	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
595865	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
595866	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
595867	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
595868	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	19.25	%
595869	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
595870	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
595871	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Winding Temp Present	30	°C
595872	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Winding Temp Max	30	°C
595873	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Totalizer Meter Reading	.5920	
595874	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
595875	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Top Oil Temperature Present	39	°C
595876	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Top Oil Temperature Max	44	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
595877	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	19.25	%
595878	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	19.25	%
595879	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	2	
595880	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
595881	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
595882	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
595883	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
595884	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
595885	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
595886	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
595887	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
595888	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
595889	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
595890	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
595891	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
595892	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
595893	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	LTC Totalizer Reading	10656.00	kw
595894	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
595895	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	General Comments		
595896	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	General Comments		
595897	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
595898	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
595899	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Follow-up Action Required?	n	
595900	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Totalizer Meter Multiplier	1800	
595901	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Totalizer Meter Reading	2.6004	
595902	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
595903	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
595904	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
595905	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
595906	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
595907	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
595908	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
595909	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
595910	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
595911	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
595912	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
595913	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
595914	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
595915	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
595916	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
595917	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
595918	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
595919	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
595920	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
595921	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
595922	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
595923	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
595924	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
595925	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
595926	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
595927	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
595928	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
595929	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
595930	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
595931	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
595932	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Follow-up Action Required?	n	
595933	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
595934	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
595935	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	General Comments		
595936	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	General Comments		
595937	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
595938	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	LTC Totalizer Reading	4680.72	kw
595939	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
595940	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
595941	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Oil Temp Max	30	°C
595942	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Oil Temp Present	30	°C
595943	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
595944	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
595945	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
595946	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
595947	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
595948	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
595949	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
595950	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
595951	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
595952	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
595953	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
595954	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
595955	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
595956	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
595957	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
595958	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
595959	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
595960	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
595961	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
595962	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
595963	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
595964	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
595965	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
595966	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
595967	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
595968	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
595969	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Follow-up Action Required?	n	
595970	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
595971	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
595972	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
595973	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
595974	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
595975	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	60.0	
595976	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	BAT000274	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	n	
595977	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	BAT000274	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
595978	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	BAT000274	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
595979	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
595980	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
595981	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	General Comments		
595982	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	General Comments		
595983	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
595984	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	LTC Totalizer Reading	9849.60	kw
595985	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
595986	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	9 Month Operations	3	
595987	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
595988	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
595989	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
595990	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
595991	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Oil Temp Max	40	°C
595992	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Oil Temp Present	35	°C
595993	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
595994	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
595995	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
595996	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
595997	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
595998	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
595999	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
596000	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	9 Month Operations	1	
596001	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Accumulated Fault Duty A Ph V	1.10	%
596002	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Accumulated Fault Duty B Ph V	1.10	%
596003	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Accumulated Fault Duty C Ph V	1.10	%
596004	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Amps A Ø	277.0	
596005	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Amps B Ø	264.0	
596006	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Amps C Ø	237.0	
596007	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Bushing Condition	Good	
596008	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Accumulated Fault Duty C Ph V	.27	%
596009	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
596010	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
596011	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Amps A Ø	0.0	
596012	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
596013	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
596014	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
596015	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Accumulated Fault Duty B Ph V	.27	%
596016	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Accumulated Fault Duty A Ph V	.27	%
596017	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
596018	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
596019	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
596020	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
596021	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
596022	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
596023	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
596024	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
596025	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Operations A Ø	0	
596026	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
596027	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Operations C Ø	0	
596028	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Operations Ground	0	
596029	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	9 Month Operations	1	
596030	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
596031	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
596032	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
596033	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
596034	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
596035	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
596036	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
596037	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Follow-up Action Required?	n	
596038	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Follow-up Action Required?	n	
596039	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
596040	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
596041	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
596042	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Foundation Condition	Good	
596043	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	General Comments		
596044	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	General Comments		
596045	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
596046	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
596047	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Totalizer Meter Reading	.6840	
596048	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Winding Temp Max	40	°C
596049	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Winding Temp Present	40	°C
596050	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
596051	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
596052	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Oil Temp Present	50	°C
596053	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
596054	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
596055	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
596056	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
596057	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
596058	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
596059	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
596060	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
596061	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
596062	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
596063	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Broom on Site?	y	
596064	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
596065	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
596066	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
596067	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
596068	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Evidence of Insects	None	
596069	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
596070	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
596071	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Floor Swept?	y	
596072	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
596073	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
596074	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	General Comments		
596075	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
596076	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
596077	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Panels Dusted?	y	
596078	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
596079	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
596080	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
596081	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Trash Emptied?	y	
596082	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
596083	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
596084	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	BAT000274	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
596085	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	General Comments		
596086	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	General Comments		
596087	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
596088	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	LTC Totalizer Reading	18579.60	kw
596089	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
596090	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
596091	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Oil Temp Max	60	°C
596092	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Unknown Operations	0	
596093	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Switching Operations	0	
596094	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Operations Counter AL	313	
596095	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Operations Counter AF	313	
596096	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Num Operations Last 9 Months	0	
596097	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Maintenance Operations	0	
596098	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
596099	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
596100	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Panels Dusted?	y	
596101	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
596102	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	General Comments		
596103	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
596104	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
596105	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Floor Swept?	y	
596106	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
596107	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
596108	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Evidence of Insects	None	
596109	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
596110	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
596111	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
596112	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
596113	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
596114	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
596115	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
596116	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
596117	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
596118	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
596119	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
596120	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
596121	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
596122	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
596123	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
596124	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
596125	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
596126	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
596127	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
596128	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Follow-up Action Required?	n	
596129	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
596130	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Clear of Trash?	y	
596131	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
596132	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
596133	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
596134	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000109	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
596135	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000109	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
596136	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000109	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
596137	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
596138	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Oil Temp Max	40	°C
596139	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Oil Temp Present	38	°C
596140	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	General Comments	ok	
596141	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
596142	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Vegetation	None	
596143	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
596144	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
596145	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
596146	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
596147	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
596148	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
596149	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
596150	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
596151	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
596152	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
596153	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
596154	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
596155	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Trash Emptied?	y	
596156	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
596157	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
596158	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
596159	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
596160	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Panels Dusted?	y	
596161	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
596162	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
596163	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	General Comments		
596164	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
596165	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
596166	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Floor Swept?	y	
596167	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
596168	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
596169	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Evidence of Insects	None	
596170	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
596171	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
596172	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
596173	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
596174	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Broom on Site?	y	
596175	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Foundation Condition	Good	
596176	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
596177	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
596178	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	General Comments	ok	
596179	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
596180	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
596181	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
596182	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
596183	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	General Comments	barbed wire is rusty	
596184	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
596185	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
596186	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
596187	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
596188	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
596189	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
596190	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
596191	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
596192	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
596193	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
596194	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
596195	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
596196	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
596197	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000109	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
596198	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000109	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
596199	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
596200	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AL	125	VAC
596201	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Floor Swept?	y	
596202	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
596203	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
596204	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
596205	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
596206	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
596207	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
596208	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
596209	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
596210	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
596211	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
596212	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
596213	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
596214	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
596215	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	Follow-up Action Required?	n	
596216	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Tank Leaks	None	
596217	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
596218	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Operations Counter	205	
596219	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
596220	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
596221	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	General Comments		
596222	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
596223	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
596224	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
596225	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
596226	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
596227	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
596228	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
596229	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
596230	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
596231	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
596232	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
596233	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
596234	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
596235	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
596236	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
596237	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
596238	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	General Comments	Neighbor has down spout ran through barb wire, picture sent to Tom G	
596239	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
596240	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
596241	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
596242	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
596243	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
596244	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
596245	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
596246	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
596247	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Amps C Ø	42.0	
596248	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Amps B Ø	39.0	
596249	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Amps A Ø	44.0	
596250	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
596251	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
596252	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
596253	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
596254	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
596255	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
596256	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
596257	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
596258	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
596259	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
596260	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
596261	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Amps A Ø	89.0	
596262	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
596263	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
596264	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
596265	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
596266	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000109	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
596267	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000109	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
596268	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000109	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
596269	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000109	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
596270	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
596271	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Vegetation	None	
596272	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
596273	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	General Comments		
596274	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
596275	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
596276	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
596277	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
596278	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	125	
596279	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
596280	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	General Comments	OK	
596281	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
596282	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
596283	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
596284	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
596285	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
596286	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
596287	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
596288	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
596289	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	16.25	%
596290	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
596291	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
596292	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
596293	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	4200	
596294	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.1356	
596295	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	17.06	%
596296	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	13.81	%
596297	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	90.0	
596298	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	80.0	
596299	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	80.0	
596300	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
596301	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
596302	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
596303	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
596304	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
596305	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
596306	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	General Comments		
596307	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
596308	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
596309	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
596310	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
596311	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
596312	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
596313	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
596314	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Foundation Condition	Good	
596315	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
596316	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
596317	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	General Comments		
596318	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
596319	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
596320	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
596321	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
596322	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
596323	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
596324	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
596325	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
596326	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
596327	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Readings	General Comments		
596328	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
596329	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
596330	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
596331	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
596332	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
596333	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
596334	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
596335	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
596336	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
596337	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
596338	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
596339	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Panels Dusted?	y	
596340	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
596341	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
596342	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
596343	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
596344	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
596345	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
596346	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
596347	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
596348	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.7	VDC
596349	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	2.2	VDC
596350	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
596351	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
596352	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
596353	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
596354	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	General Comments		
596355	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	HVAC Filter Replaced?	n	
596356	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000109	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
596357	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000109	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
596358	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000109	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
596359	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000109	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
596360	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
596361	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
596362	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
596363	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
596364	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000109	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
596365	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
596366	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	6	
596367	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
596368	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	452	
596369	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	447	
596370	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	FE000109	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
596371	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
596372	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
596373	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
596374	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
596375	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	6.0	VDC
596376	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	10.0	VDC
596377	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	10	
596378	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
596379	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
596380	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
596381	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
596382	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
596383	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Tank Leaks	None	
596384	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
596385	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Regulator As Left Counter	121203	
596386	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
596387	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
596388	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
596389	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
596390	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
596391	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
596392	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
596393	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
596394	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	General Comments	ok	
596395	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
596396	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
596397	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
596398	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
596399	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
596400	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
596401	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
596402	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
596403	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
596404	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
596405	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
596406	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
596407	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
596408	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
596409	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
596410	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
596411	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
596412	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AF	125	VAC
596413	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Output Voltage Level	125	VAC
596414	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Operation Checked?	y	
596415	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
596416	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCControl	932-Offline Distribution	LTC Control Insp	General Comments	Downloaded beckwith settings	
596417	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCControl	932-Offline Distribution	LTC Control Insp	Follow-up Action Required?	n	
596418	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCControl	932-Offline Distribution	LTC Control Insp	All Connections OK?	y	
596419	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
596420	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
596421	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
596422	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
596423	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
596424	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
596425	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
596426	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
596427	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	125	
596428	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
596429	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
596430	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
596431	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
596432	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
596433	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
596434	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
596435	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
596436	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
596437	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
596438	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	General Comments		
596439	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
596440	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
596441	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
596442	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
596443	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
596444	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
596445	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
596446	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
596447	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Regulator As Left Counter	43944	
596448	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
596449	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Tank Leaks	None	
596450	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
596451	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
596452	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Amps C Ø	35.0	
596453	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
596454	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
596455	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
596456	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
596457	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
596458	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
596459	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
596460	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
596461	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	General Comments	ok	
596462	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	18	
596463	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
596464	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
596465	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
596466	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
596467	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
596468	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
596469	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
596470	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
596471	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
596472	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
596473	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
596474	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
596475	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
596476	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
596477	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
596478	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
596479	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
596480	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
596481	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.01	%
596482	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.01	%
596483	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.01	%
596484	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
596485	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10.0	
596486	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
596487	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
596488	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
596489	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Bushing Condition	Good	
596490	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Bushings Connection/Risers	Good	
596491	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
596492	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
596493	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
596494	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
596495	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
596496	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
596497	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
596498	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
596499	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
596500	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
596501	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
596502	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Operations A Ø	0	
596503	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
596504	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Tank Leaks	None	
596505	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
596506	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Regulator As Left Counter	246370	
596507	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
596508	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
596509	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
596510	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
596511	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
596512	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
596513	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
596514	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
596515	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
596516	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Operations B Ø	0	
596517	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Operations C Ø	0	
596518	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Operations Ground	0	
596519	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Follow-up Action Required?	n	
596520	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Follow-up Action Required?	n	
596521	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Foundation Condition	Good	
596522	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
596523	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
596524	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
596525	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
596526	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
596527	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
596528	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	General Comments		
596529	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	General Comments		
596530	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Grounds in Place?	y	
596531	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Heaters (All) Functioning?	y	
596532	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Maintenance Operations	0	
596533	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
596534	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
596535	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	General Comments		
596536	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
596537	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
596538	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
596539	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
596540	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
596541	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
596542	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
596543	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
596544	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
596545	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
596546	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Moisture and Leak Free?	y	
596547	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	General Comments		
596548	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
596549	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
596550	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
596551	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
596552	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
596553	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
596554	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
596555	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
596556	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Regulator As Left Counter	37646	
596557	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
596558	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Operations Counter AF	198	
596559	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Operations Counter AL	198	
596560	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Switching Operations	1	
596561	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Tank Paint Condition	Good	
596562	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Unknown Operations	0	
596563	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Grounds in Place?	y	
596564	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	General Comments		
596565	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Tank Leaks	None	
596566	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
596567	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	LTCC000025	LTCControl	912-Offline-Distribution	LTC Control Insp	General Comments	whole sub is de-energized	
596568	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	LTCC000025	LTCControl	912-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	n	
596569	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	LTCC000025	LTCControl	912-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
596570	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	LTCC000025	LTCControl	912-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	0.0	VAC
596571	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	General Comments		
596572	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	LTCC000025	LTCControl	912-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	0.0	VAC
596573	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	LTCC000025	LTCControl	912-Offline-Distribution	LTC Control Insp	VRR Time Delay	0	Seconds
596574	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Foundation Condition	Good	
596575	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Amps A Ø	30.0	
596576	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Amps B Ø	80.0	
596577	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
596578	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
596579	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	9 Month Operations	2	
596580	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
596581	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
596582	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
596583	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Amps A Ø	418.0	
596584	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Amps B Ø	432.0	
596585	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Amps C Ø	423.0	
596586	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
596587	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
596588	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
596589	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Trash Emptied?	y	
596590	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
596591	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
596592	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
596593	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
596594	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	764	
596595	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	764	
596596	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
596597	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Bushing Condition	Good	
596598	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
596599	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
596600	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
596601	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
596602	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
596603	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
596604	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
596605	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
596606	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Panels Dusted?	y	
596607	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
596608	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
596609	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
596610	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
596611	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
596612	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
596613	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
596614	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
596615	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
596616	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
596617	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
596618	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
596619	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
596620	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
596621	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
596622	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
596623	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
596624	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
596625	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
596626	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	25	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
596627	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	30	
596628	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
596629	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
596630	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Clear of Trash?	y	
596631	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
596632	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
596633	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
596634	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
596635	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
596636	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
596637	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
596638	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	General Comments	ok	
596639	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
596640	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Vegetation	None	
596641	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
596642	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
596643	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
596644	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Switching Operations	0	
596645	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Unknown Operations	0	
596646	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
596647	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
596648	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
596649	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
596650	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
596651	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
596652	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
596653	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
596654	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
596655	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
596656	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
596657	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
596658	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	299	
596659	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	299	
596660	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
596661	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
596662	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	General Comments		
596663	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
596664	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
596665	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
596666	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
596667	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
596668	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
596669	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
596670	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9336	
596671	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
596672	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Top Oil Temperature Present	35	°C
596673	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Top Oil Temperature Max	55	°C
596674	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
596675	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
596676	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
596677	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
596678	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
596679	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
596680	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
596681	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Vegetation	None	
596682	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
596683	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
596684	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
596685	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
596686	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
596687	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	General Comments	one light out by TR1	
596688	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
596689	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
596690	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
596691	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
596692	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
596693	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
596694	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
596695	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
596696	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
596697	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	746.88	kw
596698	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
596699	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
596700	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
596701	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
596702	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	General Comments		
596703	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
596704	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
596705	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
596706	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
596707	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
596708	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
596709	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
596710	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
596711	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
596712	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
596713	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
596714	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
596715	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
596716	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
596717	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
596718	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
596719	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
596720	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
596721	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
596722	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
596723	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
596724	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
596725	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
596726	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
596727	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
596728	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Amps A Ø	170.0	
596729	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Amps B Ø	170.0	
596730	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Amps C Ø	170.0	
596731	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
596732	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	General Comments		
596733	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Patrol Inspection	General Comments		
596734	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Patrol Inspection	Gauge(s) Condition	Good	
596735	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Follow-up Action Required?	n	
596736	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Patrol Inspection	Follow-up Action Required?	n	
596737	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
596738	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
596739	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
596740	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
596741	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
596742	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
596743	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
596744	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Unknown Operations	0	
596745	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Tank Paint Condition	Good	
596746	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Switching Operations	1	
596747	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Patrol Inspection	Equipment Properly Labeled?	y	
596748	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Fault Operations	0	
596749	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Patrol Inspection	Follow-up Action Required?	n	
596750	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Follow-up Action Required?	n	
596751	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	General Comments		
596752	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Patrol Inspection	General Comments	A phase IOC	
596753	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Maintenance Operations	0	
596754	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Num Operations Last 9 Months	3	
596755	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Operations Counter AF	698	
596756	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Operations Counter AL	698	
596757	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Switching Operations	0	
596758	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Unknown Operations	0	
596759	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Operations Counter AL	180	
596760	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	BAT001084	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
596761	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	BAT001084	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	42	°F
596762	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	BAT001084	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
596763	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	BAT001084	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
596764	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	BAT001084	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
596765	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	BAT001084	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
596766	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	BAT001084	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
596767	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
596768	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
596769	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Totalizer Meter Reading	1.0322	
596770	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Operations Counter AL	174	
596771	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Switching Operations	2	
596772	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	BAT001084	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
596773	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	BAT001084	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
596774	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	BAT001084	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.1	VDC
596775	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	BAT001084	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
596776	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	BAT001084	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
596777	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	BAT001084	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
596778	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
596779	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
596780	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Winding Temp Max	47	°C
596781	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Winding Temp Present	40	°C
596782	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
596783	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
596784	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
596785	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
596786	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
596787	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
596788	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
596789	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BCH000515	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
596790	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BCH000515	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
596791	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BCH000515	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
596792	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BCH000515	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
596793	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Unknown Operations	0	
596794	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
596795	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
596796	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
596797	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
596798	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	35.0	
596799	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	33.0	
596800	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	35.0	
596801	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
596802	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
596803	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
596804	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
596805	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
596806	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
596807	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
596808	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
596809	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
596810	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
596811	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
596812	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
596813	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
596814	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
596815	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Grounds in Place?	y	
596816	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
596817	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Maintenance Operations	0	
596818	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
596819	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
596820	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
596821	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
596822	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Operations Counter AF	218	
596823	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Operations Counter AL	219	
596824	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Switching Operations	1	
596825	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Tank Paint Condition	Good	
596826	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Unknown Operations	0	
596827	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Amps B Ø	0.0	
596828	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Amps C Ø	0.0	
596829	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
596830	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
596831	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
596832	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
596833	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
596834	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
596835	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	General Comments	whole sub de-energized	
596836	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	ok	
596837	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
596838	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
596839	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
596840	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-3.0	psi
596841	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	35	°C
596842	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	10	°C
596843	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
596844	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
596845	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
596846	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
596847	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
596848	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
596849	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
596850	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
596851	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
596852	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Operations A Ø	0	
596853	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Operations B Ø	0	
596854	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Operations C Ø	0	
596855	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Operations Ground	0	
596856	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
596857	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Follow-up Action Required?	n	
596858	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
596859	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	General Comments		
596860	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	General Comments		
596861	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	BCH001050	Charger	610-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
596862	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	BCH001050	Charger	610-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
596863	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	BCH001050	Charger	610-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
596864	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	BCH001050	Charger	610-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
596865	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	BCH001050	Charger	610-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
596866	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
596867	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
596868	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Maintenance Operations	0	
596869	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
596870	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Operations Counter AF	173	
596871	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
596872	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
596873	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
596874	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
596875	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
596876	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Cabinet Paint Condition	Good	
596877	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
596878	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
596879	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
596880	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Bushings Connection/Risers	Good	
596881	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Bushing Condition	Good	
596882	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
596883	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Amps C Ø	41.0	
596884	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Amps B Ø	44.0	
596885	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Amps A Ø	28.0	
596886	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
596887	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
596888	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
596889	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	9 Month Operations	2	
596890	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
596891	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
596892	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	22	
596893	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	LTCC000025	LTCControl	912-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
596894	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	LTCC000025	LTCControl	912-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
596895	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
596896	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	39	°F
596897	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
596898	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
596899	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
596900	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
596901	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
596902	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
596903	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
596904	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.2	VDC
596905	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	9.9	VDC
596906	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
596907	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Ambient Temp	38	°F
596908	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
596909	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
596910	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Clear of Trash?	y	
596911	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
596912	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
596913	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
596914	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
596915	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
596916	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
596917	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	General Comments	ok	
596918	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
596919	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Vegetation	None	
596920	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
596921	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	9 Month Operations	3	
596922	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Accumulated Fault Duty A Ph V	2.28	%
596923	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Accumulated Fault Duty B Ph V	1.83	%
596924	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Accumulated Fault Duty C Ph V	1.83	%
596925	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Amps A Ø	135.0	
596926	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Amps B Ø	140.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
596927	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Unknown Operations	0	
596928	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Tank Paint Condition	Good	
596929	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Switching Operations	0	
596930	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Operations Counter AL	148	
596931	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Operations Counter AF	148	
596932	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
596933	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Maintenance Operations	0	
596934	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
596935	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Amps C Ø	140.0	
596936	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Bushing Condition	Good	
596937	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Bushings Connection/Risers	Good	
596938	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
596939	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
596940	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
596941	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Cabinet Paint Condition	Good	
596942	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Fault Operations	0	
596943	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Patrol Inspection	Equipment Properly Labeled?	y	
596944	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Amps C Ø	500.0	
596945	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Amps B Ø	500.0	
596946	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Amps A Ø	525.0	
596947	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Equipment Properly Labeled?	y	
596948	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
596949	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
596950	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
596951	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
596952	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
596953	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
596954	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
596955	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
596956	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
596957	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
596958	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Amps A Ø	190.0	
596959	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Amps B Ø	190.0	
596960	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Amps C Ø	190.0	
596961	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Patrol Inspection	Equipment Properly Labeled?	y	
596962	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Fault Operations	0	
596963	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Patrol Inspection	Follow-up Action Required?	n	
596964	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
596965	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
596966	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
596967	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
596968	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
596969	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Operations Counter AF	179	
596970	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Moisture and Leak Free?	y	
596971	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
596972	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
596973	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
596974	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
596975	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
596976	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
596977	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
596978	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
596979	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Follow-up Action Required?	n	
596980	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Patrol Inspection	General Comments		
596981	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	General Comments		
596982	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Maintenance Operations	0	
596983	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Num Operations Last 9 Months	3	
596984	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Operations Counter AF	349	
596985	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Operations Counter AL	349	
596986	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
596987	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
596988	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
596989	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	145	
596990	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	145	
596991	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	BCH000442	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
596992	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	BCH000442	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
596993	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
596994	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
596995	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
596996	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
596997	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
596998	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	2	
596999	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
597000	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
597001	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
597002	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Maintenance Operations	0	
597003	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Grounds in Place?	y	
597004	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	General Comments		
597005	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
597006	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
597007	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
597008	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
597009	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
597010	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
597011	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
597012	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	General Comments		
597013	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Foundation Condition	Good	
597014	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
597015	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
597016	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Follow-up Action Required?	n	
597017	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Follow-up Action Required?	n	
597018	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Operations Ground	0	
597019	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Operations C Ø	0	
597020	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Operations B Ø	0	
597021	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Operations A Ø	0	
597022	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
597023	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
597024	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
597025	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Equipment Properly Labeled?	y	
597026	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	BAT001064	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
597027	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
597028	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
597029	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
597030	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	BAT001064	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
597031	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	General Comments		
597032	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	General Comments		
597033	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	BAT001064	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
597034	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
597035	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
597036	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
597037	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
597038	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	BCH001027	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
597039	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	BCH001027	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
597040	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	BCH001027	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
597041	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
597042	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
597043	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
597044	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
597045	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
597046	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
597047	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
597048	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
597049	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
597050	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
597051	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
597052	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	BCH001027	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
597053	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	BCH001027	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
597054	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
597055	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
597056	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
597057	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
597058	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
597059	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
597060	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
597061	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
597062	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
597063	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
597064	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
597065	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
597066	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
597067	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
597068	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
597069	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
597070	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	VRR Time Delay	30	Seconds
597071	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
597072	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BAT001271	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
597073	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BAT001271	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	48	°F
597074	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BAT001271	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
597075	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BAT001271	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
597076	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BAT001271	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
597077	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BAT001271	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
597078	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
597079	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
597080	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
597081	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	LTC Operation Checked?	y	
597082	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	General Comments		
597083	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	Follow-up Action Required?	n	
597084	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	All Connections OK?	y	
597085	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BAT001271	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
597086	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BAT001271	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
597087	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BAT001271	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
597088	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BAT001271	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
597089	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BAT001271	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
597090	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	BAT001271	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
597091	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Tank Leaks	None	
597092	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
597093	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
597094	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Regulator As Left Counter	117448	
597095	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BAT000190	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
597096	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BAT000190	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
597097	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BAT000190	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
597098	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BAT000190	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
597099	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BAT000190	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
597100	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
597101	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
597102	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
597103	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
597104	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
597105	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
597106	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
597107	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
597108	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
597109	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
597110	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
597111	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
597112	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
597113	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
597114	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
597115	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
597116	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
597117	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
597118	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	General Comments	ok	
597119	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
597120	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
597121	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
597122	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
597123	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
597124	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
597125	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
597126	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
597127	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
597128	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
597129	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Amps C Ø	32.0	
597130	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Amps B Ø	66.0	
597131	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Amps A Ø	66.0	
597132	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	10.0	
597133	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
597134	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
597135	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
597136	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
597137	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
597138	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
597139	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
597140	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
597141	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
597142	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
597143	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
597144	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	BAT001064	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
597145	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	BAT001064	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
597146	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	BAT001064	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
597147	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	BAT001064	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
597148	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	BAT001064	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
597149	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	BAT001064	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
597150	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	BAT001064	Battery	Retired Distribution	Battery Patrol Inspection	Dry Cell Battery Install Date	2017-02-04 00:00:00.000000	
597151	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	BAT001064	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
597152	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
597153	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
597154	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
597155	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
597156	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
597157	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
597158	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Readings	General Comments		
597159	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
597160	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
597161	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
597162	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	All Connections OK?	y	
597163	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	Follow-up Action Required?	n	
597164	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	General Comments		
597165	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	LTC Operation Checked?	y	
597166	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
597167	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
597168	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
597169	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	777.60	kw
597170	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
597171	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	VRR Time Delay	60	Seconds
597172	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	BAT001064	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
597173	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	BAT001064	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
597174	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	BAT001064	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
597175	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
597176	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
597177	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	3235.20	kw
597178	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	71.00	
597179	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Bushing Condition	Good	
597180	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Bushings Connection/Risers	Good	
597181	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
597182	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
597183	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
597184	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Cabinet Paint Condition	Good	
597185	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Equipment Properly Labeled?	y	
597186	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	30.0	
597187	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
597188	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
597189	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
597190	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
597191	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
597192	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
597193	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
597194	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
597195	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
597196	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
597197	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
597198	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
597199	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
597200	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
597201	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
597202	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
597203	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
597204	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Operations A Ø	0	
597205	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	BAT000181	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
597206	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
597207	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
597208	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
597209	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
597210	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
597211	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
597212	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
597213	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	40	°C
597214	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
597215	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Top Oil Temperature Max	40	°C
597216	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Top Oil Temperature Present	40	°C
597217	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
597218	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Totalizer Meter Reading	1.0110	
597219	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
597220	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	BAT000181	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	n	If no, which cells in comments
597221	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	BAT000181	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
597222	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	BAT000181	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
597223	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	BAT000181	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	Cell 9 corrosion; Cleaned.	
597224	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	BAT000181	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	y	
597225	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	BAT000181	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
597226	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	BAT000181	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
597227	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	BAT000181	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
597228	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	BAT000181	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
597229	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	BAT000181	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
597230	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	BAT000181	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
597231	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	BAT000181	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
597232	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
597233	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
597234	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	645	
597235	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	645	
597236	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
597237	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
597238	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
597239	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
597240	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
597241	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
597242	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
597243	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	BAT000181	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
597244	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
597245	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
597246	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
597247	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
597248	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
597249	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
597250	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	VRR Time Delay	30	Seconds
597251	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
597252	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
597253	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
597254	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
597255	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
597256	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	LTC Operation Checked?	y	
597257	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	General Comments	ok	
597258	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	Follow-up Action Required?	n	
597259	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	All Connections OK?	y	
597260	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BAT000190	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
597261	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
597262	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
597263	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
597264	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
597265	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
597266	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
597267	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
597268	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Foundation Condition	Good	
597269	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
597270	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
597271	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	General Comments	needs vermint guarding	
597272	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
597273	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
597274	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
597275	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
597276	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
597277	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BAT000190	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
597278	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BAT000190	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
597279	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BAT000190	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
597280	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BAT000190	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
597281	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BAT000190	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
597282	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BAT000190	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
597283	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BAT000190	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
597284	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BAT000190	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
597285	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	9 Month Operations	3	
597286	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Accumulated Fault Duty A Ph V	9.77	%
597287	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Accumulated Fault Duty B Ph V	7.33	%
597288	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Accumulated Fault Duty C Ph V	12.21	%
597289	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Amps A Ø	170.0	
597290	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
597291	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
597292	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
597293	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
597294	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
597295	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
597296	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
597297	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
597298	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
597299	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
597300	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
597301	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
597302	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	General Comments		
597303	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
597304	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
597305	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
597306	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Amps B Ø	180.0	
597307	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Amps C Ø	120.0	
597308	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Ambient Temp	48	°F
597309	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
597310	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
597311	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Clear of Trash?	y	
597312	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
597313	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
597314	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
597315	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
597316	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
597317	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
597318	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	General Comments		
597319	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
597320	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
597321	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Vegetation	None	
597322	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	General Comments	ok	
597323	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
597324	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
597325	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
597326	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
597327	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
597328	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
597329	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
597330	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Tank Leaks	None	
597331	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
597332	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Regulator As Left Counter	50147	
597333	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.9	volts
597334	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
597335	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
597336	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
597337	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
597338	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Min Tap Position	Neutral	
597339	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
597340	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
597341	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	General Comments	ok	
597342	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
597343	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
597344	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
597345	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
597346	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
597347	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
597348	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
597349	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
597350	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
597351	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
597352	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
597353	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
597354	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
597355	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Clear of Trash?	y	
597356	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
597357	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
597358	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
597359	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Maintenance Operations	0	
597360	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Grounds in Place?	y	
597361	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	General Comments		
597362	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	General Comments		
597363	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Foundation Condition	Good	
597364	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Follow-up Action Required?	n	
597365	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Follow-up Action Required?	n	
597366	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Fault Operations Ground	0	
597367	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Fault Operations C Ø	0	
597368	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Fault Operations B Ø	0	
597369	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Fault Operations A Ø	0	
597370	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
597371	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
597372	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
597373	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Equipment Properly Labeled?	y	
597374	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Cabinet Paint Condition	Good	
597375	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
597376	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
597377	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
597378	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Bushings Connection/Risers	Good	
597379	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Bushing Condition	Good	
597380	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Amps C Ø	27.0	
597381	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
597382	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Tank Leaks	None	
597383	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
597384	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
597385	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Regulator As Left Counter	124423	
597386	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
597387	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
597388	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
597389	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
597390	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
597391	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
597392	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
597393	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
597394	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	General Comments		
597395	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
597396	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
597397	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
597398	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
597399	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
597400	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
597401	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
597402	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
597403	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	VRR Time Delay	30	Seconds
597404	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
597405	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
597406	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
597407	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	LTC Operation Checked?	y	
597408	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	General Comments		
597409	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	Follow-up Action Required?	n	
597410	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	All Connections OK?	y	
597411	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
597412	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
597413	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
597414	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
597415	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
597416	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
597417	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
597418	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
597419	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
597420	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
597421	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
597422	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	180.0	
597423	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	180.0	
597424	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	3.02	%
597425	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
597426	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
597427	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
597428	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.01	%
597429	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	3.02	%
597430	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
597431	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
597432	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
597433	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
597434	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
597435	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
597436	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	General Comments	ok	
597437	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
597438	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
597439	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	General Comments	no 911 signage	
597440	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
597441	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
597442	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
597443	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
597444	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
597445	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
597446	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
597447	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
597448	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
597449	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
597450	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
597451	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
597452	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
597453	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
597454	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Unknown Operations	0	
597455	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Tank Paint Condition	Good	
597456	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Switching Operations	1	
597457	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
597458	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Operations Counter AL	202	
597459	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Operations Counter AF	201	
597460	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Moisture and Leak Free?	y	
597461	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
597462	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
597463	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
597464	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
597465	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
597466	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
597467	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
597468	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
597469	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
597470	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
597471	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
597472	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	848	
597473	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	853	
597474	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Vegetation	None	
597475	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
597476	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	32	°C
597477	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	35	°C
597478	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
597479	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	30	°C
597480	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	28	°C
597481	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	28	°C
597482	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
597483	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
597484	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
597485	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
597486	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
597487	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
597488	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
597489	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
597490	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
597491	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	Oil Temp Present	27	°C
597492	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	Oil Temp Max	27	°C
597493	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.7	psi
597494	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
597495	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	20	°C
597496	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	20	°C
597497	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
597498	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
597499	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
597500	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
597501	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	General Comments		
597502	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	25.40	%
597503	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
597504	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
597505	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
597506	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
597507	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
597508	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
597509	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	23.14	%
597510	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	30.0	
597511	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	30.0	
597512	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	10.0	
597513	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	10.0	
597514	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	84.0	
597515	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	88.0	
597516	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
597517	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
597518	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
597519	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
597520	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
597521	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
597522	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
597523	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
597524	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
597525	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
597526	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
597527	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
597528	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
597529	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	640	
597530	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	640	
597531	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
597532	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
597533	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.2960	
597534	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
597535	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
597536	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Operations Counter	63	
597537	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
597538	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
597539	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	General Comments	ok controller operations counter said 63	
597540	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
597541	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
597542	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
597543	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
597544	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
597545	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
597546	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
597547	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
597548	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
597549	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
597550	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Amps B Ø	25.0	
597551	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Amps A Ø	52.0	
597552	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Accumulated Fault Duty C Ph V	2.78	%
597553	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Accumulated Fault Duty B Ph V	3.57	%
597554	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Accumulated Fault Duty A Ph V	4.37	%
597555	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	9 Month Operations	5	
597556	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
597557	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
597558	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
597559	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
597560	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
597561	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
597562	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
597563	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
597564	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	472	
597565	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	467	
597566	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
597567	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
597568	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
597569	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
597570	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
597571	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
597572	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
597573	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
597574	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
597575	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
597576	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
597577	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
597578	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
597579	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
597580	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
597581	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
597582	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
597583	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
597584	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
597585	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
597586	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
597587	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
597588	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
597589	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
597590	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
597591	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
597592	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	5.0	
597593	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	5.0	
597594	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	5.0	
597595	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
597596	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
597597	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
597598	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0239	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
597599	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	21	
597600	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	1.32	%
597601	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	2.64	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
597602	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
597603	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
597604	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
597605	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Clear of Trash?	y	
597606	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
597607	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	2.64	%
597608	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	88.0	
597609	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
597610	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
597611	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
597612	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
597613	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	20	
597614	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	26.31	%
597615	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
597616	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
597617	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
597618	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
597619	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
597620	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	General Comments		
597621	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
597622	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
597623	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
597624	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Amps B Ø	173.0	
597625	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Amps A Ø	144.0	
597626	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Accumulated Fault Duty C Ph V	.76	%
597627	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Accumulated Fault Duty B Ph V	.76	%
597628	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Accumulated Fault Duty A Ph V	.76	%
597629	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	9 Month Operations	3	
597630	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
597631	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	General Comments		
597632	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
597633	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
597634	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
597635	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
597636	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
597637	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
597638	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
597639	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
597640	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
597641	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
597642	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
597643	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
597644	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
597645	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
597646	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
597647	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	General Comments	no 911 signage	
597648	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
597649	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
597650	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
597651	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
597652	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
597653	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
597654	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
597655	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	BCH000391	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
597656	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	BCH000391	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
597657	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	BCH000391	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
597658	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	BCH000391	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
597659	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	BCH000391	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
597660	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	BCH000391	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
597661	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
597662	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
597663	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
597664	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
597665	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
597666	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
597667	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
597668	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
597669	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	General Comments		
597670	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
597671	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
597672	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
597673	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	General Comments		
597674	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
597675	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
597676	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
597677	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
597678	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
597679	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
597680	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
597681	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LTCC000284	LTCControl	FL-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
597682	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LTCC000284	LTCControl	FL-TRANS 1	LTC Control Insp	General Comments		
597683	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LTCC000284	LTCControl	FL-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
597684	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	7	
597685	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
597686	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
597687	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
597688	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
597689	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
597690	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
597691	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
597692	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	Oil Temp Present	38	°C
597693	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	Oil Temp Max	40	°C
597694	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
597695	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
597696	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
597697	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	899	
597698	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
597699	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
597700	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
597701	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
597702	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
597703	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
597704	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
597705	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Foundation Condition	Good	
597706	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
597707	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
597708	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	General Comments		
597709	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
597710	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
597711	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
597712	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
597713	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
597714	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
597715	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	50	°C
597716	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
597717	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
597718	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
597719	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
597720	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
597721	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
597722	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
597723	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
597724	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	7	
597725	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
597726	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
597727	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
597728	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
597729	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
597730	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
597731	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
597732	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Vegetation	None	
597733	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
597734	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
597735	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
597736	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
597737	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Unknown Operations	0	
597738	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Tank Paint Condition	Good	
597739	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Switching Operations	0	
597740	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
597741	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Operations Counter AL	175	
597742	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Operations Counter AF	175	
597743	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Moisture and Leak Free?	y	
597744	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Maintenance Operations	0	
597745	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Heaters (All) Functioning?	y	
597746	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Grounds in Place?	y	
597747	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	General Comments	ok	
597748	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	General Comments	ok	
597749	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Foundation Condition	Good	
597750	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Follow-up Action Required?	n	
597751	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
597752	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Operations Ground	0	
597753	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Operations C Ø	0	
597754	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Operations B Ø	0	
597755	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Operations A Ø	0	
597756	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
597757	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
597758	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
597759	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Equipment Properly Labeled?	y	
597760	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Cabinet Paint Condition	Good	
597761	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
597762	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
597763	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
597764	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
597765	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
597766	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
597767	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
597768	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
597769	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
597770	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Bushings Connection/Risers	Good	
597771	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Bushing Condition	Good	
597772	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Amps C Ø	161.0	
597773	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
597774	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
597775	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
597776	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
597777	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
597778	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Amps C Ø	88.0	
597779	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Amps B Ø	86.0	
597780	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
597781	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
597782	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
597783	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
597784	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
597785	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
597786	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
597787	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
597788	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
597789	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
597790	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
597791	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
597792	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
597793	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
597794	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
597795	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
597796	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	75.0	
597797	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	75.0	
597798	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	75.0	
597799	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
597800	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
597801	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	9.64	%
597802	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	10.84	%
597803	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	8.43	%
597804	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	21	
597805	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
597806	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
597807	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
597808	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
597809	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
597810	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
597811	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
597812	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
597813	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
597814	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
597815	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
597816	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	General Comments		
597817	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	General Comments		
597818	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
597819	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
597820	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
597821	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	569.52	kw
597822	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
597823	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
597824	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
597825	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC Operations Since Last Insp	256	
597826	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC Min Tap Position	4L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
597827	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC Max Tap Position	4R	
597828	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC Current Tap Position	3L	
597829	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
597830	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC As Left Counter	154200	
597831	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC As Found Counter	154200	
597832	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
597833	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	General Comments		
597834	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
597835	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
597836	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Foundation Condition	Good	
597837	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
597838	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
597839	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
597840	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
597841	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
597842	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
597843	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
597844	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Mechanism Patrol Inspection	General Comments		
597845	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	General Comments		
597846	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	225.00	
597847	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
597848	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
597849	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
597850	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Operations Counter	304	
597851	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
597852	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
597853	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	General Comments	ok	
597854	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	225.00	
597855	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
597856	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
597857	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
597858	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
597859	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	899	
597860	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
597861	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
597862	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
597863	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
597864	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	General Comments	ok	
597865	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
597866	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
597867	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
597868	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
597869	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
597870	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
597871	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
597872	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
597873	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
597874	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
597875	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
597876	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
597877	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	General Comments		
597878	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	General Comments		
597879	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
597880	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
597881	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
597882	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
597883	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
597884	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
597885	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
597886	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
597887	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
597888	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
597889	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
597890	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
597891	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
597892	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
597893	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
597894	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
597895	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
597896	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
597897	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
597898	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
597899	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
597900	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
597901	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
597902	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
597903	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
597904	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
597905	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
597906	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
597907	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
597908	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
597909	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Broom on Site?	y	
597910	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
597911	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
597912	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
597913	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
597914	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
597915	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
597916	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
597917	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
597918	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
597919	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
597920	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
597921	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Evidence of Insects	None	
597922	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
597923	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
597924	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
597925	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
597926	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
597927	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
597928	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
597929	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Tank Leaks	None	
597930	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
597931	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Regulator As Left Counter	92733	
597932	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
597933	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
597934	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
597935	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
597936	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
597937	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
597938	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
597939	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
597940	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	General Comments	ok	
597941	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
597942	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
597943	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
597944	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
597945	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
597946	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	5.20	%
597947	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	5.20	%
597948	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
597949	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
597950	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
597951	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
597952	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
597953	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC As Found Counter	37403	
597954	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	General Comments		
597955	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	General Comments		
597956	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
597957	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	Follow-up Action Required?	n	
597958	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
597959	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
597960	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
597961	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
597962	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
597963	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
597964	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
597965	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
597966	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
597967	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
597968	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	Follow-up Action Required?	n	
597969	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
597970	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
597971	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
597972	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
597973	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
597974	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	40	°C
597975	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
597976	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
597977	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
597978	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
597979	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
597980	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
597981	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
597982	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
597983	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	General Comments		
597984	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	General Comments		
597985	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
597986	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
597987	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
597988	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
597989	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
597990	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
597991	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	General Comments		
597992	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	General Comments		
597993	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
597994	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
597995	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
597996	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	148.32	kw
597997	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
597998	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Foundation Condition	Good	
597999	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
598000	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
598001	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	General Comments		
598002	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
598003	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
598004	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
598005	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
598006	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
598007	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
598008	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
598009	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
598010	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
598011	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
598012	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
598013	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
598014	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
598015	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
598016	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
598017	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC Operations Since Last Insp	799	
598018	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
598019	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC Min Tap Position	9L	
598020	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC Max Tap Position	1L	
598021	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC Current Tap Position	6L	
598022	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
598023	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC As Left Counter	37409	
598024	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
598025	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
598026	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
598027	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
598028	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
598029	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
598030	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	250.0	
598031	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	250.0	
598032	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
598033	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
598034	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
598035	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
598036	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
598037	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
598038	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
598039	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	250.0	
598040	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	5.20	%
598041	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
598042	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
598043	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
598044	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
598045	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
598046	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
598047	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
598048	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
598049	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
598050	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
598051	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	127	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
598052	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	127	
598053	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
598054	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
598055	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
598056	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
598057	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
598058	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
598059	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1653	
598060	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1657	
598061	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
598062	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
598063	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
598064	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Min Tap Position	13L	
598065	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
598066	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
598067	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
598068	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
598069	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
598070	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
598071	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
598072	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	General Comments		
598073	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
598074	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
598075	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
598076	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
598077	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Panels Dusted?	y	
598078	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
598079	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	General Comments		
598080	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
598081	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
598082	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Floor Swept?	y	
598083	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
598084	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
598085	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	40	°C
598086	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
598087	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Evidence of Insects	None	
598088	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
598089	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
598090	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
598091	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
598092	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
598093	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
598094	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
598095	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
598096	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
598097	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
598098	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
598099	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
598100	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
598101	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
598102	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
598103	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
598104	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
598105	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	154.0	
598106	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	153.0	
598107	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	157.0	
598108	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
598109	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
598110	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
598111	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	15	
598112	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
598113	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
598114	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Operations B Ø	0	
598115	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Operations C Ø	0	
598116	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Operations Ground	0	
598117	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Follow-up Action Required?	n	
598118	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Follow-up Action Required?	n	
598119	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Foundation Condition	Good	
598120	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	General Comments	ok	
598121	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	General Comments	ok	
598122	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Grounds in Place?	y	
598123	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Heaters (All) Functioning?	y	
598124	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Maintenance Operations	0	
598125	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Moisture and Leak Free?	y	
598126	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
598127	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
598128	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
598129	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
598130	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
598131	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
598132	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
598133	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
598134	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
598135	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
598136	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
598137	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
598138	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
598139	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
598140	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
598141	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Operations Counter AF	152	
598142	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Operations Counter AL	152	
598143	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
598144	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Switching Operations	0	
598145	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Tank Paint Condition	Good	
598146	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Unknown Operations	0	
598147	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
598148	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
598149	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
598150	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
598151	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
598152	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
598153	2/5/2019 9:34	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
598154	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
598155	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
598156	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	569	
598157	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	569	
598158	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
598159	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
598160	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
598161	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	LTC Totalizer Reading	3283.20	kw
598162	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
598163	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
598164	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
598165	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	Oil Temp Max	35	°C
598166	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	Oil Temp Present	35	°C
598167	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
598168	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
598169	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
598170	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
598171	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
598172	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
598173	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
598174	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
598175	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	Totalizer Meter Reading	.3420	
598176	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
598177	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
598178	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
598179	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
598180	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Clear of Trash?	y	
598181	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
598182	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
598183	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
598184	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
598185	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
598186	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
598187	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	General Comments		
598188	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
598189	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
598190	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
598191	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Vegetation	None	
598192	2/5/2019 12:18	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
598193	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
598194	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
598195	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
598196	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
598197	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
598198	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
598199	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
598200	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
598201	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
598202	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
598203	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
598204	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
598205	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
598206	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
598207	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
598208	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Totalizer Meter Reading	.1236	
598209	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
598210	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
598211	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
598212	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
598213	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
598214	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
598215	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
598216	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
598217	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
598218	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
598219	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
598220	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
598221	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
598222	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
598223	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
598224	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
598225	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
598226	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
598227	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
598228	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
598229	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
598230	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	General Comments		
598231	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
598232	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
598233	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	General Comments	ok	
598234	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
598235	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
598236	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Linkage Grounds in Place?	y	
598237	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
598238	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Operating Linkage OK?	y	
598239	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Operations Counter AL	136	
598240	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Operations Counter AF	136	
598241	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Moisture and Leak Free?	y	
598242	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Maintenance Operations	0	
598243	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Heaters (All) Functioning?	y	
598244	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
598245	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
598246	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
598247	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
598248	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
598249	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
598250	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Site Service Trans Condition	OK	
598251	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
598252	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
598253	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Wood Structures OK?	y	
598254	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
598255	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
598256	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
598257	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
598258	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
598259	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
598260	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
598261	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	311	
598262	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	325	
598263	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	300	
598264	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
598265	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
598266	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
598267	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
598268	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
598269	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
598270	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	600	psi
598271	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	BCH000334	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	0.0	VDC
598272	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
598273	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
598274	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	BCH000334	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
598275	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	BCH000334	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
598276	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	BCH000334	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
598277	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	BCH000334	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	Has been disconnected	
598278	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
598279	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
598280	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
598281	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
598282	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
598283	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
598284	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
598285	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	General Comments		
598286	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Mechanism Patrol Inspection	General Comments		
598287	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC As Found Counter	13502	
598288	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC As Left Counter	13506	
598289	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
598290	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
598291	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Tank Paint Condition	Good	
598292	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
598293	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
598294	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
598295	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
598296	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
598297	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
598298	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Foundation Condition	Good	
598299	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
598300	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	General Comments		
598301	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
598302	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
598303	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
598304	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Unknown Operations	0	
598305	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Tank Paint Condition	Good	
598306	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Switching Operations	0	
598307	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
598308	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
598309	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Broom on Site?	y	
598310	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
598311	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
598312	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
598313	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Vegetation	None	
598314	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
598315	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
598316	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
598317	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
598318	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
598319	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
598320	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
598321	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
598322	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
598323	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	General Comments	ok	
598324	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
598325	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
598326	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Foundation Condition	Good	
598327	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
598328	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
598329	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
598330	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
598331	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
598332	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
598333	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	9 Month Operations	7	
598334	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Accumulated Fault Duty A Ph V	25.51	%
598335	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Accumulated Fault Duty B Ph V	21.52	%
598336	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Accumulated Fault Duty C Ph V	18.33	%
598337	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	Follow-up Action Required?	n	
598338	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
598339	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	General Comments		
598340	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	General Comments		
598341	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC As Found Counter	203861	
598342	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC As Left Counter	203861	
598343	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
598344	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
598345	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	General Comments		
598346	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
598347	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
598348	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
598349	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
598350	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
598351	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
598352	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
598353	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
598354	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
598355	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
598356	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	2	
598357	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
598358	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
598359	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
598360	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
598361	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
598362	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Regulator As Left Counter	4015	
598363	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
598364	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
598365	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
598366	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	9 Month Operations	2	
598367	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Accumulated Fault Duty A Ph V	.91	%
598368	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
598369	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
598370	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
598371	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Accumulated Fault Duty B Ph V	1.83	%
598372	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
598373	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	General Comments		
598374	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
598375	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
598376	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
598377	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
598378	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
598379	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	Winding Temp Max	32	°C
598380	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	Winding Temp Present	26	°C
598381	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
598382	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC Current Tap Position	6L	
598383	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
598384	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
598385	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
598386	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Regulator As Left Counter	2370	
598387	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
598388	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
598389	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Tank Leaks	None	
598390	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
598391	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
598392	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	General Comments		
598393	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
598394	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
598395	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Foundation Condition	Good	
598396	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
598397	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
598398	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
598399	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
598400	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
598401	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Current Tap Position	1L	
598402	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
598403	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
598404	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
598405	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Tank Leaks	None	
598406	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
598407	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
598408	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
598409	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Regulator As Left Counter	13495	
598410	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	All Connections OK?	y	
598411	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	Follow-up Action Required?	n	
598412	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	General Comments		
598413	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	LTC Operation Checked?	y	
598414	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
598415	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
598416	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
598417	2/5/2019 11:51	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	VRR Time Delay	30	Seconds
598418	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
598419	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
598420	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
598421	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	General Comments	ok	
598422	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
598423	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Max Tap Position	10R	
598424	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
598425	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
598426	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
598427	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
598428	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Min Tap Position	13L	
598429	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
598430	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
598431	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
598432	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
598433	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
598434	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
598435	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
598436	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
598437	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
598438	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
598439	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
598440	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
598441	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
598442	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
598443	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	General Comments	ok	
598444	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Amps C Ø	108.0	
598445	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Amps B Ø	108.0	
598446	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Amps A Ø	120.0	
598447	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	General Comments		
598448	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Grounds in Place?	y	
598449	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
598450	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
598451	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
598452	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Maintenance Operations	0	
598453	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Moisture and Leak Free?	y	
598454	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Min Tap Position	5L	
598455	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Max Tap Position	1R	
598456	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
598457	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	General Comments	ok	
598458	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
598459	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Accumulated Fault Duty C Ph V	17.94	%
598460	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Accumulated Fault Duty B Ph V	15.38	%
598461	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Accumulated Fault Duty A Ph V	11.96	%
598462	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
598463	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
598464	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
598465	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
598466	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Operations A Ø	0	
598467	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Operations B Ø	0	
598468	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Operations C Ø	0	
598469	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Operations Ground	0	
598470	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
598471	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
598472	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
598473	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
598474	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	670	
598475	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	670	
598476	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	BCH000437	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
598477	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	BCH000437	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
598478	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	BCH000437	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
598479	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	BCH000437	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
598480	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	BCH000437	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
598481	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
598482	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
598483	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
598484	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Maintenance Operations	0	
598485	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Moisture and Leak Free?	y	
598486	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Operations Counter AF	208	
598487	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Operations Counter AL	209	
598488	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Switching Operations	1	
598489	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Maintenance Operations	0	
598490	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Operations Counter AF	116	
598491	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Operations Counter AL	116	
598492	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Switching Operations	0	
598493	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Unknown Operations	0	
598494	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
598495	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
598496	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
598497	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
598498	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
598499	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
598500	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
598501	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
598502	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Foundation Condition	Good	
598503	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	General Comments	ok	
598504	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	General Comments	ok	
598505	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Grounds in Place?	y	
598506	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
598507	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
598508	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
598509	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Tank Leaks	None	
598510	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
598511	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
598512	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0	VDC
598513	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0	VDC
598514	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
598515	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
598516	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
598517	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
598518	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
598519	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
598520	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
598521	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
598522	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
598523	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
598524	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
598525	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
598526	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
598527	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
598528	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
598529	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
598530	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
598531	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
598532	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
598533	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
598534	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
598535	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
598536	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Regulator As Left Counter	14158	
598537	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
598538	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
598539	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	General Comments		
598540	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	BCH000432	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
598541	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	BCH000432	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
598542	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	BCH000432	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
598543	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	BCH000432	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	51.1	VDC
598544	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	BCH000432	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	51.1	VDC
598545	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
598546	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
598547	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
598548	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
598549	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
598550	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Patrol Inspection	Follow-up Action Required?	n	
598551	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
598552	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
598553	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
598554	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
598555	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
598556	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
598557	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Operations Ground	0	
598558	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Follow-up Action Required?	n	
598559	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Tank Paint Condition	Good	
598560	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Unknown Operations	0	
598561	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
598562	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
598563	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
598564	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
598565	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
598566	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
598567	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
598568	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	Totalizer Meter Reading	1.4046	
598569	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
598570	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
598571	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Readings	General Comments		
598572	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
598573	2/5/2019 14:07	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
598574	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Follow-up Action Required?	n	
598575	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Patrol Inspection	General Comments		
598576	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
598577	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Follow-up Action Required?	n	
598578	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
598579	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
598580	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
598581	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
598582	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Current Tap Position	4R	
598583	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
598584	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
598585	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
598586	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC Operations Since Last Insp	591	
598587	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
598588	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
598589	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
598590	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC Operations Since Last Insp	586	
598591	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
598592	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
598593	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
598594	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
598595	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
598596	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
598597	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
598598	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC As Found Counter	26521	
598599	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
598600	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
598601	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
598602	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
598603	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
598604	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
598605	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	General Comments	Fence is old	
598606	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
598607	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
598608	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	Follow-up Action Required?	n	
598609	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Tank Leaks	None	
598610	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
598611	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	General Comments		
598612	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
598613	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
598614	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Tank Leaks	None	
598615	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
598616	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
598617	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
598618	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Regulator As Left Counter	12810	
598619	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
598620	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
598621	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
598622	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	General Comments		
598623	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC As Left Counter	26529	
598624	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
598625	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
598626	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
598627	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
598628	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
598629	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
598630	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
598631	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
598632	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
598633	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	General Comments		
598634	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC Max Tap Position	14L	
598635	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC Min Tap Position	3L	
598636	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
598637	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
598638	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
598639	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	13726.8	kw
598640	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
598641	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
598642	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2000	psi
598643	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	60	°C
598644	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	30	°C
598645	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
598646	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
598647	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
598648	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Clear of Trash?	y	
598649	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
598650	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
598651	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
598652	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
598653	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Ambient Temp	60	°F
598654	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Min Tap Position	1R	
598655	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Max Tap Position	7R	
598656	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
598657	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	General Comments	ok	
598658	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
598659	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	General Comments		
598660	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC As Found Counter	14307	
598661	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC As Left Counter	14307	
598662	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
598663	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC Current Tap Position	2L	
598664	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC Max Tap Position	2L	
598665	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC Min Tap Position	11L	
598666	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
598667	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
598668	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
598669	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
598670	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
598671	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
598672	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
598673	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
598674	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
598675	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
598676	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Switching Operations	0	
598677	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Unknown Operations	0	
598678	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	PF000129	PowerFuse	FA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
598679	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
598680	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	122	
598681	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
598682	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
598683	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3L	
598684	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
598685	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	PF000129	PowerFuse	FA-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
598686	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
598687	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
598688	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
598689	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC As Left Counter	3986	
598690	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
598691	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
598692	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
598693	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
598694	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
598695	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
598696	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Mechanism Patrol Inspection	General Comments		
598697	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
598698	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
598699	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BCH000265	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
598700	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BCH000265	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
598701	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BCH000265	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
598702	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BCH000265	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.8	VDC
598703	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC As Found Counter	3986	
598704	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
598705	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	BCH000265	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.8	VDC
598706	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	General Comments		
598707	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
598708	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
598709	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
598710	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
598711	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
598712	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Regulator As Left Counter	50623	
598713	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
598714	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
598715	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
598716	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
598717	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
598718	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
598719	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
598720	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
598721	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
598722	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
598723	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
598724	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
598725	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
598726	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	General Comments	ok	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
598727	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
598728	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
598729	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
598730	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
598731	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
598732	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
598733	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
598734	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
598735	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Bushing Condition	Good	
598736	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
598737	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
598738	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	9 Month Operations	21	
598739	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.7626	
598740	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Winding Temp Max	70	°C
598741	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Winding Temp Present	35	°C
598742	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
598743	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
598744	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
598745	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Operations Counter AF	133	
598746	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
598747	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	PF000128	PowerFuse	FA-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
598748	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	PF000128	PowerFuse	FA-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
598749	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
598750	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
598751	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	General Comments	ok	
598752	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
598753	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
598754	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
598755	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC Max Tap Position	1R	
598756	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
598757	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
598758	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
598759	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	General Comments		
598760	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	General Comments		
598761	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Grounds in Place?	y	
598762	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
598763	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
598764	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
598765	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
598766	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
598767	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
598768	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
598769	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
598770	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
598771	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
598772	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
598773	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
598774	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
598775	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
598776	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
598777	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
598778	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
598779	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Heaters (All) Functioning?	y	
598780	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
598781	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
598782	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
598783	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Maintenance Operations	0	
598784	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
598785	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
598786	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
598787	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Moisture and Leak Free?	y	
598788	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC Min Tap Position	9L	
598789	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Amps A Ø	65.0	
598790	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC Operations Since Last Insp	340	
598791	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Operations Counter AF	181	
598792	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Operations Counter AL	182	
598793	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
598794	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
598795	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
598796	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Switching Operations	1	
598797	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
598798	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Tank Paint Condition	Good	
598799	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
598800	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
598801	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
598802	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Amps A Ø	165.0	
598803	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Amps B Ø	173.0	
598804	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Amps C Ø	161.0	
598805	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Foundation Condition	Good	
598806	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
598807	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Bushing Condition	Good	
598808	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Bushings Connection/Risers	Good	
598809	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
598810	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
598811	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
598812	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
598813	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	General Comments		
598814	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Cabinet Paint Condition	Good	
598815	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Equipment Properly Labeled?	y	
598816	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
598817	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
598818	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
598819	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Operations A Ø	0	
598820	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Operations B Ø	0	
598821	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Operations C Ø	0	
598822	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
598823	2/5/2019 9:44	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
598824	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
598825	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
598826	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
598827	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
598828	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	General Comments	OK 877 MOD heater not working	
598829	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
598830	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Foundation Condition	Good	
598831	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Follow-up Action Required?	y	
598832	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
598833	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
598834	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
598835	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
598836	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
598837	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Clear of Trash?	y	
598838	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
598839	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Operations Ground	0	
598840	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Follow-up Action Required?	n	
598841	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Follow-up Action Required?	n	
598842	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Foundation Condition	Good	
598843	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC Current Tap Position	7L	
598844	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
598845	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
598846	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
598847	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
598848	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
598849	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
598850	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
598851	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
598852	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
598853	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
598854	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
598855	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC Operations Since Last Insp	620	
598856	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC Min Tap Position	15L	
598857	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC Max Tap Position	3L	
598858	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC Current Tap Position	8L	
598859	2/5/2019 12:00	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
598860	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Tank Leaks	None	
598861	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
598862	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Regulator As Left Counter	59786	
598863	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	15	
598864	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	290	
598865	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	294	
598866	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
598867	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
598868	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
598869	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
598870	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
598871	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Bushings Connection/Risers	Good	
598872	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
598873	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
598874	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
598875	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
598876	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
598877	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
598878	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
598879	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
598880	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments	New bottle added checked for leaks didn't find any	
598881	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
598882	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
598883	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
598884	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Switch Stick and Container OK?	y	
598885	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
598886	2/5/2019 13:27	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
598887	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
598888	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Unknown Operations	0	
598889	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
598890	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
598891	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
598892	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Ambient Temp	66	°F
598893	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
598894	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Patrol Inspection	General Comments		
598895	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	General Comments		
598896	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Maintenance Operations	0	
598897	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
598898	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
598899	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
598900	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
598901	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1	
598902	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1	
598903	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
598904	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
598905	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
598906	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
598907	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Tank Leaks	None	
598908	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
598909	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
598910	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	Follow-up Action Required?	n	
598911	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
598912	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
598913	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
598914	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
598915	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Operations A Ø	0	
598916	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Operations Counter AF	94	
598917	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Operations Counter AL	94	
598918	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Switching Operations	0	
598919	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Tank Paint Condition	Good	
598920	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Operations Counter AL	133	
598921	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Operations B Ø	0	
598922	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Moisture and Leak Free?	y	
598923	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Heaters (All) Functioning?	y	
598924	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Grounds in Place?	y	
598925	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	General Comments	ok	
598926	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Foundation Condition	Good	
598927	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Follow-up Action Required?	n	
598928	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Equipment Properly Labeled?	y	
598929	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Cabinet Paint Condition	Good	
598930	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
598931	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
598932	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
598933	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Regulator As Left Counter	10848	
598934	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
598935	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
598936	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
598937	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
598938	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
598939	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Tank Leaks	None	
598940	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
598941	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
598942	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Regulator As Left Counter	3465	
598943	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
598944	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
598945	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Ambient Temp	38	°F
598946	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
598947	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
598948	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
598949	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
598950	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
598951	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
598952	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
598953	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	General Comments		
598954	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
598955	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
598956	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Operations A Ø	0	
598957	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
598958	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Unknown Operations	0	
598959	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
598960	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Operations B Ø	0	
598961	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
598962	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Tank Paint Condition	Good	
598963	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Switching Operations	8	
598964	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
598965	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
598966	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Operations C Ø	0	
598967	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Operations Ground	0	
598968	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Follow-up Action Required?	n	
598969	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Follow-up Action Required?	n	
598970	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Vegetation	None	
598971	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
598972	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
598973	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	General Comments		
598974	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Foundation Condition	Good	
598975	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	General Comments		
598976	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
598977	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
598978	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
598979	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
598980	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
598981	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
598982	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
598983	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
598984	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Patrol Inspection	Equipment Properly Labeled?	y	
598985	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Amps C Ø	65.0	
598986	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Amps B Ø	65.0	
598987	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
598988	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Operations A Ø	3	
598989	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
598990	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
598991	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
598992	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
598993	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
598994	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Amps C Ø	90.0	
598995	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Amps B Ø	65.0	
598996	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
598997	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
598998	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Amps A Ø	70.0	
598999	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
599000	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
599001	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
599002	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
599003	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
599004	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
599005	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
599006	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
599007	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6876	
599008	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
599009	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
599010	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Tank Leaks	None	
599011	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
599012	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
599013	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
599014	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
599015	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
599016	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	General Comments		
599017	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
599018	2/5/2019 12:03	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
599019	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Foundation Condition	Good	
599020	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
599021	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
599022	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
599023	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
599024	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	120.0	
599025	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
599026	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	161	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
599027	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	159	
599028	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
599029	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	2	
599030	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
599031	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	120.0	
599032	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
599033	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
599034	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
599035	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
599036	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
599037	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
599038	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
599039	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
599040	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
599041	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Foundation Condition	Good	
599042	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
599043	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Follow-up Action Required?	n	
599044	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Follow-up Action Required?	n	
599045	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
599046	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
599047	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
599048	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
599049	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
599050	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
599051	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
599052	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
599053	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
599054	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
599055	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
599056	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
599057	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Vegetation	None	
599058	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
599059	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
599060	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
599061	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
599062	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	General Comments		
599063	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Grounds in Place?	y	
599064	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
599065	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Maintenance Operations	0	
599066	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
599067	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Operations Counter AF	160	
599068	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Operations Counter AL	161	
599069	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Switching Operations	2	
599070	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Tank Paint Condition	Good	
599071	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Unknown Operations	0	
599072	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
599073	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
599074	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	9 Month Operations	1	
599075	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
599076	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
599077	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Operations Counter AL	960	
599078	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
599079	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Operations B Ø	0	
599080	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Operations C Ø	0	
599081	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Operations Ground	0	
599082	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Operations Counter AF	952	
599083	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Follow-up Action Required?	n	
599084	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
599085	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Follow-up Action Required?	n	
599086	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Foundation Condition	Good	
599087	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
599088	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
599089	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
599090	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
599091	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
599092	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
599093	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
599094	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Moisture and Leak Free?	y	
599095	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Maintenance Operations	0	
599096	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Grounds in Place?	y	
599097	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	General Comments		
599098	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	General Comments		
599099	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	General Comments		
599100	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
599101	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	120.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
599102	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
599103	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
599104	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
599105	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
599106	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
599107	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Unknown Operations	0	
599108	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Tank Paint Condition	Good	
599109	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Switching Operations	1	
599110	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Operations Counter AL	192	
599111	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Operations Counter AF	191	
599112	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Accumulated Fault Duty A Ph V	3.66	%
599113	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Moisture and Leak Free?	y	
599114	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	9 Month Operations	2	
599115	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
599116	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
599117	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
599118	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Maintenance Operations	0	
599119	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Heaters (All) Functioning?	y	
599120	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
599121	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
599122	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	General Comments		
599123	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
599124	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Grounds in Place?	y	
599125	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	General Comments		
599126	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	General Comments		
599127	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Foundation Condition	Good	
599128	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Follow-up Action Required?	n	
599129	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Follow-up Action Required?	n	
599130	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Fault Operations Ground	0	
599131	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Fault Operations C Ø	0	
599132	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Fault Operations B Ø	0	
599133	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Fault Operations A Ø	0	
599134	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
599135	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
599136	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
599137	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
599138	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
599139	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
599140	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Accumulated Fault Duty C Ph V	8.55	%
599141	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
599142	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
599143	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Oil Temp Max	39	°C
599144	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Oil Temp Present	38	°C
599145	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
599146	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
599147	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
599148	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
599149	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
599150	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
599151	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
599152	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
599153	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	General Comments	2) 8ft single pin 2 tube light fixtures not working in control house.	
599154	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
599155	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
599156	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Floor Swept?	y	
599157	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
599158	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
599159	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
599160	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
599161	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	0	
599162	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	General Comments	ok	
599163	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
599164	2/5/2019 9:19	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Ambient Temp	48	°F
599165	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
599166	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
599167	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	General Comments		
599168	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
599169	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
599170	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.3	psi
599171	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Follow-up Action Required?	n	
599172	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Patrol Inspection	Follow-up Action Required?	n	
599173	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
599174	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
599175	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
599176	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1650.24	kw

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
599177	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	225.00	
599178	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
599179	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Amps B Ø	104.0	
599180	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Amps C Ø	92.0	
599181	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
599182	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Amps C Ø	10.0	
599183	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Amps B Ø	6.0	
599184	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Amps A Ø	10.0	
599185	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Operations Ground	0	
599186	2/5/2019 13:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
599187	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Bushing Condition	Good	
599188	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Bushings Connection/Risers	Good	
599189	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Operations C Ø	0	
599190	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Accumulated Fault Duty B Ph V	2.44	%
599191	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
599192	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
599193	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
599194	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Equipment Properly Labeled?	y	
599195	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Adjusted Amps A Phase V	19.64	
599196	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
599197	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
599198	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
599199	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
599200	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
599201	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	General Comments		
599202	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
599203	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
599204	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
599205	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
599206	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
599207	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
599208	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
599209	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
599210	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
599211	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
599212	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
599213	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
599214	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
599215	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
599216	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Bushing Condition	Good	
599217	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Amps C Ø	293.0	
599218	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Amps B Ø	273.0	
599219	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Amps A Ø	292.0	
599220	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
599221	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
599222	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
599223	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
599224	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
599225	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
599226	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
599227	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
599228	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
599229	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
599230	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
599231	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
599232	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
599233	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
599234	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
599235	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
599236	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Tank Leaks	None	
599237	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
599238	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
599239	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
599240	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Follow-up Action Required?	n	
599241	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Follow-up Action Required?	n	
599242	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Operations Counter	6	
599243	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
599244	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
599245	2/5/2019 12:53	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Evidence of Insects	None	
599246	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Equipment Properly Labeled?	y	
599247	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Cabinet Paint Condition	Good	
599248	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
599249	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
599250	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
599251	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
599252	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Operations Ground	0	
599253	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Operations C Ø	0	
599254	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Operations B Ø	0	
599255	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Operations A Ø	0	
599256	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
599257	2/5/2019 14:09	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	General Comments		
599258	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
599259	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
599260	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
599261	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Operations B Ø	0	
599262	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Operations A Ø	0	
599263	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
599264	2/5/2019 14:16	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
599265	2/5/2019 12:56	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
599266	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
599267	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Bushings Connection/Risers	Good	
599268	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Bushing Condition	Good	
599269	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Amps C Ø	85.0	
599270	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Amps B Ø	89.0	
599271	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Amps A Ø	86.0	
599272	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
599273	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Accumulated Fault Duty B Ph V	.43	%
599274	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Accumulated Fault Duty A Ph V	.44	%
599275	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	9 Month Operations	3	
599276	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Cabinet Paint Condition	Good	
599277	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
599278	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
599279	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
599280	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
599281	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
599282	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	General Comments	ok	
599283	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
599284	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
599285	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
599286	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
599287	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
599288	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
599289	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Vegetation	None	
599290	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
599291	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
599292	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Cabinet Paint Condition	Good	
599293	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Bushing Condition	Good	
599294	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
599295	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
599296	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
599297	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Clear of Trash?	y	
599298	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Amps B Ø	185.0	
599299	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	General Comments		
599300	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Equipment Properly Labeled?	y	
599301	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
599302	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Amps C Ø	150.0	
599303	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
599304	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Operations A Ø	0	
599305	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Operations B Ø	0	
599306	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Operations C Ø	0	
599307	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
599308	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Equipment Properly Labeled?	y	
599309	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
599310	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
599311	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
599312	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
599313	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Heaters (All) Functioning?	y	
599314	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Bushings Connection/Risers	Good	
599315	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
599316	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Follow-up Action Required?	n	
599317	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Follow-up Action Required?	n	
599318	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Foundation Condition	Good	
599319	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
599320	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
599321	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Grounds in Place?	y	
599322	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	General Comments		
599323	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	General Comments		
599324	2/5/2019 14:40	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	General Comments		
599325	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
599326	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Current Tap Position	5L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
599327	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
599328	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
599329	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
599330	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
599331	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
599332	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
599333	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
599334	2/6/2019 7:54	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
599335	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
599336	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Equipment Properly Labeled?	y	
599337	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
599338	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Cabinet Paint Condition	Good	
599339	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	2.64	%
599340	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Fault Operations C Ø	0	
599341	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	86.0	
599342	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
599343	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
599344	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Fault Operations A Ø	0	
599345	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
599346	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
599347	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
599348	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
599349	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
599350	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Fault Operations B Ø	0	
599351	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Cabinet Paint Condition	Good	
599352	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	Oil Temp Present	28	°C
599353	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	Oil Temp Max	42	°C
599354	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
599355	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
599356	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	38	
599357	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
599358	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	5.27	%
599359	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	3.96	%
599360	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
599361	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
599362	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	LTC Totalizer Reading	13484.16	kw
599363	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
599364	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
599365	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
599366	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
599367	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
599368	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
599369	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	General Comments		
599370	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	General Comments		
599371	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
599372	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
599373	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
599374	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
599375	2/5/2019 12:50	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	Follow-up Action Required?	n	
599376	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	BCH000442	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
599377	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
599378	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
599379	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
599380	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	General Comments		
599381	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
599382	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Vegetation	None	
599383	2/5/2019 10:42	Distribution	KU Park-Greasy Creek Quarterly Inspection	BCH000334	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	0.0	VDC
599384	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
599385	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Bushings Connection/Risers	Good	
599386	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
599387	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
599388	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
599389	2/5/2019 10:18	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
599390	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Clear of Trash?	y	
599391	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
599392	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
599393	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
599394	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Bushing Condition	Good	
599395	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Fault Operations Ground	0	
599396	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Operations Ground	0	
599397	2/5/2019 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Operations C Ø	0	
599398	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
599399	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	Follow-up Action Required?	n	
599400	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Clear of Trash?	y	
599401	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Clear of Trash?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
599402	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
599403	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
599404	2/5/2019 10:51	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
599405	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
599406	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Vegetation	None	
599407	2/5/2019 9:37	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
599408	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
599409	2/5/2019 14:04	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
599410	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Amps A Ø	190.0	
599411	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
599412	2/5/2019 11:17	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
599413	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
599414	2/5/2019 10:46	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
599415	2/5/2019 14:29	Distribution	Okonite Quarterly Inspection	CB0119	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
599416	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	82.0	
599417	2/5/2019 12:22	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	80.0	
599418	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	BCH000455	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
599419	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	BCH000455	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
599420	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	BCH000455	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	OK	
599421	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	BCH000455	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
599422	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	BCH000455	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
599423	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
599424	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
599425	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
599426	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
599427	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
599428	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
599429	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
599430	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
599431	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
599432	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
599433	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
599434	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
599435	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
599436	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
599437	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	General Comments	OK	
599438	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
599439	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
599440	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
599441	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
599442	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
599443	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
599444	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
599445	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	General Comments	OK	
599446	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
599447	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
599448	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
599449	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
599450	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
599451	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
599452	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
599453	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	BCH001238	Charger	451-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
599454	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	BCH001238	Charger	451-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
599455	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
599456	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
599457	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	BCH001238	Charger	451-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
599458	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
599459	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
599460	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
599461	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
599462	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
599463	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
599464	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
599465	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
599466	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
599467	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
599468	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
599469	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
599470	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
599471	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
599472	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
599473	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
599474	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
599475	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
599476	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
599477	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
599478	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
599479	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
599480	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
599481	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
599482	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
599483	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	General Comments		
599484	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Maintenance Operations	0	
599485	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	1368	
599486	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Operations Counter AF	847	
599487	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
599488	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
599489	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
599490	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Operations Counter AL	847	
599491	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Switching Operations	0	
599492	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	BCH001238	Charger	451-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
599493	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	BCH001238	Charger	451-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
599494	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
599495	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
599496	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
599497	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
599498	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
599499	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Switching Operations	0	
599500	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
599501	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	BCH001238	Charger	451-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
599502	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
599503	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
599504	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
599505	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
599506	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
599507	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
599508	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	LTC Operation Checked?	y	
599509	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
599510	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Amps C Ø	808.0	
599511	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	General Comments		
599512	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
599513	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
599514	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Amps B Ø	750.0	
599515	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Amps A Ø	730.0	
599516	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
599517	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
599518	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
599519	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
599520	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
599521	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
599522	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
599523	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
599524	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
599525	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
599526	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Operations Counter	79	
599527	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
599528	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
599529	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	LTCC000749	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
599530	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	LTCC000749	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
599531	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
599532	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
599533	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	General Comments		
599534	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
599535	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
599536	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Amps B Ø	198.0	
599537	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Amps C Ø	205.0	
599538	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
599539	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
599540	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Clear of Trash?	y	
599541	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
599542	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
599543	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
599544	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Follow-up Action Required?	n	
599545	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Patrol Inspection	General Comments		
599546	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
599547	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
599548	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	General Comments		
599549	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Maintenance Operations	0	
599550	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
599551	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
599552	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
599553	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
599554	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
599555	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
599556	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
599557	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
599558	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
599559	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Unknown Operations	0	
599560	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Foundation Condition	Good	
599561	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
599562	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
599563	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
599564	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
599565	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
599566	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
599567	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	General Comments		
599568	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	General Comments	Added nitrogen	
599569	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
599570	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	General Comments		
599571	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
599572	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
599573	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	General Comments		
599574	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
599575	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
599576	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
599577	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
599578	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
599579	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	46.08	kw
599580	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
599581	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
599582	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Oil Temp Max	26	°C
599583	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Oil Temp Present	22	°C
599584	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
599585	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
599586	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
599587	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
599588	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
599589	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC Operations Since Last Insp	265	
599590	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC Min Tap Position	2L	
599591	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC Max Tap Position	9L	
599592	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC Current Tap Position	6L	
599593	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
599594	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps A Ø Max	0.0	
599595	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps B Ø	0.0	
599596	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps B Ø Max	0.0	
599597	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
599598	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
599599	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	General Comments	OK	
599600	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC As Left Counter	68075	
599601	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC As Found Counter	68074	
599602	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	General Comments		
599603	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	General Comments		
599604	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
599605	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Accumulated Fault Duty C Ph AM	13.25	%
599606	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Amps A Ø	400.0	
599607	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
599608	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
599609	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	General Comments		
599610	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Amps B Ø	380.0	
599611	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Amps C Ø	380.0	
599612	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
599613	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	Follow-up Action Required?	n	
599614	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
599615	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
599616	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
599617	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
599618	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
599619	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
599620	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Operations Counter AL	11571	
599621	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Operations Counter AF	11571	
599622	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Maintenance Operations	0	
599623	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	General Comments		
599624	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Patrol Inspection	General Comments		
599625	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
599626	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
599627	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	General Comments	ok	
599628	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
599629	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
599630	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	9 Months Operations	0	
599631	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
599632	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
599633	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
599634	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
599635	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
599636	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
599637	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
599638	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
599639	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
599640	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	46	°C
599641	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
599642	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
599643	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
599644	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
599645	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
599646	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Operations Counter AF	562	
599647	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Operations Counter AL	562	
599648	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
599649	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
599650	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Switching Operations	0	
599651	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
599652	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
599653	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Amps A Ø	33.0	
599654	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
599655	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Unknown Operations	0	
599656	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
599657	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
599658	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Follow-up Action Required?	n	
599659	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
599660	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	9 Months Operations	10	
599661	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
599662	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
599663	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
599664	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
599665	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	VRR Time Delay	30	Seconds
599666	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
599667	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Maintenance Operations	0	
599668	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
599669	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
599670	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
599671	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	General Comments	ok	
599672	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments	ok	
599673	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	225922	
599674	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	225931	
599675	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
599676	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
599677	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
599678	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
599679	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
599680	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
599681	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Operations Counter AF	35	
599682	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Operations C Ø	0	
599683	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
599684	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	323	
599685	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
599686	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Operations Ground	0	
599687	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Patrol Inspection	Follow-up Action Required?	n	
599688	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	General Comments		
599689	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
599690	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	41	
599691	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
599692	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Operations Counter AL	35	
599693	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
599694	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps C Ø Max	0.0	
599695	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps C Ø	0.0	
599696	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps B Ø Max	0.0	
599697	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps B Ø	0.0	
599698	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Operations Counter AL	317	
599699	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
599700	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Operations Counter AF	317	
599701	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps A Ø Max	0.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
599702	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps A Ø	0.0	
599703	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Maintenance Operations	0	
599704	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Unknown Operations	0	
599705	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
599706	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
599707	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
599708	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
599709	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	General Comments	ok	
599710	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
599711	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
599712	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
599713	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
599714	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
599715	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Vegetation	None	
599716	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
599717	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
599718	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
599719	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
599720	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	General Comments		
599721	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
599722	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	50	°C
599723	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
599724	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
599725	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
599726	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
599727	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
599728	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
599729	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Clear of Trash?	y	
599730	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
599731	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
599732	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
599733	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Operations A Ø	0	
599734	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
599735	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
599736	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
599737	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
599738	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps C Ø Max	0.0	
599739	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps C Ø	0.0	
599740	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
599741	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
599742	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
599743	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
599744	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
599745	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps C Ø	0.0	
599746	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps C Ø Max	0.0	
599747	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	PF000335	PowerFuse	S-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
599748	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
599749	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
599750	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	PF000336	PowerFuse	S-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
599751	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
599752	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps B Ø Max	0.0	
599753	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps B Ø	0.0	
599754	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
599755	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps A Ø Max	0.0	
599756	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	PF000336	PowerFuse	S-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
599757	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
599758	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
599759	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	PF000338	PowerFuse	S-1308 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
599760	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	PF000338	PowerFuse	S-1308 POT	Disconnect Powerfuse Inspection	General Comments	ok	
599761	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
599762	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
599763	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
599764	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
599765	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
599766	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Operations A Ø	0	
599767	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps A Ø	0.0	
599768	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
599769	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
599770	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Follow-up Action Required?	n	
599771	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
599772	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
599773	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
599774	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
599775	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
599776	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
599777	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
599778	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
599779	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
599780	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	PF000335	PowerFuse	S-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
599781	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
599782	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	General Comments	y	
599783	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
599784	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Num Operations Last 9 Months	9	
599785	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
599786	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
599787	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
599788	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	General Comments	OK	
599789	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
599790	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
599791	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Foundation Condition	Good	
599792	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
599793	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
599794	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Operations A Ø	0	
599795	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Operations B Ø	0	
599796	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
599797	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
599798	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	LTCC000749	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
599799	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	9 Months Operations	11	
599800	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
599801	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
599802	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
599803	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
599804	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
599805	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
599806	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
599807	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Operations B Ø	0	
599808	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Operations C Ø	0	
599809	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
599810	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
599811	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
599812	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Patrol Inspection	General Comments		
599813	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
599814	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	LTCC000749	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
599815	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	General Comments		
599816	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
599817	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
599818	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
599819	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
599820	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
599821	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
599822	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
599823	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
599824	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Amps A Ø	223.0	
599825	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
599826	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Equipment Properly Labeled?	y	
599827	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.31	%
599828	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.31	%
599829	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps A Ø	60.0	
599830	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps B Ø	48.0	
599831	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps C Ø	38.0	
599832	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
599833	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
599834	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
599835	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
599836	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
599837	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	BCH001238	Charger	451-Battery Charger	Battery Charger Patrol Insp	General Comments		
599838	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	General Comments		
599839	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Patrol Inspection	General Comments		
599840	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Follow-up Action Required?	n	
599841	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
599842	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Patrol Inspection	General Comments		
599843	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	General Comments		
599844	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
599845	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
599846	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
599847	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Maintenance Operations	0	
599848	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Operations Counter AF	795	
599849	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Operations Counter AL	794	
599850	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Switching Operations	0	
599851	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
599852	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
599853	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
599854	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
599855	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps A Ø	0.0	
599856	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	323	
599857	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	0	
599858	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
599859	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
599860	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
599861	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Cabinet Paint Condition	Good	
599862	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
599863	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
599864	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
599865	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Bushings Connection/Risers	Good	
599866	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
599867	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
599868	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	5.86	
599869	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	5.86	
599870	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	9 Months Operations	0	
599871	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Bushing Condition	Good	
599872	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
599873	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Accumulated Fault Duty B Ph AM	14.45	%
599874	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Amps C Ø	110.0	
599875	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Amps B Ø	110.0	
599876	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Maintenance Operations	0	
599877	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	General Comments		
599878	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Patrol Inspection	General Comments		
599879	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Amps A Ø	100.0	
599880	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Accumulated Fault Duty C Ph V	2.85	%
599881	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
599882	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Follow-up Action Required?	n	
599883	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Patrol Inspection	Follow-up Action Required?	n	
599884	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Accumulated Fault Duty A Ph AM	12.05	%
599885	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	9 Months Operations	0	
599886	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
599887	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	7L	
599888	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	2R	
599889	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	10L	
599890	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
599891	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
599892	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
599893	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
599894	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
599895	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
599896	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Accumulated Fault Duty B Ph V	2.14	%
599897	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Accumulated Fault Duty A Ph V	2.14	%
599898	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	9 Month Operations	2	
599899	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Follow-up Action Required?	n	
599900	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
599901	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
599902	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
599903	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps B Ø Max	0.0	
599904	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps B Ø	0.0	
599905	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
599906	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
599907	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
599908	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	General Comments		
599909	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
599910	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
599911	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
599912	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
599913	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
599914	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	General Comments		
599915	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Patrol Inspection	General Comments		
599916	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps A Ø Max	0.0	
599917	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps A Ø	0.0	
599918	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Accumulated Fault Duty C Ph AM	1.12	%
599919	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Accumulated Fault Duty B Ph AM	1.12	%
599920	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Follow-up Action Required?	n	
599921	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Patrol Inspection	Follow-up Action Required?	n	
599922	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations Ground	0	
599923	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations C Ø	0	
599924	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations B Ø	0	
599925	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations A Ø	0	
599926	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
599927	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
599928	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
599929	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
599930	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
599931	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
599932	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
599933	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
599934	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
599935	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
599936	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
599937	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
599938	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Accumulated Fault Duty A Ph AM	1.12	%
599939	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	9 Months Operations	0	
599940	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
599941	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
599942	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
599943	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
599944	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
599945	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
599946	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
599947	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
599948	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
599949	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
599950	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
599951	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
599952	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
599953	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
599954	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	9 Months Operations	6	
599955	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
599956	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
599957	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	80	°C
599958	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
599959	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
599960	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
599961	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps A Ø	0.0	
599962	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps A Ø Max	0.0	
599963	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps B Ø	0.0	
599964	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
599965	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
599966	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
599967	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
599968	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
599969	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	9 Month Operations	5	
599970	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Accumulated Fault Duty A Ph V	23.12	%
599971	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Accumulated Fault Duty B Ph V	22.32	%
599972	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Accumulated Fault Duty C Ph V	18.33	%
599973	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	9 Month Operations	3	
599974	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Switching Operations	0	
599975	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.31	%
599976	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Operations Ground	0	
599977	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Patrol Inspection	Follow-up Action Required?	n	
599978	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Follow-up Action Required?	n	
599979	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
599980	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
599981	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
599982	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
599983	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
599984	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Operations Counter AL	785	
599985	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Operations Counter AF	785	
599986	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Maintenance Operations	0	
599987	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	General Comments		
599988	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
599989	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	60	°C
599990	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	65	°C
599991	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
599992	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
599993	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
599994	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
599995	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	General Comments		
599996	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
599997	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
599998	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
599999	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
600000	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
600001	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
600002	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
600003	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
600004	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
600005	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
600006	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
600007	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
600008	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations Ground	0	
600009	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations C Ø	0	
600010	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations B Ø	0	
600011	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations A Ø	0	
600012	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
600013	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
600014	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
600015	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
600016	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	9 Month Operations	1	
600017	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Accumulated Fault Duty A Ph V	.33	%
600018	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Accumulated Fault Duty B Ph V	.33	%
600019	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
600020	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
600021	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
600022	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Accumulated Fault Duty C Ph V	.33	%
600023	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Amps A Ø	20.0	
600024	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Amps B Ø	21.0	
600025	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Amps C Ø	20.0	
600026	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Bushing Condition	Good	
600027	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Bushings Connection/Risers	Good	
600028	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
600029	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	General Comments		
600030	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
600031	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
600032	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
600033	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.0	VDC
600034	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.0	VDC
600035	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.700	millivolts
600036	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
600037	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
600038	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
600039	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	General Comments		
600040	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	General Comments		
600041	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
600042	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Unknown Operations	0	
600043	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
600044	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
600045	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
600046	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC As Found Counter	1580	
600047	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC As Left Counter	1580	
600048	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
600049	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC Current Tap Position	6L	
600050	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC Max Tap Position	3L	
600051	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC Min Tap Position	9L	
600052	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
600053	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
600054	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	22	°C
600055	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	31	°C
600056	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC Operations Since Last Insp	287	
600057	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
600058	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
600059	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
600060	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
600061	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
600062	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
600063	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
600064	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	LTC Totalizer Reading	15024.00	kw
600065	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
600066	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	General Comments		
600067	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	General Comments		
600068	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
600069	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
600070	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
600071	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
600072	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
600073	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
600074	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
600075	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
600076	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
600077	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
600078	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	General Comments		
600079	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
600080	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
600081	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
600082	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
600083	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
600084	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
600085	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Foundation Condition	Good	
600086	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
600087	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
600088	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
600089	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
600090	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Unknown Operations	0	
600091	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Switching Operations	1	
600092	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
600093	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
600094	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
600095	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
600096	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
600097	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
600098	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
600099	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	General Comments		
600100	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	General Comments		
600101	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
600102	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	LTC Totalizer Reading	4452.48	kw
600103	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
600104	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
600105	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	Oil Temp Max	35	°C
600106	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	Oil Temp Present	25	°C
600107	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
600108	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
600109	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
600110	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
600111	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations B Ø	0	
600112	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
600113	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
600114	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
600115	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
600116	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
600117	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
600118	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
600119	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
600120	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
600121	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
600122	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
600123	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
600124	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	General Comments	ok	
600125	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
600126	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
600127	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
600128	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations A Ø	0	
600129	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
600130	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
600131	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
600132	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
600133	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
600134	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
600135	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	General Comments		
600136	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
600137	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
600138	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
600139	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
600140	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
600141	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
600142	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Foundation Condition	Good	
600143	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
600144	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
600145	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
600146	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
600147	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
600148	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
600149	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
600150	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
600151	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
600152	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
600153	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps C Ø Max	61.0	
600154	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps C Ø	55.0	
600155	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Cabinet Paint Condition	Good	
600156	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Equipment Properly Labeled?	y	
600157	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
600158	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
600159	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
600160	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
600161	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
600162	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
600163	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
600164	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Fault Operations A Ø	0	
600165	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Fault Operations B Ø	0	
600166	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Patrol Inspection	General Comments		
600167	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Follow-up Action Required?	n	
600168	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Fault Operations C Ø	0	
600169	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
600170	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
600171	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Fault Operations Ground	0	
600172	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Follow-up Action Required?	n	
600173	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Follow-up Action Required?	n	
600174	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Foundation Condition	Good	
600175	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	General Comments	ok	
600176	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	General Comments	ok	
600177	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Grounds in Place?	y	
600178	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Heaters (All) Functioning?	y	
600179	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Maintenance Operations	0	
600180	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Moisture and Leak Free?	y	
600181	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Operations Counter AF	214	
600182	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Operations Counter AL	214	
600183	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
600184	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Switching Operations	0	
600185	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Tank Paint Condition	Good	
600186	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Unknown Operations	0	
600187	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	40	°C
600188	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	40	°C
600189	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
600190	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
600191	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
600192	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
600193	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
600194	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
600195	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
600196	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
600197	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
600198	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
600199	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
600200	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
600201	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
600202	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
600203	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
600204	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
600205	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
600206	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
600207	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
600208	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
600209	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
600210	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
600211	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
600212	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	Follow-up Action Required?	n	
600213	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	General Comments		
600214	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	Follow-up Action Required?	n	
600215	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	All Connections OK?	y	
600216	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
600217	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
600218	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
600219	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
600220	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
600221	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
600222	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
600223	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Positive DC Ground	23.0	VDC
600224	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Negative DC Ground	22.0	VDC
600225	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	General Comments		
600226	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
600227	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
600228	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
600229	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
600230	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
600231	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
600232	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Tank Leaks	None	
600233	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
600234	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
600235	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
600236	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
600237	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
600238	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Operations Counter AL	365	
600239	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
600240	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
600241	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
600242	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
600243	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Switching Operations	0	
600244	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Operations Counter AL	881	
600245	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Operations Counter AF	881	
600246	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Maintenance Operations	0	
600247	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	General Comments		
600248	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Patrol Inspection	General Comments		
600249	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Follow-up Action Required?	n	
600250	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
600251	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	9 Month Operations	0	
600252	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Accumulated Fault Duty A Ph V	.80	%
600253	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Accumulated Fault Duty B Ph V	.80	%
600254	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Accumulated Fault Duty C Ph V	.80	%
600255	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Amps A Ø	50.0	
600256	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Amps B Ø	52.0	
600257	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Amps C Ø	50.0	
600258	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Regulator As Left Counter	366726	
600259	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
600260	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
600261	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
600262	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
600263	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
600264	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
600265	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
600266	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
600267	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	General Comments		
600268	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
600269	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
600270	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
600271	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations Ground	0	
600272	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations C Ø	0	
600273	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations B Ø	0	
600274	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations A Ø	0	
600275	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
600276	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
600277	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
600278	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
600279	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps C Ø Max	65.0	
600280	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps C Ø	50.0	
600281	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps B Ø Max	72.0	
600282	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps B Ø	40.0	
600283	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps A Ø Max	70.0	
600284	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps A Ø	50.0	
600285	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
600286	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
600287	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
600288	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Patrol Inspection	Follow-up Action Required?	n	
600289	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Follow-up Action Required?	n	
600290	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Patrol Inspection	General Comments		
600291	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	General Comments		
600292	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Maintenance Operations	0	
600293	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Operations Counter AF	515	
600294	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
600295	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
600296	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
600297	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
600298	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Maintenance Operations	0	
600299	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Operations Counter AF	545	
600300	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Operations Counter AL	545	
600301	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Switching Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
600302	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Unknown Operations	0	
600303	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
600304	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	5.86	
600305	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	VRR Time Delay	30	Seconds
600306	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
600307	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
600308	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
600309	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	LTC Operation Checked?	y	
600310	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
600311	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
600312	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
600313	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
600314	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Reading	1.4418	
600315	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
600316	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
600317	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
600318	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
600319	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
600320	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	9 Months Operations	0	
600321	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	General Comments	ok	
600322	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	General Comments	ok	
600323	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
600324	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
600325	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Maintenance Operations	1	
600326	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
600327	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Unknown Operations	0	
600328	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Switching Operations	0	
600329	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
600330	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
600331	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Unknown Operations	0	
600332	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Switching Operations	0	
600333	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Operations Counter AL	4472	
600334	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Patrol Inspection	General Comments		
600335	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	General Comments		
600336	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Maintenance Operations	0	
600337	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Operations Counter AF	296	
600338	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
600339	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations Ground	0	
600340	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
600341	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
600342	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
600343	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
600344	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
600345	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
600346	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
600347	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
600348	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Unknown Operations	0	
600349	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Vegetation	None	
600350	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
600351	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Amps C Ø	707.0	
600352	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
600353	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
600354	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Amps B Ø	773.0	
600355	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Amps A Ø	818.0	
600356	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	General Comments		
600357	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	3.85	%
600358	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	3.85	%
600359	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	5.78	%
600360	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
600361	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
600362	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
600363	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	9 Month Operations	0	
600364	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	PF000248	PowerFuse	ML-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
600365	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	PF000248	PowerFuse	ML-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	0k	
600366	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	PF000249	PowerFuse	ML-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
600367	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	PF000249	PowerFuse	ML-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	ok	
600368	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
600369	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	Follow-up Action Required?	n	
600370	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
600371	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
600372	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	PF000250	PowerFuse	ML-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
600373	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	PF000250	PowerFuse	ML-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
600374	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	PF000252	PowerFuse	ML-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
600375	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	PF000252	PowerFuse	ML-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
600376	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Oil Temp Present	30	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
600377	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
600378	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
600379	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
600380	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Oil Temp Max	38	°C
600381	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1550	psi
600382	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
600383	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
600384	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
600385	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
600386	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
600387	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
600388	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
600389	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations A Ø	0	
600390	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations B Ø	0	
600391	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations C Ø	0	
600392	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations Ground	0	
600393	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Patrol Inspection	Follow-up Action Required?	n	
600394	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Follow-up Action Required?	n	
600395	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Patrol Inspection	General Comments		
600396	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	General Comments		
600397	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
600398	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
600399	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
600400	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
600401	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
600402	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
600403	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Maintenance Operations	0	
600404	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Operations Counter AF	230	
600405	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Operations Counter AL	230	
600406	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
600407	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Switching Operations	0	
600408	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Unknown Operations	0	
600409	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
600410	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
600411	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
600412	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
600413	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
600414	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Unknown Operations	0	
600415	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Winding Temp Present	31	°C
600416	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Winding Temp Max	41	°C
600417	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
600418	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
600419	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
600420	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
600421	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
600422	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
600423	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
600424	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
600425	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Totalizer Meter Reading	.6260	
600426	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
600427	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AF	158	
600428	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AL	158	
600429	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
600430	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Switching Operations	0	
600431	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
600432	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
600433	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Operations Counter AL	515	
600434	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Switching Operations	0	
600435	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Operations Counter AF	365	
600436	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
600437	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
600438	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Unknown Operations	1	
600439	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
600440	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
600441	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
600442	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
600443	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Maintenance Operations	0	
600444	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	General Comments		
600445	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Patrol Inspection	General Comments		
600446	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	9 Months Operations	0	
600447	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Switching Operations	0	
600448	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Operations Counter AL	549	
600449	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Operations Counter AF	549	
600450	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Maintenance Operations	0	
600451	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
600452	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Patrol Inspection	General Comments		
600453	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Follow-up Action Required?	n	
600454	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Patrol Inspection	Follow-up Action Required?	n	
600455	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations Ground	0	
600456	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations C Ø	0	
600457	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations B Ø	0	
600458	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
600459	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
600460	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
600461	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations A Ø	0	
600462	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
600463	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	9 Months Operations	7	
600464	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC As Left Counter	90681	
600465	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC As Found Counter	90681	
600466	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
600467	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	General Comments		
600468	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC As Found Counter	74704	
600469	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC As Left Counter	74704	
600470	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
600471	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
600472	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
600473	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
600474	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
600475	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	7	
600476	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Current Tap Position	5L	
600477	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Max Tap Position	4L	
600478	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Min Tap Position	7L	
600479	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	83	
600480	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
600481	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Switching Operations	0	
600482	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Operations Counter AL	337	
600483	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Operations Counter AF	337	
600484	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Maintenance Operations	0	
600485	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	General Comments		
600486	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
600487	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
600488	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
600489	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	163	
600490	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	163	
600491	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
600492	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
600493	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
600494	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
600495	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Maintenance Operations	0	
600496	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
600497	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
600498	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	General Comments		
600499	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Patrol Inspection	General Comments		
600500	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	LTC Totalizer Reading	4613.76	kw
600501	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
600502	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
600503	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
600504	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	General Comments		
600505	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
600506	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
600507	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
600508	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
600509	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
600510	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	454	
600511	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Maintenance Operations	0	
600512	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	General Comments		
600513	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
600514	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
600515	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Patrol Inspection	General Comments		
600516	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Follow-up Action Required?	n	
600517	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Patrol Inspection	Follow-up Action Required?	n	
600518	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations Ground	0	
600519	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations C Ø	0	
600520	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
600521	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
600522	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
600523	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
600524	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
600525	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
600526	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
600527	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
600528	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Patrol Inspection	Equipment Properly Labeled?	y	
600529	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations B Ø	0	
600530	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations A Ø	0	
600531	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
600532	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
600533	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
600534	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Patrol Inspection	Follow-up Action Required?	n	
600535	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Operations Ground	0	
600536	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Operations C Ø	0	
600537	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Operations B Ø	0	
600538	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Operations A Ø	0	
600539	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
600540	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
600541	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
600542	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
600543	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps C Ø Max	0.0	
600544	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps C Ø	0.0	
600545	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps B Ø Max	0.0	
600546	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps B Ø	0.0	
600547	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps A Ø Max	0.0	
600548	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps A Ø	0.0	
600549	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
600550	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
600551	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Unknown Operations	0	
600552	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
600553	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps C Ø Max	275.0	
600554	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps C Ø	85.0	
600555	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps B Ø Max	150.0	
600556	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps B Ø	60.0	
600557	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps A Ø Max	210.0	
600558	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps A Ø	80.0	
600559	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Accumulated Fault Duty C Ph AM	1.11	%
600560	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Accumulated Fault Duty B Ph AM	1.11	%
600561	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
600562	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
600563	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
600564	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
600565	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Accumulated Fault Duty A Ph V	5.58	%
600566	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Unknown Operations	0	
600567	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations Ground	0	
600568	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
600569	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
600570	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
600571	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
600572	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
600573	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
600574	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
600575	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
600576	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
600577	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
600578	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10.0	
600579	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
600580	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	4.84	%
600581	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	6.92	%
600582	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	4.84	%
600583	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	14	
600584	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Operations Counter AL	399	
600585	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
600586	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
600587	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
600588	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	General Comments	ok	
600589	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	ok	
600590	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
600591	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
600592	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
600593	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
600594	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
600595	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
600596	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Foundation Condition	Good	
600597	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
600598	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
600599	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
600600	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
600601	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
600602	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
600603	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
600604	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LTCC000331	LTCControl	S-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
600605	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LTCC000331	LTCControl	S-TRANS 1	LTC Control Insp	General Comments		
600606	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LTCC000331	LTCControl	S-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
600607	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LTCC000330	LTCControl	S-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
600608	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
600609	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LTCC000330	LTCControl	S-TRANS 2	LTC Control Insp	General Comments		
600610	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0384	
600611	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	All Connections OK?	y	
600612	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	Follow-up Action Required?	n	
600613	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	General Comments	OK	
600614	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Operations Counter AF	399	
600615	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
600616	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
600617	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
600618	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
600619	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
600620	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
600621	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
600622	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
600623	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	General Comments		
600624	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
600625	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	General Comments		
600626	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Patrol Inspection	General Comments		
600627	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
600628	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
600629	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
600630	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
600631	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
600632	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
600633	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
600634	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
600635	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Follow-up Action Required?	n	
600636	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Patrol Inspection	Follow-up Action Required?	n	
600637	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations Ground	0	
600638	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations C Ø	0	
600639	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations B Ø	0	
600640	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations A Ø	0	
600641	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
600642	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
600643	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
600644	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
600645	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
600646	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
600647	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
600648	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
600649	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
600650	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
600651	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
600652	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
600653	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
600654	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
600655	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
600656	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
600657	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Unknown Operations	0	
600658	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
600659	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
600660	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
600661	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
600662	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
600663	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
600664	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
600665	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
600666	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1011	
600667	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1011	
600668	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
600669	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
600670	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
600671	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
600672	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
600673	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
600674	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Switching Operations	0	
600675	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
600676	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
600677	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
600678	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Switching Operations	0	
600679	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
600680	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	LTC As Left Counter	5704	
600681	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	LTC As Found Counter	5698	
600682	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Mechanism Patrol Inspection	General Comments	OK	
600683	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
600684	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	General Comments		
600685	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	General Comments	OK	
600686	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
600687	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	Follow-up Action Required?	n	
600688	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations C Ø	0	
600689	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
600690	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
600691	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
600692	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
600693	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps C Ø Max	200.0	
600694	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps C Ø	200.0	
600695	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
600696	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
600697	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps B Ø Max	200.0	
600698	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
600699	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
600700	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps B Ø	200.0	
600701	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps A Ø Max	200.0	
600702	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps A Ø	200.0	
600703	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
600704	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
600705	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
600706	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	VRR Time Delay	30	Seconds
600707	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
600708	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
600709	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
600710	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
600711	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	LTC Operation Checked?	y	
600712	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	General Comments	OK	
600713	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	Follow-up Action Required?	n	
600714	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	All Connections OK?	y	
600715	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
600716	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
600717	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Unknown Operations	0	
600718	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Switching Operations	0	
600719	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Operations Counter AL	1	
600720	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Operations Counter AF	1	
600721	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Amps A Ø	400.0	
600722	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Amps B Ø	420.0	
600723	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
600724	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
600725	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
600726	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
600727	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	25	°C
600728	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	25	°C
600729	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
600730	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
600731	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
600732	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
600733	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
600734	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
600735	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
600736	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
600737	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps B Ø Max	95.0	
600738	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps B Ø	50.0	
600739	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps A Ø Max	109.0	
600740	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps A Ø	60.0	
600741	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Accumulated Fault Duty C Ph AM	6.11	%
600742	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Accumulated Fault Duty B Ph AM	8.15	%
600743	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Accumulated Fault Duty A Ph AM	6.11	%
600744	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
600745	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
600746	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	Totalizer Meter Reading	.4638	
600747	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
600748	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
600749	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Amps A Ø	.8	
600750	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Amps B Ø	1.1	
600751	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Amps C Ø	.3	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
600752	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
600753	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	9 Month Operations	48	
600754	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	9 Months Operations	0	
600755	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
600756	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
600757	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
600758	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
600759	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	General Comments		
600760	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
600761	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Operations Counter	68	
600762	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
600763	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
600764	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
600765	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
600766	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
600767	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
600768	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Operations Counter AF	4472	
600769	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Maintenance Operations	0	
600770	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
600771	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
600772	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	General Comments		
600773	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Patrol Inspection	General Comments		
600774	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
600775	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	26.00	
600776	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Follow-up Action Required?	n	
600777	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Patrol Inspection	Follow-up Action Required?	n	
600778	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
600779	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	General Comments		
600780	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
600781	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
600782	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
600783	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
600784	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations Ground	0	
600785	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
600786	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
600787	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
600788	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	LTC Operations Since Last Insp	410	
600789	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
600790	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	LTC Max Tap Position	2R	
600791	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Follow-up Action Required?	n	
600792	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Patrol Inspection	Follow-up Action Required?	n	
600793	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Operations Ground	0	
600794	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	LTC Current Tap Position	1R	
600795	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Operations C Ø	0	
600796	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Operations B Ø	0	
600797	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Amps A Ø	288.0	
600798	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
600799	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
600800	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
600801	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Clear of Trash?	y	
600802	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
600803	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
600804	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
600805	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	BAT001147	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
600806	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
600807	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
600808	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Tank Leaks	None	
600809	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
600810	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
600811	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Regulator As Left Counter	162958	
600812	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
600813	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
600814	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
600815	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
600816	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Accumulated Fault Duty C Ph AM	9.64	%
600817	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Accumulated Fault Duty B Ph AM	7.23	%
600818	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
600819	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	General Comments		
600820	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Vegetation	None	
600821	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Accumulated Fault Duty A Ph AM	8.43	%
600822	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	9 Months Operations	4	
600823	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
600824	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
600825	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
600826	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
600827	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
600828	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Clear of Trash?	y	
600829	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
600830	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
600831	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
600832	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
600833	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	General Comments		
600834	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
600835	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Amps B Ø	288.0	
600836	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Amps C Ø	250.0	
600837	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
600838	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
600839	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
600840	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
600841	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
600842	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
600843	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
600844	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
600845	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
600846	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Unknown Operations	0	
600847	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Switching Operations	0	
600848	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Operations Counter AL	400	
600849	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Operations Counter AF	400	
600850	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
600851	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
600852	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
600853	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
600854	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
600855	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
600856	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
600857	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
600858	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
600859	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
600860	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
600861	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Amps C Ø	360.0	
600862	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
600863	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
600864	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	9	
600865	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
600866	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
600867	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations A Ø	0	
600868	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	23.10	%
600869	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	23.10	%
600870	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	23.10	%
600871	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
600872	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
600873	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
600874	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
600875	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
600876	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
600877	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
600878	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
600879	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
600880	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
600881	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
600882	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
600883	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
600884	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	25.0	VDC
600885	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	22.0	VDC
600886	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
600887	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
600888	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
600889	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
600890	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
600891	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations B Ø	0	
600892	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations C Ø	0	
600893	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	BAT001147	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
600894	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	BAT001147	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
600895	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
600896	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	BAT001147	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
600897	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	BAT001147	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
600898	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	BAT001147	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	OK	
600899	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	BAT001147	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
600900	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	BAT001147	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
600901	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	BAT001147	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
600902	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	BAT001147	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
600903	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	BAT001147	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
600904	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	BAT001147	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
600905	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	BAT001147	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	56	°F
600906	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	35	°C
600907	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
600908	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
600909	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
600910	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
600911	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
600912	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
600913	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
600914	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	General Comments		
600915	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Vegetation	None	
600916	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Operations Counter AL	382	
600917	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Switching Operations	0	
600918	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Unknown Operations	0	
600919	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Switching Operations	0	
600920	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Unknown Operations	0	
600921	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
600922	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
600923	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
600924	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
600925	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Unknown Operations	2	
600926	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
600927	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
600928	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
600929	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
600930	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
600931	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
600932	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
600933	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
600934	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	Follow-up Action Required?	n	
600935	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	9 Months Operations	12	
600936	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Accumulated Fault Duty A Ph AM	3.35	%
600937	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	General Comments		
600938	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
600939	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Accumulated Fault Duty B Ph AM	5.59	%
600940	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
600941	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps A Ø	50.0	
600942	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Insulators In Good Condition?	n	
600943	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps A Ø Max	104.0	
600944	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps B Ø	50.0	
600945	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
600946	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
600947	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
600948	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1647	
600949	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1647	
600950	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
600951	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	30	°C
600952	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	30	°C
600953	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	22	°C
600954	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	22	°C
600955	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	15	°C
600956	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	15	°C
600957	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
600958	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
600959	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
600960	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
600961	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
600962	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	General Comments	2 insulators on high side fuses has a chipped skirt.	
600963	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
600964	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
600965	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
600966	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Clear of Trash?	y	
600967	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
600968	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
600969	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
600970	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
600971	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
600972	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
600973	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	General Comments		
600974	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.2596	
600975	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps C Ø	60.0	
600976	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
600977	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
600978	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
600979	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
600980	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
600981	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
600982	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
600983	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
600984	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
600985	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
600986	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	Follow-up Action Required?	n	
600987	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
600988	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
600989	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	General Comments		
600990	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps C Ø Max	70.0	
600991	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
600992	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	General Comments		
600993	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
600994	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	LTC Totalizer Reading	2363.04	kw
600995	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
600996	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
600997	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	Oil Temp Max	26	°C
600998	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	Oil Temp Present	26	°C
600999	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
601000	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
601001	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
601002	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
601003	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
601004	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
601005	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	Totalizer Meter Multiplier	3600	
601006	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	Totalizer Meter Reading	.6564	
601007	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
601008	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
601009	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
601010	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
601011	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
601012	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
601013	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
601014	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
601015	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
601016	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
601017	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	General Comments	Rusty barbed wire but still ok	
601018	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
601019	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
601020	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations A Ø	0	
601021	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations B Ø	0	
601022	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations C Ø	0	
601023	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Patrol Inspection	General Comments		
601024	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations Ground	0	
601025	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	General Comments		
601026	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Patrol Inspection	Follow-up Action Required?	n	
601027	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Follow-up Action Required?	n	
601028	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Patrol Inspection	General Comments		
601029	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	General Comments		
601030	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Maintenance Operations	0	
601031	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Operations Counter AF	382	
601032	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Maintenance Operations	0	
601033	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Operations Counter AF	913	
601034	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Operations Counter AL	913	
601035	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Ambient Temp	66	°F
601036	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
601037	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Clear of Trash?	y	
601038	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
601039	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
601040	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
601041	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
601042	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
601043	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
601044	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
601045	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
601046	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
601047	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
601048	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
601049	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
601050	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
601051	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
601052	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
601053	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
601054	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
601055	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
601056	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Foundation Condition	Good	
601057	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
601058	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
601059	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
601060	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
601061	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
601062	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
601063	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
601064	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Amps A Ø	0.0	
601065	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Amps B Ø	0.0	
601066	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	All Connections OK?	y	
601067	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	Follow-up Action Required?	n	
601068	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Amps C Ø	0.0	
601069	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Patrol Inspection	Equipment Properly Labeled?	y	
601070	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
601071	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
601072	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
601073	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations A Ø	0	
601074	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations B Ø	0	
601075	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations C Ø	0	
601076	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations Ground	0	
601077	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Patrol Inspection	Follow-up Action Required?	n	
601078	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Follow-up Action Required?	n	
601079	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Patrol Inspection	General Comments		
601080	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
601081	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	General Comments		
601082	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	LTC Operation Checked?	y	
601083	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
601084	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
601085	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
601086	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
601087	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Unknown Operations	0	
601088	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Switching Operations	0	
601089	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Operations Counter AL	831	
601090	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Operations Counter AF	831	
601091	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Maintenance Operations	0	
601092	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	General Comments		
601093	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
601094	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
601095	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
601096	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
601097	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	9 Month Operations	3	
601098	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
601099	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
601100	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
601101	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
601102	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
601103	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	Follow-up Action Required?	n	
601104	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
601105	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
601106	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps B Ø Max	191.0	
601107	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
601108	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
601109	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
601110	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Vegetation	None	
601111	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps B Ø	50.0	
601112	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps A Ø Max	147.0	
601113	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps A Ø	60.0	
601114	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
601115	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
601116	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
601117	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
601118	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
601119	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	PF000343	PowerFuse	S-4KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
601120	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
601121	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
601122	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
601123	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
601124	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
601125	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
601126	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
601127	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
601128	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
601129	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
601130	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
601131	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Oil Temp Present	25	°C
601132	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
601133	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	57	°F
601134	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
601135	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	Oil Temp Present	15	°C
601136	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	Oil Temp Max	20	°C
601137	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
601138	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
601139	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
601140	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	H2 Winding Temp Present	12	°C
601141	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	H2 Winding Temp Max	28	°C
601142	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
601143	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
601144	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
601145	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
601146	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
601147	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Oil Temp Max	30	°C
601148	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
601149	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
601150	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	9 Month Operations	0	
601151	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
601152	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
601153	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
601154	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
601155	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
601156	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
601157	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
601158	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
601159	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
601160	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
601161	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
601162	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
601163	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	General Comments	ok	
601164	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
601165	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
601166	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
601167	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	General Comments		
601168	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
601169	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
601170	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
601171	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
601172	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Patrol Inspection	General Comments		
601173	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
601174	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Trash Emptied?	y	
601175	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
601176	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BCH000984	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
601177	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BCH000984	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
601178	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
601179	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	General Comments		
601180	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Maintenance Operations	0	
601181	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Operations Counter AF	355	
601182	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Operations Counter AL	355	
601183	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Switching Operations	0	
601184	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
601185	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC As Left Counter	6167	
601186	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
601187	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
601188	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
601189	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
601190	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	229	
601191	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
601192	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Unknown Operations	0	
601193	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
601194	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
601195	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Patrol Inspection	General Comments		
601196	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
601197	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Amps A Ø	205.0	
601198	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
601199	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
601200	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
601201	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	9 Month Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
601202	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations C Ø	0	
601203	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
601204	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Switching Operations	0	
601205	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Operations Counter AL	296	
601206	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Follow-up Action Required?	n	
601207	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
601208	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations Ground	0	
601209	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Switching Operations	0	
601210	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
601211	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Unknown Operations	1	
601212	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Patrol Inspection	Follow-up Action Required?	n	
601213	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Follow-up Action Required?	n	
601214	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Patrol Inspection	General Comments		
601215	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	General Comments		
601216	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Maintenance Operations	0	
601217	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Operations Counter AF	394	
601218	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Operations Counter AL	394	
601219	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
601220	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations Ground	0	
601221	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Switching Operations	0	
601222	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations C Ø	0	
601223	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations B Ø	0	
601224	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations A Ø	0	
601225	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	9 Months Operations	2	
601226	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Accumulated Fault Duty A Ph AM	3.61	%
601227	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	General Comments		
601228	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
601229	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
601230	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	LTC Totalizer Reading	3072.96	kw
601231	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LTCC000330	LTCControl	S-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
601232	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
601233	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.7104	
601234	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
601235	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Accumulated Fault Duty B Ph AM	2.41	%
601236	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
601237	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
601238	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Bushings Connection/Risers	Good	
601239	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Bushing Condition	Good	
601240	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Amps C Ø	38.0	
601241	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Amps B Ø	43.0	
601242	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Amps A Ø	38.0	
601243	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
601244	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
601245	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
601246	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
601247	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
601248	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
601249	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
601250	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Accumulated Fault Duty C Ph V	.33	%
601251	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Accumulated Fault Duty B Ph V	.66	%
601252	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Accumulated Fault Duty A Ph V	.33	%
601253	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	9 Month Operations	2	
601254	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
601255	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
601256	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
601257	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	General Comments	ok	
601258	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	General Comments	ok	
601259	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
601260	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
601261	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
601262	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	General Comments		
601263	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
601264	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
601265	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
601266	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
601267	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
601268	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
601269	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
601270	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
601271	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
601272	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
601273	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
601274	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Bushing Condition	Good	
601275	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations Ground	0	
601276	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
601277	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Follow-up Action Required?	n	
601278	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC As Found Counter	6167	
601279	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Amps C Ø	178.0	
601280	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Amps B Ø	185.0	
601281	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BCH000984	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	General Comments	ok	
601282	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BCH000984	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
601283	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BCH000984	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
601284	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Floor Swept?	y	
601285	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
601286	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	Oil Temp Present	30	°C
601287	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	Oil Temp Max	40	°C
601288	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
601289	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
601290	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	General Comments		
601291	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
601292	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
601293	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
601294	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Maintenance Operations	1	
601295	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
601296	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AF	164	
601297	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AL	164	
601298	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
601299	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
601300	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Panels Dusted?	y	
601301	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
601302	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
601303	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
601304	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
601305	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	56	°F
601306	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
601307	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
601308	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	General Comments	OK	
601309	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	General Comments	OK	
601310	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
601311	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
601312	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations A Ø	0	
601313	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
601314	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
601315	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
601316	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
601317	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Operations C Ø	0	
601318	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Operations Ground	0	
601319	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
601320	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
601321	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	61	°F
601322	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
601323	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	9 Months Operations	0	
601324	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
601325	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
601326	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
601327	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps A Ø	70.0	
601328	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
601329	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
601330	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
601331	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations B Ø	0	
601332	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations C Ø	0	
601333	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations Ground	0	
601334	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Patrol Inspection	Follow-up Action Required?	n	
601335	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Follow-up Action Required?	n	
601336	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
601337	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
601338	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
601339	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
601340	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
601341	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
601342	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
601343	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
601344	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
601345	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
601346	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
601347	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
601348	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
601349	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
601350	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
601351	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps A Ø Max	70.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
601352	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps B Ø	60.0	
601353	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps B Ø Max	60.0	
601354	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
601355	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
601356	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
601357	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
601358	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps C Ø	70.0	
601359	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
601360	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
601361	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
601362	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
601363	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
601364	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
601365	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
601366	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Accumulated Fault Duty C Ph AM	1.20	%
601367	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Amps A Ø	150.0	
601368	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Amps B Ø	150.0	
601369	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Amps C Ø	150.0	
601370	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
601371	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
601372	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
601373	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
601374	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
601375	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
601376	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
601377	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
601378	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
601379	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
601380	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
601381	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
601382	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
601383	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	General Comments		
601384	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
601385	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
601386	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
601387	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
601388	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	General Comments		
601389	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
601390	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
601391	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
601392	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
601393	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
601394	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
601395	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
601396	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
601397	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
601398	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
601399	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Operations A Ø	0	
601400	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Operations B Ø	0	
601401	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
601402	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
601403	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
601404	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
601405	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
601406	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
601407	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.1	VDC
601408	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	26.4	VDC
601409	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
601410	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
601411	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
601412	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
601413	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
601414	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
601415	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
601416	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
601417	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
601418	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
601419	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
601420	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
601421	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
601422	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
601423	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
601424	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Unknown Operations	0	
601425	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
601426	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
601427	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	General Comments	OK	
601428	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
601429	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
601430	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
601431	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations Ground	0	
601432	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Patrol Inspection	Follow-up Action Required?	n	
601433	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Follow-up Action Required?	n	
601434	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Patrol Inspection	General Comments		
601435	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Cabinet Paint Condition	Good	
601436	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
601437	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
601438	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
601439	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Equipment Properly Labeled?	y	
601440	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
601441	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
601442	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
601443	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Operations A Ø	0	
601444	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Operations B Ø	0	
601445	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
601446	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
601447	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
601448	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
601449	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	General Comments		
601450	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
601451	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
601452	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
601453	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Moisture and Leak Free?	y	
601454	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
601455	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
601456	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
601457	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
601458	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
601459	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
601460	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
601461	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	426.24	kw
601462	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
601463	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
601464	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
601465	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
601466	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
601467	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	General Comments		
601468	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	General Comments		
601469	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
601470	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
601471	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
601472	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
601473	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
601474	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
601475	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
601476	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
601477	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	PF000340	PowerFuse	S-1496 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
601478	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	PF000340	PowerFuse	S-1496 POT	Disconnect Powerfuse Inspection	General Comments	ok	
601479	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Operations C Ø	0	
601480	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Operations Ground	0	
601481	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Follow-up Action Required?	n	
601482	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Follow-up Action Required?	n	
601483	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Foundation Condition	Good	
601484	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Operations Counter AF	174	
601485	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Operations Counter AL	174	
601486	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
601487	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Switching Operations	0	
601488	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Tank Paint Condition	Good	
601489	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Unknown Operations	0	
601490	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	General Comments		
601491	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	General Comments		
601492	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Grounds in Place?	y	
601493	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Heaters (All) Functioning?	y	
601494	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
601495	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
601496	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
601497	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
601498	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
601499	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
601500	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	General Comments		
601501	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
601502	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
601503	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
601504	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
601505	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
601506	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
601507	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
601508	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
601509	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	9 Months Operations	0	
601510	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
601511	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations A Ø	0	
601512	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations B Ø	0	
601513	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
601514	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Clear of Trash?	y	
601515	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	9 Month Operations	3	
601516	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
601517	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
601518	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
601519	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	PF000251	PowerFuse	ML-12KV TR 6 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
601520	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Amps A Ø	135.0	
601521	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Amps B Ø	120.0	
601522	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Amps C Ø	118.0	
601523	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Bushing Condition	Good	
601524	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Bushings Connection/Risers	Good	
601525	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	PF000251	PowerFuse	ML-12KV TR 6 POT	Disconnect Powerfuse Inspection	General Comments	ok	
601526	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
601527	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations A Ø	0	
601528	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations B Ø	0	
601529	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations C Ø	0	
601530	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations Ground	0	
601531	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
601532	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
601533	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
601534	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
601535	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
601536	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
601537	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
601538	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
601539	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
601540	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	
601541	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.38	%
601542	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	3.46	%
601543	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Patrol Inspection	Follow-up Action Required?	n	
601544	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
601545	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.69	%
601546	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
601547	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Ambient Temp	57	°F
601548	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
601549	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
601550	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
601551	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Tank Leaks	None	
601552	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
601553	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
601554	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Regulator As Left Counter	81000	
601555	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
601556	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
601557	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
601558	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
601559	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations C Ø	0	
601560	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
601561	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Panels Dusted?	y	
601562	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
601563	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations A Ø	0	
601564	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
601565	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
601566	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	PF000341	PowerFuse	S-STA SER	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
601567	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	PF000341	PowerFuse	S-STA SER	Disconnect Powerfuse Inspection	General Comments	ok	
601568	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
601569	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Evidence of Insects	None	
601570	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
601571	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Unknown Operations	0	
601572	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
601573	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	9 Months Operations	8	
601574	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Unknown Operations	0	
601575	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Switching Operations	0	
601576	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Operations Counter AL	1118	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
601577	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Operations Counter AF	1118	
601578	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Maintenance Operations	0	
601579	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	General Comments		
601580	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Patrol Inspection	General Comments		
601581	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Follow-up Action Required?	n	
601582	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
601583	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Follow-up Action Required?	n	
601584	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
601585	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	General Comments		
601586	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
601587	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
601588	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Panel Lights OK?	y	
601589	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
601590	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
601591	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
601592	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps A Ø	50.0	
601593	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps A Ø Max	50.0	
601594	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps B Ø	50.0	
601595	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps B Ø Max	50.0	
601596	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps C Ø	50.0	
601597	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
601598	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC As Left Counter	146549	
601599	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC As Found Counter	146544	
601600	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Mechanism Patrol Inspection	General Comments		
601601	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	General Comments		
601602	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps C Ø Max	50.0	
601603	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
601604	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
601605	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
601606	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
601607	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations A Ø	0	
601608	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations B Ø	0	
601609	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations C Ø	0	
601610	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations Ground	0	
601611	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
601612	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	Follow-up Action Required?	n	
601613	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
601614	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	General Comments	OK	
601615	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	General Comments	OK	
601616	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps C Ø Max	200.0	
601617	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
601618	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	9 Months Operations	0	
601619	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Patrol Inspection	Follow-up Action Required?	n	
601620	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BCH001275	Charger	648-Battery Charger	Battery Charger Patrol Insp	General Comments	OK	
601621	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BCH001275	Charger	648-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
601622	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BCH001275	Charger	648-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
601623	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BCH001275	Charger	648-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
601624	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BCH001275	Charger	648-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
601625	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	Oil Temp Present	35	°C
601626	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	Oil Temp Max	40	°C
601627	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
601628	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Maintenance Operations	0	
601629	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Moisture and Leak Free?	y	
601630	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Operations Counter AF	176	
601631	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Operations Counter AL	178	
601632	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
601633	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Switching Operations	3	
601634	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Tank Paint Condition	Good	
601635	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Unknown Operations	0	
601636	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	9 Months Operations	30	
601637	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Accumulated Fault Duty A Ph AM	40.95	%
601638	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Accumulated Fault Duty B Ph AM	57.82	%
601639	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Accumulated Fault Duty C Ph AM	42.16	%
601640	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Amps A Ø	300.0	
601641	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Amps B Ø	300.0	
601642	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
601643	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
601644	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
601645	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC Operations Since Last Insp	891	
601646	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC Min Tap Position	11L	
601647	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
601648	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC Current Tap Position	5L	
601649	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
601650	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
601651	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
601652	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
601653	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Operations Since Last Insp	75	
601654	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
601655	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Min Tap Position	10L	
601656	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Max Tap Position	7L	
601657	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Current Tap Position	9L	
601658	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
601659	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC As Left Counter	13400	
601660	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC As Found Counter	13400	
601661	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	General Comments		
601662	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	General Comments		
601663	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
601664	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	Follow-up Action Required?	n	
601665	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps B Ø Max	260.0	
601666	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps C Ø	50.0	
601667	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
601668	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Vent Fans OK?	y	
601669	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
601670	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
601671	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	General Comments		
601672	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Maintenance Operations	0	
601673	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Operations Counter AF	371	
601674	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps C Ø Max	255.0	
601675	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Amps C Ø	280.0	
601676	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
601677	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
601678	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
601679	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	LTC Totalizer Reading	5639.04	kw
601680	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
601681	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
601682	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
601683	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Operations Counter AL	371	
601684	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
601685	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
601686	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Door Alarms OK?	y	
601687	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
601688	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
601689	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Switching Operations	0	
601690	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
601691	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Follow-up Action Required?	n	
601692	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
601693	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations B Ø	0	
601694	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Patrol Inspection	Follow-up Action Required?	n	
601695	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Amps A Ø	77.0	
601696	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Amps B Ø	68.0	
601697	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Amps C Ø	55.0	
601698	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Bushing Condition	Good	
601699	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Bushings Connection/Risers	Good	
601700	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
601701	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
601702	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
601703	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Cabinet Paint Condition	Good	
601704	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Equipment Properly Labeled?	y	
601705	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
601706	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
601707	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
601708	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Operations A Ø	0	
601709	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Operations B Ø	0	
601710	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Operations C Ø	0	
601711	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations A Ø	0	
601712	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
601713	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Operations Ground	0	
601714	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Follow-up Action Required?	n	
601715	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Follow-up Action Required?	n	
601716	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
601717	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
601718	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps C Ø Max	0.0	
601719	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
601720	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
601721	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
601722	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
601723	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations A Ø	0	
601724	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations B Ø	0	
601725	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations C Ø	0	
601726	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
601727	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Patrol Inspection	Follow-up Action Required?	n	
601728	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Follow-up Action Required?	n	
601729	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Patrol Inspection	General Comments		
601730	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	General Comments		
601731	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Maintenance Operations	0	
601732	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Operations Counter AF	2542	
601733	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Operations Counter AL	2542	
601734	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Switching Operations	0	
601735	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Unknown Operations	0	
601736	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
601737	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
601738	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps C Ø Max	50.0	
601739	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps C Ø	50.0	
601740	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps B Ø Max	50.0	
601741	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps B Ø	50.0	
601742	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps A Ø Max	50.0	
601743	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps A Ø	50.0	
601744	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
601745	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
601746	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
601747	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	9 Months Operations	9	
601748	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
601749	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Foundation Condition	Good	
601750	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	General Comments		
601751	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
601752	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
601753	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
601754	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
601755	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
601756	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
601757	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	VRR Time Delay	30	Seconds
601758	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	PF000343	PowerFuse	S-4KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
601759	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
601760	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Maintenance Operations	0	
601761	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	General Comments		
601762	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Patrol Inspection	General Comments		
601763	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
601764	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Patrol Inspection	General Comments		
601765	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Follow-up Action Required?	n	
601766	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Patrol Inspection	Follow-up Action Required?	n	
601767	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations Ground	0	
601768	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations C Ø	0	
601769	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	9 Months Operations	0	
601770	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
601771	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
601772	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
601773	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps A Ø	0.0	
601774	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps A Ø Max	0.0	
601775	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps B Ø	0.0	
601776	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps B Ø Max	0.0	
601777	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps C Ø	0.0	
601778	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
601779	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
601780	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
601781	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
601782	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
601783	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
601784	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X3 Winding Temp Present	36	°C
601785	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X3 Winding Temp Max	40	°C
601786	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X2 Winding Temp Present	40	°C
601787	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X2 Winding Temp Max	86	°C
601788	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X1 Winding Temp Present	38	°C
601789	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X1 Winding Temp Max	43	°C
601790	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
601791	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
601792	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
601793	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
601794	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Tank Leaks	None	
601795	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
601796	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
601797	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
601798	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
601799	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	Oil Temp Present	32	°C
601800	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	Oil Temp Max	39	°C
601801	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
601802	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
601803	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
601804	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	General Comments	X2 will not reset	
601805	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	General Comments		
601806	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
601807	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
601808	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	Follow-up Action Required?	y	
601809	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
601810	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Fans Operational?	y	
601811	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Fans Condition	Good	
601812	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
601813	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
601814	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
601815	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
601816	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
601817	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
601818	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
601819	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
601820	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	9 Months Operations	0	
601821	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
601822	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
601823	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
601824	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps A Ø	0.0	
601825	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
601826	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Operations B Ø	0	
601827	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Operations C Ø	0	
601828	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Operations Ground	0	
601829	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Follow-up Action Required?	n	
601830	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Follow-up Action Required?	n	
601831	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Foundation Condition	Good	
601832	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	General Comments	OK	
601833	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	General Comments	OK	
601834	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Grounds in Place?	y	
601835	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Heaters (All) Functioning?	y	
601836	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Maintenance Operations	0	
601837	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
601838	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps A Ø Max	0.0	
601839	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps B Ø	0.0	
601840	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	General Comments	R&C	
601841	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Maintenance Operations	0	
601842	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
601843	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
601844	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Operations Counter AF	123	
601845	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Operations Counter AL	123	
601846	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Switching Operations	0	
601847	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Unknown Operations	0	
601848	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
601849	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps B Ø Max	0.0	
601850	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps C Ø	0.0	
601851	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps C Ø Max	0.0	
601852	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
601853	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
601854	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
601855	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
601856	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Operations A Ø	0	
601857	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Operations B Ø	0	
601858	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Operations C Ø	0	
601859	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Operations Ground	0	
601860	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Patrol Inspection	Follow-up Action Required?	n	
601861	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Follow-up Action Required?	n	
601862	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Patrol Inspection	General Comments		
601863	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	General Comments		
601864	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Maintenance Operations	0	
601865	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Operations Counter AF	250	
601866	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Operations Counter AL	250	
601867	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Switching Operations	0	
601868	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Unknown Operations	0	
601869	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
601870	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
601871	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
601872	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
601873	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
601874	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
601875	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
601876	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
601877	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
601878	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
601879	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
601880	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
601881	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
601882	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
601883	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Vegetation	None	
601884	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
601885	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	207.68	kw
601886	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
601887	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Foundation Condition	Good	
601888	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	General Comments		
601889	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
601890	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	General Comments		
601891	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Grounds in Place?	y	
601892	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	General Comments	Oil level low. Made work order to add oil.	
601893	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Heaters (All) Functioning?	y	
601894	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Maintenance Operations	0	
601895	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	General Comments		
601896	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
601897	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
601898	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
601899	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
601900	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
601901	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
601902	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
601903	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
601904	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
601905	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
601906	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
601907	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
601908	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
601909	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
601910	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
601911	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
601912	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
601913	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
601914	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
601915	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
601916	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
601917	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
601918	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
601919	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
601920	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
601921	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	General Comments		
601922	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
601923	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
601924	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
601925	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
601926	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
601927	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
601928	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
601929	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
601930	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
601931	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	PF000339	PowerFuse	S-1372 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
601932	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	PF000339	PowerFuse	S-1372 POT	Disconnect Powerfuse Inspection	General Comments	ok	
601933	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	General Comments		
601934	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Moisture and Leak Free?	y	
601935	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
601936	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
601937	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Operations A Ø	0	
601938	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
601939	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
601940	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
601941	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
601942	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Operations Counter AF	180	
601943	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Operations Counter AL	182	
601944	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
601945	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Switching Operations	3	
601946	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Tank Paint Condition	Good	
601947	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
601948	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
601949	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Unknown Operations	0	
601950	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Num Operations Last 9 Months	165	
601951	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Operations Counter AF	999	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
601952	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Operations Counter AL	999	
601953	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	SF6 Bushing Condition	Good	
601954	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	SF6 Pressure Indicator	good	
601955	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
601956	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Switching Operations	30	
601957	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Tank Paint Condition	Good	
601958	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
601959	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
601960	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
601961	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Operations Counter AL	178	
601962	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Operations Counter AF	178	
601963	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
601964	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Maintenance Operations	0	
601965	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
601966	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Grounds in Place?	y	
601967	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
601968	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	General Comments		
601969	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	General Comments		
601970	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	9 Months Operations	17	
601971	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
601972	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
601973	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
601974	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
601975	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
601976	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
601977	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
601978	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
601979	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
601980	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
601981	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
601982	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
601983	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
601984	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
601985	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
601986	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
601987	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps A Ø	0.0	
601988	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
601989	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	9 Month Operations	3	
601990	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Accumulated Fault Duty A Ph V	68.56	%
601991	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Accumulated Fault Duty B Ph V	74.14	%
601992	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Accumulated Fault Duty C Ph V	74.14	%
601993	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Amps A Ø	158.0	
601994	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Amps B Ø	155.0	
601995	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Amps C Ø	158.0	
601996	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations A Ø	0	
601997	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
601998	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
601999	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
602000	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
602001	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
602002	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Foundation Condition	Good	
602003	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
602004	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
602005	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Oil Temp Max	50	°C
602006	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
602007	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
602008	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
602009	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
602010	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	LTC Totalizer Reading	5345.28	kw
602011	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
602012	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	General Comments		
602013	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	Totalizer Meter Reading	.6402	
602014	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Ambient Temperature	61	°F
602015	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Bushings Connection/Risers	Good	
602016	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
602017	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
602018	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Cabinet Paint Condition	Good	
602019	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Equipment Properly Labeled?	y	
602020	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Fault Operations	0	
602021	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Follow-up Action Required?	n	
602022	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Follow-up Action Required?	n	
602023	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Foundation Condition	Good	
602024	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Gauge(s) Condition	Good	
602025	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	General Comments	ok	
602026	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	General Comments	ok	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
602027	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Grounds in Place?	y	
602028	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Heaters (All) Functioning?	y	
602029	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Maintenance Operations	0	
602030	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
602031	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	General Comments		
602032	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
602033	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
602034	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Follow-up Action Required?	n	
602035	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
602036	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
602037	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
602038	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
602039	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	PF000337	PowerFuse	S-1378 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
602040	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	PF000337	PowerFuse	S-1378 POT	Disconnect Powerfuse Inspection	General Comments	ok	
602041	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
602042	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
602043	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
602044	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Clear of Trash?	y	
602045	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
602046	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
602047	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Moisture and Leak Free?	y	
602048	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
602049	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
602050	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
602051	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
602052	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
602053	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
602054	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
602055	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	General Comments		
602056	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
602057	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Vegetation	None	
602058	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
602059	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
602060	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Amps A Ø	79.0	
602061	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Amps B Ø	82.1	
602062	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Amps C Ø	64.0	
602063	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	General Comments		
602064	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Patrol Inspection	General Comments		
602065	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Patrol Inspection	Equipment Properly Labeled?	y	
602066	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps B Ø	0.0	
602067	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Amps C Ø	81.0	
602068	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
602069	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
602070	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps B Ø Max	0.0	
602071	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
602072	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
602073	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
602074	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
602075	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
602076	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
602077	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
602078	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
602079	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
602080	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
602081	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
602082	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
602083	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Ambient Temp	59	°F
602084	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
602085	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
602086	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Clear of Trash?	y	
602087	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
602088	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
602089	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
602090	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
602091	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
602092	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
602093	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	General Comments		
602094	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
602095	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
602096	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
602097	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
602098	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
602099	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
602100	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
602101	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Vegetation	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
602102	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
602103	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
602104	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
602105	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
602106	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Unknown Operations	0	
602107	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
602108	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
602109	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
602110	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
602111	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
602112	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
602113	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Switching Operations	0	
602114	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Operations Counter AL	255	
602115	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
602116	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
602117	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps A Ø Max	0.0	
602118	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations B Ø	0	
602119	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations C Ø	0	
602120	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Unknown Operations	0	
602121	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Switching Operations	0	
602122	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
602123	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	9 Month Operations	6	
602124	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Accumulated Fault Duty A Ph V	27.10	%
602125	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Patrol Inspection	Equipment Properly Labeled?	y	
602126	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
602127	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
602128	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
602129	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations A Ø	0	
602130	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations B Ø	0	
602131	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations C Ø	1	
602132	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations Ground	0	
602133	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Patrol Inspection	Follow-up Action Required?	n	
602134	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
602135	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	General Comments		
602136	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
602137	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
602138	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Foundation Condition	Good	
602139	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
602140	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
602141	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
602142	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
602143	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Operations Counter AL	4962	
602144	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Operations Counter AF	4962	
602145	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Maintenance Operations	0	
602146	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Accumulated Fault Duty B Ph V	27.90	%
602147	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
602148	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
602149	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
602150	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
602151	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
602152	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Accumulated Fault Duty C Ph V	18.33	%
602153	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Amps A Ø	103.0	
602154	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Amps B Ø	111.0	
602155	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
602156	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	6.0	
602157	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
602158	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
602159	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
602160	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Follow-up Action Required?	n	
602161	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Patrol Inspection	General Comments		
602162	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	General Comments	C phase IOC	
602163	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Maintenance Operations	0	
602164	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Operations Counter AF	563	
602165	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Operations Counter AL	564	
602166	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Switching Operations	0	
602167	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Unknown Operations	0	
602168	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
602169	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
602170	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC Max Tap Position	3L	
602171	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC Min Tap Position	10L	
602172	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC Operations Since Last Insp	461	
602173	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
602174	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
602175	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
602176	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	9 Months Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
602177	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps B Ø Max	0.0	
602178	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps C Ø	0.0	
602179	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps C Ø Max	0.0	
602180	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
602181	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
602182	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
602183	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
602184	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Operations A Ø	0	
602185	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Operations B Ø	0	
602186	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Operations C Ø	0	
602187	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Operations Ground	0	
602188	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Patrol Inspection	Follow-up Action Required?	n	
602189	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Follow-up Action Required?	n	
602190	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Patrol Inspection	General Comments		
602191	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	General Comments		
602192	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Maintenance Operations	0	
602193	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Operations Counter AF	735	
602194	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Operations Counter AL	734	
602195	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Switching Operations	1	
602196	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Unknown Operations	0	
602197	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps C Ø Max	51.0	
602198	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps C Ø	53.0	
602199	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps B Ø Max	70.0	
602200	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps B Ø	40.0	
602201	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	General Comments		
602202	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
602203	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
602204	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
602205	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps A Ø Max	38.0	
602206	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Ambient Temp	61	°F
602207	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
602208	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	9 Month Operations	4	
602209	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.44	%
602210	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.18	%
602211	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.75	%
602212	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps A Ø	113.0	
602213	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps B Ø	127.0	
602214	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
602215	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
602216	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
602217	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
602218	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
602219	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Ambient Temp	56	°F
602220	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
602221	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
602222	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Clear of Trash?	y	
602223	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps C Ø	131.0	
602224	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
602225	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	LTCC000749	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
602226	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	LTCC000749	LTCControl	920-Offline-Distribution	LTC Control Insp	General Comments	ok	
602227	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	LTCC000749	LTCControl	920-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
602228	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	LTCC000749	LTCControl	920-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
602229	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
602230	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
602231	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Vegetation	None	
602232	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
602233	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
602234	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
602235	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
602236	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
602237	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
602238	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
602239	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
602240	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
602241	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	211	
602242	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	211	
602243	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
602244	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
602245	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
602246	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
602247	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
602248	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
602249	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
602250	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
602251	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
602252	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
602253	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
602254	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
602255	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
602256	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
602257	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
602258	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
602259	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
602260	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	General Comments		
602261	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
602262	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
602263	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
602264	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
602265	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	PF000342	PowerFuse	S-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
602266	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Unknown Operations	0	
602267	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
602268	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
602269	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	PF000342	PowerFuse	S-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
602270	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	Follow-up Action Required?	n	
602271	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
602272	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	General Comments	OK	
602273	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Mechanism Patrol Inspection	General Comments	OK	
602274	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC As Found Counter	1322	
602275	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC As Left Counter	1331	
602276	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
602277	2/4/2019 15:08	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
602278	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
602279	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC Current Tap Position	7L	
602280	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
602281	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Vegetation	None	
602282	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
602283	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Unknown Operations	0	
602284	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Tank Paint Condition	Good	
602285	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Switching Operations	1	
602286	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
602287	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Operations Counter AL	278	
602288	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Operations Counter AF	278	
602289	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Moisture and Leak Free?	y	
602290	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Maintenance Operations	0	
602291	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
602292	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
602293	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps C Ø	0.0	
602294	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps C Ø Max	0.0	
602295	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps A Ø	33.0	
602296	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
602297	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
602298	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Accumulated Fault Duty C Ph AM	2.75	%
602299	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Accumulated Fault Duty B Ph AM	2.75	%
602300	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
602301	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	9 Months Operations	0	
602302	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
602303	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
602304	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
602305	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
602306	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	Totalizer Meter Reading	.5874	
602307	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
602308	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
602309	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
602310	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
602311	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
602312	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
602313	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps A Ø Max	200.0	
602314	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps B Ø	200.0	
602315	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Heaters (All) Functioning?	y	
602316	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
602317	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps B Ø Max	200.0	
602318	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps C Ø	200.0	
602319	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Unknown Operations	0	
602320	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Tank Paint Condition	Good	
602321	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Switching Operations	0	
602322	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
602323	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Totalizer Meter Reading	.5568	
602324	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
602325	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
602326	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
602327	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
602328	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
602329	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
602330	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
602331	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
602332	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
602333	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
602334	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Oil Temp Present	30	°C
602335	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
602336	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
602337	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
602338	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
602339	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
602340	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
602341	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
602342	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
602343	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
602344	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
602345	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	General Comments		
602346	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
602347	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
602348	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Vegetation	None	
602349	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
602350	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
602351	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
602352	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	5.86	
602353	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Patrol Inspection	Follow-up Action Required?	n	
602354	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations Ground	0	
602355	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations C Ø	0	
602356	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations B Ø	0	
602357	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations A Ø	0	
602358	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
602359	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
602360	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
602361	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
602362	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
602363	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
602364	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
602365	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
602366	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps A Ø	200.0	
602367	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
602368	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Clear of Trash?	y	
602369	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
602370	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
602371	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
602372	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
602373	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
602374	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
602375	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
602376	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC Operations Since Last Insp	284	
602377	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC Min Tap Position	10L	
602378	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC Max Tap Position	16R	
602379	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC Current Tap Position	6L	
602380	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
602381	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC As Left Counter	236156	
602382	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC As Found Counter	236152	
602383	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	General Comments		
602384	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	General Comments		
602385	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
602386	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	Follow-up Action Required?	n	
602387	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
602388	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
602389	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	General Comments	ok	
602390	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
602391	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Bushings Connection/Risers	Good	
602392	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	General Comments		
602393	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
602394	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Operations Counter	115	
602395	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Bushing Condition	Good	
602396	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Amps C Ø	10.0	
602397	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Amps B Ø	10.0	
602398	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Amps A Ø	220.0	
602399	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Amps A Ø	10.0	
602400	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Accumulated Fault Duty C Ph V	21.21	%
602401	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Accumulated Fault Duty B Ph V	16.09	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
602402	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Accumulated Fault Duty A Ph V	20.48	%
602403	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	9 Month Operations	8	
602404	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Operations B Ø	0	
602405	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Amps B Ø	200.0	
602406	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Amps C Ø	280.0	
602407	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations A Ø	0	
602408	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Follow-up Action Required?	n	
602409	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Patrol Inspection	Follow-up Action Required?	n	
602410	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations Ground	0	
602411	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations C Ø	0	
602412	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
602413	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations B Ø	0	
602414	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
602415	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
602416	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
602417	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
602418	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
602419	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
602420	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
602421	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Operations B Ø	0	
602422	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Operations A Ø	0	
602423	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations B Ø	0	
602424	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations A Ø	0	
602425	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
602426	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
602427	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
602428	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps C Ø Max	0.0	
602429	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps C Ø	0.0	
602430	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
602431	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Operations A Ø	0	
602432	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps C Ø Max	155.0	
602433	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Operations B Ø	0	
602434	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
602435	2/4/2019 15:09	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
602436	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Operations C Ø	0	
602437	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
602438	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
602439	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
602440	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
602441	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
602442	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Operations Ground	0	
602443	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Follow-up Action Required?	n	
602444	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Follow-up Action Required?	n	
602445	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations A Ø	0	
602446	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations B Ø	0	
602447	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations C Ø	0	
602448	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations Ground	0	
602449	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Patrol Inspection	Follow-up Action Required?	n	
602450	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
602451	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
602452	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
602453	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
602454	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Follow-up Action Required?	n	
602455	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
602456	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
602457	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Operations C Ø	0	
602458	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Operations Ground	0	
602459	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	5.86	
602460	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
602461	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
602462	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Amps A Ø	1.0	
602463	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	434	
602464	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	5.86	
602465	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
602466	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
602467	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Switching Operations	0	
602468	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	6.0	
602469	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
602470	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
602471	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
602472	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Amps B Ø	.3	
602473	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
602474	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
602475	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
602476	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
602477	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
602478	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
602479	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	General Comments		
602480	2/4/2019 12:20	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
602481	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Operations Counter AL	208	
602482	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Operations Counter AF	208	
602483	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Moisture and Leak Free?	y	
602484	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Maintenance Operations	1	
602485	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
602486	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Heaters (All) Functioning?	y	
602487	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
602488	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Grounds in Place?	y	
602489	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
602490	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Cabinet Paint Condition	Good	
602491	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Equipment Properly Labeled?	y	
602492	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
602493	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	General Comments	OK	
602494	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Patrol Inspection	Follow-up Action Required?	n	
602495	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
602496	2/6/2019 7:57	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
602497	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations Ground	0	
602498	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations C Ø	0	
602499	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Amps C Ø	.3	
602500	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
602501	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
602502	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	8.78	%
602503	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Tank Paint Condition	Good	
602504	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Unknown Operations	0	
602505	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	General Comments	ok	
602506	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Foundation Condition	Good	
602507	2/4/2019 9:41	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
602508	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Follow-up Action Required?	n	
602509	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Follow-up Action Required?	n	
602510	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Operations Ground	0	
602511	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Operations C Ø	0	
602512	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
602513	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
602514	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	9.51	%
602515	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	8.78	%
602516	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	20	
602517	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
602518	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
602519	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
602520	2/4/2019 11:27	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
602521	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations B Ø	0	
602522	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	9 Months Operations	9	
602523	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Accumulated Fault Duty A Ph AM	22.89	%
602524	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Accumulated Fault Duty B Ph AM	20.48	%
602525	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
602526	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Operations A Ø	0	
602527	2/4/2019 11:49	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Accumulated Fault Duty C Ph AM	15.66	%
602528	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	405	
602529	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
602530	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
602531	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	185	
602532	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
602533	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Broom on Site?	y	
602534	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
602535	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
602536	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
602537	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
602538	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
602539	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
602540	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
602541	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Evidence of Insects	None	
602542	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Cabinet Paint Condition	Good	
602543	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Equipment Properly Labeled?	y	
602544	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
602545	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Grounds in Place?	y	
602546	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
602547	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
602548	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	General Comments		
602549	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
602550	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
602551	2/4/2019 11:29	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
602552	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	General Comments		
602553	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Foundation Condition	Good	
602554	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Follow-up Action Required?	n	
602555	2/4/2019 12:57	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Follow-up Action Required?	n	
602556	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
602557	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
602558	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
602559	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Operations Counter AF	255	
602560	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
602561	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
602562	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	26	°C
602563	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
602564	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
602565	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
602566	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
602567	2/4/2019 14:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
602568	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	General Comments		
602569	2/4/2019 10:47	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	40	°C
602570	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
602571	2/4/2019 14:54	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
602572	2/4/2019 9:22	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
602573	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Operations B Ø	0	
602574	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Maintenance Operations	0	
602575	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	General Comments		
602576	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Follow-up Action Required?	n	
602577	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Operations A Ø	0	
602578	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
602579	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Operations C Ø	0	
602580	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Unknown Operations	0	
602581	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Operations Counter AF	836	
602582	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Operations Counter AL	836	
602583	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	9 Months Operations	2	
602584	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Switching Operations	0	
602585	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Accumulated Fault Duty A Ph AM	6.66	%
602586	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
602587	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
602588	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Amps C Ø	180.0	
602589	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Amps B Ø	190.0	
602590	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Operations Ground	0	
602591	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Accumulated Fault Duty B Ph AM	5.71	%
602592	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Amps A Ø	180.0	
602593	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Accumulated Fault Duty C Ph AM	2.85	%
602594	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Patrol Inspection	Follow-up Action Required?	n	
602595	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Patrol Inspection	General Comments		
602596	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
602597	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
602598	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
602599	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
602600	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
602601	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	TV Winding Temp Present	25	°C
602602	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
602603	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
602604	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Winding Temp Max	24	°C
602605	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
602606	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
602607	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
602608	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
602609	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
602610	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
602611	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
602612	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Unknown Operations	1	
602613	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
602614	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Switching Operations	0	
602615	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Operations Counter AL	847	
602616	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
602617	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
602618	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
602619	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
602620	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
602621	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Operations Counter AF	490	
602622	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
602623	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Amps C Ø	0.0	
602624	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Operations Counter AF	847	
602625	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	Oil Temp Present	35	°C
602626	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	Oil Temp Max	45	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
602627	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
602628	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Condition	Good	
602629	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
602630	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
602631	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
602632	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	General Comments		
602633	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Operations A Ø	0	
602634	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	General Comments		
602635	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
602636	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
602637	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
602638	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
602639	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
602640	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5209.92	kw
602641	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
602642	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
602643	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
602644	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Fault Operations A Ø	0	
602645	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Fault Operations B Ø	0	
602646	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Fault Operations C Ø	0	
602647	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
602648	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Oil Temp Max	25	°C
602649	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCC000121	LTCControl	451-2	LTC Control Insp	VRR Time Delay	30	Seconds
602650	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
602651	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Fault Operations Ground	0	
602652	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Patrol Inspection	Follow-up Action Required?	n	
602653	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
602654	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
602655	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
602656	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Operations Ground	0	
602657	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
602658	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Operations C Ø	0	
602659	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Follow-up Action Required?	n	
602660	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Patrol Inspection	Follow-up Action Required?	n	
602661	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Accumulated Fault Duty B Ph V	68.87	%
602662	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Accumulated Fault Duty A Ph V	82.50	%
602663	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
602664	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	9 Month Operations	23	
602665	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
602666	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Bushing Condition	Good	
602667	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
602668	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
602669	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
602670	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
602671	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	All Connections OK?	y	
602672	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Clear of Trash?	y	
602673	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
602674	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
602675	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
602676	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
602677	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
602678	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
602679	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
602680	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	53	°F
602681	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
602682	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0854	
602683	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
602684	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
602685	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Follow-up Action Required?	n	
602686	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
602687	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Operations Ground	0	
602688	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Amps A Ø	0.0	
602689	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Operations C Ø	0	
602690	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Switching Operations	0	
602691	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Operations Counter AL	436	
602692	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
602693	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
602694	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
602695	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
602696	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
602697	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
602698	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Operations A Ø	0	
602699	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
602700	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
602701	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Operations Counter AF	436	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
602702	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Maintenance Operations	0	
602703	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	General Comments	OUT OF SERVICE	
602704	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Patrol Inspection	General Comments		
602705	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
602706	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
602707	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
602708	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
602709	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
602710	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
602711	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
602712	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
602713	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
602714	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Follow-up Action Required?	n	
602715	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Switching Operations	0	
602716	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Amps B Ø	0.0	
602717	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
602718	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Operations B Ø	0	
602719	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
602720	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	Totalizer Meter Reading	.9162	
602721	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
602722	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
602723	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
602724	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
602725	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
602726	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
602727	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
602728	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
602729	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
602730	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
602731	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
602732	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
602733	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
602734	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
602735	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
602736	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
602737	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
602738	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
602739	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
602740	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Unknown Operations	0	
602741	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
602742	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
602743	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
602744	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
602745	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	General Comments		
602746	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
602747	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
602748	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Patrol Inspection	General Comments		
602749	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
602750	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Follow-up Action Required?	n	
602751	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
602752	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Moisture and Leak Free?	y	
602753	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Maintenance Operations	0	
602754	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Grounds in Place?	y	
602755	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Unknown Operations	0	
602756	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Amps A Ø	0.0	
602757	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Amps B Ø	0.0	
602758	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Patrol Inspection	Follow-up Action Required?	n	
602759	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Operations Ground	0	
602760	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Operations C Ø	0	
602761	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Operations B Ø	0	
602762	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
602763	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
602764	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	24	
602765	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
602766	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC Min Tap Position	4L	
602767	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
602768	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
602769	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
602770	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC As Left Counter	186754	
602771	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC As Found Counter	186754	
602772	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
602773	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
602774	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
602775	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
602776	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
602777	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
602778	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
602779	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
602780	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
602781	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Maintenance Operations	0	
602782	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	84.0	
602783	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	General Comments		
602784	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Switching Operations	0	
602785	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Maintenance Operations	0	
602786	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	General Comments		
602787	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Operations Counter AL	501	
602788	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Patrol Inspection	General Comments		
602789	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
602790	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Operations Counter AL	157	
602791	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
602792	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
602793	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	General Comments		
602794	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Patrol Inspection	General Comments		
602795	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Follow-up Action Required?	n	
602796	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Patrol Inspection	Follow-up Action Required?	n	
602797	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
602798	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
602799	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	General Comments	Fabric is rusty, couple of spots at bottom of fence with 4 inch gaps	
602800	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
602801	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
602802	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	LTCC000545	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
602803	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	LTCC000545	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
602804	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
602805	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	General Comments		
602806	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
602807	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Operations Ground	0	
602808	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
602809	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Operations C Ø	0	
602810	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
602811	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Operations B Ø	0	
602812	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
602813	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
602814	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
602815	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Operations Counter AF	156	
602816	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Operations A Ø	0	
602817	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
602818	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
602819	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
602820	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
602821	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
602822	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
602823	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
602824	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
602825	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Tank Leaks	None	
602826	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
602827	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
602828	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
602829	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	9 Months Operations	0	
602830	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Patrol Inspection	Equipment Properly Labeled?	y	
602831	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
602832	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Unknown Operations	0	
602833	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Switching Operations	0	
602834	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Operations Counter AL	6	
602835	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Operations Counter AF	6	
602836	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Amps C Ø	0.0	
602837	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
602838	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Maintenance Operations	0	
602839	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	General Comments		
602840	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	General Comments		
602841	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	General Comments		
602842	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
602843	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Patrol Inspection	General Comments		
602844	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Amps B Ø	0.0	
602845	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
602846	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Operations Counter AL	490	
602847	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Switching Operations	0	
602848	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Operations B Ø	0	
602849	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Warning Signs OK?	y	
602850	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	9 Month Operations	1	
602851	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
602852	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	General Comments		
602853	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	LTC Totalizer Reading	16491.60	kw
602854	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	9 Months Operations	0	
602855	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
602856	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Amps A Ø	0.0	
602857	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
602858	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
602859	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Vegetation	None	
602860	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Unknown Operations	0	
602861	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
602862	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
602863	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
602864	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
602865	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
602866	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
602867	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
602868	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
602869	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
602870	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
602871	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
602872	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	1.73	%
602873	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	1.73	%
602874	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Amps A Ø	750.0	
602875	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Amps B Ø	750.0	
602876	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Amps C Ø	750.0	
602877	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
602878	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Unknown Operations	0	
602879	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
602880	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
602881	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
602882	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
602883	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
602884	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
602885	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	Follow-up Action Required?	n	
602886	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Foundation Condition	Good	
602887	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Follow-up Action Required?	n	
602888	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Switching Operations	1	
602889	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Tank Paint Condition	Good	
602890	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Unknown Operations	0	
602891	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCC000121	LTCControl	451-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
602892	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCC000121	LTCControl	451-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
602893	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCC000121	LTCControl	451-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
602894	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.63	%
602895	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.81	%
602896	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	General Comments		
602897	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Patrol Inspection	General Comments		
602898	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Unknown Operations	0	
602899	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	16	
602900	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
602901	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
602902	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Switching Operations	0	
602903	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
602904	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Operations Counter AL	217	
602905	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
602906	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
602907	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
602908	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
602909	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
602910	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	9 Month Operations	0	
602911	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
602912	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
602913	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
602914	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
602915	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Accumulated Fault Duty A Ph V	15.46	%
602916	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Accumulated Fault Duty B Ph V	15.46	%
602917	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	General Comments		
602918	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
602919	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
602920	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
602921	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Accumulated Fault Duty C Ph V	15.46	%
602922	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Amps A Ø	0.0	
602923	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Amps B Ø	0.0	
602924	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
602925	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
602926	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Operations Counter AF	217	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
602927	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Maintenance Operations	0	
602928	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
602929	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
602930	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	General Comments		
602931	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Follow-up Action Required?	n	
602932	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Patrol Inspection	General Comments		
602933	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Follow-up Action Required?	n	
602934	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Amps C Ø	0.0	
602935	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Patrol Inspection	Equipment Properly Labeled?	y	
602936	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
602937	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Patrol Inspection	Follow-up Action Required?	n	
602938	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Operations Ground	0	
602939	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Operations C Ø	0	
602940	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Patrol Inspection	Follow-up Action Required?	n	
602941	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Amps C Ø	160.0	
602942	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
602943	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Amps B Ø	110.0	
602944	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
602945	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Operations A Ø	0	
602946	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
602947	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Grounds in Place?	y	
602948	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	General Comments		
602949	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
602950	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
602951	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
602952	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Maintenance Operations	0	
602953	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	LTCC000545	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
602954	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	LTCC000545	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
602955	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
602956	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
602957	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	LTCC000545	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
602958	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	LTCC000545	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
602959	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	LTCC000545	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
602960	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	LTCC000545	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
602961	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	9 Month Operations	0	
602962	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Operations Ground	0	
602963	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Accumulated Fault Duty A Ph V	4.14	%
602964	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Accumulated Fault Duty B Ph V	4.14	%
602965	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Accumulated Fault Duty C Ph V	4.14	%
602966	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
602967	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Operations Counter AF	808	
602968	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Amps A Ø	110.0	
602969	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Operations Counter AL	808	
602970	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	131	
602971	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
602972	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
602973	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	139	
602974	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	96.0	
602975	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	84.0	
602976	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.81	%
602977	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Maintenance Operations	0	
602978	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Foundation Condition	Good	
602979	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Follow-up Action Required?	n	
602980	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCC000121	LTCControl	451-2	LTC Control Insp	All Connections OK?	y	
602981	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCC000121	LTCControl	451-2	LTC Control Insp	Follow-up Action Required?	n	
602982	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCC000121	LTCControl	451-2	LTC Control Insp	General Comments		
602983	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCC000121	LTCControl	451-2	LTC Control Insp	LTC Operation Checked?	y	
602984	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Grounds in Place?	y	
602985	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	General Comments		
602986	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCC000121	LTCControl	451-2	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
602987	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	General Comments		
602988	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
602989	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Accumulated Fault Duty C Ph V	50.94	%
602990	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Operations Counter AF	501	
602991	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Maintenance Operations	0	
602992	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Tank Paint Condition	Good	
602993	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
602994	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Moisture and Leak Free?	y	
602995	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Heaters (All) Functioning?	y	
602996	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
602997	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
602998	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Patrol Inspection	Equipment Properly Labeled?	y	
602999	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Amps A Ø	155.0	
603000	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Amps B Ø	136.0	
603001	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
603002	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
603003	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
603004	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
603005	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
603006	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
603007	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Amps C Ø	118.0	
603008	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Bushing Condition	Good	
603009	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
603010	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
603011	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
603012	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Amps B Ø	58.0	
603013	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Amps C Ø	95.0	
603014	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
603015	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Operations A Ø	0	
603016	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Operations B Ø	0	
603017	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
603018	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
603019	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
603020	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
603021	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Operations C Ø	0	
603022	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
603023	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
603024	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	All Connections OK?	y	
603025	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Amps C Ø	180.0	
603026	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
603027	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
603028	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	2	
603029	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
603030	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
603031	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
603032	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	8.63	
603033	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	8.63	
603034	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	8.63	
603035	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
603036	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
603037	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
603038	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
603039	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
603040	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	PF000162	PowerFuse	HI-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
603041	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	Follow-up Action Required?	n	
603042	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	General Comments		
603043	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
603044	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
603045	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
603046	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
603047	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	General Comments	Battery check 27.6/25.3	
603048	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
603049	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
603050	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Operations Counter	7	
603051	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Operations Ground	0	
603052	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
603053	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
603054	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
603055	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Amps B Ø	160.0	
603056	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	PF000163	PowerFuse	HI-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
603057	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Bushing Condition	Good	
603058	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	LTC Operation Checked?	y	
603059	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	LTC Output Voltage Level	125.5	VAC
603060	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	y	
603061	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Follow-up Action Required?	n	
603062	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Patrol Inspection	Follow-up Action Required?	n	
603063	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
603064	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Operations Ground	0	
603065	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Operations C Ø	0	
603066	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
603067	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Amps A Ø	62.0	
603068	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	LTCC000527	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
603069	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	LTCC000527	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
603070	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	LTCC000527	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
603071	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	LTCC000527	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
603072	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
603073	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
603074	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
603075	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Unknown Operations	0	
603076	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
603077	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Follow-up Action Required?	n	
603078	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
603079	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
603080	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Switching Operations	0	
603081	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	9 Months Operations	11	
603082	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Accumulated Fault Duty A Ph AM	13.31	%
603083	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Amps B Ø	0.0	
603084	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
603085	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Amps A Ø	0.0	
603086	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
603087	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	VRR Time Delay	60	Seconds
603088	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
603089	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
603090	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	9 Months Operations	0	
603091	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
603092	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
603093	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
603094	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
603095	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
603096	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
603097	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
603098	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
603099	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
603100	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
603101	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
603102	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
603103	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	9 Month Operations	0	
603104	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
603105	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
603106	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
603107	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
603108	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
603109	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
603110	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Accumulated Fault Duty B Ph AM	20.92	%
603111	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Accumulated Fault Duty C Ph AM	14.26	%
603112	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Amps A Ø	80.0	
603113	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Condition	Good	
603114	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
603115	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
603116	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
603117	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Amps B Ø	243.0	
603118	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Amps C Ø	222.0	
603119	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Patrol Inspection	Equipment Properly Labeled?	y	
603120	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Operations A Ø	0	
603121	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
603122	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	General Comments		
603123	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
603124	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Amps A Ø	140.0	
603125	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
603126	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	General Comments		
603127	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
603128	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
603129	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
603130	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
603131	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
603132	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
603133	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Accumulated Fault Duty C Ph V	53.09	%
603134	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Accumulated Fault Duty B Ph V	68.87	%
603135	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Unknown Operations	0	
603136	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
603137	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
603138	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
603139	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Accumulated Fault Duty A Ph V	58.11	%
603140	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	9 Month Operations	7	
603141	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
603142	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
603143	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	General Comments		
603144	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
603145	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
603146	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Operations A Ø	0	
603147	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Operations B Ø	0	
603148	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Operations C Ø	0	
603149	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Operations Ground	0	
603150	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Patrol Inspection	Follow-up Action Required?	n	
603151	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
603152	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
603153	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
603154	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
603155	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
603156	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
603157	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
603158	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
603159	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Amps A Ø	22.2	
603160	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
603161	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
603162	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
603163	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
603164	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Operations A Ø	0	
603165	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Operations B Ø	0	
603166	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Operations C Ø	0	
603167	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
603168	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
603169	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Maintenance Operations	0	
603170	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
603171	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
603172	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
603173	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
603174	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
603175	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Foundation Condition	Good	
603176	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
603177	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
603178	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
603179	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
603180	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Operations Ground	0	
603181	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Follow-up Action Required?	n	
603182	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Unknown Operations	0	
603183	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Tank Paint Condition	Good	
603184	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Switching Operations	0	
603185	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
603186	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Operations Counter AL	170	
603187	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Operations Counter AF	170	
603188	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
603189	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	General Comments		
603190	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	General Comments		
603191	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Tank Leaks	None	
603192	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
603193	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	PF000163	PowerFuse	HI-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
603194	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
603195	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
603196	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
603197	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Operations A Ø	0	
603198	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Operations B Ø	0	
603199	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Operations C Ø	0	
603200	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Operations Ground	0	
603201	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
603202	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	VRR Time Delay	30	Seconds
603203	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	All Connections OK?	y	
603204	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Foundation Condition	Good	
603205	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Follow-up Action Required?	n	
603206	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	PF000164	PowerFuse	HI-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
603207	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	PF000164	PowerFuse	HI-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
603208	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
603209	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
603210	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
603211	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Follow-up Action Required?	n	
603212	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Patrol Inspection	General Comments		
603213	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	General Comments		
603214	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Maintenance Operations	0	
603215	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Operations Counter AF	403	
603216	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Operations Counter AL	403	
603217	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
603218	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Patrol Inspection	Follow-up Action Required?	n	
603219	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
603220	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Follow-up Action Required?	n	
603221	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Amps B Ø	80.0	
603222	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Unknown Operations	0	
603223	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Switching Operations	0	
603224	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Operations Counter AL	744	
603225	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Operations Counter AF	744	
603226	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
603227	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
603228	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Operations Counter	139	
603229	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	General Comments		
603230	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Patrol Inspection	General Comments		
603231	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
603232	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
603233	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
603234	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
603235	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Follow-up Action Required?	n	
603236	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	5.0	
603237	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
603238	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
603239	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	5.0	
603240	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	5.0	
603241	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	38.05	%
603242	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	29.75	%
603243	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	21.45	%
603244	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
603245	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
603246	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
603247	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Amps C Ø	80.0	
603248	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
603249	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
603250	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
603251	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
603252	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
603253	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
603254	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
603255	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC As Left Counter	128336	
603256	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC As Found Counter	128330	
603257	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
603258	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Switching Operations	0	
603259	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Grounds in Place?	y	
603260	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	General Comments		
603261	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Operations Counter AL	114	
603262	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	General Comments		
603263	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Operations Counter AF	114	
603264	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Maintenance Operations	0	
603265	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	General Comments		
603266	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Amps C Ø	100.0	
603267	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Amps B Ø	100.0	
603268	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Unknown Operations	0	
603269	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Tank Paint Condition	Good	
603270	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Switching Operations	0	
603271	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
603272	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
603273	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Operations Counter AL	121	
603274	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
603275	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
603276	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
603277	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
603278	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Tank Leaks	None	
603279	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
603280	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
603281	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Grounds in Place?	y	
603282	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	General Comments		
603283	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	General Comments		
603284	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
603285	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	Follow-up Action Required?	n	
603286	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	needs desicannt screw on filter.	
603287	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Unknown Operations	0	
603288	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Operations Counter AF	121	
603289	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Switching Operations	0	
603290	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Operations Counter AL	636	
603291	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	General Comments	24 operation since last checked. Hands have not moved on guage. Might need replaced.	
603292	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Operations Counter AF	636	
603293	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	LTCC000527	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
603294	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	LTCC000527	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
603295	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	LTCC000527	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
603296	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Amps A Ø	100.0	
603297	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Maintenance Operations	0	
603298	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	General Comments		
603299	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Patrol Inspection	General Comments		
603300	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Follow-up Action Required?	n	
603301	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
603302	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Patrol Inspection	General Comments		
603303	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	General Comments	Racked Out with Do Not Operate	
603304	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Maintenance Operations	0	
603305	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	9 Month Operations	1	
603306	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Operations Counter AF	160	
603307	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Accumulated Fault Duty A Ph V	1.72	%
603308	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Accumulated Fault Duty B Ph V	2.58	%
603309	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Patrol Inspection	Follow-up Action Required?	n	
603310	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Operations Ground	0	
603311	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Operations C Ø	0	
603312	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Operations Counter AL	160	
603313	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
603314	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
603315	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Accumulated Fault Duty C Ph V	6.87	%
603316	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Amps A Ø	225.0	
603317	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Operations A Ø	0	
603318	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
603319	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
603320	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
603321	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Amps C Ø	0.0	
603322	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Bushing Condition	Good	
603323	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
603324	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
603325	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
603326	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
603327	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
603328	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
603329	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
603330	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
603331	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
603332	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
603333	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
603334	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	General Comments		
603335	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Unknown Operations	0	
603336	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
603337	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
603338	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
603339	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	9 Month Operations	3	
603340	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
603341	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
603342	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
603343	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
603344	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Amps A Ø	200.0	
603345	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
603346	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
603347	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
603348	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
603349	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
603350	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
603351	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments		
603352	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
603353	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
603354	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
603355	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
603356	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
603357	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC Operations Since Last Insp	605	
603358	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC Min Tap Position	7L	
603359	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC Max Tap Position	2R	
603360	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC Current Tap Position	3L	
603361	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
603362	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Amps B Ø	197.0	
603363	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
603364	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
603365	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
603366	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Amps C Ø	193.0	
603367	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Bushing Condition	Good	
603368	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Bushings Connection/Risers	Good	
603369	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
603370	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
603371	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
603372	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
603373	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	General Comments		
603374	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
603375	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Cabinet Paint Condition	Good	
603376	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
603377	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Warning Signs OK?	y	
603378	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
603379	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Regulator As Left Counter	192079	
603380	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Equipment Properly Labeled?	y	
603381	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
603382	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
603383	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Patrol Inspection	General Comments		
603384	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Amps C Ø	0.0	
603385	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Follow-up Action Required?	n	
603386	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Follow-up Action Required?	n	
603387	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Amps B Ø	0.0	
603388	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Operations A Ø	0	
603389	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Amps A Ø	0.0	
603390	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	Follow-up Action Required?	n	
603391	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
603392	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
603393	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
603394	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
603395	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
603396	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	General Comments		
603397	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
603398	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Equipment Properly Labeled?	y	
603399	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
603400	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
603401	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Cabinet Paint Condition	Good	
603402	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
603403	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	9 Months Operations	0	
603404	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Foundation Condition	Good	
603405	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	General Comments		
603406	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	General Comments		
603407	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Grounds in Place?	y	
603408	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Foundation Condition	Good	
603409	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
603410	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
603411	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Amps C Ø	0.0	
603412	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
603413	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Mechanism Patrol Inspection	General Comments		
603414	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
603415	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	All Connections OK?	y	
603416	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	Follow-up Action Required?	n	
603417	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC As Found Counter	113000	
603418	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC As Left Counter	113004	
603419	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
603420	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC Current Tap Position	5L	
603421	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
603422	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	General Comments		
603423	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	LTC Operation Checked?	n	
603424	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
603425	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
603426	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC Min Tap Position	9L	
603427	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC Operations Since Last Insp	727	
603428	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
603429	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
603430	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
603431	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
603432	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
603433	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Tank Leaks	None	
603434	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
603435	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0035	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
603436	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
603437	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
603438	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
603439	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	Needs eyewash	
603440	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	LTCC000527	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
603441	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
603442	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
603443	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Bushings Connection/Risers	Good	
603444	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Bushing Condition	Good	
603445	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
603446	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
603447	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Patrol Inspection	Follow-up Action Required?	n	
603448	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Operations Ground	0	
603449	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Operations C Ø	0	
603450	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Operations B Ø	0	
603451	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
603452	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
603453	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Switching Operations	0	
603454	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
603455	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
603456	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	112	
603457	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
603458	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC Max Tap Position	8L	
603459	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC Current Tap Position	11L	
603460	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
603461	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC As Left Counter	23802	
603462	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC As Found Counter	23802	
603463	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
603464	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	General Comments		
603465	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
603466	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Accumulated Fault Duty C Ph V	20.80	%
603467	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Accumulated Fault Duty B Ph V	37.30	%
603468	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
603469	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Unknown Operations	0	
603470	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
603471	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
603472	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	PF000162	PowerFuse	HI-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
603473	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Foundation Condition	Good	
603474	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Follow-up Action Required?	n	
603475	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Unknown Operations	0	
603476	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Switching Operations	0	
603477	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Operations Counter AL	361	
603478	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
603479	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	Follow-up Action Required?	y	
603480	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Operations Counter AF	361	
603481	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Maintenance Operations	0	
603482	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
603483	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
603484	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	General Comments		
603485	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
603486	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Operations A Ø	0	
603487	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Operations B Ø	0	
603488	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Accumulated Fault Duty A Ph V	35.87	%
603489	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Operations C Ø	0	
603490	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Operations Ground	0	
603491	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
603492	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Patrol Inspection	General Comments		
603493	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	General Comments		
603494	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Maintenance Operations	0	
603495	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Operations Counter AF	147	
603496	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Patrol Inspection	General Comments		
603497	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Follow-up Action Required?	n	
603498	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Patrol Inspection	Follow-up Action Required?	n	
603499	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Operations Counter AL	147	
603500	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Switching Operations	0	
603501	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Operations Ground	0	
603502	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Unknown Operations	0	
603503	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Operations B Ø	0	
603504	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Operations A Ø	0	
603505	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	9 Month Operations	5	
603506	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
603507	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Operations C Ø	0	
603508	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Operations B Ø	0	
603509	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
603510	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
603511	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
603512	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
603513	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
603514	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
603515	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	General Comments		
603516	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Operations A Ø	0	
603517	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
603518	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Vegetation	None	
603519	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
603520	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Operations B Ø	0	
603521	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Operations C Ø	0	
603522	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Operations Ground	0	
603523	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BCH001120	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.8	VDC
603524	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BCH001120	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
603525	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BCH001120	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
603526	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BCH001120	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
603527	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BCH001120	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
603528	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
603529	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
603530	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
603531	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
603532	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Patrol Inspection	Follow-up Action Required?	n	
603533	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Follow-up Action Required?	n	
603534	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Patrol Inspection	General Comments		
603535	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	General Comments		
603536	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Maintenance Operations	0	
603537	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Operations Counter AF	119	
603538	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Operations Counter AL	119	
603539	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
603540	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
603541	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	PF000205	PowerFuse	MD-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
603542	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	PF000205	PowerFuse	MD-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
603543	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
603544	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
603545	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
603546	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
603547	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
603548	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
603549	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
603550	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Foundation Condition	Good	
603551	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
603552	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
603553	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
603554	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
603555	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC Operations Since Last Insp	357	
603556	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC Min Tap Position	5L	
603557	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC Max Tap Position	2L	
603558	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC Current Tap Position	5L	
603559	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
603560	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC As Left Counter	80672	
603561	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC As Found Counter	80668	
603562	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	General Comments		
603563	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	General Comments		
603564	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
603565	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	Follow-up Action Required?	n	
603566	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
603567	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
603568	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
603569	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
603570	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
603571	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
603572	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
603573	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
603574	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
603575	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	General Comments		
603576	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
603577	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
603578	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
603579	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
603580	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	9 Month Operations	11	
603581	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Accumulated Fault Duty A Ph V	16.50	%
603582	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Accumulated Fault Duty B Ph V	27.98	%
603583	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Accumulated Fault Duty C Ph V	26.54	%
603584	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Amps A Ø	160.0	
603585	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Amps B Ø	120.0	
603586	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Amps C Ø	120.0	
603587	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Patrol Inspection	Equipment Properly Labeled?	y	
603588	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
603589	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
603590	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
603591	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Ambient Temp	41	°F
603592	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
603593	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
603594	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
603595	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
603596	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Clear of Trash?	y	
603597	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC Current Tap Position	9L	
603598	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
603599	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC As Left Counter	16677	
603600	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC As Found Counter	16677	
603601	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
603602	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Switching Operations	0	
603603	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Unknown Operations	0	
603604	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	9 Months Operations	5	
603605	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
603606	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
603607	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
603608	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	General Comments		
603609	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
603610	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Tank Paint Condition	Good	
603611	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
603612	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Moisture and Leak Free?	y	
603613	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Heaters (All) Functioning?	y	
603614	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Grounds in Place?	y	
603615	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
603616	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
603617	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
603618	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
603619	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
603620	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	General Comments		
603621	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Foundation Condition	Good	
603622	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Follow-up Action Required?	n	
603623	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Equipment Properly Labeled?	y	
603624	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Cabinet Paint Condition	Good	
603625	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
603626	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
603627	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
603628	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Bushings Connection/Risers	Good	
603629	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Bushing Condition	Good	
603630	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Evidence of Insects	None	
603631	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
603632	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
603633	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
603634	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
603635	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	General Comments		
603636	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
603637	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
603638	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
603639	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Panels Dusted?	y	
603640	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	General Comments	Broken skirt on high side insulator. The transfer switch above the recloser is not operating correctly, we lubricated it and tried to oper	
603641	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
603642	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
603643	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
603644	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Unknown Operations	0	
603645	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Switching Operations	0	
603646	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Operations Counter AL	178	
603647	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Operations Counter AF	178	
603648	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Maintenance Operations	0	
603649	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	General Comments	Racked Out with Do Not Operate	
603650	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
603651	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Operating Linkage OK?	n	
603652	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
603653	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
603654	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
603655	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Patrol Inspection	General Comments		
603656	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Follow-up Action Required?	n	
603657	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Patrol Inspection	Follow-up Action Required?	n	
603658	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Operations Ground	0	
603659	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Operations C Ø	0	
603660	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Operations B Ø	0	
603661	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Operations A Ø	0	
603662	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
603663	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
603664	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
603665	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Patrol Inspection	Equipment Properly Labeled?	y	
603666	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
603667	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
603668	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
603669	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
603670	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	123	
603671	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	13	°C
603672	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	29	°C
603673	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Amps C Ø	0.0	
603674	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Amps B Ø	0.0	
603675	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Amps A Ø	0.0	
603676	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
603677	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
603678	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
603679	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	9 Month Operations	0	
603680	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	PF000204	PowerFuse	MD-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
603681	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	PF000204	PowerFuse	MD-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
603682	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC Min Tap Position	11L	
603683	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC Max Tap Position	8L	
603684	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
603685	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Amps C Ø	0.0	
603686	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Amps B Ø	0.0	
603687	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Amps A Ø	0.0	
603688	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
603689	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
603690	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
603691	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	9 Months Operations	0	
603692	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
603693	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
603694	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
603695	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
603696	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
603697	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
603698	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
603699	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	23	°C
603700	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	35	°C
603701	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	23	°C
603702	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	35	°C
603703	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	23	°C
603704	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	35	°C
603705	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
603706	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
603707	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
603708	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
603709	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
603710	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
603711	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
603712	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
603713	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
603714	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	Oil Temp Present	21	°C
603715	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	Oil Temp Max	34	°C
603716	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
603717	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
603718	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
603719	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
603720	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	General Comments		
603721	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
603722	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
603723	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
603724	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
603725	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
603726	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
603727	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Bushing Condition	Good	
603728	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
603729	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
603730	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
603731	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
603732	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
603733	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
603734	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
603735	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
603736	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
603737	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Operations A Ø	0	
603738	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Operations B Ø	0	
603739	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Operations C Ø	0	
603740	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Operations Ground	0	
603741	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Follow-up Action Required?	n	
603742	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Follow-up Action Required?	n	
603743	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Foundation Condition	Good	
603744	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
603745	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Operations Counter	3	
603746	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
603747	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Tank Leaks	None	
603748	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BCH001120	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
603749	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BCH001120	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.8	VDC
603750	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	BCH000593	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
603751	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	BCH000593	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
603752	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	General Comments		
603753	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	General Comments		
603754	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Grounds in Place?	y	
603755	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
603756	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Maintenance Operations	0	
603757	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
603758	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Operations Counter AF	42	
603759	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Operations Counter AL	42	
603760	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
603761	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Switching Operations	0	
603762	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Tank Paint Condition	Good	
603763	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Unknown Operations	0	
603764	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Fault Operations B Ø	0	
603765	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Fault Operations A Ø	0	
603766	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
603767	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	BCH000593	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
603768	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
603769	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
603770	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
603771	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC As Left Counter	12361	
603772	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC As Found Counter	12361	
603773	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	General Comments		
603774	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	General Comments		
603775	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
603776	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
603777	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
603778	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
603779	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
603780	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	11L	
603781	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
603782	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
603783	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
603784	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Patrol Inspection	Equipment Properly Labeled?	y	
603785	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
603786	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
603787	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
603788	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Operations A Ø	0	
603789	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Operations B Ø	0	
603790	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Operations C Ø	0	
603791	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Operations Ground	0	
603792	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
603793	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
603794	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
603795	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
603796	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
603797	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	Follow-up Action Required?	n	
603798	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Patrol Inspection	Follow-up Action Required?	n	
603799	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Follow-up Action Required?	n	
603800	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Patrol Inspection	General Comments		
603801	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	General Comments		
603802	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Maintenance Operations	0	
603803	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
603804	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
603805	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
603806	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
603807	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
603808	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
603809	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
603810	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
603811	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Operations Counter AF	167	
603812	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Operations Counter AL	167	
603813	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Switching Operations	0	
603814	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Unknown Operations	0	
603815	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
603816	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
603817	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
603818	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
603819	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
603820	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
603821	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
603822	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
603823	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Oil Temp Max	32	°C
603824	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Oil Temp Present	32	°C
603825	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
603826	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
603827	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
603828	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
603829	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
603830	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
603831	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
603832	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
603833	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
603834	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Totalizer Meter Reading	1.5534	
603835	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Winding Temp Max	34	°C
603836	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Winding Temp Present	32	°C
603837	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
603838	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
603839	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
603840	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
603841	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC Operations Since Last Insp	95	
603842	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
603843	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
603844	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
603845	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	9 Month Operations	0	
603846	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Accumulated Fault Duty A Ph V	.86	%
603847	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Accumulated Fault Duty B Ph V	.86	%
603848	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Accumulated Fault Duty C Ph V	.86	%
603849	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Amps A Ø	42.0	
603850	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Amps B Ø	41.0	
603851	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Amps C Ø	39.0	
603852	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
603853	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	10	°C
603854	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	20	°C
603855	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC Min Tap Position	8L	
603856	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC Max Tap Position	6L	
603857	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC Current Tap Position	8L	
603858	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
603859	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	PF000202	PowerFuse	MD-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
603860	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	9 Month Operations	0	
603861	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Accumulated Fault Duty A Ph V	3.44	%
603862	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Accumulated Fault Duty B Ph V	3.44	%
603863	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
603864	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
603865	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
603866	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
603867	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
603868	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
603869	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
603870	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Maintenance Operations	0	
603871	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	General Comments		
603872	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Accumulated Fault Duty C Ph V	2.58	%
603873	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Amps A Ø	175.0	
603874	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Amps B Ø	143.0	
603875	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Amps C Ø	170.0	
603876	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Patrol Inspection	Equipment Properly Labeled?	y	
603877	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
603878	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Patrol Inspection	General Comments		
603879	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Follow-up Action Required?	n	
603880	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
603881	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Operations Ground	0	
603882	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
603883	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
603884	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	PF000203	PowerFuse	MD-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
603885	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	PF000203	PowerFuse	MD-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
603886	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	PF000206	PowerFuse	MD-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
603887	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	PF000206	PowerFuse	MD-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
603888	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	PF000207	PowerFuse	MD-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
603889	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	PF000207	PowerFuse	MD-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
603890	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Operations A Ø	0	
603891	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Operations B Ø	0	
603892	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Operations C Ø	0	
603893	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Operations Ground	0	
603894	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Patrol Inspection	Follow-up Action Required?	n	
603895	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Follow-up Action Required?	n	
603896	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Patrol Inspection	General Comments		
603897	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	General Comments		
603898	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Maintenance Operations	0	
603899	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Operations Counter AF	139	
603900	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Operations Counter AL	139	
603901	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Switching Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
603902	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Operations Ground	0	
603903	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
603904	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
603905	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
603906	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
603907	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
603908	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1128	
603909	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1128	
603910	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
603911	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
603912	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
603913	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
603914	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Operations A Ø	0	
603915	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Operations B Ø	0	
603916	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Operations C Ø	0	
603917	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
603918	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
603919	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Patrol Inspection	Follow-up Action Required?	n	
603920	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Follow-up Action Required?	n	
603921	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Patrol Inspection	General Comments		
603922	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	General Comments		
603923	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Maintenance Operations	0	
603924	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Operations Counter AF	562	
603925	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Operations Counter AL	562	
603926	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Switching Operations	0	
603927	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Unknown Operations	0	
603928	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Operations Ground	0	
603929	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
603930	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Follow-up Action Required?	n	
603931	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Patrol Inspection	General Comments		
603932	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	General Comments		
603933	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Maintenance Operations	0	
603934	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Operations Counter AF	296	
603935	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Operations Counter AL	296	
603936	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Switching Operations	0	
603937	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Unknown Operations	0	
603938	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
603939	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
603940	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
603941	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
603942	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
603943	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
603944	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
603945	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	PF000202	PowerFuse	MD-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
603946	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC Min Tap Position	2R	
603947	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC Max Tap Position	15R	
603948	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Amps C Ø	0.0	
603949	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
603950	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
603951	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
603952	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
603953	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Operations A Ø	0	
603954	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Operations B Ø	0	
603955	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Operations C Ø	0	
603956	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Operations Ground	0	
603957	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
603958	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Follow-up Action Required?	n	
603959	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Patrol Inspection	General Comments		
603960	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	General Comments		
603961	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Maintenance Operations	0	
603962	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Operations Counter AF	119	
603963	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
603964	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
603965	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
603966	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
603967	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	LTC Operations Since Last Insp	1425	
603968	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	40	°C
603969	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
603970	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
603971	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.5	psi
603972	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	LTC Min Tap Position	6L	
603973	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	LTC Max Tap Position	1L	
603974	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	LTC Current Tap Position	6L	
603975	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
603976	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	LTC As Left Counter	133647	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
603977	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	LTC As Found Counter	133647	
603978	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	General Comments		
603979	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	General Comments		
603980	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Surge Arrester Condition	Blown	
603981	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
603982	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
603983	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
603984	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
603985	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	Follow-up Action Required?	n	
603986	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
603987	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
603988	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
603989	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	PF000165	PowerFuse	HI-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
603990	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	PF000165	PowerFuse	HI-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
603991	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Unknown Operations	0	
603992	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
603993	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
603994	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Equipment Properly Labeled?	y	
603995	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Cabinet Paint Condition	Good	
603996	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
603997	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
603998	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
603999	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
604000	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
604001	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
604002	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
604003	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
604004	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
604005	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Bushings Connection/Risers	Good	
604006	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Bushing Condition	Good	
604007	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Amps C Ø	82.0	
604008	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Amps B Ø	85.0	
604009	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Amps A Ø	88.0	
604010	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Accumulated Fault Duty C Ph V	4.76	%
604011	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Accumulated Fault Duty B Ph V	9.52	%
604012	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Accumulated Fault Duty A Ph V	4.53	%
604013	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	9 Month Operations	3	
604014	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
604015	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
604016	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
604017	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	25	°F
604018	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
604019	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
604020	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
604021	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	9 Month Operations	0	
604022	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
604023	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
604024	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
604025	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Amps A Ø	0.0	
604026	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Amps B Ø	0.0	
604027	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
604028	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	184	
604029	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	16	°C
604030	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
604031	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
604032	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
604033	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
604034	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	General Comments	Broken porcelain found in station from an unused insulator at top side of structure, no other damage found. Removed broken pieces.	
604035	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
604036	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
604037	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Vegetation	None	
604038	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Patrol Inspection	General Comments		
604039	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	General Comments		
604040	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
604041	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	General Comments		
604042	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
604043	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
604044	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
604045	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
604046	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
604047	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
604048	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
604049	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Amps C Ø	220.0	
604050	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Amps B Ø	190.0	
604051	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Amps A Ø	220.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
604052	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
604053	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
604054	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
604055	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
604056	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
604057	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
604058	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
604059	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Maintenance Operations	0	
604060	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Operations Counter AF	163	
604061	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Operations Counter AL	163	
604062	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Switching Operations	0	
604063	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Unknown Operations	0	
604064	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
604065	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
604066	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
604067	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
604068	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	General Comments		
604069	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
604070	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
604071	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
604072	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
604073	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
604074	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Clear of Trash?	y	
604075	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
604076	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
604077	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Amps A Ø	459.0	
604078	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Amps B Ø	438.0	
604079	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Amps C Ø	448.0	
604080	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
604081	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
604082	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
604083	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
604084	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
604085	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
604086	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
604087	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
604088	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
604089	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
604090	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
604091	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
604092	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
604093	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
604094	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
604095	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
604096	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Operations Ground	0	
604097	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BAT000157	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
604098	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BAT000157	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
604099	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	9 Months Operations	0	
604100	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
604101	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
604102	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
604103	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Amps A Ø	0.0	
604104	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Amps B Ø	0.0	
604105	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Amps C Ø	0.0	
604106	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
604107	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
604108	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
604109	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Amps A Ø	150.0	
604110	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Amps B Ø	140.0	
604111	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Amps C Ø	140.0	
604112	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
604113	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
604114	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
604115	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
604116	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
604117	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
604118	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
604119	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
604120	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
604121	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
604122	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
604123	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
604124	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
604125	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
604126	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
604127	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
604128	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
604129	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
604130	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
604131	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
604132	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	9 Months Operations	12	
604133	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
604134	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
604135	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
604136	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Amps A Ø	130.0	
604137	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Amps B Ø	130.0	
604138	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Amps C Ø	130.0	
604139	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
604140	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
604141	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
604142	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
604143	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
604144	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
604145	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
604146	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
604147	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
604148	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Follow-up Action Required?	n	
604149	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Operations Ground	0	
604150	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Operations C Ø	0	
604151	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Operations B Ø	0	
604152	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Unknown Operations	0	
604153	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Switching Operations	0	
604154	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Operations A Ø	0	
604155	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
604156	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
604157	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
604158	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Operations Counter AL	527	
604159	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Operations Counter AF	527	
604160	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
604161	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Operations A Ø	0	
604162	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Operations B Ø	0	
604163	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Operations C Ø	0	
604164	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
604165	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
604166	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
604167	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Accumulated Fault Duty B Ph AM	3.98	%
604168	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
604169	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Ambient Temp	38	°F
604170	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Accumulated Fault Duty A Ph AM	1.59	%
604171	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	9 Months Operations	0	
604172	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BAT000157	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
604173	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BAT000157	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
604174	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BAT000157	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
604175	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BAT000157	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
604176	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BAT000157	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
604177	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BAT000157	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
604178	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BAT000157	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
604179	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BAT000157	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
604180	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BAT000157	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
604181	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BAT000157	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
604182	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BAT000157	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
604183	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BAT000157	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
604184	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
604185	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	35.28	%
604186	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	34.59	%
604187	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	33.21	%
604188	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	190.0	
604189	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	180.0	
604190	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
604191	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
604192	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
604193	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
604194	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Unknown Operations	0	
604195	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Tank Paint Condition	Good	
604196	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Switching Operations	1	
604197	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Operations Counter AL	323	
604198	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Operations Counter AF	322	
604199	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Moisture and Leak Free?	y	
604200	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Maintenance Operations	0	
604201	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
604202	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	General Comments		
604203	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	General Comments		
604204	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Foundation Condition	Good	
604205	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Follow-up Action Required?	n	
604206	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
604207	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Foundation Condition	Good	
604208	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
604209	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
604210	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
604211	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
604212	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
604213	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
604214	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
604215	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
604216	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
604217	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
604218	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
604219	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
604220	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
604221	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
604222	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
604223	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
604224	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
604225	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
604226	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	Oil Temp Max	30	°C
604227	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	700	psi
604228	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
604229	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Unknown Operations	0	
604230	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Switching Operations	0	
604231	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Bushings Connection/Risers	Good	
604232	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
604233	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
604234	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
604235	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Cabinet Paint Condition	Good	
604236	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Equipment Properly Labeled?	y	
604237	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Follow-up Action Required?	n	
604238	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Foundation Condition	Good	
604239	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	General Comments		
604240	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Grounds in Place?	y	
604241	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Heaters (All) Functioning?	y	
604242	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Moisture and Leak Free?	y	
604243	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
604244	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Unknown Operations	0	
604245	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Tank Paint Condition	Good	
604246	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Switching Operations	1	
604247	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Operations Counter AL	186	
604248	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Operations Counter AF	185	
604249	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Moisture and Leak Free?	y	
604250	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Maintenance Operations	0	
604251	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
604252	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
604253	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
604254	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
604255	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
604256	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
604257	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
604258	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
604259	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
604260	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
604261	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
604262	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Totalizer Meter Reading	1.2444	
604263	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
604264	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
604265	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
604266	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
604267	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	General Comments		
604268	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
604269	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Winding Temp Max	25	°C
604270	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Winding Temp Present	25	°C
604271	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
604272	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
604273	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
604274	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
604275	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
604276	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	29	°F

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
604277	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
604278	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
604279	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
604280	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
604281	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
604282	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
604283	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Adequate	
604284	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
604285	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
604286	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
604287	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	Oil Temp Present	20	°C
604288	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
604289	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
604290	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	Oil Temp Max	30	°C
604291	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
604292	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Bushing Condition	Good	
604293	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
604294	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
604295	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
604296	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
604297	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
604298	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
604299	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
604300	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	General Comments		
604301	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	General Comments		
604302	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
604303	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
604304	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
604305	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
604306	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
604307	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
604308	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
604309	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
604310	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LTCC000432	LTCControl	HI-TRANS 1	LTC Control Insp	General Comments	ok	
604311	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LTCC000432	LTCControl	HI-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
604312	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	9 Months Operations	2	
604313	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Accumulated Fault Duty A Ph AM	1.53	%
604314	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Accumulated Fault Duty B Ph AM	1.53	%
604315	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
604316	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Amps A Ø	25.0	
604317	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Amps B Ø	25.0	
604318	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
604319	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Amps C Ø	25.0	
604320	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
604321	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
604322	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
604323	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
604324	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Operations A Ø	0	
604325	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Operations B Ø	0	
604326	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Operations C Ø	0	
604327	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Operations Ground	0	
604328	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Patrol Inspection	Follow-up Action Required?	n	
604329	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Follow-up Action Required?	n	
604330	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Patrol Inspection	General Comments		
604331	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	General Comments		
604332	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Maintenance Operations	0	
604333	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Operations Counter AF	606	
604334	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Operations Counter AL	606	
604335	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Switching Operations	0	
604336	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Unknown Operations	0	
604337	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
604338	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Grounds in Place?	y	
604339	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	General Comments		
604340	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	General Comments		
604341	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Foundation Condition	Good	
604342	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Follow-up Action Required?	n	
604343	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Follow-up Action Required?	n	
604344	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Operations Ground	0	
604345	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Operations C Ø	0	
604346	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Operations B Ø	0	
604347	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Operations A Ø	0	
604348	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
604349	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
604350	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
604351	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
604352	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Cabinet Paint Condition	Good	
604353	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
604354	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
604355	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
604356	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Bushings Connection/Risers	Good	
604357	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Bushing Condition	Good	
604358	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Amps C Ø	144.0	
604359	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Amps B Ø	78.0	
604360	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Amps A Ø	98.0	
604361	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Accumulated Fault Duty C Ph V	.40	%
604362	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
604363	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Accumulated Fault Duty A Ph V	.40	%
604364	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	9 Month Operations	4	
604365	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	BCH000582	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
604366	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	BCH000582	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
604367	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	BCH000582	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
604368	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	BCH000582	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
604369	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	BCH000582	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
604370	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	BCH000582	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
604371	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BCH000207	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
604372	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BCH000207	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
604373	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BCH000207	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
604374	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BCH000207	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
604375	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BCH000207	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
604376	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Tank Paint Condition	Good	
604377	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
604378	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Tank Leaks	None	
604379	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
604380	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
604381	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
604382	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
604383	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
604384	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
604385	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
604386	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
604387	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
604388	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
604389	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
604390	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
604391	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
604392	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
604393	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Regulator As Left Counter	11396	
604394	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
604395	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
604396	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
604397	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
604398	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
604399	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
604400	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
604401	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
604402	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	General Comments		
604403	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
604404	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
604405	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
604406	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
604407	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
604408	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
604409	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
604410	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
604411	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
604412	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
604413	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
604414	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LTCC000598	LTCControl	HI-TRANS 2	LTC Control Insp	General Comments	ok	
604415	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LTCC000598	LTCControl	HI-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
604416	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	General Comments		
604417	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
604418	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
604419	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
604420	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Follow-up Action Required?	n	
604421	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
604422	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
604423	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
604424	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
604425	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Unknown Operations	0	
604426	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
604427	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
604428	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	LTC Totalizer Reading	14912.64	kw
604429	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
604430	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
604431	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Operations Counter	478	
604432	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
604433	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	General Comments		
604434	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
604435	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
604436	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
604437	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
604438	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
604439	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Amps A Ø	23.2	
604440	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Switching Operations	0	
604441	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Operations Counter AL	546	
604442	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Operations Counter AF	546	
604443	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Maintenance Operations	0	
604444	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	General Comments		
604445	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Patrol Inspection	General Comments		
604446	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Follow-up Action Required?	n	
604447	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Patrol Inspection	Follow-up Action Required?	n	
604448	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Operations Ground	0	
604449	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Operations C Ø	0	
604450	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Operations B Ø	0	
604451	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Operations A Ø	0	
604452	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
604453	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
604454	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
604455	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
604456	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Amps C Ø	0.0	
604457	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Amps B Ø	0.0	
604458	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Amps A Ø	0.0	
604459	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
604460	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
604461	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
604462	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	9 Months Operations	0	
604463	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
604464	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Tank Leaks	None	
604465	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
604466	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
604467	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	General Comments	Added Nitrogen	
604468	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
604469	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Accumulated Fault Duty A Ph V	.40	%
604470	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	9 Month Operations	4	
604471	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
604472	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	25	°C
604473	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	35	°C
604474	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
604475	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
604476	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
604477	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
604478	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
604479	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
604480	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
604481	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
604482	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
604483	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
604484	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
604485	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
604486	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
604487	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
604488	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
604489	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
604490	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
604491	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
604492	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
604493	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
604494	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
604495	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
604496	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
604497	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
604498	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Follow-up Action Required?	n	
604499	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
604500	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
604501	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
604502	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	General Comments		
604503	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
604504	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	LTC Totalizer Reading	22399.20	kw
604505	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
604506	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	900.0	psi
604507	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2	psi
604508	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Oil Temp Max	30	°C
604509	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Oil Temp Present	30	°C
604510	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
604511	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
604512	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
604513	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
604514	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
604515	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
604516	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
604517	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
604518	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
604519	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
604520	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
604521	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
604522	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	40	°C
604523	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	15	°C
604524	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	35	°C
604525	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Unknown Operations	0	
604526	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Tank Paint Condition	Good	
604527	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Switching Operations	1	
604528	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Operations Counter AL	173	
604529	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Operations Counter AF	172	
604530	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Moisture and Leak Free?	y	
604531	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Maintenance Operations	0	
604532	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Grounds in Place?	y	
604533	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	General Comments		
604534	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	General Comments		
604535	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Foundation Condition	Good	
604536	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Follow-up Action Required?	n	
604537	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Follow-up Action Required?	n	
604538	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Operations Ground	0	
604539	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Operations C Ø	2	
604540	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Operations B Ø	0	
604541	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Operations A Ø	0	
604542	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Adjusted Amps C Phase V	10.65	
604543	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
604544	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
604545	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Equipment Properly Labeled?	y	
604546	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Cabinet Paint Condition	Good	
604547	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
604548	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
604549	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
604550	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Bushings Connection/Risers	Good	
604551	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Bushing Condition	Good	
604552	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Amps C Ø	118.0	
604553	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Amps B Ø	138.0	
604554	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Amps A Ø	162.0	
604555	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Accumulated Fault Duty C Ph V	.79	%
604556	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
604557	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Amps A Ø	130.0	
604558	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
604559	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
604560	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
604561	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	9 Months Operations	4	
604562	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Operations Counter AL	555	
604563	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Switching Operations	0	
604564	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Unknown Operations	0	
604565	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
604566	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
604567	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
604568	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	General Comments		
604569	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	9 Month Operations	0	
604570	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
604571	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
604572	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
604573	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
604574	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
604575	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
604576	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
604577	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
604578	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
604579	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Unknown Operations	0	
604580	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
604581	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
604582	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
604583	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
604584	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
604585	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
604586	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Switching Operations	0	
604587	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Operations Counter AL	356	
604588	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Operations Counter AF	356	
604589	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Maintenance Operations	0	
604590	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	General Comments		
604591	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Patrol Inspection	General Comments		
604592	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
604593	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	20	°C
604594	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	5	°C
604595	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
604596	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Follow-up Action Required?	n	
604597	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Patrol Inspection	Follow-up Action Required?	n	
604598	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Fault Operations Ground	0	
604599	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
604600	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
604601	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
604602	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
604603	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
604604	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
604605	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
604606	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
604607	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
604608	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
604609	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
604610	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
604611	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
604612	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
604613	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
604614	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
604615	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
604616	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
604617	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
604618	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
604619	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
604620	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
604621	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
604622	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
604623	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
604624	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	General Comments		
604625	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
604626	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	40	
604627	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	40	
604628	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
604629	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
604630	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
604631	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
604632	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Patrol Inspection	Follow-up Action Required?	n	
604633	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Follow-up Action Required?	n	
604634	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
604635	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
604636	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
604637	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
604638	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Patrol Inspection	General Comments		
604639	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	General Comments		
604640	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Maintenance Operations	0	
604641	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Operations Counter AF	555	
604642	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Amps C Ø	130.0	
604643	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Amps B Ø	120.0	
604644	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Operations Ground	0	
604645	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
604646	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Follow-up Action Required?	n	
604647	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Patrol Inspection	General Comments		
604648	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	General Comments		
604649	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Maintenance Operations	0	
604650	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Operations Counter AF	355	
604651	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Operations Counter AL	355	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
604652	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
604653	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
604654	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Switching Operations	0	
604655	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Unknown Operations	0	
604656	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
604657	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	BCH000593	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
604658	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	BCH000593	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
604659	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	BCH000593	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
604660	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
604661	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
604662	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
604663	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
604664	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
604665	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Fault Operations C Ø	0	
604666	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
604667	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
604668	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
604669	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
604670	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
604671	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
604672	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
604673	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
604674	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
604675	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
604676	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	General Comments		
604677	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
604678	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LTCC000023	LTCControl	MD-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
604679	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LTCC000023	LTCControl	MD-TRANS 1	LTC Control Insp	General Comments		
604680	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LTCC000023	LTCControl	MD-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
604681	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	9 Month Operations	0	
604682	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
604683	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
604684	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
604685	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Amps A Ø	340.0	
604686	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Amps B Ø	340.0	
604687	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Amps C Ø	390.0	
604688	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
604689	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
604690	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
604691	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
604692	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
604693	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
604694	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
604695	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
604696	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
604697	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	Oil Temp Max	70	°C
604698	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
604699	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
604700	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
604701	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
604702	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitro. Bottle alarm is isolated at TR.	
604703	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	General Comments		
604704	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
604705	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
604706	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
604707	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
604708	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	Linkage Grounds in Place?	y	
604709	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
604710	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
604711	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
604712	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
604713	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
604714	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
604715	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
604716	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	9 Months Operations	0	
604717	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	Steel Structures Rust Free?	y	
604718	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
604719	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
604720	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
604721	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
604722	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Amps A Ø	0.0	
604723	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Amps B Ø	0.0	
604724	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Amps C Ø	0.0	
604725	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
604726	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
604727	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
604728	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
604729	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Operations A Ø	0	
604730	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Operations B Ø	0	
604731	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Operations C Ø	0	
604732	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
604733	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	General Comments		
604734	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
604735	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
604736	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
604737	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
604738	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
604739	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
604740	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
604741	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
604742	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
604743	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
604744	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Operations Counter AL	598	
604745	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Operations Counter AF	598	
604746	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Maintenance Operations	0	
604747	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	General Comments		
604748	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Patrol Inspection	General Comments		
604749	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Follow-up Action Required?	n	
604750	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Patrol Inspection	Follow-up Action Required?	n	
604751	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Operations Ground	0	
604752	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Operations C Ø	0	
604753	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Operations B Ø	0	
604754	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Operations A Ø	0	
604755	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
604756	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
604757	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
604758	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
604759	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
604760	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
604761	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
604762	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
604763	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
604764	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
604765	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
604766	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
604767	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
604768	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
604769	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Follow-up Action Required?	n	
604770	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Patrol Inspection	General Comments		
604771	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	General Comments		
604772	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Maintenance Operations	0	
604773	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Operations Counter AF	930	
604774	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Operations Counter AL	930	
604775	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Min Tap Position	16L	
604776	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	YD000427	Yard	Retired Distribution	Yard Patrol Inspection	Ambient Temp	33	°F
604777	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	YD000427	Yard	Retired Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
604778	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	YD000427	Yard	Retired Distribution	Yard Patrol Inspection	Clear of Trash?	y	
604779	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
604780	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Ambient Temp	24	°F
604781	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
604782	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
604783	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Clear of Trash?	y	
604784	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
604785	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
604786	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
604787	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
604788	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
604789	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
604790	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	General Comments		
604791	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
604792	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
604793	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	General Comments		
604794	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
604795	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
604796	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
604797	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
604798	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Current Tap Position	10L	
604799	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
604800	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
604801	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
604802	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Switch Stick and Container OK?	y	
604803	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Vegetation	None	
604804	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
604805	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
604806	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
604807	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
604808	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
604809	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Fault Operations A Ø	0	
604810	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Fault Operations B Ø	0	
604811	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Fault Operations C Ø	0	
604812	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Fault Operations Ground	0	
604813	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Patrol Inspection	Follow-up Action Required?	n	
604814	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
604815	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
604816	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
604817	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	35	°C
604818	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	35	°C
604819	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	General Comments		
604820	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Foundation Condition	Good	
604821	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Follow-up Action Required?	n	
604822	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Follow-up Action Required?	n	
604823	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Operations Ground	0	
604824	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Operations C Ø	0	
604825	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Operations B Ø	0	
604826	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Operations A Ø	0	
604827	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
604828	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
604829	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
604830	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Equipment Properly Labeled?	y	
604831	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Cabinet Paint Condition	Good	
604832	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
604833	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
604834	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
604835	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Bushings Connection/Risers	Good	
604836	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Bushing Condition	Good	
604837	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Amps C Ø	144.0	
604838	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Amps B Ø	134.0	
604839	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Amps A Ø	150.0	
604840	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Accumulated Fault Duty C Ph V	.79	%
604841	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Accumulated Fault Duty B Ph V	1.19	%
604842	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
604843	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	9 Month Operations	2	
604844	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
604845	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	15.22	%
604846	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	13.84	%
604847	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	13.14	%
604848	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	180.0	
604849	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	180.0	
604850	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
604851	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
604852	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
604853	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
604854	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
604855	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
604856	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
604857	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
604858	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
604859	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
604860	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
604861	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
604862	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
604863	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Switching Operations	0	
604864	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Unknown Operations	0	
604865	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	YD000427	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
604866	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	9 Months Operations	2	
604867	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
604868	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
604869	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
604870	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
604871	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
604872	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
604873	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
604874	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
604875	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
604876	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
604877	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Amps A Ø	0.0	
604878	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Amps B Ø	0.0	
604879	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Amps C Ø	0.0	
604880	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
604881	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
604882	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
604883	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
604884	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Operations A Ø	0	
604885	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Operations B Ø	0	
604886	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Operations C Ø	0	
604887	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Operations Ground	0	
604888	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	YD000427	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
604889	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	YD000427	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
604890	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	YD000427	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
604891	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	YD000427	Yard	Retired Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
604892	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Unknown Operations	0	
604893	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Tank Paint Condition	Good	
604894	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Switching Operations	1	
604895	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Operations Counter AL	174	
604896	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	YD000427	Yard	Retired Distribution	Yard Patrol Inspection	General Comments		
604897	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	YD000427	Yard	Retired Distribution	Yard Patrol Inspection	Vegetation	None	
604898	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
604899	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
604900	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
604901	2/1/2019 9:54	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
604902	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Operations Counter AF	173	
604903	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Moisture and Leak Free?	y	
604904	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Maintenance Operations	0	
604905	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Grounds in Place?	y	
604906	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	General Comments		
604907	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
604908	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	25	°C
604909	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	40	°C
604910	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
604911	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
604912	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
604913	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	9 Months Operations	0	
604914	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
604915	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
604916	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
604917	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Amps A Ø	0.0	
604918	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Amps B Ø	0.0	
604919	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
604920	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
604921	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
604922	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
604923	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
604924	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
604925	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
604926	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Operations A Ø	0	
604927	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
604928	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
604929	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
604930	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
604931	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
604932	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
604933	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
604934	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
604935	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Foundation Condition	Good	
604936	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
604937	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
604938	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	Oil Temp Present	19	°C
604939	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	Oil Temp Max	45	°C
604940	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
604941	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
604942	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	LTC Totalizer Reading	2160.00	kw
604943	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
604944	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	General Comments	added nitrogen	
604945	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	General Comments		
604946	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
604947	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
604948	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
604949	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
604950	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
604951	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
604952	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
604953	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
604954	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
604955	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
604956	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
604957	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
604958	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	126	
604959	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
604960	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
604961	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
604962	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
604963	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	286.08	kw
604964	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
604965	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
604966	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
604967	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
604968	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
604969	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
604970	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
604971	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
604972	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
604973	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Tank Leaks	None	
604974	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
604975	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Operations Counter	5	
604976	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
604977	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
604978	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
604979	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
604980	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
604981	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	General Comments		
604982	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
604983	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Switching Operations	0	
604984	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
604985	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Foundation Condition	Good	
604986	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
604987	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
604988	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
604989	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	9 Months Operations	4	
604990	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Accumulated Fault Duty A Ph AM	3.80	%
604991	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Accumulated Fault Duty B Ph AM	3.80	%
604992	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Accumulated Fault Duty C Ph AM	3.80	%
604993	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Amps A Ø	10.0	
604994	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Amps B Ø	10.0	
604995	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Accumulated Fault Duty B Ph AM	.76	%
604996	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Accumulated Fault Duty A Ph AM	.76	%
604997	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	9 Months Operations	9	
604998	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC Max Tap Position	7R	
604999	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
605000	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC Min Tap Position	3R	
605001	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
605002	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Amps C Ø	10.0	
605003	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
605004	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
605005	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
605006	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
605007	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	General Comments		
605008	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Patrol Inspection	General Comments		
605009	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Follow-up Action Required?	n	
605010	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Patrol Inspection	Follow-up Action Required?	n	
605011	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Operations Ground	0	
605012	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Operations C Ø	0	
605013	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
605014	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
605015	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
605016	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
605017	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
605018	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	General Comments		
605019	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
605020	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	52	°C
605021	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	34	°C
605022	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
605023	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
605024	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
605025	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
605026	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
605027	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Operations A Ø	0	
605028	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
605029	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
605030	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
605031	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Patrol Inspection	Equipment Properly Labeled?	y	
605032	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Amps C Ø	180.0	
605033	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Amps B Ø	140.0	
605034	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Amps A Ø	180.0	
605035	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Accumulated Fault Duty C Ph V	33.00	%
605036	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Accumulated Fault Duty B Ph V	45.20	%
605037	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Accumulated Fault Duty A Ph V	44.48	%
605038	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	9 Month Operations	4	
605039	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
605040	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
605041	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
605042	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
605043	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Adequate	
605044	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
605045	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
605046	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
605047	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Operations Ground	0	
605048	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Follow-up Action Required?	n	
605049	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
605050	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
605051	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	General Comments		
605052	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	General Comments		
605053	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
605054	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	LTC Totalizer Reading	16899.84	kw
605055	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
605056	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
605057	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Oil Temp Max	40	°C
605058	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Oil Temp Present	28	°C
605059	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
605060	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
605061	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
605062	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
605063	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
605064	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
605065	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
605066	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
605067	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Totalizer Meter Reading	1.7604	
605068	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Winding Temp Max	40	°C
605069	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Winding Temp Present	28	°C
605070	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
605071	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
605072	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
605073	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
605074	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
605075	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
605076	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
605077	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
605078	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
605079	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
605080	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
605081	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
605082	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
605083	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
605084	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
605085	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
605086	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
605087	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
605088	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
605089	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
605090	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
605091	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Amps C Ø	80.0	
605092	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
605093	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
605094	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
605095	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
605096	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Switching Operations	0	
605097	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Unknown Operations	0	
605098	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
605099	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
605100	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
605101	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
605102	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
605103	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Amps B Ø	40.0	
605104	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Amps A Ø	44.0	
605105	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Patrol Inspection	Follow-up Action Required?	n	
605106	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Follow-up Action Required?	n	
605107	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Patrol Inspection	General Comments		
605108	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	General Comments		
605109	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Maintenance Operations	0	
605110	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Operations Counter AF	563	
605111	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Operations Counter AL	563	
605112	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Switching Operations	0	
605113	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Unknown Operations	0	
605114	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
605115	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
605116	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	General Comments	Battery check 27.9/25.5	
605117	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
605118	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
605119	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
605120	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
605121	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
605122	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
605123	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
605124	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
605125	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	General Comments		
605126	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Operations B Ø	0	
605127	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Operations C Ø	0	
605128	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
605129	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
605130	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
605131	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
605132	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
605133	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Amps C Ø	0.0	
605134	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Operations Ground	0	
605135	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Patrol Inspection	Follow-up Action Required?	n	
605136	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Follow-up Action Required?	n	
605137	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Patrol Inspection	General Comments		
605138	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	General Comments		
605139	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Maintenance Operations	0	
605140	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
605141	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
605142	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
605143	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
605144	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	Follow-up Action Required?	n	
605145	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
605146	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
605147	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
605148	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
605149	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
605150	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
605151	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
605152	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
605153	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
605154	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
605155	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Operations Counter AF	739	
605156	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
605157	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
605158	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
605159	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
605160	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Foundation Condition	Crumbling	
605161	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Follow-up Action Required?	y	
605162	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
605163	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
605164	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
605165	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
605166	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
605167	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Operations Counter AL	739	
605168	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	Oil Temp Max	49	°C
605169	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	Oil Temp Present	31	°C
605170	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
605171	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
605172	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
605173	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
605174	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
605175	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
605176	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
605177	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
605178	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
605179	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
605180	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Operations A Ø	0	
605181	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Operations B Ø	0	
605182	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Operations C Ø	0	
605183	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
605184	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
605185	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
605186	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
605187	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	General Comments	High side structure pad is crumbling.	
605188	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
605189	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
605190	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
605191	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	Totalizer Meter Reading	.9000	
605192	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
605193	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
605194	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
605195	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
605196	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
605197	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
605198	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
605199	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
605200	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
605201	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
605202	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
605203	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	General Comments		
605204	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
605205	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC As Found Counter	5533	
605206	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
605207	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
605208	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
605209	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
605210	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
605211	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
605212	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
605213	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Follow-up Action Required?	n	
605214	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
605215	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
605216	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	General Comments		
605217	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	General Comments		
605218	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
605219	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
605220	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
605221	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
605222	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Unknown Operations	0	
605223	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Tank Paint Condition	Good	
605224	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Switching Operations	0	
605225	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
605226	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
605227	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
605228	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
605229	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
605230	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Operations Counter AL	172	
605231	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Operations Counter AF	172	
605232	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
605233	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Maintenance Operations	0	
605234	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Grounds in Place?	y	
605235	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	General Comments		
605236	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	General Comments		
605237	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Foundation Condition	Good	
605238	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Follow-up Action Required?	n	
605239	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Follow-up Action Required?	n	
605240	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Operations Ground	0	
605241	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Operations C Ø	0	
605242	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Operations B Ø	0	
605243	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC As Left Counter	5533	
605244	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
605245	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	21	°C
605246	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	53	°C
605247	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
605248	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	General Comments		
605249	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
605250	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
605251	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
605252	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
605253	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
605254	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
605255	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
605256	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
605257	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
605258	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
605259	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
605260	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
605261	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
605262	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
605263	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
605264	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
605265	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
605266	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
605267	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
605268	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
605269	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Operations Counter AL	641	
605270	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Operations Counter AF	641	
605271	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Maintenance Operations	0	
605272	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	General Comments	one operation with no targets	
605273	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Patrol Inspection	General Comments		
605274	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Follow-up Action Required?	n	
605275	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Patrol Inspection	Follow-up Action Required?	n	
605276	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Fault Operations Ground	0	
605277	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Fault Operations C Ø	0	
605278	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	9 Month Operations	0	
605279	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	12.88	%
605280	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	12.88	%
605281	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	12.88	%
605282	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
605283	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
605284	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
605285	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
605286	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
605287	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	21	°C
605288	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	53	°C
605289	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
605290	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	21	°C
605291	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	53	°C
605292	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	21	°C
605293	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	53	°C
605294	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
605295	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
605296	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
605297	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
605298	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
605299	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
605300	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
605301	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
605302	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
605303	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
605304	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
605305	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
605306	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
605307	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
605308	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	Oil Temp Present	22	°C
605309	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	Oil Temp Max	32	°C
605310	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
605311	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
605312	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
605313	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
605314	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
605315	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
605316	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
605317	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
605318	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
605319	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
605320	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
605321	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Unknown Operations	0	
605322	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Switching Operations	0	
605323	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Operations Counter AL	498	
605324	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Operations Counter AF	498	
605325	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Maintenance Operations	0	
605326	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
605327	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Patrol Inspection	General Comments		
605328	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Unknown Operations	0	
605329	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
605330	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
605331	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
605332	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Switching Operations	0	
605333	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Operations Counter AL	165	
605334	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Operations Counter AF	165	
605335	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Maintenance Operations	0	
605336	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Ambient Temp	29	°F
605337	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
605338	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Follow-up Action Required?	n	
605339	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Patrol Inspection	Follow-up Action Required?	n	
605340	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Operations Ground	0	
605341	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Operations C Ø	0	
605342	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Clear of Trash?	y	
605343	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
605344	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
605345	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
605346	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
605347	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
605348	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
605349	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	General Comments		
605350	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
605351	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
605352	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Vegetation	None	
605353	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
605354	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
605355	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
605356	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
605357	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Bushing Condition	Good	
605358	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Operations B Ø	0	
605359	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Operations A Ø	0	
605360	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
605361	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
605362	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Amps C Ø	479.0	
605363	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Amps B Ø	486.0	
605364	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
605365	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
605366	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Amps C Ø	140.0	
605367	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Amps B Ø	130.0	
605368	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Amps A Ø	453.0	
605369	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Amps A Ø	140.0	
605370	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Accumulated Fault Duty C Ph AM	.76	%
605371	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.3576	
605372	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Fault Operations B Ø	0	
605373	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
605374	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
605375	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
605376	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
605377	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
605378	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Fault Operations A Ø	0	
605379	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
605380	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
605381	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
605382	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6R	
605383	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LTCC000588	LTCControl	MD-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
605384	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LTCC000588	LTCControl	MD-TRANS 3	LTC Control Insp	General Comments		
605385	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LTCC000588	LTCControl	MD-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
605386	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
605387	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	9 Month Operations	0	
605388	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
605389	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
605390	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
605391	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
605392	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
605393	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
605394	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
605395	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
605396	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
605397	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
605398	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
605399	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
605400	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
605401	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
605402	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	General Comments		
605403	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
605404	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	219	
605405	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	219	
605406	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Switching Operations	0	
605407	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
605408	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
605409	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
605410	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
605411	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
605412	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
605413	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
605414	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
605415	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
605416	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	9 Months Operations	0	
605417	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
605418	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
605419	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
605420	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Amps A Ø	0.0	
605421	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Amps B Ø	0.0	
605422	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Amps C Ø	0.0	
605423	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
605424	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
605425	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
605426	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
605427	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Operations A Ø	0	
605428	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Operations B Ø	0	
605429	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Operations C Ø	0	
605430	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	LTC Totalizer Reading	11443.20	kw
605431	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
605432	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
605433	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Oil Temp Max	35	°C
605434	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Oil Temp Present	30	°C
605435	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
605436	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
605437	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
605438	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
605439	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
605440	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
605441	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
605442	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
605443	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Operations Ground	0	
605444	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
605445	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Operations A Ø	0	
605446	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Follow-up Action Required?	n	
605447	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Patrol Inspection	General Comments		
605448	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	General Comments		
605449	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Maintenance Operations	0	
605450	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Operations Counter AF	315	
605451	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
605452	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
605453	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
605454	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Totalizer Meter Reading	1.1920	
605455	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
605456	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
605457	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Operations Counter AL	315	
605458	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Switching Operations	0	
605459	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Unknown Operations	0	
605460	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Amps B Ø	0.0	
605461	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Evidence of Insects	None	
605462	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
605463	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
605464	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Floor Swept?	y	
605465	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
605466	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
605467	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	General Comments		
605468	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
605469	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Trash Emptied?	y	
605470	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
605471	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Amps C Ø	0.0	
605472	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
605473	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
605474	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
605475	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
605476	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Vegetation	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
605477	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
605478	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
605479	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
605480	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	General Comments		
605481	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
605482	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Accumulated Fault Duty B Ph AM	3.05	%
605483	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
605484	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
605485	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
605486	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
605487	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
605488	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
605489	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
605490	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
605491	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
605492	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Accumulated Fault Duty A Ph AM	3.05	%
605493	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
605494	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0261	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
605495	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Operations Counter AL	119	
605496	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Switching Operations	0	
605497	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Unknown Operations	0	
605498	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Unknown Operations	0	
605499	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
605500	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Switching Operations	0	
605501	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
605502	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
605503	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Operations Counter AL	491	
605504	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Operations Counter AF	491	
605505	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
605506	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	32	
605507	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
605508	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
605509	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	General Comments		
605510	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Maintenance Operations	0	
605511	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Operations Counter AF	624	
605512	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Operations Counter AL	624	
605513	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Switching Operations	0	
605514	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Amps C Ø	150.0	
605515	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Amps B Ø	160.0	
605516	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Amps A Ø	150.0	
605517	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Accumulated Fault Duty B Ph AM	16.17	%
605518	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Accumulated Fault Duty A Ph AM	15.21	%
605519	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	9 Months Operations	3	
605520	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	25.33	
605521	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
605522	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
605523	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
605524	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
605525	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Accumulated Fault Duty C Ph AM	3.05	%
605526	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Operations B Ø	0	
605527	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Operations A Ø	0	
605528	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
605529	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
605530	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
605531	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
605532	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
605533	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
605534	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Unknown Operations	0	
605535	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	All Connections OK?	y	
605536	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	Follow-up Action Required?	n	
605537	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	General Comments		
605538	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	LTC Operation Checked?	y	
605539	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
605540	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
605541	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	108.0	
605542	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	47.94	%
605543	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
605544	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
605545	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Broom on Site?	y	
605546	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
605547	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
605548	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
605549	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	VRR Time Delay	30	Seconds
605550	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
605551	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
605552	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
605553	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Amps A Ø	0.0	
605554	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0261	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
605555	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0261	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
605556	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	28	
605557	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0261	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
605558	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0261	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
605559	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	33.32	%
605560	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.300	millivolts
605561	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Patrol Inspection	Equipment Properly Labeled?	y	
605562	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Amps C Ø	64.0	
605563	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0261	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
605564	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
605565	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Amps B Ø	61.0	
605566	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0261	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
605567	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
605568	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
605569	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
605570	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
605571	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
605572	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
605573	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
605574	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
605575	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
605576	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
605577	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
605578	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
605579	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
605580	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	11L	
605581	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Amps A Ø	64.0	
605582	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Accumulated Fault Duty C Ph V	20.61	%
605583	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
605584	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
605585	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
605586	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
605587	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
605588	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
605589	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
605590	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
605591	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
605592	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
605593	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
605594	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Accumulated Fault Duty B Ph V	28.35	%
605595	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Accumulated Fault Duty A Ph V	30.92	%
605596	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	9 Month Operations	2	
605597	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
605598	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.0	amps
605599	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
605600	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
605601	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
605602	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Maintenance Operations	0	
605603	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	General Comments		
605604	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Patrol Inspection	General Comments		
605605	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Follow-up Action Required?	n	
605606	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
605607	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
605608	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
605609	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	32	
605610	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
605611	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
605612	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Patrol Inspection	Follow-up Action Required?	n	
605613	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Operations Ground	0	
605614	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Operations C Ø	0	
605615	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
605616	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
605617	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	faults were wrote up as neutral targets	
605618	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
605619	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
605620	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
605621	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
605622	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Operations B Ø	0	
605623	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Operations A Ø	0	
605624	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
605625	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
605626	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
605627	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
605628	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
605629	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	General Comments		
605630	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
605631	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Ambient Temp	28	°F
605632	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	9 Months Operations	5	
605633	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
605634	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	General Comments		
605635	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
605636	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	50.38	%
605637	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
605638	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
605639	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
605640	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
605641	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
605642	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
605643	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
605644	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
605645	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
605646	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0261	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
605647	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0261	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
605648	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Amps C Ø	329.0	
605649	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
605650	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
605651	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Clear of Trash?	y	
605652	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
605653	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
605654	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
605655	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
605656	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
605657	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	957	
605658	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	949	
605659	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
605660	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
605661	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	9 Months Operations	0	
605662	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
605663	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
605664	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
605665	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
605666	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
605667	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Unknown Operations	2	
605668	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Switching Operations	0	
605669	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Operations Counter AL	735	
605670	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Operations Counter AF	735	
605671	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
605672	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
605673	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
605674	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Amps A Ø	747.0	
605675	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Amps B Ø	720.0	
605676	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Amps C Ø	722.0	
605677	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
605678	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Maintenance Operations	0	
605679	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	General Comments		
605680	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Patrol Inspection	General Comments		
605681	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
605682	2/4/2019 17:04	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
605683	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
605684	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Follow-up Action Required?	n	
605685	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Patrol Inspection	Follow-up Action Required?	n	
605686	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Operations Ground	0	
605687	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Operations C Ø	0	
605688	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
605689	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Amps A Ø	0.0	
605690	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Amps B Ø	0.0	
605691	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Amps C Ø	0.0	
605692	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
605693	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
605694	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
605695	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
605696	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
605697	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
605698	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
605699	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	General Comments	Lightning arrester on middle phase of line side circuit 4641 is blown.	
605700	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
605701	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
605702	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Foundation Condition	Good	
605703	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Follow-up Action Required?	y	
605704	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	9 Months Operations	1	
605705	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
605706	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
605707	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
605708	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
605709	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
605710	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
605711	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	189	
605712	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
605713	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
605714	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Operations Counter	444	
605715	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
605716	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	General Comments		
605717	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
605718	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
605719	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
605720	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
605721	2/1/2019 10:56	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
605722	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
605723	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
605724	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
605725	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
605726	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Amps C Ø	92.0	
605727	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Amps B Ø	28.0	
605728	2/1/2019 10:22	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Amps A Ø	20.0	
605729	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
605730	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
605731	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
605732	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
605733	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC Current Tap Position	4R	
605734	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
605735	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC As Left Counter	166284	
605736	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
605737	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
605738	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
605739	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Amps A Ø	330.0	
605740	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Amps B Ø	341.0	
605741	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
605742	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Clear of Trash?	y	
605743	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
605744	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
605745	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
605746	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
605747	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
605748	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0261	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
605749	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC As Found Counter	166284	
605750	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
605751	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
605752	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Tank Leaks	None	
605753	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
605754	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Regulator As Left Counter	128847	
605755	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
605756	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
605757	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
605758	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
605759	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
605760	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Min Tap Position	13L	
605761	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
605762	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
605763	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	General Comments		
605764	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
605765	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	General Comments		
605766	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
605767	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
605768	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
605769	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	9 Months Operations	0	
605770	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Operations A Ø	0	
605771	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Operations B Ø	0	
605772	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Operations C Ø	0	
605773	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Operations Ground	0	
605774	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Operations A Ø	0	
605775	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
605776	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
605777	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
605778	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
605779	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
605780	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Follow-up Action Required?	n	
605781	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
605782	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
605783	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
605784	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Patrol Inspection	General Comments		
605785	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	9 Months Operations	1	
605786	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
605787	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
605788	2/1/2019 12:09	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
605789	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
605790	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
605791	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Operations B Ø	0	
605792	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
605793	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Vegetation	None	
605794	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Operations A Ø	0	
605795	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	5	
605796	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	5	
605797	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
605798	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
605799	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
605800	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
605801	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
605802	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	General Comments		
605803	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
605804	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	DB0036	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	25.33	
605805	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Adjusted Amps C Phase AM	16.00	
605806	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Adjusted Amps B Phase AM	16.00	
605807	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Adjusted Amps A Phase AM	16.00	
605808	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
605809	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Amps C Ø	60.0	
605810	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Amps B Ø	60.0	
605811	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Amps A Ø	80.0	
605812	2/1/2019 14:30	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Accumulated Fault Duty C Ph AM	11.41	%
605813	2/1/2019 15:19	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Vegetation	None	
605814	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Operations Ground	0	
605815	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Operations C Ø	0	
605816	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Operations B Ø	0	
605817	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
605818	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	General Comments		
605819	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
605820	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
605821	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
605822	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
605823	2/1/2019 11:29	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
605824	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
605825	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
605826	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
605827	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Operations A Ø	0	
605828	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Operations B Ø	0	
605829	2/1/2019 10:56	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Operations C Ø	0	
605830	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
605831	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
605832	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
605833	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
605834	2/1/2019 13:32	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
605835	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
605836	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
605837	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
605838	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	Top Oil Temperature Present	45	°C
605839	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
605840	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
605841	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
605842	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
605843	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
605844	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
605845	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
605846	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
605847	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
605848	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
605849	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
605850	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
605851	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
605852	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
605853	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
605854	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Tank Paint Condition	Good	
605855	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Tank Leaks	None	
605856	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Surge Arrester Condition	Good	
605857	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
605858	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Reg Operation Checked?	y	
605859	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Reg Oil Level	Good	
605860	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
605861	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Moisture and Leak Free?	y	
605862	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Grounds in Place?	y	
605863	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	General Comments		
605864	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Gauge(s) Condition	Good	
605865	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Foundation Condition	Good	
605866	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Follow-up Action Required?	n	
605867	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
605868	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Current Tap Position	4R	
605869	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
605870	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
605871	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
605872	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
605873	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Bushing Condition	Good	
605874	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	General Comments	Extremely low on oil!	
605875	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	Top Oil Temperature Present	5	°C
605876	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	Top Oil Temperature Max	35	°C
605877	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
605878	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
605879	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	General Comments		
605880	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
605881	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
605882	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
605883	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
605884	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
605885	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
605886	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
605887	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
605888	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.1092	
605889	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
605890	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
605891	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
605892	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
605893	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Top Oil Temperature Present	5	°C
605894	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Top Oil Temperature Max	40	°C
605895	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
605896	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
605897	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
605898	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
605899	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
605900	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
605901	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
605902	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
605903	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
605904	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Vegetation	None	
605905	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
605906	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	65.52	kw
605907	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
605908	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
605909	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	General Comments		
605910	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	General Comments		
605911	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
605912	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
605913	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
605914	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
605915	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
605916	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
605917	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
605918	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
605919	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
605920	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
605921	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
605922	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
605923	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
605924	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
605925	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
605926	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
605927	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	General Comments		
605928	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
605929	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
605930	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
605931	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
605932	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
605933	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
605934	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
605935	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
605936	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
605937	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	47	
605938	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
605939	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
605940	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	63	
605941	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Amps C Ø	5.7	
605942	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Bushing Condition	Good	
605943	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
605944	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
605945	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
605946	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
605947	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Current Tap Position	5R	
605948	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
605949	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Follow-up Action Required?	n	
605950	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Foundation Condition	Good	
605951	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Gauge(s) Condition	Good	
605952	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	General Comments		
605953	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Grounds in Place?	y	
605954	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Max Tap Position	8R	
605955	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Min Tap Position	15L	
605956	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Moisture and Leak Free?	y	
605957	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
605958	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Reg Oil Level	Good	
605959	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Reg Operation Checked?	y	
605960	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
605961	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
605962	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Surge Arrester Condition	Good	
605963	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Tank Leaks	None	
605964	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Tank Paint Condition	Good	
605965	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
605966	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
605967	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
605968	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	General Comments		
605969	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
605970	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
605971	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
605972	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
605973	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
605974	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
605975	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
605976	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
605977	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
605978	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
605979	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
605980	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
605981	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
605982	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
605983	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
605984	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	446	
605985	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
605986	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
605987	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
605988	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
605989	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
605990	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
605991	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	General Comments		
605992	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Amps A Ø	7.6	
605993	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
605994	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
605995	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Clear of Trash?	y	
605996	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
605997	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
605998	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
605999	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	General Comments		
606000	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	General Comments		
606001	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Amps B Ø	8.3	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
606002	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
606003	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
606004	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Ambient Temp	18	°F
606005	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
606006	1/31/2019 11:31	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	General Comments		
606007	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
606008	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60	
606009	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55	
606010	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	Oil Temp Max	42	°C
606011	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	Oil Temp Present	30	°C
606012	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
606013	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
606014	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
606015	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
606016	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	General Comments		
606017	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
606018	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	General Comments		
606019	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
606020	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
606021	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
606022	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
606023	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
606024	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
606025	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
606026	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
606027	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
606028	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
606029	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
606030	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
606031	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
606032	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
606033	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
606034	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC Current Tap Position	5L	
606035	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
606036	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
606037	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
606038	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Amps A Ø	284.0	
606039	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
606040	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
606041	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
606042	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Operations Counter AF	191	
606043	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Amps B Ø	262.0	
606044	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Cabinet Paint Condition	Good	
606045	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Amps B Ø	0.0	
606046	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Equipment Properly Labeled?	y	
606047	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
606048	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
606049	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
606050	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Fault Operations A Ø	0	
606051	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Fault Operations B Ø	0	
606052	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Fault Operations C Ø	0	
606053	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Fault Operations Ground	0	
606054	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Follow-up Action Required?	n	
606055	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Follow-up Action Required?	n	
606056	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC Min Tap Position	6L	
606057	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
606058	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Switching Operations	0	
606059	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC Operations Since Last Insp	169	
606060	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
606061	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Amps C Ø	0.0	
606062	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
606063	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
606064	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
606065	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Foundation Condition	Good	
606066	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	General Comments		
606067	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	General Comments		
606068	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Grounds in Place?	y	
606069	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Tank Paint Condition	Good	
606070	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Unknown Operations	0	
606071	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Switching Operations	1	
606072	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Tank Paint Condition	Good	
606073	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Unknown Operations	0	
606074	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Operations Counter AL	191	
606075	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Moisture and Leak Free?	y	
606076	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
606077	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Equipment Properly Labeled?	y	
606078	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
606079	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
606080	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
606081	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
606082	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Operations A Ø	0	
606083	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Operations B Ø	0	
606084	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
606085	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Operations C Ø	0	
606086	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Operations Ground	0	
606087	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Follow-up Action Required?	n	
606088	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Follow-up Action Required?	n	
606089	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Cabinet Paint Condition	Good	
606090	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Foundation Condition	Good	
606091	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	General Comments		
606092	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
606093	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
606094	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Follow-up Action Required?	n	
606095	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Follow-up Action Required?	n	
606096	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Foundation Condition	Good	
606097	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	General Comments		
606098	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	General Comments		
606099	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Grounds in Place?	y	
606100	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Heaters (All) Functioning?	y	
606101	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Maintenance Operations	0	
606102	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Moisture and Leak Free?	y	
606103	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Operations Counter AF	196	
606104	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Operations Counter AL	196	
606105	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
606106	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Switching Operations	0	
606107	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Tank Paint Condition	Good	
606108	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Unknown Operations	0	
606109	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Bushings Connection/Risers	Good	
606110	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Bushing Condition	Good	
606111	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Amps C Ø	271.0	
606112	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	General Comments		
606113	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Grounds in Place?	y	
606114	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Maintenance Operations	0	
606115	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Moisture and Leak Free?	y	
606116	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Operations Counter AF	173	
606117	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Bushings Connection/Risers	Good	
606118	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Amps A Ø	0.0	
606119	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
606120	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
606121	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Operations Ground	0	
606122	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Operations C Ø	0	
606123	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Operations B Ø	0	
606124	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Operations A Ø	0	
606125	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
606126	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
606127	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
606128	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Equipment Properly Labeled?	y	
606129	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
606130	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	9 Month Operations	18	
606131	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
606132	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	9 Month Operations	0	
606133	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Bushing Condition	Good	
606134	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Amps C Ø	205.0	
606135	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Amps B Ø	199.0	
606136	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Amps A Ø	200.0	
606137	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
606138	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
606139	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
606140	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Cabinet Paint Condition	Good	
606141	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	9 Month Operations	0	
606142	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Unknown Operations	0	
606143	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Tank Paint Condition	Good	
606144	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Switching Operations	0	
606145	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
606146	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
606147	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
606148	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Bushings Connection/Risers	Good	
606149	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Bushing Condition	Good	
606150	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Amps C Ø	0.0	
606151	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Amps B Ø	0.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
606152	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Amps A Ø	0.0	
606153	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
606154	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
606155	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
606156	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	9 Month Operations	5	
606157	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Operations Counter AL	173	
606158	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Ambient Temp	18	°F
606159	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
606160	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
606161	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
606162	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
606163	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
606164	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
606165	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
606166	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
606167	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC Operations Since Last Insp	449	
606168	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	12	°C
606169	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
606170	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
606171	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
606172	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
606173	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
606174	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC Min Tap Position	8L	
606175	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Unknown Operations	0	
606176	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC Max Tap Position	2L	
606177	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC Current Tap Position	5L	
606178	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Tank Paint Condition	Good	
606179	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Switching Operations	0	
606180	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Operations Counter AL	138	
606181	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Operations Counter AF	138	
606182	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
606183	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Maintenance Operations	0	
606184	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Grounds in Place?	y	
606185	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	General Comments		
606186	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	General Comments		
606187	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Foundation Condition	Good	
606188	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Follow-up Action Required?	n	
606189	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Follow-up Action Required?	n	
606190	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Operations Ground	0	
606191	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Operations C Ø	0	
606192	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Operations B Ø	0	
606193	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Operations A Ø	0	
606194	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
606195	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
606196	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
606197	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
606198	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
606199	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
606200	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
606201	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
606202	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
606203	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Bushing Condition	Good	
606204	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Amps C Ø	821.0	
606205	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Amps B Ø	818.0	
606206	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Amps A Ø	814.0	
606207	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
606208	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
606209	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
606210	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
606211	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
606212	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
606213	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Totalizer Meter Reading	.8570	
606214	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
606215	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
606216	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
606217	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Cabinet Paint Condition	Good	
606218	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Equipment Properly Labeled?	y	
606219	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
606220	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Winding Temp Max	40	°C
606221	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Winding Temp Present	40	°C
606222	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
606223	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
606224	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
606225	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
606226	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
606227	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Operations B Ø	0	
606228	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Operations C Ø	0	
606229	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Operations Ground	0	
606230	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Follow-up Action Required?	n	
606231	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Follow-up Action Required?	n	
606232	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
606233	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Vegetation	None	
606234	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
606235	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
606236	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	General Comments		
606237	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
606238	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
606239	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Foundation Condition	Good	
606240	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	General Comments		
606241	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	General Comments		
606242	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
606243	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
606244	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
606245	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Grounds in Place?	y	
606246	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Maintenance Operations	4	
606247	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Moisture and Leak Free?	y	
606248	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Operations Counter AF	174	
606249	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Operations Counter AL	174	
606250	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Switching Operations	1	
606251	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Tank Paint Condition	Good	
606252	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Unknown Operations	0	
606253	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
606254	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
606255	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
606256	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
606257	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
606258	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
606259	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
606260	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
606261	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
606262	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Clear of Trash?	y	
606263	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
606264	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Winding Temp Present	22	°C
606265	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Winding Temp Max	22	°C
606266	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Totalizer Meter Reading	.9540	
606267	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
606268	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
606269	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
606270	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
606271	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
606272	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
606273	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
606274	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
606275	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
606276	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	General Comments		
606277	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
606278	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
606279	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
606280	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
606281	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
606282	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Unknown Operations	0	
606283	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Tank Paint Condition	Good	
606284	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Switching Operations	1	
606285	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Operations Counter AL	191	
606286	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	General Comments		
606287	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Operations Counter AF	191	
606288	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Moisture and Leak Free?	y	
606289	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
606290	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
606291	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Maintenance Operations	8	
606292	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Grounds in Place?	y	
606293	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	General Comments		
606294	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	General Comments		
606295	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
606296	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
606297	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
606298	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
606299	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
606300	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
606301	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
606302	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
606303	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Foundation Condition	Good	
606304	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Follow-up Action Required?	n	
606305	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Follow-up Action Required?	n	
606306	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Operations Ground	0	
606307	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Operations C Ø	0	
606308	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Operations B Ø	0	
606309	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Operations A Ø	0	
606310	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
606311	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
606312	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
606313	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Equipment Properly Labeled?	y	
606314	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Cabinet Paint Condition	Good	
606315	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
606316	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
606317	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
606318	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Bushings Connection/Risers	Good	
606319	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Bushing Condition	Good	
606320	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Amps C Ø	0.0	
606321	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Amps B Ø	0.0	
606322	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Amps A Ø	0.0	
606323	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	9 Month Operations	0	
606324	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
606325	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC As Left Counter	3370	
606326	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC As Found Counter	3370	
606327	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
606328	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
606329	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
606330	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
606331	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
606332	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Oil Temp Present	12	°C
606333	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Oil Temp Max	12	°C
606334	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
606335	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	General Comments		
606336	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	General Comments		
606337	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
606338	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	Follow-up Action Required?	n	
606339	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
606340	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
606341	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	VRR Time Delay	30	Seconds
606342	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
606343	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
606344	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
606345	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
606346	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
606347	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	LTC Operation Checked?	y	
606348	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	General Comments		
606349	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	Follow-up Action Required?	n	
606350	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	All Connections OK?	y	
606351	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
606352	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
606353	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
606354	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
606355	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Foundation Condition	Good	
606356	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
606357	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	General Comments		
606358	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
606359	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
606360	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
606361	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
606362	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
606363	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
606364	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Follow-up Action Required?	n	
606365	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
606366	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
606367	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
606368	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
606369	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	LTC Totalizer Reading	22896.00	kw
606370	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
606371	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	General Comments		
606372	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	9 Month Operations	42	
606373	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
606374	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
606375	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
606376	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
606377	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
606378	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	General Comments		
606379	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
606380	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Maintenance Operations	17	
606381	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
606382	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Operations Counter AF	171	
606383	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Operations Counter AL	171	
606384	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Switching Operations	0	
606385	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
606386	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Unknown Operations	0	
606387	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	9 Month Operations	15	
606388	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
606389	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
606390	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
606391	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Amps A Ø	466.0	
606392	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Amps B Ø	439.0	
606393	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Amps C Ø	475.0	
606394	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Bushing Condition	Good	
606395	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
606396	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
606397	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
606398	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
606399	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
606400	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
606401	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
606402	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
606403	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
606404	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Operations A Ø	0	
606405	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Operations B Ø	0	
606406	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Operations C Ø	0	
606407	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Operations Ground	0	
606408	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Follow-up Action Required?	n	
606409	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Follow-up Action Required?	n	
606410	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Foundation Condition	Good	
606411	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	General Comments		
606412	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	General Comments		
606413	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Grounds in Place?	y	
606414	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Maintenance Operations	6	
606415	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
606416	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Operations Counter AF	175	
606417	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
606418	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
606419	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
606420	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Operations Counter AL	175	
606421	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
606422	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
606423	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
606424	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
606425	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
606426	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
606427	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Operations Counter AL	175	
606428	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Operations Counter AF	175	
606429	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Moisture and Leak Free?	y	
606430	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Maintenance Operations	6	
606431	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Grounds in Place?	y	
606432	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	General Comments		
606433	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	General Comments		
606434	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Foundation Condition	Good	
606435	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Follow-up Action Required?	n	
606436	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Follow-up Action Required?	n	
606437	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Operations Ground	0	
606438	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Operations C Ø	0	
606439	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
606440	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC As Left Counter	97343	
606441	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC As Found Counter	97343	
606442	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	General Comments		
606443	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	General Comments		
606444	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
606445	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	Follow-up Action Required?	n	
606446	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Operations B Ø	0	
606447	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Operations A Ø	0	
606448	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
606449	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
606450	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Operations A Ø	0	
606451	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
606452	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Operations C Ø	0	
606453	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Operations Ground	0	
606454	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
606455	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Follow-up Action Required?	n	
606456	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
606457	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
606458	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Equipment Properly Labeled?	y	
606459	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Cabinet Paint Condition	Good	
606460	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
606461	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
606462	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
606463	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Bushings Connection/Risers	Good	
606464	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Amps C Ø	438.0	
606465	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Amps B Ø	451.0	
606466	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Amps A Ø	436.0	
606467	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
606468	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
606469	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
606470	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	9 Month Operations	7	
606471	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
606472	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	General Comments		
606473	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	9 Month Operations	55	
606474	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
606475	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
606476	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	All Connections OK?	y	
606477	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	Follow-up Action Required?	n	
606478	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
606479	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	General Comments		
606480	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
606481	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
606482	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
606483	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
606484	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
606485	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
606486	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
606487	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Amps A Ø	380.0	
606488	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Amps B Ø	366.0	
606489	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Amps C Ø	395.0	
606490	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	LTC Operation Checked?	y	
606491	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
606492	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
606493	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
606494	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	VRR Time Delay	30	Seconds
606495	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
606496	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
606497	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Oil Temp Present	25	°C
606498	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Oil Temp Max	25	°C
606499	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
606500	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
606501	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	LTC Totalizer Reading	20568.00	kw
606502	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
606503	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	General Comments		
606504	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	General Comments		
606505	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
606506	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Bushing Condition	Good	
606507	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
606508	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Follow-up Action Required?	n	
606509	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
606510	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
606511	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
606512	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Bushings Connection/Risers	Good	
606513	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
606514	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Unknown Operations	0	
606515	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Tank Paint Condition	Good	
606516	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Switching Operations	1	
606517	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
606518	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
606519	1/29/2019 15:32	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
606520	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	137	
606521	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
606522	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
606523	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
606524	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
606525	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
606526	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
606527	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
606528	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
606529	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
606530	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	137	
606531	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
606532	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
606533	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
606534	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
606535	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
606536	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
606537	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
606538	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
606539	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
606540	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
606541	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
606542	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
606543	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
606544	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
606545	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
606546	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
606547	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
606548	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
606549	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
606550	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
606551	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
606552	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
606553	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
606554	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
606555	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
606556	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
606557	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	482	
606558	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.63	%
606559	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.63	%
606560	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
606561	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
606562	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	482	
606563	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
606564	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
606565	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
606566	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
606567	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
606568	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
606569	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
606570	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.63	%
606571	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
606572	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
606573	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
606574	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
606575	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
606576	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
606577	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
606578	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
606579	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
606580	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
606581	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
606582	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
606583	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
606584	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
606585	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
606586	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
606587	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
606588	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
606589	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
606590	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
606591	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
606592	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
606593	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
606594	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
606595	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
606596	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
606597	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
606598	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	42	
606599	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	242	
606600	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
606601	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
606602	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
606603	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
606604	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
606605	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
606606	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
606607	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
606608	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
606609	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.81	%
606610	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	.81	%
606611	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.81	%
606612	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
606613	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
606614	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
606615	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
606616	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
606617	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
606618	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
606619	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
606620	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
606621	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
606622	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
606623	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
606624	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
606625	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
606626	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
606627	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
606628	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
606629	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	UG Pothead Condition Good?	y	
606630	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
606631	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Operating Linkage OK?	y	
606632	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
606633	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Steel Structures Rust Free?	y	
606634	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
606635	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Moisture and Leak Free?	y	
606636	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
606637	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
606638	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
606639	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
606640	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
606641	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Site Service Trans Condition	OK	
606642	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
606643	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
606644	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
606645	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
606646	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
606647	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Foundation Condition	Good	
606648	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
606649	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
606650	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	General Comments		
606651	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
606652	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
606653	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Linkage Grounds in Place?	y	
606654	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
606655	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
606656	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
606657	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
606658	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
606659	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
606660	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
606661	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
606662	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
606663	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
606664	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
606665	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
606666	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
606667	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
606668	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
606669	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
606670	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
606671	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Readings	LTC Totalizer Reading	499.20	kw
606672	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
606673	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
606674	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
606675	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	50	°C
606676	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
606677	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	121	
606678	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	121	
606679	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
606680	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
606681	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
606682	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
606683	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
606684	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
606685	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
606686	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
606687	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
606688	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
606689	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
606690	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
606691	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
606692	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
606693	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
606694	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
606695	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
606696	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	110.0	
606697	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	130.0	
606698	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
606699	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
606700	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
606701	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
606702	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
606703	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
606704	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
606705	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
606706	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
606707	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
606708	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
606709	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
606710	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
606711	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
606712	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
606713	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
606714	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
606715	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
606716	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	General Comments		
606717	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
606718	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
606719	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
606720	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
606721	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
606722	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
606723	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
606724	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
606725	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
606726	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
606727	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
606728	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
606729	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
606730	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
606731	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments		
606732	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
606733	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
606734	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
606735	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
606736	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	212262	
606737	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
606738	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	298	
606739	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
606740	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
606741	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
606742	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	212268	
606743	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
606744	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
606745	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
606746	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
606747	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
606748	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
606749	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
606750	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	110.0	
606751	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
606752	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
606753	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
606754	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
606755	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
606756	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
606757	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	146	
606758	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	146	
606759	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
606760	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
606761	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
606762	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
606763	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
606764	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
606765	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
606766	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
606767	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
606768	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
606769	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
606770	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
606771	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
606772	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
606773	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
606774	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
606775	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
606776	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
606777	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10.0	
606778	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
606779	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
606780	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
606781	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
606782	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000673	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	1	
606783	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
606784	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
606785	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
606786	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
606787	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
606788	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000676	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
606789	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
606790	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
606791	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
606792	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
606793	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
606794	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
606795	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
606796	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
606797	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Reading	.1040	
606798	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
606799	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
606800	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
606801	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
606802	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	141	
606803	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	141	
606804	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
606805	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	9L	
606806	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	Neutral	
606807	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
606808	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
606809	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
606810	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	LTCC000667	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
606811	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	LTCC000667	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
606812	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	LTCC000667	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
606813	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	LTCC000667	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
606814	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	LTCC000667	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
606815	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
606816	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	LTCC000667	LTCControl	930-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
606817	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	LTCC000667	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
606818	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	LTCC000667	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
606819	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
606820	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	LTCC000667	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
606821	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
606822	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
606823	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	4L	
606824	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0246	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
606825	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
606826	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
606827	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
606828	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BK000675	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
606829	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
606830	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
606831	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
606832	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC Operations Since Last Insp	974	
606833	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Follow-up Action Required?	n	
606834	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
606835	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
606836	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
606837	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
606838	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
606839	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
606840	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
606841	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
606842	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
606843	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
606844	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	Oil Temp Max	55	°C
606845	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
606846	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
606847	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
606848	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
606849	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
606850	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
606851	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
606852	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
606853	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
606854	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
606855	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
606856	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
606857	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
606858	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
606859	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
606860	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
606861	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	28	°F
606862	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
606863	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	General Comments		
606864	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	General Comments		
606865	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
606866	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
606867	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	Follow-up Action Required?	n	
606868	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
606869	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
606870	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
606871	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	Follow-up Action Required?	n	
606872	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
606873	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	General Comments		
606874	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Mechanism Patrol Inspection	General Comments		
606875	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC As Found Counter	94098	
606876	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC As Left Counter	94098	
606877	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
606878	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC Current Tap Position	4L	
606879	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
606880	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC Min Tap Position	5L	
606881	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC Operations Since Last Insp	29	
606882	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
606883	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
606884	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
606885	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
606886	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
606887	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
606888	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
606889	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
606890	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
606891	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
606892	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
606893	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
606894	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
606895	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
606896	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
606897	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
606898	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
606899	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
606900	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
606901	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
606902	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BCH000514	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
606903	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BCH000514	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
606904	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
606905	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
606906	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Winding Temp Present	15	°C
606907	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Winding Temp Max	28	°C
606908	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Totalizer Meter Reading	.099	
606909	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
606910	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
606911	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
606912	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
606913	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
606914	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
606915	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BCH000514	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
606916	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BCH000514	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
606917	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
606918	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
606919	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BCH000514	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
606920	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BCH000514	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
606921	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BCH000514	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
606922	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
606923	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
606924	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
606925	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
606926	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
606927	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Oil Temp Present	15	°C
606928	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Oil Temp Max	30	°C
606929	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
606930	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	LTC Totalizer Reading	1782	kw
606931	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
606932	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	General Comments		
606933	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	General Comments		
606934	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
606935	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
606936	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
606937	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
606938	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Vegetation	None	
606939	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
606940	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
606941	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	SWG000194	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
606942	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	SWG000194	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
606943	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	SWG000194	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
606944	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	SWG000194	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Evidence of Insects	None	
606945	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	SWG000194	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
606946	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	SWG000194	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Follow-up Action Required?	n	
606947	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	SWG000194	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
606948	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	SWG000194	Switchgear	Retired Distribution	Switchgear Patrol Inspection	General Comments		
606949	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	SWG000194	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
606950	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	SWG000194	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
606951	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	SWG000194	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Panel Lights OK?	y	
606952	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	SWG000194	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Panels Dusted?	y	
606953	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	SWG000194	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
606954	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
606955	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Foundation Condition	Good	
606956	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
606957	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	SWG000194	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
606958	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
606959	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	General Comments		
606960	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
606961	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
606962	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
606963	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
606964	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
606965	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
606966	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
606967	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
606968	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
606969	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
606970	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
606971	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	LTC Operation Checked?	y	
606972	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	General Comments		
606973	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	Follow-up Action Required?	n	
606974	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	All Connections OK?	y	
606975	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
606976	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
606977	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
606978	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BCH000613	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
606979	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
606980	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
606981	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
606982	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
606983	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
606984	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
606985	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
606986	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
606987	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
606988	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
606989	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
606990	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
606991	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
606992	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
606993	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
606994	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
606995	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
606996	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
606997	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
606998	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0	psi
606999	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC Min Tap Position	10L	
607000	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC Max Tap Position	2L	
607001	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC Current Tap Position	3L	
607002	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
607003	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC As Left Counter	55383	
607004	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC As Found Counter	55380	
607005	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	General Comments		
607006	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	General Comments		
607007	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
607008	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	Follow-up Action Required?	n	
607009	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
607010	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
607011	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
607012	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	General Comments		
607013	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
607014	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
607015	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	All Connections OK?	y	
607016	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	Follow-up Action Required?	n	
607017	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Ambient Temp	26	°F
607018	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
607019	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
607020	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Clear of Trash?	y	
607021	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	General Comments		
607022	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
607023	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
607024	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
607025	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
607026	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	LTC Operation Checked?	y	
607027	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
607028	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
607029	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
607030	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	VRR Time Delay	30	Seconds
607031	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BCH000613	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
607032	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BCH000613	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
607033	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BCH000613	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
607034	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BCH000613	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
607035	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
607036	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
607037	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BCH000613	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
607038	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
607039	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
607040	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
607041	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
607042	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	General Comments		
607043	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
607044	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
607045	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	General Comments		
607046	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
607047	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
607048	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Vegetation	None	
607049	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
607050	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
607051	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
607052	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Tank Paint Condition	Good	
607053	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
607054	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Moisture and Leak Free?	y	
607055	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Heaters (All) Functioning?	y	
607056	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Grounds in Place?	y	
607057	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
607058	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
607059	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	General Comments		
607060	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Foundation Condition	Good	
607061	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Follow-up Action Required?	n	
607062	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Equipment Properly Labeled?	y	
607063	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Cabinet Paint Condition	Good	
607064	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
607065	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
607066	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
607067	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
607068	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
607069	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
607070	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
607071	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
607072	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
607073	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
607074	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
607075	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
607076	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	VRR Base Voltage AF	124	VAC
607077	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
607078	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
607079	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
607080	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Follow-up Action Required?	n	
607081	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
607082	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
607083	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	General Comments		
607084	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
607085	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	General Comments		
607086	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
607087	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	LTC Totalizer Reading	8532	kw
607088	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
607089	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
607090	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Oil Temp Max	35	°C
607091	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
607092	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
607093	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
607094	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	26	°F
607095	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Bushing Condition	Good	
607096	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
607097	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
607098	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
607099	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
607100	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
607101	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
607102	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
607103	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
607104	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
607105	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
607106	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
607107	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
607108	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
607109	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0	VDC
607110	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	53.5	VDC
607111	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
607112	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
607113	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
607114	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
607115	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
607116	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
607117	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
607118	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
607119	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
607120	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
607121	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
607122	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
607123	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
607124	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
607125	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Follow-up Action Required?	n	
607126	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
607127	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	General Comments		
607128	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Grounds in Place?	y	
607129	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
607130	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
607131	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Tank Paint Condition	Good	
607132	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Ambient Temp	29	°F
607133	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
607134	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
607135	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Clear of Trash?	y	
607136	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
607137	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
607138	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
607139	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
607140	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	Follow-up Action Required?	n	
607141	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	General Comments		
607142	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	LTC Operation Checked?	y	
607143	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
607144	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	All Connections OK?	y	
607145	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
607146	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
607147	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
607148	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	VRR Base Voltage AF	124	VAC
607149	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Tank Paint Condition	Good	
607150	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Moisture and Leak Free?	y	
607151	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Heaters (All) Functioning?	y	
607152	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Grounds in Place?	y	
607153	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	VRR Base Voltage AL	124	VAC
607154	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	VRR Time Delay	30	Seconds
607155	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
607156	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
607157	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
607158	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
607159	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
607160	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	General Comments		
607161	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Foundation Condition	Good	
607162	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Follow-up Action Required?	n	
607163	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Equipment Properly Labeled?	y	
607164	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Cabinet Paint Condition	Good	
607165	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
607166	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
607167	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
607168	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Bushings Connection/Risers	Good	
607169	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
607170	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
607171	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
607172	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
607173	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
607174	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
607175	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20	
607176	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Winding Temp Present	23	°C
607177	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Winding Temp Max	37	°C
607178	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Bushing Condition	Good	
607179	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
607180	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Bushings Connection/Risers	Good	
607181	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Bushing Condition	Good	
607182	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
607183	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Totalizer Meter Reading	.474	
607184	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
607185	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
607186	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
607187	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
607188	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
607189	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
607190	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
607191	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
607192	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
607193	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
607194	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
607195	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
607196	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
607197	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
607198	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
607199	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
607200	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	VRR Base Voltage AL	124	VAC
607201	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	VRR Time Delay	30	Seconds

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
607202	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
607203	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
607204	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
607205	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
607206	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
607207	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
607208	1/24/2019 12:39	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	General Comments		
607209	1/25/2019 7:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Oil Temp Present	18	°C
607210	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	VRR Time Delay	0	Seconds
607211	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	All Connections OK?	y	
607212	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	Follow-up Action Required?	n	
607213	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	General Comments		
607214	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	LTC Operation Checked?	y	
607215	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
607216	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
607217	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
607218	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
607219	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	Follow-up Action Required?	n	
607220	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Follow-up Action Required?	n	
607221	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Follow-up Action Required?	n	
607222	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Operations Ground	0	
607223	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Operations C Ø	0	
607224	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
607225	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
607226	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
607227	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
607228	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Grounds in Place?	y	
607229	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
607230	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
607231	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
607232	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
607233	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
607234	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Bushing Condition	Good	
607235	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Amps C Ø	0	
607236	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
607237	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
607238	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
607239	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
607240	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Operations B Ø	0	
607241	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Amps B Ø	0	
607242	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	General Comments		
607243	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Amps A Ø	0	
607244	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	General Comments		
607245	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
607246	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
607247	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
607248	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
607249	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	9 Month Operations	0	
607250	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
607251	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Operations A Ø	0	
607252	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Operations B Ø	0	
607253	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Operations C Ø	0	
607254	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
607255	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Tank Paint Condition	Good	
607256	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
607257	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Operations Counter AL	323	
607258	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Operations A Ø	0	
607259	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
607260	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	150.0	
607261	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	9 Month Operations	6	
607262	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Accumulated Fault Duty A Ph V	0	%
607263	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	180.0	
607264	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	180.0	
607265	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Maintenance Operations	0	
607266	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Heaters (All) Functioning?	y	
607267	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Grounds in Place?	y	
607268	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	General Comments		
607269	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	General Comments		
607270	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Foundation Condition	Good	
607271	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
607272	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Cabinet Paint Condition	Good	
607273	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Equipment Properly Labeled?	y	
607274	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
607275	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Follow-up Action Required?	n	
607276	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Accumulated Fault Duty B Ph V	0	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
607277	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Accumulated Fault Duty C Ph V	0	%
607278	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Amps A Ø	300	
607279	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Amps B Ø	272	
607280	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Amps C Ø	295	
607281	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
607282	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
607283	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Operations A Ø	0	
607284	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Operations B Ø	0	
607285	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Operations C Ø	0	
607286	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Operations Ground	0	
607287	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Follow-up Action Required?	n	
607288	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Follow-up Action Required?	n	
607289	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Bushing Condition	Good	
607290	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Bushings Connection/Risers	Good	
607291	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
607292	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
607293	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
607294	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Cabinet Paint Condition	Good	
607295	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Equipment Properly Labeled?	y	
607296	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Adjusted Amps A Phase V	0	
607297	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Adjusted Amps B Phase V	0	
607298	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Foundation Condition	Good	
607299	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	General Comments		
607300	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	General Comments		
607301	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Grounds in Place?	y	
607302	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Adjusted Amps C Phase V	0	
607303	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Operations A Ø	0	
607304	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Operations B Ø	0	
607305	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Operations C Ø	0	
607306	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Heaters (All) Functioning?	y	
607307	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Maintenance Operations	0	
607308	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Operations Ground	0	
607309	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Follow-up Action Required?	n	
607310	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Follow-up Action Required?	n	
607311	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Foundation Condition	Good	
607312	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	General Comments		
607313	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	General Comments		
607314	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Grounds in Place?	y	
607315	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Maintenance Operations	0	
607316	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Moisture and Leak Free?	y	
607317	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Moisture and Leak Free?	y	
607318	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Operations Counter AF	173	
607319	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Operations Counter AL	175	
607320	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Switching Operations	2	
607321	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Tank Paint Condition	Good	
607322	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Unknown Operations	0	
607323	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Operations Counter AF	318	
607324	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
607325	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Follow-up Action Required?	n	
607326	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Operations Ground	0	
607327	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
607328	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
607329	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
607330	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
607331	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
607332	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
607333	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
607334	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC As Left Counter	198112	
607335	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC As Found Counter	198112	
607336	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Amps B Ø	300.0	
607337	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Amps A Ø	300.0	
607338	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Accumulated Fault Duty C Ph V	1.93	%
607339	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Accumulated Fault Duty B Ph V	1.93	%
607340	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Accumulated Fault Duty A Ph V	1.93	%
607341	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	9 Month Operations	5	
607342	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Unknown Operations	0	
607343	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Tank Paint Condition	Good	
607344	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Switching Operations	2	
607345	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Operations Counter AL	186	
607346	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
607347	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	General Comments		
607348	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
607349	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Operations Counter AF	184	
607350	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
607351	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
607352	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Grounds in Place?	y	
607353	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	General Comments		
607354	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	General Comments		
607355	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Foundation Condition	Good	
607356	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Follow-up Action Required?	n	
607357	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
607358	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Operations Ground	0	
607359	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Operations C Ø	0	
607360	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Operations B Ø	0	
607361	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Operations A Ø	0	
607362	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
607363	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
607364	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
607365	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
607366	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
607367	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
607368	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
607369	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
607370	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
607371	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
607372	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
607373	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
607374	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
607375	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
607376	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
607377	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
607378	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
607379	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
607380	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
607381	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
607382	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
607383	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Bushing Condition	Good	
607384	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Amps C Ø	0	
607385	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Amps B Ø	0	
607386	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Amps A Ø	0	
607387	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	.3	%
607388	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	.3	%
607389	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	.3	%
607390	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	9 Month Operations	6	
607391	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	VRR Time Delay	30	Seconds
607392	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
607393	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
607394	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
607395	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	LTC Operation Checked?	y	
607396	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	General Comments		
607397	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	Follow-up Action Required?	n	
607398	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	All Connections OK?	y	
607399	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
607400	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
607401	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
607402	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	9 Month Operations	6	
607403	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Accumulated Fault Duty A Ph V	5.79	%
607404	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Accumulated Fault Duty B Ph V	3.86	%
607405	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Accumulated Fault Duty C Ph V	3.86	%
607406	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Amps A Ø	175.0	
607407	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Amps B Ø	175.0	
607408	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Amps C Ø	145.0	
607409	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Bushing Condition	Good	
607410	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Bushings Connection/Risers	Good	
607411	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
607412	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
607413	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
607414	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Cabinet Paint Condition	Good	
607415	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Equipment Properly Labeled?	y	
607416	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
607417	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
607418	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
607419	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Operations A Ø	0	
607420	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Operations B Ø	0	
607421	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Operations C Ø	0	
607422	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Operations Ground	0	
607423	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Follow-up Action Required?	n	
607424	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Follow-up Action Required?	n	
607425	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Foundation Condition	Good	
607426	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
607427	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	General Comments		
607428	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Grounds in Place?	y	
607429	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Heaters (All) Functioning?	y	
607430	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Maintenance Operations	0	
607431	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Moisture and Leak Free?	y	
607432	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Operations Counter AF	222	
607433	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Operations Counter AL	226	
607434	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
607435	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Switching Operations	4	
607436	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Tank Paint Condition	Good	
607437	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Unknown Operations	0	
607438	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Unknown Operations	0	
607439	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Tank Paint Condition	Good	
607440	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Switching Operations	5	
607441	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
607442	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Operations Counter AL	520	
607443	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Operations Counter AF	515	
607444	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Moisture and Leak Free?	y	
607445	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Maintenance Operations	0	
607446	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Heaters (All) Functioning?	y	
607447	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Grounds in Place?	y	
607448	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	General Comments		
607449	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	General Comments		
607450	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Foundation Condition	Good	
607451	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Follow-up Action Required?	n	
607452	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Follow-up Action Required?	n	
607453	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Operations Ground	0	
607454	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Operations C Ø	0	
607455	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Operations B Ø	0	
607456	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Operations A Ø	0	
607457	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
607458	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
607459	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
607460	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Equipment Properly Labeled?	y	
607461	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Cabinet Paint Condition	Good	
607462	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
607463	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
607464	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
607465	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Bushings Connection/Risers	Good	
607466	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Bushing Condition	Good	
607467	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Amps C Ø	300.0	
607468	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
607469	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
607470	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Totalizer Meter Reading	0	
607471	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Winding Temp Max	25	°C
607472	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
607473	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
607474	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
607475	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
607476	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
607477	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
607478	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	6	
607479	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
607480	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	82	
607481	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	78	
607482	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	10	
607483	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
607484	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
607485	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
607486	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
607487	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	General Comments		
607488	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
607489	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
607490	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
607491	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
607492	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
607493	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
607494	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
607495	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
607496	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
607497	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
607498	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
607499	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
607500	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Bushing Condition	Good	
607501	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Amps C Ø	502	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
607502	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Amps B Ø	417	
607503	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Amps A Ø	460	
607504	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Accumulated Fault Duty C Ph V	.52	%
607505	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Accumulated Fault Duty B Ph V	.52	%
607506	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Accumulated Fault Duty A Ph V	.52	%
607507	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	9 Month Operations	8	
607508	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Bushings Connection/Risers	Good	
607509	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
607510	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
607511	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
607512	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
607513	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
607514	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
607515	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
607516	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
607517	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
607518	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
607519	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Cabinet Paint Condition	Good	
607520	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Equipment Properly Labeled?	y	
607521	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
607522	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
607523	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Unknown Operations	0	
607524	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Tank Paint Condition	Good	
607525	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Switching Operations	0	
607526	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Operations Counter AL	151	
607527	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Operations Counter AF	151	
607528	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
607529	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Maintenance Operations	0	
607530	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Grounds in Place?	y	
607531	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	General Comments		
607532	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	General Comments		
607533	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Foundation Condition	Good	
607534	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
607535	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
607536	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
607537	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
607538	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Unknown Operations	0	
607539	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Tank Paint Condition	Good	
607540	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Switching Operations	1	
607541	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Operations Counter AL	154	
607542	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Operations Counter AF	154	
607543	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
607544	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Maintenance Operations	0	
607545	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Grounds in Place?	y	
607546	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	General Comments		
607547	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	General Comments		
607548	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Foundation Condition	Good	
607549	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Follow-up Action Required?	n	
607550	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Follow-up Action Required?	n	
607551	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Operations Ground	0	
607552	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Operations C Ø	0	
607553	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Operations B Ø	0	
607554	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Operations A Ø	0	
607555	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	9 Month Operations	7	
607556	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Accumulated Fault Duty A Ph V	1.93	%
607557	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Accumulated Fault Duty B Ph V	1.93	%
607558	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
607559	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Amps A Ø	300.0	
607560	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	9 Month Operations	5	
607561	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Amps B Ø	300.0	
607562	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Amps C Ø	300.0	
607563	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Bushing Condition	Good	
607564	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Adjusted Amps C Phase V	0	
607565	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Adjusted Amps B Phase V	0	
607566	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Adjusted Amps A Phase V	0	
607567	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
607568	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
607569	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
607570	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Amps A Ø	0.0	
607571	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Amps B Ø	0.0	
607572	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Amps C Ø	0.0	
607573	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Bushing Condition	Good	
607574	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Bushings Connection/Risers	Good	
607575	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
607576	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
607577	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
607578	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
607579	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
607580	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
607581	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Follow-up Action Required?	n	
607582	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
607583	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
607584	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	General Comments		
607585	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	General Comments		
607586	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
607587	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	LTC Totalizer Reading	0	kw
607588	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
607589	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
607590	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Oil Temp Max	25	°C
607591	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Oil Temp Present	20	°C
607592	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
607593	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
607594	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
607595	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
607596	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
607597	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
607598	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
607599	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
607600	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
607601	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
607602	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
607603	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
607604	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
607605	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
607606	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
607607	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Accumulated Fault Duty B Ph V	0	%
607608	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Accumulated Fault Duty A Ph V	0	%
607609	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	9 Month Operations	3	
607610	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	Oil Temp Max	50	°C
607611	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
607612	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
607613	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	LTC Totalizer Reading	4112.00	kw
607614	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	9 Month Operations	0	
607615	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Accumulated Fault Duty A Ph V	0	%
607616	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Accumulated Fault Duty B Ph V	0	%
607617	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Accumulated Fault Duty C Ph V	0	%
607618	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Amps A Ø	0	
607619	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Amps B Ø	0	
607620	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Amps C Ø	0	
607621	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Bushing Condition	Good	
607622	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Bushings Connection/Risers	Good	
607623	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
607624	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
607625	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	General Comments		
607626	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
607627	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
607628	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
607629	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
607630	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	74	
607631	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	78	
607632	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
607633	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	5	
607634	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
607635	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
607636	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Accumulated Fault Duty A Ph V	0	%
607637	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	9 Month Operations	0	
607638	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	General Comments		
607639	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC As Found Counter	3074	
607640	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC As Left Counter	3074	
607641	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
607642	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC Current Tap Position	14L	
607643	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
607644	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	Follow-up Action Required?	n	
607645	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
607646	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
607647	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
607648	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
607649	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
607650	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Amps B Ø	0	
607651	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Amps C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
607652	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Bushing Condition	Good	
607653	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Bushings Connection/Risers	Good	
607654	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
607655	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
607656	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
607657	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Cabinet Paint Condition	Good	
607658	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Equipment Properly Labeled?	y	
607659	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Adjusted Amps A Phase V	0	
607660	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Adjusted Amps B Phase V	0	
607661	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Adjusted Amps C Phase V	0	
607662	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Operations A Ø	0	
607663	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Operations B Ø	0	
607664	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
607665	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Switching Operations	5	
607666	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Operations C Ø	0	
607667	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Tank Paint Condition	Good	
607668	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Cabinet Paint Condition	Good	
607669	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
607670	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
607671	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
607672	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Bushings Connection/Risers	Good	
607673	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Bushing Condition	Good	
607674	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Amps C Ø	0	
607675	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Amps B Ø	0	
607676	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Amps A Ø	0	
607677	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Accumulated Fault Duty C Ph V	0	%
607678	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Foundation Condition	Good	
607679	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Follow-up Action Required?	n	
607680	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Follow-up Action Required?	n	
607681	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Operations Ground	0	
607682	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	9 Month Operations	5	
607683	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Accumulated Fault Duty A Ph V	.37	%
607684	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Operations C Ø	0	
607685	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Operations B Ø	0	
607686	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	LTC Operation Checked?	n	
607687	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Operations A Ø	0	
607688	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Adjusted Amps C Phase V	0	
607689	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Adjusted Amps B Phase V	0	
607690	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Adjusted Amps A Phase V	0	
607691	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Equipment Properly Labeled?	y	
607692	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Accumulated Fault Duty B Ph V	.37	%
607693	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Accumulated Fault Duty C Ph V	.37	%
607694	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Amps A Ø	0	
607695	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Cabinet Paint Condition	Good	
607696	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
607697	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
607698	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
607699	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	LTC Output Voltage Level	0	VAC
607700	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
607701	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	VRR Base Voltage AL	224	VAC
607702	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	VRR Time Delay	30	Seconds
607703	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Accumulated Fault Duty B Ph V	0	%
607704	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Moisture and Leak Free?	y	
607705	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Operations Counter AF	56	
607706	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Operations Counter AL	60	
607707	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	120.0	
607708	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	180.0	
607709	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	150.0	
607710	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
607711	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
607712	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
607713	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
607714	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
607715	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
607716	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
607717	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
607718	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
607719	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Bushings Connection/Risers	Good	
607720	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Bushing Condition	Good	
607721	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
607722	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
607723	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
607724	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
607725	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	General Comments		
607726	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
607727	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
607728	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Amps C Ø	188	
607729	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Amps B Ø	159	
607730	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Amps A Ø	164	
607731	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Accumulated Fault Duty C Ph V	0	%
607732	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
607733	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
607734	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	Totalizer Meter Reading	.5140	
607735	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
607736	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
607737	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
607738	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
607739	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Cabinet Paint Condition	Good	
607740	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Equipment Properly Labeled?	y	
607741	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Adjusted Amps A Phase V	0	
607742	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Adjusted Amps B Phase V	0	
607743	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Adjusted Amps C Phase V	0	
607744	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Operations A Ø	0	
607745	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Operations B Ø	0	
607746	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Operations C Ø	0	
607747	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	General Comments		
607748	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
607749	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
607750	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	Follow-up Action Required?	n	
607751	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
607752	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	General Comments		
607753	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	General Comments		
607754	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Grounds in Place?	y	
607755	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Operations Ground	0	
607756	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Follow-up Action Required?	n	
607757	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Follow-up Action Required?	n	
607758	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Foundation Condition	Good	
607759	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	General Comments		
607760	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	General Comments		
607761	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Grounds in Place?	y	
607762	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Maintenance Operations	0	
607763	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Maintenance Operations	0	
607764	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Moisture and Leak Free?	y	
607765	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Moisture and Leak Free?	y	
607766	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Operations Counter AF	177	
607767	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Operations Counter AL	177	
607768	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Switching Operations	0	
607769	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Tank Paint Condition	Good	
607770	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
607771	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
607772	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	General Comments		
607773	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
607774	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
607775	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3	amps
607776	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133	VDC
607777	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133	VDC
607778	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
607779	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
607780	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
607781	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
607782	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
607783	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
607784	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
607785	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
607786	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
607787	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
607788	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
607789	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
607790	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
607791	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Operations Counter AF	174	
607792	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Operations Counter AL	174	
607793	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Switching Operations	0	
607794	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
607795	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	General Comments		
607796	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
607797	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Tank Paint Condition	Good	
607798	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Unknown Operations	0	
607799	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
607800	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	LTC Totalizer Reading	8960.00	kw
607801	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
607802	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
607803	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	Oil Temp Max	60	°C
607804	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Unknown Operations	0	
607805	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Unknown Operations	0	
607806	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
607807	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
607808	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	Totalizer Meter Reading	1.1200	
607809	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
607810	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
607811	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
607812	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
607813	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
607814	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Operations Ground	0	
607815	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Follow-up Action Required?	n	
607816	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Follow-up Action Required?	n	
607817	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Foundation Condition	Good	
607818	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
607819	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	General Comments		
607820	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
607821	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC Min Tap Position	9L	
607822	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
607823	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	34	°C
607824	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
607825	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC Operations Since Last Insp	306	
607826	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
607827	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
607828	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
607829	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Cabinet Paint Condition	Good	
607830	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
607831	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Equipment Properly Labeled?	y	
607832	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Adjusted Amps A Phase V	0	
607833	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Adjusted Amps B Phase V	0	
607834	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Adjusted Amps C Phase V	0	
607835	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Operations A Ø	0	
607836	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Operations B Ø	0	
607837	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Operations C Ø	0	
607838	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Operations Ground	0	
607839	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Follow-up Action Required?	n	
607840	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Follow-up Action Required?	n	
607841	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Foundation Condition	Good	
607842	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	General Comments		
607843	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	General Comments		
607844	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Grounds in Place?	y	
607845	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Maintenance Operations	0	
607846	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Moisture and Leak Free?	y	
607847	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Operations Counter AF	185	
607848	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Operations Counter AL	185	
607849	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Switching Operations	0	
607850	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Tank Paint Condition	Good	
607851	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Unknown Operations	0	
607852	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
607853	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	General Comments		
607854	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
607855	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	9 Month Operations	0	
607856	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Accumulated Fault Duty A Ph V	0	%
607857	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Accumulated Fault Duty B Ph V	0	%
607858	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Accumulated Fault Duty C Ph V	0	%
607859	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
607860	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
607861	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
607862	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
607863	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
607864	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
607865	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
607866	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
607867	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
607868	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Amps A Ø	0	
607869	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Amps B Ø	0	
607870	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Amps C Ø	0	
607871	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Bushing Condition	Good	
607872	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Bushings Connection/Risers	Good	
607873	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
607874	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
607875	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
607876	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
607877	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	General Comments	y	
607878	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
607879	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Foundation Condition	Good	
607880	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	All Connections OK?	y	
607881	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	Follow-up Action Required?	n	
607882	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	General Comments		
607883	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	LTC Operation Checked?	y	
607884	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
607885	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
607886	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC Operations Since Last Insp	285	
607887	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
607888	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
607889	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Follow-up Action Required?	n	
607890	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
607891	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
607892	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Ambient Temperature	40	°F
607893	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
607894	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	VRR Time Delay	30	Seconds
607895	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
607896	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
607897	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
607898	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
607899	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
607900	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Ambient Temperature	40	°F
607901	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
607902	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
607903	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
607904	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
607905	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
607906	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
607907	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Tank Paint Condition	Good	
607908	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Switching Operations	0	
607909	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Operations Counter AL	170	
607910	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Operations Counter AF	170	
607911	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Moisture and Leak Free?	y	
607912	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Maintenance Operations	0	
607913	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Grounds in Place?	y	
607914	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	General Comments		
607915	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
607916	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
607917	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
607918	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	General Comments		
607919	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
607920	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
607921	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
607922	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
607923	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
607924	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Foundation Condition	Good	
607925	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	Follow-up Action Required?	n	
607926	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	Follow-up Action Required?	n	
607927	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
607928	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
607929	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	General Comments		
607930	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
607931	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
607932	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	General Comments		
607933	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
607934	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
607935	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	General Comments		
607936	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	Follow-up Action Required?	n	
607937	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
607938	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC As Found Counter	10639	
607939	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
607940	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	General Comments		
607941	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
607942	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
607943	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Vegetation	None	
607944	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	General Comments		
607945	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC As Found Counter	24743	
607946	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC As Left Counter	24743	
607947	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	General Comments		
607948	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC As Left Counter	10639	
607949	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
607950	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC Current Tap Position	5L	
607951	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC Max Tap Position	2R	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
607952	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
607953	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
607954	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
607955	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
607956	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
607957	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC Current Tap Position	4L	
607958	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC Max Tap Position	2R	
607959	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC Min Tap Position	7L	
607960	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC Operations Since Last Insp	280	
607961	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
607962	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
607963	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Unknown Operations	0	
607964	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
607965	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
607966	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
607967	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
607968	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
607969	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
607970	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
607971	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
607972	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Tank Paint Condition	Good	
607973	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
607974	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
607975	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
607976	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC Min Tap Position	8L	
607977	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	General Comments		
607978	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
607979	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
607980	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
607981	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1700	psi
607982	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
607983	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
607984	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
607985	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
607986	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
607987	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
607988	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
607989	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
607990	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Unknown Operations	0	
607991	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Tank Paint Condition	Good	
607992	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Switching Operations	3	
607993	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Operations Counter AL	173	
607994	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Operations Counter AF	170	
607995	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Moisture and Leak Free?	y	
607996	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Clear of Trash?	y	
607997	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
607998	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Foundation Condition	Good	
607999	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
608000	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
608001	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
608002	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
608003	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
608004	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
608005	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Foundation Condition	Good	
608006	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Maintenance Operations	0	
608007	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Grounds in Place?	y	
608008	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	General Comments		
608009	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	General Comments		
608010	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
608011	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
608012	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
608013	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
608014	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
608015	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
608016	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	General Comments	y	
608017	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
608018	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Operations Ground	0	
608019	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Operations C Ø	0	
608020	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Operations B Ø	0	
608021	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	All Connections OK?	y	
608022	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	Follow-up Action Required?	n	
608023	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	General Comments		
608024	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Operations A Ø	0	
608025	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Adjusted Amps C Phase V	0	
608026	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Adjusted Amps B Phase V	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
608027	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Adjusted Amps A Phase V	0	
608028	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	General Comments		
608029	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Equipment Properly Labeled?	y	
608030	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Follow-up Action Required?	n	
608031	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
608032	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Follow-up Action Required?	n	
608033	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
608034	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
608035	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
608036	1/23/2019 8:04	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Follow-up Action Required?	n	
608037	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Unknown Operations	0	
608038	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Tank Paint Condition	Good	
608039	1/23/2019 12:09	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Switching Operations	5	
608040	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
608041	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
608042	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
608043	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
608044	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
608045	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
608046	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
608047	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
608048	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
608049	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BCH000583	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
608050	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BCH000583	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
608051	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	Follow-up Action Required?	n	
608052	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
608053	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
608054	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
608055	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
608056	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	General Comments	NO GROUP OR BANK SWITCH	
608057	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
608058	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
608059	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	Follow-up Action Required?	n	
608060	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
608061	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
608062	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
608063	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	LTC Totalizer Reading	6096.00	kw
608064	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
608065	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
608066	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BCH000583	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
608067	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BCH000583	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
608068	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
608069	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
608070	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
608071	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
608072	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
608073	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
608074	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
608075	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
608076	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
608077	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
608078	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
608079	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC As Left Counter	3382	
608080	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC As Found Counter	3382	
608081	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
608082	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
608083	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
608084	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
608085	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	General Comments		
608086	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	2233	
608087	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	2233	
608088	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	12	
608089	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
608090	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
608091	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
608092	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
608093	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
608094	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
608095	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
608096	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
608097	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
608098	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
608099	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
608100	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
608101	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
608102	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
608103	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
608104	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
608105	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
608106	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
608107	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
608108	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
608109	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC Current Tap Position	1L	
608110	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	LTC Totalizer Reading	7146.00	kw
608111	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
608112	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC Max Tap Position	3R	
608113	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Readings	General Comments		
608114	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC Min Tap Position	7L	
608115	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC Operations Since Last Insp	333	
608116	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
608117	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
608118	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
608119	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
608120	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
608121	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	General Comments	NO BANK OR GROUP SWITCH	
608122	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	General Comments		
608123	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
608124	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
608125	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	Oil Temp Max	45	°C
608126	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
608127	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
608128	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
608129	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
608130	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
608131	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
608132	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
608133	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
608134	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
608135	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	Totalizer Meter Reading	1.1910	
608136	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
608137	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Operations Counter AF	180	
608138	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Moisture and Leak Free?	y	
608139	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Maintenance Operations	0	
608140	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Grounds in Place?	y	
608141	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	General Comments		
608142	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	General Comments		
608143	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Foundation Condition	Good	
608144	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Follow-up Action Required?	n	
608145	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
608146	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
608147	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
608148	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Equipment Properly Labeled?	y	
608149	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Cabinet Paint Condition	Good	
608150	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
608151	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
608152	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
608153	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Bushings Connection/Risers	Good	
608154	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Bushing Condition	Good	
608155	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Amps C Ø	300.0	
608156	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Follow-up Action Required?	n	
608157	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Operations Ground	0	
608158	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Operations C Ø	0	
608159	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Operations B Ø	0	
608160	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Amps B Ø	240.0	
608161	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Amps A Ø	240.0	
608162	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
608163	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Operations A Ø	0	
608164	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
608165	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
608166	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
608167	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	9 Month Operations	12	
608168	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
608169	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
608170	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
608171	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	General Comments		
608172	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
608173	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
608174	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
608175	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Equipment Properly Labeled?	y	
608176	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
608177	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
608178	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
608179	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
608180	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Bushings Connection/Risers	Good	
608181	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Bushing Condition	Good	
608182	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
608183	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
608184	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Amps C Ø	217.0	
608185	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Amps B Ø	240.0	
608186	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Amps A Ø	265.0	
608187	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
608188	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
608189	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
608190	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	9 Month Operations	6	
608191	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
608192	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
608193	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
608194	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
608195	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
608196	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
608197	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
608198	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
608199	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
608200	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
608201	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	5	
608202	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
608203	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	484	
608204	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	484	
608205	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
608206	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
608207	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
608208	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
608209	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	General Comments		
608210	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
608211	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	General Comments		
608212	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
608213	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	Follow-up Action Required?	n	
608214	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
608215	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
608216	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
608217	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
608218	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
608219	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC Operations Since Last Insp	945	
608220	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
608221	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
608222	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
608223	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Vegetation	None	
608224	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
608225	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
608226	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
608227	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	General Comments		
608228	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
608229	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
608230	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
608231	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
608232	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
608233	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
608234	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Clear of Trash?	y	
608235	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
608236	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	29	°C
608237	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	29	°C
608238	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
608239	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
608240	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC Min Tap Position	8L	
608241	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC Max Tap Position	1R	
608242	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC Current Tap Position	4L	
608243	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
608244	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC As Left Counter	69705	
608245	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC As Found Counter	69705	
608246	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	General Comments		
608247	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	General Comments		
608248	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
608249	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	Follow-up Action Required?	n	
608250	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
608251	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
608252	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Tank Paint Condition	Good	
608253	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
608254	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
608255	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
608256	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
608257	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Switching Operations	0	
608258	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
608259	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Operations Counter AL	180	
608260	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
608261	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
608262	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
608263	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	General Comments		
608264	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Bushing Condition	Good	
608265	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	General Comments		
608266	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Foundation Condition	Good	
608267	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Amps C Ø	176.0	
608268	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Amps B Ø	174.0	
608269	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Amps A Ø	187.0	
608270	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Accumulated Fault Duty C Ph V	.81	%
608271	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Accumulated Fault Duty B Ph V	.41	%
608272	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Accumulated Fault Duty A Ph V	1.22	%
608273	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	9 Month Operations	3	
608274	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Follow-up Action Required?	n	
608275	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Follow-up Action Required?	n	
608276	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Operations Ground	0	
608277	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Operations C Ø	0	
608278	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Operations B Ø	0	
608279	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Operations A Ø	0	
608280	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
608281	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
608282	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
608283	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
608284	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
608285	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
608286	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
608287	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
608288	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	542	
608289	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	542	
608290	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
608291	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Operations A Ø	0	
608292	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Operations B Ø	0	
608293	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
608294	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
608295	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
608296	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
608297	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	Winding Temp Present	39	°C
608298	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	Winding Temp Max	40	°C
608299	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	Totalizer Meter Reading	.4070	
608300	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
608301	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
608302	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
608303	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
608304	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
608305	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
608306	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
608307	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
608308	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
608309	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
608310	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
608311	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Operations Counter AF	168	
608312	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Moisture and Leak Free?	y	
608313	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Maintenance Operations	0	
608314	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
608315	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
608316	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Grounds in Place?	y	
608317	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	General Comments		
608318	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	General Comments		
608319	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Foundation Condition	Good	
608320	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Follow-up Action Required?	n	
608321	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Follow-up Action Required?	n	
608322	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Operations Ground	0	
608323	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Operations C Ø	0	
608324	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Operations B Ø	0	
608325	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Operations A Ø	0	
608326	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
608327	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
608328	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
608329	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Equipment Properly Labeled?	y	
608330	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Cabinet Paint Condition	Good	
608331	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
608332	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
608333	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
608334	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Unknown Operations	0	
608335	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Tank Paint Condition	Good	
608336	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Switching Operations	0	
608337	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
608338	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
608339	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
608340	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Bushings Connection/Risers	Good	
608341	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Operations Counter AL	53	
608342	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Operations Counter AF	53	
608343	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
608344	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Maintenance Operations	0	
608345	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Grounds in Place?	y	
608346	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
608347	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
608348	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
608349	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
608350	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
608351	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
608352	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
608353	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	Oil Temp Present	29	°C
608354	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	Oil Temp Max	33	°C
608355	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
608356	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
608357	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	LTC Totalizer Reading	7326.00	kw
608358	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
608359	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	General Comments		
608360	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	General Comments		
608361	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
608362	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
608363	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	Follow-up Action Required?	n	
608364	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
608365	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
608366	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
608367	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
608368	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
608369	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
608370	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
608371	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
608372	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
608373	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
608374	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
608375	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
608376	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Bushing Condition	Good	
608377	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Amps C Ø	240.0	
608378	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Amps B Ø	240.0	
608379	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Amps A Ø	240.0	
608380	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Accumulated Fault Duty C Ph V	.70	%
608381	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
608382	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
608383	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
608384	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
608385	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
608386	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	9 Month Operations	0	
608387	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
608388	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
608389	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
608390	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
608391	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
608392	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Operations C Ø	0	
608393	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Operations Ground	0	
608394	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Follow-up Action Required?	n	
608395	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Follow-up Action Required?	n	
608396	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Foundation Condition	Good	
608397	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	General Comments		
608398	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	General Comments		
608399	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Grounds in Place?	y	
608400	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Maintenance Operations	0	
608401	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
608402	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
608403	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
608404	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
608405	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	240.0	
608406	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	300.0	
608407	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
608408	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
608409	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
608410	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
608411	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Operations Counter AF	680	
608412	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Operations Counter AL	680	
608413	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
608414	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Switching Operations	0	
608415	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Tank Paint Condition	Good	
608416	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Unknown Operations	0	
608417	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCC000592	LTCControl	472-1	LTC Control Insp	VRR Time Delay	30	Seconds
608418	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCC000592	LTCControl	472-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
608419	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCC000592	LTCControl	472-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
608420	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCC000592	LTCControl	472-1	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
608421	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCC000592	LTCControl	472-1	LTC Control Insp	LTC Operation Checked?	y	
608422	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCC000592	LTCControl	472-1	LTC Control Insp	General Comments		
608423	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCC000592	LTCControl	472-1	LTC Control Insp	Follow-up Action Required?	n	
608424	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCC000592	LTCControl	472-1	LTC Control Insp	All Connections OK?	y	
608425	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
608426	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
608427	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
608428	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
608429	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
608430	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
608431	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
608432	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
608433	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
608434	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
608435	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.71	%
608436	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	.85	%
608437	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.71	%
608438	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
608439	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
608440	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
608441	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
608442	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0022	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	240.0	
608443	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
608444	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
608445	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
608446	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
608447	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
608448	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
608449	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
608450	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
608451	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
608452	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
608453	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
608454	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	General Comments		
608455	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
608456	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
608457	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
608458	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
608459	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	All Connections OK?	y	
608460	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	Follow-up Action Required?	n	
608461	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	General Comments		
608462	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	LTC Operation Checked?	y	
608463	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
608464	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
608465	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Ambient Temp	41	°F
608466	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
608467	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Clear of Trash?	y	
608468	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
608469	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
608470	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
608471	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
608472	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
608473	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	Oil Temp Max	65	°C
608474	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
608475	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
608476	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
608477	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
608478	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
608479	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
608480	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
608481	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
608482	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
608483	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
608484	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	Totalizer Meter Reading	.6350	
608485	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
608486	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
608487	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BCH000583	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
608488	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BCH000583	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
608489	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BCH000583	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
608490	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	471	
608491	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	471	
608492	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
608493	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
608494	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
608495	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
608496	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
608497	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
608498	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
608499	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
608500	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
608501	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
608502	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
608503	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
608504	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
608505	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
608506	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
608507	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
608508	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
608509	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
608510	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
608511	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0364	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
608512	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	5L	
608513	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	2R	
608514	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	12L	
608515	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
608516	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	530	
608517	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
608518	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
608519	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
608520	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	9 Month Operations	6	
608521	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Accumulated Fault Duty A Ph V	3.50	%
608522	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Accumulated Fault Duty B Ph V	3.50	%
608523	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Accumulated Fault Duty C Ph V	1.75	%
608524	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Amps A Ø	30.0	
608525	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Amps B Ø	30.0	
608526	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Amps C Ø	30.0	
608527	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Bushing Condition	Good	
608528	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Bushings Connection/Risers	Good	
608529	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
608530	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
608531	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
608532	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Cabinet Paint Condition	Good	
608533	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Equipment Properly Labeled?	y	
608534	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
608535	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
608536	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
608537	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Unknown Operations	0	
608538	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Tank Paint Condition	Good	
608539	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Switching Operations	0	
608540	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Operations Counter AL	168	
608541	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
608542	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.85	%
608543	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
608544	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
608545	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
608546	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
608547	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
608548	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
608549	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
608550	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
608551	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
608552	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0365	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
608553	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
608554	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
608555	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
608556	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
608557	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	General Comments		
608558	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
608559	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
608560	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
608561	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Vegetation	None	
608562	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
608563	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
608564	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
608565	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
608566	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
608567	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	VRR Time Delay	30	Seconds
608568	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
608569	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
608570	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
608571	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
608572	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Foundation Condition	Good	
608573	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
608574	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
608575	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	General Comments		
608576	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
608577	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
608578	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
608579	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
608580	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
608581	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
608582	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
608583	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
608584	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
608585	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
608586	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
608587	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
608588	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
608589	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
608590	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	General Comments		
608591	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
608592	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	5416	
608593	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	5416	
608594	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
608595	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	Follow-up Action Required?	n	
608596	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
608597	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
608598	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
608599	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	General Comments		
608600	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	General Comments	NO GROUP OR BANK SWITCH	
608601	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Switching Operations	0	
608602	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
608603	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Operations Counter AL	313	
608604	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Operations Counter AF	313	
608605	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Moisture and Leak Free?	y	
608606	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Maintenance Operations	0	
608607	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Heaters (All) Functioning?	y	
608608	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Grounds in Place?	y	
608609	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	General Comments		
608610	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
608611	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
608612	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
608613	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
608614	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
608615	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0198	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
608616	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	General Comments		
608617	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Foundation Condition	Good	
608618	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Follow-up Action Required?	n	
608619	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Follow-up Action Required?	n	
608620	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Fault Operations Ground	0	
608621	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Fault Operations C Ø	1	
608622	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
608623	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
608624	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Fault Operations B Ø	1	
608625	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Fault Operations A Ø	0	
608626	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
608627	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Operations A Ø	0	
608628	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Operations B Ø	0	
608629	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Operations C Ø	0	
608630	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Operations Ground	0	
608631	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Follow-up Action Required?	n	
608632	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Fault Adjusted Amps C Phase V	16.96	
608633	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Fault Adjusted Amps B Phase V	16.96	
608634	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
608635	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Equipment Properly Labeled?	y	
608636	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Cabinet Paint Condition	Good	
608637	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
608638	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
608639	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
608640	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Follow-up Action Required?	n	
608641	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Foundation Condition	Good	
608642	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	General Comments		
608643	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	General Comments		
608644	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Grounds in Place?	y	
608645	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
608646	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
608647	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
608648	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
608649	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
608650	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
608651	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
608652	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
608653	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
608654	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
608655	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
608656	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
608657	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
608658	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
608659	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
608660	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
608661	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
608662	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
608663	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
608664	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
608665	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
608666	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	General Comments		
608667	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
608668	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
608669	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Foundation Condition	Good	
608670	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
608671	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
608672	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
608673	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
608674	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
608675	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
608676	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC Max Tap Position	5R	
608677	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC Min Tap Position	7L	
608678	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC Operations Since Last Insp	1364	
608679	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
608680	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
608681	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
608682	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
608683	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
608684	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Unknown Operations	0	
608685	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Tank Paint Condition	Good	
608686	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
608687	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
608688	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
608689	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
608690	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
608691	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
608692	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
608693	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
608694	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
608695	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
608696	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Amps B Ø	420.0	
608697	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Amps A Ø	370.0	
608698	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Accumulated Fault Duty C Ph V	1.26	%
608699	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Accumulated Fault Duty B Ph V	2.53	%
608700	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Accumulated Fault Duty A Ph V	1.26	%
608701	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	9 Month Operations	15	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
608702	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Unknown Operations	0	
608703	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Tank Paint Condition	Good	
608704	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Switching Operations	0	
608705	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
608706	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Operations Counter AL	296	
608707	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Operations Counter AF	296	
608708	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
608709	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Operations A Ø	0	
608710	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Operations B Ø	0	
608711	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Operations C Ø	0	
608712	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Operations Ground	0	
608713	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Moisture and Leak Free?	y	
608714	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Maintenance Operations	0	
608715	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Heaters (All) Functioning?	y	
608716	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Grounds in Place?	y	
608717	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	General Comments		
608718	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	General Comments		
608719	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Foundation Condition	Good	
608720	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Follow-up Action Required?	n	
608721	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Follow-up Action Required?	n	
608722	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
608723	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Follow-up Action Required?	n	
608724	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Follow-up Action Required?	n	
608725	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Foundation Condition	Good	
608726	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	General Comments		
608727	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	General Comments		
608728	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Grounds in Place?	y	
608729	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Heaters (All) Functioning?	y	
608730	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Maintenance Operations	0	
608731	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Moisture and Leak Free?	y	
608732	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Operations Counter AF	328	
608733	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Operations Counter AL	328	
608734	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
608735	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Switching Operations	0	
608736	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Tank Paint Condition	Good	
608737	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Unknown Operations	0	
608738	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Fault Operations Ground	0	
608739	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Fault Operations C Ø	0	
608740	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Fault Operations B Ø	0	
608741	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Fault Operations A Ø	0	
608742	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
608743	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
608744	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
608745	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Equipment Properly Labeled?	y	
608746	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Cabinet Paint Condition	Good	
608747	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Maintenance Operations	0	
608748	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Moisture and Leak Free?	y	
608749	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Operations Counter AF	208	
608750	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Operations Counter AL	208	
608751	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Switching Operations	0	
608752	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Tank Paint Condition	Good	
608753	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Unknown Operations	0	
608754	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
608755	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	LTC Totalizer Reading	6990.00	kw
608756	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
608757	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
608758	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	Oil Temp Max	60	°C
608759	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
608760	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
608761	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
608762	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
608763	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
608764	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Equipment Properly Labeled?	y	
608765	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Cabinet Paint Condition	Good	
608766	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
608767	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
608768	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
608769	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Bushings Connection/Risers	Good	
608770	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Bushing Condition	Good	
608771	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Amps C Ø	26.0	
608772	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Amps B Ø	33.0	
608773	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Amps A Ø	35.0	
608774	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Accumulated Fault Duty C Ph V	.41	%
608775	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Accumulated Fault Duty B Ph V	.41	%
608776	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Accumulated Fault Duty A Ph V	1.22	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
608777	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	9 Month Operations	2	
608778	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
608779	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	9 Month Operations	14	
608780	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
608781	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
608782	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Accumulated Fault Duty C Ph V	2.53	%
608783	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Amps A Ø	300.0	
608784	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Amps B Ø	300.0	
608785	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Amps C Ø	380.0	
608786	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
608787	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
608788	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	Totalizer Meter Reading	1.1650	
608789	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
608790	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
608791	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Bushing Condition	Good	
608792	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Bushings Connection/Risers	Good	
608793	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
608794	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
608795	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Bushings Connection/Risers	Good	
608796	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Bushing Condition	Good	
608797	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Amps C Ø	360.0	
608798	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
608799	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Positive DC Ground	22.0	VDC
608800	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Negative DC Ground	15.0	VDC
608801	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	General Comments		
608802	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
608803	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
608804	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
608805	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
608806	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
608807	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
608808	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
608809	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
608810	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC Current Tap Position	1L	
608811	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
608812	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
608813	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	41	°F
608814	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
608815	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
608816	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC As Left Counter	207145	
608817	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC As Found Counter	207145	
608818	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	General Comments		
608819	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	General Comments		
608820	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
608821	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
608822	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
608823	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
608824	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
608825	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
608826	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
608827	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
608828	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
608829	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
608830	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
608831	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
608832	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	Follow-up Action Required?	n	
608833	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	General Comments		
608834	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
608835	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
608836	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	VRR Time Delay	30	Seconds
608837	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
608838	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
608839	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
608840	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
608841	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
608842	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
608843	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
608844	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
608845	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
608846	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	31	
608847	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	31	
608848	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
608849	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
608850	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
608851	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
608852	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
608853	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
608854	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	General Comments		
608855	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
608856	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
608857	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
608858	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
608859	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
608860	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
608861	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
608862	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
608863	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	LTC Operation Checked?	y	
608864	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	General Comments		
608865	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	Follow-up Action Required?	n	
608866	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	All Connections OK?	y	
608867	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
608868	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
608869	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
608870	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
608871	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
608872	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
608873	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
608874	1/22/2019 14:22	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
608875	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
608876	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
608877	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
608878	1/22/2019 14:36	Distribution	Race Street Quarterly Inspection	BB0480	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
608879	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	98	
608880	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
608881	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
608882	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
608883	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	98	
608884	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
608885	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
608886	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
608887	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
608888	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
608889	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	484	
608890	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
608891	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
608892	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	140	
608893	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Heaters (All) Functioning?	y	
608894	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
608895	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
608896	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
608897	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
608898	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Amps C Ø	435.0	
608899	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
608900	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
608901	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Amps B Ø	350.0	
608902	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Maintenance Operations	0	
608903	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Moisture and Leak Free?	y	
608904	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Operations Counter AF	79	
608905	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Amps A Ø	415.0	
608906	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Operations Counter AL	79	
608907	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
608908	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	14L	
608909	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
608910	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
608911	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
608912	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
608913	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
608914	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	3.85	%
608915	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
608916	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	9 Month Operations	1	
608917	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
608918	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
608919	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	Follow-up Action Required?	y	
608920	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
608921	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
608922	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
608923	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Switching Operations	0	
608924	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Tank Paint Condition	Good	
608925	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Unknown Operations	0	
608926	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
608927	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
608928	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
608929	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
608930	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
608931	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
608932	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
608933	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
608934	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
608935	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
608936	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
608937	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
608938	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
608939	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	140	
608940	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
608941	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
608942	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	9 Month Operations	26	
608943	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LTCC000337	LTCControl	TA-TRANS 4	LTC Control Insp	General Comments		
608944	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Accumulated Fault Duty A Ph V	27.90	%
608945	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Accumulated Fault Duty B Ph V	28.70	%
608946	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
608947	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Accumulated Fault Duty C Ph V	27.10	%
608948	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
608949	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
608950	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	970	
608951	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	970	
608952	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
608953	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
608954	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
608955	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
608956	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
608957	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
608958	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
608959	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
608960	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
608961	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Amps A Ø	70.0	
608962	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
608963	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
608964	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
608965	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
608966	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
608967	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
608968	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
608969	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
608970	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
608971	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
608972	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
608973	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	85.0	
608974	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	80.0	
608975	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	80.0	
608976	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LTCC000337	LTCControl	TA-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
608977	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Amps B Ø	65.0	
608978	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Amps C Ø	70.0	
608979	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Patrol Inspection	Equipment Properly Labeled?	y	
608980	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
608981	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
608982	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
608983	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Operations A Ø	0	
608984	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Operations B Ø	0	
608985	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Operations C Ø	0	
608986	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
608987	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
608988	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
608989	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	2.41	%
608990	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	9.64	%
608991	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Operations Ground	0	
608992	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Patrol Inspection	Follow-up Action Required?	n	
608993	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Follow-up Action Required?	n	
608994	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Patrol Inspection	General Comments		
608995	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	General Comments		
608996	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Maintenance Operations	0	
608997	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Operations Counter AF	113	
608998	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Operations Counter AL	113	
608999	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
609000	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	10.84	%
609001	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	41	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
609002	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
609003	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Switching Operations	0	
609004	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Unknown Operations	0	
609005	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
609006	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
609007	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
609008	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	190.0	
609009	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	190.0	
609010	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	200.0	
609011	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	42.16	%
609012	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
609013	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
609014	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC Current Tap Position	7L	
609015	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
609016	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
609017	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
609018	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
609019	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Cabinet Paint Condition	Good	
609020	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Equipment Properly Labeled?	y	
609021	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Adjusted Amps A Phase V	67.08	
609022	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
609023	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
609024	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
609025	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	General Comments		
609026	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
609027	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
609028	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
609029	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
609030	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
609031	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
609032	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC Max Tap Position	1R	
609033	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC Min Tap Position	14L	
609034	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
609035	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	1664	
609036	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
609037	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
609038	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
609039	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
609040	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Operations A Ø	6	
609041	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	71	
609042	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	25.29	%
609043	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	26.50	%
609044	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
609045	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
609046	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
609047	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
609048	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
609049	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
609050	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
609051	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
609052	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
609053	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	PF000355	PowerFuse	TA-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
609054	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	PF000355	PowerFuse	TA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
609055	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	PF000354	PowerFuse	TA-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
609056	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	PF000354	PowerFuse	TA-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
609057	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
609058	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
609059	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
609060	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
609061	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
609062	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
609063	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
609064	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
609065	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	846	
609066	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	846	
609067	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
609068	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
609069	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
609070	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
609071	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
609072	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	9 Month Operations	25	
609073	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Accumulated Fault Duty A Ph V	5.58	%
609074	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
609075	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
609076	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
609077	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
609078	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
609079	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
609080	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
609081	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
609082	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
609083	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
609084	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
609085	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
609086	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
609087	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
609088	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
609089	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
609090	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
609091	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
609092	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
609093	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
609094	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
609095	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
609096	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
609097	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
609098	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Accumulated Fault Duty C Ph V	.80	%
609099	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Amps A Ø	0.0	
609100	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Amps B Ø	0.0	
609101	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
609102	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
609103	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	General Comments		
609104	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
609105	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC As Found Counter	58991	
609106	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Amps C Ø	0.0	
609107	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Bushing Condition	Good	
609108	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Bushings Connection/Risers	Good	
609109	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC As Left Counter	58991	
609110	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
609111	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
609112	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
609113	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
609114	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
609115	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
609116	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
609117	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	1265	
609118	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
609119	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
609120	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
609121	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
609122	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	General Comments		
609123	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
609124	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Follow-up Action Required?	n	
609125	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
609126	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
609127	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC As Left Counter	222086	
609128	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC As Found Counter	222086	
609129	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	General Comments	could not read indicator, need to replace glass	
609130	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Unknown Operations	0	
609131	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Switching Operations	0	
609132	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
609133	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Operations Counter AL	68	
609134	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Operations Counter AF	68	
609135	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Maintenance Operations	0	
609136	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	General Comments		
609137	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Patrol Inspection	General Comments		
609138	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Follow-up Action Required?	n	
609139	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
609140	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	28	
609141	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	7.23	%
609142	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	2.41	%
609143	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	4.82	%
609144	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	80.0	
609145	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	80.0	
609146	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	90.0	
609147	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
609148	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
609149	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC As Found Counter	15688	
609150	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC As Left Counter	15688	
609151	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
609152	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Operations C Ø	0	
609153	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Foundation Condition	Good	
609154	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
609155	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Operations B Ø	0	
609156	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	General Comments		
609157	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Operations A Ø	0	
609158	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	General Comments		
609159	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Grounds in Place?	y	
609160	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
609161	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
609162	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
609163	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
609164	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
609165	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	250.0	
609166	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	190.0	
609167	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	200.0	
609168	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
609169	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Tank Paint Condition	Good	
609170	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Switching Operations	2	
609171	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
609172	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	148	
609173	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	148	
609174	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
609175	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
609176	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
609177	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
609178	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	65	°C
609179	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
609180	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	75	°C
609181	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	°C
609182	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Operations B Ø	0	
609183	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Operations C Ø	0	
609184	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
609185	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
609186	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	725	
609187	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	725	
609188	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
609189	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	carded out	
609190	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
609191	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
609192	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
609193	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
609194	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
609195	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
609196	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
609197	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
609198	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
609199	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Operations Ground	0	
609200	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Follow-up Action Required?	n	
609201	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
609202	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
609203	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
609204	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
609205	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Grounds in Place?	y	
609206	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	General Comments		
609207	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
609208	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
609209	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
609210	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
609211	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
609212	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
609213	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
609214	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	215.0	
609215	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
609216	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
609217	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	580.0	
609218	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Unknown Operations	5	
609219	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	510.0	
609220	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Tank Paint Condition	Good	
609221	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	510.0	
609222	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	2.60	%
609223	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	2.60	%
609224	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	2.60	%
609225	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
609226	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
609227	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
609228	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Switching Operations	0	
609229	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
609230	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
609231	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
609232	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	Oil Temp Present	30	°C
609233	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Operations Counter AL	87	
609234	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Operations Counter AF	87	
609235	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Moisture and Leak Free?	y	
609236	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Maintenance Operations	0	
609237	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Heaters (All) Functioning?	y	
609238	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
609239	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	210.0	
609240	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	2.41	%
609241	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	2.41	%
609242	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	1.20	%
609243	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Unknown Operations	0	
609244	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
609245	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Switching Operations	0	
609246	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
609247	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
609248	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
609249	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
609250	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
609251	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Grounds in Place?	y	
609252	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	General Comments		
609253	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	General Comments		
609254	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Foundation Condition	Good	
609255	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Follow-up Action Required?	n	
609256	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Follow-up Action Required?	n	
609257	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Operations Ground	0	
609258	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Operations C Ø	0	
609259	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Operations B Ø	0	
609260	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	Oil Temp Max	60	°C
609261	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	General Comments		
609262	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	General Comments		
609263	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Grounds in Place?	y	
609264	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Heaters (All) Functioning?	y	
609265	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Maintenance Operations	0	
609266	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Moisture and Leak Free?	y	
609267	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Operations Counter AF	48	
609268	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Operations Counter AL	48	
609269	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Amps B Ø	200.0	
609270	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Amps A Ø	200.0	
609271	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
609272	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
609273	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
609274	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Switching Operations	0	
609275	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Tank Paint Condition	Good	
609276	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Unknown Operations	0	
609277	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Accumulated Fault Duty A Ph V	.80	%
609278	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	9 Month Operations	19	
609279	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	PF000350	PowerFuse	TA-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
609280	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	PF000350	PowerFuse	TA-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	OK	
609281	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	PF000351	PowerFuse	TA-12KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
609282	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
609283	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
609284	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	PF000351	PowerFuse	TA-12KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	OK	
609285	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	PF000352	PowerFuse	TA-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
609286	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	PF000352	PowerFuse	TA-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	OK	
609287	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	PF000353	PowerFuse	TA-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
609288	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
609289	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	27.00	
609290	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
609291	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
609292	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
609293	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	PF000353	PowerFuse	TA-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	OK	
609294	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	27.00	
609295	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
609296	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
609297	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
609298	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
609299	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
609300	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
609301	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
609302	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
609303	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
609304	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
609305	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
609306	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
609307	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
609308	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
609309	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
609310	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
609311	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
609312	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
609313	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
609314	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
609315	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
609316	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
609317	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
609318	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
609319	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
609320	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
609321	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	Oil Temp Present	35	°C
609322	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	Oil Temp Max	85	°C
609323	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Accumulated Fault Duty C Ph V	7.17	%
609324	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
609325	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
609326	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
609327	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	General Comments		
609328	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
609329	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
609330	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
609331	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
609332	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
609333	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
609334	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
609335	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
609336	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
609337	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
609338	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
609339	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
609340	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
609341	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
609342	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
609343	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
609344	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
609345	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
609346	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
609347	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
609348	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
609349	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
609350	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
609351	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
609352	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
609353	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
609354	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	9 Month Operations	14	
609355	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
609356	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Amps B Ø	200.0	
609357	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Amps A Ø	200.0	
609358	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
609359	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
609360	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
609361	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Amps C Ø	470.0	
609362	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Amps B Ø	490.0	
609363	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Amps A Ø	490.0	
609364	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
609365	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
609366	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
609367	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
609368	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1279	
609369	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1279	
609370	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Operations A Ø	0	
609371	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Adjusted Amps C Phase V	55.90	
609372	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Adjusted Amps B Phase V	55.90	
609373	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Adjusted Amps A Phase V	55.90	
609374	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Equipment Properly Labeled?	y	
609375	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Operations Counter AL	38	
609376	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Operations Counter AF	38	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
609377	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
609378	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Maintenance Operations	0	
609379	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
609380	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Cabinet Paint Condition	Good	
609381	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
609382	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
609383	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
609384	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
609385	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	General Comments		
609386	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	General Comments		
609387	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
609388	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
609389	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
609390	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Operations Ground	0	
609391	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
609392	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
609393	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
609394	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
609395	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
609396	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
609397	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
609398	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	General Comments		
609399	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
609400	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
609401	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Bushings Connection/Risers	Good	
609402	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Bushing Condition	Good	
609403	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	9 Month Operations	30	
609404	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Accumulated Fault Duty A Ph V	7.17	%
609405	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Accumulated Fault Duty B Ph V	3.99	%
609406	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	45	°C
609407	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	100	°C
609408	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Amps C Ø	200.0	
609409	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
609410	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
609411	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
609412	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	20	°C
609413	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	55	°C
609414	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
609415	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
609416	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
609417	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Cabinet Paint Condition	Good	
609418	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LTCC000337	LTCControl	TA-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
609419	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LTCC000336	LTCControl	TA-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
609420	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LTCC000336	LTCControl	TA-TRANS 1	LTC Control Insp	General Comments		
609421	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LTCC000336	LTCControl	TA-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
609422	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	1	
609423	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
609424	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99964	
609425	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99964	
609426	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
609427	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
609428	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
609429	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
609430	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
609431	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
609432	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
609433	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
609434	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
609435	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
609436	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
609437	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
609438	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
609439	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	30	°C
609440	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	70	°C
609441	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	30	°C
609442	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	70	°C
609443	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	30	°C
609444	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	70	°C
609445	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
609446	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
609447	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
609448	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
609449	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
609450	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LTCC000335	LTCControl	TA-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
609451	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LTCC000335	LTCControl	TA-TRANS 3	LTC Control Insp	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
609452	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
609453	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LTCC000335	LTCControl	TA-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
609454	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
609455	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
609456	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
609457	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
609458	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
609459	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
609460	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Foundation Condition	Good	
609461	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
609462	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
609463	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
609464	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
609465	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
609466	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
609467	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	111.80	
609468	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
609469	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
609470	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	10	
609471	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
609472	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
609473	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
609474	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
609475	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
609476	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
609477	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1073	
609478	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1073	
609479	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
609480	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
609481	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
609482	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
609483	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
609484	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
609485	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
609486	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
609487	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
609488	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
609489	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
609490	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
609491	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
609492	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
609493	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
609494	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
609495	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Bushing Condition	Good	
609496	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
609497	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
609498	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
609499	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
609500	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
609501	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
609502	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations	11	
609503	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Equipment Properly Labeled?	y	
609504	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
609505	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
609506	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
609507	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
609508	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
609509	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
609510	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
609511	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
609512	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	6.02	%
609513	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	7.23	%
609514	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	13.25	%
609515	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	17	
609516	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
609517	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
609518	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
609519	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
609520	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Bushings Connection/Risers	Good	
609521	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Bushing Condition	Good	
609522	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
609523	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
609524	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
609525	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Amps C Ø	150.0	
609526	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
609527	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
609528	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
609529	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
609530	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
609531	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Operations A Ø	0	
609532	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Operations B Ø	0	
609533	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Operations C Ø	0	
609534	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Operations Ground	0	
609535	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
609536	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Follow-up Action Required?	n	
609537	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
609538	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
609539	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	27.00	
609540	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Follow-up Action Required?	n	
609541	1/21/2019 14:44	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Foundation Condition	Good	
609542	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
609543	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
609544	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
609545	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
609546	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
609547	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
609548	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
609549	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Cabinet Paint Condition	Good	
609550	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
609551	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
609552	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
609553	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Equipment Properly Labeled?	y	
609554	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
609555	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
609556	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
609557	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
609558	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
609559	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	PF001213	PowerFuse	060-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
609560	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	PF001213	PowerFuse	060-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	OK	
609561	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Readings	General Comments		
609562	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
609563	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
609564	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
609565	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
609566	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
609567	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
609568	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
609569	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Clear of Trash?	y	
609570	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
609571	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
609572	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
609573	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Oil Temp Max	50	°C
609574	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
609575	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
609576	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
609577	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
609578	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
609579	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
609580	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
609581	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
609582	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
609583	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	62	
609584	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
609585	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
609586	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
609587	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
609588	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
609589	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
609590	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	General Comments		
609591	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
609592	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
609593	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	39	
609594	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
609595	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
609596	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Vegetation	None	
609597	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	331	
609598	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	331	
609599	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
609600	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
609601	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
609602	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
609603	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	General Comments		
609604	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	256.32	kw
609605	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
609606	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
609607	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Tank Leaks	None	
609608	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
609609	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Winding Temp Max	55	°C
609610	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
609611	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
609612	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
609613	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
609614	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Totalizer Meter Reading	.8180	
609615	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
609616	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
609617	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
609618	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
609619	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
609620	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
609621	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
609622	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
609623	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
609624	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
609625	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
609626	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
609627	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
609628	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
609629	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
609630	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
609631	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
609632	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
609633	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Regulator As Left Counter	374059	
609634	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
609635	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
609636	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
609637	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
609638	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	PF001214	PowerFuse	060-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
609639	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	PF001214	PowerFuse	060-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	OK	
609640	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
609641	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
609642	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
609643	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
609644	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
609645	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
609646	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
609647	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
609648	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
609649	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
609650	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC As Left Counter	25177	
609651	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
609652	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
609653	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC As Found Counter	25177	
609654	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	General Comments		
609655	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
609656	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	General Comments		
609657	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
609658	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Unknown Operations	0	
609659	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	36	
609660	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	1.3	
609661	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	.6	
609662	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	14.0	
609663	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
609664	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
609665	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
609666	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
609667	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
609668	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
609669	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
609670	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
609671	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
609672	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
609673	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
609674	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	General Comments		
609675	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
609676	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
609677	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
609678	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
609679	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
609680	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
609681	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	Follow-up Action Required?	n	
609682	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
609683	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
609684	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
609685	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
609686	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
609687	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	General Comments	NO BANK OR GROUP SWITCH	
609688	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
609689	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
609690	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
609691	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
609692	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
609693	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	296	
609694	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	300	
609695	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
609696	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
609697	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
609698	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
609699	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
609700	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
609701	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
609702	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
609703	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
609704	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	160.0	
609705	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
609706	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
609707	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
609708	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
609709	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
609710	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
609711	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
609712	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
609713	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
609714	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
609715	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
609716	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
609717	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
609718	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
609719	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
609720	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
609721	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
609722	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
609723	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	General Comments		
609724	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
609725	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
609726	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Min Tap Position	3L	
609727	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
609728	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
609729	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
609730	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
609731	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
609732	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Regulator As Left Counter	151720	
609733	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
609734	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
609735	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Tank Leaks	None	
609736	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	23156	
609737	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
609738	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	23152	
609739	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC Operations Since Last Insp	322	
609740	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC Min Tap Position	13L	
609741	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
609742	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	VRR Time Delay	30	Seconds
609743	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
609744	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
609745	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
609746	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	LTC Operation Checked?	y	
609747	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	General Comments		
609748	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	Follow-up Action Required?	n	
609749	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	All Connections OK?	y	
609750	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	Follow-up Action Required?	n	
609751	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
609752	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Operations Counter AL	259	
609753	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
609754	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
609755	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
609756	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Follow-up Action Required?	n	
609757	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Operations Counter AF	258	
609758	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Moisture and Leak Free?	y	
609759	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
609760	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
609761	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
609762	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Maintenance Operations	0	
609763	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Heaters (All) Functioning?	y	
609764	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Grounds in Place?	y	
609765	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	General Comments		
609766	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	General Comments		
609767	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Foundation Condition	Good	
609768	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Switching Operations	1	
609769	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Tank Paint Condition	Good	
609770	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Follow-up Action Required?	n	
609771	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Follow-up Action Required?	n	
609772	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Operations Ground	0	
609773	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Switching Operations	2	
609774	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	Follow-up Action Required?	n	
609775	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
609776	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	General Comments		
609777	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Tank Paint Condition	Good	
609778	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Operations C Ø	0	
609779	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Unknown Operations	0	
609780	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Operations B Ø	0	
609781	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Operations A Ø	0	
609782	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
609783	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
609784	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
609785	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
609786	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
609787	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
609788	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
609789	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
609790	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Equipment Properly Labeled?	y	
609791	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
609792	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
609793	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
609794	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	General Comments		
609795	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC As Found Counter	116923	
609796	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC As Left Counter	116923	
609797	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
609798	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	General Comments		
609799	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
609800	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
609801	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Cabinet Paint Condition	Good	
609802	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
609803	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
609804	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
609805	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Bushings Connection/Risers	Good	
609806	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Bushing Condition	Good	
609807	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Amps C Ø	240.0	
609808	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Amps B Ø	200.0	
609809	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
609810	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
609811	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
609812	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
609813	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
609814	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
609815	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC Current Tap Position	7L	
609816	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC Max Tap Position	Neutral	
609817	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
609818	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC Min Tap Position	12L	
609819	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC Operations Since Last Insp	606	
609820	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
609821	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1509.84	kw
609822	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
609823	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
609824	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
609825	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Oil Temp Max	42	°C
609826	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Oil Temp Present	23	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
609827	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
609828	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
609829	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
609830	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
609831	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
609832	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
609833	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
609834	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.2582	
609835	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
609836	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
609837	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
609838	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
609839	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
609840	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
609841	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
609842	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
609843	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	350.0	
609844	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	400.0	
609845	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	320.0	
609846	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
609847	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
609848	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
609849	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	General Comments		
609850	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
609851	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
609852	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
609853	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
609854	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
609855	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Totalizer Meter Reading	1.0540	
609856	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
609857	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
609858	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
609859	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
609860	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
609861	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
609862	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
609863	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Regulator As Left Counter	91799	
609864	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
609865	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
609866	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Tank Leaks	None	
609867	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
609868	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	18	
609869	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.93	%
609870	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
609871	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.44	%
609872	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	40.0	
609873	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	80.0	
609874	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	40.0	
609875	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
609876	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
609877	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
609878	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
609879	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
609880	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
609881	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
609882	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
609883	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
609884	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
609885	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
609886	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
609887	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
609888	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
609889	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
609890	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	General Comments		
609891	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	General Comments		
609892	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC As Found Counter	25177	
609893	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC As Left Counter	25177	
609894	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
609895	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
609896	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC Current Tap Position	3L	
609897	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC Current Tap Position	5L	
609898	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC Max Tap Position	3R	
609899	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
609900	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
609901	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
609902	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
609903	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
609904	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
609905	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
609906	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
609907	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
609908	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Unreadable	
609909	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	General Comments		
609910	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	General Comments		
609911	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
609912	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
609913	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
609914	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	LTC Totalizer Reading	7588.80	kw
609915	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
609916	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
609917	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Operations Counter AL	176	
609918	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Operations Counter AF	174	
609919	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Moisture and Leak Free?	y	
609920	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Maintenance Operations	0	
609921	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
609922	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0285	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
609923	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
609924	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC As Left Counter	153068	
609925	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC As Found Counter	153068	
609926	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Heaters (All) Functioning?	y	
609927	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Grounds in Place?	y	
609928	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	General Comments		
609929	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	General Comments		
609930	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	General Comments		
609931	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
609932	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
609933	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Oil Temp Max	50	°C
609934	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Oil Temp Present	45	°C
609935	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
609936	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
609937	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
609938	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
609939	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
609940	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
609941	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	General Comments		
609942	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Foundation Condition	Good	
609943	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Follow-up Action Required?	n	
609944	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Follow-up Action Required?	n	
609945	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Operations Ground	0	
609946	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	160.0	
609947	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	160.0	
609948	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	3.42	%
609949	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.95	%
609950	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	4.88	%
609951	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0286	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	25	
609952	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Operations C Ø	0	
609953	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Operations B Ø	0	
609954	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	Follow-up Action Required?	n	
609955	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Operations A Ø	0	
609956	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
609957	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
609958	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
609959	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
609960	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
609961	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
609962	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
609963	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
609964	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
609965	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
609966	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
609967	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
609968	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
609969	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Operations A Ø	0	
609970	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Operations B Ø	0	
609971	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Operations C Ø	0	
609972	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Operations Ground	0	
609973	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Follow-up Action Required?	n	
609974	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	9 Month Operations	3	
609975	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
609976	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
609977	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
609978	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Amps A Ø	590.0	
609979	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Amps B Ø	577.0	
609980	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Amps C Ø	570.0	
609981	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Bushing Condition	Good	
609982	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
609983	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
609984	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
609985	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
609986	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
609987	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
609988	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
609989	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
609990	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
609991	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Operations A Ø	0	
609992	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Operations B Ø	0	
609993	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Operations C Ø	0	
609994	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Operations Ground	0	
609995	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Follow-up Action Required?	n	
609996	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Foundation Condition	Good	
609997	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	General Comments		
609998	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	General Comments		
609999	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
610000	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
610001	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
610002	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
610003	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
610004	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
610005	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Follow-up Action Required?	n	
610006	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Follow-up Action Required?	n	
610007	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Foundation Condition	Good	
610008	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	General Comments		
610009	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	General Comments		
610010	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Grounds in Place?	y	
610011	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Maintenance Operations	0	
610012	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
610013	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Bushing Condition	Good	
610014	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
610015	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
610016	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
610017	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
610018	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
610019	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Oil Temp Present	55	°C
610020	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	42.45	
610021	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
610022	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
610023	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	3	
610024	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
610025	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
610026	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
610027	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
610028	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	General Comments		
610029	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
610030	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
610031	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
610032	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
610033	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Oil Temp Present	30	°C
610034	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Oil Temp Max	50	°C
610035	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
610036	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
610037	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
610038	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
610039	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
610040	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
610041	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
610042	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
610043	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
610044	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
610045	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	LTC Totalizer Reading	11018.00	kw
610046	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
610047	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
610048	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
610049	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
610050	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	General Comments	NO BANK OR GROUP SWITHCH	
610051	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
610052	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
610053	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1331	
610054	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1338	
610055	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
610056	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
610057	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
610058	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
610059	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
610060	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
610061	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
610062	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Follow-up Action Required?	n	
610063	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
610064	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
610065	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
610066	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
610067	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Operations Counter AF	201	
610068	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Moisture and Leak Free?	y	
610069	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Maintenance Operations	0	
610070	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Grounds in Place?	y	
610071	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	General Comments		
610072	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	General Comments		
610073	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Foundation Condition	Good	
610074	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Follow-up Action Required?	n	
610075	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
610076	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
610077	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
610078	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
610079	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	General Comments		
610080	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
610081	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Vegetation	None	
610082	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
610083	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Grounds in Place?	y	
610084	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Heaters (All) Functioning?	y	
610085	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Maintenance Operations	0	
610086	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Follow-up Action Required?	n	
610087	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Operations Ground	0	
610088	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Operations C Ø	0	
610089	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Operations B Ø	0	
610090	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Operations A Ø	0	
610091	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
610092	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
610093	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
610094	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Equipment Properly Labeled?	y	
610095	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Cabinet Paint Condition	Good	
610096	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
610097	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
610098	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
610099	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Bushings Connection/Risers	Good	
610100	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Bushing Condition	Good	
610101	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Amps C Ø	121.0	
610102	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Amps B Ø	145.0	
610103	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Amps A Ø	116.0	
610104	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Accumulated Fault Duty C Ph V	2.96	%
610105	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Accumulated Fault Duty B Ph V	2.96	%
610106	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Accumulated Fault Duty A Ph V	3.95	%
610107	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	9 Month Operations	14	
610108	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
610109	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
610110	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
610111	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
610112	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
610113	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
610114	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Readings	General Comments		
610115	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
610116	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
610117	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
610118	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
610119	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	16	
610120	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Operations Counter AF	202	
610121	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Operations Counter AL	203	
610122	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Switching Operations	1	
610123	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Tank Paint Condition	Good	
610124	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Unknown Operations	0	
610125	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
610126	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
610127	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
610128	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Clear of Trash?	y	
610129	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
610130	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
610131	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
610132	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
610133	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
610134	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
610135	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	48	°F
610136	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
610137	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
610138	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
610139	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
610140	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
610141	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
610142	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
610143	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
610144	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
610145	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
610146	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
610147	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	BCH001258	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
610148	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	BCH001258	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
610149	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	BCH001258	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
610150	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	BCH001258	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
610151	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	BCH001258	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
610152	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	BCH001258	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
610153	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
610154	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
610155	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
610156	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
610157	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
610158	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
610159	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	180.0	
610160	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	180.0	
610161	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	180.0	
610162	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
610163	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
610164	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
610165	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
610166	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
610167	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
610168	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
610169	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
610170	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Unknown Operations	0	
610171	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Tank Paint Condition	Good	
610172	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Switching Operations	1	
610173	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Operations Counter AL	1	
610174	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
610175	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
610176	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
610177	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
610178	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
610179	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
610180	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
610181	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
610182	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
610183	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
610184	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	1.7	
610185	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	2.8	
610186	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.4	
610187	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.73	%
610188	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	.73	%
610189	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.73	%
610190	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	18	
610191	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
610192	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
610193	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Winding Temp Present	35	°C
610194	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Winding Temp Max	70	°C
610195	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Totalizer Meter Reading	.7930	
610196	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Unknown Operations	0	
610197	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
610198	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Switching Operations	6	
610199	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
610200	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Operations Counter AL	254	
610201	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Totalizer Meter Multiplier	18000	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
610202	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Operations Counter AF	248	
610203	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
610204	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Maintenance Operations	0	
610205	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
610206	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
610207	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	General Comments		
610208	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	General Comments		
610209	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
610210	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Follow-up Action Required?	n	
610211	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
610212	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	LTCC000505	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
610213	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	LTCC000505	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
610214	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	LTCC000505	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
610215	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	LTCC000505	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
610216	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	LTCC000505	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
610217	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	LTCC000505	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
610218	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	LTCC000505	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
610219	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	LTCC000505	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
610220	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Operations Ground	0	
610221	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Operations C Ø	0	
610222	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Operations B Ø	0	
610223	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Operations A Ø	0	
610224	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
610225	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
610226	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
610227	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
610228	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
610229	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
610230	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
610231	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
610232	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
610233	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
610234	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
610235	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	70	
610236	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	74	
610237	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
610238	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
610239	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
610240	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
610241	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
610242	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
610243	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
610244	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
610245	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
610246	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
610247	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
610248	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
610249	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
610250	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
610251	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
610252	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
610253	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
610254	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
610255	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
610256	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
610257	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
610258	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
610259	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
610260	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
610261	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
610262	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
610263	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
610264	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
610265	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
610266	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
610267	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	64	
610268	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	56	
610269	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
610270	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
610271	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
610272	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	BFTC	
610273	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
610274	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
610275	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
610276	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
610277	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
610278	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
610279	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
610280	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
610281	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
610282	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
610283	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
610284	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
610285	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
610286	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
610287	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
610288	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
610289	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
610290	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	General Comments		
610291	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
610292	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
610293	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
610294	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
610295	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Operations Counter	29	
610296	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
610297	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
610298	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
610299	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
610300	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
610301	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
610302	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	220.00	
610303	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Winding Temp Present	30	°C
610304	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
610305	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
610306	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Winding Temp Max	50	°C
610307	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Totalizer Meter Reading	.7870	
610308	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Totalizer Meter Multiplier	14000	
610309	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
610310	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	18	
610311	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	8.44	%
610312	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	9.49	%
610313	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	8.44	%
610314	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	220.0	
610315	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	220.0	
610316	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	220.0	
610317	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
610318	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
610319	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
610320	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
610321	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
610322	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
610323	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
610324	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
610325	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
610326	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
610327	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
610328	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
610329	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Amps A Ø	500.0	
610330	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Amps B Ø	510.0	
610331	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Amps C Ø	510.0	
610332	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Tank Leaks	None	
610333	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
610334	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
610335	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
610336	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
610337	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
610338	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
610339	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
610340	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
610341	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	9 Month Operations	6	
610342	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
610343	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
610344	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
610345	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Amps A Ø	36.0	
610346	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Amps B Ø	42.0	
610347	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Amps C Ø	18.0	
610348	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
610349	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
610350	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
610351	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Amps C Ø	0.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
610352	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Amps B Ø	0.0	
610353	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Amps A Ø	0.0	
610354	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
610355	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
610356	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
610357	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	9 Month Operations	15	
610358	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
610359	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
610360	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
610361	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
610362	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
610363	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
610364	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
610365	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
610366	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
610367	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
610368	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
610369	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
610370	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	General Comments		
610371	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
610372	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
610373	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Foundation Condition	Good	
610374	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
610375	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
610376	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
610377	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
610378	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
610379	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
610380	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
610381	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
610382	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
610383	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
610384	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
610385	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
610386	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
610387	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
610388	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
610389	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	General Comments		
610390	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	General Comments		
610391	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Grounds in Place?	y	
610392	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
610393	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
610394	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Equipment Properly Labeled?	y	
610395	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Maintenance Operations	0	
610396	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Moisture and Leak Free?	y	
610397	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Operations Counter AF	177	
610398	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Cabinet Paint Condition	Good	
610399	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Operations Counter AL	178	
610400	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Switching Operations	1	
610401	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Tank Paint Condition	Good	
610402	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Unknown Operations	0	
610403	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
610404	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
610405	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
610406	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	9 Month Operations	6	
610407	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Accumulated Fault Duty A Ph V	2.44	%
610408	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Accumulated Fault Duty B Ph V	1.46	%
610409	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
610410	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Tank Leaks	None	
610411	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
610412	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
610413	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Regulator As Left Counter	342234	
610414	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
610415	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
610416	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
610417	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
610418	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Bushings Connection/Risers	Good	
610419	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Bushing Condition	Good	
610420	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Amps C Ø	210.0	
610421	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Amps B Ø	205.0	
610422	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Amps A Ø	205.0	
610423	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Accumulated Fault Duty C Ph V	2.44	%
610424	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Amps A Ø	125.0	
610425	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Amps B Ø	150.0	
610426	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Accumulated Fault Duty C Ph V	4.94	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
610427	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Accumulated Fault Duty B Ph V	3.95	%
610428	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Accumulated Fault Duty A Ph V	1.98	%
610429	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	9 Month Operations	12	
610430	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
610431	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
610432	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
610433	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
610434	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Readings	General Comments		
610435	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
610436	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
610437	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
610438	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
610439	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	12	
610440	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1642	
610441	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1647	
610442	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
610443	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
610444	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
610445	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
610446	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
610447	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
610448	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
610449	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
610450	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
610451	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
610452	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
610453	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
610454	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
610455	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
610456	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
610457	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	39	°F
610458	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
610459	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
610460	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Oil Temp Max	65	°C
610461	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
610462	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
610463	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
610464	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
610465	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
610466	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
610467	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
610468	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
610469	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
610470	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
610471	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
610472	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	LTC Totalizer Reading	14274.00	kw
610473	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
610474	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	General Comments		
610475	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	General Comments		
610476	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
610477	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
610478	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Follow-up Action Required?	n	
610479	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
610480	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
610481	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
610482	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
610483	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
610484	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
610485	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
610486	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	General Comments		
610487	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
610488	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
610489	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
610490	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
610491	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
610492	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
610493	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Cabinet Paint Condition	Good	
610494	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Equipment Properly Labeled?	y	
610495	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
610496	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
610497	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
610498	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Operations A Ø	0	
610499	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Operations B Ø	0	
610500	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Operations C Ø	0	
610501	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
610502	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Follow-up Action Required?	n	
610503	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Follow-up Action Required?	n	
610504	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Foundation Condition	Good	
610505	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
610506	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
610507	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
610508	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
610509	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
610510	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Operations A Ø	0	
610511	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Operations B Ø	0	
610512	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Operations C Ø	0	
610513	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Operations Ground	0	
610514	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Follow-up Action Required?	n	
610515	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Follow-up Action Required?	n	
610516	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Foundation Condition	Good	
610517	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	General Comments		
610518	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	General Comments		
610519	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Grounds in Place?	y	
610520	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Maintenance Operations	0	
610521	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Moisture and Leak Free?	y	
610522	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Operations Counter AF	198	
610523	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Operations Counter AL	198	
610524	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Switching Operations	1	
610525	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Tank Paint Condition	Good	
610526	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Unknown Operations	0	
610527	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Readings	Totalizer Meter Reading	.1068	
610528	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
610529	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
610530	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
610531	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
610532	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC Min Tap Position	13L	
610533	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC Max Tap Position	2L	
610534	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC Current Tap Position	7L	
610535	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
610536	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
610537	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
610538	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
610539	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
610540	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Readings	Oil Temp Max	47	°C
610541	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
610542	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
610543	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
610544	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
610545	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
610546	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
610547	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
610548	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
610549	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
610550	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
610551	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
610552	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
610553	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
610554	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Follow-up Action Required?	n	
610555	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
610556	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
610557	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
610558	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
610559	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
610560	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
610561	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	General Comments		
610562	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
610563	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
610564	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
610565	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	General Comments		
610566	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	General Comments		
610567	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
610568	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	LTC Totalizer Reading	14724.00	kw
610569	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
610570	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
610571	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	All Connections OK?	y	
610572	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	Follow-up Action Required?	n	
610573	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	General Comments		
610574	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	LTC Operation Checked?	y	
610575	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
610576	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
610577	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	5	
610578	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
610579	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
610580	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
610581	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	VRR Time Delay	30	Seconds
610582	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	All Connections OK?	y	
610583	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	Follow-up Action Required?	n	
610584	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	General Comments		
610585	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	LTC Operation Checked?	y	
610586	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
610587	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
610588	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
610589	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
610590	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
610591	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
610592	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
610593	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
610594	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
610595	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
610596	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
610597	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
610598	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	VRR Time Delay	30	Seconds
610599	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
610600	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC Operations Since Last Insp	551	
610601	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Amps C Ø	155.0	
610602	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Bushing Condition	Good	
610603	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Bushings Connection/Risers	Good	
610604	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
610605	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
610606	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
610607	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
610608	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
610609	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC Operations Since Last Insp	1088	
610610	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
610611	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
610612	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
610613	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
610614	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC Min Tap Position	11L	
610615	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	9 Month Operations	15	
610616	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Accumulated Fault Duty A Ph V	7.38	%
610617	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Accumulated Fault Duty B Ph V	2.11	%
610618	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
610619	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Amps A Ø	267.0	
610620	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Amps B Ø	241.0	
610621	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Amps C Ø	240.0	
610622	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Bushing Condition	Good	
610623	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Bushings Connection/Risers	Good	
610624	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
610625	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
610626	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
610627	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Cabinet Paint Condition	Good	
610628	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Equipment Properly Labeled?	y	
610629	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
610630	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
610631	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
610632	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
610633	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
610634	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
610635	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	General Comments		
610636	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
610637	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Adjusted Amps B Phase V	26.50	
610638	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Adjusted Amps C Phase V	26.50	
610639	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Operations A Ø	0	
610640	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
610641	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
610642	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
610643	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
610644	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	6	
610645	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
610646	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Operations B Ø	2	
610647	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Operations C Ø	2	
610648	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	0	
610649	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0188	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	457	
610650	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
610651	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
610652	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
610653	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
610654	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
610655	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Unknown Operations	0	
610656	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Operations Ground	0	
610657	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Follow-up Action Required?	n	
610658	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Follow-up Action Required?	n	
610659	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Foundation Condition	Good	
610660	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	General Comments		
610661	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	General Comments		
610662	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Grounds in Place?	y	
610663	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Tank Paint Condition	Good	
610664	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Switching Operations	1	
610665	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
610666	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Operations Counter AL	160	
610667	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Operations Counter AF	159	
610668	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
610669	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Tank Leaks	None	
610670	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
610671	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
610672	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Regulator As Left Counter	9636	
610673	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
610674	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
610675	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
610676	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
610677	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
610678	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
610679	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Heaters (All) Functioning?	y	
610680	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Maintenance Operations	0	
610681	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Moisture and Leak Free?	y	
610682	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Operations Counter AF	296	
610683	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Operations Counter AL	301	
610684	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
610685	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Switching Operations	2	
610686	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Tank Paint Condition	Good	
610687	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Unknown Operations	0	
610688	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
610689	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
610690	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	General Comments		
610691	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
610692	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
610693	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
610694	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Amps A Ø	240.0	
610695	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Accumulated Fault Duty C Ph V	3.95	%
610696	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Accumulated Fault Duty B Ph V	4.94	%
610697	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Accumulated Fault Duty A Ph V	.99	%
610698	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	9 Month Operations	42	
610699	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
610700	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
610701	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
610702	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
610703	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
610704	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
610705	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
610706	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
610707	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	General Comments		
610708	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
610709	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
610710	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
610711	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
610712	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
610713	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
610714	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
610715	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
610716	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
610717	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
610718	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
610719	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
610720	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
610721	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
610722	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	General Comments		
610723	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
610724	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
610725	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Foundation Condition	Good	
610726	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
610727	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
610728	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
610729	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
610730	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
610731	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
610732	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
610733	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
610734	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
610735	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
610736	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
610737	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	60.0	
610738	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	40.0	
610739	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
610740	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	40.0	
610741	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
610742	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
610743	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
610744	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
610745	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
610746	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
610747	1/18/2019 12:34	Distribution	Joyland Quarterly Inspection	BB0145	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
610748	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Foundation Condition	Good	
610749	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
610750	1/18/2019 14:55	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
610751	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Bushings Connection/Risers	Good	
610752	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	ST000024	Structure	351-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
610753	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	9 Month Operations	9	
610754	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Accumulated Fault Duty A Ph V	1.98	%
610755	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Accumulated Fault Duty B Ph V	1.98	%
610756	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
610757	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Bushing Condition	Good	
610758	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Amps A Ø	90.0	
610759	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Amps B Ø	80.0	
610760	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
610761	1/18/2019 13:36	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Amps C Ø	80.0	
610762	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
610763	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
610764	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Regulator As Left Counter	302845	
610765	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Tank Leaks	None	
610766	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
610767	1/18/2019 14:58	Distribution	Virginia City Distribution Quarterly Inspectio	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
610768	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
610769	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
610770	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
610771	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
610772	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
610773	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
610774	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Vegetation	None	
610775	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
610776	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	General Comments		
610777	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
610778	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
610779	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
610780	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
610781	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
610782	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
610783	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
610784	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
610785	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	General Comments		
610786	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
610787	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
610788	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
610789	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Clear of Trash?	y	
610790	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
610791	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
610792	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
610793	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
610794	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
610795	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
610796	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
610797	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
610798	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
610799	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
610800	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	General Comments		
610801	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
610802	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
610803	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
610804	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
610805	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
610806	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Operations A Ø	0	
610807	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Operations B Ø	0	
610808	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Operations C Ø	0	
610809	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Operations Ground	0	
610810	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Follow-up Action Required?	n	
610811	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Follow-up Action Required?	n	
610812	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Foundation Condition	Good	
610813	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	General Comments		
610814	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	General Comments		
610815	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Unknown Operations	0	
610816	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Tank Paint Condition	Good	
610817	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Switching Operations	2	
610818	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
610819	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Operations Counter AL	214	
610820	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Operations Counter AF	212	
610821	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Moisture and Leak Free?	y	
610822	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Maintenance Operations	0	
610823	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Heaters (All) Functioning?	y	
610824	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Grounds in Place?	y	
610825	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	General Comments		
610826	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	General Comments		
610827	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Foundation Condition	Good	
610828	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Follow-up Action Required?	n	
610829	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Follow-up Action Required?	n	
610830	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Operations Ground	0	
610831	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Grounds in Place?	y	
610832	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Maintenance Operations	0	
610833	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
610834	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Operations Counter AF	219	
610835	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Operations Counter AL	223	
610836	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
610837	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
610838	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
610839	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
610840	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
610841	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Foundation Condition	Good	
610842	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
610843	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Operations C Ø	0	
610844	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Operations B Ø	0	
610845	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Operations A Ø	5	
610846	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
610847	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
610848	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Adjusted Amps A Phase V	8.28	
610849	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Equipment Properly Labeled?	y	
610850	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Cabinet Paint Condition	Good	
610851	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
610852	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
610853	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Switching Operations	4	
610854	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
610855	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
610856	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Bushings Connection/Risers	Good	
610857	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Bushing Condition	Good	
610858	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Amps C Ø	35.0	
610859	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Amps B Ø	35.0	
610860	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Amps A Ø	30.0	
610861	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
610862	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
610863	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Accumulated Fault Duty A Ph V	.62	%
610864	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	VRR Time Delay	30	Seconds
610865	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	9 Month Operations	11	
610866	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
610867	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Tank Paint Condition	Good	
610868	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Unknown Operations	0	
610869	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
610870	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
610871	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
610872	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
610873	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
610874	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
610875	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
610876	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
610877	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
610878	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
610879	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
610880	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
610881	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
610882	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
610883	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
610884	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
610885	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
610886	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
610887	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	66	
610888	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	61	
610889	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
610890	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
610891	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
610892	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
610893	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
610894	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
610895	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
610896	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
610897	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
610898	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
610899	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
610900	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
610901	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
610902	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
610903	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
610904	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
610905	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
610906	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
610907	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
610908	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
610909	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
610910	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
610911	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
610912	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	300.0	
610913	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	240.0	
610914	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	240.0	
610915	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
610916	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
610917	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
610918	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
610919	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
610920	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
610921	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
610922	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	BCH000591	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
610923	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	BCH000591	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	51.8	VDC
610924	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	BCH000591	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
610925	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	BCH000591	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
610926	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	BCH000591	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
610927	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	BCH000591	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
610928	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
610929	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
610930	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
610931	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
610932	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
610933	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
610934	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
610935	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	General Comments		
610936	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
610937	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
610938	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
610939	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
610940	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
610941	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
610942	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
610943	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	5	
610944	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6R	
610945	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC Max Tap Position	7R	
610946	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Amps A Ø	50.0	
610947	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Amps B Ø	100.0	
610948	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Amps C Ø	170.0	
610949	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
610950	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
610951	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
610952	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
610953	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations A Ø	0	
610954	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations B Ø	0	
610955	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations C Ø	0	
610956	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations Ground	0	
610957	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
610958	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Follow-up Action Required?	n	
610959	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	General Comments		
610960	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	General Comments		
610961	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
610962	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Maintenance Operations	0	
610963	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Operations Counter AF	401	
610964	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Operations Counter AL	401	
610965	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Switching Operations	0	
610966	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Unknown Operations	0	
610967	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC Min Tap Position	3R	
610968	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	209	
610969	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
610970	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	19.75	
610971	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	44.45	
610972	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	19.75	
610973	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
610974	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
610975	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
610976	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
610977	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
610978	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
610979	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
610980	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
610981	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
610982	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
610983	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
610984	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
610985	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
610986	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	96.0	
610987	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
610988	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	96.0	
610989	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	8.71	%
610990	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	14.26	%
610991	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	11.09	%
610992	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	39	
610993	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
610994	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
610995	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
610996	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
610997	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
610998	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
610999	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
611000	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
611001	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
611002	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
611003	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Tank Paint Condition	Good	
611004	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Switching Operations	1	
611005	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
611006	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Unknown Operations	0	
611007	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Switching Operations	0	
611008	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Operations Counter AL	34888	
611009	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Operations Counter AF	34888	
611010	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Maintenance Operations	0	
611011	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
611012	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
611013	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
611014	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
611015	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
611016	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
611017	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
611018	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
611019	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
611020	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
611021	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
611022	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
611023	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	General Comments		
611024	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	General Comments		
611025	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Follow-up Action Required?	n	
611026	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
611027	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations Ground	0	
611028	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations C Ø	0	
611029	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations B Ø	0	
611030	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Operations Counter AL	218	
611031	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Operations Counter AF	217	
611032	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Moisture and Leak Free?	y	
611033	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Maintenance Operations	0	
611034	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Grounds in Place?	y	
611035	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	General Comments		
611036	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations A Ø	0	
611037	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
611038	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
611039	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
611040	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
611041	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Amps C Ø	200.0	
611042	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Amps B Ø	240.0	
611043	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Amps A Ø	100.0	
611044	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
611045	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
611046	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	General Comments		
611047	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Foundation Condition	Good	
611048	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Follow-up Action Required?	n	
611049	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Follow-up Action Required?	n	
611050	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Operations Ground	0	
611051	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Operations C Ø	0	
611052	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Operations B Ø	0	
611053	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Operations A Ø	1	
611054	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
611055	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
611056	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Adjusted Amps A Phase V	4.94	
611057	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Equipment Properly Labeled?	y	
611058	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Cabinet Paint Condition	Good	
611059	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
611060	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
611061	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
611062	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Bushings Connection/Risers	Good	
611063	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Bushing Condition	Good	
611064	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Amps C Ø	86.0	
611065	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Amps B Ø	95.0	
611066	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
611067	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
611068	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
611069	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
611070	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Regulator As Left Counter	98502	
611071	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
611072	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
611073	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Tank Leaks	None	
611074	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
611075	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	9 Months Operations	28	
611076	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
611077	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
611078	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
611079	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Amps A Ø	25.0	
611080	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Amps B Ø	25.0	
611081	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Amps C Ø	25.0	
611082	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
611083	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
611084	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
611085	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
611086	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Operations A Ø	0	
611087	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Operations B Ø	0	
611088	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Operations C Ø	0	
611089	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Operations Ground	0	
611090	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
611091	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Follow-up Action Required?	n	
611092	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Patrol Inspection	General Comments		
611093	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	General Comments		
611094	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
611095	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Maintenance Operations	0	
611096	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Operations Counter AF	584	
611097	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Operations Counter AL	584	
611098	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Switching Operations	1	
611099	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Unknown Operations	0	
611100	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
611101	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
611102	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
611103	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
611104	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
611105	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
611106	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
611107	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
611108	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
611109	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
611110	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	General Comments		
611111	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
611112	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
611113	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
611114	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
611115	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
611116	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
611117	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
611118	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
611119	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Regulator As Left Counter	113771	
611120	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
611121	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
611122	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Tank Leaks	None	
611123	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
611124	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
611125	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
611126	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
611127	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
611128	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Unknown Operations	0	
611129	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
611130	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Operations Counter	2329	
611131	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
611132	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
611133	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	General Comments		
611134	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
611135	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
611136	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
611137	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
611138	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
611139	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
611140	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
611141	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
611142	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
611143	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
611144	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	10.0	
611145	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	10.0	
611146	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	10.0	
611147	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	
611148	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	General Comments		
611149	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	General Comments		
611150	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
611151	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Maintenance Operations	0	
611152	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
611153	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Operations Counter AF	215	
611154	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Operations Counter AL	225	
611155	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
611156	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Switching Operations	10	
611157	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Tank Paint Condition	Good	
611158	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Unknown Operations	0	
611159	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
611160	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
611161	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
611162	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC Operations Since Last Insp	662	
611163	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC Min Tap Position	9L	
611164	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC Max Tap Position	3R	
611165	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC Current Tap Position	4L	
611166	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
611167	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC As Left Counter	57996	
611168	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC As Found Counter	57996	
611169	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	General Comments		
611170	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	General Comments		
611171	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
611172	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	Follow-up Action Required?	n	
611173	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
611174	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
611175	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
611176	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC Operations Since Last Insp	213	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
611177	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC Min Tap Position	9L	
611178	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC Max Tap Position	4L	
611179	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC Current Tap Position	6L	
611180	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
611181	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC As Left Counter	168338	
611182	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC As Found Counter	168336	
611183	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	General Comments		
611184	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	General Comments		
611185	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
611186	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	Follow-up Action Required?	n	
611187	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
611188	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
611189	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
611190	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
611191	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
611192	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
611193	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
611194	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
611195	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
611196	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	9 Months Operations	17	
611197	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
611198	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
611199	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
611200	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
611201	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
611202	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
611203	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
611204	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
611205	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
611206	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
611207	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
611208	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	General Comments		
611209	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
611210	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Maintenance Operations	0	
611211	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Operations Counter AF	533	
611212	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Operations Counter AL	533	
611213	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Switching Operations	1	
611214	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Unknown Operations	0	
611215	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
611216	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
611217	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
611218	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
611219	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
611220	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
611221	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
611222	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
611223	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
611224	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
611225	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
611226	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
611227	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
611228	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	General Comments		
611229	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
611230	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	9 Month Operations	20	
611231	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
611232	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
611233	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
611234	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Amps A Ø	0.0	
611235	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Amps B Ø	0.0	
611236	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Amps C Ø	0.0	
611237	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Bushing Condition	Good	
611238	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
611239	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
611240	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
611241	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
611242	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
611243	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
611244	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
611245	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
611246	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
611247	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Operations A Ø	0	
611248	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Operations B Ø	0	
611249	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Operations C Ø	0	
611250	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Operations Ground	0	
611251	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
611252	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Follow-up Action Required?	n	
611253	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
611254	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
611255	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC Current Tap Position	6L	
611256	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC Max Tap Position	4L	
611257	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC Min Tap Position	9L	
611258	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC Operations Since Last Insp	298	
611259	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
611260	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
611261	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
611262	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
611263	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	General Comments		
611264	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
611265	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
611266	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
611267	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
611268	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
611269	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
611270	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
611271	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
611272	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
611273	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
611274	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
611275	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
611276	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
611277	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
611278	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
611279	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
611280	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
611281	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
611282	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
611283	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
611284	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
611285	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
611286	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
611287	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
611288	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
611289	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
611290	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
611291	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
611292	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
611293	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
611294	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
611295	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
611296	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	General Comments		
611297	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	small leak from valve on LTC cabinet	
611298	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC As Found Counter	409944	
611299	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC As Left Counter	409944	
611300	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
611301	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	9 Months Operations	2	
611302	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
611303	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
611304	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
611305	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	4	
611306	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
611307	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
611308	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
611309	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	130	
611310	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	122	
611311	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
611312	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
611313	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
611314	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
611315	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
611316	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
611317	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
611318	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
611319	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
611320	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
611321	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
611322	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
611323	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
611324	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
611325	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
611326	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
611327	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
611328	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
611329	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Foundation Condition	Good	
611330	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
611331	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
611332	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
611333	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
611334	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
611335	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
611336	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.300	millivolts
611337	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	25.3	VDC
611338	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	25.3	VDC
611339	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
611340	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
611341	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
611342	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	General Comments		
611343	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
611344	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
611345	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Totalizer Meter Reading	1.0270	
611346	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
611347	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
611348	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
611349	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
611350	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
611351	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
611352	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
611353	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
611354	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Oil Temp Present	30	°C
611355	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Oil Temp Max	55	°C
611356	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
611357	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
611358	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	LTC Totalizer Reading	9859.20	kw
611359	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
611360	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	General Comments		
611361	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	General Comments		
611362	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
611363	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
611364	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Follow-up Action Required?	n	
611365	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
611366	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
611367	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
611368	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
611369	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
611370	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
611371	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
611372	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
611373	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
611374	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	Follow-up Action Required?	n	
611375	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
611376	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	General Comments		
611377	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	General Comments		
611378	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC As Found Counter	152058	
611379	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC As Left Counter	152065	
611380	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
611381	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
611382	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
611383	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
611384	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
611385	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
611386	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
611387	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
611388	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
611389	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
611390	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
611391	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
611392	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Clear of Trash?	y	
611393	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
611394	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
611395	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	17	
611396	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
611397	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
611398	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
611399	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.38	%
611400	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	3.17	%
611401	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.38	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
611402	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	300.0	
611403	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	General Comments		
611404	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
611405	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
611406	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Vegetation	None	
611407	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
611408	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
611409	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	280.0	
611410	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	250.0	
611411	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
611412	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
611413	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
611414	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
611415	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
611416	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
611417	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
611418	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
611419	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
611420	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
611421	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Amps C Ø	25.0	
611422	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Amps B Ø	75.0	
611423	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Amps A Ø	50.0	
611424	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
611425	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
611426	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
611427	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
611428	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
611429	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
611430	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
611431	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
611432	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	9 Months Operations	2	
611433	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
611434	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
611435	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	General Comments		
611436	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
611437	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
611438	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
611439	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
611440	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	Gauge shows low oil	
611441	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC As Found Counter	396655	
611442	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC As Left Counter	396655	
611443	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
611444	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Accumulated Fault Duty C Ph V	.34	%
611445	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Amps A Ø	35.0	
611446	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Amps B Ø	40.0	
611447	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Amps C Ø	20.0	
611448	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC As Left Counter	75277	
611449	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
611450	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
611451	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6L	
611452	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
611453	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
611454	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	7	
611455	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
611456	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
611457	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Bushing Condition	Good	
611458	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Bushings Connection/Risers	Good	
611459	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
611460	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
611461	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
611462	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Cabinet Paint Condition	Good	
611463	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Equipment Properly Labeled?	y	
611464	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
611465	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
611466	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
611467	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Operations A Ø	0	
611468	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
611469	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Vegetation	None	
611470	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
611471	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
611472	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	General Comments		
611473	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
611474	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
611475	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Operations B Ø	0	
611476	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
611477	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Operations Ground	0	
611478	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Follow-up Action Required?	n	
611479	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Follow-up Action Required?	n	
611480	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Foundation Condition	Good	
611481	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	General Comments		
611482	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	General Comments		
611483	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Grounds in Place?	y	
611484	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Maintenance Operations	0	
611485	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Moisture and Leak Free?	y	
611486	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Operations Counter AF	161	
611487	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Operations Counter AL	161	
611488	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Switching Operations	0	
611489	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Tank Paint Condition	Good	
611490	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
611491	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
611492	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
611493	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Clear of Trash?	y	
611494	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
611495	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
611496	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
611497	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Unknown Operations	0	
611498	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
611499	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	General Comments		
611500	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
611501	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
611502	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
611503	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
611504	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
611505	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
611506	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
611507	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
611508	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	89	
611509	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	97	
611510	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
611511	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
611512	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
611513	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
611514	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
611515	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
611516	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
611517	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
611518	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
611519	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
611520	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
611521	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
611522	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Winding Temp Present	20	°C
611523	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Winding Temp Max	21	°C
611524	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Totalizer Meter Reading	.9408	
611525	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
611526	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
611527	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
611528	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
611529	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
611530	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Vegetation	None	
611531	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
611532	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
611533	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	General Comments		
611534	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
611535	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
611536	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
611537	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
611538	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
611539	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
611540	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Clear of Trash?	y	
611541	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
611542	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
611543	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
611544	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
611545	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
611546	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
611547	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Oil Temp Present	34	°C
611548	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Oil Temp Max	34	°C
611549	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
611550	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
611551	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	LTC Totalizer Reading	9031.68	kw

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
611552	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
611553	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
611554	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Tank Leaks	None	
611555	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
611556	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	General Comments		
611557	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	General Comments		
611558	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
611559	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
611560	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Regulator As Left Counter	93235	
611561	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
611562	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
611563	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
611564	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
611565	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
611566	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
611567	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
611568	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
611569	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	General Comments		
611570	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
611571	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	42	°F
611572	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
611573	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
611574	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
611575	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
611576	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
611577	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
611578	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
611579	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
611580	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	General Comments		
611581	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
611582	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
611583	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
611584	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
611585	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Max Tap Position	8L	
611586	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Min Tap Position	12L	
611587	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
611588	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	587	
611589	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
611590	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Very Low	
611591	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
611592	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Follow-up Action Required?	n	
611593	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
611594	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
611595	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
611596	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
611597	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
611598	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
611599	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
611600	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
611601	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
611602	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
611603	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
611604	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
611605	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
611606	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
611607	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
611608	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
611609	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
611610	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
611611	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
611612	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
611613	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
611614	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
611615	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
611616	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
611617	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
611618	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
611619	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
611620	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
611621	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
611622	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
611623	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
611624	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
611625	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
611626	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
611627	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	General Comments		
611628	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
611629	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
611630	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Foundation Condition	Good	
611631	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
611632	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
611633	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
611634	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
611635	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
611636	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
611637	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
611638	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
611639	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Readings	General Comments		
611640	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
611641	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
611642	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
611643	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
611644	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	13	
611645	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	275	
611646	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	279	
611647	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
611648	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
611649	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
611650	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
611651	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
611652	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
611653	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
611654	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
611655	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
611656	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
611657	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
611658	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
611659	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
611660	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
611661	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
611662	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
611663	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
611664	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
611665	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
611666	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
611667	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	General Comments		
611668	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
611669	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
611670	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
611671	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	27.3	VDC
611672	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	27.3	VDC
611673	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.600	millivolts
611674	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
611675	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	General Comments		
611676	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
611677	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
611678	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
611679	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
611680	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
611681	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
611682	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
611683	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
611684	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
611685	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
611686	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
611687	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
611688	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
611689	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	General Comments	Fence/barbwire in plans to be replaced	
611690	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	FE000024	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
611691	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
611692	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
611693	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
611694	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
611695	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
611696	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Amps A Ø	88.0	
611697	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Accumulated Fault Duty C Ph V	2.95	%
611698	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	230.0	
611699	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	280.0	
611700	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	220.0	
611701	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
611702	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
611703	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
611704	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
611705	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
611706	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
611707	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
611708	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
611709	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
611710	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
611711	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
611712	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
611713	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Accumulated Fault Duty B Ph V	5.52	%
611714	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
611715	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	9 Months Operations	18	
611716	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
611717	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
611718	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
611719	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
611720	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
611721	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Accumulated Fault Duty A Ph V	3.68	%
611722	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	9 Month Operations	7	
611723	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
611724	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
611725	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
611726	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	VRR Time Delay	30	Seconds
611727	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
611728	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
611729	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
611730	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	LTC Operation Checked?	y	
611731	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	General Comments		
611732	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	Follow-up Action Required?	n	
611733	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	All Connections OK?	y	
611734	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	Follow-up Action Required?	n	
611735	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
611736	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	General Comments		
611737	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	General Comments		
611738	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC As Found Counter	107804	
611739	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC As Left Counter	107804	
611740	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
611741	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
611742	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC Max Tap Position	4R	
611743	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC Min Tap Position	8L	
611744	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC Operations Since Last Insp	493	
611745	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
611746	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
611747	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
611748	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
611749	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
611750	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
611751	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
611752	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
611753	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
611754	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	General Comments		
611755	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
611756	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	General Comments		
611757	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
611758	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
611759	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Unknown Operations	0	
611760	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Unknown Operations	0	
611761	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Switching Operations	0	
611762	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Operations Counter AL	324	
611763	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Operations Counter AF	324	
611764	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Maintenance Operations	0	
611765	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
611766	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	General Comments		
611767	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
611768	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
611769	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	General Comments		
611770	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Follow-up Action Required?	n	
611771	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
611772	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations Ground	0	
611773	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
611774	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations C Ø	0	
611775	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
611776	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
611777	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
611778	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
611779	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
611780	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
611781	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
611782	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
611783	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
611784	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
611785	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
611786	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
611787	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
611788	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
611789	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
611790	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
611791	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	General Comments		
611792	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
611793	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
611794	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Foundation Condition	Good	
611795	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
611796	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
611797	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
611798	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
611799	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
611800	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
611801	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
611802	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC As Found Counter	75277	
611803	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
611804	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
611805	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
611806	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
611807	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
611808	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
611809	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
611810	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	General Comments		
611811	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations B Ø	0	
611812	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations A Ø	0	
611813	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
611814	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
611815	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
611816	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
611817	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
611818	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
611819	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	9 Month Operations	4	
611820	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Accumulated Fault Duty A Ph V	.34	%
611821	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
611822	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
611823	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	General Comments		
611824	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
611825	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
611826	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.6	psi
611827	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
611828	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4723.20	kw
611829	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
611830	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
611831	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
611832	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Oil Temp Present	42	°C
611833	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
611834	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
611835	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
611836	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
611837	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
611838	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
611839	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
611840	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
611841	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4920	
611842	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
611843	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
611844	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
611845	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
611846	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
611847	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
611848	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
611849	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
611850	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
611851	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
611852	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	9 Month Operations	8	
611853	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Accumulated Fault Duty A Ph V	1.02	%
611854	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Accumulated Fault Duty B Ph V	1.02	%
611855	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
611856	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Amps A Ø	195.0	
611857	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Amps B Ø	150.0	
611858	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Amps C Ø	170.0	
611859	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Bushing Condition	Good	
611860	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Bushings Connection/Risers	Good	
611861	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
611862	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
611863	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
611864	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Cabinet Paint Condition	Good	
611865	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Equipment Properly Labeled?	y	
611866	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
611867	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
611868	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
611869	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Operations A Ø	0	
611870	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Operations B Ø	0	
611871	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
611872	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Operations C Ø	0	
611873	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Operations Ground	0	
611874	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Follow-up Action Required?	n	
611875	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Follow-up Action Required?	n	
611876	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Foundation Condition	Good	
611877	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	General Comments		
611878	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	General Comments		
611879	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Grounds in Place?	y	
611880	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Maintenance Operations	0	
611881	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Moisture and Leak Free?	y	
611882	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Operations Counter AF	171	
611883	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Operations Counter AL	171	
611884	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Switching Operations	0	
611885	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Tank Paint Condition	Good	
611886	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Switching Operations	4	
611887	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Tank Paint Condition	Good	
611888	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Unknown Operations	0	
611889	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
611890	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
611891	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
611892	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Equipment Properly Labeled?	y	
611893	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Cabinet Paint Condition	Good	
611894	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
611895	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
611896	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
611897	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Bushings Connection/Risers	Good	
611898	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Bushing Condition	Good	
611899	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Amps C Ø	66.0	
611900	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Amps B Ø	127.0	
611901	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Amps A Ø	63.0	
611902	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
611903	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
611904	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
611905	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	9 Month Operations	12	
611906	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
611907	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
611908	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
611909	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	General Comments		
611910	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	9 Months Operations	0	
611911	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
611912	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
611913	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
611914	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Amps A Ø	130.0	
611915	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Amps B Ø	130.0	
611916	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Amps C Ø	190.0	
611917	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
611918	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
611919	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
611920	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
611921	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations A Ø	0	
611922	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations B Ø	0	
611923	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations C Ø	0	
611924	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations Ground	0	
611925	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
611926	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
611927	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	General Comments		
611928	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	General Comments		
611929	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
611930	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Maintenance Operations	0	
611931	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Operations Counter AF	1301	
611932	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Operations Counter AL	1301	
611933	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Switching Operations	0	
611934	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Unknown Operations	0	
611935	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	All Connections OK?	y	
611936	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	Follow-up Action Required?	n	
611937	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	General Comments		
611938	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	LTC Operation Checked?	y	
611939	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
611940	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
611941	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
611942	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	VRR Time Delay	30	Seconds
611943	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
611944	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
611945	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Foundation Condition	Good	
611946	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
611947	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
611948	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
611949	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
611950	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
611951	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
611952	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	Follow-up Action Required?	n	
611953	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
611954	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	General Comments		
611955	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	General Comments		
611956	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC As Found Counter	28909	
611957	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC As Left Counter	28909	
611958	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC Current Tap Position	1L	
611959	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
611960	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC As Left Counter	69243	
611961	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC As Found Counter	69243	
611962	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	General Comments		
611963	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	General Comments		
611964	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
611965	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	Follow-up Action Required?	n	
611966	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
611967	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
611968	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
611969	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
611970	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
611971	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
611972	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
611973	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
611974	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Totalizer Meter Reading	.7730	
611975	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
611976	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
611977	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
611978	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
611979	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
611980	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	9 Month Operations	8	
611981	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Accumulated Fault Duty A Ph V	1.51	%
611982	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Accumulated Fault Duty B Ph V	.38	%
611983	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Accumulated Fault Duty C Ph V	.38	%
611984	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Amps A Ø	50.0	
611985	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Amps B Ø	50.0	
611986	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Amps C Ø	60.0	
611987	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Bushing Condition	Good	
611988	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Bushings Connection/Risers	Good	
611989	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
611990	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
611991	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
611992	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Cabinet Paint Condition	Good	
611993	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Equipment Properly Labeled?	y	
611994	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
611995	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
611996	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
611997	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Operations A Ø	0	
611998	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Operations B Ø	0	
611999	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Operations C Ø	0	
612000	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Operations Ground	0	
612001	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
612002	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Follow-up Action Required?	n	
612003	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Foundation Condition	Good	
612004	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	General Comments		
612005	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	General Comments		
612006	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Unknown Operations	0	
612007	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Tank Paint Condition	Good	
612008	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Switching Operations	1	
612009	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Operations Counter AL	155	
612010	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Operations Counter AF	154	
612011	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Moisture and Leak Free?	y	
612012	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Maintenance Operations	0	
612013	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Grounds in Place?	y	
612014	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	General Comments		
612015	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	General Comments		
612016	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Foundation Condition	Good	
612017	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Follow-up Action Required?	n	
612018	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Follow-up Action Required?	n	
612019	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Operations Ground	0	
612020	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Operations C Ø	0	
612021	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Operations B Ø	0	
612022	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Operations A Ø	0	
612023	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Grounds in Place?	y	
612024	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Heaters (All) Functioning?	y	
612025	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Maintenance Operations	0	
612026	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Moisture and Leak Free?	y	
612027	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Operations Counter AF	235	
612028	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Operations Counter AL	239	
612029	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
612030	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
612031	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
612032	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
612033	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
612034	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
612035	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
612036	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
612037	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
612038	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
612039	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
612040	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
612041	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
612042	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Follow-up Action Required?	n	
612043	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
612044	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
612045	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	General Comments		
612046	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	General Comments	added nitrogen	
612047	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
612048	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	LTC Totalizer Reading	5938.56	kw
612049	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
612050	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
612051	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Oil Temp Max	21	°C
612052	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Oil Temp Present	21	°C
612053	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
612054	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
612055	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
612056	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
612057	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
612058	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
612059	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
612060	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
612061	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Totalizer Meter Reading	.6186	
612062	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Winding Temp Max	31	°C
612063	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Winding Temp Present	20	°C
612064	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
612065	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
612066	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
612067	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
612068	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
612069	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
612070	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
612071	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
612072	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
612073	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
612074	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
612075	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
612076	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
612077	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
612078	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
612079	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
612080	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Clear of Trash?	y	
612081	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
612082	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Ambient Temp	41	°F
612083	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
612084	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
612085	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
612086	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
612087	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
612088	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
612089	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	General Comments		
612090	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
612091	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
612092	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
612093	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	Oil Temp Max	30	°C
612094	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
612095	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
612096	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
612097	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
612098	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
612099	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
612100	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
612101	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
612102	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
612103	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC Current Tap Position	1R	
612104	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC Max Tap Position	9R	
612105	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC Min Tap Position	6L	
612106	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC Operations Since Last Insp	621	
612107	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
612108	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
612109	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
612110	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
612111	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Vegetation	None	
612112	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
612113	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	General Comments		
612114	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
612115	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
612116	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
612117	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	150.0	
612118	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	150.0	
612119	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	60.0	
612120	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	80.0	
612121	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	80.0	
612122	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	110.0	
612123	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
612124	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
612125	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
612126	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
612127	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
612128	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
612129	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
612130	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
612131	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	2	
612132	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
612133	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
612134	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
612135	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
612136	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
612137	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Readings	General Comments		
612138	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
612139	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
612140	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
612141	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
612142	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	13	
612143	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	129	
612144	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	129	
612145	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
612146	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
612147	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
612148	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
612149	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
612150	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0008	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
612151	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
612152	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
612153	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
612154	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
612155	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
612156	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
612157	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
612158	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
612159	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
612160	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
612161	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
612162	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
612163	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
612164	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
612165	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Readings	General Comments		
612166	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
612167	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
612168	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
612169	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
612170	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	9	
612171	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1234	
612172	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1239	
612173	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
612174	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0149	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	5	
612175	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	General Comments		
612176	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	120.0	
612177	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	100.0	
612178	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	100.0	
612179	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
612180	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
612181	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
612182	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
612183	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
612184	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
612185	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
612186	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
612187	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
612188	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
612189	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
612190	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
612191	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
612192	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
612193	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Readings	General Comments		
612194	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
612195	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
612196	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
612197	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
612198	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	10	
612199	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	69	
612200	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	75	
612201	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
612202	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	6	
612203	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
612204	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
612205	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
612206	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0137	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
612207	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
612208	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
612209	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
612210	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
612211	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
612212	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
612213	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
612214	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
612215	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
612216	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
612217	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
612218	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
612219	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
612220	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	General Comments		
612221	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
612222	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Ambient Temp	41	°F
612223	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
612224	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Clear of Trash?	y	
612225	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
612226	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
612227	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
612228	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	General Comments		
612229	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
612230	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
612231	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
612232	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
612233	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
612234	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Vegetation	None	
612235	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
612236	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
612237	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Follow-up Action Required?	n	
612238	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
612239	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
612240	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	General Comments		
612241	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	General Comments		
612242	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
612243	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	LTC Totalizer Reading	8428.80	kw
612244	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
612245	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
612246	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Oil Temp Max	60	°C
612247	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
612248	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
612249	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
612250	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
612251	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Bushing Condition	Good	
612252	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Amps C Ø	225.0	
612253	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Amps B Ø	250.0	
612254	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Amps A Ø	225.0	
612255	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
612256	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
612257	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
612258	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	9 Month Operations	5	
612259	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
612260	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
612261	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
612262	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
612263	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
612264	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
612265	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	LTCC000357	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
612266	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	LTCC000357	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
612267	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	LTCC000357	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
612268	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
612269	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
612270	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
612271	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
612272	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
612273	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	LTCC000357	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
612274	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	LTCC000357	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
612275	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	LTCC000357	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
612276	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	LTCC000357	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
612277	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	LTCC000357	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
612278	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
612279	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
612280	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
612281	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
612282	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
612283	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
612284	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
612285	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
612286	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
612287	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	General Comments		
612288	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
612289	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
612290	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
612291	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
612292	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
612293	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	43	°F
612294	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
612295	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
612296	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
612297	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
612298	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	LTC Operation Checked?	y	
612299	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	General Comments		
612300	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
612301	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
612302	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
612303	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
612304	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
612305	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
612306	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
612307	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	General Comments		
612308	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
612309	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
612310	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
612311	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
612312	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	Follow-up Action Required?	n	
612313	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	All Connections OK?	y	
612314	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
612315	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	As Found Float Voltage	134.1	VDC
612316	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	As Left Float Voltage	134.1	VDC
612317	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
612318	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
612319	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
612320	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
612321	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
612322	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
612323	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
612324	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Follow-up Action Required?	n	
612325	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
612326	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
612327	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Switching Operations	4	
612328	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
612329	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Operations Counter AL	287	
612330	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Operations Counter AF	283	
612331	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Moisture and Leak Free?	y	
612332	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Maintenance Operations	0	
612333	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Heaters (All) Functioning?	y	
612334	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Grounds in Place?	y	
612335	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	General Comments		
612336	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	General Comments		
612337	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Foundation Condition	Good	
612338	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Follow-up Action Required?	n	
612339	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Follow-up Action Required?	n	
612340	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Operations Ground	0	
612341	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Operations C Ø	0	
612342	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Operations B Ø	0	
612343	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Operations A Ø	1	
612344	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
612345	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
612346	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Adjusted Amps A Phase V	5.07	
612347	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Equipment Properly Labeled?	y	
612348	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Cabinet Paint Condition	Good	
612349	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
612350	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
612351	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
612352	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Bushings Connection/Risers	Good	
612353	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	General Comments		
612354	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	General Comments		
612355	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
612356	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Bushing Condition	Good	
612357	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Amps C Ø	60.0	
612358	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Amps B Ø	20.0	
612359	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Amps A Ø	20.0	
612360	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Accumulated Fault Duty C Ph V	1.51	%
612361	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Accumulated Fault Duty B Ph V	2.27	%
612362	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Accumulated Fault Duty A Ph V	1.89	%
612363	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	9 Month Operations	9	
612364	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
612365	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
612366	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
612367	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
612368	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
612369	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
612370	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
612371	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
612372	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
612373	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
612374	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
612375	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
612376	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
612377	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
612378	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
612379	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
612380	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC Operations Since Last Insp	399	
612381	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC Min Tap Position	8L	
612382	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC Max Tap Position	5R	
612383	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	LTC Totalizer Reading	7420.80	kw
612384	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
612385	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
612386	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Oil Temp Max	55	°C
612387	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
612388	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
612389	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
612390	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
612391	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
612392	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
612393	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
612394	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
612395	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
612396	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
612397	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
612398	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
612399	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
612400	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Totalizer Meter Reading	1.0536	
612401	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
612402	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
612403	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
612404	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
612405	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
612406	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	42	°F
612407	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
612408	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
612409	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
612410	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
612411	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
612412	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
612413	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
612414	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
612415	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	General Comments		
612416	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
612417	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
612418	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
612419	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
612420	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	9 Month Operations	5	
612421	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
612422	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
612423	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
612424	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Amps A Ø	352.0	
612425	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Amps B Ø	330.0	
612426	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Amps C Ø	370.0	
612427	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Bushing Condition	Good	
612428	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
612429	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
612430	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
612431	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
612432	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
612433	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
612434	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
612435	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
612436	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
612437	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Operations A Ø	0	
612438	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Operations B Ø	0	
612439	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Operations C Ø	0	
612440	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Operations Ground	0	
612441	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Follow-up Action Required?	n	
612442	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Follow-up Action Required?	n	
612443	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Foundation Condition	Good	
612444	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	General Comments		
612445	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	General Comments		
612446	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Grounds in Place?	y	
612447	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Maintenance Operations	0	
612448	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
612449	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Operations Counter AF	170	
612450	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Operations Counter AL	174	
612451	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
612452	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Switching Operations	4	
612453	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Tank Paint Condition	Good	
612454	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Unknown Operations	0	
612455	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
612456	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
612457	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Unknown Operations	0	
612458	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Tank Paint Condition	Good	
612459	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
612460	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
612461	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
612462	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
612463	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
612464	1/17/2019 15:08	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
612465	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
612466	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
612467	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
612468	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
612469	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
612470	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
612471	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
612472	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
612473	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
612474	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
612475	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
612476	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
612477	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
612478	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	General Comments		
612479	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
612480	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
612481	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
612482	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
612483	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
612484	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
612485	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
612486	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
612487	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
612488	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
612489	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
612490	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
612491	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
612492	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	General Comments		
612493	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
612494	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Readings	General Comments		
612495	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
612496	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
612497	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
612498	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
612499	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	9	
612500	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	164	
612501	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	169	
612502	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
612503	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	5	
612504	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
612505	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
612506	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
612507	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
612508	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
612509	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	Oil Temp Max	35	°C
612510	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
612511	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
612512	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	41	°F
612513	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
612514	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
612515	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
612516	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
612517	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	General Comments		
612518	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
612519	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
612520	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
612521	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
612522	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
612523	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
612524	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	Oil Temp Max	25	°C
612525	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
612526	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
612527	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	LTC Totalizer Reading	4258.56	kw
612528	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
612529	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	General Comments		
612530	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	General Comments		
612531	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
612532	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
612533	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	124	
612534	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	128	
612535	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
612536	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
612537	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
612538	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
612539	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	140.0	
612540	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	150.0	
612541	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	130.0	
612542	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
612543	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
612544	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
612545	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
612546	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
612547	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
612548	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
612549	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
612550	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
612551	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	Oil Temp Present	38	°C
612552	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	Oil Temp Max	32	°C
612553	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
612554	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
612555	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	90	°C
612556	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
612557	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	General Comments	the winding temp gauge is old and broken. needs to be replaced.	
612558	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitro	
612559	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
612560	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
612561	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	y	
612562	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
612563	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
612564	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
612565	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
612566	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
612567	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
612568	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
612569	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
612570	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
612571	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
612572	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
612573	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
612574	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
612575	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
612576	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	Follow-up Action Required?	n	
612577	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
612578	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
612579	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
612580	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
612581	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
612582	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
612583	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
612584	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
612585	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
612586	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
612587	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	122.9	VAC
612588	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
612589	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
612590	1/17/2019 15:00	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
612591	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
612592	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
612593	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
612594	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
612595	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
612596	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
612597	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
612598	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
612599	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
612600	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	General Comments		
612601	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
612602	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
612603	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
612604	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
612605	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Unknown Operations	0	
612606	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Switching Operations	1	
612607	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Operations Counter AL	599	
612608	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Operations Counter AF	599	
612609	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Maintenance Operations	0	
612610	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
612611	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	General Comments		
612612	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Patrol Inspection	General Comments		
612613	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Follow-up Action Required?	n	
612614	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
612615	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Operations Ground	0	
612616	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Operations C Ø	0	
612617	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Operations B Ø	0	
612618	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Amps C Ø	110.0	
612619	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
612620	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
612621	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
612622	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
612623	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Operations A Ø	0	
612624	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Operations B Ø	0	
612625	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Operations C Ø	0	
612626	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Operations Ground	0	
612627	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
612628	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Follow-up Action Required?	n	
612629	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Patrol Inspection	General Comments		
612630	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Operations A Ø	0	
612631	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
612632	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
612633	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
612634	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
612635	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Amps C Ø	170.0	
612636	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Amps B Ø	160.0	
612637	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Amps A Ø	150.0	
612638	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
612639	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
612640	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
612641	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
612642	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
612643	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
612644	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
612645	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
612646	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
612647	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
612648	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
612649	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
612650	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	4.0	VDC
612651	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	5.0	VDC
612652	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
612653	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	BAT000588	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
612654	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
612655	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
612656	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
612657	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
612658	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
612659	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
612660	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Clear of Trash?	y	
612661	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
612662	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	General Comments		
612663	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
612664	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
612665	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
612666	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
612667	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
612668	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Vegetation	None	
612669	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
612670	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
612671	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
612672	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	General Comments		
612673	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
612674	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
612675	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
612676	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
612677	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
612678	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
612679	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Clear of Trash?	y	
612680	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
612681	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
612682	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Ambient Temp	41	°F
612683	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Vegetation	None	
612684	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
612685	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
612686	1/17/2019 10:09	Distribution	Procter and Gamble Quarterly Inspection	BB0134	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
612687	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
612688	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
612689	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
612690	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
612691	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
612692	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
612693	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
612694	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
612695	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
612696	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	9 Months Operations	23	
612697	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
612698	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
612699	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
612700	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Amps A Ø	50.0	
612701	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Amps B Ø	50.0	
612702	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
612703	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
612704	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
612705	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
612706	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
612707	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
612708	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
612709	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
612710	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
612711	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
612712	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
612713	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
612714	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
612715	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
612716	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
612717	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
612718	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.06	%
612719	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.12	%
612720	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.39	%
612721	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	17	
612722	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
612723	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
612724	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
612725	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	General Comments		
612726	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
612727	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
612728	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
612729	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
612730	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
612731	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Foundation Condition	Good	
612732	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
612733	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
612734	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
612735	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
612736	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
612737	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
612738	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
612739	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
612740	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
612741	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
612742	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
612743	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
612744	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
612745	1/17/2019 14:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
612746	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
612747	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
612748	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
612749	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
612750	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
612751	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
612752	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
612753	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
612754	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	80.0	
612755	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	80.0	
612756	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
612757	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	3.09	%
612758	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	3.09	%
612759	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	4.63	%
612760	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
612761	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
612762	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
612763	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
612764	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
612765	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
612766	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
612767	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
612768	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
612769	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
612770	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
612771	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
612772	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	378	
612773	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
612774	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
612775	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
612776	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
612777	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
612778	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
612779	1/17/2019 13:09	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
612780	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	Totalizer Meter Reading	.8872	
612781	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
612782	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	374	
612783	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
612784	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	1	
612785	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
612786	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
612787	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
612788	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
612789	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
612790	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
612791	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
612792	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
612793	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
612794	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	8.28	
612795	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	3.31	
612796	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
612797	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
612798	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	5	
612799	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	2	
612800	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
612801	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
612802	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
612803	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
612804	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
612805	1/17/2019 8:42	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
612806	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
612807	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
612808	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
612809	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
612810	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
612811	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
612812	1/17/2019 12:26	Distribution	Donerail Quarterly Inspection	BB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
612813	1/17/2019 10:40	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
612814	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
612815	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
612816	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
612817	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
612818	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
612819	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
612820	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
612821	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	300.0	
612822	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	300.0	
612823	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	300.0	
612824	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
612825	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
612826	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
612827	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
612828	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
612829	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	491	
612830	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	491	
612831	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
612832	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
612833	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
612834	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
612835	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	27.70	%
612836	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	345.0	
612837	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	310.0	
612838	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	280.0	
612839	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
612840	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
612841	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
612842	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
612843	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
612844	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	31.32	%
612845	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	26.50	%
612846	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
612847	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
612848	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	24	
612849	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
612850	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
612851	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
612852	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	785	
612853	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	785	
612854	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
612855	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
612856	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
612857	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
612858	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	
612859	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
612860	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	18.07	%
612861	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	18.07	%
612862	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	30.11	%
612863	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
612864	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
612865	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	44	
612866	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
612867	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	100.0	
612868	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
612869	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
612870	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
612871	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
612872	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
612873	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
612874	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	597	
612875	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	597	
612876	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
612877	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
612878	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
612879	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
612880	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
612881	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
612882	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
612883	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	4.82	%
612884	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	4.82	%
612885	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	2.41	%
612886	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	
612887	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
612888	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	100.0	
612889	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
612890	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
612891	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
612892	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
612893	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
612894	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
612895	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	740	
612896	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	740	
612897	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
612898	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
612899	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	410.0	
612900	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	390.0	
612901	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	450.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
612902	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	6.02	%
612903	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	7.23	%
612904	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	10.84	%
612905	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	8	
612906	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
612907	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
612908	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
612909	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	970	
612910	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	970	
612911	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
612912	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
612913	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
612914	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
612915	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
612916	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
612917	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
612918	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
612919	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
612920	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
612921	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
612922	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
612923	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
612924	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0965	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
612925	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
612926	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
612927	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
612928	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
612929	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
612930	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
612931	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
612932	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
612933	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
612934	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
612935	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
612936	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
612937	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
612938	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
612939	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
612940	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
612941	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Unknown Operations	0	
612942	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Switching Operations	0	
612943	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Operations Counter AL	391	
612944	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Operations Counter AF	391	
612945	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Maintenance Operations	0	
612946	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	General Comments	A Phase IOC	
612947	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Patrol Inspection	General Comments		
612948	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Follow-up Action Required?	n	
612949	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
612950	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Patrol Inspection	Follow-up Action Required?	n	
612951	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
612952	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
612953	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
612954	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
612955	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
612956	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
612957	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
612958	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
612959	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
612960	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
612961	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
612962	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
612963	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
612964	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
612965	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
612966	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
612967	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
612968	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
612969	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
612970	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
612971	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
612972	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Tank Leaks	None	
612973	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
612974	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
612975	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Regulator As Left Counter	91595	
612976	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123	volts

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
612977	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
612978	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
612979	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
612980	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
612981	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
612982	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
612983	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
612984	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
612985	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Bushing Condition	Good	
612986	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Amps C Ø	180.0	
612987	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Amps B Ø	160.0	
612988	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Amps A Ø	162.0	
612989	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
612990	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
612991	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
612992	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
612993	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
612994	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
612995	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
612996	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Winding Temp Present	29	°C
612997	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
612998	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
612999	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
613000	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
613001	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
613002	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
613003	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
613004	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
613005	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
613006	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
613007	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
613008	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
613009	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
613010	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
613011	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
613012	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
613013	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
613014	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
613015	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
613016	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
613017	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	13550.40	kw
613018	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
613019	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
613020	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	40	°C
613021	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	40	°C
613022	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
613023	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Operations Counter AL	195	
613024	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
613025	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Switching Operations	4	
613026	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Tank Paint Condition	Good	
613027	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Unknown Operations	0	
613028	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Operational?	y	
613029	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
613030	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
613031	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
613032	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
613033	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
613034	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
613035	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
613036	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
613037	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.9410	
613038	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	Winding Temp Max	50	°C
613039	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	Winding Temp Present	40	°C
613040	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
613041	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
613042	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
613043	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
613044	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	248	
613045	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	12L	
613046	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	2L	
613047	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	7L	
613048	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
613049	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
613050	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
613051	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
613052	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
613053	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
613054	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
613055	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
613056	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
613057	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
613058	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
613059	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
613060	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	114426	
613061	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	114426	
613062	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
613063	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
613064	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
613065	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Operations Ground	0	
613066	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Operations C Ø	0	
613067	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Operations B Ø	0	
613068	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Operations A Ø	1	
613069	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
613070	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
613071	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
613072	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
613073	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Amps C Ø	600.0	
613074	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Amps B Ø	250.0	
613075	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Amps A Ø	200.0	
613076	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Operations A Ø	0	
613077	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Operations B Ø	0	
613078	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Operations C Ø	0	
613079	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Operations Ground	0	
613080	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Follow-up Action Required?	n	
613081	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Follow-up Action Required?	n	
613082	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Foundation Condition	Good	
613083	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	General Comments		
613084	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	General Comments		
613085	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Grounds in Place?	y	
613086	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Maintenance Operations	0	
613087	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
613088	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Operations Counter AF	194	
613089	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Accumulated Fault Duty C Ph AM	10.84	%
613090	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Accumulated Fault Duty B Ph AM	12.05	%
613091	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Accumulated Fault Duty A Ph AM	14.45	%
613092	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	9 Months Operations	12	
613093	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
613094	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
613095	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	9 Month Operations	5	
613096	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
613097	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
613098	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
613099	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
613100	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
613101	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
613102	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
613103	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
613104	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
613105	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
613106	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
613107	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
613108	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Follow-up Action Required?	n	
613109	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
613110	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
613111	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	General Comments		
613112	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	General Comments		
613113	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
613114	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	LTC Totalizer Reading	12165.12	kw
613115	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
613116	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
613117	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Oil Temp Max	32	°C
613118	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Oil Temp Present	26	°C
613119	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
613120	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
613121	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
613122	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
613123	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
613124	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
613125	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
613126	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
613127	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Totalizer Meter Reading	1.2672	
613128	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Winding Temp Max	34	°C
613129	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
613130	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
613131	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
613132	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
613133	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	General Comments		
613134	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
613135	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
613136	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
613137	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
613138	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
613139	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
613140	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
613141	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
613142	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
613143	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
613144	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	General Comments		
613145	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
613146	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
613147	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
613148	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
613149	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
613150	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
613151	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
613152	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
613153	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Regulator As Left Counter	45163	
613154	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
613155	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
613156	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Tank Leaks	None	
613157	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
613158	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
613159	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Vegetation	None	
613160	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
613161	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
613162	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
613163	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
613164	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
613165	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
613166	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	General Comments		
613167	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
613168	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
613169	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
613170	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	TV Winding Temp Present	19	°C
613171	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	TV Winding Temp Max	31	°C
613172	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	9 Month Operations	4	
613173	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Accumulated Fault Duty A Ph V	1.59	%
613174	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Accumulated Fault Duty B Ph V	4.78	%
613175	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Accumulated Fault Duty C Ph V	7.97	%
613176	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Amps A Ø	39.0	
613177	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Amps B Ø	78.0	
613178	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Amps C Ø	72.0	
613179	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	9 Months Operations	0	
613180	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
613181	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
613182	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
613183	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Amps A Ø	130.0	
613184	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Amps B Ø	210.0	
613185	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Amps C Ø	50.0	
613186	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
613187	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
613188	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
613189	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
613190	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
613191	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Panel Lights OK?	y	
613192	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
613193	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	General Comments		
613194	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
613195	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
613196	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
613197	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
613198	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
613199	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
613200	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
613201	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
613202	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	General Comments		
613203	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
613204	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
613205	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
613206	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
613207	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
613208	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
613209	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
613210	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
613211	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	38	°F
613212	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
613213	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Unknown Operations	0	
613214	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Switching Operations	0	
613215	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Operations Counter AL	179	
613216	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Operations Counter AF	179	
613217	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Maintenance Operations	0	
613218	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	General Comments		
613219	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Patrol Inspection	General Comments		
613220	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Follow-up Action Required?	n	
613221	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Patrol Inspection	Follow-up Action Required?	n	
613222	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Operations Ground	0	
613223	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Operations C Ø	0	
613224	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Operations B Ø	0	
613225	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Operations A Ø	0	
613226	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
613227	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
613228	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
613229	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
613230	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Amps C Ø	110.0	
613231	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Amps B Ø	250.0	
613232	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Amps A Ø	250.0	
613233	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Accumulated Fault Duty C Ph AM	8.43	%
613234	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Accumulated Fault Duty B Ph AM	22.89	%
613235	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Accumulated Fault Duty A Ph AM	19.27	%
613236	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	9 Months Operations	11	
613237	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
613238	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Maintenance Operations	0	
613239	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
613240	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
613241	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
613242	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
613243	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
613244	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
613245	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Regulator As Left Counter	40671	
613246	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
613247	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
613248	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Tank Leaks	None	
613249	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
613250	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
613251	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
613252	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
613253	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
613254	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	Oil Temp Present	20	°C
613255	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	Oil Temp Max	33	°C
613256	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
613257	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
613258	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
613259	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	LV Winding Temp Present	20	°C
613260	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	LV Winding Temp Max	32	°C
613261	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	HV Winding Temp Present	22	°C
613262	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	HV Winding Temp Max	33	°C
613263	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
613264	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	General Comments		
613265	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	General Comments		
613266	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
613267	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
613268	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	Follow-up Action Required?	n	
613269	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
613270	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
613271	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
613272	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
613273	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
613274	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
613275	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
613276	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
613277	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	9 Month Operations	23	
613278	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Accumulated Fault Duty A Ph V	43.05	%
613279	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Accumulated Fault Duty B Ph V	37.47	%
613280	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Accumulated Fault Duty C Ph V	23.12	%
613281	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Amps A Ø	152.0	
613282	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Amps B Ø	163.0	
613283	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Amps C Ø	178.0	
613284	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
613285	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
613286	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
613287	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Operations A Ø	0	
613288	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Operations B Ø	0	
613289	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Operations C Ø	0	
613290	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
613291	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
613292	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
613293	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Operations A Ø	0	
613294	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Operations B Ø	0	
613295	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Operations C Ø	0	
613296	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Operations Ground	0	
613297	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
613298	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
613299	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
613300	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
613301	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
613302	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
613303	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Clear of Trash?	y	
613304	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
613305	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
613306	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Follow-up Action Required?	n	
613307	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	General Comments		
613308	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Maintenance Operations	2	
613309	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Operations Counter AF	165	
613310	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Operations Counter AL	165	
613311	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
613312	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Switching Operations	0	
613313	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Unknown Operations	0	
613314	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Ambient Temp	38	°F
613315	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
613316	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
613317	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Operations A Ø	0	
613318	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Operations B Ø	0	
613319	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Operations C Ø	0	
613320	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Operations Ground	0	
613321	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
613322	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Follow-up Action Required?	n	
613323	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Patrol Inspection	General Comments		
613324	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
613325	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
613326	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
613327	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
613328	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
613329	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
613330	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
613331	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
613332	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
613333	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
613334	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
613335	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
613336	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
613337	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	General Comments		
613338	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
613339	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
613340	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	General Comments		
613341	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
613342	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
613343	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
613344	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
613345	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	32	°C
613346	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	22	°C
613347	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	32	°C
613348	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	22	°C
613349	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	32	°C
613350	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	22	°C
613351	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
613352	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Switching Operations	0	
613353	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Operations Counter AL	143	
613354	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Operations Counter AF	143	
613355	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Maintenance Operations	0	
613356	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	General Comments		
613357	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Patrol Inspection	General Comments		
613358	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Follow-up Action Required?	n	
613359	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Patrol Inspection	Follow-up Action Required?	n	
613360	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Operations Ground	0	
613361	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Operations C Ø	0	
613362	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Operations B Ø	0	
613363	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Operations A Ø	0	
613364	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
613365	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
613366	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
613367	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
613368	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Amps C Ø	100.0	
613369	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Amps B Ø	250.0	
613370	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Amps A Ø	200.0	
613371	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Accumulated Fault Duty C Ph AM	7.23	%
613372	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Accumulated Fault Duty B Ph AM	13.25	%
613373	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Accumulated Fault Duty A Ph AM	9.64	%
613374	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	9 Months Operations	7	
613375	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	LTCC000143	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
613376	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	LTCC000143	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
613377	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	LTCC000143	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
613378	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	LTCC000143	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
613379	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	LTCC000143	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
613380	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	LTCC000143	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
613381	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	LTCC000143	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
613382	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	LTCC000143	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
613383	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	LTCC000816	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
613384	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	LTCC000816	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
613385	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	LTCC000816	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
613386	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	LTCC000816	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
613387	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	LTCC000816	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Operation Checked?	y	
613388	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	LTCC000816	LTCControl	932-Offline Distribution	LTC Control Insp	General Comments		
613389	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	LTCC000816	LTCControl	932-Offline Distribution	LTC Control Insp	Follow-up Action Required?	n	
613390	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	LTCC000816	LTCControl	932-Offline Distribution	LTC Control Insp	All Connections OK?	y	
613391	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PF000346	PowerFuse	SW-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
613392	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PF000346	PowerFuse	SW-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
613393	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PF000347	PowerFuse	SW-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
613394	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
613395	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
613396	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	455	
613397	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	455	
613398	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
613399	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
613400	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
613401	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
613402	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
613403	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
613404	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
613405	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
613406	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
613407	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
613408	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
613409	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
613410	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
613411	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
613412	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
613413	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
613414	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
613415	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
613416	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
613417	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	0	
613418	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
613419	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
613420	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
613421	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
613422	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
613423	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
613424	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
613425	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
613426	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
613427	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
613428	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
613429	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
613430	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
613431	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
613432	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
613433	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
613434	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	General Comments		
613435	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
613436	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
613437	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
613438	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	Oil Temp Max	26	°C
613439	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	Oil Temp Present	13	°C
613440	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
613441	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
613442	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
613443	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
613444	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
613445	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
613446	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
613447	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
613448	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	5	
613449	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	7L	
613450	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	6L	
613451	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	6L	
613452	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
613453	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	122168	
613454	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	122168	
613455	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments	ok	
613456	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
613457	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
613458	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
613459	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
613460	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
613461	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
613462	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
613463	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
613464	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
613465	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	188	
613466	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	188	
613467	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
613468	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
613469	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
613470	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
613471	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
613472	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	General Comments		
613473	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
613474	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
613475	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
613476	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
613477	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
613478	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
613479	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
613480	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
613481	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
613482	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
613483	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
613484	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
613485	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	100.0	
613486	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	110.0	
613487	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	120.0	
613488	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
613489	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	General Comments		
613490	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
613491	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
613492	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
613493	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
613494	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
613495	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
613496	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
613497	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
613498	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PF000347	PowerFuse	SW-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
613499	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.700	millivolts
613500	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	27.1	VDC
613501	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	27.1	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
613502	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
613503	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
613504	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
613505	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	General Comments		
613506	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	9 Months Operations	1	
613507	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
613508	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
613509	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
613510	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Amps A Ø	140.0	
613511	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Amps B Ø	140.0	
613512	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Amps C Ø	130.0	
613513	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
613514	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
613515	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
613516	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
613517	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Operations A Ø	0	
613518	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Operations B Ø	0	
613519	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Operations C Ø	0	
613520	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Operations Ground	0	
613521	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
613522	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Follow-up Action Required?	n	
613523	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Patrol Inspection	General Comments		
613524	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	General Comments		
613525	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
613526	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Maintenance Operations	0	
613527	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Operations Counter AF	377	
613528	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Operations Counter AL	377	
613529	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Switching Operations	0	
613530	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Unknown Operations	0	
613531	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PF000348	PowerFuse	SW-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
613532	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PF000348	PowerFuse	SW-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
613533	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PF000349	PowerFuse	SW-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
613534	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PF000349	PowerFuse	SW-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
613535	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
613536	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
613537	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
613538	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	66	
613539	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	10L	
613540	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	6L	
613541	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	8L	
613542	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
613543	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	134332	
613544	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	134332	
613545	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments	ok	
613546	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
613547	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
613548	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
613549	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
613550	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
613551	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
613552	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	General Comments		
613553	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	General Comments		
613554	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
613555	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	LTC Totalizer Reading	6370.56	kw
613556	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
613557	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
613558	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Oil Temp Max	30	°C
613559	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Oil Temp Present	17	°C
613560	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
613561	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
613562	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	Follow-up Action Required?	n	
613563	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
613564	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	General Comments		
613565	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	General Comments		
613566	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC As Found Counter	84867	
613567	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
613568	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
613569	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
613570	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
613571	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
613572	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
613573	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Totalizer Meter Reading	.6636	
613574	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC As Left Counter	84870	
613575	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
613576	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC Current Tap Position	5L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
613577	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
613578	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
613579	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	13.53	%
613580	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	17.29	%
613581	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	20.29	%
613582	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	144.0	
613583	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	144.0	
613584	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	146.0	
613585	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
613586	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
613587	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
613588	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Winding Temp Max	29	°C
613589	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC Min Tap Position	16L	
613590	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC Operations Since Last Insp	736	
613591	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Winding Temp Present	18	°C
613592	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
613593	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
613594	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC As Left Counter	71908	
613595	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
613596	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
613597	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Tank Leaks	None	
613598	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
613599	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
613600	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Regulator As Left Counter	71114	
613601	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
613602	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
613603	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
613604	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
613605	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
613606	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
613607	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
613608	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
613609	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
613610	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
613611	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	General Comments		
613612	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
613613	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
613614	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
613615	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
613616	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	40.0	
613617	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	40.0	
613618	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	40.0	
613619	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
613620	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
613621	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
613622	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
613623	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
613624	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1825	
613625	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1825	
613626	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
613627	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
613628	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
613629	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
613630	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
613631	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
613632	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
613633	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
613634	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
613635	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
613636	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
613637	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
613638	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	General Comments		
613639	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
613640	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC As Found Counter	71908	
613641	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
613642	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
613643	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
613644	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
613645	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
613646	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
613647	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
613648	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
613649	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
613650	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
613651	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
613652	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Follow-up Action Required?	n	
613653	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	527	
613654	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
613655	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
613656	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
613657	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
613658	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
613659	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
613660	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
613661	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	General Comments		
613662	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
613663	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
613664	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
613665	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
613666	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
613667	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
613668	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
613669	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
613670	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
613671	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
613672	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
613673	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
613674	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
613675	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
613676	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
613677	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
613678	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
613679	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
613680	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
613681	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
613682	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
613683	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
613684	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
613685	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
613686	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	General Comments		
613687	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	General Comments		
613688	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
613689	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
613690	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
613691	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	671.76	kw
613692	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	210	
613693	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200	
613694	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Oil Temp Max	46	°C
613695	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
613696	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
613697	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
613698	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
613699	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
613700	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
613701	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
613702	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
613703	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
613704	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5598	
613705	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
613706	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
613707	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
613708	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
613709	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
613710	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
613711	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
613712	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
613713	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	General Comments		
613714	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
613715	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
613716	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
613717	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
613718	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
613719	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
613720	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
613721	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
613722	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
613723	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
613724	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
613725	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5L	
613726	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
613727	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
613728	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	79	
613729	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
613730	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
613731	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
613732	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
613733	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BCH000551	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
613734	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BCH000551	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
613735	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BCH000551	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
613736	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BCH000551	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.8	amps
613737	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BCH000551	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
613738	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BCH000551	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
613739	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.900	millivolts
613740	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.4	VDC
613741	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.4	VDC
613742	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	6.0	amps
613743	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
613744	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
613745	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
613746	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
613747	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
613748	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
613749	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
613750	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
613751	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	General Comments		
613752	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
613753	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
613754	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
613755	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	15	
613756	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	527	
613757	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
613758	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
613759	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Trash Emptied?	y	
613760	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
613761	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
613762	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Panels Dusted?	y	
613763	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
613764	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
613765	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	General Comments		
613766	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
613767	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
613768	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Floor Swept?	y	
613769	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
613770	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
613771	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Evidence of Insects	None	
613772	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
613773	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
613774	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
613775	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
613776	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Broom on Site?	y	
613777	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
613778	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
613779	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	9 Month Operations	22	
613780	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Accumulated Fault Duty A Ph V	7.97	%
613781	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Accumulated Fault Duty B Ph V	7.97	%
613782	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Accumulated Fault Duty C Ph V	7.17	%
613783	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Amps A Ø	29.0	
613784	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Amps B Ø	28.0	
613785	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Amps C Ø	26.0	
613786	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
613787	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
613788	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
613789	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Operations A Ø	0	
613790	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	LTCC000453	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
613791	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	LTCC000453	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
613792	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	LTCC000453	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
613793	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	LTCC000453	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
613794	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	LTCC000453	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
613795	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	LTCC000453	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
613796	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	LTCC000453	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
613797	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	LTCC000453	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
613798	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	LTCC000453	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
613799	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Operations B Ø	0	
613800	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Operations C Ø	0	
613801	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
613802	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Follow-up Action Required?	n	
613803	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	General Comments		
613804	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Maintenance Operations	0	
613805	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Operations Counter AF	137	
613806	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Operations Counter AL	137	
613807	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Switching Operations	0	
613808	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Unknown Operations	0	
613809	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Operations Ground	0	
613810	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Follow-up Action Required?	n	
613811	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	General Comments		
613812	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Maintenance Operations	8	
613813	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Operations Counter AF	251	
613814	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Operations Counter AL	251	
613815	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Switching Operations	0	
613816	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Unknown Operations	0	
613817	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
613818	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Operations Counter AF	506	
613819	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Operations Counter AL	506	
613820	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Switching Operations	0	
613821	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Unknown Operations	0	
613822	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
613823	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
613824	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
613825	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	9 Month Operations	9	
613826	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Accumulated Fault Duty A Ph V	15.94	%
613827	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Accumulated Fault Duty B Ph V	11.96	%
613828	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Accumulated Fault Duty C Ph V	7.97	%
613829	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Amps A Ø	61.0	
613830	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Amps B Ø	47.0	
613831	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Amps C Ø	86.0	
613832	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
613833	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
613834	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
613835	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Operations A Ø	0	
613836	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Operations B Ø	0	
613837	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Operations C Ø	0	
613838	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Operations Ground	0	
613839	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Follow-up Action Required?	n	
613840	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	General Comments		
613841	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Maintenance Operations	1	
613842	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Operations Counter AF	167	
613843	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Operations Counter AL	167	
613844	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Switching Operations	0	
613845	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Unknown Operations	0	
613846	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
613847	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	General Comments		
613848	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
613849	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
613850	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
613851	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
613852	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
613853	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
613854	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
613855	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
613856	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
613857	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
613858	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
613859	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
613860	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
613861	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
613862	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Clear of Trash?	y	
613863	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
613864	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
613865	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Ambient Temp	38	°F
613866	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
613867	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
613868	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
613869	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
613870	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
613871	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
613872	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
613873	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	35	°F
613874	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
613875	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
613876	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
613877	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
613878	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
613879	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
613880	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
613881	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
613882	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	General Comments		
613883	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
613884	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Foundation Condition	Good	
613885	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
613886	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
613887	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Vegetation	None	
613888	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
613889	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
613890	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
613891	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
613892	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
613893	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	General Comments	This Station should not have a spill kit it's not on the the list to have one. DJ	
613894	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
613895	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
613896	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
613897	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
613898	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
613899	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
613900	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Clear of Trash?	y	
613901	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	180.0	
613902	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	120.0	
613903	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
613904	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
613905	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
613906	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
613907	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
613908	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
613909	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	100.0	
613910	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
613911	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
613912	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
613913	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
613914	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
613915	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
613916	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
613917	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
613918	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
613919	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
613920	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
613921	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
613922	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
613923	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	2371	
613924	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
613925	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
613926	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
613927	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
613928	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
613929	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC As Left Counter	456035	
613930	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC As Found Counter	456035	
613931	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
613932	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	General Comments		
613933	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
613934	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
613935	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
613936	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
613937	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
613938	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
613939	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	2643	
613940	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
613941	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
613942	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
613943	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
613944	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
613945	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC As Left Counter	457367	
613946	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC As Found Counter	457367	
613947	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
613948	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	General Comments		
613949	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
613950	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
613951	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
613952	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
613953	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
613954	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Vegetation	None	
613955	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
613956	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
613957	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
613958	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
613959	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	General Comments		
613960	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
613961	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
613962	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
613963	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
613964	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
613965	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
613966	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
613967	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
613968	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
613969	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
613970	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
613971	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
613972	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
613973	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	500.0	
613974	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	475.0	
613975	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
613976	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	General Comments		
613977	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
613978	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
613979	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
613980	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	475.0	
613981	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
613982	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
613983	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
613984	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
613985	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
613986	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
613987	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	9 Month Operations	4	
613988	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
613989	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
613990	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
613991	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
613992	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
613993	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
613994	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
613995	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
613996	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
613997	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
613998	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
613999	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
614000	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
614001	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
614002	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
614003	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
614004	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
614005	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
614006	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
614007	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
614008	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
614009	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Operations Counter AL	171	
614010	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Operations Counter AF	164	
614011	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
614012	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
614013	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
614014	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
614015	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
614016	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
614017	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
614018	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
614019	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
614020	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
614021	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
614022	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
614023	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	21.79	%
614024	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
614025	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
614026	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
614027	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	General Comments		
614028	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
614029	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	General Comments		
614030	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
614031	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
614032	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	23.30	%
614033	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
614034	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Foundation Condition	Good	
614035	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
614036	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
614037	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
614038	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
614039	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Switching Operations	0	
614040	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Operations Counter AL	49	
614041	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Operations Counter AF	49	
614042	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
614043	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
614044	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
614045	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
614046	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
614047	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Maintenance Operations	0	
614048	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	General Comments		
614049	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Patrol Inspection	General Comments		
614050	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
614051	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
614052	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
614053	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
614054	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
614055	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
614056	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
614057	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
614058	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
614059	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
614060	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
614061	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
614062	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
614063	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	General Comments		
614064	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
614065	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
614066	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
614067	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
614068	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
614069	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
614070	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
614071	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Amps C Ø	300.0	
614072	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Amps B Ø	300.0	
614073	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Amps A Ø	300.0	
614074	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	2.60	%
614075	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	2.60	%
614076	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	2.60	%
614077	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	9 Months Operations	2	
614078	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
614079	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Foundation Condition	Good	
614080	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
614081	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	55	°C
614082	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
614083	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
614084	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
614085	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	3.33	%
614086	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
614087	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	110.0	
614088	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	140.0	
614089	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
614090	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
614091	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
614092	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Tank Leaks	None	
614093	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Follow-up Action Required?	n	
614094	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Operations Ground	0	
614095	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
614096	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
614097	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
614098	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
614099	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
614100	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
614101	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
614102	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
614103	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
614104	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	9 Months Operations	0	
614105	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
614106	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
614107	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
614108	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
614109	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Operations Counter AL	296	
614110	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Operations C Ø	0	
614111	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Operations B Ø	0	
614112	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
614113	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
614114	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
614115	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
614116	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
614117	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
614118	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
614119	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
614120	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
614121	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Operations A Ø	0	
614122	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Operations A Ø	0	
614123	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
614124	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
614125	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
614126	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
614127	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
614128	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
614129	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
614130	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
614131	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Amps A Ø	180.0	
614132	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Amps B Ø	200.0	
614133	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Amps C Ø	240.0	
614134	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Bushing Condition	Good	
614135	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Bushings Connection/Risers	Good	
614136	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
614137	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
614138	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
614139	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
614140	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
614141	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
614142	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
614143	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
614144	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
614145	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
614146	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
614147	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
614148	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	General Comments		
614149	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	9 Months Operations	0	
614150	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
614151	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Maintenance Operations	0	
614152	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
614153	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
614154	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
614155	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
614156	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
614157	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Amps A Ø	0.0	
614158	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Amps B Ø	0.0	
614159	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Amps C Ø	0.0	
614160	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
614161	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BCH000973	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
614162	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BCH000973	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
614163	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BCH000973	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
614164	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BCH000973	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
614165	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	LTCC000155	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
614166	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	LTCC000155	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
614167	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	LTCC000155	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
614168	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	LTCC000155	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
614169	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	LTCC000155	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
614170	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	LTCC000155	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
614171	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	LTCC000155	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
614172	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	LTCC000155	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
614173	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BCH000973	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	134.5	VDC
614174	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
614175	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	5.83	%
614176	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	5.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
614177	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BCH000973	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	134.5	VDC
614178	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9006	
614179	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Grounds in Place?	y	
614180	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	General Comments		
614181	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
614182	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
614183	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
614184	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
614185	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
614186	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
614187	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
614188	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	General Comments		
614189	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	60	°C
614190	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Regulator As Left Counter	35720	
614191	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Foundation Condition	Good	
614192	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Follow-up Action Required?	n	
614193	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
614194	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
614195	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
614196	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	55	°C
614197	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
614198	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Tank Paint Condition	Good	
614199	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Unknown Operations	0	
614200	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
614201	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
614202	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
614203	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
614204	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
614205	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
614206	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
614207	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
614208	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
614209	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Operational?	y	
614210	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
614211	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	30	°C
614212	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	30	°C
614213	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
614214	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
614215	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	Follow-up Action Required?	n	
614216	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
614217	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	General Comments		
614218	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	General Comments		
614219	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC As Found Counter	73634	
614220	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC As Left Counter	73639	
614221	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
614222	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC Current Tap Position	4L	
614223	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
614224	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments	oil leak under pump not sure if its active	
614225	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
614226	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
614227	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
614228	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	4444	
614229	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	4444	
614230	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
614231	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
614232	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
614233	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
614234	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
614235	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
614236	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
614237	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
614238	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC Max Tap Position	2L	
614239	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC Min Tap Position	9L	
614240	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC Operations Since Last Insp	556	
614241	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
614242	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
614243	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
614244	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
614245	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
614246	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
614247	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
614248	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
614249	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
614250	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
614251	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
614252	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
614253	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
614254	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
614255	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
614256	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
614257	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
614258	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
614259	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
614260	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
614261	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
614262	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
614263	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
614264	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
614265	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
614266	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
614267	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	9 Month Operations	17	
614268	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Accumulated Fault Duty A Ph V	3.45	%
614269	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Accumulated Fault Duty B Ph V	5.29	%
614270	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Accumulated Fault Duty C Ph V	3.45	%
614271	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Amps A Ø	15.5	
614272	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Amps B Ø	16.7	
614273	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Amps C Ø	11.7	
614274	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Bushing Condition	Good	
614275	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X3 Winding Temp Present	30	°C
614276	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X3 Winding Temp Max	40	°C
614277	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X2 Winding Temp Present	30	°C
614278	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X2 Winding Temp Max	35	°C
614279	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Present	30	°C
614280	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Max	35	°C
614281	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
614282	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
614283	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
614284	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
614285	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	8645.76	kw
614286	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
614287	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
614288	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
614289	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Bushings Connection/Risers	Good	
614290	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
614291	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
614292	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
614293	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Cabinet Paint Condition	Good	
614294	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Equipment Properly Labeled?	y	
614295	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Adjusted Amps A Phase V	17.26	
614296	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
614297	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Adjusted Amps C Phase V	17.26	
614298	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Operations A Ø	4	
614299	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Operations B Ø	0	
614300	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Operations C Ø	4	
614301	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Operations Ground	0	
614302	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Follow-up Action Required?	n	
614303	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Follow-up Action Required?	n	
614304	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Foundation Condition	Good	
614305	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	General Comments		
614306	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	General Comments		
614307	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Grounds in Place?	y	
614308	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Heaters (All) Functioning?	y	
614309	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Maintenance Operations	0	
614310	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Moisture and Leak Free?	y	
614311	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Operations Counter AF	118	
614312	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Operations Counter AL	119	
614313	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
614314	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Switching Operations	5	
614315	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Switching Operations	3	
614316	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Tank Paint Condition	Good	
614317	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Unknown Operations	0	
614318	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
614319	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
614320	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	480.0	
614321	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	480.0	
614322	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	480.0	
614323	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Unknown Operations	0	
614324	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
614325	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
614326	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
614327	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
614328	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
614329	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
614330	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
614331	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
614332	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
614333	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
614334	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
614335	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Operations A Ø	0	
614336	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Operations B Ø	0	
614337	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Operations C Ø	0	
614338	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Operations Ground	0	
614339	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
614340	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Follow-up Action Required?	n	
614341	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Patrol Inspection	General Comments		
614342	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	General Comments		
614343	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
614344	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Maintenance Operations	0	
614345	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Operations Counter AF	296	
614346	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
614347	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
614348	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
614349	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
614350	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
614351	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
614352	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
614353	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
614354	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
614355	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
614356	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
614357	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
614358	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
614359	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
614360	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
614361	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
614362	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
614363	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
614364	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
614365	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
614366	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
614367	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
614368	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
614369	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	150.0	
614370	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	144.0	
614371	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
614372	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	14.28	%
614373	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
614374	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
614375	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
614376	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
614377	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
614378	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
614379	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
614380	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
614381	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
614382	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
614383	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
614384	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
614385	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
614386	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
614387	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
614388	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	9 Month Operations	13	
614389	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Accumulated Fault Duty A Ph V	1.15	%
614390	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Accumulated Fault Duty B Ph V	.69	%
614391	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Accumulated Fault Duty C Ph V	1.84	%
614392	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Amps A Ø	20.3	
614393	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
614394	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
614395	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
614396	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
614397	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
614398	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
614399	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
614400	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
614401	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Amps B Ø	19.9	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
614402	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Amps C Ø	16.4	
614403	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Bushing Condition	Good	
614404	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Bushings Connection/Risers	Good	
614405	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
614406	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
614407	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
614408	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Cabinet Paint Condition	Good	
614409	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Equipment Properly Labeled?	y	
614410	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
614411	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Adjusted Amps B Phase V	8.63	
614412	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
614413	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Adjusted Amps C Phase V	8.63	
614414	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Operations A Ø	0	
614415	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Operations B Ø	2	
614416	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Operations C Ø	2	
614417	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Operations Ground	0	
614418	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Follow-up Action Required?	n	
614419	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Follow-up Action Required?	n	
614420	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Foundation Condition	Good	
614421	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	General Comments		
614422	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	General Comments		
614423	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Grounds in Place?	y	
614424	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Heaters (All) Functioning?	y	
614425	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Maintenance Operations	0	
614426	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Moisture and Leak Free?	y	
614427	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
614428	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
614429	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Operations Counter AF	53	
614430	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Operations Counter AL	54	
614431	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
614432	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
614433	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
614434	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Clear of Trash?	y	
614435	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
614436	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
614437	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
614438	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
614439	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
614440	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	General Comments		
614441	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
614442	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
614443	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Vegetation	None	
614444	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
614445	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	General Comments		
614446	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	General Comments		
614447	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Foundation Condition	Good	
614448	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Follow-up Action Required?	n	
614449	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
614450	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
614451	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
614452	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
614453	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
614454	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	135.0	
614455	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	240.0	
614456	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	144.0	
614457	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Follow-up Action Required?	n	
614458	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Operations Ground	0	
614459	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	General Comments		
614460	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
614461	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Operations Counter	195	
614462	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
614463	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
614464	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Operations C Ø	0	
614465	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Operations B Ø	0	
614466	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Operations A Ø	0	
614467	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
614468	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
614469	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
614470	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Equipment Properly Labeled?	y	
614471	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LTCC000333	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
614472	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LTCC000333	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
614473	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LTCC000333	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
614474	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LTCC000333	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
614475	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Cabinet Paint Condition	Good	
614476	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	15.03	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
614477	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	8.27	%
614478	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	10.52	%
614479	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
614480	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
614481	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
614482	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Bushings Connection/Risers	Good	
614483	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Bushing Condition	Good	
614484	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Amps C Ø	140.0	
614485	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Amps B Ø	150.0	
614486	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Operations Counter AL	530	
614487	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BCH000589	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
614488	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Unknown Operations	0	
614489	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Switching Operations	0	
614490	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
614491	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Crumbling	
614492	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
614493	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
614494	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
614495	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
614496	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
614497	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
614498	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
614499	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
614500	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
614501	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
614502	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
614503	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
614504	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	General Comments		
614505	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
614506	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
614507	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
614508	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
614509	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
614510	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
614511	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
614512	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
614513	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	2	
614514	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LTCC000334	LTCControl	SW-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
614515	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LTCC000334	LTCControl	SW-TRANS 1	LTC Control Insp	General Comments		
614516	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LTCC000334	LTCControl	SW-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
614517	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LTCC000334	LTCControl	SW-TRANS 1	LTC Control Insp	All Connections OK?	y	
614518	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Maintenance Operations	0	
614519	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Heaters (All) Functioning?	y	
614520	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Grounds in Place?	y	
614521	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
614522	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
614523	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
614524	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Amps A Ø	0	
614525	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Amps B Ø	15	
614526	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Amps C Ø	0	
614527	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
614528	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
614529	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
614530	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
614531	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
614532	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	0	
614533	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
614534	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	9.37	
614535	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
614536	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
614537	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
614538	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
614539	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
614540	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
614541	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Amps B Ø	267.0	
614542	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Amps A Ø	288.0	
614543	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Accumulated Fault Duty C Ph V	1.93	%
614544	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Accumulated Fault Duty B Ph V	1.93	%
614545	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Accumulated Fault Duty A Ph V	1.93	%
614546	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	9 Month Operations	2	
614547	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Ambient Temp	38	°F
614548	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Operations Ground	0	
614549	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
614550	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
614551	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	All Connections OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
614552	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	37	°F
614553	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Battery Bank Amps	2.8	AMPS
614554	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Battery Bank Volts	54.0	VDC
614555	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
614556	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
614557	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Follow-up Action Required?	n	
614558	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Patrol Inspection	General Comments		
614559	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	General Comments		
614560	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
614561	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
614562	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
614563	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
614564	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
614565	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
614566	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
614567	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
614568	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
614569	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	36.67	%
614570	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	39.17	%
614571	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	36.67	%
614572	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
614573	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
614574	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	9 Months Operations	2	
614575	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
614576	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
614577	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
614578	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
614579	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
614580	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
614581	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	General Comments		
614582	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
614583	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
614584	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
614585	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
614586	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
614587	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
614588	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
614589	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
614590	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
614591	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
614592	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
614593	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
614594	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
614595	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
614596	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Operations A Ø	0	
614597	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
614598	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
614599	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
614600	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Equipment Properly Labeled?	y	
614601	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Operations Counter AL	618	
614602	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Operations Counter AF	618	
614603	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Maintenance Operations	0	
614604	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
614605	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Cabinet Paint Condition	Good	
614606	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BCH000589	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
614607	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BCH000589	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
614608	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Amps A Ø	150.0	
614609	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Accumulated Fault Duty C Ph V	.98	%
614610	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Accumulated Fault Duty B Ph V	.98	%
614611	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Accumulated Fault Duty A Ph V	4.88	%
614612	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	9 Month Operations	2	
614613	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
614614	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Percent Thermal Load A Ø Max	-60	%
614615	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
614616	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Percent Thermal Load C Ø Max	-60	%
614617	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
614618	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
614619	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
614620	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Clear of Trash?	y	
614621	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
614622	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
614623	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
614624	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
614625	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
614626	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
614627	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	General Comments		
614628	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
614629	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
614630	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Vegetation	None	
614631	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	LTCC000456	LTCControl	977-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
614632	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	LTCC000456	LTCControl	977-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
614633	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	LTCC000456	LTCControl	977-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
614634	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
614635	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BCH000589	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.6	VDC
614636	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BCH000589	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.6	VDC
614637	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BCH000589	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
614638	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
614639	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
614640	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
614641	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
614642	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
614643	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
614644	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	LTCC000456	LTCControl	977-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	118.1	VAC
614645	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	LTCC000456	LTCControl	977-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
614646	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	LTCC000456	LTCControl	977-Offline-Distribution	LTC Control Insp	General Comments		
614647	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	LTCC000456	LTCControl	977-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
614648	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Foundation Condition	Good	
614649	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
614650	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
614651	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	LTCC000456	LTCControl	977-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
614652	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Switching Operations	0	
614653	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Unknown Operations	0	
614654	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Operations A Ø	0	
614655	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Operations B Ø	0	
614656	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
614657	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
614658	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
614659	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
614660	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
614661	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Operations C Ø	0	
614662	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	General Comments		
614663	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
614664	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
614665	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
614666	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	Follow-up Action Required?	n	
614667	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
614668	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
614669	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
614670	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
614671	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
614672	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	185	
614673	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
614674	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Amps A Ø	285.0	
614675	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	185	
614676	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
614677	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
614678	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
614679	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
614680	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
614681	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
614682	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
614683	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
614684	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
614685	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
614686	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
614687	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
614688	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
614689	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Patrol Inspection	Follow-up Action Required?	n	
614690	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
614691	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Follow-up Action Required?	n	
614692	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
614693	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Broom on Site?	y	
614694	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
614695	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
614696	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
614697	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
614698	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Evidence of Insects	None	
614699	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
614700	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
614701	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Floor Swept?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
614702	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
614703	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
614704	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
614705	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
614706	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
614707	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	General Comments		
614708	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
614709	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
614710	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Panels Dusted?	y	
614711	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
614712	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Trash Emptied?	y	
614713	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
614714	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
614715	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
614716	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
614717	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
614718	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
614719	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
614720	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
614721	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
614722	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
614723	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Operations B Ø	0	
614724	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Operations C Ø	0	
614725	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	334	
614726	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	9L	
614727	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	2L	
614728	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	8L	
614729	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
614730	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	121675	
614731	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	121675	
614732	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
614733	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
614734	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Operations Ground	0	
614735	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
614736	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Amps A Ø	100.0	
614737	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Amps B Ø	75.0	
614738	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
614739	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
614740	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
614741	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC Operations Since Last Insp	54	
614742	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC Min Tap Position	2L	
614743	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC Max Tap Position	4R	
614744	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
614745	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
614746	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
614747	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
614748	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
614749	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
614750	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Bushing Condition	Good	
614751	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Amps C Ø	300.0	
614752	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Amps B Ø	388.0	
614753	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Amps C Ø	100.0	
614754	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
614755	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
614756	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
614757	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
614758	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	8010	
614759	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	5010	
614760	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
614761	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
614762	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
614763	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
614764	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC As Left Counter	61733	
614765	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC As Found Counter	61721	
614766	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	General Comments		
614767	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
614768	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
614769	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
614770	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
614771	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
614772	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	226	
614773	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	226	
614774	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
614775	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
614776	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
614777	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
614778	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
614779	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
614780	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
614781	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	General Comments		
614782	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
614783	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
614784	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
614785	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Operations A Ø	0	
614786	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Operations B Ø	0	
614787	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Operations C Ø	0	
614788	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Operations Ground	0	
614789	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Follow-up Action Required?	n	
614790	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Follow-up Action Required?	n	
614791	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Foundation Condition	Good	
614792	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	General Comments		
614793	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	General Comments		
614794	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Grounds in Place?	y	
614795	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Maintenance Operations	7	
614796	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
614797	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Operations Counter AF	13	
614798	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Operations Counter AL	21	
614799	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Patrol Inspection	General Comments		
614800	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	General Comments	R&C	
614801	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Maintenance Operations	0	
614802	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	General Comments		
614803	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Operations Counter AF	530	
614804	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
614805	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Unknown Operations	0	
614806	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Tank Paint Condition	Good	
614807	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Switching Operations	0	
614808	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Operations Counter AL	227	
614809	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
614810	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
614811	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
614812	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
614813	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
614814	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Switching Operations	4	
614815	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
614816	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
614817	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
614818	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
614819	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
614820	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
614821	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	183	
614822	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	183	
614823	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Operations Counter AF	227	
614824	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Moisture and Leak Free?	y	
614825	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Tank Paint Condition	Good	
614826	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Unknown Operations	0	
614827	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
614828	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
614829	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
614830	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
614831	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
614832	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
614833	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
614834	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
614835	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
614836	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
614837	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Unknown Operations	0	
614838	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Switching Operations	0	
614839	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
614840	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
614841	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	9 Month Operations	9	
614842	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
614843	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
614844	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
614845	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
614846	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
614847	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
614848	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
614849	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
614850	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
614851	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
614852	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
614853	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Unknown Operations	0	
614854	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Switching Operations	0	
614855	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Operations Counter AL	139	
614856	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Operations Counter AF	139	
614857	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Maintenance Operations	1	
614858	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	General Comments		
614859	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
614860	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
614861	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
614862	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
614863	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
614864	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
614865	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
614866	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Follow-up Action Required?	n	
614867	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Operations Ground	0	
614868	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Operations C Ø	0	
614869	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Operations B Ø	0	
614870	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Operations A Ø	0	
614871	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
614872	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
614873	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
614874	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Amps C Ø	272.0	
614875	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
614876	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
614877	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
614878	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
614879	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
614880	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
614881	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
614882	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
614883	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	9 Month Operations	21	
614884	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
614885	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
614886	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
614887	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
614888	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
614889	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Amps A Ø	0.0	
614890	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Amps B Ø	0.0	
614891	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Amps C Ø	0.0	
614892	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Bushing Condition	Good	
614893	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
614894	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
614895	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
614896	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
614897	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
614898	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
614899	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
614900	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
614901	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.1	psi
614902	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
614903	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
614904	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
614905	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	General Comments		
614906	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Operations B Ø	0	
614907	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
614908	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Operations C Ø	0	
614909	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Operations Ground	0	
614910	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Follow-up Action Required?	n	
614911	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	91	
614912	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
614913	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
614914	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
614915	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
614916	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
614917	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
614918	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
614919	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
614920	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Follow-up Action Required?	n	
614921	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Foundation Condition	Good	
614922	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
614923	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
614924	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
614925	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Regulator As Left Counter	80167	
614926	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
614927	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
614928	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
614929	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Tank Leaks	None	
614930	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
614931	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
614932	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	925	
614933	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	925	
614934	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
614935	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
614936	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
614937	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
614938	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	General Comments		
614939	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	30	°C
614940	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
614941	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
614942	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
614943	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
614944	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
614945	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
614946	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
614947	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PF001153	PowerFuse	SW-B 14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
614948	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
614949	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
614950	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
614951	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
614952	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
614953	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
614954	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
614955	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
614956	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PF001153	PowerFuse	SW-B 14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
614957	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
614958	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Operations A Ø	0	
614959	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Operations B Ø	0	
614960	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
614961	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
614962	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
614963	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
614964	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Operations C Ø	0	
614965	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Operations Ground	0	
614966	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Follow-up Action Required?	n	
614967	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Follow-up Action Required?	n	
614968	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Foundation Condition	Good	
614969	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	General Comments		
614970	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	General Comments		
614971	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Grounds in Place?	y	
614972	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Maintenance Operations	0	
614973	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
614974	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Operations Counter AF	95	
614975	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Operations Counter AL	95	
614976	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Switching Operations	2	
614977	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Tank Paint Condition	Good	
614978	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Unknown Operations	0	
614979	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
614980	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
614981	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
614982	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
614983	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
614984	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
614985	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Operational?	y	
614986	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
614987	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	45	°C
614988	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	5.81	%
614989	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	5.81	%
614990	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	5.81	%
614991	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	4	
614992	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
614993	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
614994	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
614995	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
614996	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	General Comments		
614997	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
614998	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
614999	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
615000	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
615001	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Current Tap Position	2L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
615002	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
615003	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
615004	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
615005	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
615006	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
615007	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	9 Month Operations	2	
615008	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Accumulated Fault Duty A Ph V	1.34	%
615009	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Accumulated Fault Duty B Ph V	.89	%
615010	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
615011	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Amps A Ø	230.0	
615012	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Amps B Ø	220.0	
615013	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Amps C Ø	205.0	
615014	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Bushing Condition	Good	
615015	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Bushings Connection/Risers	Good	
615016	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
615017	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
615018	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Cabinet Paint Condition	Good	
615019	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Equipment Properly Labeled?	y	
615020	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
615021	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	General Comments		
615022	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
615023	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
615024	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
615025	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
615026	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
615027	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
615028	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
615029	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
615030	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Foundation Condition	Crumbling	
615031	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
615032	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
615033	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
615034	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	General Comments	Distribution pads crumbling on 660	
615035	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
615036	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
615037	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
615038	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
615039	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
615040	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
615041	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
615042	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
615043	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
615044	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
615045	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
615046	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
615047	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
615048	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	Winding Temp Present	45	°C
615049	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	Winding Temp Max	55	°C
615050	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	1.0180	
615051	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
615052	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
615053	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
615054	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
615055	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
615056	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
615057	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	230.0	
615058	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	240.0	
615059	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	310.0	
615060	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
615061	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
615062	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
615063	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
615064	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
615065	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
615066	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
615067	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
615068	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
615069	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
615070	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
615071	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
615072	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
615073	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Clear of Trash?	y	
615074	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
615075	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
615076	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
615077	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
615078	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
615079	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
615080	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
615081	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
615082	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
615083	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
615084	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
615085	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
615086	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
615087	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Tank Paint Condition	Good	
615088	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Switching Operations	0	
615089	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
615090	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Operations Counter AL	304	
615091	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Operations Counter AF	304	
615092	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
615093	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
615094	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
615095	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
615096	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
615097	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	General Comments	WHAT IS A METER ARRAY?	
615098	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	NotOK	
615099	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
615100	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
615101	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	267	
615102	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	267	
615103	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
615104	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
615105	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
615106	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	9 Months Operations	1	
615107	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Amps A Ø	50.0	
615108	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Amps B Ø	50.0	
615109	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Amps C Ø	75.0	
615110	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
615111	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
615112	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
615113	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
615114	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
615115	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
615116	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
615117	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
615118	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Unknown Operations	0	
615119	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
615120	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
615121	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	7	
615122	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
615123	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
615124	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	149	
615125	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Amps C Ø	15	
615126	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Amps B Ø	15	
615127	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Amps A Ø	15	
615128	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	General Comments		
615129	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
615130	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
615131	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
615132	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
615133	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
615134	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
615135	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
615136	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
615137	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
615138	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
615139	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
615140	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
615141	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
615142	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
615143	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
615144	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
615145	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
615146	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	PF001225	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	General Comments	2	
615147	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	PF001225	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
615148	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
615149	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
615150	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	9 Month Operations	2	
615151	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
615152	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
615153	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
615154	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
615155	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Amps A Ø	33.5	
615156	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
615157	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
615158	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
615159	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
615160	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
615161	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
615162	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
615163	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	PF001224	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	General Comments	2	
615164	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	PF001224	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
615165	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
615166	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
615167	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
615168	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Amps B Ø	35.5	
615169	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Amps C Ø	28.0	
615170	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Bushing Condition	Good	
615171	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
615172	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
615173	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
615174	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
615175	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
615176	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
615177	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
615178	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
615179	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
615180	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
615181	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
615182	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
615183	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
615184	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	40	°C
615185	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
615186	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
615187	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
615188	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
615189	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
615190	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
615191	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
615192	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Moisture and Leak Free?	y	
615193	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Maintenance Operations	0	
615194	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Heaters (All) Functioning?	y	
615195	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Grounds in Place?	y	
615196	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	General Comments		
615197	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
615198	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
615199	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
615200	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
615201	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
615202	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
615203	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
615204	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
615205	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
615206	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Vegetation	None	
615207	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
615208	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
615209	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Vegetation	None	
615210	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
615211	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
615212	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
615213	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
615214	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
615215	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
615216	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
615217	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
615218	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
615219	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
615220	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
615221	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
615222	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
615223	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
615224	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
615225	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
615226	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	91	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
615227	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
615228	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
615229	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
615230	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Patrol Inspection	Follow-up Action Required?	n	
615231	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Follow-up Action Required?	n	
615232	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Patrol Inspection	General Comments		
615233	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	General Comments		
615234	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
615235	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
615236	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
615237	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
615238	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
615239	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
615240	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
615241	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
615242	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
615243	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
615244	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
615245	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Moisture and Leak Free?	y	
615246	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
615247	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
615248	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Maintenance Operations	0	
615249	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Operations Counter AF	326	
615250	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
615251	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Operations Counter AF	202	
615252	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Operations Counter AL	202	
615253	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Switching Operations	0	
615254	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Tank Paint Condition	Good	
615255	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Unknown Operations	0	
615256	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Operations Counter AL	326	
615257	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Switching Operations	0	
615258	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Unknown Operations	0	
615259	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
615260	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
615261	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
615262	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
615263	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
615264	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
615265	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
615266	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
615267	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
615268	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
615269	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
615270	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	14659.20	kw
615271	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
615272	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
615273	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
615274	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
615275	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
615276	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
615277	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
615278	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
615279	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
615280	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
615281	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
615282	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Unknown Operations	0	
615283	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Tank Paint Condition	Good	
615284	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
615285	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
615286	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
615287	1/16/2019 12:21	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	205	
615288	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
615289	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Fault Operations A Ø	0	
615290	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
615291	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Fault Operations B Ø	0	
615292	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Fault Operations C Ø	0	
615293	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Fault Operations Ground	0	
615294	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Follow-up Action Required?	n	
615295	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
615296	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Follow-up Action Required?	n	
615297	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
615298	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	General Comments		
615299	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
615300	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
615301	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Amps A Ø	75.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
615302	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Amps B Ø	75.0	
615303	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Amps C Ø	50.0	
615304	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
615305	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
615306	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
615307	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Foundation Condition	Good	
615308	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	General Comments		
615309	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
615310	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
615311	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
615312	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Operations Ground	0	
615313	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Operations C Ø	0	
615314	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Operations B Ø	0	
615315	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Switching Operations	8	
615316	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Operations A Ø	0	
615317	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
615318	1/16/2019 16:46	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
615319	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
615320	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Clear of Trash?	y	
615321	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Maintenance Operations	0	
615322	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Heaters (All) Functioning?	y	
615323	1/16/2019 10:27	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	General Comments		
615324	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
615325	1/16/2019 10:29	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
615326	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Grounds in Place?	y	
615327	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
615328	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
615329	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
615330	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
615331	1/16/2019 8:27	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
615332	1/16/2019 14:47	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	General Comments		
615333	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	6L	
615334	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	143493	
615335	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	143493	
615336	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	General Comments		
615337	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
615338	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
615339	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	367	
615340	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	12L	
615341	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	2L	
615342	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
615343	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
615344	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
615345	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
615346	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
615347	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
615348	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
615349	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
615350	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	General Comments		
615351	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	80.00	
615352	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
615353	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
615354	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
615355	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
615356	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
615357	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
615358	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
615359	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
615360	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
615361	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
615362	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
615363	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
615364	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
615365	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
615366	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
615367	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
615368	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
615369	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
615370	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
615371	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
615372	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
615373	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
615374	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
615375	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
615376	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
615377	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
615378	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
615379	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
615380	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
615381	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
615382	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
615383	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
615384	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	240.0	
615385	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.79	%
615386	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.90	%
615387	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
615388	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	200.0	
615389	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
615390	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	916	
615391	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	916	
615392	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
615393	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
615394	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.90	%
615395	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	200.0	
615396	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
615397	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
615398	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
615399	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
615400	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
615401	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
615402	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
615403	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
615404	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
615405	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
615406	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
615407	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
615408	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
615409	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
615410	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
615411	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
615412	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
615413	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	822	
615414	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
615415	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
615416	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
615417	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
615418	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
615419	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
615420	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
615421	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
615422	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
615423	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.90	%
615424	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
615425	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
615426	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
615427	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
615428	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
615429	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
615430	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
615431	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	822	
615432	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
615433	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
615434	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
615435	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
615436	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
615437	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
615438	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
615439	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
615440	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
615441	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
615442	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
615443	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
615444	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
615445	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
615446	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
615447	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	407	
615448	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
615449	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
615450	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	407	
615451	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
615452	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
615453	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
615454	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
615455	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
615456	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
615457	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
615458	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
615459	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
615460	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
615461	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	300.0	
615462	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	300.0	
615463	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	300.0	
615464	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.69	%
615465	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	3.59	%
615466	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
615467	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
615468	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
615469	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
615470	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
615471	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
615472	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
615473	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
615474	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
615475	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
615476	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
615477	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
615478	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
615479	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
615480	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
615481	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
615482	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0354	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
615483	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	957	
615484	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	957	
615485	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
615486	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
615487	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
615488	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
615489	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
615490	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
615491	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
615492	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
615493	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	3.59	%
615494	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.69	%
615495	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.69	%
615496	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
615497	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
615498	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	200.0	
615499	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
615500	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
615501	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
615502	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
615503	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
615504	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
615505	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
615506	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
615507	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
615508	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
615509	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
615510	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
615511	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
615512	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
615513	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
615514	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
615515	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
615516	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
615517	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
615518	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
615519	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.17	%
615520	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.17	%
615521	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	650.0	
615522	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	700.0	
615523	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	800.0	
615524	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
615525	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
615526	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
615527	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
615528	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
615529	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
615530	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
615531	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
615532	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
615533	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
615534	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
615535	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	258	
615536	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	258	
615537	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
615538	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
615539	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	21.65	%
615540	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
615541	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
615542	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
615543	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
615544	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
615545	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
615546	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
615547	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
615548	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
615549	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
615550	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
615551	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
615552	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
615553	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
615554	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
615555	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
615556	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
615557	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
615558	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
615559	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
615560	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
615561	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
615562	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
615563	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	4.47	%
615564	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
615565	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC Operations Since Last Insp	990	
615566	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	320.0	
615567	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	320.0	
615568	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	320.0	
615569	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
615570	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Bushings Connection/Risers	Good	
615571	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
615572	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
615573	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	°F
615574	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
615575	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
615576	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
615577	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
615578	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
615579	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
615580	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
615581	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations Ground	0	
615582	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
615583	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Follow-up Action Required?	n	
615584	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
615585	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	General Comments		
615586	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0388	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	10	
615587	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0388	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	215	
615588	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0388	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	215	
615589	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0129	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	150.0	
615590	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
615591	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC Operations Since Last Insp	321	
615592	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
615593	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
615594	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
615595	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
615596	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
615597	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
615598	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
615599	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	5	
615600	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Maintenance Operations	0	
615601	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	LTCC000251	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
615602	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Operations Counter AF	259	
615603	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Operations Counter AL	259	
615604	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	LTCC000251	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
615605	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
615606	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Switching Operations	0	
615607	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
615608	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
615609	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Unknown Operations	0	
615610	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
615611	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	30.8	%
615612	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	General Comments		
615613	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
615614	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	30.8	%
615615	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	30.8	%
615616	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
615617	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
615618	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
615619	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Floor Swept?	y	
615620	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
615621	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
615622	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
615623	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
615624	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	LTC Operations Since Last Insp	550	
615625	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
615626	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	LTC Min Tap Position	Neutral	
615627	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	LTC Max Tap Position	6L	
615628	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
615629	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC Min Tap Position	8L	
615630	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	9 Month Operations	4	
615631	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	LTC As Found Counter	254637	
615632	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	General Comments		
615633	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
615634	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
615635	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	LTC Current Tap Position	12L	
615636	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	General Comments		
615637	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
615638	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
615639	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Panels Dusted?	y	
615640	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
615641	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
615642	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
615643	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Evidence of Insects	None	
615644	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
615645	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
615646	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
615647	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
615648	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
615649	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Operations A Ø	0	
615650	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Accumulated Fault Duty A Ph V	2.87	%
615651	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
615652	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Accumulated Fault Duty C Ph V	.48	%
615653	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Amps A Ø	160.0	
615654	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
615655	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
615656	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Amps B Ø	190.0	
615657	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	LTC As Left Counter	254637	
615658	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Amps C Ø	100.0	
615659	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	LTCC000251	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
615660	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC Current Tap Position	3L	
615661	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
615662	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
615663	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	3.13	%
615664	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
615665	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Bushing Condition	Good	
615666	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
615667	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
615668	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	General Comments		
615669	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
615670	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
615671	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
615672	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
615673	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	Follow-up Action Required?	n	
615674	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
615675	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
615676	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
615677	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.79	%
615678	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
615679	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC Min Tap Position	7L	
615680	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
615681	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Bushings Connection/Risers	Good	
615682	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Bushing Condition	Good	
615683	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Amps C Ø	340.0	
615684	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Amps B Ø	400.0	
615685	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Amps A Ø	304.0	
615686	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Accumulated Fault Duty C Ph V	2.23	%
615687	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Accumulated Fault Duty B Ph V	3.13	%
615688	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
615689	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Clear of Trash?	y	
615690	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
615691	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
615692	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Operations B Ø	0	
615693	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
615694	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Operations C Ø	0	
615695	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Maintenance Operations	7	
615696	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Heaters (All) Functioning?	y	
615697	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Grounds in Place?	y	
615698	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	General Comments		
615699	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	General Comments		
615700	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Foundation Condition	Good	
615701	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Follow-up Action Required?	n	
615702	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC Operations Since Last Insp	358	
615703	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
615704	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
615705	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
615706	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Accumulated Fault Duty A Ph V	3.13	%
615707	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	9 Month Operations	10	
615708	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Operations Ground	0	
615709	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BCH000373	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
615710	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BCH000373	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
615711	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BCH000373	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
615712	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BCH000373	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
615713	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BCH000373	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
615714	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Follow-up Action Required?	n	
615715	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	General Comments		
615716	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
615717	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
615718	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
615719	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BCH000375	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
615720	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BCH000375	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
615721	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BCH000375	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
615722	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BCH000375	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
615723	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
615724	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
615725	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
615726	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BCH000375	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
615727	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	BK001038	BreakerSF6	828-608	GCB Readings	Amps C Ø	0.0	
615728	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BCH000375	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
615729	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	BK001038	BreakerSF6	828-608	GCB Readings	Amps B Ø	0.0	
615730	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Operations Ground	0	
615731	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Operations C Ø	0	
615732	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Operations B Ø	0	
615733	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Operations A Ø	0	
615734	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
615735	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
615736	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
615737	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Follow-up Action Required?	y	
615738	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Accumulated Fault Duty A Ph V	.91	%
615739	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Equipment Properly Labeled?	y	
615740	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
615741	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Cabinet Paint Condition	Good	
615742	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
615743	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
615744	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	Follow-up Action Required?	n	
615745	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
615746	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	BK001038	BreakerSF6	828-608	GCB Readings	Fault Operations	0	
615747	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
615748	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Amps A Ø	180.0	
615749	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Amps B Ø	180.0	
615750	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Amps C Ø	180.0	
615751	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
615752	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
615753	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
615754	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
615755	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Operations A Ø	0	
615756	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
615757	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
615758	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Vegetation	None	
615759	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
615760	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
615761	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
615762	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	General Comments		
615763	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	General Comments		
615764	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
615765	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
615766	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
615767	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Moisture and Leak Free?	y	
615768	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC As Found Counter	53479	
615769	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC As Left Counter	53479	
615770	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
615771	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
615772	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
615773	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	General Comments		
615774	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
615775	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
615776	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
615777	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
615778	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
615779	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
615780	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC Current Tap Position	1L	
615781	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC Max Tap Position	3R	
615782	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Tank Paint Condition	Good	
615783	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Unknown Operations	0	
615784	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
615785	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Operations Ground	0	
615786	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Operations C Ø	0	
615787	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Operations B Ø	0	
615788	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Maintenance Operations	0	
615789	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Operations Counter AF	545	
615790	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Operations Counter AL	545	
615791	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Switching Operations	0	
615792	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Unknown Operations	0	
615793	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Operations A Ø	0	
615794	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
615795	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	General Comments		
615796	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
615797	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
615798	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Panels Dusted?	y	
615799	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
615800	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
615801	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
615802	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
615803	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
615804	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
615805	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
615806	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
615807	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
615808	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
615809	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
615810	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Equipment Properly Labeled?	y	
615811	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
615812	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
615813	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
615814	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Cabinet Paint Condition	Good	
615815	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
615816	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
615817	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
615818	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
615819	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
615820	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
615821	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
615822	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
615823	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
615824	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
615825	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC Operations Since Last Insp	254	
615826	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
615827	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
615828	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
615829	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
615830	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
615831	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
615832	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
615833	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
615834	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	BK001038	BreakerSF6	828-608	GCB Readings	Amps A Ø	0.0	
615835	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Ambient Temperature	33	°F
615836	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
615837	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
615838	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
615839	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	121	
615840	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	121	
615841	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
615842	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	General Comments		
615843	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
615844	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
615845	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
615846	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
615847	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	AirCompressor Heater Condition	good	
615848	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
615849	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Air Pressure OK?	y	
615850	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Air Leaks	None	
615851	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
615852	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
615853	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Foundation Condition	Good	
615854	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Follow-up Action Required?	n	
615855	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Follow-up Action Required?	n	
615856	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Follow-up Action Required?	n	
615857	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Operations Ground	0	
615858	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Operations C Ø	0	
615859	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Operations B Ø	0	
615860	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Operations A Ø	0	
615861	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
615862	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
615863	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
615864	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
615865	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
615866	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
615867	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Operations Counter AF	298	
615868	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Operations Counter AL	0	
615869	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
615870	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
615871	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
615872	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
615873	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
615874	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
615875	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
615876	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
615877	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
615878	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
615879	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
615880	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Air Compressor Oil Status	Good	
615881	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Air Compressor Belt Condition	Good	
615882	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	General Comments	heater not working	
615883	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
615884	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	LTCC000251	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
615885	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Switching Operations	2	
615886	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
615887	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	33	°F
615888	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
615889	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
615890	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Totalizer Meter Reading	.4630	
615891	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
615892	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
615893	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
615894	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
615895	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
615896	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
615897	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
615898	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
615899	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
615900	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
615901	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
615902	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
615903	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
615904	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
615905	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
615906	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
615907	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
615908	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
615909	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
615910	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
615911	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
615912	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
615913	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
615914	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
615915	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	General Comments		
615916	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
615917	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
615918	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
615919	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC As Left Counter	4115	
615920	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC As Found Counter	4115	
615921	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	General Comments		
615922	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	General Comments		
615923	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
615924	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	Follow-up Action Required?	n	
615925	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC Min Tap Position	11L	
615926	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC Max Tap Position	5R	
615927	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
615928	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
615929	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC As Left Counter	26610	
615930	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC As Found Counter	26610	
615931	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	General Comments		
615932	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	General Comments		
615933	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
615934	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	Follow-up Action Required?	n	
615935	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
615936	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
615937	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	General Comments		
615938	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
615939	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
615940	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Foundation Condition	Good	
615941	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
615942	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
615943	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
615944	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
615945	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC Operations Since Last Insp	241	
615946	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC Min Tap Position	10L	
615947	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC Max Tap Position	Neutral	
615948	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC Current Tap Position	4L	
615949	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
615950	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC As Left Counter	34535	
615951	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC As Found Counter	34535	
615952	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	General Comments		
615953	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	S0029	LTCMechanism	662-3	LTC Counter Readings	General Comments		
615954	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
615955	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	VRR Time Delay	30	Seconds
615956	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	S0029	LTCMechanism	662-3	LTC Counter Readings	Follow-up Action Required?	n	
615957	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0388	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
615958	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
615959	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
615960	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Clear of Trash?	y	
615961	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Amps A Ø	320.0	
615962	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
615963	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
615964	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations C Ø	0	
615965	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations B Ø	0	
615966	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	LTCC000251	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
615967	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations A Ø	0	
615968	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	LTCC000251	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
615969	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	LTCC000251	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
615970	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
615971	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
615972	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
615973	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
615974	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	FE000839	Fence	662-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
615975	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
615976	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
615977	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
615978	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
615979	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
615980	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	FE000839	Fence	662-Fence	Fence Patrol Inspection	General Comments		
615981	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Accumulated Fault Duty C Ph V	.91	%
615982	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
615983	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
615984	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	FE000839	Fence	662-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
615985	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	FE000839	Fence	662-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
615986	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	9 Month Operations	4	
615987	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
615988	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	FE000839	Fence	662-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
615989	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	FE000839	Fence	662-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
615990	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
615991	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
615992	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	9 Months Operations	38	
615993	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Amps C Ø	170.0	
615994	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Amps B Ø	150.0	
615995	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Amps A Ø	190.0	
615996	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Accumulated Fault Duty C Ph AM	25.29	%
615997	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Accumulated Fault Duty A Ph AM	33.73	%
615998	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Accumulated Fault Duty B Ph AM	32.52	%
615999	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC Min Tap Position	8L	
616000	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
616001	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC Current Tap Position	4L	
616002	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
616003	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
616004	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
616005	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Switching Operations	0	
616006	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Tank Paint Condition	Good	
616007	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	LTC Totalizer Reading	8334.00	kw
616008	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	BCH000607	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
616009	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	BCH000607	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
616010	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
616011	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
616012	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Oil Temp Max	65	°C
616013	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Oil Temp Present	30	°C
616014	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
616015	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
616016	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
616017	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
616018	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
616019	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
616020	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
616021	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
616022	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
616023	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
616024	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
616025	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Vegetation	None	
616026	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
616027	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	General Comments		
616028	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
616029	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
616030	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	FE000839	Fence	662-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
616031	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
616032	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
616033	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
616034	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
616035	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	General Comments		
616036	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
616037	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
616038	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
616039	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
616040	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
616041	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
616042	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
616043	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
616044	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
616045	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	FE000839	Fence	662-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
616046	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
616047	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
616048	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
616049	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	155	
616050	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	155	
616051	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
616052	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	BCH000607	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
616053	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	BCH000607	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
616054	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	BCH000607	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
616055	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	BCH000607	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
616056	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
616057	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
616058	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
616059	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
616060	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
616061	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
616062	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
616063	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
616064	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
616065	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
616066	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
616067	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	VRR Time Delay	30	Seconds
616068	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
616069	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
616070	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
616071	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
616072	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
616073	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
616074	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
616075	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
616076	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
616077	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	LTC Operation Checked?	n	
616078	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
616079	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	General Comments		
616080	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Ambient Temperature	29	°F
616081	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
616082	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
616083	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
616084	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
616085	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
616086	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
616087	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
616088	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
616089	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Fault Operations	0	
616090	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Follow-up Action Required?	n	
616091	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Follow-up Action Required?	n	
616092	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Foundation Condition	Good	
616093	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
616094	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
616095	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
616096	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
616097	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
616098	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	Follow-up Action Required?	n	
616099	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	All Connections OK?	y	
616100	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
616101	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
616102	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
616103	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Follow-up Action Required?	n	
616104	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
616105	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
616106	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	General Comments		
616107	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	General Comments		
616108	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
616109	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	General Comments		
616110	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
616111	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	General Comments	y	
616112	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Grounds in Place?	y	
616113	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
616114	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Maintenance Operations	0	
616115	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
616116	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Num Operations Last 9 Months	0	
616117	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Operations Counter AF	68	
616118	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Operations Counter AL	68	
616119	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
616120	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
616121	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	General Comments	breaker is open	
616122	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
616123	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Follow-up Action Required?	n	
616124	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
616125	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
616126	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
616127	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	General Comments		
616128	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
616129	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	LTC Totalizer Reading	11199.60	kw
616130	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
616131	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
616132	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	218	
616133	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	218	
616134	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	0	
616135	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Oil Temp Max	75	°C
616136	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Oil Temp Present	40	°C
616137	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	LTC Totalizer Reading	14184.00	kw
616138	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
616139	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	General Comments		
616140	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	General Comments		
616141	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
616142	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Bushing Condition	Good	
616143	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
616144	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
616145	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
616146	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
616147	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
616148	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	General Comments		
616149	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
616150	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
616151	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
616152	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
616153	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
616154	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
616155	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
616156	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
616157	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	°F
616158	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
616159	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
616160	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
616161	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Amps C Ø	53.0	
616162	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
616163	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Follow-up Action Required?	n	
616164	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
616165	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
616166	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
616167	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
616168	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
616169	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
616170	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Amps B Ø	47.0	
616171	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
616172	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
616173	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
616174	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
616175	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
616176	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
616177	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
616178	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
616179	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
616180	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
616181	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC As Left Counter	386	
616182	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC As Found Counter	486	
616183	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
616184	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
616185	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
616186	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	General Comments		
616187	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
616188	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
616189	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
616190	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
616191	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Equipment Properly Labeled?	y	
616192	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Cabinet Paint Condition	Good	
616193	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
616194	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
616195	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
616196	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Winding Temp Present	27	°C
616197	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Winding Temp Max	36	°C
616198	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Totalizer Meter Reading	.5910	
616199	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
616200	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
616201	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
616202	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
616203	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
616204	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
616205	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
616206	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
616207	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
616208	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
616209	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
616210	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Bushings Connection/Risers	Good	
616211	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
616212	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Counter Readings	General Comments		
616213	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
616214	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Counter Readings	Follow-up Action Required?	n	
616215	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
616216	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
616217	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
616218	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
616219	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
616220	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
616221	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
616222	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
616223	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
616224	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
616225	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Oil Temp Present	25	°C
616226	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
616227	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
616228	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Oil Temp Max	36	°C
616229	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
616230	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
616231	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
616232	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
616233	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
616234	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
616235	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
616236	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
616237	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
616238	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
616239	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	General Comments		
616240	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
616241	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Ambient Temperature	29	°F
616242	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
616243	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
616244	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
616245	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
616246	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
616247	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
616248	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
616249	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
616250	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
616251	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Bushings Connection/Risers	Good	
616252	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	All Connections OK?	y	
616253	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	Follow-up Action Required?	n	
616254	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	General Comments		
616255	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	LTC Operation Checked?	y	
616256	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Bushing Condition	Good	
616257	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Amps C Ø	360.0	
616258	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
616259	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
616260	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
616261	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
616262	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Amps B Ø	380.0	
616263	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Amps A Ø	480.0	
616264	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Fault Operations	0	
616265	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Follow-up Action Required?	n	
616266	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Follow-up Action Required?	n	
616267	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Amps C Ø	320.0	
616268	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Amps B Ø	320.0	
616269	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
616270	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
616271	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
616272	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Accumulated Fault Duty B Ph V	4.06	%
616273	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Accumulated Fault Duty A Ph V	4.06	%
616274	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	9 Month Operations	16	
616275	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	General Comments		
616276	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
616277	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
616278	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	General Comments		
616279	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	General Comments	y	
616280	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Grounds in Place?	y	
616281	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
616282	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Maintenance Operations	0	
616283	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
616284	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Num Operations Last 9 Months	1	
616285	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Operations Counter AF	63	
616286	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Operations Counter AL	63	
616287	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
616288	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
616289	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
616290	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Switching Operations	1	
616291	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Tank Paint Condition	Good	
616292	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
616293	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
616294	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	LTCMechanism	662-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
616295	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
616296	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
616297	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Amps A Ø	49.0	
616298	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
616299	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
616300	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	LTCC000251	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
616301	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
616302	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
616303	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
616304	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
616305	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	General Comments		
616306	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
616307	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Accumulated Fault Duty A Ph V	1.01	%
616308	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	9 Month Operations	11	
616309	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
616310	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
616311	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
616312	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
616313	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
616314	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
616315	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
616316	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
616317	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	35	°F
616318	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	All Connections OK?	y	
616319	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
616320	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
616321	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Totalizer Meter Reading	.6222	
616322	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
616323	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
616324	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
616325	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
616326	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
616327	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Equipment Properly Labeled?	y	
616328	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Bushing Condition	Good	
616329	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Amps C Ø	100.0	
616330	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Amps B Ø	100.0	
616331	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
616332	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
616333	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
616334	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
616335	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Amps A Ø	100.0	
616336	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
616337	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
616338	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
616339	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
616340	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
616341	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
616342	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
616343	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	9 Month Operations	0	
616344	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
616345	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
616346	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
616347	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
616348	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	2118	
616349	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Cabinet Paint Condition	Good	
616350	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	2118	
616351	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
616352	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
616353	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
616354	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
616355	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
616356	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
616357	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations A Ø	0	
616358	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations B Ø	0	
616359	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations C Ø	0	
616360	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
616361	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Follow-up Action Required?	n	
616362	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations Ground	0	
616363	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Follow-up Action Required?	n	
616364	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	General Comments	.	
616365	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Maintenance Operations	0	
616366	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations Counter AF	302	
616367	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations Counter AL	302	
616368	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Switching Operations	1	
616369	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Unknown Operations	0	
616370	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Patrol Inspection	General Comments		
616371	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	General Comments		
616372	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
616373	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	General Comments		
616374	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	General Comments	NO GROUP SELECTOR SWITCH	
616375	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Amps A Ø	390.0	
616376	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	9.63	%
616377	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	9.63	%
616378	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
616379	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	LTC Totalizer Reading	23760.00	kw
616380	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
616381	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
616382	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Oil Temp Max	80	°C
616383	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Oil Temp Present	40	°C
616384	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
616385	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
616386	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
616387	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	9.63	%
616388	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	9 Month Operations	1	
616389	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	9 Month Operations	5	
616390	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Accumulated Fault Duty A Ph V	.44	%
616391	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Accumulated Fault Duty B Ph V	.44	%
616392	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Accumulated Fault Duty C Ph V	.44	%
616393	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Amps A Ø	241.0	
616394	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Amps B Ø	260.0	
616395	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Amps C Ø	245.0	
616396	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Bushing Condition	Good	
616397	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Bushings Connection/Risers	Good	
616398	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
616399	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
616400	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
616401	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Cabinet Paint Condition	Good	
616402	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	LTCC000814	LTCControl	662-2	LTC Control Insp	General Comments		
616403	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	LTCC000814	LTCControl	662-2	LTC Control Insp	Follow-up Action Required?	n	
616404	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Amps C Ø	390.0	
616405	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Amps C Ø	0.0	
616406	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Amps B Ø	0.0	
616407	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Amps A Ø	0.0	
616408	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
616409	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
616410	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
616411	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	9 Month Operations	4	
616412	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Amps B Ø	390.0	
616413	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	LTCC000814	LTCControl	662-2	LTC Control Insp	All Connections OK?	y	
616414	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
616415	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
616416	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
616417	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
616418	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
616419	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
616420	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	80	
616421	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	80	
616422	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
616423	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
616424	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	1	
616425	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Pressure Acceptable?	y	
616426	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	9 Months Operations	3	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
616427	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Accumulated Fault Duty A Ph AM	2.14	%
616428	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Accumulated Fault Duty B Ph AM	5.34	%
616429	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
616430	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Amps A Ø	100.0	
616431	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Amps B Ø	110.0	
616432	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Amps C Ø	110.0	
616433	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
616434	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
616435	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
616436	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	Follow-up Action Required?	n	
616437	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	All Connections OK?	y	
616438	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
616439	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Operations A Ø	0	
616440	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Operations B Ø	0	
616441	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Operations C Ø	0	
616442	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	9 Month Operations	14	
616443	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty A Ph V	35.87	%
616444	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty B Ph V	55.8	%
616445	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty C Ph V	15.94	%
616446	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps A Ø	61.0	
616447	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps B Ø	67.0	
616448	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Operations Ground	0	
616449	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps C Ø	55.0	
616450	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Follow-up Action Required?	n	
616451	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Operations Ground	0	
616452	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Operations C Ø	0	
616453	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Operations B Ø	0	
616454	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Operations A Ø	0	
616455	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
616456	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
616457	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
616458	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Equipment Properly Labeled?	y	
616459	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Cabinet Paint Condition	Good	
616460	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
616461	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
616462	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
616463	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Bushings Connection/Risers	Good	
616464	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Bushing Condition	Good	
616465	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Amps C Ø	220.0	
616466	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Amps B Ø	240.0	
616467	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Amps A Ø	230.0	
616468	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
616469	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
616470	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Accumulated Fault Duty A Ph V	.92	%
616471	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	9 Month Operations	2	
616472	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
616473	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
616474	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
616475	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Amps A Ø	77.0	
616476	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Amps B Ø	106.0	
616477	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Amps C Ø	156.0	
616478	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Bushing Condition	Good	
616479	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Bushings Connection/Risers	Good	
616480	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
616481	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
616482	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
616483	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Cabinet Paint Condition	Good	
616484	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Equipment Properly Labeled?	y	
616485	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
616486	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
616487	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
616488	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Operations A Ø	0	
616489	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Operations B Ø	0	
616490	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Operations C Ø	0	
616491	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Operations Ground	0	
616492	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Follow-up Action Required?	n	
616493	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Follow-up Action Required?	n	
616494	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Foundation Condition	Good	
616495	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	General Comments		
616496	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	General Comments		
616497	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Grounds in Place?	y	
616498	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Equipment Properly Labeled?	y	
616499	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
616500	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
616501	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
616502	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Operations A Ø	0	
616503	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Operations B Ø	0	
616504	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Operations C Ø	0	
616505	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Operations Ground	0	
616506	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Follow-up Action Required?	n	
616507	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Follow-up Action Required?	n	
616508	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Foundation Condition	Good	
616509	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	General Comments		
616510	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	General Comments		
616511	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Grounds in Place?	y	
616512	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Heaters (All) Functioning?	y	
616513	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Maintenance Operations	0	
616514	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Moisture and Leak Free?	y	
616515	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Operations Counter AF	181	
616516	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Operations Counter AL	181	
616517	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
616518	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Switching Operations	0	
616519	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Tank Paint Condition	Good	
616520	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Unknown Operations	0	
616521	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Maintenance Operations	0	
616522	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Operations Counter AF	537	
616523	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Operations Counter AL	537	
616524	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Switching Operations	0	
616525	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Unknown Operations	0	
616526	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
616527	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
616528	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
616529	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC Operations Since Last Insp	485	
616530	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC Min Tap Position	13L	
616531	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC Max Tap Position	1L	
616532	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC Current Tap Position	7L	
616533	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
616534	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Unknown Operations	0	
616535	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Tank Paint Condition	Good	
616536	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Switching Operations	0	
616537	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Operations Counter AL	184	
616538	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Operations Counter AF	184	
616539	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Moisture and Leak Free?	y	
616540	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Maintenance Operations	0	
616541	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Heaters (All) Functioning?	y	
616542	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Grounds in Place?	y	
616543	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	General Comments		
616544	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	General Comments		
616545	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Foundation Condition	Good	
616546	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Follow-up Action Required?	n	
616547	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Switching Operations	0	
616548	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Operations Counter AL	210	
616549	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Operations Counter AF	210	
616550	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Moisture and Leak Free?	y	
616551	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Maintenance Operations	0	
616552	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Heaters (All) Functioning?	y	
616553	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Grounds in Place?	y	
616554	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	General Comments		
616555	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	General Comments		
616556	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Foundation Condition	Good	
616557	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations C Ø	0	
616558	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations B Ø	0	
616559	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations A Ø	0	
616560	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
616561	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Follow-up Action Required?	n	
616562	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Follow-up Action Required?	n	
616563	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
616564	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
616565	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Operations Ground	0	
616566	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Operations C Ø	0	
616567	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Amps C Ø	146.0	
616568	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Amps B Ø	168.0	
616569	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Amps A Ø	166.0	
616570	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Accumulated Fault Duty C Ph V	57.4	%
616571	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Operations B Ø	0	
616572	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Operations A Ø	0	
616573	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
616574	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
616575	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
616576	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
616577	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Cabinet Paint Condition	Good	
616578	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
616579	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
616580	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
616581	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Bushings Connection/Risers	Good	
616582	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Bushing Condition	Good	
616583	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Accumulated Fault Duty B Ph V	46.24	%
616584	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Accumulated Fault Duty A Ph V	69.35	%
616585	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	9 Month Operations	17	
616586	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Amps C Ø	100.0	
616587	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Amps B Ø	90.0	
616588	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Amps A Ø	100.0	
616589	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
616590	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Unknown Operations	0	
616591	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
616592	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Switching Operations	0	
616593	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Grounds in Place?	y	
616594	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Maintenance Operations	1	
616595	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
616596	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
616597	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
616598	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
616599	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
616600	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
616601	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Amps A Ø	523.0	
616602	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Amps B Ø	433.0	
616603	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Amps C Ø	428.0	
616604	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Bushing Condition	Good	
616605	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
616606	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
616607	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
616608	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
616609	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
616610	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
616611	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
616612	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
616613	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
616614	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
616615	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
616616	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Unknown Operations	0	
616617	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Switching Operations	0	
616618	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Operations Counter AL	307	
616619	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Operations Counter AF	307	
616620	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Maintenance Operations	0	
616621	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	General Comments	1 operation unaccounted for	
616622	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
616623	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
616624	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
616625	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
616626	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
616627	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
616628	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
616629	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Operations A Ø	0	
616630	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Operations B Ø	0	
616631	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Follow-up Action Required?	n	
616632	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations Ground	0	
616633	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Operations C Ø	0	
616634	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Operations Ground	0	
616635	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Follow-up Action Required?	n	
616636	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Follow-up Action Required?	n	
616637	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Foundation Condition	Good	
616638	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	General Comments		
616639	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	General Comments		
616640	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
616641	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Unknown Operations	0	
616642	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Tank Paint Condition	Good	
616643	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
616644	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
616645	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
616646	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Bushings Connection/Risers	Good	
616647	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Bushing Condition	Good	
616648	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	9 Month Operations	3	
616649	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Accumulated Fault Duty A Ph V	.41	%
616650	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Accumulated Fault Duty B Ph V	.41	%
616651	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Accumulated Fault Duty C Ph V	.41	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
616652	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Amps A Ø	64.0	
616653	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Amps B Ø	63.0	
616654	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Amps C Ø	66.0	
616655	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Bushing Condition	Good	
616656	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Bushings Connection/Risers	Good	
616657	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
616658	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
616659	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
616660	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Cabinet Paint Condition	Good	
616661	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Equipment Properly Labeled?	y	
616662	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
616663	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
616664	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
616665	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Operations A Ø	0	
616666	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Operations B Ø	0	
616667	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Operations C Ø	0	
616668	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Operations Ground	0	
616669	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Follow-up Action Required?	n	
616670	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Follow-up Action Required?	n	
616671	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Foundation Condition	Good	
616672	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	General Comments		
616673	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	General Comments		
616674	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Grounds in Place?	y	
616675	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Maintenance Operations	0	
616676	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Moisture and Leak Free?	y	
616677	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Operations Counter AF	173	
616678	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Operations Counter AL	173	
616679	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Switching Operations	0	
616680	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Tank Paint Condition	Good	
616681	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Unknown Operations	0	
616682	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	General Comments	trans center buss burnt up	
616683	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
616684	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
616685	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
616686	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	LTCC000814	LTCControl	662-2	LTC Control Insp	VRR Time Delay	30	Seconds
616687	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	LTCC000814	LTCControl	662-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
616688	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	LTCC000814	LTCControl	662-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
616689	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	LTCC000814	LTCControl	662-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
616690	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	LTCC000814	LTCControl	662-2	LTC Control Insp	LTC Operation Checked?	y	
616691	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
616692	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
616693	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	9 Month Operations	3	
616694	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Operations Counter AF	183	
616695	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Operations Counter AL	183	
616696	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Switching Operations	1	
616697	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Tank Paint Condition	Good	
616698	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Unknown Operations	0	
616699	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
616700	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
616701	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Operations Counter AL	197	
616702	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Operations Counter AF	197	
616703	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Maintenance Operations	0	
616704	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	General Comments		
616705	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
616706	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
616707	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
616708	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
616709	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Follow-up Action Required?	n	
616710	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations Ground	0	
616711	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
616712	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
616713	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
616714	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
616715	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
616716	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
616717	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
616718	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	9 Month Operations	10	
616719	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	421	
616720	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	6	
616721	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
616722	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
616723	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
616724	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
616725	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
616726	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	All Connections OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
616727	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	Follow-up Action Required?	n	
616728	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	General Comments		
616729	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	LTC Operation Checked?	y	
616730	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
616731	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
616732	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
616733	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
616734	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	VRR Time Delay	30	Seconds
616735	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
616736	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
616737	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
616738	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Equipment Properly Labeled?	y	
616739	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Cabinet Paint Condition	Good	
616740	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
616741	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
616742	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
616743	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
616744	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Switching Operations	0	
616745	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Operations Counter AL	171	
616746	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Operations Counter AF	171	
616747	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Maintenance Operations	0	
616748	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	General Comments		
616749	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
616750	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations Ground	0	
616751	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
616752	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
616753	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
616754	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Unknown Operations	0	
616755	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Tank Paint Condition	Good	
616756	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Switching Operations	0	
616757	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
616758	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Operations Counter AL	154	
616759	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	480.0	
616760	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	460.0	
616761	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	430.0	
616762	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
616763	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
616764	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Operations Counter AF	154	
616765	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
616766	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Maintenance Operations	0	
616767	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
616768	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Grounds in Place?	y	
616769	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	General Comments		
616770	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	General Comments		
616771	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Foundation Condition	Good	
616772	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Follow-up Action Required?	n	
616773	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Follow-up Action Required?	n	
616774	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Operations Ground	0	
616775	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Operations C Ø	0	
616776	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
616777	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	General Comments		
616778	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
616779	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
616780	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
616781	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
616782	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
616783	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	9 Month Operations	5	
616784	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
616785	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
616786	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
616787	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Amps A Ø	0.0	
616788	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
616789	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
616790	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
616791	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
616792	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
616793	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
616794	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
616795	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
616796	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Operations A Ø	0	
616797	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Operations B Ø	0	
616798	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Operations C Ø	0	
616799	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Operations Ground	0	
616800	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Follow-up Action Required?	n	
616801	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
616802	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Foundation Condition	Good	
616803	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	General Comments		
616804	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	General Comments		
616805	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Grounds in Place?	y	
616806	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Maintenance Operations	0	
616807	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
616808	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Operations Counter AF	137	
616809	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Operations Counter AL	137	
616810	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Switching Operations	1	
616811	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Tank Paint Condition	Good	
616812	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Unknown Operations	0	
616813	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	LTCC000712	LTCControl	601-1	LTC Control Insp	All Connections OK?	y	
616814	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	LTCC000712	LTCControl	601-1	LTC Control Insp	Follow-up Action Required?	n	
616815	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	LTCC000712	LTCControl	601-1	LTC Control Insp	General Comments		
616816	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Unknown Operations	0	
616817	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
616818	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Vegetation	None	
616819	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
616820	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
616821	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
616822	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	Vegetation	None	
616823	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
616824	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
616825	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	LTCC000712	LTCControl	601-1	LTC Control Insp	LTC Operation Checked?	y	
616826	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	LTCC000712	LTCControl	601-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
616827	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	LTCC000712	LTCControl	601-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
616828	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	LTCC000712	LTCControl	601-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
616829	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	LTCC000712	LTCControl	601-1	LTC Control Insp	VRR Time Delay	30	Seconds
616830	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
616831	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
616832	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	General Comments		
616833	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
616834	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
616835	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
616836	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
616837	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
616838	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
616839	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
616840	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
616841	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Bushing Condition	Good	
616842	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Amps C Ø	220.0	
616843	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Amps B Ø	162.0	
616844	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Amps A Ø	131.0	
616845	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
616846	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
616847	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
616848	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
616849	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
616850	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
616851	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
616852	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
616853	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
616854	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	9 Month Operations	0	
616855	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
616856	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
616857	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
616858	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps C Ø	306.0	
616859	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps B Ø	279.0	
616860	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	9 Month Operations	2	
616861	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
616862	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	1.93	%
616863	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
616864	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps A Ø	314.0	
616865	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
616866	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
616867	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	General Comments		
616868	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
616869	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
616870	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
616871	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
616872	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
616873	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
616874	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Totalizer Meter Reading	.9900	
616875	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
616876	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
616877	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
616878	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Clear of Trash?	y	
616879	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
616880	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
616881	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
616882	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Winding Temp Present	40	°C
616883	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Winding Temp Max	60	°C
616884	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Amps B Ø	0.0	
616885	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Amps C Ø	0.0	
616886	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
616887	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
616888	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
616889	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
616890	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
616891	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
616892	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
616893	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
616894	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
616895	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
616896	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Operations A Ø	0	
616897	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Operations B Ø	0	
616898	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Operations C Ø	0	
616899	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Operations Ground	0	
616900	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
616901	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Follow-up Action Required?	n	
616902	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
616903	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	General Comments		
616904	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	General Comments		
616905	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
616906	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
616907	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Maintenance Operations	0	
616908	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
616909	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Operations Counter AF	158	
616910	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Operations Counter AL	158	
616911	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
616912	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Switching Operations	1	
616913	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
616914	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Unknown Operations	0	
616915	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
616916	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
616917	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
616918	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	Clear of Trash?	y	
616919	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
616920	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
616921	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
616922	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Operations B Ø	0	
616923	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Operations A Ø	0	
616924	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
616925	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
616926	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
616927	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
616928	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
616929	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
616930	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
616931	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
616932	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
616933	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Readings	Totalizer Meter Reading	.8180	
616934	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
616935	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
616936	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
616937	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
616938	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
616939	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
616940	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
616941	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Switching Operations	0	
616942	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Operations Counter AL	162	
616943	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Operations Counter AF	162	
616944	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Unknown Operations	0	
616945	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
616946	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Switching Operations	0	
616947	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Operations Counter AL	184	
616948	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Operations Counter AF	184	
616949	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
616950	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Maintenance Operations	0	
616951	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
616952	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
616953	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	General Comments		
616954	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	General Comments		
616955	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
616956	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Follow-up Action Required?	n	
616957	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
616958	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Operations Ground	0	
616959	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Operations C Ø	0	
616960	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Operations B Ø	0	
616961	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Operations A Ø	0	
616962	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
616963	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
616964	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
616965	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
616966	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
616967	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
616968	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
616969	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
616970	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
616971	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
616972	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Amps C Ø	0.0	
616973	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Amps B Ø	0.0	
616974	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Amps A Ø	0.0	
616975	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
616976	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
616977	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
616978	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	9 Month Operations	4	
616979	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
616980	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Readings	Oil Temp Max	25	°C
616981	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Heaters (All) Functioning?	y	
616982	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Maintenance Operations	0	
616983	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Moisture and Leak Free?	y	
616984	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Operations Counter AF	137	
616985	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Operations Counter AL	137	
616986	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
616987	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Switching Operations	0	
616988	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Tank Paint Condition	Good	
616989	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Unknown Operations	0	
616990	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	9 Month Operations	3	
616991	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Unknown Operations	0	
616992	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Unknown Operations	0	
616993	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Tank Paint Condition	Good	
616994	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Switching Operations	0	
616995	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Operations Counter AL	163	
616996	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Operations Counter AF	163	
616997	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
616998	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Maintenance Operations	0	
616999	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
617000	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Grounds in Place?	y	
617001	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	General Comments		
617002	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	General Comments		
617003	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Foundation Condition	Good	
617004	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Follow-up Action Required?	n	
617005	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Follow-up Action Required?	n	
617006	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Operations Ground	0	
617007	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Operations C Ø	0	
617008	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Operations B Ø	0	
617009	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Operations A Ø	0	
617010	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
617011	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
617012	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
617013	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
617014	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
617015	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
617016	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
617017	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
617018	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
617019	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Bushing Condition	Good	
617020	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Amps C Ø	520.0	
617021	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Amps B Ø	560.0	
617022	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Amps A Ø	465.0	
617023	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
617024	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
617025	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
617026	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	9 Month Operations	2	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
617027	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
617028	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
617029	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Readings	Winding Temp Max	50	°C
617030	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
617031	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
617032	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
617033	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
617034	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
617035	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
617036	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Maintenance Operations	0	
617037	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	General Comments		
617038	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
617039	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Follow-up Action Required?	n	
617040	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations Ground	0	
617041	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations C Ø	0	
617042	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations B Ø	0	
617043	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
617044	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
617045	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
617046	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
617047	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
617048	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
617049	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
617050	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC As Left Counter	4857	
617051	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC As Found Counter	4851	
617052	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
617053	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
617054	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations A Ø	0	
617055	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
617056	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
617057	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
617058	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Amps C Ø	106.0	
617059	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	General Comments		
617060	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	General Comments		
617061	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
617062	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	Follow-up Action Required?	n	
617063	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Amps B Ø	65.0	
617064	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Amps A Ø	76.0	
617065	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Accumulated Fault Duty C Ph V	6.38	%
617066	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Accumulated Fault Duty B Ph V	7.97	%
617067	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Accumulated Fault Duty A Ph V	6.38	%
617068	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	9 Month Operations	1	
617069	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	9 Month Operations	31	
617070	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
617071	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
617072	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
617073	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Amps A Ø	252.0	
617074	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Amps B Ø	277.0	
617075	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Amps C Ø	259.0	
617076	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Bushing Condition	Good	
617077	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
617078	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
617079	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
617080	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Readings	LTC Totalizer Reading	11779.20	kw
617081	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
617082	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	9 Month Operations	4	
617083	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
617084	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
617085	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
617086	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Amps A Ø	0.0	
617087	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Amps B Ø	0.0	
617088	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Amps C Ø	0.0	
617089	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Bushing Condition	Good	
617090	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Bushings Connection/Risers	Good	
617091	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
617092	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
617093	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
617094	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Cabinet Paint Condition	Good	
617095	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Equipment Properly Labeled?	y	
617096	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
617097	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
617098	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
617099	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Operations A Ø	0	
617100	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Operations B Ø	0	
617101	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
617102	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Operations Ground	0	
617103	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Follow-up Action Required?	n	
617104	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Follow-up Action Required?	n	
617105	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Foundation Condition	Good	
617106	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	General Comments		
617107	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	General Comments		
617108	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Grounds in Place?	y	
617109	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Maintenance Operations	0	
617110	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Moisture and Leak Free?	y	
617111	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Operations Counter AF	183	
617112	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Operations Counter AL	183	
617113	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Switching Operations	0	
617114	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Tank Paint Condition	Good	
617115	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Unknown Operations	0	
617116	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Readings	General Comments		
617117	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	General Comments		
617118	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
617119	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
617120	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Readings	Follow-up Action Required?	n	
617121	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
617122	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
617123	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
617124	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
617125	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
617126	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
617127	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
617128	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
617129	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
617130	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
617131	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
617132	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	General Comments		
617133	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
617134	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
617135	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
617136	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
617137	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
617138	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
617139	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	9 Month Operations	6	
617140	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
617141	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
617142	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
617143	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Amps A Ø	240.0	
617144	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Amps B Ø	240.0	
617145	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Amps C Ø	240.0	
617146	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Bushing Condition	Good	
617147	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Bushings Connection/Risers	Good	
617148	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
617149	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
617150	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
617151	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Unknown Operations	0	
617152	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Switching Operations	0	
617153	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations Counter AL	181	
617154	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations Counter AF	181	
617155	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Maintenance Operations	0	
617156	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	General Comments		
617157	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Follow-up Action Required?	n	
617158	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations Ground	0	
617159	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations C Ø	0	
617160	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations B Ø	0	
617161	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations A Ø	0	
617162	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
617163	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
617164	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
617165	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	9 Month Operations	17	
617166	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Accumulated Fault Duty A Ph V	3.82	%
617167	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Accumulated Fault Duty B Ph V	4.78	%
617168	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Accumulated Fault Duty C Ph V	4.78	%
617169	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Amps A Ø	300.0	
617170	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Amps B Ø	350.0	
617171	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Amps C Ø	280.0	
617172	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Bushing Condition	Good	
617173	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Bushings Connection/Risers	Good	
617174	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
617175	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
617176	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
617177	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
617178	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
617179	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
617180	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
617181	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
617182	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Foundation Condition	Good	
617183	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
617184	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Ambient Temperature	30	°F
617185	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
617186	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	General Comments		
617187	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
617188	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
617189	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
617190	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
617191	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
617192	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
617193	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
617194	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
617195	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
617196	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
617197	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
617198	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
617199	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
617200	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
617201	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
617202	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
617203	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
617204	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
617205	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
617206	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
617207	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
617208	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
617209	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
617210	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
617211	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
617212	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
617213	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
617214	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
617215	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
617216	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
617217	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
617218	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	411	
617219	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	411	
617220	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
617221	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
617222	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
617223	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	General Comments		
617224	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	General Comments		
617225	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Grounds in Place?	y	
617226	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Unknown Operations	0	
617227	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Switching Operations	0	
617228	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Operations Counter AL	184	
617229	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Operations Counter AF	184	
617230	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Maintenance Operations	0	
617231	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	General Comments	Breaker is open	
617232	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Follow-up Action Required?	n	
617233	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations Ground	0	
617234	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations C Ø	0	
617235	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Heaters (All) Functioning?	y	
617236	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Maintenance Operations	0	
617237	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Moisture and Leak Free?	y	
617238	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Operations Counter AF	304	
617239	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Operations Counter AL	304	
617240	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
617241	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
617242	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
617243	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
617244	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
617245	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
617246	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
617247	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
617248	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
617249	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
617250	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
617251	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
617252	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
617253	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
617254	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
617255	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
617256	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
617257	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	General Comments		
617258	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
617259	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
617260	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
617261	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
617262	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Switching Operations	0	
617263	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Tank Paint Condition	Good	
617264	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Unknown Operations	0	
617265	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
617266	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
617267	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations B Ø	0	
617268	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
617269	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
617270	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Cabinet Paint Condition	Good	
617271	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
617272	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
617273	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Cabinet Paint Condition	Good	
617274	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps C Ø	120.0	
617275	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps B Ø	90.0	
617276	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps A Ø	100.0	
617277	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty C Ph V	6.38	%
617278	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
617279	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
617280	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
617281	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
617282	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
617283	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
617284	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
617285	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
617286	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
617287	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
617288	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
617289	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	General Comments		
617290	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
617291	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
617292	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
617293	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
617294	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
617295	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	408	
617296	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	408	
617297	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pop-off Valve Tested Date	2018-04-18 00:00:00.000000	
617298	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
617299	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
617300	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
617301	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
617302	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
617303	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
617304	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
617305	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
617306	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Equipment Properly Labeled?	y	
617307	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty B Ph V	22.32	%
617308	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty A Ph V	32.68	%
617309	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	9 Month Operations	37	
617310	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
617311	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
617312	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Adjusted Amps C Phase V	6.41	
617313	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Operations A Ø	0	
617314	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Operations B Ø	0	
617315	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Operations C Ø	1	
617316	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Operations Ground	0	
617317	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Follow-up Action Required?	n	
617318	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Follow-up Action Required?	n	
617319	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Foundation Condition	Good	
617320	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.3	amps
617321	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
617322	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BCH000373	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
617323	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BCH000373	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
617324	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	°F
617325	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
617326	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
617327	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
617328	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Unknown Operations	0	
617329	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Switching Operations	0	
617330	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	7.04	%
617331	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	7.04	%
617332	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
617333	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations Counter AL	282	
617334	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations Counter AF	282	
617335	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Maintenance Operations	0	
617336	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	General Comments		
617337	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Follow-up Action Required?	n	
617338	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations Ground	0	
617339	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations C Ø	0	
617340	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations B Ø	0	
617341	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations A Ø	0	
617342	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
617343	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
617344	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
617345	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps C Ø	12.0	
617346	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps B Ø	12.0	
617347	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	130.0	
617348	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
617349	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
617350	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
617351	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
617352	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
617353	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
617354	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps A Ø	11.0	
617355	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty C Ph V	12.76	%
617356	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty B Ph V	12.76	%
617357	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty A Ph V	12.76	%
617358	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	9 Month Operations	0	
617359	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
617360	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
617361	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
617362	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
617363	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
617364	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
617365	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	General Comments		
617366	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
617367	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
617368	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Follow-up Action Required?	n	
617369	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Follow-up Action Required?	n	
617370	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Foundation Condition	Good	
617371	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	General Comments		
617372	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	General Comments		
617373	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Grounds in Place?	y	
617374	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Heaters (All) Functioning?	y	
617375	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Maintenance Operations	0	
617376	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Moisture and Leak Free?	y	
617377	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Operations Counter AF	207	
617378	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Operations Counter AL	207	
617379	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Switching Operations	6	
617380	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Tank Paint Condition	Good	
617381	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Unknown Operations	0	
617382	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
617383	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
617384	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
617385	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
617386	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
617387	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
617388	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
617389	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
617390	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
617391	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Oil Status	Good	
617392	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
617393	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
617394	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
617395	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
617396	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
617397	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
617398	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
617399	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
617400	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
617401	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
617402	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
617403	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	150.0	
617404	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	150.0	
617405	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	7.04	%
617406	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
617407	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
617408	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
617409	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
617410	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
617411	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
617412	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
617413	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
617414	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
617415	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
617416	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
617417	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
617418	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Vegetation	None	
617419	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
617420	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	4.47	%
617421	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	4.02	%
617422	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	3.13	%
617423	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	80.0	
617424	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	80.0	
617425	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Tank Paint Condition	Good	
617426	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Switching Operations	0	
617427	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
617428	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	80.0	
617429	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
617430	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
617431	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
617432	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
617433	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
617434	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
617435	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
617436	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
617437	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
617438	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
617439	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
617440	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
617441	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
617442	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
617443	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
617444	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
617445	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
617446	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
617447	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
617448	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
617449	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Operations Counter AL	66	
617450	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Operations Counter AF	66	
617451	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Num Operations Last 9 Months	2	
617452	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
617453	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Maintenance Operations	0	
617454	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
617455	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Grounds in Place?	y	
617456	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	General Comments	y	
617457	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	General Comments		
617458	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
617459	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Foundation Condition	Good	
617460	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Follow-up Action Required?	n	
617461	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Follow-up Action Required?	n	
617462	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Fault Operations	0	
617463	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
617464	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.3	amps
617465	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
617466	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
617467	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
617468	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
617469	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
617470	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
617471	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
617472	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
617473	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
617474	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
617475	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
617476	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
617477	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
617478	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
617479	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
617480	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	62.50	
617481	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
617482	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
617483	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
617484	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
617485	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
617486	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
617487	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	36	°F
617488	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
617489	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
617490	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
617491	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
617492	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
617493	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
617494	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
617495	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
617496	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
617497	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
617498	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Ambient Temp	31	°F
617499	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
617500	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Clear of Trash?	y	
617501	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
617502	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
617503	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
617504	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
617505	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
617506	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
617507	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
617508	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
617509	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
617510	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
617511	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	General Comments		
617512	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
617513	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	500	psi
617514	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
617515	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
617516	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Switching Operations	0	
617517	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Operations Counter AL	210	
617518	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	LTC Totalizer Reading	4636.80	kw
617519	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
617520	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Operations Counter AF	210	
617521	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Moisture and Leak Free?	y	
617522	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Maintenance Operations	0	
617523	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Heaters (All) Functioning?	y	
617524	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Grounds in Place?	y	
617525	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	General Comments		
617526	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	General Comments		
617527	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Foundation Condition	Good	
617528	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Follow-up Action Required?	n	
617529	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Follow-up Action Required?	n	
617530	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Operations Ground	0	
617531	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Operations C Ø	0	
617532	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Operations B Ø	0	
617533	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Operations A Ø	0	
617534	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
617535	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
617536	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
617537	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Equipment Properly Labeled?	y	
617538	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Cabinet Paint Condition	Good	
617539	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
617540	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	VRR Time Delay	30	Seconds
617541	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
617542	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
617543	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
617544	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	LTC Operation Checked?	y	
617545	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	General Comments		
617546	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
617547	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
617548	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Bushings Connection/Risers	Good	
617549	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Bushing Condition	Good	
617550	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Amps C Ø	205.0	
617551	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Amps B Ø	200.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
617552	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Amps A Ø	170.0	
617553	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
617554	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
617555	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
617556	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	9 Month Operations	3	
617557	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	General Comments		
617558	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	General Comments		
617559	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
617560	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Tank Leaks	None	
617561	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
617562	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
617563	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
617564	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Follow-up Action Required?	n	
617565	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Follow-up Action Required?	n	
617566	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Foundation Condition	Good	
617567	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
617568	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	General Comments		
617569	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	General Comments	y	
617570	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Grounds in Place?	y	
617571	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
617572	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Maintenance Operations	0	
617573	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
617574	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Num Operations Last 9 Months	1	
617575	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Operations Counter AF	46	
617576	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Operations Counter AL	46	
617577	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
617578	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
617579	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
617580	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
617581	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
617582	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
617583	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
617584	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Switching Operations	1	
617585	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Tank Paint Condition	Good	
617586	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Unknown Operations	0	
617587	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
617588	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
617589	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
617590	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
617591	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
617592	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
617593	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
617594	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
617595	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Winding Temp Present	20	°C
617596	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Winding Temp Max	25	°C
617597	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Totalizer Meter Reading	.3220	
617598	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
617599	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
617600	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
617601	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
617602	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
617603	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
617604	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
617605	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Tank Paint Condition	Good	
617606	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
617607	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Oil Temp Present	15	°C
617608	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Oil Temp Max	20	°C
617609	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
617610	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
617611	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
617612	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
617613	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
617614	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
617615	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
617616	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
617617	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
617618	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
617619	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
617620	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	9 Month Operations	3	
617621	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
617622	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Tank Leaks	None	
617623	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
617624	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
617625	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Regulator As Left Counter	47402	
617626	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	120.0	volts

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
617627	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
617628	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
617629	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
617630	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
617631	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
617632	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
617633	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
617634	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
617635	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
617636	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
617637	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
617638	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	General Comments		
617639	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
617640	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
617641	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Leaks	None	
617642	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Oil Levels OK?	y	
617643	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
617644	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
617645	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
617646	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
617647	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
617648	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
617649	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	General Comments		
617650	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
617651	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
617652	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
617653	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
617654	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
617655	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
617656	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
617657	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
617658	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
617659	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Regulator As Left Counter	53307	
617660	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	120.0	volts
617661	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
617662	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
617663	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
617664	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
617665	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
617666	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
617667	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
617668	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Follow-up Action Required?	n	
617669	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
617670	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Unknown Operations	0	
617671	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Tank Paint Condition	Good	
617672	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Switching Operations	0	
617673	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
617674	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Operations Counter AL	22	
617675	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Operations Counter AF	22	
617676	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Moisture and Leak Free?	y	
617677	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Maintenance Operations	0	
617678	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Heaters (All) Functioning?	y	
617679	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Grounds in Place?	y	
617680	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	General Comments		
617681	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	General Comments		
617682	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Foundation Condition	Good	
617683	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Follow-up Action Required?	n	
617684	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Follow-up Action Required?	n	
617685	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Operations Ground	0	
617686	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Operations C Ø	0	
617687	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Operations B Ø	0	
617688	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Operations A Ø	0	
617689	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
617690	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
617691	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	General Comments		
617692	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
617693	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
617694	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
617695	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
617696	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
617697	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
617698	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
617699	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
617700	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
617701	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
617702	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
617703	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
617704	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
617705	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
617706	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Tank Paint Condition	Good	
617707	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
617708	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
617709	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
617710	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
617711	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
617712	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
617713	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	VRR Time Delay	30	Seconds
617714	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
617715	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
617716	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
617717	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	LTC Operation Checked?	y	
617718	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	General Comments		
617719	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	Follow-up Action Required?	n	
617720	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	All Connections OK?	y	
617721	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
617722	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
617723	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Amps C Ø	0.0	
617724	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Amps B Ø	0.0	
617725	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Amps A Ø	0.0	
617726	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Accumulated Fault Duty C Ph V	11.16	%
617727	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
617728	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
617729	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Accumulated Fault Duty B Ph V	11.16	%
617730	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Accumulated Fault Duty A Ph V	11.16	%
617731	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	9 Month Operations	0	
617732	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
617733	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
617734	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	421	
617735	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Unknown Operations	0	
617736	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
617737	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
617738	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
617739	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
617740	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
617741	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
617742	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.7	amps
617743	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
617744	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Tank Paint Condition	Good	
617745	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Switching Operations	0	
617746	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
617747	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Operations Counter AL	482	
617748	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
617749	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	General Comments		
617750	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Operations Counter AF	482	
617751	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Moisture and Leak Free?	y	
617752	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Maintenance Operations	0	
617753	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Heaters (All) Functioning?	y	
617754	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Equipment Properly Labeled?	y	
617755	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
617756	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
617757	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
617758	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Operations A Ø	0	
617759	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Operations B Ø	0	
617760	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Operations C Ø	0	
617761	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Operations Ground	0	
617762	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Follow-up Action Required?	n	
617763	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations A Ø	0	
617764	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Follow-up Action Required?	n	
617765	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Foundation Condition	Good	
617766	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	General Comments		
617767	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
617768	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
617769	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
617770	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
617771	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
617772	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	General Comments		
617773	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Grounds in Place?	y	
617774	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Heaters (All) Functioning?	y	
617775	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Maintenance Operations	0	
617776	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
617777	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Operations Counter AF	434	
617778	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BB0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
617779	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BB0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	81.00	
617780	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BB0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
617781	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BB0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
617782	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BB0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
617783	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BB0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
617784	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BB0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
617785	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
617786	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
617787	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	670	
617788	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	670	
617789	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
617790	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	2	
617791	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
617792	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
617793	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
617794	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
617795	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BB0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
617796	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BB0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
617797	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BB0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
617798	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BB0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
617799	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BB0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
617800	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Operations Counter AL	434	
617801	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
617802	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Switching Operations	0	
617803	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Bushing Condition	Good	
617804	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Amps C Ø	240.0	
617805	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Amps B Ø	240.0	
617806	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Amps A Ø	240.0	
617807	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Accumulated Fault Duty C Ph V	5.40	%
617808	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Accumulated Fault Duty B Ph V	5.40	%
617809	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
617810	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations Ground	0	
617811	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations C Ø	0	
617812	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
617813	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
617814	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
617815	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
617816	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations B Ø	0	
617817	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations A Ø	0	
617818	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
617819	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
617820	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Ambient Temperature	30	°F
617821	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
617822	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
617823	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
617824	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
617825	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
617826	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Fault Operations	0	
617827	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
617828	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Amps C Ø	90.0	
617829	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Amps B Ø	100.0	
617830	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Amps A Ø	60.0	
617831	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Accumulated Fault Duty C Ph V	7.17	%
617832	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Accumulated Fault Duty B Ph V	3.99	%
617833	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
617834	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
617835	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
617836	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
617837	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
617838	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
617839	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Foundation Condition	Good	
617840	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Accumulated Fault Duty A Ph V	3.99	%
617841	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	9 Month Operations	8	
617842	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
617843	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
617844	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	FE000346	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
617845	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
617846	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	General Comments		
617847	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
617848	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
617849	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Unknown Operations	0	
617850	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
617851	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
617852	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	General Comments		
617853	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	General Comments		
617854	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Foundation Condition	Good	
617855	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Follow-up Action Required?	n	
617856	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Follow-up Action Required?	n	
617857	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Operations Ground	0	
617858	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Operations C Ø	0	
617859	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
617860	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
617861	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
617862	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
617863	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
617864	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC Operations Since Last Insp	427	
617865	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
617866	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
617867	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
617868	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC Min Tap Position	8L	
617869	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC Max Tap Position	2R	
617870	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC Current Tap Position	3L	
617871	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
617872	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC As Left Counter	4229	
617873	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC As Found Counter	4229	
617874	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	General Comments		
617875	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	General Comments		
617876	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
617877	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	Follow-up Action Required?	n	
617878	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Unknown Operations	0	
617879	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Switching Operations	0	
617880	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations Counter AL	204	
617881	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations Counter AF	204	
617882	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Maintenance Operations	0	
617883	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
617884	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0129	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	171	
617885	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0129	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	171	
617886	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0129	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	10	
617887	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	General Comments		
617888	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Follow-up Action Required?	n	
617889	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Operations B Ø	0	
617890	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Operations A Ø	0	
617891	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
617892	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
617893	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
617894	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Equipment Properly Labeled?	y	
617895	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Cabinet Paint Condition	Good	
617896	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
617897	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
617898	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
617899	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Bushings Connection/Risers	Good	
617900	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
617901	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
617902	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Accumulated Fault Duty B Ph V	5.49	%
617903	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Winding Temp Present	65	°C
617904	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Winding Temp Max	35	°C
617905	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Totalizer Meter Reading	1.0368	
617906	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
617907	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
617908	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
617909	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
617910	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
617911	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
617912	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
617913	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Accumulated Fault Duty A Ph V	10.99	%
617914	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
617915	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
617916	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	9 Months Operations	2	
617917	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
617918	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	9 Month Operations	6	
617919	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	9 Month Operations	4	
617920	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Accumulated Fault Duty A Ph V	7.32	%
617921	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Accumulated Fault Duty B Ph V	7.32	%
617922	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
617923	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
617924	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
617925	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
617926	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
617927	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
617928	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	9 Months Operations	1	
617929	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Accumulated Fault Duty A Ph AM	11.74	%
617930	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Accumulated Fault Duty B Ph AM	10.67	%
617931	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
617932	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Amps A Ø	100.0	
617933	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Amps B Ø	150.0	
617934	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Amps C Ø	160.0	
617935	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
617936	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Accumulated Fault Duty B Ph V	12.59	%
617937	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	General Comments		
617938	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
617939	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
617940	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Oil Temp Present	30	°C
617941	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
617942	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
617943	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
617944	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
617945	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
617946	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
617947	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
617948	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
617949	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
617950	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Totalizer Meter Reading	.8070	
617951	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
617952	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
617953	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
617954	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
617955	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Readings	Operations Counter AF	120	
617956	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
617957	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	455	
617958	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
617959	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Bushing Condition	Good	
617960	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Amps C Ø	335.0	
617961	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Amps B Ø	320.0	
617962	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Amps A Ø	395.0	
617963	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Accumulated Fault Duty C Ph V	7.32	%
617964	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	455	
617965	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
617966	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Switching Operations	0	
617967	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Operations Counter AL	351	
617968	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Operations Counter AF	351	
617969	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Maintenance Operations	0	
617970	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
617971	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	General Comments		
617972	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Patrol Inspection	General Comments		
617973	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Follow-up Action Required?	n	
617974	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
617975	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
617976	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Operations Ground	0	
617977	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Operations C Ø	0	
617978	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Operations B Ø	0	
617979	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Operations A Ø	0	
617980	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
617981	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
617982	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
617983	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
617984	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
617985	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	B0417	WithLTC	662-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
617986	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	B0417	WithLTC	662-2	LTC Transformer Readings	Totalizer Meter Reading	.7540	
617987	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	B0417	WithLTC	662-2	LTC Transformer Readings	Winding Temp Max	40	°C
617988	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	B0417	WithLTC	662-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
617989	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	B0417	WithLTC	662-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
617990	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
617991	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
617992	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
617993	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
617994	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	9 Month Operations	4	
617995	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
617996	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Accumulated Fault Duty B Ph V	.91	%
617997	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Accumulated Fault Duty C Ph V	2.73	%
617998	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
617999	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Winding Temp Max	40	°C
618000	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Totalizer Meter Reading	.2310	
618001	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
618002	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
618003	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
618004	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
618005	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
618006	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
618007	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
618008	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Operations A Ø	0	
618009	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Operations B Ø	0	
618010	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Operations C Ø	0	
618011	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Operations Ground	0	
618012	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Follow-up Action Required?	n	
618013	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Follow-up Action Required?	n	
618014	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Foundation Condition	Good	
618015	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	General Comments		
618016	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	General Comments		
618017	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Grounds in Place?	y	
618018	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Heaters (All) Functioning?	y	
618019	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Maintenance Operations	0	
618020	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Moisture and Leak Free?	y	
618021	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Accumulated Fault Duty C Ph V	5.49	%
618022	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Amps A Ø	1120.0	
618023	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Amps B Ø	200.0	
618024	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Amps C Ø	175.0	
618025	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Bushing Condition	Good	
618026	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Accumulated Fault Duty A Ph AM	7.47	%
618027	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Accumulated Fault Duty B Ph AM	10.67	%
618028	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Accumulated Fault Duty C Ph AM	7.47	%
618029	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Bushings Connection/Risers	Good	
618030	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Accumulated Fault Duty C Ph V	12.59	%
618031	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
618032	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Amps A Ø	100.0	
618033	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.18	%
618034	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Amps B Ø	50.0	
618035	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.18	%
618036	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.18	%
618037	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Amps C Ø	50.0	
618038	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
618039	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
618040	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
618041	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
618042	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Operations A Ø	0	
618043	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Operations B Ø	0	
618044	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Operations C Ø	0	
618045	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Operations Ground	0	
618046	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
618047	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Follow-up Action Required?	n	
618048	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Patrol Inspection	General Comments		
618049	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	General Comments		
618050	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
618051	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Maintenance Operations	0	
618052	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Operations Counter AF	445	
618053	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Operations Counter AL	445	
618054	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Switching Operations	0	
618055	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Unknown Operations	0	
618056	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	320.0	
618057	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Unknown Operations	0	
618058	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Tank Paint Condition	Good	
618059	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Switching Operations	0	
618060	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Operations Counter AL	299	
618061	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Operations Counter AF	299	
618062	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
618063	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
618064	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
618065	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
618066	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
618067	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
618068	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
618069	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	9 Month Operations	5	
618070	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Accumulated Fault Duty A Ph V	.48	%
618071	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Accumulated Fault Duty B Ph V	.48	%
618072	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Accumulated Fault Duty C Ph V	.48	%
618073	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	Seeping	
618074	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
618075	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
618076	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
618077	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
618078	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
618079	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
618080	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	Oil Temp Max	70	°C
618081	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
618082	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
618083	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	20	°C
618084	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	40	°C
618085	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
618086	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Needs Nitro	
618087	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	General Comments		
618088	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
618089	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
618090	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
618091	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
618092	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
618093	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
618094	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
618095	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
618096	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
618097	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
618098	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
618099	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
618100	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
618101	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
618102	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
618103	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
618104	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
618105	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
618106	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
618107	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Operations Counter AL	229	
618108	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Operations Counter AF	229	
618109	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Moisture and Leak Free?	y	
618110	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Maintenance Operations	0	
618111	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Heaters (All) Functioning?	y	
618112	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Bushings Connection/Risers	Good	
618113	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Bushing Condition	Good	
618114	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0053	BreakerVacuum	662-0179	VCB Readings	Amps C Ø	0.0	
618115	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Amps B Ø	100.0	
618116	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
618117	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Vegetation	None	
618118	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
618119	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
618120	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	General Comments		
618121	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
618122	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
618123	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Grounds in Place?	y	
618124	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Amps A Ø	100.0	
618125	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	General Comments		
618126	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	General Comments		
618127	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Follow-up Action Required?	n	
618128	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Readings	Follow-up Action Required?	n	
618129	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Foundation Condition	Good	
618130	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	General Comments		
618131	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Readings	General Comments		
618132	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Foundation Condition	Good	
618133	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Follow-up Action Required?	n	
618134	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0053	BreakerVacuum	662-0179	VCB Readings	Amps B Ø	0.0	
618135	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0053	BreakerVacuum	662-0179	VCB Readings	Amps A Ø	0.0	
618136	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Follow-up Action Required?	n	
618137	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Operations Ground	0	
618138	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Operations C Ø	0	
618139	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Operations B Ø	0	
618140	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Operations A Ø	0	
618141	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
618142	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
618143	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Oil Temp Max	40	°C
618144	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
618145	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
618146	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	LTC Totalizer Reading	4842.00	kw
618147	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
618148	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
618149	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
618150	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
618151	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
618152	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
618153	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	General Comments		
618154	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	General Comments		
618155	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
618156	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
618157	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
618158	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
618159	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
618160	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
618161	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
618162	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
618163	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
618164	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
618165	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
618166	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
618167	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Follow-up Action Required?	n	
618168	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
618169	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
618170	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
618171	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	BCH000105	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
618172	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Unknown Operations	0	
618173	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Tank Paint Condition	Good	
618174	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
618175	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Readings	Maintenance Operations	0	
618176	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
618177	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Grounds in Place?	y	
618178	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Bushings Connection/Risers	Good	
618179	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
618180	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
618181	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
618182	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Cabinet Paint Condition	Good	
618183	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
618184	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
618185	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
618186	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
618187	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
618188	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
618189	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	y	
618190	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	General Comments	heater not working	
618191	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
618192	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
618193	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
618194	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
618195	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
618196	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
618197	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Clear of Trash?	y	
618198	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
618199	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Unknown Operations	0	
618200	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
618201	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
618202	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	General Comments		
618203	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
618204	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
618205	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
618206	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
618207	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
618208	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
618209	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
618210	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
618211	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
618212	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
618213	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
618214	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Maintenance Operations	1	
618215	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Moisture and Leak Free?	y	
618216	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Operations Counter AF	230	
618217	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Operations Counter AL	230	
618218	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Switching Operations	2	
618219	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
618220	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
618221	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
618222	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
618223	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Equipment Properly Labeled?	y	
618224	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Accumulated Fault Duty B Ph V	.89	%
618225	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
618226	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
618227	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Accumulated Fault Duty C Ph V	.89	%
618228	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Amps A Ø	10.0	
618229	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Amps B Ø	10.0	
618230	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
618231	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Amps C Ø	10.0	
618232	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
618233	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Bushing Condition	Good	
618234	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Bushings Connection/Risers	Good	
618235	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
618236	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
618237	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
618238	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Cabinet Paint Condition	Good	
618239	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
618240	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
618241	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
618242	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
618243	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
618244	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
618245	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
618246	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
618247	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
618248	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
618249	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
618250	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
618251	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
618252	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
618253	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
618254	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
618255	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
618256	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
618257	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
618258	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
618259	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
618260	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Readings	Follow-up Action Required?	n	
618261	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
618262	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
618263	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	General Comments		
618264	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	General Comments		
618265	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
618266	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
618267	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
618268	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
618269	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
618270	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
618271	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
618272	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
618273	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
618274	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
618275	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
618276	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
618277	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
618278	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
618279	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
618280	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.93	%
618281	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Operations Counter AF	54	
618282	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Maintenance Operations	1	
618283	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	General Comments	.	
618284	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
618285	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
618286	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
618287	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
618288	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
618289	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
618290	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
618291	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	175.0	
618292	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	175.0	
618293	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	150.0	
618294	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
618295	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
618296	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Readings	Oil Temp Max	35	°C
618297	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
618298	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
618299	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
618300	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
618301	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
618302	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Readings	LTC Totalizer Reading	10857.60	kw
618303	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
618304	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Readings	General Comments		
618305	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
618306	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations Ground	0	
618307	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations C Ø	0	
618308	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations B Ø	0	
618309	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
618310	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
618311	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
618312	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
618313	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
618314	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
618315	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
618316	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
618317	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
618318	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
618319	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
618320	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
618321	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
618322	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
618323	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations A Ø	0	
618324	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
618325	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
618326	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
618327	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
618328	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
618329	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Amps C Ø	0.0	
618330	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
618331	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
618332	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Totalizer Meter Reading	.7580	
618333	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
618334	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Totalizer Meter Reading	.9170	
618335	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
618336	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
618337	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
618338	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
618339	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
618340	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
618341	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
618342	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
618343	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
618344	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
618345	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
618346	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	9 Month Operations	4	
618347	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
618348	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
618349	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	9 Months Operations	4	
618350	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Accumulated Fault Duty A Ph AM	1.2	%
618351	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Accumulated Fault Duty B Ph AM	6.02	%
618352	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Accumulated Fault Duty C Ph AM	2.41	%
618353	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Amps A Ø	0.0	
618354	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Amps B Ø	0.0	
618355	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
618356	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
618357	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	352	
618358	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
618359	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
618360	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
618361	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
618362	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
618363	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Oil Temp Max	40	°C
618364	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Oil Temp Present	30	°C
618365	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
618366	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
618367	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
618368	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
618369	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
618370	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
618371	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
618372	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
618373	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
618374	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
618375	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
618376	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Totalizer Meter Reading	1.0470	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
618377	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Winding Temp Max	40	°C
618378	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
618379	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
618380	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
618381	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
618382	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
618383	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
618384	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
618385	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
618386	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
618387	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
618388	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
618389	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Tank Paint Condition	Good	
618390	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Switching Operations	0	
618391	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
618392	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Operations Counter AL	120	
618393	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
618394	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	405.00	
618395	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
618396	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
618397	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
618398	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Maintenance Operations	0	
618399	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	400.0	
618400	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	320.0	
618401	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	General Comments		
618402	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	General Comments		
618403	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
618404	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
618405	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Follow-up Action Required?	n	
618406	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
618407	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
618408	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
618409	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
618410	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
618411	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
618412	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
618413	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
618414	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
618415	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
618416	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Heaters (All) Functioning?	y	
618417	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Grounds in Place?	y	
618418	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	General Comments		
618419	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	General Comments		
618420	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Foundation Condition	Good	
618421	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Follow-up Action Required?	n	
618422	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Follow-up Action Required?	n	
618423	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Operations Ground	0	
618424	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
618425	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
618426	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
618427	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
618428	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
618429	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Cabinet Paint Condition	Good	
618430	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Heaters (All) Functioning?	y	
618431	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
618432	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	13.19	%
618433	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	13.19	%
618434	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	8.11	%
618435	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
618436	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
618437	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	360.0	
618438	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	360.0	
618439	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	370.0	
618440	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
618441	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
618442	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
618443	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
618444	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
618445	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
618446	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
618447	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Equipment Properly Labeled?	y	
618448	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
618449	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
618450	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
618451	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
618452	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Operations B Ø	0	
618453	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
618454	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
618455	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
618456	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
618457	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
618458	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
618459	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
618460	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Grounds in Place?	y	
618461	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	General Comments		
618462	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	General Comments		
618463	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Operations C Ø	0	
618464	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Readings	Oil Temp Max	45	°C
618465	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
618466	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
618467	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Operations Counter AL	54	
618468	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
618469	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	General Comments		
618470	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
618471	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
618472	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
618473	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
618474	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Readings	Totalizer Meter Reading	.4680	
618475	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
618476	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
618477	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
618478	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
618479	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
618480	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
618481	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
618482	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
618483	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
618484	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	LTC Totalizer Reading	7336.00	kw
618485	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
618486	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
618487	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
618488	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	2	
618489	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
618490	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	737	
618491	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	737	
618492	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
618493	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
618494	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
618495	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	LTC Totalizer Reading	18846.00	kw
618496	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
618497	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
618498	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Oil Temp Max	35	°C
618499	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
618500	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
618501	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
618502	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
618503	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
618504	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
618505	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
618506	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
618507	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
618508	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Unknown Operations	0	
618509	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
618510	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Moisture and Leak Free?	y	
618511	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Operations Counter AF	384	
618512	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCC000203	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
618513	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCC000203	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
618514	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCC000203	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
618515	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCC000203	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
618516	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCC000203	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
618517	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCC000203	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
618518	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCC000203	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
618519	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCC000203	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
618520	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	LTCC000203	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
618521	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Operations Counter AL	384	
618522	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
618523	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Switching Operations	0	
618524	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Tank Paint Condition	Good	
618525	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Unknown Operations	0	
618526	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
618527	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
618528	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	120.0	
618529	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
618530	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
618531	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
618532	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
618533	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
618534	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
618535	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
618536	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
618537	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
618538	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
618539	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
618540	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
618541	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
618542	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
618543	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
618544	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
618545	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
618546	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	General Comments		
618547	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Unknown Operations	0	
618548	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Switching Operations	0	
618549	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Follow-up Action Required?	n	
618550	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Follow-up Action Required?	n	
618551	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
618552	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
618553	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
618554	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Amps A Ø	10.0	
618555	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Amps B Ø	10.0	
618556	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Amps C Ø	10.0	
618557	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Bushing Condition	Good	
618558	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Bushings Connection/Risers	Good	
618559	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
618560	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Follow-up Action Required?	n	
618561	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Follow-up Action Required?	n	
618562	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Foundation Condition	Good	
618563	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	General Comments		
618564	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	General Comments		
618565	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Grounds in Place?	y	
618566	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Maintenance Operations	0	
618567	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Moisture and Leak Free?	y	
618568	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Operations Counter AF	174	
618569	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
618570	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
618571	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Cabinet Paint Condition	Good	
618572	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
618573	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
618574	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Amps C Ø	800.0	
618575	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
618576	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Operations Counter AL	174	
618577	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Switching Operations	1	
618578	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Tank Paint Condition	Good	
618579	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Unknown Operations	0	
618580	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Amps B Ø	800.0	
618581	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Equipment Properly Labeled?	y	
618582	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
618583	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
618584	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
618585	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
618586	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC As Found Counter	365924	
618587	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC As Left Counter	365924	
618588	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
618589	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Switching Operations	2	
618590	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
618591	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Operations Counter AL	270	
618592	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Operations Counter AF	270	
618593	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Heaters (All) Functioning?	y	
618594	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Grounds in Place?	y	
618595	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Moisture and Leak Free?	y	
618596	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Maintenance Operations	2	
618597	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	General Comments		
618598	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
618599	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
618600	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
618601	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.9	amps

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
618602	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
618603	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	General Comments		
618604	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	General Comments		
618605	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Foundation Condition	Good	
618606	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Follow-up Action Required?	n	
618607	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Follow-up Action Required?	n	
618608	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Operations Ground	0	
618609	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Operations C Ø	0	
618610	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Operations B Ø	0	
618611	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Operations A Ø	0	
618612	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Oil Temp Max	45	°C
618613	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
618614	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
618615	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	LTC Totalizer Reading	3326.40	kw
618616	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
618617	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	General Comments		
618618	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	General Comments		
618619	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
618620	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	Follow-up Action Required?	n	
618621	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
618622	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
618623	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
618624	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
618625	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1186	
618626	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
618627	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
618628	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
618629	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
618630	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Maintenance Operations	0	
618631	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Operations Counter AF	457	
618632	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Operations Counter AL	457	
618633	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
618634	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
618635	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
618636	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
618637	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
618638	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	9 Month Operations	2	
618639	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
618640	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Switching Operations	0	
618641	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
618642	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
618643	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
618644	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
618645	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
618646	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
618647	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
618648	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
618649	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
618650	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Vegetation	None	
618651	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
618652	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
618653	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
618654	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
618655	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
618656	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
618657	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
618658	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Accumulated Fault Duty C Ph V	.78	%
618659	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Amps A Ø	30.0	
618660	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Amps B Ø	42.0	
618661	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Amps C Ø	33.0	
618662	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Bushing Condition	Good	
618663	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Bushings Connection/Risers	Good	
618664	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
618665	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
618666	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
618667	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
618668	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
618669	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
618670	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Foundation Condition	Good	
618671	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	General Comments		
618672	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	General Comments		
618673	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Grounds in Place?	y	
618674	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Heaters (All) Functioning?	y	
618675	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	9 Month Operations	6	
618676	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
618677	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	LTC oil level starting to get low.	
618678	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	General Comments		
618679	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
618680	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
618681	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Operations Ground	0	
618682	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Operations C Ø	1	
618683	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Operations B Ø	0	
618684	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Operations A Ø	0	
618685	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Adjusted Amps C Phase V	10.52	
618686	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
618687	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
618688	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Equipment Properly Labeled?	y	
618689	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Cabinet Paint Condition	Good	
618690	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
618691	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
618692	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
618693	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
618694	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
618695	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
618696	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
618697	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
618698	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
618699	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
618700	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
618701	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
618702	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	General Comments		
618703	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
618704	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
618705	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
618706	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
618707	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
618708	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
618709	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
618710	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
618711	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
618712	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
618713	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	General Comments		
618714	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
618715	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
618716	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
618717	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
618718	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
618719	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
618720	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
618721	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
618722	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
618723	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
618724	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
618725	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
618726	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
618727	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
618728	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
618729	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
618730	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
618731	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
618732	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
618733	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
618734	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
618735	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	9 Month Operations	16	
618736	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Accumulated Fault Duty A Ph V	9.37	%
618737	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Accumulated Fault Duty B Ph V	15.62	%
618738	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
618739	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
618740	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
618741	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
618742	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
618743	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
618744	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
618745	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
618746	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
618747	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
618748	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
618749	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
618750	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
618751	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
618752	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
618753	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
618754	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	General Comments		
618755	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC As Found Counter	109245	
618756	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC As Left Counter	109245	
618757	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
618758	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
618759	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
618760	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
618761	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
618762	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	General Comments		
618763	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC Current Tap Position	4L	
618764	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
618765	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
618766	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
618767	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
618768	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Moisture and Leak Free?	y	
618769	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Operations Counter AF	218	
618770	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Operations Counter AL	218	
618771	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
618772	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Switching Operations	0	
618773	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Tank Paint Condition	Good	
618774	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Unknown Operations	0	
618775	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
618776	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Gate Locks Functioning ?	y	
618777	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
618778	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
618779	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
618780	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Follow-up Action Required?	n	
618781	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Ties Intact?	y	
618782	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Posts Condition OK?	y	
618783	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Grounds in Place?	y	
618784	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Gates Aligned?	y	
618785	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Accumulated Fault Duty C Ph V	8.33	%
618786	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
618787	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
618788	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
618789	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
618790	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
618791	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
618792	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Follow-up Action Required?	n	
618793	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Operations Ground	0	
618794	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Operations C Ø	0	
618795	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Operations B Ø	0	
618796	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Operations A Ø	0	
618797	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
618798	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
618799	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
618800	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Amps C Ø	100.0	
618801	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Amps B Ø	100.0	
618802	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Amps A Ø	80.0	
618803	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Accumulated Fault Duty C Ph V	2.73	%
618804	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
618805	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Accumulated Fault Duty A Ph V	1.82	%
618806	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	9 Month Operations	4	
618807	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
618808	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Readings	Follow-up Action Required?	n	
618809	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
618810	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
618811	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	General Comments		
618812	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Readings	General Comments		
618813	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
618814	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Operations Counter AL	250	
618815	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Readings	LTC Totalizer Reading	2246.40	kw
618816	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
618817	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
618818	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
618819	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
618820	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
618821	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
618822	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.01	%
618823	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	4.02	%
618824	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Operations Ground	0	
618825	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Operations Counter AF	250	
618826	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	5.03	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
618827	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Moisture and Leak Free?	y	
618828	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Maintenance Operations	0	
618829	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
618830	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
618831	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Unknown Operations	0	
618832	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Tank Paint Condition	Good	
618833	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
618834	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
618835	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
618836	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Signage Visible, and Proper?	y	
618837	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Amps A Ø	363.0	
618838	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Amps B Ø	277.0	
618839	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Amps C Ø	270.0	
618840	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC Min Tap Position	9L	
618841	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC Operations Since Last Insp	385	
618842	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
618843	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
618844	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
618845	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Unknown Operations	0	
618846	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Tank Paint Condition	Good	
618847	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Switching Operations	0	
618848	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Bushing Condition	Good	
618849	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Bushings Connection/Risers	Good	
618850	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
618851	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
618852	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
618853	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Cabinet Paint Condition	Good	
618854	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Equipment Properly Labeled?	y	
618855	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
618856	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Adjusted Amps B Phase V	27.94	
618857	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
618858	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Operations A Ø	0	
618859	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Operations B Ø	2	
618860	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Operations C Ø	0	
618861	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	9 Month Operations	0	
618862	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
618863	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
618864	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
618865	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Amps A Ø	800.0	
618866	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
618867	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Unknown Operations	0	
618868	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Switching Operations	0	
618869	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
618870	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Operations Counter AL	456	
618871	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Operations Counter AF	456	
618872	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Maintenance Operations	0	
618873	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	General Comments		
618874	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
618875	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
618876	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
618877	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
618878	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
618879	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
618880	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
618881	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
618882	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
618883	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
618884	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
618885	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
618886	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
618887	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
618888	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
618889	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
618890	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
618891	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
618892	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Oil Temp Present	25	°C
618893	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Oil Temp Max	35	°C
618894	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
618895	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
618896	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	LTC Totalizer Reading	18662.40	kw
618897	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
618898	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	General Comments	one fan will not shut off	
618899	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	General Comments		
618900	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
618901	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
618902	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Follow-up Action Required?	y	
618903	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
618904	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
618905	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
618906	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
618907	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
618908	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
618909	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
618910	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
618911	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
618912	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
618913	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
618914	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	9 Month Operations	48	
618915	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
618916	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	168	
618917	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	168	
618918	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
618919	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
618920	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
618921	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Operations Counter AL	352	
618922	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Switching Operations	0	
618923	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0290	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
618924	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0290	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
618925	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0290	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
618926	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0290	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
618927	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0290	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
618928	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0290	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
618929	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0290	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	61.00	
618930	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0290	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
618931	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0290	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
618932	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0290	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
618933	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0290	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
618934	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0290	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
618935	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0290	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
618936	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0290	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
618937	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0290	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
618938	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Unknown Operations	0	
618939	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0290	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
618940	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0290	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
618941	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	General Comments		
618942	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
618943	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
618944	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Follow-up Action Required?	n	
618945	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0290	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
618946	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
618947	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
618948	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
618949	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
618950	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
618951	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
618952	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
618953	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
618954	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
618955	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
618956	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
618957	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
618958	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
618959	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
618960	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Switching Operations	0	
618961	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Tank Paint Condition	Good	
618962	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Unknown Operations	0	
618963	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
618964	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
618965	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
618966	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Cabinet Paint Condition	Good	
618967	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Equipment Properly Labeled?	y	
618968	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
618969	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Amps C Ø	100.0	
618970	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
618971	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
618972	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
618973	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
618974	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
618975	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
618976	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
618977	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
618978	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
618979	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
618980	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
618981	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
618982	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
618983	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
618984	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
618985	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC Operations Since Last Insp	426	
618986	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
618987	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
618988	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
618989	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
618990	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
618991	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
618992	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
618993	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
618994	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
618995	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
618996	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
618997	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Operations A Ø	0	
618998	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
618999	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
619000	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	General Comments		
619001	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
619002	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
619003	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
619004	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
619005	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
619006	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
619007	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
619008	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
619009	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
619010	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
619011	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	General Comments		
619012	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
619013	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
619014	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Foundation Condition	Good	
619015	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	LTCC000507	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
619016	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	LTCC000507	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
619017	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	Follow-up Action Required?	n	
619018	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	General Comments		
619019	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC As Found Counter	68720	
619020	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC As Left Counter	68720	
619021	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	LTCC000507	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
619022	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	LTCC000507	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
619023	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	LTCC000507	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	122.0	VAC
619024	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	LTCC000507	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
619025	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	LTCC000507	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	122.0	VAC
619026	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	LTCC000507	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	122.0	VAC
619027	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	LTCC000507	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
619028	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
619029	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Foundation Condition	Good	
619030	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
619031	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
619032	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC Current Tap Position	5L	
619033	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
619034	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC Min Tap Position	10L	
619035	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
619036	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
619037	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
619038	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
619039	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
619040	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
619041	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
619042	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
619043	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	FE000522	Fence	920-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
619044	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	FE000522	Fence	920-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
619045	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	FE000522	Fence	920-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
619046	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	FE000522	Fence	920-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
619047	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Follow-up Action Required?	n	
619048	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0053	BreakerVacuum	662-0179	VCB Readings	Follow-up Action Required?	n	
619049	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Foundation Condition	Good	
619050	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	General Comments		
619051	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
619052	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
619053	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
619054	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	204	
619055	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	203	
619056	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	General Comments		
619057	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Grounds in Place?	y	
619058	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Accumulated Fault Duty A Ph V	3.60	%
619059	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Heaters (All) Functioning?	y	
619060	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	9 Month Operations	14	
619061	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Maintenance Operations	0	
619062	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	BCH000105	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
619063	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	BCH000105	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
619064	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	BCH000105	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
619065	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
619066	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	BCH000105	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	26.0	VDC
619067	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	BCH000105	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	26.0	VDC
619068	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	BCH000105	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.600	millivolts
619069	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
619070	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
619071	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
619072	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
619073	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
619074	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
619075	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
619076	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	General Comments		
619077	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Follow-up Action Required?	n	
619078	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	burnt trans buss	
619079	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Unknown Operations	0	
619080	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
619081	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
619082	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Follow-up Action Required?	n	
619083	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
619084	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
619085	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	General Comments		
619086	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
619087	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
619088	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
619089	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
619090	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
619091	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
619092	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
619093	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
619094	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
619095	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
619096	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	General Comments		
619097	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	General Comments		
619098	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
619099	1/15/2019 14:38	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
619100	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
619101	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC As Found Counter	48578	
619102	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC As Left Counter	48578	
619103	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
619104	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC Current Tap Position	2L	
619105	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
619106	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC Min Tap Position	4L	
619107	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Operations A Ø	0	
619108	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Operations B Ø	0	
619109	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
619110	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC Operations Since Last Insp	407	
619111	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
619112	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
619113	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
619114	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Operations Ground	0	
619115	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Operations C Ø	0	
619116	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
619117	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
619118	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
619119	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
619120	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Oil Temp Present	20	°C
619121	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Oil Temp Max	20	°C
619122	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
619123	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Follow-up Action Required?	n	
619124	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
619125	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	LTC Totalizer Reading	8395.20	kw
619126	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
619127	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Follow-up Action Required?	n	
619128	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Operations Ground	0	
619129	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Operations C Ø	0	
619130	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Operations B Ø	0	
619131	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Maintenance Operations	0	
619132	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Operations Counter AF	352	
619133	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
619134	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	General Comments		
619135	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Operations C Ø	0	
619136	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Operations B Ø	0	
619137	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Operations A Ø	0	
619138	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
619139	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
619140	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
619141	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Equipment Properly Labeled?	y	
619142	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Cabinet Paint Condition	Good	
619143	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
619144	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
619145	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
619146	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Bushings Connection/Risers	Good	
619147	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Bushing Condition	Good	
619148	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Amps C Ø	192.0	
619149	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Amps B Ø	219.0	
619150	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Amps A Ø	255.0	
619151	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
619152	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
619153	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Operations A Ø	0	
619154	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
619155	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
619156	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Operations B Ø	0	
619157	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
619158	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
619159	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
619160	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
619161	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
619162	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	FE000522	Fence	920-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
619163	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	FE000522	Fence	920-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
619164	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	FE000522	Fence	920-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
619165	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	FE000522	Fence	920-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
619166	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
619167	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
619168	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Winding Temp Present	25	°C
619169	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Winding Temp Max	25	°C
619170	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	FE000522	Fence	920-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
619171	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	FE000522	Fence	920-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
619172	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Totalizer Meter Reading	.5830	
619173	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
619174	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
619175	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
619176	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
619177	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	FE000522	Fence	920-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
619178	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	FE000522	Fence	920-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
619179	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	FE000522	Fence	920-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
619180	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	FE000522	Fence	920-Fence	Fence Patrol Inspection	General Comments		
619181	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	FE000522	Fence	920-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
619182	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Operations C Ø	0	
619183	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Operations Ground	0	
619184	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Follow-up Action Required?	n	
619185	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
619186	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Unknown Operations	0	
619187	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Tank Paint Condition	Good	
619188	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Switching Operations	0	
619189	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Operations Counter AL	182	
619190	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Operations Counter AF	182	
619191	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Moisture and Leak Free?	y	
619192	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Maintenance Operations	0	
619193	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Grounds in Place?	y	
619194	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	General Comments		
619195	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	General Comments		
619196	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Foundation Condition	Good	
619197	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
619198	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	General Comments		
619199	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Follow-up Action Required?	n	
619200	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
619201	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
619202	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Oil Temp Max	20	°C
619203	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Oil Temp Present	10	°C
619204	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
619205	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
619206	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
619207	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
619208	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Operations Ground	0	
619209	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
619210	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Equipment Properly Labeled?	y	
619211	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Cabinet Paint Condition	Good	
619212	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
619213	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
619214	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
619215	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
619216	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Follow-up Action Required?	n	
619217	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
619218	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	General Comments		
619219	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
619220	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
619221	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
619222	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Operations C Ø	0	
619223	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Operations B Ø	0	
619224	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Operations A Ø	0	
619225	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
619226	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
619227	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
619228	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
619229	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
619230	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
619231	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
619232	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
619233	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
619234	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
619235	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
619236	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
619237	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
619238	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
619239	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC Operations Since Last Insp	725	
619240	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
619241	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC Min Tap Position	2L	
619242	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC Max Tap Position	15L	
619243	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC Current Tap Position	5L	
619244	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
619245	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC As Left Counter	10090	
619246	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
619247	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
619248	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC As Found Counter	10086	
619249	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	General Comments		
619250	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	General Comments		
619251	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
619252	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	Follow-up Action Required?	n	
619253	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
619254	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Follow-up Action Required?	n	
619255	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
619256	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
619257	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
619258	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
619259	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
619260	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
619261	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	General Comments		
619262	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	General Comments		
619263	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
619264	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
619265	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
619266	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
619267	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
619268	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
619269	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
619270	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
619271	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
619272	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Bushing Condition	Good	
619273	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Amps C Ø	320.0	
619274	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Amps B Ø	320.0	
619275	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
619276	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
619277	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
619278	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
619279	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
619280	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
619281	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
619282	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
619283	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
619284	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
619285	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
619286	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
619287	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
619288	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Panels Dusted?	y	
619289	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
619290	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
619291	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	General Comments		
619292	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
619293	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
619294	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Floor Swept?	y	
619295	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
619296	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
619297	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Evidence of Insects	None	
619298	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
619299	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
619300	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
619301	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
619302	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
619303	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
619304	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
619305	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
619306	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
619307	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
619308	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
619309	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	General Comments		
619310	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	General Comments		
619311	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
619312	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
619313	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
619314	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Operations A Ø	0	
619315	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
619316	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
619317	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
619318	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	Follow-up Action Required?	n	
619319	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	480.0	
619320	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	460.0	
619321	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	470.0	
619322	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
619323	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
619324	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
619325	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
619326	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Switching Operations	0	
619327	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
619328	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Unknown Operations	0	
619329	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Grounds in Place?	y	
619330	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	General Comments		
619331	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
619332	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	General Comments		
619333	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
619334	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
619335	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
619336	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
619337	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
619338	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
619339	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
619340	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
619341	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
619342	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
619343	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
619344	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
619345	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
619346	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
619347	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
619348	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
619349	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
619350	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Foundation Condition	Good	
619351	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
619352	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Follow-up Action Required?	n	
619353	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
619354	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	LTC Totalizer Reading	7276.80	kw
619355	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
619356	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
619357	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
619358	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
619359	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
619360	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Foundation Condition	Good	
619361	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	General Comments		
619362	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	General Comments		
619363	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Grounds in Place?	y	
619364	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Heaters (All) Functioning?	y	
619365	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	LTC Totalizer Reading	20322.00	kw
619366	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
619367	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	General Comments		
619368	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Maintenance Operations	0	
619369	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Moisture and Leak Free?	y	
619370	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Operations Counter AF	65	
619371	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
619372	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
619373	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
619374	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC Operations Since Last Insp	210	
619375	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC Min Tap Position	10L	
619376	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
619377	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC Current Tap Position	6L	
619378	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
619379	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC As Left Counter	35261	
619380	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC As Found Counter	35254	
619381	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Operations Counter AL	65	
619382	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
619383	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
619384	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Operations Counter AF	229	
619385	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Operations Counter AL	229	
619386	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
619387	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Switching Operations	0	
619388	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Tank Paint Condition	Good	
619389	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Unknown Operations	0	
619390	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Switching Operations	0	
619391	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Tank Paint Condition	Good	
619392	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Unknown Operations	0	
619393	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.34	%
619394	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
619395	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
619396	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
619397	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
619398	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	General Comments		
619399	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
619400	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	General Comments		
619401	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	General Comments		
619402	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.34	%
619403	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	200.0	
619404	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	200.0	
619405	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	160.0	
619406	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
619407	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
619408	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Follow-up Action Required?	n	
619409	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
619410	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
619411	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
619412	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
619413	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
619414	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
619415	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Unknown Operations	0	
619416	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Tank Paint Condition	Good	
619417	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Switching Operations	0	
619418	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Operations Counter AL	163	
619419	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Operations Counter AF	163	
619420	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Moisture and Leak Free?	y	
619421	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Maintenance Operations	0	
619422	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Heaters (All) Functioning?	y	
619423	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Grounds in Place?	y	
619424	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	General Comments		
619425	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	General Comments		
619426	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
619427	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Follow-up Action Required?	n	
619428	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Follow-up Action Required?	n	
619429	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Operations Ground	0	
619430	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Operations C Ø	0	
619431	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
619432	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
619433	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	LTC Totalizer Reading	15960.00	kw
619434	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
619435	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
619436	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Oil Temp Max	65	°C
619437	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Oil Temp Present	30	°C
619438	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
619439	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	35	
619440	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	35	
619441	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
619442	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	0	
619443	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
619444	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
619445	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
619446	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	640.0	
619447	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	600.0	
619448	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	640.0	
619449	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
619450	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
619451	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
619452	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
619453	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
619454	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
619455	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
619456	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
619457	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
619458	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
619459	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
619460	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Winding Temp Present	28	°C
619461	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Winding Temp Max	58	°C
619462	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Totalizer Meter Reading	1.1290	
619463	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
619464	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
619465	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
619466	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
619467	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
619468	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
619469	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
619470	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
619471	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
619472	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
619473	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
619474	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
619475	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
619476	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
619477	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
619478	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
619479	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
619480	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
619481	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
619482	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	50	
619483	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	50	
619484	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
619485	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
619486	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
619487	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
619488	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
619489	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
619490	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
619491	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
619492	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
619493	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
619494	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
619495	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
619496	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
619497	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
619498	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
619499	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
619500	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Oil Temp Present	20	°C
619501	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
619502	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
619503	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
619504	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Oil Temp Max	60	°C
619505	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
619506	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
619507	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
619508	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
619509	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Maintenance Operations	0	
619510	1/15/2019 10:24	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
619511	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
619512	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
619513	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
619514	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
619515	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
619516	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
619517	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
619518	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCC000246	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
619519	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCC000246	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
619520	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCC000246	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
619521	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCC000246	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
619522	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCC000246	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
619523	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
619524	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
619525	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
619526	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCC000246	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
619527	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCC000246	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
619528	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
619529	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
619530	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
619531	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
619532	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
619533	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
619534	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	General Comments		
619535	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
619536	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
619537	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
619538	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
619539	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
619540	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
619541	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
619542	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
619543	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
619544	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
619545	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
619546	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCC000246	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
619547	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
619548	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
619549	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
619550	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
619551	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
619552	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
619553	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
619554	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
619555	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
619556	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
619557	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
619558	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Panels Dusted?	y	
619559	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
619560	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
619561	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Clear of Trash?	y	
619562	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	General Comments		
619563	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
619564	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	150.0	
619565	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	180.0	
619566	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	190.0	
619567	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
619568	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Floor Swept?	y	
619569	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
619570	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
619571	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Evidence of Insects	None	
619572	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
619573	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
619574	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Operations A Ø	0	
619575	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Operations B Ø	0	
619576	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
619577	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
619578	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
619579	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	n	If Bkr is Closed
619580	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Operations Ground	0	
619581	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Follow-up Action Required?	n	
619582	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Follow-up Action Required?	n	
619583	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Foundation Condition	Good	
619584	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	General Comments		
619585	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	General Comments	should have been 229 at last quarter check	
619586	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Grounds in Place?	y	
619587	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Ambient Temp	29	°F
619588	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
619589	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Readings	Follow-up Action Required?	y	
619590	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Foundation Condition	Good	
619591	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
619592	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	General Comments	BREAKER NOT IN LOT	
619593	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Readings	General Comments	BREAKER NOT IN LOT	
619594	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Grounds in Place?	y	
619595	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
619596	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Hydraulic Leaks	None	
619597	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Hydraulic Oil Levels OK?	y	
619598	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Hydraulic Pressure Acceptable?	y	
619599	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Readings	Maintenance Operations	0	
619600	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
619601	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	9 Month Operations	5	
619602	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Floor Swept?	y	
619603	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
619604	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Readings	Num Operations Last 9 Months	0	
619605	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Readings	Operations Counter AF	0	
619606	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Readings	Operations Counter AL	0	
619607	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	VRR Time Delay	30	Seconds
619608	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
619609	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
619610	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
619611	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	LTC Operation Checked?	y	
619612	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	General Comments		
619613	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	Follow-up Action Required?	n	
619614	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	All Connections OK?	y	
619615	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	n	
619616	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Evidence of Insects	None	
619617	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
619618	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
619619	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
619620	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Pre-Charge Pressure Correct?	y	
619621	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
619622	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
619623	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	General Comments		
619624	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Pressure Vessel Condition	Good	
619625	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
619626	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	SF6 Compressor Belt Condition	Good	
619627	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
619628	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
619629	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	SF6 Compressor Heater Cond.	good	
619630	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	SF6 Compressor Hours	0.00	hrs
619631	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	SF6 Compressor Hours Pole 1	0.00	hrs
619632	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
619633	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
619634	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
619635	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	SF6 Compressor Hours Pole 2	0.00	hrs
619636	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	SF6 Compressor Hours Pole 3	0.00	hrs
619637	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	SF6 Compressor Oil Level OK?	y	
619638	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
619639	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
619640	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Readings	Switching Operations	0	
619641	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Tank Paint Condition	Good	
619642	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	BK001038	BreakerSF6	828-608	GCB Readings	Unknown Operations	0	
619643	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
619644	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
619645	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
619646	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
619647	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
619648	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
619649	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
619650	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
619651	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly I	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
619652	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
619653	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
619654	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
619655	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Vegetation	None	
619656	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
619657	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	General Comments		
619658	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
619659	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
619660	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
619661	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
619662	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
619663	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
619664	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Grounds in Place?	y	
619665	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Heaters (All) Functioning?	y	
619666	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
619667	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
619668	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
619669	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	2	
619670	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	15.59	%
619671	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
619672	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	15.59	%
619673	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
619674	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
619675	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
619676	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
619677	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
619678	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	General Comments		
619679	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
619680	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
619681	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
619682	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
619683	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
619684	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
619685	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
619686	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
619687	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
619688	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Operations Counter AL	390	
619689	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
619690	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Switching Operations	0	
619691	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Tank Paint Condition	Good	
619692	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Unknown Operations	0	
619693	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	3.74	%
619694	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Operations C Ø	0	
619695	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Operations Ground	0	
619696	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
619697	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
619698	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
619699	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
619700	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
619701	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
619702	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Follow-up Action Required?	n	
619703	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
619704	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
619705	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	120.0	volts
619706	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
619707	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
619708	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
619709	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
619710	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
619711	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
619712	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
619713	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
619714	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
619715	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	15.59	%
619716	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
619717	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
619718	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
619719	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
619720	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
619721	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
619722	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
619723	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
619724	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Regulator As Left Counter	53613	
619725	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
619726	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
619727	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Tank Leaks	None	
619728	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
619729	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
619730	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
619731	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
619732	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
619733	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
619734	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
619735	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	89	
619736	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	89	
619737	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
619738	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
619739	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
619740	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	115.00	
619741	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
619742	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
619743	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Operations B Ø	0	
619744	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
619745	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
619746	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCC000246	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
619747	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Readings	9 Month Operations	0	
619748	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Follow-up Action Required?	n	
619749	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
619750	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
619751	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Readings	Maintenance Operations	0	
619752	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Moisture and Leak Free?	y	
619753	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
619754	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
619755	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
619756	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
619757	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
619758	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
619759	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
619760	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
619761	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
619762	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
619763	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Readings	Operations Counter AF	99773	
619764	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Readings	Operations Counter AL	99773	
619765	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
619766	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Readings	Switching Operations	0	
619767	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Tank Paint Condition	Good	
619768	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0054	BreakerVacuum	662-0109	VCB Readings	Unknown Operations	0	
619769	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Readings	Amps A Ø	480.0	
619770	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Readings	Amps B Ø	500.0	
619771	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Readings	Amps C Ø	400.0	
619772	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
619773	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
619774	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
619775	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
619776	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
619777	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
619778	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
619779	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Bushing Condition	Good	
619780	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
619781	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
619782	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
619783	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
619784	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
619785	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
619786	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
619787	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
619788	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
619789	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
619790	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC Operations Since Last Insp	460	
619791	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC Min Tap Position	13L	
619792	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Operations B Ø	0	
619793	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
619794	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC Max Tap Position	1L	
619795	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
619796	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
619797	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
619798	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	General Comments		
619799	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
619800	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
619801	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
619802	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Operations Ground	0	
619803	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Follow-up Action Required?	n	
619804	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	General Comments		
619805	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Maintenance Operations	0	
619806	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC Current Tap Position	9L	
619807	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
619808	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC As Left Counter	114907	
619809	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Operations Counter AF	456	
619810	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Operations Counter AL	456	
619811	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC As Found Counter	114900	
619812	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	General Comments		
619813	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	General Comments		
619814	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
619815	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	Follow-up Action Required?	n	
619816	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Operations Counter AF	390	
619817	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
619818	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Maintenance Operations	0	
619819	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
619820	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
619821	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
619822	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly T	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
619823	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC Current Tap Position	6L	
619824	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
619825	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC As Left Counter	149724	
619826	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC As Found Counter	149721	
619827	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	General Comments		
619828	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	General Comments		
619829	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
619830	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	Follow-up Action Required?	n	
619831	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Bushings Connection/Risers	Good	
619832	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	Follow-up Action Required?	n	
619833	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
619834	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	General Comments		
619835	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	General Comments		
619836	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
619837	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Bushing Condition	Good	
619838	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Amps C Ø	270.0	
619839	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Amps B Ø	270.0	
619840	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
619841	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Operations C Ø	0	
619842	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Operations Ground	0	
619843	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Follow-up Action Required?	n	
619844	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Follow-up Action Required?	n	
619845	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Foundation Condition	Good	
619846	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
619847	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
619848	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
619849	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
619850	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
619851	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Amps A Ø	320.0	
619852	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
619853	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
619854	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
619855	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
619856	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
619857	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
619858	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
619859	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
619860	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
619861	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
619862	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
619863	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
619864	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
619865	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Follow-up Action Required?	n	
619866	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
619867	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
619868	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
619869	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
619870	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	9 Month Operations	0	
619871	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
619872	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
619873	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	VRR Time Delay	30	Seconds
619874	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
619875	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
619876	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	LTC Output Voltage Level	124.4	VAC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
619877	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
619878	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Vegetation	None	
619879	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
619880	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
619881	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
619882	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
619883	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
619884	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
619885	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
619886	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
619887	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
619888	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
619889	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
619890	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
619891	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
619892	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
619893	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
619894	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
619895	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
619896	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
619897	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	General Comments		
619898	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	General Comments		
619899	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
619900	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
619901	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
619902	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
619903	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
619904	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
619905	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2666.88	kw
619906	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
619907	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
619908	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
619909	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
619910	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
619911	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
619912	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
619913	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC Operations Since Last Insp	487	
619914	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
619915	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
619916	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC Min Tap Position	Neutral	
619917	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
619918	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC Max Tap Position	14L	
619919	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	9 Month Operations	5	
619920	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
619921	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
619922	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
619923	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Amps A Ø	750.0	
619924	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Amps B Ø	650.0	
619925	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Amps C Ø	646.0	
619926	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Bushing Condition	Good	
619927	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
619928	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
619929	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
619930	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
619931	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
619932	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
619933	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
619934	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
619935	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
619936	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Operations A Ø	0	
619937	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Operations B Ø	0	
619938	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Operations C Ø	0	
619939	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Operations Ground	0	
619940	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Follow-up Action Required?	n	
619941	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Follow-up Action Required?	n	
619942	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Foundation Condition	Good	
619943	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	General Comments		
619944	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	General Comments		
619945	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
619946	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
619947	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Operations A Ø	0	
619948	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Operations B Ø	0	
619949	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Grounds in Place?	y	
619950	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
619951	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Maintenance Operations	3	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
619952	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
619953	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Operations Counter AF	206	
619954	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Operations Counter AL	206	
619955	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Switching Operations	1	
619956	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Tank Paint Condition	Good	
619957	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Unknown Operations	0	
619958	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
619959	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Foundation Condition	Good	
619960	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
619961	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
619962	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	All Connections OK?	y	
619963	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	Follow-up Action Required?	n	
619964	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	General Comments		
619965	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	LTC Operation Checked?	y	
619966	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
619967	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Clear of Trash?	y	
619968	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
619969	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
619970	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
619971	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
619972	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
619973	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
619974	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
619975	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
619976	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
619977	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
619978	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	VRR Time Delay	30	Seconds
619979	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
619980	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
619981	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	LTCC000665	LTCControl	662-1	LTC Control Insp	VRR Time Delay	30	Seconds
619982	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	LTCC000665	LTCControl	662-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
619983	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	LTCC000665	LTCControl	662-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
619984	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	LTCC000665	LTCControl	662-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
619985	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	LTCC000665	LTCControl	662-1	LTC Control Insp	LTC Operation Checked?	y	
619986	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	LTCC000665	LTCControl	662-1	LTC Control Insp	General Comments		
619987	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	LTCC000665	LTCControl	662-1	LTC Control Insp	Follow-up Action Required?	n	
619988	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	LTCC000665	LTCControl	662-1	LTC Control Insp	All Connections OK?	y	
619989	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
619990	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
619991	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
619992	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	General Comments		
619993	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
619994	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
619995	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
619996	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
619997	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
619998	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Unknown Operations	0	
619999	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Switching Operations	0	
620000	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Operations Counter AL	192	
620001	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Operations Counter AF	192	
620002	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Maintenance Operations	0	
620003	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	352	
620004	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
620005	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
620006	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
620007	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
620008	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
620009	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
620010	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
620011	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
620012	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
620013	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
620014	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
620015	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
620016	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
620017	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
620018	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
620019	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
620020	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	General Comments		
620021	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Follow-up Action Required?	n	
620022	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
620023	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
620024	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
620025	1/15/2019 12:37	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
620026	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
620027	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	General Comments		
620028	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
620029	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
620030	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Foundation Condition	Good	
620031	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
620032	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Fault Operations A Ø	0	
620033	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
620034	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
620035	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
620036	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Totalizer Meter Reading	2.2224	
620037	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
620038	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
620039	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
620040	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
620041	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	General Comments		
620042	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
620043	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC As Found Counter	14260	
620044	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC As Left Counter	14260	
620045	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
620046	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC Current Tap Position	2L	
620047	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC Max Tap Position	1R	
620048	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC Min Tap Position	5L	
620049	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	34	°C
620050	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	11	°C
620051	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC Operations Since Last Insp	550	
620052	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
620053	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
620054	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
620055	1/15/2019 11:34	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
620056	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
620057	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
620058	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
620059	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
620060	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	LTC Operation Checked?	y	
620061	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	General Comments		
620062	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	Follow-up Action Required?	n	
620063	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	All Connections OK?	y	
620064	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Fault Operations B Ø	0	
620065	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Fault Operations C Ø	0	
620066	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Fault Operations Ground	0	
620067	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
620068	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
620069	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
620070	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
620071	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
620072	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
620073	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
620074	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
620075	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
620076	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
620077	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
620078	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
620079	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
620080	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Amps A Ø	270.0	
620081	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	258	
620082	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	258	
620083	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
620084	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
620085	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
620086	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
620087	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
620088	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
620089	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
620090	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
620091	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
620092	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
620093	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	General Comments		
620094	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
620095	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
620096	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
620097	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
620098	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Operations B Ø	0	
620099	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Operations A Ø	0	
620100	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
620101	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
620102	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
620103	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
620104	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
620105	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Equipment Properly Labeled?	y	
620106	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Cabinet Paint Condition	Good	
620107	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
620108	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
620109	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
620110	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Bushings Connection/Risers	Good	
620111	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Bushing Condition	Good	
620112	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Amps C Ø	10.0	
620113	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Amps B Ø	10.0	
620114	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Amps A Ø	10.0	
620115	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
620116	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
620117	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
620118	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	9 Month Operations	4	
620119	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
620120	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
620121	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
620122	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
620123	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
620124	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
620125	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
620126	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
620127	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
620128	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
620129	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
620130	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
620131	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
620132	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
620133	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	General Comments		
620134	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
620135	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
620136	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Foundation Condition	Good	
620137	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
620138	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
620139	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
620140	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
620141	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
620142	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
620143	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
620144	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
620145	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	201	
620146	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	201	
620147	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
620148	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
620149	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
620150	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
620151	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	9 Months Operations	1	
620152	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
620153	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
620154	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
620155	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
620156	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Amps A Ø	200.0	
620157	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Amps B Ø	200.0	
620158	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
620159	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
620160	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
620161	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
620162	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
620163	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
620164	1/15/2019 10:14	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
620165	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
620166	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
620167	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
620168	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
620169	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
620170	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
620171	1/15/2019 12:06	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	Follow-up Action Required?	n	
620172	1/15/2019 9:38	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
620173	1/15/2019 15:08	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
620174	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
620175	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
620176	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
620177	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
620178	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
620179	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
620180	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
620181	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
620182	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	592	
620183	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	592	
620184	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
620185	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Totalizer Meter Multiplier	14000	
620186	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
620187	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
620188	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
620189	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
620190	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
620191	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
620192	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
620193	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
620194	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
620195	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
620196	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
620197	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
620198	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
620199	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
620200	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Foundation Condition	Good	
620201	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
620202	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
620203	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	General Comments		
620204	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
620205	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
620206	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
620207	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
620208	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
620209	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
620210	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
620211	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
620212	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
620213	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
620214	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
620215	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
620216	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
620217	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
620218	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
620219	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Totalizer Meter Reading	1.1400	
620220	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Winding Temp Max	65	°C
620221	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Winding Temp Present	30	°C
620222	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
620223	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
620224	1/15/2019 15:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
620225	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
620226	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
620227	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
620228	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
620229	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
620230	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
620231	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
620232	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
620233	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
620234	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
620235	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
620236	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
620237	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
620238	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.46	%
620239	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.46	%
620240	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	20	
620241	1/15/2019 11:56	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
620242	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
620243	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.46	%
620244	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
620245	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
620246	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
620247	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
620248	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	200.0	
620249	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
620250	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
620251	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
620252	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
620253	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
620254	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Amps C Ø	200.0	
620255	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
620256	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	275.0	
620257	1/15/2019 13:26	Distribution	Lexington Water Company Quarterly Inspec	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	400.0	
620258	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0	
620259	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	General Comments		
620260	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
620261	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
620262	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
620263	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	900.0	
620264	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	900.0	
620265	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
620266	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
620267	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
620268	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
620269	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
620270	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Panels Dusted?	y	
620271	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
620272	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Tank Leaks	None	
620273	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
620274	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	General Comments		
620275	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0	
620276	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
620277	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
620278	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
620279	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
620280	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	22	°C
620281	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
620282	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
620283	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
620284	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
620285	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
620286	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Tank Leaks	None	
620287	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Tank 3 Oil Level	Good	
620288	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
620289	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Switching Operations	2	
620290	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Foundation Condition	Good	
620291	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
620292	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
620293	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
620294	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
620295	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
620296	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
620297	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
620298	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
620299	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
620300	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	General Comments		
620301	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	900.0	
620302	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
620303	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
620304	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Bushing Condition	Good	
620305	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	General Comments		
620306	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
620307	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
620308	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
620309	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
620310	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Operations Ground	0	
620311	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Bushing Oil Level	Good	
620312	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
620313	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
620314	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
620315	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
620316	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	240.0	
620317	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
620318	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
620319	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.40	%
620320	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Unknown Operations	0	
620321	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Follow-up Action Required?	n	
620322	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Follow-up Action Required?	n	
620323	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Tank Paint Condition	Good	
620324	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	14	
620325	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
620326	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
620327	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	VRR Time Delay	30	Seconds
620328	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BCH000519	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
620329	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BCH000519	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
620330	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BCH000519	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
620331	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BCH000519	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
620332	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BCH000519	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
620333	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BCH000519	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
620334	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
620335	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.62	%
620336	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Tank Leaks	None	
620337	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
620338	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
620339	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
620340	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0	
620341	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
620342	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
620343	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
620344	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
620345	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
620346	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
620347	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
620348	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
620349	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
620350	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
620351	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
620352	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Air Leaks	None	
620353	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Air Pressure OK?	y	
620354	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
620355	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
620356	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0	
620357	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0	
620358	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0	
620359	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
620360	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
620361	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
620362	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
620363	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Amps A Ø	25.0	
620364	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Amps B Ø	25.0	
620365	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC Current Tap Position	18R	
620366	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
620367	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.46	%
620368	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.46	%
620369	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.46	%
620370	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
620371	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
620372	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Air Leaks	None	
620373	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
620374	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
620375	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
620376	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
620377	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.62	%
620378	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.62	%
620379	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120	
620380	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120	
620381	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
620382	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
620383	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
620384	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
620385	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC As Left Counter	14895	
620386	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	General Comments		
620387	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	General Comments	needs 2 desicant filters ontop of LTC	
620388	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC As Found Counter	14895	
620389	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Operations Counter AL	94	
620390	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
620391	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
620392	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Grounds in Place?	y	
620393	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Tank 1 Oil Level	Good	
620394	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Tank 2 Oil level	Good	
620395	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
620396	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Amps C Ø	25.0	
620397	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
620398	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
620399	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
620400	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Floor Swept?	y	
620401	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Tank 1 Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
620402	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Tank 2 Oil level	Good	
620403	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Tank 3 Oil Level	Good	
620404	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Foundation Condition	Good	
620405	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	General Comments		
620406	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	General Comments		
620407	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Grounds in Place?	y	
620408	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
620409	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
620410	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
620411	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
620412	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
620413	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
620414	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
620415	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Winding Temp Present	30	°C
620416	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
620417	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Foundation Condition	Good	
620418	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
620419	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
620420	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
620421	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Patrol Inspection	General Comments		
620422	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
620423	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	General Comments		
620424	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
620425	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
620426	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
620427	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	LTC Totalizer Reading	21888.00	kw
620428	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
620429	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
620430	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Oil Temp Max	40	°C
620431	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Oil Temp Present	30	°C
620432	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
620433	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
620434	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
620435	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
620436	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC Max Tap Position	23R	
620437	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
620438	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC Min Tap Position	17R	
620439	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	81	
620440	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Radiator Leaks	None	
620441	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
620442	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
620443	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	9 Months Operations	2	
620444	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
620445	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
620446	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
620447	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
620448	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
620449	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Operations Counter AL	3243	
620450	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Operations Counter AF	3243	
620451	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
620452	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
620453	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
620454	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Fault Operations	0	
620455	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
620456	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
620457	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
620458	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
620459	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	4R	
620460	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
620461	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
620462	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
620463	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Equipment Properly Labeled?	y	
620464	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
620465	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
620466	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
620467	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Amps B Ø	463.0	
620468	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
620469	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
620470	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Follow-up Action Required?	n	
620471	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Operations Counter AF	1163	
620472	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Operations Counter AL	1163	
620473	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
620474	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Switching Operations	1	
620475	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
620476	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
620477	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	8R	
620478	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	4L	
620479	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
620480	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
620481	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
620482	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
620483	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Number of Ops last 9 Months	4	
620484	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
620485	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
620486	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Maintenance Operations	0	
620487	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Grounds in Place?	y	
620488	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
620489	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
620490	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
620491	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
620492	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
620493	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
620494	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	22	°C
620495	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	201762	
620496	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
620497	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
620498	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Patrol Inspection	General Comments		
620499	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
620500	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Amps A Ø	426.0	
620501	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
620502	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
620503	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Grounds in Place?	y	
620504	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
620505	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
620506	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	General Comments		
620507	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
620508	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
620509	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	°C
620510	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
620511	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	32	°F
620512	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Number of Ops last 9 Months	1	
620513	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
620514	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
620515	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	9 Month Operations	4	
620516	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
620517	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
620518	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
620519	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
620520	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	LTC Operation Checked?	y	
620521	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	General Comments		
620522	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
620523	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
620524	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
620525	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Evidence of Insects	None	
620526	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	Follow-up Action Required?	n	
620527	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	All Connections OK?	y	
620528	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
620529	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
620530	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
620531	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120	
620532	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
620533	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
620534	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
620535	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
620536	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
620537	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
620538	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Tank Leaks	None	
620539	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Tank 3 Oil Level	Good	
620540	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
620541	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	9 Month Operations	2	
620542	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
620543	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
620544	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Broom on Site?	y	
620545	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
620546	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
620547	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
620548	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	General Comments		
620549	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Grounds in Place?	y	
620550	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	General Comments		
620551	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
620552	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Amps A Ø	454.0	
620553	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
620554	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
620555	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
620556	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
620557	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Foundation Condition	Good	
620558	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Follow-up Action Required?	n	
620559	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Equipment Properly Labeled?	y	
620560	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
620561	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
620562	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
620563	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
620564	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Operations Counter AF	18	
620565	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Operations Counter AL	18	
620566	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
620567	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
620568	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
620569	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Switching Operations	0	
620570	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Unknown Operations	0	
620571	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
620572	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Totalizer Meter Reading	.9120	
620573	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
620574	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Winding Temp Max	40	°C
620575	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
620576	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
620577	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
620578	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Equipment Properly Labeled?	y	
620579	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
620580	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Follow-up Action Required?	n	
620581	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Trash Emptied?	y	
620582	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
620583	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
620584	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
620585	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
620586	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	General Comments		
620587	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
620588	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	General Comments		
620589	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
620590	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
620591	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
620592	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Amps C Ø	463.0	
620593	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
620594	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
620595	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
620596	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
620597	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
620598	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
620599	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
620600	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
620601	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
620602	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Bushing Condition	Good	
620603	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
620604	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Switching Operations	0	
620605	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
620606	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
620607	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
620608	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
620609	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	870	
620610	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	870	
620611	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
620612	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
620613	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Tank Leaks	None	
620614	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
620615	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Follow-up Action Required?	n	
620616	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
620617	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Amps B Ø	462.0	
620618	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
620619	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
620620	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Amps C Ø	417.0	
620621	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
620622	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	General Comments		
620623	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
620624	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
620625	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
620626	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
620627	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Maintenance Operations	0	
620628	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Operations Counter AF	94	
620629	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Maintenance Operations	0	
620630	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Tank 2 Oil level	Good	
620631	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Tank 1 Oil Level	Good	
620632	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Grounds in Place?	y	
620633	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	General Comments		
620634	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Foundation Condition	Good	
620635	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
620636	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	22	°C
620637	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
620638	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	General Comments		
620639	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
620640	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Number of Ops last 9 Months	2	
620641	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Operations Counter AF	1306	
620642	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Operations Counter AL	1306	
620643	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Maintenance Operations	0	
620644	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Operations Counter AF	142	
620645	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
620646	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Switching Operations	1	
620647	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
620648	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
620649	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
620650	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
620651	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
620652	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
620653	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
620654	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
620655	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
620656	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Operations Counter AL	142	
620657	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
620658	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
620659	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
620660	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
620661	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
620662	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Switching Operations	1	
620663	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Unknown Operations	0	
620664	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
620665	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
620666	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
620667	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
620668	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Patrol Inspection	General Comments		
620669	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	General Comments		
620670	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Maintenance Operations	0	
620671	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Operations Counter AL	295	
620672	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Operations Counter AF	295	
620673	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
620674	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Maintenance Operations	0	
620675	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	General Comments		
620676	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Patrol Inspection	General Comments		
620677	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
620678	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
620679	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Operations A Ø	0	
620680	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Operations B Ø	0	
620681	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
620682	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
620683	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
620684	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
620685	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
620686	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
620687	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	General Comments		
620688	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	General Comments		
620689	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
620690	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
620691	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
620692	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	115.00	
620693	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
620694	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	Oil Temp Max	60	°C
620695	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	Oil Temp Present	30	°C
620696	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
620697	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Foundation Condition	Good	
620698	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	General Comments		
620699	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Grounds in Place?	y	
620700	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
620701	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
620702	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
620703	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Operations C Ø	0	
620704	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Operations Ground	0	
620705	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Follow-up Action Required?	n	
620706	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Follow-up Action Required?	n	
620707	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Foundation Condition	Good	
620708	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Amps C Ø	0.0	
620709	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
620710	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Amps A Ø	25.0	
620711	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Amps B Ø	25.0	
620712	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	PF000305	PowerFuse	SY-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
620713	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	PF000305	PowerFuse	SY-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
620714	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	PF000304	PowerFuse	SY-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
620715	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Bushing Condition	Good	
620716	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Bushing Oil Level	Good	
620717	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
620718	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
620719	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
620720	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
620721	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	PF000304	PowerFuse	SY-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
620722	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
620723	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Bushing Oil Level	Good	
620724	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
620725	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
620726	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
620727	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
620728	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
620729	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
620730	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
620731	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Follow-up Action Required?	n	
620732	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Patrol Inspection	Follow-up Action Required?	n	
620733	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
620734	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
620735	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
620736	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
620737	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
620738	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
620739	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	General Comments		
620740	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
620741	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Operations Ground	0	
620742	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Operations C Ø	0	
620743	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Operations B Ø	0	
620744	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Operations A Ø	0	
620745	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
620746	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	9 Month Operations	34	
620747	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	PF000024	PowerFuse	AS-GND TR 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
620748	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	PF000024	PowerFuse	AS-GND TR 3	Disconnect Powerfuse Inspection	General Comments	ok	
620749	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
620750	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
620751	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
620752	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
620753	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Vegetation	None	
620754	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
620755	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
620756	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
620757	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
620758	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
620759	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
620760	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
620761	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
620762	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
620763	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
620764	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	General Comments		
620765	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
620766	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
620767	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
620768	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
620769	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
620770	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
620771	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Clear of Trash?	y	
620772	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
620773	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
620774	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
620775	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Air Leaks	None	
620776	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Air Pressure OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
620777	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Air Tank Bleed (> 40"F)?	y	
620778	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Number of Ops last 9 Months	18	
620779	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Tank Leaks	None	
620780	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Tank 3 Oil Level	Good	
620781	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
620782	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Amps A Ø	0.0	
620783	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	9 Month Operations	3	
620784	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Amps B Ø	260.0	
620785	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Amps A Ø	240.0	
620786	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Accumulated Fault Duty C Ph V	.91	%
620787	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Unknown Operations	0	
620788	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
620789	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
620790	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
620791	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Amps A Ø	6.0	
620792	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Amps B Ø	6.0	
620793	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Amps C Ø	7.0	
620794	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Tank Paint Condition	Good	
620795	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Tank Leaks	None	
620796	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
620797	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
620798	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Air Pressure OK?	y	
620799	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Bushing Condition	Good	
620800	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Bushings Connection/Risers	Good	
620801	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
620802	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
620803	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Accumulated Fault Duty B Ph V	.91	%
620804	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Accumulated Fault Duty A Ph V	.91	%
620805	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	9 Month Operations	4	
620806	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
620807	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Cabinet Paint Condition	Good	
620808	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Amps A Ø	25.0	
620809	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
620810	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Equipment Properly Labeled?	y	
620811	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Amps B Ø	25.0	
620812	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Amps C Ø	25.0	
620813	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Bushing Condition	Good	
620814	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
620815	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
620816	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Follow-up Action Required?	n	
620817	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Amps B Ø	0.0	
620818	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Equipment Properly Labeled?	y	
620819	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
620820	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Unknown Operations	0	
620821	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Switching Operations	0	
620822	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Switching Operations	1	
620823	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Operations Counter AL	1156	
620824	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Operations Counter AF	1156	
620825	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Number of Ops last 9 Months	1	
620826	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
620827	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Maintenance Operations	0	
620828	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Grounds in Place?	y	
620829	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Foundation Condition	Good	
620830	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Follow-up Action Required?	n	
620831	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
620832	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	General Comments		
620833	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	General Comments		
620834	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Foundation Condition	Good	
620835	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Amps C Ø	25.0	
620836	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Bushing Condition	Good	
620837	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Bushing Oil Level	Good	
620838	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
620839	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
620840	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
620841	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
620842	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
620843	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
620844	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	LTCC000257	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
620845	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	LTCC000257	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
620846	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	LTCC000257	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
620847	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	LTCC000257	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
620848	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	LTCC000257	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
620849	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Fault Operations	0	
620850	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Follow-up Action Required?	n	
620851	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
620852	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Follow-up Action Required?	n	
620853	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	LTCC000257	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
620854	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	LTCC000257	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
620855	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	LTCC000257	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
620856	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
620857	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000285	PowerFuse	P-14KV TR 3-B POT	Disconnect Powerfuse Inspection	General Comments	OK	
620858	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000285	PowerFuse	P-14KV TR 3-B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
620859	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Foundation Condition	Good	
620860	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
620861	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	General Comments		
620862	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
620863	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	General Comments		
620864	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Grounds in Place?	y	
620865	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Maintenance Operations	0	
620866	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
620867	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Number of Ops last 9 Months	27	
620868	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Follow-up Action Required?	n	
620869	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Follow-up Action Required?	n	
620870	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Fault Operations	0	
620871	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
620872	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
620873	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
620874	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
620875	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
620876	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
620877	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Bushing Oil Level	Good	
620878	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Bushing Condition	Good	
620879	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Amps C Ø	369.0	
620880	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Amps B Ø	374.0	
620881	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Amps A Ø	367.0	
620882	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
620883	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Tank Leaks	None	
620884	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
620885	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
620886	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Regulator As Left Counter	41134	
620887	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Operations Counter AF	6231	
620888	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
620889	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
620890	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
620891	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
620892	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
620893	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
620894	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Min Tap Position	7L	
620895	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Max Tap Position	3R	
620896	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
620897	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	General Comments		
620898	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
620899	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
620900	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
620901	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Amps C Ø	500.0	
620902	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Amps B Ø	430.0	
620903	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Amps A Ø	460.0	
620904	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
620905	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
620906	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
620907	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
620908	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Fault Operations	0	
620909	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Follow-up Action Required?	n	
620910	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Follow-up Action Required?	n	
620911	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Foundation Condition	Good	
620912	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
620913	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	General Comments		
620914	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	General Comments		
620915	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Grounds in Place?	y	
620916	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Broom on Site?	y	
620917	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
620918	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
620919	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Maintenance Operations	0	
620920	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
620921	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Number of Ops last 9 Months	6	
620922	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
620923	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
620924	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
620925	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Follow-up Action Required?	n	
620926	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
620927	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	General Comments		
620928	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Grounds in Place?	y	
620929	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Heaters (All) Functioning?	y	
620930	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Maintenance Operations	0	
620931	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Moisture and Leak Free?	y	
620932	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Operations Counter AF	187	
620933	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Operations Counter AL	187	
620934	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
620935	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Switching Operations	0	
620936	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
620937	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
620938	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	General Comments		
620939	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Accumulated Fault Duty C Ph AM	19.93	%
620940	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Accumulated Fault Duty B Ph AM	23.92	%
620941	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Accumulated Fault Duty A Ph AM	19.93	%
620942	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	9 Months Operations	18	
620943	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Operations Counter AF	1927	
620944	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Operations Counter AL	1927	
620945	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Switching Operations	0	
620946	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
620947	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
620948	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
620949	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Tank Leaks	None	
620950	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Tank Paint Condition	Good	
620951	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Unknown Operations	0	
620952	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Amps A Ø	0.0	
620953	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Amps B Ø	0.0	
620954	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Amps C Ø	0.0	
620955	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Bushing Condition	Good	
620956	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Bushing Oil Level	Good	
620957	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
620958	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
620959	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
620960	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
620961	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
620962	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
620963	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Tank 1 Oil Level	Good	
620964	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Tank 2 Oil level	Good	
620965	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Tank 3 Oil Level	Good	
620966	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Tank Leaks	None	
620967	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Tank Paint Condition	Good	
620968	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Unknown Operations	0	
620969	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Tank 2 Oil level	Good	
620970	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Tank 1 Oil Level	Good	
620971	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Grounds in Place?	y	
620972	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	General Comments		
620973	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
620974	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Follow-up Action Required?	n	
620975	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Fault Operations	0	
620976	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
620977	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
620978	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
620979	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
620980	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
620981	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
620982	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Bushing Oil Level	Good	
620983	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Bushing Condition	Good	
620984	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Amps C Ø	110.0	
620985	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Amps B Ø	114.0	
620986	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
620987	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
620988	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
620989	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
620990	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	General Comments		
620991	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Follow-up Action Required?	n	
620992	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Operations Ground	0	
620993	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Operations C Ø	0	
620994	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Operations B Ø	0	
620995	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Operations A Ø	0	
620996	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
620997	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
620998	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
620999	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
621000	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
621001	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
621002	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
621003	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
621004	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
621005	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
621006	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
621007	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
621008	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
621009	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Follow-up Action Required?	n	
621010	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Follow-up Action Required?	n	
621011	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Operations Ground	0	
621012	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Operations C Ø	0	
621013	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Operations B Ø	0	
621014	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
621015	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Equipment Properly Labeled?	y	
621016	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Cabinet Paint Condition	Good	
621017	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Operations A Ø	0	
621018	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
621019	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
621020	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
621021	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
621022	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
621023	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
621024	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
621025	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
621026	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
621027	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
621028	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
621029	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	General Comments		
621030	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
621031	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
621032	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
621033	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
621034	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
621035	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
621036	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
621037	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Trash Emptied?	y	
621038	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
621039	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
621040	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
621041	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
621042	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Bushings Connection/Risers	Good	
621043	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Panels Dusted?	y	
621044	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Bushing Condition	Good	
621045	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Amps C Ø	3.0	
621046	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Amps B Ø	4.0	
621047	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Amps A Ø	3.0	
621048	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
621049	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Grounds in Place?	y	
621050	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Tank 1 Oil Level	Good	
621051	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Tank 2 Oil level	Good	
621052	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Tank 3 Oil Level	Good	
621053	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	General Comments		
621054	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Foundation Condition	Good	
621055	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Follow-up Action Required?	n	
621056	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Equipment Properly Labeled?	y	
621057	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
621058	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
621059	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
621060	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
621061	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
621062	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
621063	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
621064	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
621065	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
621066	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Unknown Operations	0	
621067	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Tank Paint Condition	Good	
621068	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Amps A Ø	0.0	
621069	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Amps B Ø	0.0	
621070	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
621071	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
621072	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Amps C Ø	0.0	
621073	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
621074	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
621075	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
621076	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
621077	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
621078	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
621079	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
621080	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
621081	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Unknown Operations	0	
621082	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Tank Paint Condition	Good	
621083	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Tank Leaks	None	
621084	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
621085	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
621086	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
621087	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Switching Operations	1	
621088	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Operations Counter AL	966	
621089	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Operations Counter AF	966	
621090	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Switching Operations	0	
621091	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Operations Counter AL	197	
621092	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
621093	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
621094	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
621095	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Number of Ops last 9 Months	1	
621096	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
621097	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Operations Counter AF	197	
621098	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Moisture and Leak Free?	y	
621099	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	General Comments		
621100	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
621101	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Unknown Operations	0	
621102	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Maintenance Operations	0	
621103	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Heaters (All) Functioning?	y	
621104	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Tank Paint Condition	Good	
621105	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Grounds in Place?	y	
621106	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Switching Operations	0	
621107	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Operations Counter AL	163	
621108	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	General Comments		
621109	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Operations Counter AF	163	
621110	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Moisture and Leak Free?	y	
621111	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Maintenance Operations	0	
621112	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Grounds in Place?	y	
621113	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	General Comments		
621114	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	General Comments		
621115	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Foundation Condition	Good	
621116	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Follow-up Action Required?	n	
621117	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	General Comments		
621118	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Foundation Condition	Good	
621119	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Maintenance Operations	0	
621120	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Grounds in Place?	y	
621121	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	General Comments		
621122	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	General Comments		
621123	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Foundation Condition	Good	
621124	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Follow-up Action Required?	n	
621125	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Switching Operations	0	
621126	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Operations Counter AL	145	
621127	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Operations Counter AF	745	
621128	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Maintenance Operations	0	
621129	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	General Comments		
621130	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Tank Paint Condition	Good	
621131	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Moisture and Leak Free?	y	
621132	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Heaters (All) Functioning?	y	
621133	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Grounds in Place?	y	
621134	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	General Comments		
621135	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Follow-up Action Required?	n	
621136	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Operations Ground	0	
621137	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Operations C Ø	0	
621138	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Operations B Ø	0	
621139	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Foundation Condition	Good	
621140	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Follow-up Action Required?	n	
621141	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Equipment Properly Labeled?	y	
621142	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Cabinet Paint Condition	Good	
621143	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Air Pressure OK?	y	
621144	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Operations A Ø	0	
621145	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
621146	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	PF000306	PowerFuse	SY-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
621147	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
621148	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
621149	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
621150	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Bushing Condition	Good	
621151	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Bushing Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
621152	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
621153	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
621154	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
621155	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
621156	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
621157	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
621158	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
621159	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
621160	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
621161	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
621162	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
621163	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
621164	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
621165	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
621166	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Fault Operations	0	
621167	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Follow-up Action Required?	n	
621168	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Follow-up Action Required?	n	
621169	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Foundation Condition	Good	
621170	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	General Comments		
621171	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	General Comments		
621172	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
621173	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
621174	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
621175	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
621176	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
621177	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
621178	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
621179	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
621180	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
621181	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Grounds in Place?	y	
621182	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Maintenance Operations	0	
621183	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Patrol Inspection	General Comments		
621184	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Patrol Inspection	Follow-up Action Required?	n	
621185	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Patrol Inspection	Equipment Properly Labeled?	y	
621186	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
621187	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	General Comments		
621188	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
621189	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
621190	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	PF000306	PowerFuse	SY-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
621191	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	6.0	amps
621192	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.2	VDC
621193	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.2	VDC
621194	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.000	millivolts
621195	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Amps C Ø	0.0	
621196	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Amps B Ø	0.0	
621197	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Amps A Ø	0.0	
621198	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Accumulated Fault Duty C Ph V	6.45	%
621199	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Accumulated Fault Duty B Ph V	6.45	%
621200	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Accumulated Fault Duty A Ph V	6.45	%
621201	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
621202	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
621203	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	General Comments		
621204	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
621205	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
621206	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Floor Swept?	y	
621207	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
621208	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
621209	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Evidence of Insects	None	
621210	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Vegetation	None	
621211	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
621212	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
621213	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	9 Month Operations	2	
621214	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
621215	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
621216	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.3	VDC
621217	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
621218	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Foundation Condition	Good	
621219	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
621220	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
621221	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Tank Leaks	None	
621222	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
621223	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Patrol Inspection	Follow-up Action Required?	n	
621224	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Patrol Inspection	General Comments		
621225	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.3	VDC
621226	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.700	millivolts

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
621227	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Equipment Properly Labeled?	y	
621228	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
621229	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
621230	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Cabinet Paint Condition	Good	
621231	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
621232	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
621233	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
621234	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
621235	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
621236	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
621237	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
621238	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
621239	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Bushings Connection/Risers	Good	
621240	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Bushing Condition	Good	
621241	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Amps C Ø	240.0	
621242	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
621243	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
621244	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
621245	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	General Comments		
621246	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
621247	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
621248	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Unknown Operations	0	
621249	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
621250	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
621251	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
621252	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
621253	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
621254	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
621255	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Clear of Trash?	y	
621256	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
621257	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
621258	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
621259	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
621260	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
621261	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
621262	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
621263	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	PF000307	PowerFuse	SY-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
621264	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	PF000307	PowerFuse	SY-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
621265	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
621266	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
621267	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Air Leaks	None	
621268	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
621269	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
621270	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
621271	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Air Leaks	None	
621272	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Air Pressure OK?	y	
621273	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
621274	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
621275	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
621276	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
621277	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
621278	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
621279	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
621280	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
621281	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
621282	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Equipment Properly Labeled?	y	
621283	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Follow-up Action Required?	n	
621284	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Foundation Condition	Good	
621285	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	General Comments		
621286	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Grounds in Place?	y	
621287	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
621288	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Tank Leaks	None	
621289	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Tank Paint Condition	Good	
621290	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Unknown Operations	0	
621291	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
621292	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
621293	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
621294	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Unknown Operations	0	
621295	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Tank Paint Condition	Good	
621296	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Switching Operations	0	
621297	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Operations Counter AL	298	
621298	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Operations Counter AF	298	
621299	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Moisture and Leak Free?	y	
621300	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Maintenance Operations	0	
621301	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
621302	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
621303	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
621304	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
621305	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
621306	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
621307	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Moisture and Leak Free?	y	
621308	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Readings	Number of Ops last 9 Months	0	
621309	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Readings	Operations Counter AF	1262	
621310	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Readings	Operations Counter AL	1262	
621311	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Tank 1 Oil Level	Good	
621312	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Tank 2 Oil level	Good	
621313	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Tank 3 Oil Level	Good	
621314	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Tank Leaks	None	
621315	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Tank Paint Condition	Good	
621316	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
621317	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
621318	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Amps A Ø	10.0	
621319	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Amps B Ø	10.0	
621320	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Amps C Ø	10.0	
621321	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
621322	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
621323	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
621324	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Bushing Condition	Good	
621325	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
621326	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
621327	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
621328	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	9 Month Operations	6	
621329	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Accumulated Fault Duty A Ph V	1.10	%
621330	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Accumulated Fault Duty B Ph V	1.10	%
621331	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Accumulated Fault Duty C Ph V	1.10	%
621332	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Amps A Ø	30.0	
621333	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Amps B Ø	6.0	
621334	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Amps C Ø	0.0	
621335	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Bushing Condition	Good	
621336	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Bushings Connection/Risers	Good	
621337	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
621338	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
621339	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
621340	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Cabinet Paint Condition	Good	
621341	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Equipment Properly Labeled?	y	
621342	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Adjusted Amps A Phase V	4.94	
621343	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Adjusted Amps B Phase V	4.94	
621344	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Adjusted Amps C Phase V	4.94	
621345	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Operations A Ø	0	
621346	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Operations B Ø	0	
621347	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Operations C Ø	0	
621348	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Operations Ground	0	
621349	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Follow-up Action Required?	n	
621350	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	General Comments		
621351	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
621352	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
621353	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
621354	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
621355	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	212	
621356	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	212	
621357	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
621358	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
621359	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Tank Leaks	None	
621360	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Tank Paint Condition	Good	
621361	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
621362	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
621363	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
621364	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
621365	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000280	PowerFuse	P-14KV BUS SEC 2-B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
621366	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000280	PowerFuse	P-14KV BUS SEC 2-B POT	Disconnect Powerfuse Inspection	General Comments	OK	
621367	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Operations B Ø	0	
621368	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Operations C Ø	0	
621369	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
621370	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	PF000027	PowerFuse	AS-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
621371	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	PF000027	PowerFuse	AS-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
621372	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
621373	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
621374	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	PF000026	PowerFuse	AS-14KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
621375	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	PF000026	PowerFuse	AS-14KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
621376	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
621377	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Tank Leaks	None	
621378	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	PF000025	PowerFuse	AS-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
621379	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	PF000025	PowerFuse	AS-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
621380	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
621381	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
621382	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Regulator As Left Counter	43850	
621383	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
621384	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Operations Ground	0	
621385	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Follow-up Action Required?	n	
621386	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Follow-up Action Required?	n	
621387	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
621388	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
621389	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Bushings Connection/Risers	Good	
621390	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Bushing Condition	Good	
621391	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
621392	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
621393	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
621394	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
621395	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Min Tap Position	6L	
621396	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Max Tap Position	5R	
621397	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
621398	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	General Comments		
621399	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
621400	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
621401	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Unknown Operations	0	
621402	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
621403	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
621404	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Current Tap Position	1L	
621405	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
621406	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
621407	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
621408	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	PF000192	PowerFuse	KE-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
621409	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	PF000192	PowerFuse	KE-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
621410	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	PF000191	PowerFuse	KE-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
621411	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	PF000191	PowerFuse	KE-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
621412	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Follow-up Action Required?	n	
621413	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Foundation Condition	Good	
621414	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	General Comments		
621415	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Bushing Condition	Good	
621416	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
621417	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Foundation Condition	Good	
621418	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	General Comments		
621419	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	General Comments		
621420	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Grounds in Place?	y	
621421	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Maintenance Operations	0	
621422	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Moisture and Leak Free?	y	
621423	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Operations Counter AF	169	
621424	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Operations Counter AL	169	
621425	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Switching Operations	0	
621426	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Tank Paint Condition	Good	
621427	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Unknown Operations	0	
621428	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
621429	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	General Comments		
621430	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
621431	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
621432	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
621433	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
621434	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
621435	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
621436	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
621437	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
621438	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
621439	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
621440	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
621441	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
621442	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
621443	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
621444	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
621445	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Totalizer Meter Reading	.7090	
621446	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Winding Temp Max	30	°C
621447	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Winding Temp Present	30	°C
621448	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
621449	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
621450	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
621451	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
621452	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
621453	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
621454	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Grounds in Place?	y	
621455	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	General Comments		
621456	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
621457	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
621458	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Equipment Properly Labeled?	y	
621459	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Follow-up Action Required?	n	
621460	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Foundation Condition	Good	
621461	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	General Comments		
621462	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Grounds in Place?	y	
621463	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Tank 1 Oil Level	Good	
621464	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Tank 2 Oil level	Good	
621465	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Tank 3 Oil Level	Good	
621466	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Tank Leaks	None	
621467	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	General Comments		
621468	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Foundation Condition	Good	
621469	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Tank Paint Condition	Good	
621470	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
621471	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
621472	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
621473	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Grounds in Place?	y	
621474	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	General Comments		
621475	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Foundation Condition	Good	
621476	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Follow-up Action Required?	n	
621477	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Unknown Operations	0	
621478	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Tank Paint Condition	Good	
621479	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Tank Leaks	None	
621480	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Follow-up Action Required?	n	
621481	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Follow-up Action Required?	n	
621482	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Operations Ground	0	
621483	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Operations C Ø	0	
621484	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Operations B Ø	0	
621485	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Operations A Ø	0	
621486	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
621487	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
621488	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
621489	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
621490	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
621491	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
621492	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
621493	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
621494	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Bushing Condition	Good	
621495	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
621496	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
621497	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
621498	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Unknown Operations	0	
621499	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Unknown Operations	0	
621500	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Tank Paint Condition	Good	
621501	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Tank Leaks	None	
621502	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
621503	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
621504	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
621505	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
621506	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
621507	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
621508	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	2	
621509	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	221	
621510	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Follow-up Action Required?	n	
621511	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
621512	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
621513	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
621514	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Foundation Condition	Good	
621515	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	General Comments		
621516	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	General Comments		
621517	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Grounds in Place?	y	
621518	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Heaters (All) Functioning?	y	
621519	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Maintenance Operations	0	
621520	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Moisture and Leak Free?	y	
621521	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Operations Counter AF	174	
621522	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Operations Counter AL	174	
621523	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
621524	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Switching Operations	0	
621525	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Tank Paint Condition	Good	
621526	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Unknown Operations	1	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
621527	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	General Comments		
621528	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
621529	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	LTC Totalizer Reading	17016.00	kw
621530	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
621531	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
621532	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Oil Temp Max	45	°C
621533	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Oil Temp Present	45	°C
621534	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
621535	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
621536	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
621537	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
621538	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
621539	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
621540	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	General Comments		
621541	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitro	
621542	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
621543	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
621544	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
621545	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	Changed ops counter.	
621546	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
621547	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
621548	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	Oil Temp Present	18	°C
621549	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
621550	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
621551	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
621552	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
621553	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
621554	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
621555	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
621556	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
621557	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
621558	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
621559	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	PF000022	PowerFuse	AS-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
621560	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	PF000022	PowerFuse	AS-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
621561	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
621562	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
621563	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
621564	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
621565	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Readings	General Comments		
621566	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
621567	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
621568	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
621569	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
621570	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
621571	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
621572	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
621573	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
621574	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
621575	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
621576	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
621577	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
621578	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
621579	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Operations Counter	299	
621580	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Tank Leaks	None	
621581	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Max Tap Position	2R	
621582	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
621583	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	General Comments		
621584	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
621585	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
621586	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
621587	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
621588	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
621589	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
621590	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
621591	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Current Tap Position	5L	
621592	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
621593	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
621594	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
621595	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	General Comments		
621596	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Switching Operations	0	
621597	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Unknown Operations	0	
621598	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Switching Operations	3	
621599	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
621600	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
621601	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
621602	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
621603	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
621604	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
621605	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
621606	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Tank Leaks	None	
621607	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Tank Paint Condition	Good	
621608	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Unknown Operations	0	
621609	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Operations Counter AL	1167	
621610	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Operations Counter AF	1167	
621611	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Maintenance Operations	0	
621612	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	General Comments		
621613	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Patrol Inspection	General Comments		
621614	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Follow-up Action Required?	n	
621615	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Patrol Inspection	Follow-up Action Required?	n	
621616	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Operations Ground	0	
621617	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Operations C Ø	0	
621618	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Operations B Ø	0	
621619	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
621620	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
621621	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
621622	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
621623	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
621624	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
621625	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
621626	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
621627	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
621628	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
621629	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Operations A Ø	0	
621630	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
621631	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
621632	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
621633	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
621634	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Amps C Ø	0.0	
621635	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Amps B Ø	0.0	
621636	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Amps A Ø	0.0	
621637	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
621638	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
621639	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
621640	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Foundation Condition	Good	
621641	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
621642	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	LTCC000774	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
621643	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	LTCC000774	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AL	124	VAC
621644	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	LTCC000774	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AF	124	VAC
621645	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	LTCC000774	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
621646	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	LTCC000774	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Operation Checked?	y	
621647	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	LTCC000774	LTCControl	932-Offline Distribution	LTC Control Insp	General Comments		
621648	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	LTCC000774	LTCControl	932-Offline Distribution	LTC Control Insp	Follow-up Action Required?	n	
621649	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	LTCC000774	LTCControl	932-Offline Distribution	LTC Control Insp	All Connections OK?	y	
621650	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Readings	X2 Winding Temp Present	48	°C
621651	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Readings	X2 Winding Temp Max	75	°C
621652	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
621653	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Amps A Ø	110.0	
621654	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
621655	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
621656	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
621657	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
621658	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
621659	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Current Tap Position	4L	
621660	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
621661	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
621662	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
621663	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
621664	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
621665	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
621666	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
621667	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Tank Leaks	None	
621668	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Operations Counter AF	126	
621669	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
621670	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
621671	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
621672	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Fault Operations	0	
621673	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Follow-up Action Required?	n	
621674	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Operations Counter AL	6231	
621675	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
621676	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
621677	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Operations Counter AL	126	
621678	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000284	PowerFuse	P-1384 POT	Disconnect Powerfuse Inspection	General Comments	OK	
621679	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000284	PowerFuse	P-1384 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
621680	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
621681	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Switching Operations	0	
621682	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
621683	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
621684	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
621685	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
621686	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
621687	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
621688	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
621689	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
621690	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
621691	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Amps A Ø	0.0	
621692	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Amps B Ø	0.0	
621693	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Amps C Ø	0.0	
621694	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Bushing Condition	Good	
621695	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Bushing Oil Level	Good	
621696	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
621697	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
621698	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
621699	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
621700	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
621701	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
621702	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
621703	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	General Comments		
621704	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
621705	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
621706	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Regulator As Left Counter	41468	
621707	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
621708	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
621709	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
621710	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
621711	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
621712	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Min Tap Position	8L	
621713	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Fault Operations	0	
621714	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Follow-up Action Required?	n	
621715	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Follow-up Action Required?	n	
621716	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Foundation Condition	Good	
621717	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
621718	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	General Comments		
621719	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	General Comments		
621720	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Grounds in Place?	y	
621721	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Maintenance Operations	0	
621722	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
621723	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Number of Ops last 9 Months	0	
621724	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Operations Counter AF	3841	
621725	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Operations Counter AL	3841	
621726	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
621727	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Switching Operations	0	
621728	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
621729	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
621730	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
621731	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Fault Operations	0	
621732	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Follow-up Action Required?	n	
621733	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Follow-up Action Required?	n	
621734	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Foundation Condition	Good	
621735	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
621736	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	General Comments		
621737	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	General Comments	Correct VC.	
621738	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Foundation Condition	Good	
621739	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Readings	Follow-up Action Required?	n	
621740	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
621741	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Fans Operational?	y	
621742	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Fans Condition	Good	
621743	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Grounds in Place?	y	
621744	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Maintenance Operations	0	
621745	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
621746	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Number of Ops last 9 Months	1	
621747	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Operations Counter AF	1831	
621748	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Operations Counter AL	1831	
621749	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
621750	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Switching Operations	0	
621751	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
621752	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Patrol Inspection	Follow-up Action Required?	n	
621753	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
621754	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Patrol Inspection	General Comments		
621755	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Patrol Inspection	Follow-up Action Required?	n	
621756	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
621757	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
621758	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
621759	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
621760	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Amps C Ø	310.0	
621761	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
621762	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	LTC Operations Since Last Insp	552	
621763	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	LTC Min Tap Position	8L	
621764	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	LTC Max Tap Position	4R	
621765	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	LTC Current Tap Position	3L	
621766	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
621767	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	LTC As Left Counter	4800	
621768	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	LTC As Found Counter	4796	
621769	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	General Comments		
621770	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Bushing Condition	Good	
621771	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Patrol Inspection	Equipment Properly Labeled?	y	
621772	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Bushings Connection/Risers	Good	
621773	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
621774	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
621775	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
621776	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Cabinet Paint Condition	Good	
621777	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Equipment Properly Labeled?	y	
621778	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
621779	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
621780	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Patrol Inspection	Follow-up Action Required?	n	
621781	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
621782	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	General Comments		
621783	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
621784	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	Follow-up Action Required?	n	
621785	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Patrol Inspection	General Comments		
621786	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
621787	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
621788	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Operations Counter	161	
621789	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
621790	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	General Comments		
621791	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
621792	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
621793	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
621794	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
621795	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
621796	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
621797	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
621798	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Amps C Ø	10.0	
621799	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Amps B Ø	10.0	
621800	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Amps A Ø	10.0	
621801	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
621802	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
621803	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Operations A Ø	0	
621804	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
621805	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
621806	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
621807	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	General Comments		
621808	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
621809	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
621810	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
621811	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
621812	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
621813	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
621814	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
621815	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
621816	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
621817	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
621818	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
621819	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
621820	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Tank Leaks	None	
621821	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
621822	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
621823	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Radiator Leaks	None	
621824	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	9 Month Operations	2	
621825	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
621826	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
621827	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	General Comments		
621828	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
621829	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC As Found Counter	251969	
621830	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Accumulated Fault Duty A Ph V	.37	%
621831	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
621832	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
621833	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Amps A Ø	311.0	
621834	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Amps B Ø	320.0	
621835	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
621836	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Pumps Operational?	y	
621837	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Pumps Condition	Good	
621838	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Readings	Oil Temp Present	40	°C
621839	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Readings	Oil Temp Max	90	°C
621840	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Tank Paint Condition	Good	
621841	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Unknown Operations	0	
621842	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
621843	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Patrol Inspection	General Comments		
621844	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
621845	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
621846	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.0	amps
621847	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.6	VDC
621848	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.6	VDC
621849	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.700	millivolts
621850	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Patrol Inspection	Follow-up Action Required?	n	
621851	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Patrol Inspection	Equipment Properly Labeled?	y	
621852	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	400	psi
621853	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
621854	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
621855	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
621856	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC As Left Counter	251969	
621857	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Vegetation	None	
621858	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
621859	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
621860	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
621861	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4L	
621862	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
621863	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
621864	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	123	
621865	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
621866	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
621867	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
621868	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
621869	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	LTCC000772	LTCControl	314-2	LTC Control Insp	VRR Time Delay	30	Seconds
621870	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	LTCC000772	LTCControl	314-2	LTC Control Insp	VRR Base Voltage AL	124	VAC
621871	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	LTCC000772	LTCControl	314-2	LTC Control Insp	VRR Base Voltage AF	124	VAC
621872	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	LTCC000772	LTCControl	314-2	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
621873	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	LTCC000772	LTCControl	314-2	LTC Control Insp	LTC Operation Checked?	y	
621874	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	LTCC000772	LTCControl	314-2	LTC Control Insp	General Comments		
621875	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	LTCC000772	LTCControl	314-2	LTC Control Insp	Follow-up Action Required?	n	
621876	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	LTCC000772	LTCControl	314-2	LTC Control Insp	All Connections OK?	y	
621877	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Grounds in Place?	y	
621878	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Readings	General Comments	y	
621879	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	General Comments		
621880	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
621881	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
621882	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
621883	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
621884	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
621885	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
621886	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
621887	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	General Comments		
621888	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	General Comments		
621889	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Foundation Condition	Good	
621890	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Follow-up Action Required?	n	
621891	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Follow-up Action Required?	n	
621892	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Fault Operations	0	
621893	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
621894	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
621895	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
621896	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
621897	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
621898	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
621899	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
621900	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
621901	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
621902	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	General Comments		
621903	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
621904	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
621905	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
621906	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Bushing Oil Level	Good	
621907	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Bushing Condition	Good	
621908	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Amps C Ø	0.0	
621909	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Amps B Ø	0.0	
621910	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Amps A Ø	0.0	
621911	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
621912	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
621913	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
621914	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
621915	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	General Comments		
621916	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
621917	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
621918	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
621919	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
621920	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
621921	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
621922	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
621923	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	°F
621924	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
621925	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
621926	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
621927	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
621928	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
621929	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
621930	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
621931	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
621932	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	General Comments		
621933	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
621934	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
621935	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
621936	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
621937	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
621938	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
621939	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
621940	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Accumulated Fault Duty A Ph V	27.36	%
621941	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	9 Month Operations	0	
621942	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
621943	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
621944	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Bushing Condition	Good	
621945	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
621946	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
621947	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
621948	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
621949	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
621950	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
621951	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
621952	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
621953	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
621954	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
621955	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
621956	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
621957	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
621958	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
621959	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
621960	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	General Comments		
621961	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	General Comments		
621962	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
621963	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Foundation Condition	Good	
621964	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Follow-up Action Required?	n	
621965	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Follow-up Action Required?	n	
621966	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Fault Operations	0	
621967	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
621968	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
621969	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	LTC Totalizer Reading	3868.80	kw
621970	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
621971	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	General Comments		
621972	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	General Comments		
621973	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
621974	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
621975	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
621976	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
621977	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
621978	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
621979	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
621980	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Bushing Oil Level	Good	
621981	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Bushing Condition	Good	
621982	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Amps C Ø	0.0	
621983	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Amps B Ø	0.0	
621984	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Amps A Ø	0.0	
621985	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
621986	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Air Pressure OK?	y	
621987	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Air Leaks	None	
621988	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	Follow-up Action Required?	n	
621989	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
621990	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	General Comments		
621991	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	General Comments		
621992	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC As Found Counter	1882	
621993	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC As Left Counter	1893	
621994	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
621995	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC Current Tap Position	1L	
621996	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC Max Tap Position	16R	
621997	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC Min Tap Position	9L	
621998	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC Operations Since Last Insp	898	
621999	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
622000	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
622001	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
622002	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
622003	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
622004	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
622005	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
622006	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
622007	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
622008	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
622009	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
622010	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	Oil Temp Present	32	°C
622011	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
622012	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1650	psi
622013	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.4	psi
622014	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
622015	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
622016	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Air Leaks	None	
622017	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Air Pressure OK?	y	
622018	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
622019	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Amps A Ø	1100.0	
622020	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
622021	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Unknown Operations	0	
622022	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Tank Paint Condition	Good	
622023	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Tank Leaks	None	
622024	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Amps B Ø	1100.0	
622025	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Amps C Ø	1200.0	
622026	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Bushing Condition	Good	
622027	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Bushing Oil Level	Good	
622028	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
622029	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
622030	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
622031	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
622032	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
622033	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
622034	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Fault Operations	0	
622035	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Follow-up Action Required?	n	
622036	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Follow-up Action Required?	n	
622037	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Foundation Condition	Good	
622038	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
622039	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	General Comments		
622040	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	General Comments		
622041	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Grounds in Place?	y	
622042	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Maintenance Operations	0	
622043	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
622044	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Number of Ops last 9 Months	8	
622045	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Operations Counter AF	1157	
622046	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Operations Counter AL	1157	
622047	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
622048	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
622049	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
622050	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
622051	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Switching Operations	1	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
622052	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
622053	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
622054	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Switching Operations	0	
622055	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
622056	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
622057	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	9 Month Operations	4	
622058	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Accumulated Fault Duty A Ph V	2.81	%
622059	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
622060	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
622061	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
622062	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
622063	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Tank Leaks	None	
622064	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Tank Paint Condition	Good	
622065	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Unknown Operations	0	
622066	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
622067	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
622068	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
622069	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
622070	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
622071	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
622072	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
622073	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
622074	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
622075	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
622076	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
622077	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
622078	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
622079	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
622080	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
622081	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
622082	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
622083	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
622084	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
622085	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
622086	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Patrol Inspection	Equipment Properly Labeled?	y	
622087	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
622088	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
622089	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Patrol Inspection	Follow-up Action Required?	n	
622090	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
622091	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Equipment Properly Labeled?	y	
622092	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Patrol Inspection	General Comments		
622093	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Patrol Inspection	Equipment Properly Labeled?	y	
622094	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Patrol Inspection	Follow-up Action Required?	n	
622095	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Patrol Inspection	General Comments		
622096	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Follow-up Action Required?	n	
622097	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Foundation Condition	Good	
622098	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
622099	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
622100	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
622101	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
622102	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	General Comments		
622103	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Grounds in Place?	y	
622104	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Tank 1 Oil Level	Good	
622105	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Tank 2 Oil level	Good	
622106	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Tank 3 Oil Level	Good	
622107	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Tank Leaks	None	
622108	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
622109	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
622110	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
622111	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
622112	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	30	°C
622113	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	50	°C
622114	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	28	°C
622115	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
622116	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
622117	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	45	°C
622118	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
622119	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
622120	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
622121	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
622122	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
622123	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Patrol Inspection	General Comments		
622124	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Patrol Inspection	Follow-up Action Required?	n	
622125	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
622126	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	9 Months Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
622127	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
622128	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
622129	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
622130	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Amps A Ø	0.0	
622131	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Amps B Ø	0.0	
622132	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Amps C Ø	0.0	
622133	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
622134	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
622135	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
622136	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
622137	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Operations A Ø	0	
622138	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Operations B Ø	0	
622139	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Operations C Ø	0	
622140	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
622141	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	General Comments	Several trees overhanging fence	
622142	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
622143	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
622144	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
622145	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
622146	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
622147	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
622148	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
622149	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
622150	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
622151	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
622152	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
622153	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
622154	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
622155	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
622156	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
622157	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
622158	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
622159	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
622160	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
622161	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Evidence of Insects	None	
622162	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Operations Ground	0	
622163	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Patrol Inspection	Follow-up Action Required?	n	
622164	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Follow-up Action Required?	n	
622165	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Patrol Inspection	General Comments		
622166	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	General Comments	Racked out and Carded	
622167	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Maintenance Operations	0	
622168	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Operations Counter AF	114	
622169	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Operations Counter AL	114	
622170	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Switching Operations	0	
622171	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Unknown Operations	0	
622172	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Amps A Ø	0.0	
622173	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Amps B Ø	0.0	
622174	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Amps C Ø	0.0	
622175	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Bushing Condition	Good	
622176	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Bushing Oil Level	Good	
622177	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
622178	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
622179	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Amps C Ø	137.0	
622180	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
622181	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
622182	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
622183	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
622184	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Operations A Ø	0	
622185	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Operations B Ø	0	
622186	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Operations C Ø	0	
622187	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
622188	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Maintenance Operations	0	
622189	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Grounds in Place?	y	
622190	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Amps C Ø	10.0	
622191	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Operations Ground	0	
622192	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Patrol Inspection	Follow-up Action Required?	n	
622193	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Follow-up Action Required?	n	
622194	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Patrol Inspection	General Comments		
622195	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	General Comments		
622196	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Maintenance Operations	0	
622197	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Operations Counter AF	667	
622198	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Operations Counter AL	667	
622199	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Switching Operations	2	
622200	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Unknown Operations	0	
622201	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Amps B Ø	9.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
622202	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Amps A Ø	9.0	
622203	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Accumulated Fault Duty C Ph V	4.21	%
622204	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Accumulated Fault Duty B Ph V	27.36	%
622205	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
622206	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
622207	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
622208	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
622209	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
622210	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
622211	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
622212	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
622213	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
622214	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
622215	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
622216	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
622217	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
622218	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
622219	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
622220	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
622221	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
622222	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
622223	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
622224	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
622225	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
622226	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
622227	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Tank Leaks	None	
622228	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
622229	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Radiator Leaks	None	
622230	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
622231	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
622232	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
622233	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
622234	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
622235	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
622236	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
622237	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
622238	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	5	
622239	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
622240	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
622241	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Foundation Condition	Good	
622242	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
622243	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
622244	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	needs 2 desicant filters ontop of LTC	
622245	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
622246	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
622247	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
622248	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
622249	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
622250	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Totalizer Meter Reading	.4836	
622251	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
622252	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Top Oil Temperature Present	30	°C
622253	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Top Oil Temperature Max	53	°C
622254	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
622255	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
622256	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	Oil Temp Max	70	°C
622257	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
622258	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
622259	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Number of Ops last 9 Months	0	
622260	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Operations Counter AF	1634	
622261	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Operations Counter AL	1634	
622262	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Switching Operations	0	
622263	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
622264	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
622265	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
622266	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank Leaks	None	
622267	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank Oil Level	Good	
622268	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank Paint Condition	Good	
622269	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Unknown Operations	0	
622270	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	LTC Totalizer Reading	5452.8	kw
622271	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
622272	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
622273	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
622274	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
622275	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
622276	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
622277	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	General Comments		
622278	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
622279	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
622280	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
622281	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Operations Counter AF	2072	
622282	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Operations Counter AL	2072	
622283	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Switching Operations	1	
622284	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
622285	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	General Comments		
622286	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	General Comments		
622287	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
622288	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
622289	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	Follow-up Action Required?	n	
622290	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
622291	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
622292	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
622293	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
622294	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
622295	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
622296	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
622297	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
622298	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
622299	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
622300	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
622301	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Fault Operations	0	
622302	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
622303	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
622304	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
622305	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
622306	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
622307	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Follow-up Action Required?	n	
622308	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Follow-up Action Required?	n	
622309	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Unknown Operations	0	
622310	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Tank Paint Condition	Good	
622311	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Tank Leaks	None	
622312	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
622313	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
622314	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
622315	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Switching Operations	1	
622316	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
622317	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Operations Counter AL	900	
622318	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
622319	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Grounds in Place?	y	
622320	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	General Comments		
622321	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	54	
622322	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
622323	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
622324	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Operations Counter AF	900	
622325	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Number of Ops last 9 Months	1	
622326	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
622327	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Maintenance Operations	0	
622328	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Grounds in Place?	y	
622329	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Floor Swept?	y	
622330	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
622331	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
622332	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	General Comments		
622333	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Foundation Condition	Good	
622334	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	General Comments		
622335	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	General Comments		
622336	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Grounds in Place?	y	
622337	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Maintenance Operations	0	
622338	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
622339	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
622340	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
622341	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
622342	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20	
622343	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	Totalizer Meter Reading	.568	
622344	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
622345	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
622346	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
622347	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
622348	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
622349	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Panels Dusted?	y	
622350	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
622351	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
622352	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
622353	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	54	
622354	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
622355	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
622356	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
622357	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Grounds in Place?	y	
622358	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Patrol Inspection	General Comments		
622359	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
622360	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Trash Emptied?	y	
622361	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
622362	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
622363	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
622364	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
622365	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
622366	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
622367	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
622368	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
622369	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
622370	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
622371	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
622372	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
622373	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
622374	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100	
622375	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100	
622376	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
622377	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
622378	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	Oil Temp Present	25	°C
622379	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	Oil Temp Max	35	°C
622380	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
622381	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
622382	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
622383	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	General Comments		
622384	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
622385	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
622386	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
622387	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
622388	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
622389	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
622390	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
622391	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
622392	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
622393	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
622394	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
622395	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
622396	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
622397	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
622398	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
622399	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
622400	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
622401	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100	
622402	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0	%
622403	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Patrol Inspection	Follow-up Action Required?	n	
622404	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0	%
622405	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0	%
622406	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
622407	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Patrol Inspection	Equipment Properly Labeled?	y	
622408	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Heaters (All) Functioning?	y	
622409	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Maintenance Operations	0	
622410	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
622411	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Moisture and Leak Free?	y	
622412	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Operations Counter AF	230	
622413	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Operations Counter AL	230	
622414	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Switching Operations	0	
622415	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Tank Paint Condition	Good	
622416	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
622417	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
622418	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
622419	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	838	
622420	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	838	
622421	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
622422	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	9 Month Operations	3	
622423	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
622424	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Operations A Ø	0	
622425	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
622426	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
622427	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
622428	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
622429	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
622430	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
622431	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
622432	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
622433	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
622434	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
622435	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
622436	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
622437	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
622438	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
622439	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
622440	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
622441	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	20	°C
622442	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
622443	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
622444	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
622445	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
622446	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
622447	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
622448	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	45	°C
622449	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	25	°C
622450	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	45	°C
622451	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
622452	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	50	°C
622453	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
622454	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
622455	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
622456	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
622457	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
622458	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
622459	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
622460	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
622461	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
622462	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
622463	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Operations B Ø	0	
622464	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Operations C Ø	0	
622465	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Operations Ground	0	
622466	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
622467	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Follow-up Action Required?	n	
622468	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
622469	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
622470	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
622471	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Follow-up Action Required?	n	
622472	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Foundation Condition	Good	
622473	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	General Comments		
622474	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	General Comments		
622475	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
622476	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LTCC000015	LTCControl	KE-TRANS 2	LTC Control Insp	All Connections OK?	y	
622477	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
622478	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
622479	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
622480	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
622481	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
622482	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	General Comments		
622483	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
622484	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
622485	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
622486	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
622487	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
622488	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	180.0	
622489	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	230.0	
622490	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	12.16	%
622491	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
622492	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
622493	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
622494	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
622495	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
622496	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
622497	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
622498	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
622499	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
622500	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Unknown Operations	0	
622501	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Switching Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
622502	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Operations Counter AL	1002	
622503	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Operations Counter AF	1002	
622504	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Maintenance Operations	0	
622505	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	General Comments		
622506	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Patrol Inspection	General Comments		
622507	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Follow-up Action Required?	n	
622508	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Patrol Inspection	Follow-up Action Required?	n	
622509	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Operations Ground	0	
622510	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Air Leaks	None	
622511	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Air Pressure OK?	y	
622512	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Operations C Ø	0	
622513	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Operations B Ø	0	
622514	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Operations A Ø	0	
622515	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
622516	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
622517	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
622518	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
622519	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Amps C Ø	0.0	
622520	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Amps B Ø	0.0	
622521	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Amps A Ø	0.0	
622522	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
622523	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
622524	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
622525	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	9 Month Operations	0	
622526	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
622527	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	7.48	%
622528	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	7.48	%
622529	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	16	
622530	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
622531	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
622532	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	194	
622533	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	LTC Current Tap Position	5R	
622534	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Unknown Operations	0	
622535	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Ambient Temp	31	°F
622536	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
622537	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
622538	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Clear of Trash?	y	
622539	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
622540	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
622541	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
622542	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	n	
622543	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
622544	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
622545	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
622546	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	General Comments	Ruts around #2 x-former creating a tripping hazard.	
622547	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
622548	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
622549	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
622550	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Vegetation	None	
622551	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
622552	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
622553	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Cabinet Paint Condition	Good	
622554	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Equipment Properly Labeled?	y	
622555	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Follow-up Action Required?	n	
622556	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Foundation Condition	Good	
622557	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	General Comments		
622558	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Grounds in Place?	y	
622559	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Heaters (All) Functioning?	y	
622560	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Moisture and Leak Free?	y	
622561	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Tank Paint Condition	Good	
622562	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	Follow-up Action Required?	n	
622563	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
622564	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	General Comments		
622565	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	General Comments		
622566	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC As Found Counter	62923	
622567	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC As Left Counter	62923	
622568	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
622569	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC Current Tap Position	3L	
622570	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
622571	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC Min Tap Position	10L	
622572	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
622573	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC Operations Since Last Insp	194	
622574	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
622575	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
622576	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
622577	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
622578	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
622579	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
622580	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
622581	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
622582	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
622583	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Foundation Condition	Good	
622584	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
622585	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
622586	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
622587	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
622588	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
622589	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
622590	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
622591	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
622592	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
622593	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
622594	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
622595	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	General Comments		
622596	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Follow-up Action Required?	n	
622597	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
622598	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
622599	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
622600	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
622601	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
622602	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
622603	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
622604	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
622605	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
622606	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
622607	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
622608	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
622609	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
622610	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
622611	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
622612	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
622613	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	805	
622614	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
622615	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
622616	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
622617	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
622618	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
622619	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LTCC000016	LTCControl	KE-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
622620	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LTCC000016	LTCControl	KE-TRANS 1	LTC Control Insp	General Comments		
622621	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LTCC000016	LTCControl	KE-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
622622	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LTCC000016	LTCControl	KE-TRANS 1	LTC Control Insp	All Connections OK?	y	
622623	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	805	
622624	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
622625	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
622626	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
622627	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
622628	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
622629	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
622630	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LTCC000015	LTCControl	KE-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
622631	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
622632	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LTCC000015	LTCControl	KE-TRANS 2	LTC Control Insp	General Comments		
622633	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LTCC000015	LTCControl	KE-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
622634	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
622635	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
622636	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	General Comments		
622637	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
622638	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
622639	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
622640	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
622641	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
622642	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
622643	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	21	°C
622644	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
622645	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	51	°C
622646	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	16	°C
622647	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	51	°C
622648	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	16	°C
622649	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	48	°C
622650	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
622651	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
622652	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
622653	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
622654	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	General Comments		
622655	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
622656	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
622657	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
622658	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
622659	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
622660	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
622661	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
622662	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
622663	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
622664	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
622665	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
622666	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
622667	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
622668	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
622669	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
622670	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
622671	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
622672	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
622673	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
622674	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Accumulated Fault Duty B Ph V	4.68	%
622675	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Accumulated Fault Duty C Ph V	1.87	%
622676	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Amps A Ø	170.0	
622677	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Amps B Ø	210.0	
622678	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Amps C Ø	220.0	
622679	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Bushing Condition	Good	
622680	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Bushings Connection/Risers	Good	
622681	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
622682	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
622683	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
622684	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
622685	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Tank Leaks	None	
622686	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Tank Paint Condition	Good	
622687	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Unknown Operations	0	
622688	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
622689	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
622690	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
622691	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
622692	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
622693	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
622694	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
622695	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	BCH001021	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.900	millivolts
622696	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	BCH001021	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
622697	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	BCH001021	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
622698	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
622699	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
622700	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	BCH001021	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
622701	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	BCH001021	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
622702	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	BCH001021	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
622703	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	BCH001021	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
622704	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	BCH001021	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
622705	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
622706	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
622707	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
622708	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
622709	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
622710	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
622711	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
622712	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
622713	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
622714	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
622715	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Floor Swept?	y	
622716	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
622717	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
622718	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	General Comments		
622719	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
622720	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Unknown Operations	0	
622721	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Switching Operations	2	
622722	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Operations Counter AL	3	
622723	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Operations Counter AF	3	
622724	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Maintenance Operations	0	
622725	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	General Comments		
622726	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
622727	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Follow-up Action Required?	n	
622728	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Cabinet Paint Condition	Good	
622729	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Equipment Properly Labeled?	y	
622730	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
622731	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Patrol Inspection	Follow-up Action Required?	n	
622732	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	PF000189	PowerFuse	KE-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
622733	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Operations Ground	0	
622734	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Operations C Ø	0	
622735	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Operations B Ø	0	
622736	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Operations A Ø	0	
622737	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
622738	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
622739	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
622740	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
622741	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Amps C Ø	0.0	
622742	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
622743	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Panels Dusted?	y	
622744	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
622745	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
622746	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	PF000189	PowerFuse	KE-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
622747	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	PF000190	PowerFuse	KE-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
622748	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	PF000190	PowerFuse	KE-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
622749	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Amps B Ø	0.0	
622750	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Amps A Ø	0.0	
622751	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
622752	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
622753	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
622754	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
622755	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	General Comments		
622756	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	needs 2 desicant filters ontop of LTC	
622757	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC As Found Counter	193402	
622758	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC As Left Counter	193402	
622759	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
622760	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
622761	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2R	
622762	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
622763	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	385	
622764	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
622765	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Bushing Condition	Good	
622766	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Bushings Connection/Risers	Good	
622767	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
622768	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
622769	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
622770	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
622771	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
622772	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
622773	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
622774	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
622775	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
622776	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
622777	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
622778	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	Oil Temp Present	16	°C
622779	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	Oil Temp Max	46	°C
622780	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
622781	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
622782	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
622783	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
622784	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	General Comments		
622785	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
622786	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
622787	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
622788	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
622789	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
622790	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
622791	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
622792	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
622793	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
622794	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
622795	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
622796	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
622797	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
622798	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
622799	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
622800	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
622801	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
622802	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000301	PowerFuse	P-1380 POT	Disconnect Powerfuse Inspection	General Comments	OK	
622803	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000301	PowerFuse	P-1380 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
622804	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
622805	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Broom on Site?	y	
622806	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
622807	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
622808	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
622809	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
622810	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
622811	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
622812	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
622813	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
622814	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Operations Counter AL	1044	
622815	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Operations Counter AF	1044	
622816	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Number of Ops last 9 Months	2	
622817	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
622818	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Maintenance Operations	0	
622819	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Grounds in Place?	y	
622820	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	General Comments		
622821	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	General Comments		
622822	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
622823	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Foundation Condition	Good	
622824	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Follow-up Action Required?	n	
622825	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Follow-up Action Required?	n	
622826	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Fault Operations	0	
622827	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
622828	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
622829	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
622830	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
622831	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Evidence of Insects	None	
622832	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
622833	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
622834	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
622835	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
622836	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
622837	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Operations Counter AF	1076	
622838	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
622839	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
622840	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Broom on Site?	n	
622841	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
622842	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
622843	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
622844	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
622845	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
622846	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
622847	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
622848	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
622849	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
622850	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Evidence of Insects	None	
622851	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
622852	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
622853	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Floor Swept?	n	
622854	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
622855	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
622856	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	General Comments		
622857	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
622858	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Panels Dusted?	n	
622859	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
622860	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
622861	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Trash Emptied?	n	
622862	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
622863	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
622864	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
622865	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
622866	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
622867	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
622868	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
622869	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
622870	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	General Comments	Fabric starting to rust	
622871	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
622872	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
622873	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
622874	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
622875	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	Oil Temp Present	25	°C
622876	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	Oil Temp Max	40	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
622877	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
622878	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
622879	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
622880	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
622881	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
622882	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
622883	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
622884	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
622885	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
622886	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
622887	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
622888	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
622889	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
622890	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
622891	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
622892	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
622893	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
622894	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
622895	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
622896	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
622897	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
622898	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
622899	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
622900	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
622901	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
622902	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
622903	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
622904	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
622905	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
622906	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
622907	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
622908	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
622909	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	228	
622910	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	228	
622911	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
622912	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
622913	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
622914	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
622915	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
622916	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
622917	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
622918	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
622919	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
622920	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
622921	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
622922	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
622923	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
622924	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
622925	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
622926	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
622927	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Foundation Condition	Good	
622928	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
622929	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	General Comments		
622930	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
622931	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
622932	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
622933	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
622934	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
622935	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
622936	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
622937	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
622938	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
622939	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Clear of Trash?	y	
622940	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
622941	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
622942	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
622943	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Maintenance Operations	0	
622944	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Grounds in Place?	y	
622945	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	General Comments		
622946	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	General Comments		
622947	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
622948	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
622949	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
622950	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
622951	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
622952	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
622953	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Amps A Ø	384.0	
622954	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Unknown Operations	0	
622955	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Unknown Operations	0	
622956	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
622957	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
622958	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
622959	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
622960	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
622961	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
622962	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
622963	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
622964	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
622965	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
622966	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
622967	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
622968	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
622969	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
622970	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
622971	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	547	
622972	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
622973	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	49	°C
622974	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
622975	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC Min Tap Position	14L	
622976	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
622977	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11L	
622978	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
622979	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
622980	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
622981	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
622982	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
622983	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
622984	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
622985	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Patrol Inspection	General Comments		
622986	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
622987	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
622988	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
622989	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
622990	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC As Left Counter	21922	
622991	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC As Found Counter	21922	
622992	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
622993	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	General Comments		
622994	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
622995	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
622996	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
622997	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	General Comments		
622998	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
622999	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
623000	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
623001	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
623002	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
623003	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
623004	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
623005	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
623006	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
623007	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Grounds in Place?	y	
623008	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Heaters (All) Functioning?	y	
623009	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
623010	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Operations Counter AL	1076	
623011	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Switching Operations	1	
623012	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
623013	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	General Comments		
623014	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
623015	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
623016	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Tank Leaks	None	
623017	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
623018	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Radiator Leaks	None	
623019	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
623020	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
623021	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Grounds in Place?	y	
623022	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	General Comments		
623023	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
623024	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Foundation Condition	Good	
623025	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
623026	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
623027	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
623028	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
623029	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Bushing Condition	Good	
623030	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	General Comments		
623031	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
623032	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
623033	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
623034	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
623035	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
623036	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
623037	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
623038	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
623039	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
623040	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Bushing Condition	Good	
623041	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Bushings Connection/Risers	Good	
623042	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
623043	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Foundation Condition	Good	
623044	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Follow-up Action Required?	n	
623045	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Follow-up Action Required?	n	
623046	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Fault Operations	0	
623047	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
623048	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
623049	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
623050	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
623051	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
623052	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
623053	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Bushing Oil Level	Good	
623054	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Bushing Condition	Good	
623055	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Amps C Ø	392.0	
623056	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
623057	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
623058	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
623059	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Cabinet Paint Condition	Good	
623060	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Equipment Properly Labeled?	y	
623061	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Follow-up Action Required?	n	
623062	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Foundation Condition	Good	
623063	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	General Comments		
623064	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Amps B Ø	386.0	
623065	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
623066	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Tank Leaks	None	
623067	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Tank Paint Condition	Good	
623068	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
623069	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
623070	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
623071	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
623072	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
623073	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	General Comments	ongoing construction in yard piles of dirt and rocks	
623074	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Amps B Ø	260.0	
623075	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Amps C Ø	280.0	
623076	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
623077	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Equipment Properly Labeled?	y	
623078	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Follow-up Action Required?	n	
623079	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Foundation Condition	Good	
623080	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
623081	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	250.00	
623082	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	245.00	
623083	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
623084	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
623085	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	General Comments		
623086	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Grounds in Place?	y	
623087	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Tank 1 Oil Level	Good	
623088	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Tank 2 Oil level	Good	
623089	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
623090	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	General Comments		
623091	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	General Comments		
623092	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
623093	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
623094	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
623095	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
623096	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
623097	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
623098	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
623099	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
623100	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
623101	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
623102	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
623103	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
623104	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Operations A Ø	0	
623105	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Operations B Ø	0	
623106	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Operations C Ø	0	
623107	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Operations Ground	0	
623108	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Patrol Inspection	Follow-up Action Required?	n	
623109	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
623110	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	General Comments		
623111	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	General Comments		
623112	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
623113	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
623114	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	Follow-up Action Required?	n	
623115	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
623116	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
623117	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
623118	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
623119	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
623120	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
623121	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
623122	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
623123	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
623124	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
623125	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Clear of Trash?	y	
623126	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
623127	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Number of Ops last 9 Months	1	
623128	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
623129	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Vegetation	None	
623130	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
623131	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
623132	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
623133	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	General Comments		
623134	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
623135	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
623136	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
623137	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
623138	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
623139	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
623140	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
623141	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
623142	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
623143	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
623144	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
623145	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
623146	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	9 Month Operations	4	
623147	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Accumulated Fault Duty A Ph V	5.61	%
623148	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Accumulated Fault Duty B Ph V	9.35	%
623149	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Accumulated Fault Duty C Ph V	7.48	%
623150	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Amps A Ø	250.0	
623151	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Amps B Ø	240.0	
623152	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Amps C Ø	300.0	
623153	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Bushing Condition	Good	
623154	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Bushings Connection/Risers	Good	
623155	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
623156	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
623157	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
623158	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Cabinet Paint Condition	Good	
623159	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Equipment Properly Labeled?	y	
623160	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
623161	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
623162	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
623163	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Operations A Ø	0	
623164	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Operations B Ø	0	
623165	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Operations C Ø	0	
623166	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Operations Ground	0	
623167	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Follow-up Action Required?	n	
623168	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Follow-up Action Required?	n	
623169	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Foundation Condition	Good	
623170	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	General Comments		
623171	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	General Comments		
623172	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Grounds in Place?	y	
623173	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Heaters (All) Functioning?	y	
623174	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Maintenance Operations	0	
623175	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Moisture and Leak Free?	y	
623176	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Operations Counter AF	619	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
623177	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Operations Counter AL	619	
623178	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
623179	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Switching Operations	0	
623180	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Tank Paint Condition	Good	
623181	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Unknown Operations	0	
623182	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	9 Months Operations	4	
623183	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Accumulated Fault Duty A Ph AM	9.30	%
623184	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Accumulated Fault Duty B Ph AM	11.96	%
623185	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Accumulated Fault Duty C Ph AM	2.66	%
623186	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Amps A Ø	300.0	
623187	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
623188	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Cabinet Paint Condition	Good	
623189	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
623190	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
623191	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Bushings Connection/Risers	Good	
623192	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Ambient Temperature	32	°F
623193	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
623194	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
623195	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
623196	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
623197	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
623198	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
623199	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
623200	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
623201	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	Oil Temp Present	25	°C
623202	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	Oil Temp Max	40	°C
623203	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
623204	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
623205	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
623206	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
623207	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
623208	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Air Leaks	None	
623209	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Patrol Inspection	General Comments		
623210	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
623211	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
623212	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
623213	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
623214	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
623215	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
623216	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Air Pressure OK?	y	
623217	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
623218	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Amps A Ø	0.0	
623219	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
623220	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
623221	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
623222	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
623223	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	Top Oil Temperature Max	45	°C
623224	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	Top Oil Temperature Present	24	°C
623225	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Amps B Ø	0.0	
623226	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
623227	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.20	%
623228	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.20	%
623229	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	360.0	
623230	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	640.0	
623231	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	600.0	
623232	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
623233	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
623234	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
623235	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
623236	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
623237	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
623238	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
623239	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
623240	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
623241	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	General Comments		
623242	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	General Comments		
623243	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
623244	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
623245	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
623246	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
623247	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
623248	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Follow-up Action Required?	n	
623249	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Patrol Inspection	General Comments		
623250	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	General Comments		
623251	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
623252	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Operations Counter AF	164	
623253	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Operations Counter AL	164	
623254	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Switching Operations	0	
623255	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Unknown Operations	0	
623256	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
623257	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Foundation Condition	Good	
623258	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
623259	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
623260	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
623261	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
623262	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
623263	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
623264	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
623265	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
623266	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
623267	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
623268	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
623269	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
623270	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	Oil Temp Max	40	°C
623271	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	Oil Temp Present	23	°C
623272	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
623273	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
623274	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
623275	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
623276	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
623277	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
623278	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
623279	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Tank 3 Oil Level	Good	
623280	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Tank Leaks	None	
623281	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Vegetation	None	
623282	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
623283	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
623284	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
623285	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	General Comments		
623286	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
623287	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Tank Paint Condition	Good	
623288	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Switching Operations	0	
623289	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
623290	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	SF6 Pressure Indicator	good	
623291	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	SF6 Bushing Condition	Good	
623292	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Operations Counter AL	58	
623293	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Operations Counter AF	58	
623294	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Num Operations Last 9 Months	1	
623295	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Moisture and Leak Free?	y	
623296	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Maintenance Operations	0	
623297	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Heaters (All) Functioning?	y	
623298	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Grounds in Place?	y	
623299	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	General Comments		
623300	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	General Comments		
623301	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Gauge(s) Condition	Good	
623302	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Foundation Condition	Good	
623303	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Follow-up Action Required?	n	
623304	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Follow-up Action Required?	n	
623305	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Fault Operations	0	
623306	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Equipment Properly Labeled?	y	
623307	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LTCC000473	LTCControl	AS-TRANS 4	LTC Control Insp	General Comments		
623308	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LTCC000473	LTCControl	AS-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
623309	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
623310	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
623311	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
623312	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
623313	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC Operations Since Last Insp	305	
623314	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
623315	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC Min Tap Position	9L	
623316	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC Max Tap Position	2R	
623317	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC Current Tap Position	4L	
623318	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
623319	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC As Left Counter	69596	
623320	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC As Found Counter	69596	
623321	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	General Comments		
623322	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	General Comments		
623323	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
623324	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	Follow-up Action Required?	n	
623325	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
623326	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Vegetation	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
623327	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
623328	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	General Comments		
623329	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
623330	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
623331	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
623332	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
623333	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
623334	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Clear of Trash?	y	
623335	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
623336	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
623337	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Oil Temp Present	25	°C
623338	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
623339	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
623340	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
623341	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
623342	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Fault Operations	0	
623343	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Follow-up Action Required?	n	
623344	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Follow-up Action Required?	n	
623345	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Foundation Condition	Good	
623346	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
623347	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
623348	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
623349	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
623350	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
623351	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	General Comments		
623352	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	General Comments		
623353	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Grounds in Place?	y	
623354	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
623355	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
623356	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
623357	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Totalizer Meter Multiplier	14000	
623358	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Totalizer Meter Reading	.5260	
623359	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LTCC000485	LTCControl	SY-TRANS 2	LTC Control Insp	All Connections OK?	y	
623360	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LTCC000485	LTCControl	SY-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
623361	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LTCC000485	LTCControl	SY-TRANS 2	LTC Control Insp	General Comments		
623362	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LTCC000485	LTCControl	SY-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
623363	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
623364	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
623365	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Maintenance Operations	0	
623366	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Air Pressure OK?	y	
623367	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Air Leaks	None	
623368	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
623369	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Tank Paint Condition	Good	
623370	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Moisture and Leak Free?	y	
623371	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Heaters (All) Functioning?	y	
623372	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Grounds in Place?	y	
623373	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	General Comments		
623374	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Foundation Condition	Good	
623375	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Follow-up Action Required?	n	
623376	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Equipment Properly Labeled?	y	
623377	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Cabinet Paint Condition	Good	
623378	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
623379	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
623380	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
623381	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Bushings Connection/Risers	Good	
623382	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Bushing Condition	Good	
623383	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
623384	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	LTC Totalizer Reading	7364.00	kw
623385	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
623386	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Unknown Operations	0	
623387	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Switching Operations	3	
623388	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Operations Counter AL	1134	
623389	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Operations Counter AF	1134	
623390	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Maintenance Operations	0	
623391	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	General Comments		
623392	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Patrol Inspection	General Comments		
623393	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Follow-up Action Required?	n	
623394	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Patrol Inspection	Follow-up Action Required?	n	
623395	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Operations Ground	0	
623396	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Operations C Ø	0	
623397	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Operations B Ø	0	
623398	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Operations A Ø	0	
623399	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
623400	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
623401	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
623402	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
623403	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Amps C Ø	0.0	
623404	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Amps B Ø	0.0	
623405	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
623406	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Oil Temp Max	25	°C
623407	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
623408	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
623409	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0	VDC
623410	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Amps A Ø	0.0	
623411	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Accumulated Fault Duty C Ph V	3.17	%
623412	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Accumulated Fault Duty B Ph V	3.17	%
623413	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Accumulated Fault Duty A Ph V	3.17	%
623414	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	9 Month Operations	4	
623415	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Patrol Inspection	General Comments		
623416	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Patrol Inspection	Follow-up Action Required?	n	
623417	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Patrol Inspection	Equipment Properly Labeled?	y	
623418	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0	VDC
623419	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
623420	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
623421	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
623422	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
623423	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
623424	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LTCC000473	LTCControl	AS-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
623425	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	5.78	%
623426	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Patrol Inspection	Follow-up Action Required?	n	
623427	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Operations Ground	0	
623428	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Operations C Ø	0	
623429	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Operations B Ø	0	
623430	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
623431	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
623432	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
623433	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
623434	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
623435	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
623436	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
623437	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
623438	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
623439	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
623440	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Operations A Ø	0	
623441	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
623442	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
623443	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
623444	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
623445	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Unknown Operations	0	
623446	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
623447	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
623448	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
623449	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
623450	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
623451	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
623452	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
623453	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
623454	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	8630.4	kw
623455	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
623456	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
623457	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Tank Paint Condition	Good	
623458	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Tank Leaks	None	
623459	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
623460	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
623461	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
623462	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Switching Operations	1	
623463	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Operations Counter AL	5489	
623464	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Operations Counter AF	5489	
623465	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	65	°C
623466	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
623467	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
623468	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
623469	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
623470	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
623471	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
623472	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
623473	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
623474	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.899	
623475	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
623476	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
623477	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Number of Ops last 9 Months	14	
623478	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	9 Month Operations	2	
623479	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Accumulated Fault Duty A Ph V	25.26	%
623480	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Accumulated Fault Duty B Ph V	25.26	%
623481	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Accumulated Fault Duty C Ph V	25.26	%
623482	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Amps A Ø	137.0	
623483	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Amps B Ø	133.0	
623484	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
623485	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Number of Ops last 9 Months	1	
623486	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Operations Counter AF	1149	
623487	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Operations Counter AL	1149	
623488	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
623489	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Switching Operations	1	
623490	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
623491	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
623492	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
623493	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Tank Leaks	None	
623494	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Tank Paint Condition	Good	
623495	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Amps C Ø	0.0	
623496	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Bushing Condition	Good	
623497	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Bushing Oil Level	Good	
623498	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
623499	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
623500	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
623501	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
623502	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
623503	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
623504	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Fault Operations	0	
623505	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Follow-up Action Required?	n	
623506	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Follow-up Action Required?	n	
623507	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Foundation Condition	Good	
623508	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
623509	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
623510	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
623511	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
623512	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
623513	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
623514	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
623515	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	31	°F
623516	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
623517	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	General Comments		
623518	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	General Comments		
623519	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
623520	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
623521	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
623522	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
623523	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
623524	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
623525	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
623526	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Air Leaks	None	
623527	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
623528	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Unknown Operations	0	
623529	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	7	
623530	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	5.78	%
623531	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
623532	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Patrol Inspection	General Comments		
623533	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Patrol Inspection	Follow-up Action Required?	n	
623534	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Patrol Inspection	Equipment Properly Labeled?	y	
623535	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
623536	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Grounds in Place?	y	
623537	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Maintenance Operations	0	
623538	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
623539	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	8.66	%
623540	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Number of Ops last 9 Months	1	
623541	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
623542	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
623543	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
623544	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
623545	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
623546	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
623547	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
623548	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
623549	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
623550	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
623551	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
623552	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
623553	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
623554	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
623555	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
623556	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
623557	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
623558	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
623559	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
623560	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	General Comments		
623561	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
623562	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
623563	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
623564	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	Oil Temp Max	70	°C
623565	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	General Comments		
623566	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
623567	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Foundation Condition	Good	
623568	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Follow-up Action Required?	n	
623569	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Follow-up Action Required?	n	
623570	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Patrol Inspection	Equipment Properly Labeled?	y	
623571	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Fault Operations	0	
623572	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
623573	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
623574	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
623575	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
623576	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
623577	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
623578	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
623579	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
623580	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
623581	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
623582	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
623583	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
623584	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
623585	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
623586	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
623587	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
623588	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
623589	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
623590	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	55	
623591	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	55	
623592	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	55	
623593	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0	%
623594	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0	%
623595	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0	%
623596	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
623597	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
623598	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
623599	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
623600	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
623601	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
623602	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
623603	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Moisture and Leak Free?	y	
623604	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Tank Paint Condition	Good	
623605	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
623606	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Unknown Operations	0	
623607	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Switching Operations	0	
623608	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Operations Counter AL	669	
623609	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Operations Counter AF	669	
623610	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Maintenance Operations	0	
623611	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	General Comments		
623612	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Patrol Inspection	General Comments		
623613	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
623614	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
623615	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
623616	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Follow-up Action Required?	n	
623617	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
623618	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
623619	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Tank Paint Condition	Good	
623620	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Tank Leaks	None	
623621	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
623622	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
623623	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
623624	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Switching Operations	0	
623625	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
623626	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
623627	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
623628	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
623629	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
623630	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
623631	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
623632	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
623633	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
623634	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
623635	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
623636	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Operations Counter AL	845	
623637	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Operations Counter AF	845	
623638	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Number of Ops last 9 Months	0	
623639	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
623640	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
623641	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
623642	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
623643	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
623644	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
623645	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
623646	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Maintenance Operations	0	
623647	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Grounds in Place?	y	
623648	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	General Comments		
623649	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Patrol Inspection	General Comments		
623650	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Patrol Inspection	Follow-up Action Required?	n	
623651	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
623652	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
623653	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
623654	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	171	
623655	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	167	
623656	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
623657	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
623658	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
623659	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
623660	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
623661	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
623662	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
623663	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
623664	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
623665	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
623666	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
623667	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Follow-up Action Required?	n	
623668	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
623669	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
623670	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	General Comments		
623671	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	General Comments		
623672	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
623673	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
623674	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Switching Operations	1	
623675	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
623676	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Operations Counter AL	1468	
623677	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Operations Counter AF	1468	
623678	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Number of Ops last 9 Months	1	
623679	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Amps C Ø	0.0	
623680	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Amps B Ø	0.0	
623681	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Amps A Ø	0.0	
623682	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
623683	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Air Pressure OK?	y	
623684	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Fault Operations	0	
623685	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
623686	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
623687	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
623688	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
623689	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
623690	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
623691	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Bushing Oil Level	Good	
623692	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Bushing Condition	Good	
623693	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Amps C Ø	25.0	
623694	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Amps B Ø	25.0	
623695	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Amps A Ø	25.0	
623696	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
623697	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Air Pressure OK?	y	
623698	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Air Leaks	None	
623699	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
623700	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
623701	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
623702	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Grounds in Place?	y	
623703	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	General Comments		
623704	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	General Comments		
623705	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
623706	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Foundation Condition	Good	
623707	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Follow-up Action Required?	n	
623708	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Follow-up Action Required?	n	
623709	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Fault Operations	0	
623710	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
623711	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
623712	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
623713	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
623714	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
623715	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
623716	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Bushing Oil Level	Good	
623717	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Bushing Condition	Good	
623718	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Amps C Ø	0.0	
623719	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Amps B Ø	0.0	
623720	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Amps A Ø	0.0	
623721	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
623722	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
623723	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
623724	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
623725	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
623726	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
623727	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
623728	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	65	°C
623729	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
623730	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
623731	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
623732	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
623733	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Bushing Oil Level	Good	
623734	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Bushing Condition	Good	
623735	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
623736	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
623737	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
623738	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
623739	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
623740	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
623741	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
623742	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Unknown Operations	0	
623743	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Tank Paint Condition	Good	
623744	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Tank Leaks	None	
623745	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
623746	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
623747	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
623748	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Switching Operations	1	
623749	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
623750	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Operations Counter AL	1153	
623751	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Operations Counter AF	1153	
623752	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Number of Ops last 9 Months	1	
623753	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	60	°C
623754	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
623755	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
623756	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Maintenance Operations	0	
623757	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Grounds in Place?	y	
623758	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	General Comments		
623759	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	General Comments		
623760	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
623761	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Foundation Condition	Good	
623762	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Follow-up Action Required?	n	
623763	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Follow-up Action Required?	n	
623764	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Amps C Ø	0.0	
623765	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Bushing Condition	Good	
623766	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Bushing Oil Level	Good	
623767	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
623768	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
623769	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
623770	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
623771	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
623772	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
623773	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
623774	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
623775	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Amps A Ø	0.0	
623776	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Amps B Ø	0.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
623777	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Unknown Operations	0	
623778	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Tank Paint Condition	Good	
623779	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Tank Leaks	None	
623780	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
623781	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
623782	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Air Leaks	None	
623783	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Air Pressure OK?	y	
623784	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
623785	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Amps A Ø	0.0	
623786	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Amps B Ø	0.0	
623787	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Amps C Ø	0.0	
623788	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Amps B Ø	265.0	
623789	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Unknown Operations	0	
623790	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Tank Paint Condition	Good	
623791	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
623792	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Air Leaks	None	
623793	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Air Pressure OK?	y	
623794	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
623795	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Amps A Ø	0.0	
623796	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Amps B Ø	0.0	
623797	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Amps C Ø	0.0	
623798	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Amps C Ø	260.0	
623799	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Bushing Condition	Good	
623800	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Switching Operations	0	
623801	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
623802	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Operations Counter AL	598	
623803	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Tank Paint Condition	Good	
623804	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Tank Leaks	None	
623805	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Tank 3 Oil Level	Good	
623806	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	All Connections OK?	y	
623807	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	Follow-up Action Required?	n	
623808	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	General Comments		
623809	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	LTC Operation Checked?	y	
623810	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
623811	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
623812	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
623813	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
623814	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	VRR Time Delay	60	Seconds
623815	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Tank 2 Oil level	Good	
623816	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Tank 1 Oil Level	Good	
623817	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Switching Operations	0	
623818	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Operations Counter AL	645	
623819	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Operations Counter AF	645	
623820	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Number of Ops last 9 Months	0	
623821	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Moisture and Leak Free?	y	
623822	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Maintenance Operations	0	
623823	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Grounds in Place?	y	
623824	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	General Comments		
623825	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Foundation Condition	Good	
623826	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Follow-up Action Required?	n	
623827	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Follow-up Action Required?	n	
623828	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Fault Operations	0	
623829	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Equipment Properly Labeled?	y	
623830	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Cabinet Paint Condition	Good	
623831	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
623832	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
623833	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
623834	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Bushings Connection/Risers	Good	
623835	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Bushing Oil Level	Good	
623836	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Bushing Condition	Good	
623837	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Operations Counter AF	598	
623838	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Moisture and Leak Free?	y	
623839	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Operations C Ø	0	
623840	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Operations Ground	0	
623841	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Patrol Inspection	Follow-up Action Required?	n	
623842	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Follow-up Action Required?	n	
623843	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Patrol Inspection	General Comments		
623844	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
623845	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
623846	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
623847	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
623848	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
623849	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
623850	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
623851	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
623852	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	9 Month Operations	4	
623853	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
623854	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
623855	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
623856	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Amps A Ø	162.0	
623857	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Amps B Ø	174.0	
623858	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Amps C Ø	171.0	
623859	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Bushing Condition	Good	
623860	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
623861	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
623862	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
623863	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
623864	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
623865	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
623866	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
623867	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
623868	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
623869	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Operations A Ø	0	
623870	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Operations B Ø	0	
623871	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Operations C Ø	0	
623872	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Operations Ground	0	
623873	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Follow-up Action Required?	n	
623874	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Follow-up Action Required?	n	
623875	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Foundation Condition	Good	
623876	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	General Comments		
623877	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	General Comments		
623878	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Grounds in Place?	y	
623879	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
623880	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Maintenance Operations	0	
623881	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
623882	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Operations Counter AF	145	
623883	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Operations Counter AL	145	
623884	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
623885	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Switching Operations	3	
623886	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Tank Paint Condition	Good	
623887	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Unknown Operations	0	
623888	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
623889	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
623890	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	9 Month Operations	4	
623891	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Accumulated Fault Duty A Ph V	12.16	%
623892	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Accumulated Fault Duty B Ph V	12.16	%
623893	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Accumulated Fault Duty C Ph V	4.68	%
623894	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Amps A Ø	260.0	
623895	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
623896	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	Oil Temp Max	35	°C
623897	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
623898	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Bushing Oil Level	Good	
623899	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Bushing Condition	Good	
623900	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Amps C Ø	0.0	
623901	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Amps B Ø	0.0	
623902	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Amps A Ø	0.0	
623903	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
623904	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Air Pressure OK?	y	
623905	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Air Leaks	None	
623906	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
623907	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Unknown Operations	0	
623908	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Tank Paint Condition	Good	
623909	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Tank Leaks	None	
623910	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
623911	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
623912	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
623913	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Switching Operations	1	
623914	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Operations Counter AL	1460	
623915	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
623916	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Tank Leaks	None	
623917	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
623918	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Regulator As Left Counter	142892	
623919	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
623920	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
623921	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
623922	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
623923	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
623924	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
623925	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
623926	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
623927	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Operations A Ø	0	
623928	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
623929	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
623930	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
623931	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
623932	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
623933	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	General Comments		
623934	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	General Comments		
623935	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
623936	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
623937	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
623938	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
623939	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
623940	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Fault Operations	0	
623941	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Follow-up Action Required?	n	
623942	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Follow-up Action Required?	n	
623943	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Foundation Condition	Good	
623944	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
623945	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	General Comments		
623946	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	General Comments		
623947	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Grounds in Place?	y	
623948	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Maintenance Operations	0	
623949	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
623950	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Number of Ops last 9 Months	2	
623951	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Operations Counter AF	1322	
623952	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Operations Counter AL	1322	
623953	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Maintenance Operations	0	
623954	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Heaters (All) Functioning?	y	
623955	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Grounds in Place?	y	
623956	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	General Comments		
623957	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	General Comments		
623958	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Bushings Connection/Risers	Good	
623959	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
623960	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
623961	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
623962	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Cabinet Paint Condition	Good	
623963	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Foundation Condition	Good	
623964	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Follow-up Action Required?	n	
623965	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Follow-up Action Required?	n	
623966	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Patrol Inspection	General Comments		
623967	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Grounds in Place?	y	
623968	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	General Comments		
623969	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	General Comments		
623970	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
623971	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Foundation Condition	Good	
623972	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Follow-up Action Required?	n	
623973	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Follow-up Action Required?	n	
623974	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Equipment Properly Labeled?	y	
623975	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Operations Ground	0	
623976	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Operations C Ø	0	
623977	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Bushing Condition	Good	
623978	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Bushing Oil Level	Good	
623979	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
623980	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
623981	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
623982	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Fault Operations	0	
623983	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
623984	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
623985	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
623986	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
623987	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
623988	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
623989	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
623990	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Operations A Ø	0	
623991	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Operations B Ø	0	
623992	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Operations C Ø	0	
623993	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Operations Ground	0	
623994	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Bushing Condition	Good	
623995	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Bushing Oil Level	Good	
623996	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
623997	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
623998	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
623999	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Patrol Inspection	Follow-up Action Required?	n	
624000	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
624001	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
624002	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Follow-up Action Required?	n	
624003	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Follow-up Action Required?	n	
624004	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Operations B Ø	0	
624005	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Patrol Inspection	Equipment Properly Labeled?	y	
624006	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
624007	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
624008	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
624009	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
624010	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	Oil Temp Present	24	°C
624011	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Operations B Ø	0	
624012	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Operations A Ø	0	
624013	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
624014	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
624015	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
624016	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Equipment Properly Labeled?	y	
624017	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Cabinet Paint Condition	Good	
624018	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
624019	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
624020	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
624021	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
624022	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
624023	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
624024	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
624025	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
624026	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
624027	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
624028	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
624029	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	488	
624030	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
624031	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
624032	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
624033	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
624034	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
624035	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
624036	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
624037	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	84.0	
624038	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
624039	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
624040	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
624041	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
624042	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
624043	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	68.0	
624044	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	127.0	
624045	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
624046	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
624047	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	493	
624048	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
624049	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Unknown Operations	0	
624050	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
624051	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
624052	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
624053	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
624054	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
624055	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
624056	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	33.0	
624057	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	33.0	
624058	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	44.0	
624059	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
624060	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
624061	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
624062	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
624063	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	33	
624064	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Tank Paint Condition	Good	
624065	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Tank Leaks	None	
624066	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Tank 3 Oil Level	Good	
624067	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Tank 2 Oil level	Good	
624068	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
624069	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
624070	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
624071	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
624072	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Amps C Ø	400.0	
624073	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Amps B Ø	380.0	
624074	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Amps A Ø	380.0	
624075	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
624076	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
624077	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
624078	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	9 Month Operations	2	
624079	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Unknown Operations	0	
624080	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Tank Paint Condition	Good	
624081	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Switching Operations	0	
624082	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
624083	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Operations Counter AL	88	
624084	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Operations Counter AF	88	
624085	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Moisture and Leak Free?	y	
624086	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Maintenance Operations	0	
624087	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Heaters (All) Functioning?	y	
624088	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Grounds in Place?	y	
624089	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	General Comments		
624090	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	General Comments		
624091	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Foundation Condition	Good	
624092	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
624093	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
624094	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
624095	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
624096	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
624097	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
624098	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
624099	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0769	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AF	483	
624100	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0769	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AL	483	
624101	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0769	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Switching Operations	0	
624102	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0769	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Unknown Operations	0	
624103	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	14	
624104	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
624105	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
624106	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
624107	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
624108	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
624109	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
624110	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
624111	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
624112	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
624113	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.40	%
624114	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.40	%
624115	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	125.0	
624116	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	125.0	
624117	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	125.0	
624118	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
624119	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
624120	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
624121	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
624122	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Follow-up Action Required?	n	
624123	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Follow-up Action Required?	n	
624124	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Operations Ground	0	
624125	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Operations C Ø	0	
624126	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
624127	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
624128	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
624129	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LTCC000328	LTCControl	SY-TRANS 1	LTC Control Insp	All Connections OK?	y	
624130	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LTCC000328	LTCControl	SY-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
624131	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LTCC000328	LTCControl	SY-TRANS 1	LTC Control Insp	General Comments		
624132	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LTCC000328	LTCControl	SY-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
624133	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
624134	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Patrol Inspection	Follow-up Action Required?	n	
624135	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Patrol Inspection	General Comments		
624136	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
624137	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	9 Month Operations	4	
624138	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
624139	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
624140	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
624141	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Amps A Ø	0.0	
624142	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Amps B Ø	0.0	
624143	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Amps C Ø	0.0	
624144	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
624145	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
624146	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
624147	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
624148	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
624149	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
624150	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
624151	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	LTCC000549	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
624152	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	LTCC000549	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
624153	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	LTCC000549	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
624154	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	LTCC000549	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
624155	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	LTCC000549	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
624156	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	LTCC000549	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
624157	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	LTCC000549	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
624158	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	LTCC000549	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
624159	1/15/2019 7:57	Distribution	Clays Mill Quarterly Inspection	LTCC000549	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
624160	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Operations Ground	0	
624161	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
624162	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
624163	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Patrol Inspection	General Comments		
624164	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	General Comments		
624165	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Maintenance Operations	0	
624166	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Operations Counter AF	572	
624167	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Operations Counter AL	572	
624168	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Switching Operations	4	
624169	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Unknown Operations	0	
624170	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	9 Months Operations	1	
624171	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Accumulated Fault Duty A Ph AM	14.62	%
624172	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Accumulated Fault Duty B Ph AM	17.28	%
624173	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Accumulated Fault Duty C Ph AM	6.64	%
624174	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Amps A Ø	310.0	
624175	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Amps B Ø	210.0	
624176	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Amps C Ø	240.0	
624177	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
624178	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
624179	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
624180	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
624181	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Operations A Ø	0	
624182	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Operations B Ø	0	
624183	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Tank 1 Oil Level	Good	
624184	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Switching Operations	0	
624185	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Operations Counter AL	693	
624186	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Operations Counter AF	693	
624187	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Number of Ops last 9 Months	5	
624188	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	37	
624189	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Moisture and Leak Free?	y	
624190	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Maintenance Operations	0	
624191	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Grounds in Place?	y	
624192	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	General Comments		
624193	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	General Comments		
624194	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Foundation Condition	Good	
624195	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Follow-up Action Required?	n	
624196	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Follow-up Action Required?	n	
624197	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
624198	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
624199	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
624200	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
624201	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
624202	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
624203	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Bushings Connection/Risers	Good	
624204	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Bushing Condition	Good	
624205	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
624206	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
624207	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
624208	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	9 Month Operations	9	
624209	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
624210	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
624211	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
624212	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
624213	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
624214	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Fault Operations	0	
624215	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Equipment Properly Labeled?	y	
624216	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Cabinet Paint Condition	Good	
624217	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
624218	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
624219	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
624220	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Bushings Connection/Risers	Good	
624221	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Bushing Oil Level	Good	
624222	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Bushing Condition	Good	
624223	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Amps C Ø	0.0	
624224	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Amps B Ø	0.0	
624225	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Amps A Ø	0.0	
624226	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
624227	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
624228	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
624229	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
624230	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
624231	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
624232	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
624233	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
624234	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
624235	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
624236	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
624237	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
624238	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	126	
624239	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	126	
624240	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
624241	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	Follow-up Action Required?	n	
624242	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	All Connections OK?	y	
624243	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
624244	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.62	%
624245	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.62	%
624246	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Amps B Ø	53.1	
624247	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Amps A Ø	51.6	
624248	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Accumulated Fault Duty C Ph V	4.21	%
624249	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Accumulated Fault Duty B Ph V	4.21	%
624250	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Bushings Connection/Risers	Good	
624251	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Bushing Condition	Good	
624252	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Amps C Ø	100.0	
624253	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Amps B Ø	100.0	
624254	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Amps A Ø	100.0	
624255	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LTCC000419	LTCControl	AS-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
624256	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LTCC000419	LTCControl	AS-TRANS 3	LTC Control Insp	General Comments		
624257	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LTCC000419	LTCControl	AS-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
624258	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Accumulated Fault Duty C Ph V	9.35	%
624259	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
624260	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Tank Paint Condition	Good	
624261	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
624262	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Moisture and Leak Free?	y	
624263	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Heaters (All) Functioning?	y	
624264	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Grounds in Place?	y	
624265	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Accumulated Fault Duty A Ph V	4.21	%
624266	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	9 Month Operations	4	
624267	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	General Comments		
624268	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Foundation Condition	Good	
624269	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Follow-up Action Required?	n	
624270	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Equipment Properly Labeled?	y	
624271	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Evidence of Insects	None	
624272	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
624273	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
624274	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
624275	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
624276	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Fault Operations	0	
624277	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Follow-up Action Required?	n	
624278	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Follow-up Action Required?	n	
624279	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Switching Operations	0	
624280	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Tank Paint Condition	Good	
624281	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Unknown Operations	0	
624282	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
624283	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
624284	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Foundation Condition	Good	
624285	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
624286	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	General Comments		
624287	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Floor Swept?	y	
624288	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
624289	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
624290	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Accumulated Fault Duty B Ph V	6.55	%
624291	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Accumulated Fault Duty A Ph V	8.42	%
624292	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	9 Month Operations	4	
624293	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Cabinet Paint Condition	Good	
624294	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
624295	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	General Comments		
624296	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Grounds in Place?	y	
624297	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Maintenance Operations	0	
624298	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	General Comments		
624299	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
624300	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Foundation Condition	Good	
624301	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
624302	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Follow-up Action Required?	n	
624303	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Fault Operations	0	
624304	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
624305	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
624306	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
624307	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Operations Counter AL	1065	
624308	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
624309	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Switching Operations	1	
624310	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
624311	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
624312	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
624313	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Tank Leaks	None	
624314	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Tank Paint Condition	Good	
624315	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Unknown Operations	0	
624316	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
624317	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
624318	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Operations C Ø	0	
624319	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Operations B Ø	0	
624320	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
624321	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Bushing Oil Level	Good	
624322	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Bushing Condition	Good	
624323	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Operations A Ø	0	
624324	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
624325	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Amps C Ø	0.0	
624326	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Amps B Ø	0.0	
624327	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Amps A Ø	0.0	
624328	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
624329	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
624330	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
624331	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
624332	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
624333	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
624334	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	4004	
624335	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	4008	
624336	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
624337	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	8L	
624338	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	2L	
624339	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	14L	
624340	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
624341	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Amps C Ø	53.1	
624342	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	439	
624343	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	VRR Time Delay	30	Seconds
624344	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
624345	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
624346	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
624347	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
624348	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
624349	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Air Pressure OK?	y	
624350	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Air Leaks	None	
624351	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
624352	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
624353	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
624354	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	LTC Operation Checked?	y	
624355	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	General Comments		
624356	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
624357	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
624358	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
624359	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
624360	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
624361	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
624362	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
624363	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
624364	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	91	
624365	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	95	
624366	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
624367	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
624368	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
624369	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
624370	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
624371	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
624372	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
624373	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
624374	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
624375	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
624376	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
624377	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
624378	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
624379	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
624380	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	180.0	
624381	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
624382	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
624383	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Panels Dusted?	y	
624384	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
624385	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
624386	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
624387	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
624388	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Equipment Properly Labeled?	y	
624389	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Follow-up Action Required?	n	
624390	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Foundation Condition	Good	
624391	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	General Comments		
624392	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Grounds in Place?	y	
624393	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Tank 1 Oil Level	Good	
624394	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Tank 2 Oil level	Good	
624395	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Tank 3 Oil Level	Good	
624396	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Tank Leaks	None	
624397	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Trash Emptied?	y	
624398	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
624399	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
624400	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
624401	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
624402	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
624403	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
624404	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
624405	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
624406	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
624407	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
624408	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
624409	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
624410	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
624411	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
624412	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
624413	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
624414	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000278	PowerFuse	P-14KV BUS SEC 1-B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
624415	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000278	PowerFuse	P-14KV BUS SEC 1-B POT	Disconnect Powerfuse Inspection	General Comments	OK	
624416	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
624417	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Bushings Connection/Risers	Good	
624418	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Bushing Condition	Good	
624419	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000279	PowerFuse	P-14KV BUS SEC 2-A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
624420	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000279	PowerFuse	P-14KV BUS SEC 2-A POT	Disconnect Powerfuse Inspection	General Comments	OK	
624421	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	9 Month Operations	8	
624422	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Accumulated Fault Duty A Ph V	3.74	%
624423	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Accumulated Fault Duty B Ph V	1.87	%
624424	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
624425	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Amps A Ø	240.0	
624426	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Amps B Ø	230.0	
624427	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Amps C Ø	240.0	
624428	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Bushing Condition	Good	
624429	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Bushings Connection/Risers	Good	
624430	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
624431	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
624432	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.62	%
624433	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	110	
624434	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	65	
624435	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	65	
624436	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
624437	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
624438	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
624439	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
624440	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
624441	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
624442	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
624443	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
624444	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	64	
624445	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	60	
624446	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
624447	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
624448	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
624449	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
624450	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
624451	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
624452	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
624453	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
624454	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
624455	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
624456	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
624457	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
624458	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
624459	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
624460	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
624461	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	General Comments		
624462	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
624463	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
624464	1/14/2019 15:09	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
624465	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
624466	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
624467	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
624468	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
624469	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
624470	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
624471	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
624472	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
624473	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
624474	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
624475	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
624476	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Broom on Site?	y	
624477	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
624478	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Operations Counter AL	752	
624479	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
624480	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Unknown Operations	0	
624481	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Tank Paint Condition	Good	
624482	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Switching Operations	0	
624483	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
624484	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Operations Counter AL	219	
624485	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Operations Counter AF	219	
624486	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Moisture and Leak Free?	y	
624487	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Maintenance Operations	0	
624488	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Heaters (All) Functioning?	y	
624489	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Grounds in Place?	y	
624490	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	General Comments		
624491	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	General Comments		
624492	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Foundation Condition	Good	
624493	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Follow-up Action Required?	n	
624494	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Follow-up Action Required?	n	
624495	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0736	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	9.52	%
624496	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0736	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
624497	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0736	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
624498	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0736	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
624499	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0736	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
624500	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
624501	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
624502	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
624503	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Operations Ground	0	
624504	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Operations C Ø	0	
624505	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Operations B Ø	0	
624506	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
624507	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
624508	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
624509	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
624510	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
624511	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Follow-up Action Required?	n	
624512	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Follow-up Action Required?	n	
624513	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Fault Operations	0	
624514	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
624515	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
624516	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
624517	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Operations A Ø	0	
624518	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
624519	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
624520	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
624521	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Equipment Properly Labeled?	y	
624522	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
624523	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
624524	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
624525	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Bushing Oil Level	Good	
624526	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
624527	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Amps C Ø	415.0	
624528	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
624529	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Switching Operations	0	
624530	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
624531	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
624532	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
624533	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Tank Leaks	None	
624534	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Tank Paint Condition	Good	
624535	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Unknown Operations	0	
624536	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0736	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	9 Month Operations	2	
624537	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0736	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	9.52	%
624538	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
624539	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Equipment Properly Labeled?	y	
624540	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Cabinet Paint Condition	Good	
624541	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Foundation Condition	Good	
624542	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	General Comments		
624543	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	General Comments		
624544	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Grounds in Place?	y	
624545	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Heaters (All) Functioning?	y	
624546	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
624547	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
624548	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
624549	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Maintenance Operations	0	
624550	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Moisture and Leak Free?	y	
624551	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Operations Counter AF	752	
624552	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
624553	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
624554	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
624555	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
624556	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
624557	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
624558	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
624559	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
624560	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Operations Counter AF	1460	
624561	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Number of Ops last 9 Months	1	
624562	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
624563	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Maintenance Operations	0	
624564	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Grounds in Place?	y	
624565	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	General Comments		
624566	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	General Comments		
624567	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Foundation Condition	Good	
624568	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0736	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	9.52	%
624569	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
624570	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
624571	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
624572	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
624573	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
624574	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
624575	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
624576	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
624577	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
624578	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
624579	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
624580	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
624581	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
624582	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Foundation Condition	Good	
624583	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Free of Audible Arcing?	n	
624584	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
624585	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	General Comments		
624586	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0736	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
624587	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0736	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
624588	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0736	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
624589	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0736	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
624590	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Unknown Operations	0	
624591	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Switching Operations	3	
624592	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Operations Counter AL	835	
624593	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Operations Counter AF	835	
624594	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0736	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
624595	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0736	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	General Comments		
624596	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Maintenance Operations	0	
624597	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	General Comments		
624598	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0736	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	General Comments		
624599	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0736	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Maintenance Operations	0	
624600	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Patrol Inspection	General Comments		
624601	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
624602	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0736	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AF	3	
624603	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0736	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AL	3	
624604	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0736	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Switching Operations	2	
624605	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0736	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Unknown Operations	0	
624606	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Patrol Inspection	Follow-up Action Required?	n	
624607	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Operations Ground	0	
624608	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Cabinet Paint Condition	Good	
624609	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
624610	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
624611	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
624612	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Bushings Connection/Risers	Good	
624613	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Bushing Condition	Good	
624614	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Amps C Ø	0.0	
624615	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Amps B Ø	0.0	
624616	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Amps A Ø	0.0	
624617	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	BCH000981	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	5.800	millivolts
624618	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	BCH000981	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	134.0	VDC
624619	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	BCH000981	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	134.0	VDC
624620	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	BCH000981	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
624621	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	BCH000981	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
624622	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	BCH000981	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
624623	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Accumulated Fault Duty C Ph V	7.28	%
624624	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Accumulated Fault Duty B Ph V	7.28	%
624625	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Accumulated Fault Duty A Ph V	7.28	%
624626	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	9 Month Operations	4	
624627	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Unknown Operations	0	
624628	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Tank Paint Condition	Good	
624629	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Tank Leaks	None	
624630	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
624631	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
624632	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
624633	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Switching Operations	1	
624634	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
624635	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Operations Counter AL	1266	
624636	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	BCH000981	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
624637	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Operations Counter AF	1266	
624638	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Number of Ops last 9 Months	1	
624639	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
624640	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Maintenance Operations	0	
624641	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Grounds in Place?	y	
624642	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	General Comments		
624643	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Amps B Ø	408.0	
624644	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Amps A Ø	405.0	
624645	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
624646	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
624647	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
624648	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
624649	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
624650	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
624651	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
624652	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
624653	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
624654	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Air Leaks	None	
624655	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Air Pressure OK?	y	
624656	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
624657	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Amps A Ø	0.0	
624658	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Amps B Ø	0.0	
624659	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Amps C Ø	0.0	
624660	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Bushing Condition	Good	
624661	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Bushing Oil Level	Good	
624662	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
624663	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
624664	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
624665	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
624666	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
624667	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
624668	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Fault Operations	0	
624669	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Follow-up Action Required?	n	
624670	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Follow-up Action Required?	n	
624671	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Foundation Condition	Good	
624672	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
624673	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	General Comments		
624674	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	General Comments		
624675	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Grounds in Place?	y	
624676	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
624677	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
624678	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Number of Ops last 9 Months	1	
624679	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Operations Counter AF	1065	
624680	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
624681	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
624682	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
624683	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
624684	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
624685	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
624686	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
624687	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
624688	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
624689	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0736	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
624690	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0736	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
624691	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0736	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
624692	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0736	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
624693	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
624694	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
624695	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
624696	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
624697	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
624698	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
624699	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
624700	1/11/2019 13:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
624701	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0769	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	9 Month Operations	0	
624702	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0769	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
624703	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0769	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
624704	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
624705	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0769	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
624706	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Amps A Ø	50.0	
624707	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Amps B Ø	50.0	
624708	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
624709	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Operations B Ø	0	
624710	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Operations C Ø	0	
624711	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Operations Ground	0	
624712	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Follow-up Action Required?	n	
624713	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Amps C Ø	50.0	
624714	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Bushing Condition	Good	
624715	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Bushing Oil Level	Good	
624716	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
624717	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Follow-up Action Required?	n	
624718	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Foundation Condition	Good	
624719	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	General Comments		
624720	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
624721	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
624722	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
624723	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
624724	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	General Comments		
624725	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Grounds in Place?	y	
624726	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
624727	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Maintenance Operations	0	
624728	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
624729	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Fault Operations	0	
624730	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Follow-up Action Required?	n	
624731	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Tank Leaks	None	
624732	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Tank 3 Oil Level	Good	
624733	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Tank 2 Oil level	Good	
624734	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Tank 1 Oil Level	Good	
624735	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
624736	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Grounds in Place?	y	
624737	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	General Comments		
624738	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Operations Counter AF	119	
624739	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Operations Counter AL	119	
624740	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
624741	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Switching Operations	3	
624742	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Tank Paint Condition	Good	
624743	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Foundation Condition	Good	
624744	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Follow-up Action Required?	n	
624745	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Equipment Properly Labeled?	y	
624746	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Unknown Operations	0	
624747	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
624748	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
624749	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
624750	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
624751	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
624752	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
624753	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
624754	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
624755	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
624756	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
624757	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	General Comments	tr needs nitro bottle empty	
624758	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
624759	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
624760	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
624761	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
624762	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
624763	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
624764	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0769	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
624765	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0769	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
624766	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0769	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
624767	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0769	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
624768	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	259	
624769	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
624770	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
624771	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
624772	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Bushing Condition	Good	
624773	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Bushing Oil Level	Good	
624774	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Unknown Operations	0	
624775	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Tank Paint Condition	Good	
624776	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Tank Leaks	None	
624777	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
624778	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
624779	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
624780	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
624781	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Amps A Ø	60.0	
624782	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Amps B Ø	61.0	
624783	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Amps C Ø	62.0	
624784	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Bushing Condition	Good	
624785	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
624786	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	Follow-up Action Required?	n	
624787	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
624788	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
624789	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	9 Month Operations	14	
624790	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Accumulated Fault Duty A Ph V	5.01	%
624791	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Amps A Ø	0.0	
624792	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Amps B Ø	0.0	
624793	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Amps C Ø	0.0	
624794	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
624795	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	General Comments		
624796	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
624797	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
624798	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Unknown Operations	0	
624799	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Switching Operations	2	
624800	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Operations Counter AL	98	
624801	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Accumulated Fault Duty B Ph V	4.12	%
624802	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Accumulated Fault Duty C Ph V	3.54	%
624803	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Operations Counter AF	98	
624804	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Maintenance Operations	0	
624805	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	General Comments		
624806	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Follow-up Action Required?	n	
624807	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Operations Ground	0	
624808	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Amps A Ø	260.0	
624809	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Operations C Ø	0	
624810	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Operations B Ø	0	
624811	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Amps B Ø	300.0	
624812	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Amps C Ø	360.0	
624813	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Patrol Inspection	Equipment Properly Labeled?	y	
624814	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
624815	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
624816	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
624817	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Operations A Ø	0	
624818	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Operations B Ø	0	
624819	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Operations C Ø	0	
624820	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Operations Ground	0	
624821	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Patrol Inspection	Follow-up Action Required?	n	
624822	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Follow-up Action Required?	n	
624823	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Patrol Inspection	General Comments		
624824	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	General Comments		
624825	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Patrol Inspection	Heaters (All) Functioning?	y	
624826	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
624827	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Operations Counter AF	147	
624828	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Operations Counter AL	147	
624829	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Switching Operations	0	
624830	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Unknown Operations	0	
624831	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
624832	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
624833	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
624834	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
624835	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
624836	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
624837	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Operations A Ø	0	
624838	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
624839	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
624840	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
624841	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Amps C Ø	0.0	
624842	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Amps B Ø	0.0	
624843	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Amps A Ø	0.0	
624844	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
624845	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
624846	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
624847	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	9 Month Operations	2	
624848	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
624849	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Operations A Ø	0	
624850	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
624851	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
624852	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
624853	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	259	
624854	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
624855	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Number of Ops last 9 Months	5	
624856	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
624857	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Fault Operations	0	
624858	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
624859	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
624860	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Follow-up Action Required?	n	
624861	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Follow-up Action Required?	n	
624862	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Foundation Condition	Good	
624863	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
624864	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
624865	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Non LTC Totalizer Reading	2628.48	kw
624866	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Maintenance Operations	0	
624867	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Grounds in Place?	y	
624868	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	General Comments		
624869	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	General Comments		
624870	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Foundation Condition	Good	
624871	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Follow-up Action Required?	n	
624872	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
624873	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Unknown Operations	0	
624874	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Switching Operations	0	
624875	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Operations Counter AL	150	
624876	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Operations Counter AF	150	
624877	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Maintenance Operations	0	
624878	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	General Comments		
624879	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Patrol Inspection	General Comments		
624880	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
624881	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
624882	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	General Comments		
624883	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Follow-up Action Required?	n	
624884	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Patrol Inspection	Follow-up Action Required?	n	
624885	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Operations Ground	0	
624886	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	General Comments		
624887	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Oil Temp Max	45	°C
624888	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Oil Temp Present	33	°C
624889	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC As Found Counter	64810	
624890	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
624891	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
624892	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
624893	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
624894	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	General Comments		
624895	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
624896	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
624897	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
624898	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
624899	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
624900	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	General Comments		
624901	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
624902	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Maintenance Operations	0	
624903	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
624904	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Number of Ops last 9 Months	1	
624905	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC As Left Counter	64810	
624906	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
624907	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC Current Tap Position	3L	
624908	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC Max Tap Position	1L	
624909	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Operations C Ø	0	
624910	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Operations Counter AF	116	
624911	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	9 Month Operations	0	
624912	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
624913	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
624914	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
624915	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Totalizer Meter Reading	.5476	
624916	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
624917	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
624918	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
624919	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
624920	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC Operations Since Last Insp	359	
624921	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
624922	1/14/2019 11:09	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC Min Tap Position	9L	
624923	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Amps A Ø	0.0	
624924	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Amps B Ø	0.0	
624925	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Amps C Ø	0.0	
624926	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Patrol Inspection	Equipment Properly Labeled?	y	
624927	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
624928	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
624929	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Operations B Ø	0	
624930	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Operations A Ø	0	
624931	1/14/2019 9:53	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
624932	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	General Comments	needs nitro	
624933	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Grounds in Place?	y	
624934	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
624935	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
624936	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Operations Counter	30	
624937	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
624938	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
624939	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Switching Operations	0	
624940	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
624941	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Operations Counter AL	116	
624942	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	9 Month Operations	5	
624943	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Accumulated Fault Duty A Ph V	10.02	%
624944	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Accumulated Fault Duty B Ph V	5.89	%
624945	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Accumulated Fault Duty C Ph V	6.48	%
624946	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Amps A Ø	350.0	
624947	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Amps B Ø	370.0	
624948	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Amps C Ø	400.0	
624949	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Patrol Inspection	Equipment Properly Labeled?	y	
624950	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
624951	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
624952	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
624953	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
624954	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Operations A Ø	1	
624955	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Operations B Ø	1	
624956	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
624957	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Operations C Ø	0	
624958	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Operations Ground	0	
624959	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Patrol Inspection	Follow-up Action Required?	n	
624960	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Follow-up Action Required?	n	
624961	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Patrol Inspection	General Comments		
624962	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	General Comments	AB Phase IOC / AB Phase HSI	
624963	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
624964	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Patrol Inspection	Heaters (All) Functioning?	y	
624965	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
624966	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
624967	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Maintenance Operations	0	
624968	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
624969	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
624970	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Operations Counter AF	180	
624971	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Operations Counter AL	180	
624972	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Switching Operations	0	
624973	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Unknown Operations	0	
624974	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
624975	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	General Comments		
624976	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
624977	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
624978	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
624979	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
624980	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
624981	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Amps C Ø	10.0	
624982	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
624983	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
624984	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	General Comments		
624985	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	General Comments		
624986	1/14/2019 12:28	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
624987	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Amps B Ø	10.0	
624988	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
624989	1/14/2019 10:38	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Amps A Ø	10.0	
624990	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
624991	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
624992	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Tank Leaks	None	
624993	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
624994	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
624995	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Unknown Operations	0	
624996	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Tank Paint Condition	Good	
624997	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Tank Leaks	None	
624998	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
624999	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
625000	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
625001	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
625002	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
625003	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
625004	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
625005	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
625006	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Switching Operations	1	
625007	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Operations Counter AL	1227	
625008	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Operations Counter AF	1227	
625009	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
625010	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	General Comments		
625011	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
625012	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Operations Counter AL	1955	
625013	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
625014	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
625015	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0769	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
625016	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
625017	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
625018	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
625019	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
625020	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0769	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
625021	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0769	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
625022	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0769	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
625023	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0769	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
625024	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Operations Counter AF	1955	
625025	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Number of Ops last 9 Months	1	
625026	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
625027	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
625028	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
625029	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
625030	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
625031	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Maintenance Operations	0	
625032	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
625033	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
625034	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
625035	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Unknown Operations	0	
625036	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
625037	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
625038	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Switching Operations	2	
625039	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
625040	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
625041	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
625042	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
625043	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
625044	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
625045	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
625046	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
625047	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
625048	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
625049	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Switching Operations	1	
625050	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Operations Counter AL	149	
625051	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Operations Counter AF	149	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
625052	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
625053	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
625054	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
625055	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
625056	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
625057	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
625058	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
625059	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
625060	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
625061	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
625062	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
625063	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
625064	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Foundation Condition	Good	
625065	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
625066	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
625067	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
625068	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
625069	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
625070	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
625071	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	943	
625072	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	9 Month Operations	4	
625073	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Accumulated Fault Duty A Ph V	1.47	%
625074	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Accumulated Fault Duty B Ph V	1.18	%
625075	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Accumulated Fault Duty C Ph V	.29	%
625076	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Amps A Ø	390.0	
625077	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Amps B Ø	360.0	
625078	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Amps C Ø	310.0	
625079	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
625080	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
625081	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
625082	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Patrol Inspection	Equipment Properly Labeled?	y	
625083	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
625084	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
625085	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
625086	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
625087	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
625088	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
625089	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
625090	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
625091	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
625092	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
625093	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
625094	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Operations A Ø	0	
625095	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Operations B Ø	0	
625096	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Operations C Ø	0	
625097	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Operations Ground	0	
625098	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Patrol Inspection	Follow-up Action Required?	n	
625099	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Follow-up Action Required?	n	
625100	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Patrol Inspection	General Comments		
625101	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	General Comments		
625102	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Patrol Inspection	Heaters (All) Functioning?	y	
625103	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Maintenance Operations	0	
625104	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Operations Counter AF	161	
625105	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Operations Counter AL	161	
625106	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Switching Operations	0	
625107	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Unknown Operations	0	
625108	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	948	
625109	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
625110	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
625111	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
625112	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
625113	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
625114	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0769	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	General Comments		
625115	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0769	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Maintenance Operations	0	
625116	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
625117	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
625118	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Operations Ground	0	
625119	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Air Leaks	None	
625120	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
625121	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Air Pressure OK?	y	
625122	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
625123	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
625124	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0	%
625125	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0	%
625126	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
625127	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
625128	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
625129	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	9 Month Operations	4	
625130	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Amps A Ø	50.0	
625131	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Tank Paint Condition	Good	
625132	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Tank Leaks	None	
625133	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
625134	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
625135	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Amps B Ø	50.0	
625136	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	LTC As Left Counter	56649	
625137	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	LTC As Found Counter	56649	
625138	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC As Found Counter	71829	
625139	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Bushing Oil Level	Good	
625140	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Bushing Condition	Good	
625141	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Amps C Ø	50.0	
625142	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
625143	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
625144	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	185	
625145	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
625146	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	General Comments		
625147	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
625148	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
625149	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC Max Tap Position	8R	
625150	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
625151	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC As Left Counter	71829	
625152	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
625153	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
625154	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Maintenance Operations	0	
625155	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
625156	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
625157	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
625158	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Unknown Operations	0	
625159	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
625160	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
625161	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
625162	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
625163	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0	
625164	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0	
625165	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
625166	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	General Comments		
625167	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Bushing Condition	Good	
625168	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
625169	1/14/2019 13:59	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
625170	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Patrol Inspection	General Comments		
625171	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
625172	1/14/2019 10:03	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0	
625173	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
625174	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
625175	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
625176	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
625177	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
625178	1/14/2019 14:17	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
625179	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0769	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
625180	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0769	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
625181	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
625182	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
625183	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
625184	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
625185	1/14/2019 10:48	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
625186	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	BCH000407	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
625187	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	BCH000407	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
625188	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	BCH000407	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
625189	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
625190	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
625191	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
625192	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
625193	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
625194	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
625195	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
625196	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
625197	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
625198	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	BCH000449	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
625199	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	BCH000449	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
625200	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	BCH000449	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.7	VDC
625201	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	BCH000449	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.7	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
625202	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCC000146	LTCControl	SSC-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
625203	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCC000146	LTCControl	SSC-Offline-Distribution	LTC Control Insp	General Comments		
625204	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCC000146	LTCControl	SSC-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
625205	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCC000146	LTCControl	SSC-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
625206	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	BCH000845	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
625207	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	BCH000845	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.7	VDC
625208	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	BCH000845	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
625209	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
625210	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
625211	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
625212	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Unknown Operations	0	
625213	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
625214	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
625215	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Bushings Connection/Risers	Good	
625216	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
625217	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
625218	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
625219	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
625220	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
625221	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
625222	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
625223	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Tank Paint Condition	Good	
625224	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Switching Operations	0	
625225	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
625226	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Maintenance Operations	0	
625227	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Operations Counter AL	283	
625228	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Bushing Condition	Good	
625229	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	VRR Time Delay	30	Seconds
625230	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Moisture and Leak Free?	y	
625231	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Operations Counter AF	227	
625232	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Amps C Ø	70.0	
625233	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Operations Counter AL	229	
625234	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	General Comments	ok	
625235	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
625236	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
625237	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
625238	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Cabinet Paint Condition	Good	
625239	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
625240	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
625241	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
625242	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Unknown Operations	0	
625243	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
625244	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Tank Paint Condition	Good	
625245	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Switching Operations	2	
625246	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	General Comments		
625247	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Maintenance Operations	1	
625248	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Equipment Properly Labeled?	y	
625249	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	General Comments	ok	
625250	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
625251	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	Follow-up Action Required?	n	
625252	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	BCH000594	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
625253	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	BCH000594	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
625254	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
625255	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Unknown Operations	0	
625256	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Follow-up Action Required?	n	
625257	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Foundation Condition	Good	
625258	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	General Comments		
625259	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	BCH000594	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
625260	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
625261	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	BCH000594	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
625262	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	BCH000594	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
625263	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	BCH000594	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
625264	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
625265	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
625266	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	General Comments		
625267	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Grounds in Place?	y	
625268	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Maintenance Operations	0	
625269	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Heaters (All) Functioning?	y	
625270	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Grounds in Place?	y	
625271	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	General Comments		
625272	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	General Comments		
625273	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Foundation Condition	Good	
625274	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Follow-up Action Required?	n	
625275	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Follow-up Action Required?	n	
625276	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	BCH000581	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
625277	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Heaters (All) Functioning?	y	
625278	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Maintenance Operations	0	
625279	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Moisture and Leak Free?	y	
625280	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Operations Ground	1	
625281	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Operations C Ø	0	
625282	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Operations B Ø	0	
625283	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Operations A Ø	0	
625284	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
625285	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Adjusted Amps C Phase V	16.96	
625286	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Adjusted Amps B Phase V	16.96	
625287	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Adjusted Amps A Phase V	16.96	
625288	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Equipment Properly Labeled?	y	
625289	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Unknown Operations	0	
625290	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Tank Paint Condition	Good	
625291	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Switching Operations	0	
625292	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
625293	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
625294	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Operations Counter	88	
625295	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
625296	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
625297	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
625298	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Switching Operations	0	
625299	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
625300	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
625301	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Amps B Ø	40.0	
625302	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Operations A Ø	0	
625303	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
625304	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Operations B Ø	0	
625305	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Operations C Ø	0	
625306	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Operations Ground	0	
625307	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Unknown Operations	0	
625308	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Amps A Ø	35.0	
625309	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Accumulated Fault Duty C Ph V	2.89	%
625310	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Operations Counter AF	283	
625311	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
625312	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
625313	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
625314	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Follow-up Action Required?	n	
625315	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Follow-up Action Required?	n	
625316	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
625317	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Accumulated Fault Duty B Ph V	2.89	%
625318	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Accumulated Fault Duty A Ph V	2.89	%
625319	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	9 Month Operations	9	
625320	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
625321	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
625322	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Foundation Condition	Good	
625323	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	General Comments	ok	
625324	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC Operations Since Last Insp	21	
625325	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC Min Tap Position	10L	
625326	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC Max Tap Position	4R	
625327	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC Current Tap Position	3L	
625328	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	General Comments	ok	
625329	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Grounds in Place?	y	
625330	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Heaters (All) Functioning?	y	
625331	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Maintenance Operations	1	
625332	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Moisture and Leak Free?	y	
625333	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Operations Counter AF	152	
625334	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
625335	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC As Left Counter	124453	
625336	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC As Found Counter	124443	
625337	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
625338	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
625339	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
625340	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
625341	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	General Comments		
625342	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
625343	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
625344	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
625345	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	General Comments		
625346	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
625347	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Operations Ground	0	
625348	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Follow-up Action Required?	n	
625349	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	General Comments	ok	
625350	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Operations B Ø	0	
625351	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
625352	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Operations C Ø	0	
625353	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Operations Ground	0	
625354	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Follow-up Action Required?	n	
625355	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Follow-up Action Required?	n	
625356	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Foundation Condition	Good	
625357	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	General Comments	ok	
625358	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	General Comments	OK	
625359	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
625360	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	54.00	
625361	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	60.0	
625362	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	60.0	
625363	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	60.0	
625364	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
625365	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
625366	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	54.00	
625367	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	54.00	
625368	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Grounds in Place?	y	
625369	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	9 Month Operations	10	
625370	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Accumulated Fault Duty A Ph V	5.06	%
625371	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
625372	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
625373	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
625374	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
625375	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Heaters (All) Functioning?	y	
625376	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Maintenance Operations	1	
625377	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Moisture and Leak Free?	y	
625378	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
625379	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Operations Counter AF	196	
625380	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
625381	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
625382	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Regulator As Left Counter	87052	
625383	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
625384	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Tank Leaks	None	
625385	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
625386	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Operations A Ø	0	
625387	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Operations B Ø	0	
625388	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Bushing Condition	Good	
625389	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Amps C Ø	15.0	
625390	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Amps B Ø	10.0	
625391	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Amps A Ø	10.0	
625392	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Accumulated Fault Duty C Ph V	.63	%
625393	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Operations C Ø	0	
625394	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Amps B Ø	200.0	
625395	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Amps A Ø	275.0	
625396	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	5.20	%
625397	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Operations Ground	0	
625398	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Accumulated Fault Duty B Ph V	.63	%
625399	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Accumulated Fault Duty A Ph V	.63	%
625400	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	9 Month Operations	4	
625401	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Follow-up Action Required?	n	
625402	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
625403	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Patrol Inspection	General Comments		
625404	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
625405	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
625406	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
625407	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
625408	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
625409	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
625410	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	200.0	
625411	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
625412	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Equipment Properly Labeled?	y	
625413	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Cabinet Paint Condition	Good	
625414	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	25	°F
625415	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
625416	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
625417	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
625418	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
625419	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
625420	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Unknown Operations	0	
625421	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Tank Paint Condition	Good	
625422	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Switching Operations	0	
625423	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
625424	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Operations Counter AL	395	
625425	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Operations Counter AF	395	
625426	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
625427	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Operations A Ø	0	
625428	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
625429	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
625430	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
625431	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
625432	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Equipment Properly Labeled?	y	
625433	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Operations C Ø	0	
625434	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Operations B Ø	0	
625435	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Operations A Ø	0	
625436	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
625437	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
625438	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
625439	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Equipment Properly Labeled?	y	
625440	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Cabinet Paint Condition	Good	
625441	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
625442	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
625443	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Cabinet Paint Condition	Good	
625444	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
625445	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
625446	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
625447	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
625448	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Bushings Connection/Risers	Good	
625449	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
625450	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
625451	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
625452	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Operations A Ø	0	
625453	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Amps C Ø	200.0	
625454	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
625455	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
625456	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
625457	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
625458	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
625459	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
625460	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Bushings Connection/Risers	Good	
625461	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
625462	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
625463	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
625464	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Regulator As Left Counter	8444	
625465	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
625466	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
625467	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Tank Leaks	None	
625468	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
625469	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Operations Counter AF	122	
625470	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Operations Counter AL	122	
625471	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
625472	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
625473	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
625474	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
625475	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	BCH000581	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
625476	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	BCH000581	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.7	VDC
625477	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	General Comments		
625478	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	LTC Operation Checked?	y	
625479	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
625480	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	BCH000581	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.7	VDC
625481	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	BCH000581	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
625482	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
625483	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
625484	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Operations B Ø	0	
625485	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Operations C Ø	0	
625486	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Operations Ground	0	
625487	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Follow-up Action Required?	n	
625488	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Operations Counter AL	196	
625489	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
625490	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Switching Operations	0	
625491	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	General Comments		
625492	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Tank Paint Condition	Good	
625493	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	General Comments		
625494	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Grounds in Place?	y	
625495	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
625496	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
625497	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Follow-up Action Required?	n	
625498	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Foundation Condition	Good	
625499	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	General Comments		
625500	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	General Comments		
625501	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
625502	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
625503	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Heaters (All) Functioning?	y	
625504	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	General Comments	ok	
625505	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Heaters (All) Functioning?	y	
625506	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	7.80	%
625507	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	7.80	%
625508	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	9 Months Operations	2	
625509	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	200.0	
625510	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	220.0	
625511	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Follow-up Action Required?	n	
625512	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Foundation Condition	Good	
625513	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
625514	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
625515	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1542	
625516	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1542	
625517	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
625518	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
625519	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
625520	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0769	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
625521	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
625522	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
625523	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
625524	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
625525	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Operations Counter AL	158	
625526	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	All Connections OK?	y	
625527	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	Follow-up Action Required?	n	
625528	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Bushings Connection/Risers	Good	
625529	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Bushing Condition	Good	
625530	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
625531	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Amps C Ø	152.0	
625532	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0769	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
625533	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0769	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	General Comments		
625534	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
625535	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
625536	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
625537	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
625538	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
625539	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
625540	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
625541	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
625542	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
625543	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Equipment Properly Labeled?	y	
625544	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Cabinet Paint Condition	Good	
625545	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
625546	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
625547	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
625548	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
625549	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
625550	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
625551	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
625552	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
625553	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
625554	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Moisture and Leak Free?	y	
625555	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
625556	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
625557	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
625558	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
625559	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
625560	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
625561	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
625562	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
625563	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	General Comments		
625564	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
625565	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
625566	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
625567	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
625568	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
625569	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
625570	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Bushing Condition	Good	
625571	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Amps C Ø	0.0	
625572	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Amps B Ø	0.0	
625573	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Amps A Ø	0.0	
625574	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Accumulated Fault Duty C Ph V	2.46	%
625575	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Accumulated Fault Duty B Ph V	3.18	%
625576	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
625577	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Accumulated Fault Duty A Ph V	6.75	%
625578	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	9 Month Operations	1	
625579	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Unknown Operations	0	
625580	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Tank Paint Condition	Good	
625581	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Switching Operations	0	
625582	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
625583	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Operations Counter AL	118	
625584	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Operations Counter AF	118	
625585	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Moisture and Leak Free?	y	
625586	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Maintenance Operations	0	
625587	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Heaters (All) Functioning?	y	
625588	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Grounds in Place?	y	
625589	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	General Comments	ok	
625590	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	General Comments	ok	
625591	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	BCH000586	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
625592	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	BCH000586	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
625593	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	BCH000586	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
625594	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Foundation Condition	Good	
625595	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Follow-up Action Required?	n	
625596	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Follow-up Action Required?	n	
625597	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Operations Ground	0	
625598	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	BCH000586	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
625599	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
625600	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	9.55	%
625601	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	8.12	%
625602	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
625603	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	5.73	%
625604	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	150.0	
625605	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Operations Since Last Insp	12	
625606	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Min Tap Position	5L	
625607	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Max Tap Position	1L	
625608	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Current Tap Position	3L	
625609	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
625610	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC As Left Counter	34459	
625611	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC As Found Counter	34449	
625612	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	140.0	
625613	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	BCH000586	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
625614	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	General Comments	ok	
625615	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	General Comments	ok	
625616	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	BCH000586	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
625617	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BCH000585	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
625618	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
625619	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BCH000585	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
625620	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BCH000585	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
625621	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BCH000585	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
625622	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BCH000585	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.3	VDC
625623	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BCH000585	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
625624	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	140.0	
625625	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
625626	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
625627	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
625628	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
625629	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
625630	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Equipment Properly Labeled?	y	
625631	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
625632	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
625633	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Cabinet Paint Condition	Good	
625634	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
625635	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
625636	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
625637	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Bushings Connection/Risers	Good	
625638	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Bushing Condition	Good	
625639	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Amps C Ø	140.0	
625640	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Amps B Ø	135.0	
625641	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Regulator As Left Counter	6058	
625642	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
625643	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
625644	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Tank Leaks	None	
625645	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
625646	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Amps A Ø	120.0	
625647	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
625648	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
625649	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Operations Counter AF	147	
625650	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Moisture and Leak Free?	y	
625651	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	VRR Time Delay	30	Seconds

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
625652	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
625653	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Maintenance Operations	3	
625654	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
625655	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Foundation Condition	Good	
625656	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
625657	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	General Comments	ok	
625658	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	BCH000576	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
625659	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	BCH000576	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
625660	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	BCH000576	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
625661	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	BCH000576	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
625662	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	BCH000576	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
625663	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	BCH000576	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
625664	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
625665	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
625666	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	9 Month Operations	7	
625667	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
625668	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
625669	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
625670	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
625671	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
625672	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
625673	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
625674	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
625675	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Amps C Ø	77.0	
625676	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Amps B Ø	84.0	
625677	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Amps A Ø	89.0	
625678	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
625679	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
625680	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
625681	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
625682	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
625683	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
625684	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
625685	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.0	VDC
625686	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	32.0	VDC
625687	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
625688	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
625689	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Bushings Connection/Risers	Good	
625690	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
625691	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
625692	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
625693	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
625694	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
625695	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
625696	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
625697	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
625698	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
625699	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
625700	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
625701	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
625702	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	All Connections OK?	y	
625703	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Heaters (All) Functioning?	y	
625704	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
625705	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
625706	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Amps C Ø	80.0	
625707	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Amps B Ø	80.0	
625708	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	General Comments		
625709	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
625710	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
625711	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
625712	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
625713	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
625714	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
625715	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
625716	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
625717	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
625718	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
625719	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
625720	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
625721	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Amps A Ø	80.0	
625722	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Accumulated Fault Duty C Ph V	2.53	%
625723	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Accumulated Fault Duty B Ph V	5.06	%
625724	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
625725	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
625726	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
625727	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Cabinet Paint Condition	Good	
625728	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
625729	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
625730	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Bushings Connection/Risers	Good	
625731	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Bushing Condition	Good	
625732	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Amps C Ø	300.0	
625733	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Amps B Ø	280.0	
625734	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Amps A Ø	300.0	
625735	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Accumulated Fault Duty C Ph V	2.04	%
625736	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
625737	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
625738	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
625739	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
625740	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
625741	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Vegetation	None	
625742	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
625743	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
625744	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
625745	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
625746	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
625747	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
625748	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
625749	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Accumulated Fault Duty B Ph V	1.70	%
625750	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Accumulated Fault Duty A Ph V	1.70	%
625751	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
625752	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
625753	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
625754	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
625755	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
625756	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
625757	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	9 Month Operations	2	
625758	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	LTC Totalizer Reading	13842.00	kw
625759	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Follow-up Action Required?	n	
625760	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
625761	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
625762	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	General Comments	NO BANK SWITCH	
625763	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
625764	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
625765	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	General Comments		
625766	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
625767	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
625768	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
625769	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
625770	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
625771	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
625772	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
625773	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Operations C Ø	0	
625774	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Operations B Ø	0	
625775	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
625776	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Operations A Ø	0	
625777	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
625778	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
625779	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
625780	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
625781	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
625782	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
625783	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
625784	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
625785	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
625786	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
625787	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
625788	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
625789	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
625790	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
625791	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
625792	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
625793	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
625794	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
625795	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99861	
625796	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
625797	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
625798	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
625799	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Clear of Trash?	y	
625800	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
625801	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
625802	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99861	
625803	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
625804	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
625805	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
625806	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
625807	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	General Comments	o	
625808	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
625809	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Cabinet Paint Condition	Good	
625810	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
625811	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
625812	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
625813	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Bushings Connection/Risers	Good	
625814	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
625815	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Bushing Condition	Good	
625816	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
625817	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
625818	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
625819	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	General Comments		
625820	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
625821	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	Follow-up Action Required?	n	
625822	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
625823	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
625824	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
625825	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
625826	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
625827	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Oil Temp Max	60	°C
625828	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
625829	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
625830	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	LTC Operation Checked?	y	
625831	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	General Comments		
625832	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	Follow-up Action Required?	n	
625833	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
625834	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
625835	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
625836	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	BCH000903	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
625837	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	BCH000581	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
625838	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
625839	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Tank Paint Condition	Good	
625840	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Switching Operations	0	
625841	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Maintenance Operations	0	
625842	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Operations Counter AF	529	
625843	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Operations Counter AL	529	
625844	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Switching Operations	0	
625845	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
625846	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Operations Counter AL	277	
625847	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Operations Counter AF	277	
625848	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Moisture and Leak Free?	y	
625849	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Maintenance Operations	0	
625850	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Heaters (All) Functioning?	y	
625851	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Accumulated Fault Duty A Ph V	2.63	%
625852	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	9 Month Operations	5	
625853	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
625854	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
625855	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
625856	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
625857	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
625858	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
625859	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	General Comments	ok	
625860	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	General Comments	ok	
625861	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Foundation Condition	Good	
625862	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Follow-up Action Required?	n	
625863	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
625864	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
625865	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
625866	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
625867	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
625868	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
625869	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
625870	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
625871	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Grounds in Place?	y	
625872	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	General Comments		
625873	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
625874	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	General Comments		
625875	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
625876	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
625877	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
625878	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Winding Temp Present	35	°C
625879	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
625880	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	General Comments		
625881	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Foundation Condition	Good	
625882	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Follow-up Action Required?	n	
625883	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Follow-up Action Required?	n	
625884	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Operations Ground	0	
625885	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Operations C Ø	0	
625886	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Operations B Ø	0	
625887	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Operations A Ø	0	
625888	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
625889	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Follow-up Action Required?	n	
625890	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Operations Ground	0	
625891	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Operations C Ø	0	
625892	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Operations B Ø	0	
625893	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
625894	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
625895	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10	
625896	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10	
625897	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.2618	
625898	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
625899	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
625900	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
625901	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Winding Temp Max	40	°C
625902	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
625903	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
625904	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
625905	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
625906	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
625907	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Regulator As Left Counter	80534	
625908	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
625909	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Tank Leaks	None	
625910	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
625911	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0480	
625912	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Tank Paint Condition	Good	
625913	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Unknown Operations	0	
625914	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
625915	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
625916	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
625917	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Operations Counter AF	158	
625918	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Moisture and Leak Free?	y	
625919	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Maintenance Operations	0	
625920	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Heaters (All) Functioning?	y	
625921	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Grounds in Place?	y	
625922	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
625923	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
625924	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
625925	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
625926	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
625927	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
625928	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Unknown Operations	0	
625929	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Tank Paint Condition	Good	
625930	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
625931	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Switching Operations	0	
625932	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
625933	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	2298	
625934	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	2298	
625935	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	5	
625936	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
625937	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
625938	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
625939	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
625940	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
625941	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
625942	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
625943	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
625944	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
625945	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
625946	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
625947	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	10060.80	kw
625948	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
625949	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
625950	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	General Comments		
625951	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
625952	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
625953	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
625954	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	General Comments		
625955	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	General Comments		
625956	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
625957	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
625958	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
625959	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	BCH000903	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
625960	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	BCH000903	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
625961	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	BCH000903	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
625962	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	BCH000903	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54	VDC
625963	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	BCH000903	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54	VDC
625964	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
625965	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
625966	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
625967	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
625968	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
625969	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Bushing Condition	Good	
625970	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Amps C Ø	70.0	
625971	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Amps B Ø	60.0	
625972	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Amps A Ø	100.0	
625973	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Accumulated Fault Duty C Ph V	1.53	%
625974	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Accumulated Fault Duty B Ph V	2.19	%
625975	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
625976	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
625977	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
625978	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
625979	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45	
625980	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50	
625981	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10	
625982	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	15.54	%
625983	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	9084.96	kw
625984	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
625985	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
625986	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
625987	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
625988	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
625989	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
625990	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	5.0	
625991	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	5.0	
625992	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	5.0	
625993	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
625994	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
625995	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
625996	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
625997	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	16.48	%
625998	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	15.06	%
625999	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
626000	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	BCH000598	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
626001	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Unknown Operations	2	
626002	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Operations A Ø	0	
626003	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
626004	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
626005	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
626006	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Accumulated Fault Duty C Ph V	2.34	%
626007	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Accumulated Fault Duty B Ph V	1.56	%
626008	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	BCH000598	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
626009	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
626010	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
626011	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
626012	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
626013	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	BCH000598	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
626014	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Accumulated Fault Duty A Ph V	1.56	%
626015	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
626016	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
626017	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	General Comments		
626018	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
626019	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
626020	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
626021	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
626022	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
626023	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Operations A Ø	0	
626024	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Operations B Ø	0	
626025	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
626026	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
626027	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Operations C Ø	0	
626028	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Operations Ground	0	
626029	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	9 Month Operations	3	
626030	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Totalizer Meter Reading	.7690	
626031	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Operations Counter AL	147	
626032	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Follow-up Action Required?	n	
626033	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Follow-up Action Required?	n	
626034	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Foundation Condition	Good	
626035	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	General Comments	ok	
626036	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	General Comments	ok	
626037	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Grounds in Place?	y	
626038	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
626039	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
626040	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
626041	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
626042	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
626043	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
626044	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
626045	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
626046	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
626047	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
626048	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
626049	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Oil Temp Present	40	°C
626050	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Oil Temp Max	50	°C
626051	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
626052	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
626053	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
626054	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
626055	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Equipment Properly Labeled?	y	
626056	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
626057	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Cabinet Paint Condition	Good	
626058	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
626059	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
626060	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
626061	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	General Comments	ok	
626062	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	General Comments	ok	
626063	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
626064	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Bushings Connection/Risers	Good	
626065	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
626066	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
626067	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
626068	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
626069	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Follow-up Action Required?	n	
626070	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
626071	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
626072	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
626073	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
626074	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
626075	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
626076	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
626077	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	120	
626078	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	120	
626079	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
626080	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
626081	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
626082	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
626083	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
626084	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
626085	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
626086	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
626087	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
626088	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
626089	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Regulator As Left Counter	8075	
626090	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
626091	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
626092	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Tank Leaks	None	
626093	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
626094	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Amps B Ø	121.0	
626095	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Amps A Ø	105.0	
626096	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Accumulated Fault Duty C Ph V	3.59	%
626097	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Accumulated Fault Duty B Ph V	3.59	%
626098	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Accumulated Fault Duty A Ph V	2.74	%
626099	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	9 Month Operations	6	
626100	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
626101	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
626102	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Winding Temp Max	65	°C
626103	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Bushing Condition	Good	
626104	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Amps C Ø	60.0	
626105	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Amps B Ø	60.0	
626106	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Amps A Ø	60.0	
626107	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
626108	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
626109	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
626110	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
626111	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
626112	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
626113	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
626114	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
626115	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
626116	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Cabinet Paint Condition	Good	
626117	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Equipment Properly Labeled?	y	
626118	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
626119	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
626120	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
626121	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Operations A Ø	0	
626122	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Operations B Ø	0	
626123	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Operations C Ø	0	
626124	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Operations Ground	0	
626125	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Follow-up Action Required?	n	
626126	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Follow-up Action Required?	n	
626127	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Foundation Condition	Good	
626128	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Accumulated Fault Duty B Ph V	22.75	%
626129	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Accumulated Fault Duty A Ph V	23.57	%
626130	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	9 Month Operations	5	
626131	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
626132	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
626133	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
626134	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
626135	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
626136	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
626137	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
626138	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
626139	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
626140	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
626141	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
626142	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
626143	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
626144	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
626145	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	General Comments		
626146	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
626147	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
626148	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Foundation Condition	Good	
626149	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
626150	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
626151	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
626152	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	General Comments		
626153	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	General Comments		
626154	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Grounds in Place?	y	
626155	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Heaters (All) Functioning?	y	
626156	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Maintenance Operations	0	
626157	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Moisture and Leak Free?	y	
626158	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Operations Counter AF	315	
626159	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Operations Counter AL	315	
626160	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Switching Operations	0	
626161	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Tank Paint Condition	Good	
626162	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
626163	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
626164	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
626165	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
626166	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	General Comments		
626167	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
626168	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
626169	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
626170	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	27.1	VDC
626171	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	27.1	VDC
626172	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.070	millivolts
626173	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
626174	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
626175	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
626176	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
626177	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
626178	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
626179	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Vegetation	None	
626180	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
626181	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
626182	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Unknown Operations	0	
626183	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Tank Paint Condition	Good	
626184	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Switching Operations	0	
626185	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
626186	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Operations Counter AL	91	
626187	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Operations Counter AF	91	
626188	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Moisture and Leak Free?	y	
626189	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Maintenance Operations	0	
626190	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Heaters (All) Functioning?	y	
626191	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Grounds in Place?	y	
626192	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	General Comments		
626193	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	General Comments		
626194	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Foundation Condition	Good	
626195	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Follow-up Action Required?	n	
626196	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Follow-up Action Required?	n	
626197	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Operations Ground	0	
626198	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Operations C Ø	0	
626199	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Operations B Ø	0	
626200	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Operations A Ø	0	
626201	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
626202	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
626203	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
626204	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Equipment Properly Labeled?	y	
626205	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Cabinet Paint Condition	Good	
626206	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
626207	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
626208	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
626209	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Bushings Connection/Risers	Good	
626210	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Bushing Condition	Good	
626211	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Amps C Ø	300.0	
626212	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Amps B Ø	300.0	
626213	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Amps A Ø	300.0	
626214	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Accumulated Fault Duty C Ph V	23.57	%
626215	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
626216	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
626217	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
626218	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
626219	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Bushing Condition	Good	
626220	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	BCH000606	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
626221	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LTCC000281	LTCControl	OX-TRANS 1	LTC Control Insp	All Connections OK?	y	
626222	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LTCC000281	LTCControl	OX-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
626223	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LTCC000281	LTCControl	OX-TRANS 1	LTC Control Insp	General Comments		
626224	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LTCC000281	LTCControl	OX-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
626225	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
626226	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
626227	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Ambient Temp	25	°F
626228	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCC000007	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	n	
626229	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCC000007	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	y	
626230	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCC000007	LTCControl	Retired Distribution	LTC Control Insp	General Comments	Will not go back in service, can it be removed from insp?	
626231	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCC000007	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
626232	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	BCH000606	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
626233	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
626234	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	General Comments		
626235	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
626236	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
626237	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
626238	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
626239	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
626240	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
626241	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
626242	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
626243	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
626244	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
626245	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
626246	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
626247	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
626248	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	BCH000606	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
626249	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
626250	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	General Comments		
626251	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
626252	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
626253	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
626254	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
626255	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
626256	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2030.4	kw
626257	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50	
626258	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45	
626259	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
626260	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	BCH000606	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
626261	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	BCH000606	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
626262	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	BCH000606	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
626263	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
626264	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
626265	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0	VDC
626266	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	4	VDC
626267	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
626268	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Vegetation	None	
626269	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
626270	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
626271	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	General Comments	ok	
626272	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
626273	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
626274	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC As Left Counter	52700	
626275	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC As Found Counter	52700	
626276	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	General Comments		
626277	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	General Comments		
626278	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
626279	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	Follow-up Action Required?	n	
626280	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Unknown Operations	0	
626281	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF001212	PowerFuse	P-14KV TR-4A AUX PWR	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
626282	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF001212	PowerFuse	P-14KV TR-4A AUX PWR	Disconnect Powerfuse Inspection	General Comments	OK	
626283	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
626284	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
626285	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Positive DC Ground	68.9	VDC
626286	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Negative DC Ground	65.6	VDC
626287	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	General Comments		
626288	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
626289	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
626290	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
626291	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
626292	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Clear of Trash?	y	
626293	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	9 Month Operations	2	
626294	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
626295	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
626296	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
626297	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Amps A Ø	410.0	
626298	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Amps B Ø	400.0	
626299	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Amps C Ø	430.0	
626300	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
626301	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
626302	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
626303	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
626304	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
626305	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
626306	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
626307	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
626308	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
626309	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
626310	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
626311	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
626312	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
626313	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
626314	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
626315	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
626316	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
626317	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
626318	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
626319	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
626320	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
626321	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
626322	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
626323	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Vegetation	None	
626324	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
626325	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Foundation Condition	Good	
626326	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
626327	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
626328	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
626329	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
626330	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
626331	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
626332	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
626333	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	9 Month Operations	11	
626334	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Accumulated Fault Duty A Ph V	2.23	%
626335	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Accumulated Fault Duty B Ph V	1.34	%
626336	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Accumulated Fault Duty C Ph V	2.68	%
626337	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Amps A Ø	60.0	
626338	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Amps B Ø	60.0	
626339	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
626340	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	General Comments		
626341	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
626342	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
626343	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
626344	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
626345	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
626346	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
626347	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Clear of Trash?	y	
626348	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
626349	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
626350	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
626351	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Amps C Ø	60.0	
626352	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Bushing Condition	Good	
626353	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Bushings Connection/Risers	Good	
626354	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
626355	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	General Comments		
626356	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
626357	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
626358	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
626359	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
626360	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
626361	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
626362	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
626363	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
626364	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
626365	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
626366	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
626367	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
626368	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
626369	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Tank Paint Condition	Good	
626370	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
626371	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Operations C Ø	0	
626372	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Operations Ground	0	
626373	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Follow-up Action Required?	n	
626374	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Follow-up Action Required?	n	
626375	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Foundation Condition	Good	
626376	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
626377	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	General Comments		
626378	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
626379	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
626380	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
626381	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
626382	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
626383	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
626384	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
626385	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
626386	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
626387	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
626388	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	General Comments		
626389	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Grounds in Place?	y	
626390	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Heaters (All) Functioning?	y	
626391	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Maintenance Operations	0	
626392	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Moisture and Leak Free?	y	
626393	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Operations Counter AF	703	
626394	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Operations Counter AL	703	
626395	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
626396	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Switching Operations	0	
626397	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Tank Paint Condition	Good	
626398	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Unknown Operations	0	
626399	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
626400	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
626401	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
626402	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
626403	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
626404	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Foundation Condition	Good	
626405	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
626406	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
626407	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
626408	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
626409	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	General Comments		
626410	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
626411	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	General Comments		
626412	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
626413	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
626414	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
626415	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
626416	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
626417	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
626418	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
626419	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
626420	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
626421	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
626422	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
626423	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
626424	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
626425	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
626426	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
626427	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
626428	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
626429	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	General Comments	ok	
626430	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
626431	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
626432	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Foundation Condition	Good	
626433	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
626434	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
626435	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
626436	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
626437	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
626438	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
626439	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
626440	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
626441	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
626442	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
626443	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
626444	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
626445	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
626446	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
626447	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC Current Tap Position	3L	
626448	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	General Comments		
626449	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
626450	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
626451	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
626452	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC As Left Counter	270149	
626453	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC As Found Counter	270149	
626454	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	General Comments		
626455	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	General Comments		
626456	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
626457	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	Follow-up Action Required?	n	
626458	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
626459	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
626460	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
626461	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Clear of Trash?	y	
626462	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
626463	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
626464	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
626465	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
626466	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
626467	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
626468	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
626469	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	5.0	amps
626470	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
626471	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
626472	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.000	millivolts
626473	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
626474	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
626475	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Grounds in Place?	y	
626476	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
626477	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Foundation Condition	Good	
626478	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Follow-up Action Required?	n	
626479	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
626480	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
626481	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
626482	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
626483	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
626484	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
626485	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Bushing Condition	Good	
626486	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
626487	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	General Comments	ok	
626488	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
626489	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
626490	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
626491	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
626492	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
626493	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
626494	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
626495	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
626496	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
626497	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
626498	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
626499	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
626500	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
626501	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
626502	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
626503	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
626504	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
626505	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
626506	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
626507	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
626508	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
626509	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
626510	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
626511	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
626512	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
626513	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC Operations Since Last Insp	373	
626514	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC Min Tap Position	4L	
626515	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC Operations Since Last Insp	817	
626516	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC Min Tap Position	6L	
626517	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC Max Tap Position	8R	
626518	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
626519	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
626520	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
626521	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
626522	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
626523	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
626524	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
626525	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
626526	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
626527	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
626528	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
626529	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
626530	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
626531	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
626532	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
626533	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
626534	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
626535	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
626536	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
626537	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
626538	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
626539	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
626540	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
626541	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
626542	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
626543	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
626544	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Follow-up Action Required?	n	
626545	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
626546	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
626547	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	General Comments		
626548	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	General Comments		
626549	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
626550	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	All Connections OK?	y	
626551	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
626552	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	General Comments		
626553	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	LTC Operation Checked?	y	
626554	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	LTC Output Voltage Level	125.1	VAC
626555	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
626556	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
626557	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	VRR Time Delay	30	Seconds
626558	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Bushing Oil Level	Good	
626559	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
626560	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Unknown Operations	0	
626561	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Switching Operations	0	
626562	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Operations Counter AL	316	
626563	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Operations Counter AF	316	
626564	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Maintenance Operations	0	
626565	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
626566	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	General Comments		
626567	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Patrol Inspection	General Comments		
626568	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Follow-up Action Required?	n	
626569	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Patrol Inspection	Follow-up Action Required?	n	
626570	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Operations Ground	0	
626571	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Operations C Ø	0	
626572	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Operations B Ø	0	
626573	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Operations A Ø	0	
626574	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
626575	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
626576	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
626577	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
626578	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
626579	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
626580	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
626581	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
626582	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
626583	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
626584	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	General Comments		
626585	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
626586	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
626587	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
626588	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Clear of Trash?	y	
626589	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
626590	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
626591	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
626592	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
626593	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
626594	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
626595	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	General Comments		
626596	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
626597	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
626598	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
626599	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Vegetation	None	
626600	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
626601	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	5R	
626602	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	5L	
626603	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
626604	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
626605	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
626606	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
626607	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
626608	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
626609	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
626610	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
626611	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
626612	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
626613	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
626614	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
626615	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Foundation Condition	Good	
626616	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
626617	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
626618	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	General Comments		
626619	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
626620	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
626621	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
626622	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
626623	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
626624	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
626625	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
626626	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
626627	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	SF6 Pressure	68	psi
626628	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
626629	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	LTC Totalizer Reading	12124.8	kw
626630	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
626631	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
626632	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Clear of Trash?	y	
626633	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
626634	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
626635	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
626636	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
626637	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
626638	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
626639	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
626640	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	LTC Totalizer Reading	5535.36	kw
626641	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
626642	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
626643	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
626644	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
626645	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Oil Temp Max	40	°C
626646	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Oil Temp Present	35	°C
626647	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
626648	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
626649	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
626650	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
626651	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
626652	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
626653	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
626654	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
626655	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
626656	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
626657	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
626658	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
626659	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
626660	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
626661	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
626662	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
626663	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
626664	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
626665	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
626666	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
626667	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Totalizer Meter Reading	.842	
626668	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Winding Temp Max	50	°C
626669	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Winding Temp Present	40	°C
626670	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	General Comments		
626671	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
626672	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
626673	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Vegetation	None	
626674	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20	
626675	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200	
626676	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	General Comments		
626677	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	General Comments		
626678	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
626679	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
626680	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Amps C Ø	1100.0	
626681	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Amps B Ø	140.0	
626682	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Amps A Ø	130.0	
626683	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
626684	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
626685	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
626686	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	9 Months Operations	0	
626687	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
626688	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
626689	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Totalizer Meter Reading	.5766	
626690	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
626691	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
626692	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
626693	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
626694	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
626695	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
626696	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
626697	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
626698	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Oil Temp Present	20	°C
626699	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Oil Temp Max	40	°C
626700	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
626701	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
626702	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
626703	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
626704	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
626705	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Fault Operations	0	
626706	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Follow-up Action Required?	n	
626707	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Follow-up Action Required?	n	
626708	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Foundation Condition	Good	
626709	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Ambient Temperature	32	°F
626710	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
626711	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
626712	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
626713	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
626714	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
626715	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Fault Operations	0	
626716	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Follow-up Action Required?	n	
626717	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Follow-up Action Required?	n	
626718	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Foundation Condition	Good	
626719	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
626720	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	General Comments	ok	
626721	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	General Comments	ok	
626722	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Grounds in Place?	y	
626723	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
626724	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Maintenance Operations	0	
626725	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
626726	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Num Operations Last 9 Months	0	
626727	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Operations Counter AF	42	
626728	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Operations Counter AL	42	
626729	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
626730	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
626731	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
626732	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
626733	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	General Comments		
626734	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
626735	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
626736	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
626737	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
626738	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Amps A Ø	0.0	
626739	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Amps B Ø	0.0	
626740	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
626741	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
626742	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC Operations Since Last Insp	88	
626743	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC Min Tap Position	5L	
626744	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC Max Tap Position	1R	
626745	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Amps C Ø	0.0	
626746	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Bushing Condition	Good	
626747	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC Current Tap Position	2R	
626748	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
626749	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC As Left Counter	119091	
626750	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC As Found Counter	119070	
626751	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	General Comments	ok	
626752	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	General Comments	ok	
626753	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
626754	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	Follow-up Action Required?	n	
626755	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
626756	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
626757	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
626758	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
626759	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	111	
626760	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
626761	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
626762	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	9L	
626763	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
626764	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
626765	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
626766	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
626767	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
626768	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
626769	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
626770	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
626771	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
626772	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Totalizer Meter Reading	.282	
626773	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Winding Temp Max	30	°C
626774	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Winding Temp Present	30	°C
626775	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
626776	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC As Left Counter	418277	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
626777	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC As Found Counter	418277	
626778	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
626779	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
626780	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
626781	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
626782	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
626783	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
626784	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
626785	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
626786	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
626787	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
626788	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
626789	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
626790	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
626791	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
626792	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	General Comments		
626793	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
626794	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Max Tap Position	12L	
626795	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Min Tap Position	2R	
626796	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
626797	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
626798	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
626799	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
626800	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
626801	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
626802	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
626803	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
626804	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
626805	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
626806	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
626807	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Regulator As Left Counter	122839	
626808	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
626809	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Tank Leaks	None	
626810	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
626811	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
626812	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	30	°F
626813	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
626814	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Switch Diagram Present/Current	y	
626815	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Panels Dusted?	y	
626816	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Panel Lights OK?	y	
626817	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments	ok	
626818	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
626819	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
626820	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
626821	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Control Handle "Red Flagged"?	n	If Bkr is Closed
626822	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
626823	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
626824	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
626825	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
626826	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
626827	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
626828	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
626829	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
626830	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
626831	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
626832	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
626833	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
626834	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
626835	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
626836	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	25	°F
626837	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
626838	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
626839	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Tank Leaks	None	
626840	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
626841	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
626842	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Regulator As Left Counter	44639	
626843	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
626844	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
626845	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
626846	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
626847	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
626848	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
626849	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
626850	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
626851	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Min Tap Position	3R	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
626852	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Max Tap Position	9L	
626853	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
626854	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	General Comments		
626855	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
626856	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
626857	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
626858	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
626859	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
626860	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
626861	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
626862	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
626863	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
626864	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
626865	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
626866	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
626867	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	1R	
626868	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
626869	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
626870	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
626871	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
626872	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
626873	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
626874	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
626875	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
626876	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
626877	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
626878	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
626879	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
626880	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
626881	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
626882	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
626883	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
626884	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
626885	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
626886	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
626887	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Evidence of Insects	None	
626888	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
626889	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
626890	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Floor Swept?	y	
626891	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
626892	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
626893	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	General Comments		
626894	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
626895	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Panels Dusted?	y	
626896	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
626897	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
626898	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
626899	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	General Comments		
626900	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
626901	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
626902	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
626903	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
626904	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
626905	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
626906	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
626907	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
626908	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
626909	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
626910	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
626911	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
626912	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
626913	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
626914	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
626915	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	35	°F
626916	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	All Connections OK?	y	
626917	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	Follow-up Action Required?	n	
626918	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	General Comments		
626919	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	LTC Operation Checked?	y	
626920	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
626921	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
626922	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
626923	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
626924	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	VRR Time Delay	30	Seconds
626925	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
626926	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
626927	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
626928	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
626929	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
626930	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	General Comments		
626931	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
626932	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
626933	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
626934	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
626935	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
626936	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
626937	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Cabinet Paint Condition	Good	
626938	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Equipment Properly Labeled?	y	
626939	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Adjusted Amps A Phase V	0	
626940	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Adjusted Amps B Phase V	0	
626941	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Adjusted Amps C Phase V	0	
626942	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Operations A Ø	0	
626943	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Operations B Ø	0	
626944	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Operations C Ø	0	
626945	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Operations Ground	0	
626946	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Follow-up Action Required?	n	
626947	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Follow-up Action Required?	n	
626948	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Foundation Condition	Good	
626949	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	General Comments		
626950	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	General Comments		
626951	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Grounds in Place?	y	
626952	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Heaters (All) Functioning?	y	
626953	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Maintenance Operations	0	
626954	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Moisture and Leak Free?	y	
626955	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Operations Counter AF	195	
626956	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Operations Counter AL	197	
626957	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Switching Operations	2	
626958	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Tank Paint Condition	Good	
626959	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Unknown Operations	0	
626960	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
626961	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	25	°F
626962	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
626963	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
626964	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
626965	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
626966	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
626967	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
626968	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
626969	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
626970	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	26.6	VDC
626971	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	29.9	VDC
626972	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
626973	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
626974	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
626975	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	LTC Operation Checked?	y	
626976	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	General Comments	ok	
626977	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	Follow-up Action Required?	n	
626978	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	All Connections OK?	y	
626979	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
626980	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
626981	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
626982	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
626983	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
626984	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
626985	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
626986	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
626987	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
626988	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
626989	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
626990	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
626991	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	9 Month Operations	4	
626992	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Accumulated Fault Duty A Ph V	5.49	%
626993	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Accumulated Fault Duty B Ph V	1.83	%
626994	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Accumulated Fault Duty C Ph V	1.83	%
626995	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Amps A Ø	170	
626996	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Amps B Ø	130	
626997	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Amps C Ø	152	
626998	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Bushing Condition	Good	
626999	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Bushings Connection/Risers	Good	
627000	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
627001	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
627002	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
627003	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Cabinet Paint Condition	Good	
627004	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Equipment Properly Labeled?	y	
627005	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Adjusted Amps A Phase V	0	
627006	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Adjusted Amps B Phase V	0	
627007	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Adjusted Amps C Phase V	0	
627008	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Operations A Ø	0	
627009	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Operations B Ø	0	
627010	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Operations C Ø	0	
627011	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Operations Ground	0	
627012	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Follow-up Action Required?	n	
627013	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Follow-up Action Required?	n	
627014	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Foundation Condition	Good	
627015	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	General Comments		
627016	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	General Comments		
627017	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Grounds in Place?	y	
627018	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Heaters (All) Functioning?	y	
627019	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Maintenance Operations	0	
627020	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Moisture and Leak Free?	y	
627021	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Operations Counter AF	195	
627022	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Operations Counter AL	197	
627023	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Switching Operations	2	
627024	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Tank Paint Condition	Good	
627025	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Unknown Operations	0	
627026	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
627027	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	9 Month Operations	4	
627028	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Accumulated Fault Duty A Ph V	0	%
627029	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Accumulated Fault Duty B Ph V	0	%
627030	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Accumulated Fault Duty C Ph V	0	%
627031	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Amps A Ø	0	
627032	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Amps B Ø	0	
627033	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Amps C Ø	0	
627034	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Bushing Condition	Good	
627035	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Bushings Connection/Risers	Good	
627036	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
627037	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
627038	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
627039	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
627040	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
627041	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC Operations Since Last Insp	825	
627042	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC Min Tap Position	8L	
627043	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC Max Tap Position	9R	
627044	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC Current Tap Position	2R	
627045	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
627046	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC As Left Counter	189163	
627047	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC As Found Counter	189163	
627048	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	General Comments		
627049	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	General Comments		
627050	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
627051	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	Follow-up Action Required?	n	
627052	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
627053	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
627054	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
627055	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
627056	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
627057	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
627058	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	General Comments	ok	
627059	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
627060	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
627061	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
627062	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
627063	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
627064	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	54.00	
627065	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	54.00	
627066	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	54.00	
627067	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
627068	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
627069	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
627070	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
627071	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	5.20	%
627072	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	5.20	%
627073	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	5.20	%
627074	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	7	
627075	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
627076	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1530	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
627077	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1530	
627078	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
627079	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
627080	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
627081	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
627082	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
627083	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
627084	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
627085	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
627086	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
627087	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
627088	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
627089	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
627090	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
627091	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
627092	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
627093	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	General Comments		
627094	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
627095	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
627096	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Foundation Condition	Good	
627097	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
627098	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
627099	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
627100	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
627101	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
627102	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
627103	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
627104	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	22.13	%
627105	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	22.13	%
627106	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	22.6	%
627107	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60	
627108	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	2	
627109	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
627110	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	782	
627111	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	782	
627112	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
627113	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
627114	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
627115	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
627116	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
627117	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
627118	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	80	
627119	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	90	
627120	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
627121	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
627122	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
627123	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
627124	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
627125	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
627126	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
627127	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
627128	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
627129	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
627130	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
627131	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
627132	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
627133	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
627134	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
627135	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
627136	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
627137	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
627138	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
627139	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
627140	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
627141	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	General Comments		
627142	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
627143	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
627144	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
627145	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
627146	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
627147	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
627148	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
627149	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
627150	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
627151	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
627152	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
627153	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
627154	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
627155	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Heaters (All) Functioning?	y	
627156	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Grounds in Place?	y	
627157	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	General Comments		
627158	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	General Comments		
627159	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Foundation Condition	Good	
627160	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Follow-up Action Required?	n	
627161	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Follow-up Action Required?	n	
627162	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Operations Ground	0	
627163	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Operations C Ø	0	
627164	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Operations B Ø	0	
627165	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Operations A Ø	0	
627166	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
627167	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
627168	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
627169	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Equipment Properly Labeled?	y	
627170	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Cabinet Paint Condition	Good	
627171	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
627172	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
627173	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
627174	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Bushings Connection/Risers	Good	
627175	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
627176	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
627177	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
627178	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC Operations Since Last Insp	16	
627179	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
627180	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC Min Tap Position	5L	
627181	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC Max Tap Position	1L	
627182	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC Current Tap Position	2L	
627183	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
627184	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC As Left Counter	270511	
627185	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC As Found Counter	270501	
627186	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	General Comments	ok	
627187	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	General Comments	ok	
627188	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
627189	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	Follow-up Action Required?	n	
627190	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Bushing Condition	Good	
627191	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Amps C Ø	294.0	
627192	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
627193	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
627194	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
627195	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
627196	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
627197	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
627198	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
627199	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
627200	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
627201	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
627202	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
627203	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
627204	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	General Comments		
627205	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
627206	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
627207	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Foundation Condition	Good	
627208	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
627209	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
627210	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
627211	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
627212	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
627213	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
627214	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	General Comments		
627215	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
627216	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
627217	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
627218	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
627219	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
627220	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Vegetation	None	
627221	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
627222	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
627223	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
627224	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	General Comments		
627225	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
627226	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
627227	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
627228	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
627229	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
627230	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
627231	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Clear of Trash?	y	
627232	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
627233	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
627234	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
627235	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Unknown Operations	0	
627236	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Tank Paint Condition	Good	
627237	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Switching Operations	0	
627238	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Operations Counter AL	256	
627239	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Operations Counter AF	256	
627240	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Moisture and Leak Free?	y	
627241	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Maintenance Operations	0	
627242	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
627243	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC Operations Since Last Insp	16	
627244	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.5	psi
627245	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC Min Tap Position	4L	
627246	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC Max Tap Position	1L	
627247	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC Current Tap Position	3L	
627248	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
627249	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC As Left Counter	14468	
627250	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC As Found Counter	14468	
627251	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	General Comments		
627252	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	General Comments		
627253	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
627254	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	Follow-up Action Required?	n	
627255	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
627256	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
627257	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
627258	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
627259	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
627260	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
627261	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
627262	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
627263	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
627264	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
627265	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
627266	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
627267	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
627268	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
627269	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
627270	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
627271	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
627272	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
627273	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
627274	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
627275	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
627276	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
627277	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
627278	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
627279	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
627280	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
627281	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
627282	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
627283	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
627284	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
627285	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
627286	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	General Comments	ok	
627287	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
627288	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
627289	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Foundation Condition	Good	
627290	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
627291	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
627292	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	VRR Time Delay	30	Seconds
627293	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	VRR Base Voltage AL	12.0	VAC
627294	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Amps B Ø	292.0	
627295	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Amps A Ø	282.0	
627296	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
627297	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
627298	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
627299	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
627300	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Broom on Site?	y	
627301	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Control House Lighting OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
627302	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
627303	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Door Alarms OK?	y	
627304	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Doors and Locks Secure?	y	
627305	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Evidence of Insects	None	
627306	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
627307	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Floor Condition Acceptable?	y	
627308	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Floor Swept?	y	
627309	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Follow-up Action Required?	n	
627310	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
627311	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	General Comments		
627312	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Moisture and Leak Free?	y	
627313	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Panel Lights OK?	y	
627314	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Panels Dusted?	y	
627315	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Station Ground Set On Site?	y	
627316	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Switch Diagram Present/Current	y	
627317	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Trash Emptied?	y	
627318	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Ventilation Free of Debris?	y	
627319	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
627320	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Accumulated Fault Duty A Ph V	1.19	%
627321	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	9 Month Operations	1	
627322	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Amps A Ø	127	
627323	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Amps B Ø	82	
627324	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Amps C Ø	139	
627325	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
627326	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
627327	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
627328	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
627329	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
627330	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
627331	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
627332	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
627333	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
627334	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
627335	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	General Comments		
627336	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
627337	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
627338	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Operations Counter	94	
627339	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
627340	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Tank Leaks	None	
627341	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
627342	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
627343	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
627344	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
627345	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
627346	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
627347	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
627348	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Clear of Trash?	y	
627349	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
627350	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
627351	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
627352	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
627353	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
627354	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
627355	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
627356	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	BCH000399	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
627357	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
627358	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
627359	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
627360	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	General Comments		
627361	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	General Comments		
627362	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
627363	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
627364	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
627365	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
627366	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	10545.6	kw
627367	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50	
627368	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45	
627369	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Oil Temp Max	40	°C
627370	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Oil Temp Present	30	°C
627371	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
627372	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
627373	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
627374	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
627375	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
627376	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
627377	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
627378	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
627379	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Totalizer Meter Reading	1.0985	
627380	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Winding Temp Max	55	°C
627381	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Winding Temp Present	45	°C
627382	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
627383	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Air Leaks	None	
627384	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Air Pressure OK?	y	
627385	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
627386	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
627387	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
627388	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
627389	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
627390	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
627391	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
627392	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
627393	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
627394	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
627395	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	y	
627396	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
627397	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
627398	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1932	
627399	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1924	
627400	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Adjusted Amps C Phase V	0	
627401	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Adjusted Amps B Phase V	0	
627402	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Adjusted Amps A Phase V	0	
627403	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Equipment Properly Labeled?	y	
627404	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Cabinet Paint Condition	Good	
627405	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
627406	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
627407	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
627408	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Bushings Connection/Risers	Good	
627409	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Bushing Condition	Good	
627410	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Amps C Ø	300	
627411	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Amps B Ø	310	
627412	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Amps A Ø	320	
627413	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Accumulated Fault Duty C Ph V	7.32	%
627414	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Accumulated Fault Duty B Ph V	7.32	%
627415	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Accumulated Fault Duty A Ph V	7.32	%
627416	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	9 Month Operations	15	
627417	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
627418	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
627419	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
627420	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
627421	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
627422	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
627423	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
627424	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
627425	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
627426	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
627427	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
627428	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
627429	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
627430	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Vegetation	None	
627431	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
627432	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
627433	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	General Comments	ok	
627434	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
627435	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
627436	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
627437	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	BCH000399	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
627438	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	BCH000399	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
627439	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	BCH000399	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
627440	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	BCH000399	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.8	VDC
627441	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	BCH000399	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.8	VDC
627442	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
627443	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
627444	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
627445	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
627446	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
627447	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
627448	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Ambient Temp	24	°F
627449	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
627450	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
627451	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Clear of Trash?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
627452	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
627453	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
627454	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
627455	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	General Comments	ok	
627456	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	General Comments	ok	
627457	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
627458	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
627459	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.5	psi
627460	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Oil Temp Max	0	°C
627461	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Oil Temp Present	0	°C
627462	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
627463	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
627464	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
627465	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
627466	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	9 Month Operations	4	
627467	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
627468	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
627469	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
627470	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Amps A Ø	100.0	
627471	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Amps B Ø	100.0	
627472	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Amps C Ø	100.0	
627473	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Bushing Condition	Good	
627474	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Bushings Connection/Risers	Good	
627475	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
627476	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
627477	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
627478	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	General Comments		
627479	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
627480	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Vegetation	None	
627481	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
627482	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
627483	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
627484	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
627485	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Cabinet Paint Condition	Good	
627486	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Equipment Properly Labeled?	y	
627487	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
627488	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
627489	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
627490	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
627491	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
627492	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Winding Temp Max	15	°C
627493	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Winding Temp Present	5	°C
627494	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
627495	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
627496	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
627497	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Operations A Ø	0	
627498	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Operations B Ø	0	
627499	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
627500	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
627501	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	Follow-up Action Required?	n	
627502	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
627503	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	General Comments		
627504	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	General Comments	vented	
627505	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC As Found Counter	40040	
627506	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC As Left Counter	40042	
627507	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
627508	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC Current Tap Position	1L	
627509	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC Max Tap Position	10L	
627510	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC Min Tap Position	1R	
627511	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0	psi
627512	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
627513	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	45	°C
627514	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC Operations Since Last Insp	493	
627515	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
627516	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
627517	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
627518	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
627519	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
627520	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
627521	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
627522	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
627523	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
627524	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
627525	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
627526	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
627527	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
627528	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
627529	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
627530	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
627531	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Follow-up Action Required?	n	
627532	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
627533	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
627534	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	General Comments	Would not reset with a magnet	
627535	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
627536	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
627537	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
627538	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	Oil Temp Max	80	°C
627539	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	Oil Temp Present	25	°C
627540	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
627541	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
627542	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
627543	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
627544	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
627545	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
627546	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
627547	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
627548	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
627549	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	85.00	
627550	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
627551	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
627552	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Unknown Operations	0	
627553	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Tank Paint Condition	Good	
627554	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Switching Operations	4	
627555	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
627556	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Operations Counter AL	388	
627557	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Operations Counter AF	377	
627558	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Moisture and Leak Free?	y	
627559	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Maintenance Operations	7	
627560	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Heaters (All) Functioning?	y	
627561	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Grounds in Place?	y	
627562	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Ambient Temp	31	°F
627563	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
627564	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
627565	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Clear of Trash?	y	
627566	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
627567	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
627568	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
627569	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
627570	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
627571	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
627572	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	General Comments		
627573	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
627574	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
627575	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Vegetation	None	
627576	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
627577	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
627578	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
627579	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
627580	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
627581	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
627582	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	General Comments	Changed out trip coil	
627583	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	General Comments		
627584	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Foundation Condition	Good	
627585	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Follow-up Action Required?	n	
627586	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Follow-up Action Required?	n	
627587	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Operations Ground	0	
627588	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Operations C Ø	0	
627589	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Operations B Ø	0	
627590	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Operations A Ø	0	
627591	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
627592	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
627593	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
627594	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
627595	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	General Comments		
627596	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Negative DC Ground	.2	VDC
627597	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Positive DC Ground	.2	VDC
627598	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
627599	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Foundation Condition	Good	
627600	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
627601	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
627602	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
627603	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
627604	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
627605	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
627606	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	General Comments		
627607	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
627608	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
627609	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Ambient Temp	26	°F
627610	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
627611	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
627612	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
627613	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
627614	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
627615	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	General Comments		
627616	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
627617	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
627618	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
627619	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	n	
627620	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Vegetation	None	
627621	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	180.0	
627622	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	175.0	
627623	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	135.0	
627624	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
627625	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
627626	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
627627	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
627628	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
627629	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
627630	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
627631	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
627632	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
627633	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
627634	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
627635	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
627636	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
627637	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
627638	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
627639	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
627640	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
627641	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
627642	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
627643	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
627644	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
627645	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
627646	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
627647	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
627648	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	General Comments		
627649	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
627650	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
627651	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	34	°F
627652	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
627653	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
627654	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Cabinet Paint Condition	Good	
627655	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
627656	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
627657	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
627658	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Bushings Connection/Risers	Good	
627659	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Bushing Condition	Good	
627660	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Amps C Ø	10.0	
627661	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Amps B Ø	10.0	
627662	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Amps A Ø	20.0	
627663	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Accumulated Fault Duty C Ph V	1.38	%
627664	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
627665	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
627666	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	9 Month Operations	1	
627667	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
627668	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
627669	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
627670	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
627671	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
627672	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
627673	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
627674	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
627675	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
627676	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
627677	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
627678	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	Oil Temp Present	50	°C
627679	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
627680	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
627681	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-8.0	psi
627682	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
627683	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
627684	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Nitro gauge reads 8.0, but TR is in vacuum. Six pac is empty	
627685	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	General Comments		
627686	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
627687	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
627688	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
627689	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
627690	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
627691	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
627692	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
627693	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
627694	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
627695	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
627696	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
627697	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	5	
627698	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
627699	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
627700	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
627701	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
627702	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
627703	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
627704	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
627705	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	General Comments		
627706	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
627707	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
627708	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
627709	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Unknown Operations	0	
627710	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Tank Paint Condition	Good	
627711	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Switching Operations	0	
627712	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
627713	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Operations Counter AL	201	
627714	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Operations Counter AF	201	
627715	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Moisture and Leak Free?	y	
627716	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
627717	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
627718	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
627719	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
627720	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
627721	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
627722	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
627723	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
627724	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
627725	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Maintenance Operations	0	
627726	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Heaters (All) Functioning?	y	
627727	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Grounds in Place?	y	
627728	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	General Comments		
627729	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	General Comments		
627730	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Foundation Condition	Good	
627731	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Follow-up Action Required?	n	
627732	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Follow-up Action Required?	n	
627733	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
627734	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
627735	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	All Connections OK?	y	
627736	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	Follow-up Action Required?	n	
627737	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	General Comments		
627738	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	LTC Operation Checked?	y	
627739	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
627740	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
627741	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
627742	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	VRR Time Delay	30	Seconds
627743	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Operations Ground	0	
627744	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Operations C Ø	0	
627745	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Operations B Ø	0	
627746	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Operations A Ø	0	
627747	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
627748	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
627749	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
627750	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Equipment Properly Labeled?	y	
627751	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
627752	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
627753	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	General Comments		
627754	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
627755	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
627756	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
627757	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	210.0	
627758	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	200.0	
627759	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	220.0	
627760	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	11.62	%
627761	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	13.40	%
627762	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	14.74	%
627763	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
627764	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
627765	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
627766	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
627767	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
627768	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
627769	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
627770	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
627771	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
627772	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
627773	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
627774	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
627775	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
627776	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
627777	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
627778	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	General Comments	ok	
627779	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
627780	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Foundation Condition	Good	
627781	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
627782	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
627783	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
627784	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
627785	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
627786	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
627787	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
627788	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Unknown Operations	0	
627789	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Tank Paint Condition	Good	
627790	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Switching Operations	0	
627791	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
627792	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Operations Counter AL	153	
627793	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
627794	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
627795	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Clear of Trash?	y	
627796	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
627797	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
627798	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
627799	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
627800	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
627801	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
627802	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	General Comments		
627803	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
627804	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
627805	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
627806	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Vegetation	None	
627807	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
627808	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
627809	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
627810	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
627811	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Clear of Trash?	y	
627812	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
627813	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
627814	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Ambient Temp	25	°F
627815	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
627816	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Tank Leaks	None	
627817	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
627818	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
627819	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Regulator As Left Counter	6761	
627820	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
627821	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
627822	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
627823	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
627824	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
627825	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
627826	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Max Tap Position	10L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
627827	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
627828	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
627829	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
627830	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	General Comments		
627831	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
627832	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
627833	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
627834	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
627835	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Current Tap Position	9L	
627836	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
627837	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
627838	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
627839	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
627840	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
627841	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
627842	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
627843	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
627844	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
627845	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
627846	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
627847	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
627848	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
627849	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
627850	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
627851	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
627852	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
627853	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
627854	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
627855	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
627856	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
627857	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
627858	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
627859	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
627860	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
627861	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
627862	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
627863	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
627864	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
627865	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	General Comments		
627866	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
627867	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
627868	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
627869	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
627870	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
627871	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
627872	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
627873	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
627874	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
627875	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
627876	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
627877	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Clear of Trash?	y	
627878	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
627879	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
627880	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
627881	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
627882	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
627883	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
627884	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	General Comments		
627885	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
627886	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Vegetation	None	
627887	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
627888	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
627889	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	34	°F
627890	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
627891	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
627892	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Unknown Operations	0	
627893	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Tank Paint Condition	Good	
627894	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Switching Operations	0	
627895	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Operations Counter AL	180	
627896	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Operations Counter AF	180	
627897	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Moisture and Leak Free?	y	
627898	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Maintenance Operations	0	
627899	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Grounds in Place?	y	
627900	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	General Comments		
627901	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
627902	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Foundation Condition	Good	
627903	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Follow-up Action Required?	n	
627904	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Follow-up Action Required?	n	
627905	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations Ground	0	
627906	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations C Ø	1	
627907	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations B Ø	0	
627908	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations A Ø	0	
627909	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Adjusted Amps C Phase V	2.94	
627910	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
627911	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
627912	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
627913	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
627914	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
627915	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
627916	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
627917	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
627918	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
627919	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
627920	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
627921	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
627922	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Follow-up Action Required?	n	
627923	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
627924	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
627925	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	General Comments	ok	
627926	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	General Comments	ok	
627927	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
627928	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	LTC Totalizer Reading	1905.12	kw
627929	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
627930	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
627931	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Oil Temp Max	35	°C
627932	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Oil Temp Present	35	°C
627933	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
627934	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
627935	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
627936	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
627937	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
627938	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
627939	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
627940	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
627941	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Totalizer Meter Reading	.7938	
627942	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	220.00	
627943	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
627944	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
627945	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
627946	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
627947	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
627948	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
627949	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
627950	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
627951	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
627952	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
627953	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
627954	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
627955	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
627956	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
627957	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
627958	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
627959	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
627960	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
627961	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
627962	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Max Tap Position	11L	
627963	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Min Tap Position	3L	
627964	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
627965	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
627966	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
627967	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
627968	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
627969	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Regulator As Left Counter	105754	
627970	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
627971	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
627972	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Tank Leaks	None	
627973	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
627974	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	All Connections OK?	y	
627975	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	Follow-up Action Required?	n	
627976	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	General Comments	ok	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
627977	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	LTC Operation Checked?	y	
627978	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	LTC Output Voltage Level	113.7	VAC
627979	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
627980	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	VRR Base Voltage AF	112.0	VAC
627981	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	VRR Base Voltage AL	112.0	VAC
627982	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	VRR Time Delay	45	Seconds
627983	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
627984	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
627985	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
627986	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
627987	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	6L	
627988	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
627989	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
627990	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
627991	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	57	°F
627992	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
627993	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	9 Month Operations	8	
627994	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Accumulated Fault Duty A Ph V	1.45	%
627995	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Accumulated Fault Duty B Ph V	1.45	%
627996	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Accumulated Fault Duty C Ph V	1.45	%
627997	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Amps A Ø	200.0	
627998	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
627999	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Tank Leaks	None	
628000	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
628001	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
628002	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
628003	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
628004	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
628005	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
628006	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Regulator As Left Counter	1246	
628007	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
628008	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
628009	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
628010	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
628011	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
628012	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Min Tap Position	14L	
628013	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Totalizer Meter Reading	1.8300	
628014	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Winding Temp Max	55	°C
628015	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	267932	
628016	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	122.2	volts
628017	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
628018	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
628019	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
628020	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
628021	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	10L	
628022	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	2R	
628023	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
628024	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
628025	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
628026	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
628027	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
628028	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
628029	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
628030	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
628031	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
628032	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
628033	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
628034	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
628035	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
628036	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	General Comments		
628037	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
628038	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Max Tap Position	12L	
628039	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Min Tap Position	Neutral	
628040	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
628041	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
628042	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
628043	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
628044	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
628045	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Regulator As Left Counter	69879	
628046	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
628047	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
628048	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Tank Leaks	None	
628049	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
628050	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
628051	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	VRR Time Delay	45	Seconds

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
628052	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
628053	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
628054	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
628055	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
628056	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
628057	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
628058	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
628059	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
628060	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
628061	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
628062	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	General Comments		
628063	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
628064	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
628065	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
628066	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
628067	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
628068	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
628069	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	34	°F
628070	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
628071	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
628072	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
628073	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Tank Leaks	None	
628074	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
628075	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Operations A Ø	0	
628076	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Operations B Ø	0	
628077	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Operations C Ø	0	
628078	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Operations Ground	0	
628079	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Follow-up Action Required?	n	
628080	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Follow-up Action Required?	n	
628081	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Foundation Condition	Good	
628082	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	General Comments		
628083	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	General Comments		
628084	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Grounds in Place?	y	
628085	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Heaters (All) Functioning?	y	
628086	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Maintenance Operations	0	
628087	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Moisture and Leak Free?	y	
628088	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Operations Counter AF	360	
628089	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Operations Counter AL	362	
628090	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Switching Operations	2	
628091	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Tank Paint Condition	Good	
628092	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Unknown Operations	0	
628093	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Amps A Ø	0.0	
628094	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Accumulated Fault Duty C Ph V	17.93	%
628095	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Accumulated Fault Duty B Ph V	17.93	%
628096	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Accumulated Fault Duty A Ph V	17.93	%
628097	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	9 Month Operations	2	
628098	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
628099	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
628100	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
628101	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
628102	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	9	
628103	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	9	
628104	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
628105	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
628106	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
628107	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
628108	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Vegetation	None	
628109	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
628110	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
628111	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	General Comments		
628112	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
628113	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
628114	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
628115	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Max Tap Position	11L	
628116	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
628117	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Amps B Ø	185.0	
628118	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Amps C Ø	200.0	
628119	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Bushing Condition	Good	
628120	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Bushings Connection/Risers	Good	
628121	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
628122	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
628123	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
628124	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	General Comments		
628125	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
628126	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
628127	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
628128	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
628129	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Current Tap Position	13L	
628130	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
628131	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
628132	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Cabinet Paint Condition	Good	
628133	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Equipment Properly Labeled?	y	
628134	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
628135	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
628136	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
628137	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
628138	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
628139	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
628140	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
628141	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
628142	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
628143	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
628144	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
628145	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Current Tap Position	1L	
628146	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
628147	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
628148	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
628149	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
628150	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	General Comments		
628151	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
628152	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Max Tap Position	10L	
628153	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Min Tap Position	3R	
628154	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
628155	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
628156	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
628157	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
628158	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
628159	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Regulator As Left Counter	41502	
628160	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
628161	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
628162	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	8.2	VDC
628163	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	8.2	VDC
628164	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
628165	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
628166	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
628167	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
628168	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
628169	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
628170	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
628171	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
628172	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
628173	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
628174	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	General Comments		
628175	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
628176	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
628177	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Foundation Condition	Good	
628178	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
628179	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
628180	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
628181	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
628182	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
628183	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
628184	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Maintenance Operations	0	
628185	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
628186	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
628187	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
628188	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
628189	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Totalizer Meter Reading	1.0120	
628190	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
628191	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
628192	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Moisture and Leak Free?	y	
628193	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Operations Counter AF	323	
628194	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Operations Counter AL	232	
628195	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Switching Operations	0	
628196	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Tank Paint Condition	Good	
628197	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Unknown Operations	0	
628198	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
628199	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
628200	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
628201	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
628202	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
628203	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
628204	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	236	
628205	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	236	
628206	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
628207	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
628208	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
628209	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
628210	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Operations B Ø	0	
628211	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Operations A Ø	0	
628212	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Adjusted Amps C Phase V	6.41	
628213	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Adjusted Amps B Phase V	6.41	
628214	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Adjusted Amps A Phase V	6.41	
628215	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Equipment Properly Labeled?	y	
628216	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Cabinet Paint Condition	Good	
628217	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
628218	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
628219	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
628220	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
628221	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
628222	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
628223	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
628224	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
628225	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
628226	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
628227	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Cabinet Paint Condition	Good	
628228	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Equipment Properly Labeled?	y	
628229	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
628230	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Adjusted Amps B Phase V	11.99	
628231	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
628232	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Operations A Ø	0	
628233	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Operations B Ø	2	
628234	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Operations C Ø	0	
628235	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Operations Ground	0	
628236	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Follow-up Action Required?	n	
628237	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Follow-up Action Required?	n	
628238	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Foundation Condition	Good	
628239	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	Follow-up Action Required?	n	
628240	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	General Comments		
628241	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	General Comments		
628242	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Grounds in Place?	y	
628243	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Heaters (All) Functioning?	y	
628244	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
628245	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
628246	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	General Comments		
628247	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Oil Temp Max	60	°C
628248	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Oil Temp Present	30	°C
628249	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
628250	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
628251	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
628252	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
628253	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Follow-up Action Required?	n	
628254	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Eyewash Solution	Good	
628255	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
628256	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
628257	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
628258	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
628259	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
628260	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Battery Overall Condition	Good	
628261	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
628262	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
628263	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	All Connections OK?	y	
628264	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
628265	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
628266	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
628267	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
628268	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
628269	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
628270	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
628271	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
628272	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Cabinet Paint Condition	Good	
628273	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Equipment Properly Labeled?	y	
628274	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
628275	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
628276	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
628277	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Operations A Ø	0	
628278	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Operations B Ø	0	
628279	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Operations C Ø	0	
628280	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Operations Ground	0	
628281	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Follow-up Action Required?	n	
628282	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Follow-up Action Required?	n	
628283	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Foundation Condition	Good	
628284	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	General Comments	ok	
628285	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	General Comments	ok	
628286	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Grounds in Place?	y	
628287	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Heaters (All) Functioning?	y	
628288	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Maintenance Operations	1	
628289	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Moisture and Leak Free?	y	
628290	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Operations Counter AF	212	
628291	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Operations Counter AL	212	
628292	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
628293	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Switching Operations	0	
628294	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Tank Paint Condition	Good	
628295	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Unknown Operations	0	
628296	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Accumulated Fault Duty A Ph V	.63	%
628297	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Accumulated Fault Duty B Ph V	.63	%
628298	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Accumulated Fault Duty C Ph V	.84	%
628299	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Amps A Ø	20.0	
628300	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Amps B Ø	50.0	
628301	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	As Found Float Voltage	135.0	VDC
628302	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	A.C. Ripple on Batteries	4.400	millivolts
628303	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Amps C Ø	70.0	
628304	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Bushing Condition	Good	
628305	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Bushings Connection/Risers	Good	
628306	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
628307	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
628308	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
628309	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Cabinet Paint Condition	Good	
628310	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Equipment Properly Labeled?	y	
628311	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
628312	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
628313	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
628314	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
628315	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
628316	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
628317	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
628318	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
628319	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
628320	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
628321	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
628322	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Bushings Connection/Risers	Good	
628323	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Bushing Condition	Good	
628324	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Amps C Ø	205.0	
628325	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Amps B Ø	213.0	
628326	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Amps A Ø	205.0	
628327	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Accumulated Fault Duty C Ph V	.48	%
628328	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Accumulated Fault Duty B Ph V	.48	%
628329	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Accumulated Fault Duty A Ph V	.48	%
628330	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	9 Month Operations	7	
628331	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
628332	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
628333	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
628334	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
628335	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Totalizer Meter Reading	.6130	
628336	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
628337	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
628338	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
628339	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
628340	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
628341	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
628342	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
628343	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
628344	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
628345	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
628346	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
628347	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
628348	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
628349	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
628350	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
628351	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
628352	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
628353	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
628354	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
628355	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
628356	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	Ground Lights	None	
628357	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	General Comments		
628358	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	Follow-up Action Required?	n	
628359	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
628360	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	Battery Charger Current	4.4	amps
628361	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	As Left Float Voltage	135.0	VDC
628362	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	9 Month Operations	8	
628363	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Accumulated Fault Duty A Ph V	.86	%
628364	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Accumulated Fault Duty B Ph V	.86	%
628365	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Accumulated Fault Duty C Ph V	1.24	%
628366	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Amps A Ø	46.0	
628367	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Amps B Ø	40.0	
628368	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Amps C Ø	33.0	
628369	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	9 Month Operations	6	
628370	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Bushing Condition	Good	
628371	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Bushings Connection/Risers	Good	
628372	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Winding Temp Max	45	°C
628373	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
628374	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	LTC Totalizer Reading	6072.00	kw
628375	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
628376	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
628377	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Totalizer Meter Reading	.7280	
628378	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
628379	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Top Oil Temperature Max	45	°C
628380	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
628381	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
628382	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
628383	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
628384	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
628385	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
628386	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
628387	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
628388	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
628389	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
628390	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	LTC Totalizer Reading	10483.20	kw
628391	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
628392	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	36	°F
628393	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
628394	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
628395	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
628396	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
628397	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
628398	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
628399	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
628400	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
628401	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC Operations Since Last Insp	878	
628402	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC Min Tap Position	2R	
628403	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC Max Tap Position	10L	
628404	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
628405	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
628406	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC As Left Counter	429320	
628407	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC As Found Counter	429317	
628408	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	General Comments		
628409	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	General Comments		
628410	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
628411	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
628412	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
628413	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.2	VDC
628414	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.2	VDC
628415	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
628416	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
628417	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
628418	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	General Comments		
628419	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	General Comments		
628420	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
628421	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
628422	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Follow-up Action Required?	n	
628423	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Adjusted Amps B Phase V	0	
628424	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Adjusted Amps A Phase V	0	
628425	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Equipment Properly Labeled?	y	
628426	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
628427	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
628428	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
628429	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
628430	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Bushings Connection/Risers	Good	
628431	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Bushing Condition	Good	
628432	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Amps C Ø	230	
628433	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Amps B Ø	218	
628434	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Amps A Ø	224	
628435	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Accumulated Fault Duty C Ph V	.44	%
628436	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Accumulated Fault Duty B Ph V	.22	%
628437	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Accumulated Fault Duty A Ph V	0	%
628438	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	9 Month Operations	4	
628439	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
628440	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
628441	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
628442	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
628443	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
628444	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	2.0	VDC
628445	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	2.0	VDC
628446	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
628447	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
628448	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Follow-up Action Required?	n	
628449	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
628450	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
628451	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	General Comments		
628452	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	General Comments		
628453	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
628454	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	LTC Totalizer Reading	4904.00	kw
628455	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
628456	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
628457	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Oil Temp Max	45	°C
628458	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Oil Temp Present	20	°C
628459	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
628460	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
628461	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
628462	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
628463	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
628464	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
628465	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
628466	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
628467	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Follow-up Action Required?	n	
628468	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
628469	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
628470	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	General Comments		
628471	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	General Comments		
628472	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
628473	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
628474	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Winding Temp Present	20	°C
628475	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Heaters (All) Functioning?	y	
628476	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Grounds in Place?	y	
628477	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	General Comments		
628478	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	General Comments		
628479	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Foundation Condition	Good	
628480	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Follow-up Action Required?	n	
628481	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Follow-up Action Required?	n	
628482	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Operations Ground	0	
628483	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Operations C Ø	0	
628484	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	General Comments		
628485	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
628486	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
628487	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
628488	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
628489	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	9	
628490	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1138	
628491	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1138	
628492	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
628493	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
628494	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
628495	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
628496	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
628497	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
628498	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	9 Month Operations	10	
628499	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
628500	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Accumulated Fault Duty B Ph V	1.79	%
628501	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
628502	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Amps A Ø	200.0	
628503	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Amps B Ø	210.0	
628504	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Amps C Ø	190.0	
628505	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Bushing Condition	Good	
628506	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Bushings Connection/Risers	Good	
628507	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
628508	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
628509	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
628510	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.87	%
628511	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.43	%
628512	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.43	%
628513	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
628514	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
628515	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
628516	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
628517	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
628518	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
628519	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
628520	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
628521	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
628522	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
628523	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
628524	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
628525	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
628526	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
628527	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
628528	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
628529	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
628530	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
628531	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
628532	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
628533	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
628534	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
628535	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
628536	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
628537	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
628538	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
628539	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	36	°F
628540	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
628541	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
628542	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
628543	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
628544	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
628545	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
628546	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
628547	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
628548	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
628549	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
628550	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
628551	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
628552	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	BAT000582	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
628553	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	10.0	
628554	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	20.0	
628555	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	20.0	
628556	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
628557	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
628558	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
628559	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
628560	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
628561	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
628562	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
628563	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
628564	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
628565	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
628566	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
628567	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
628568	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
628569	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
628570	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Unknown Operations	1	
628571	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Tank Paint Condition	Good	
628572	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Switching Operations	2	
628573	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
628574	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Operations Counter AL	219	
628575	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Operations Counter AF	217	
628576	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
628577	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Maintenance Operations	0	
628578	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
628579	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
628580	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
628581	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
628582	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
628583	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
628584	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
628585	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
628586	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
628587	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
628588	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
628589	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
628590	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
628591	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
628592	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	General Comments		
628593	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
628594	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Amps B Ø	80.0	
628595	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Amps C Ø	80.0	
628596	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Bushing Condition	Good	
628597	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Bushings Connection/Risers	Good	
628598	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
628599	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
628600	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
628601	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Cabinet Paint Condition	Good	
628602	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Equipment Properly Labeled?	y	
628603	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Adjusted Amps A Phase V	33.91	
628604	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
628605	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
628606	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Operations A Ø	2	
628607	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Operations B Ø	0	
628608	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Operations C Ø	0	
628609	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
628610	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
628611	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
628612	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
628613	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
628614	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
628615	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
628616	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
628617	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
628618	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
628619	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
628620	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
628621	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
628622	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	General Comments	ok	
628623	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
628624	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
628625	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
628626	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Totalizer Meter Reading	.6174	
628627	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
628628	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
628629	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
628630	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
628631	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
628632	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
628633	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
628634	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
628635	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
628636	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
628637	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	General Comments		
628638	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
628639	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
628640	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
628641	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
628642	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
628643	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
628644	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
628645	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	General Comments		
628646	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
628647	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
628648	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
628649	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
628650	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
628651	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
628652	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
628653	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
628654	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
628655	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
628656	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Follow-up Action Required?	n	
628657	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
628658	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
628659	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	General Comments	OK	
628660	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	General Comments	OK	
628661	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
628662	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	LTC Totalizer Reading	4445.28	kw
628663	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
628664	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
628665	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Oil Temp Max	60	°C
628666	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Oil Temp Present	45	°C
628667	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
628668	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
628669	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
628670	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
628671	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
628672	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
628673	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
628674	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	General Comments		
628675	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
628676	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
628677	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
628678	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
628679	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
628680	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
628681	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
628682	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
628683	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	36	°F
628684	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
628685	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
628686	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
628687	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
628688	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
628689	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
628690	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
628691	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
628692	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Bushing Condition	Good	
628693	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Amps C Ø	425.0	
628694	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Amps B Ø	480.0	
628695	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Amps A Ø	435.0	
628696	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
628697	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
628698	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Accumulated Fault Duty A Ph V	2.31	%
628699	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	9 Month Operations	1	
628700	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
628701	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
628702	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
628703	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
628704	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	General Comments		
628705	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
628706	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
628707	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
628708	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
628709	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
628710	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
628711	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
628712	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	°F
628713	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
628714	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Unknown Operations	0	
628715	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Tank Paint Condition	Good	
628716	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Switching Operations	0	
628717	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
628718	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Operations Counter AL	56	
628719	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Operations Counter AF	56	
628720	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Moisture and Leak Free?	y	
628721	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Maintenance Operations	0	
628722	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
628723	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Grounds in Place?	y	
628724	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	General Comments	ok	
628725	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	General Comments	ok	
628726	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
628727	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Follow-up Action Required?	n	
628728	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Follow-up Action Required?	n	
628729	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Operations Ground	0	
628730	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Operations C Ø	0	
628731	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Operations Ground	0	
628732	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Follow-up Action Required?	n	
628733	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Follow-up Action Required?	n	
628734	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Foundation Condition	Good	
628735	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	General Comments		
628736	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	General Comments		
628737	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Grounds in Place?	y	
628738	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Heaters (All) Functioning?	y	
628739	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Maintenance Operations	0	
628740	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Moisture and Leak Free?	y	
628741	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Operations Counter AF	441	
628742	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Operations Counter AL	441	
628743	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
628744	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Switching Operations	0	
628745	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Tank Paint Condition	Good	
628746	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Unknown Operations	0	
628747	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	9 Month Operations	4	
628748	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Accumulated Fault Duty A Ph V	.34	%
628749	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Accumulated Fault Duty B Ph V	.68	%
628750	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Unknown Operations	0	
628751	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Tank Paint Condition	Good	
628752	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Switching Operations	1	
628753	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Operations Counter AL	187	
628754	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Operations Counter AF	187	
628755	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
628756	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Maintenance Operations	0	
628757	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
628758	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
628759	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Amps A Ø	160.0	
628760	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Amps B Ø	160.0	
628761	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Grounds in Place?	y	
628762	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	General Comments		
628763	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	General Comments		
628764	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Foundation Condition	Good	
628765	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Follow-up Action Required?	n	
628766	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Follow-up Action Required?	n	
628767	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Operations Ground	0	
628768	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Operations C Ø	0	
628769	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Operations B Ø	0	
628770	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Amps C Ø	160.0	
628771	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Operations A Ø	0	
628772	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
628773	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
628774	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
628775	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
628776	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
628777	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
628778	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	General Comments		
628779	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
628780	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
628781	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
628782	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
628783	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BCH000879	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
628784	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BCH000879	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
628785	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BCH000879	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
628786	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Operations A Ø	0	
628787	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Operations B Ø	0	
628788	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
628789	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Tank Leaks	None	
628790	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
628791	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Operations C Ø	0	
628792	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
628793	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Vegetation	None	
628794	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
628795	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	General Comments		
628796	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
628797	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
628798	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
628799	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
628800	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
628801	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
628802	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Clear of Trash?	y	
628803	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
628804	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
628805	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
628806	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	General Comments		
628807	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	General Comments		
628808	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
628809	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
628810	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Follow-up Action Required?	n	
628811	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
628812	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
628813	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
628814	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
628815	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
628816	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
628817	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
628818	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
628819	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
628820	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
628821	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
628822	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
628823	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6906	
628824	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
628825	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
628826	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
628827	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
628828	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
628829	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
628830	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
628831	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
628832	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
628833	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Oil Temp Max	58	°C
628834	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
628835	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
628836	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
628837	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
628838	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	General Comments		
628839	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
628840	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
628841	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Foundation Condition	Good	
628842	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
628843	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
628844	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
628845	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
628846	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
628847	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
628848	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
628849	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
628850	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Grounds in Place?	y	
628851	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Maintenance Operations	0	
628852	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
628853	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
628854	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
628855	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
628856	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Current Tap Position	4R	
628857	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
628858	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
628859	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
628860	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
628861	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	General Comments		
628862	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
628863	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Max Tap Position	8L	
628864	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
628865	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
628866	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
628867	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Min Tap Position	4R	
628868	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
628869	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
628870	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
628871	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
628872	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
628873	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Regulator As Left Counter	122013	
628874	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
628875	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
628876	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
628877	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
628878	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
628879	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
628880	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
628881	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	General Comments		
628882	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BCH000879	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
628883	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BCH000879	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
628884	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BCH000879	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
628885	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BCH000879	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
628886	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Operations Ground	0	
628887	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Follow-up Action Required?	n	
628888	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Follow-up Action Required?	n	
628889	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Foundation Condition	Good	
628890	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	General Comments		
628891	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	General Comments		
628892	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Grounds in Place?	y	
628893	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Heaters (All) Functioning?	y	
628894	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Maintenance Operations	0	
628895	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Moisture and Leak Free?	y	
628896	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Operations Counter AF	215	
628897	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Operations Counter AL	215	
628898	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
628899	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Switching Operations	0	
628900	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Tank Paint Condition	Good	
628901	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Unknown Operations	0	
628902	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
628903	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
628904	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
628905	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
628906	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
628907	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
628908	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
628909	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
628910	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
628911	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
628912	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC Operations Since Last Insp	570	
628913	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1	psi
628914	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC Min Tap Position	9L	
628915	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC Max Tap Position	1R	
628916	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC Current Tap Position	5L	
628917	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
628918	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC As Left Counter	23160	
628919	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC As Found Counter	23160	
628920	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	General Comments		
628921	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	General Comments		
628922	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
628923	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	Follow-up Action Required?	n	
628924	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
628925	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
628926	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
628927	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
628928	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
628929	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
628930	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
628931	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	9 Month Operations	10	
628932	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Accumulated Fault Duty A Ph V	17.69	%
628933	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Accumulated Fault Duty B Ph V	5.06	%
628934	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Accumulated Fault Duty C Ph V	3.79	%
628935	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Amps A Ø	80.0	
628936	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
628937	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
628938	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	207.50	
628939	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	552.48	kw
628940	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
628941	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
628942	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
628943	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
628944	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	General Comments		
628945	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	General Comments		
628946	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
628947	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
628948	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
628949	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
628950	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
628951	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
628952	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
628953	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
628954	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Operations Ground	0	
628955	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Follow-up Action Required?	n	
628956	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Follow-up Action Required?	n	
628957	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Foundation Condition	Good	
628958	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	General Comments		
628959	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	General Comments		
628960	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Grounds in Place?	y	
628961	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
628962	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Maintenance Operations	0	
628963	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
628964	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Operations Counter AF	155	
628965	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Operations Counter AL	155	
628966	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Switching Operations	0	
628967	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Tank Paint Condition	Good	
628968	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Unknown Operations	0	
628969	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	9 Month Operations	6	
628970	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Accumulated Fault Duty A Ph V	10.11	%
628971	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Accumulated Fault Duty B Ph V	8.85	%
628972	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Accumulated Fault Duty C Ph V	2.53	%
628973	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Amps A Ø	70.0	
628974	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Amps B Ø	50.0	
628975	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Amps C Ø	65.0	
628976	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Bushing Condition	Good	
628977	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Bushings Connection/Risers	Good	
628978	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
628979	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
628980	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
628981	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Cabinet Paint Condition	Good	
628982	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Equipment Properly Labeled?	y	
628983	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Adjusted Amps A Phase V	16.96	
628984	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
628985	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
628986	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Operations A Ø	1	
628987	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Operations B Ø	0	
628988	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Operations C Ø	0	
628989	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Follow-up Action Required?	n	
628990	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
628991	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
628992	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
628993	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
628994	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Tank Leaks	None	
628995	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
628996	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
628997	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Regulator As Left Counter	7479	
628998	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
628999	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
629000	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
629001	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
629002	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
629003	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
629004	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Max Tap Position	9L	
629005	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
629006	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
629007	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
629008	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
629009	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
629010	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
629011	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
629012	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
629013	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
629014	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
629015	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
629016	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
629017	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
629018	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
629019	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
629020	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
629021	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
629022	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
629023	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
629024	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	32	°F
629025	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
629026	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
629027	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
629028	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
629029	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
629030	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
629031	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
629032	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
629033	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	General Comments		
629034	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
629035	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
629036	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
629037	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
629038	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	General Comments		
629039	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
629040	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Operations Counter AF	220	
629041	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Operations Counter AL	220	
629042	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
629043	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Switching Operations	0	
629044	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Tank Paint Condition	Good	
629045	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Unknown Operations	0	
629046	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Totalizer Meter Reading	.4590	
629047	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
629048	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
629049	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
629050	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
629051	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
629052	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1387	
629053	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1387	
629054	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
629055	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
629056	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
629057	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
629058	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
629059	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
629060	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
629061	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
629062	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
629063	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
629064	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
629065	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
629066	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
629067	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	360.0	
629068	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	360.0	
629069	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
629070	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Number of Ops last 9 Months	0	
629071	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Operations Counter AF	1695	
629072	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Operations Counter AL	1696	
629073	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
629074	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Switching Operations	0	
629075	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
629076	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
629077	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
629078	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Tank Leaks	None	
629079	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Tank Paint Condition	Good	
629080	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Unknown Operations	0	
629081	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
629082	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Oil Temp Present	15	°C
629083	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Oil Temp Max	20	°C
629084	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	750	psi
629085	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
629086	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
629087	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	LTC Totalizer Reading	6609.60	kw
629088	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
629089	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	General Comments		
629090	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	General Comments		
629091	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
629092	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	31.6	VDC
629093	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	37.0	VDC
629094	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
629095	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
629096	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
629097	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
629098	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
629099	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
629100	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
629101	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
629102	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
629103	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
629104	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Follow-up Action Required?	n	
629105	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
629106	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
629107	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
629108	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	General Comments		
629109	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	General Comments	DOES NOT HAVE BANK SWITCH	
629110	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
629111	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	LTC Totalizer Reading	26352.00	kw
629112	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
629113	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
629114	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Oil Temp Max	15	°C
629115	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	All Connections OK?	y	
629116	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	Follow-up Action Required?	n	
629117	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	General Comments	ok	
629118	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	LTC Operation Checked?	y	
629119	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	LTC Output Voltage Level	113.7	VAC
629120	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
629121	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
629122	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
629123	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
629124	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
629125	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
629126	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
629127	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
629128	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	VRR Base Voltage AF	112.0	VAC
629129	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	VRR Base Voltage AL	112.0	VAC
629130	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	VRR Time Delay	45	Seconds
629131	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	All Connections OK?	y	
629132	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	Follow-up Action Required?	n	
629133	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	General Comments	ok	
629134	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	LTC Operation Checked?	y	
629135	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	LTC Output Voltage Level	113.7	VAC
629136	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
629137	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	VRR Base Voltage AF	112.0	VAC
629138	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	VRR Base Voltage AL	112.0	VAC
629139	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
629140	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
629141	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
629142	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
629143	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
629144	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
629145	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Current Tap Position	12L	
629146	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
629147	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
629148	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
629149	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
629150	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
629151	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	330.0	
629152	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
629153	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
629154	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
629155	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
629156	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
629157	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
629158	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
629159	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
629160	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
629161	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
629162	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
629163	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
629164	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
629165	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
629166	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
629167	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
629168	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
629169	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
629170	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
629171	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
629172	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	22	
629173	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
629174	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
629175	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
629176	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
629177	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
629178	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
629179	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
629180	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
629181	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
629182	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
629183	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
629184	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
629185	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
629186	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
629187	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
629188	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
629189	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	General Comments		
629190	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
629191	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Switching Operations	0	
629192	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Tank Paint Condition	Good	
629193	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	BAT000578	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
629194	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Bushing Condition	Good	
629195	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Amps C Ø	0.0	
629196	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Amps B Ø	0.0	
629197	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Unknown Operations	0	
629198	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Tank Paint Condition	Good	
629199	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Switching Operations	2	
629200	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Operations Counter AL	185	
629201	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Operations Counter AF	183	
629202	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Moisture and Leak Free?	y	
629203	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Maintenance Operations	0	
629204	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Grounds in Place?	y	
629205	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	General Comments		
629206	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	General Comments		
629207	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Foundation Condition	Good	
629208	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Follow-up Action Required?	n	
629209	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Follow-up Action Required?	n	
629210	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Operations Ground	0	
629211	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Operations C Ø	0	
629212	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Operations B Ø	0	
629213	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Operations A Ø	0	
629214	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Adjusted Amps C Phase V	0	
629215	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Adjusted Amps B Phase V	0	
629216	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Adjusted Amps A Phase V	0	
629217	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Equipment Properly Labeled?	y	
629218	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Cabinet Paint Condition	Good	
629219	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
629220	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
629221	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
629222	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Bushings Connection/Risers	Good	
629223	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Bushing Condition	Good	
629224	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Amps C Ø	259	
629225	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Amps B Ø	208	
629226	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Amps A Ø	255	
629227	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Accumulated Fault Duty C Ph V	0	%
629228	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Accumulated Fault Duty B Ph V	0	%
629229	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Accumulated Fault Duty A Ph V	0	%
629230	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	9 Month Operations	4	
629231	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
629232	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
629233	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
629234	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
629235	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
629236	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
629237	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BCH000369	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
629238	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BCH000369	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
629239	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
629240	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BCH000369	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
629241	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BCH000369	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
629242	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BCH000369	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
629243	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BCH000369	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
629244	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
629245	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Amps A Ø	125	
629246	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Amps B Ø	140	
629247	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Amps C Ø	145	
629248	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
629249	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
629250	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
629251	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
629252	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
629253	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
629254	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
629255	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
629256	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
629257	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
629258	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	General Comments		
629259	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
629260	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
629261	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Operations Counter	924	
629262	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
629263	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Tank Leaks	None	
629264	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
629265	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
629266	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	°F
629267	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
629268	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
629269	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
629270	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
629271	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
629272	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
629273	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
629274	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
629275	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	General Comments		
629276	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
629277	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
629278	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BCH000386	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
629279	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BCH000386	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
629280	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BCH000386	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
629281	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BCH000386	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
629282	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BCH000386	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
629283	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	BCH000386	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
629284	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
629285	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
629286	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Operations B Ø	0	
629287	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Operations A Ø	0	
629288	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
629289	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
629290	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
629291	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
629292	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
629293	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
629294	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
629295	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
629296	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Bushings Connection/Risers	Good	
629297	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
629298	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
629299	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
629300	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
629301	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
629302	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Bushing Condition	Good	
629303	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Bushings Connection/Risers	Good	
629304	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
629305	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
629306	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
629307	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
629308	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
629309	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
629310	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
629311	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
629312	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Cabinet Paint Condition	Good	
629313	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Equipment Properly Labeled?	y	
629314	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
629315	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
629316	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Foundation Condition	Good	
629317	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
629318	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
629319	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	General Comments		
629320	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
629321	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
629322	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
629323	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
629324	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
629325	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
629326	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
629327	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
629328	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations A Ø	0	
629329	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations B Ø	0	
629330	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations C Ø	0	
629331	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations Ground	0	
629332	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Follow-up Action Required?	n	
629333	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Follow-up Action Required?	n	
629334	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Foundation Condition	Good	
629335	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	General Comments		
629336	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	General Comments		
629337	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
629338	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Grounds in Place?	y	
629339	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Heaters (All) Functioning?	y	
629340	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Maintenance Operations	0	
629341	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Moisture and Leak Free?	y	
629342	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
629343	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
629344	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
629345	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
629346	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
629347	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
629348	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
629349	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
629350	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
629351	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
629352	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
629353	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
629354	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
629355	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
629356	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
629357	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
629358	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
629359	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
629360	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
629361	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
629362	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
629363	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
629364	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
629365	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
629366	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
629367	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Winding Temp Present	6	°C
629368	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Winding Temp Max	10	°C
629369	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
629370	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
629371	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
629372	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
629373	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
629374	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
629375	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
629376	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
629377	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
629378	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
629379	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
629380	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
629381	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
629382	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
629383	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	Oil Temp Present	20	°C
629384	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	Oil Temp Max	50	°C
629385	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
629386	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
629387	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
629388	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	General Comments	ok	
629389	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	General Comments	ok	
629390	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
629391	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
629392	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	Follow-up Action Required?	n	
629393	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
629394	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
629395	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
629396	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
629397	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
629398	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
629399	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
629400	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	General Comments	ok	
629401	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
629402	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
629403	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
629404	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
629405	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
629406	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
629407	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
629408	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
629409	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
629410	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
629411	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
629412	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
629413	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
629414	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
629415	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
629416	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	72	
629417	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	72	
629418	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
629419	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
629420	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
629421	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
629422	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
629423	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
629424	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
629425	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
629426	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
629427	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCC000091	LTCControl	P-TRANS 4A	LTC Control Insp	Follow-up Action Required?	n	
629428	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCC000091	LTCControl	P-TRANS 4A	LTC Control Insp	General Comments		
629429	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCC000091	LTCControl	P-TRANS 4A	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
629430	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
629431	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
629432	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
629433	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
629434	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
629435	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
629436	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
629437	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
629438	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
629439	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
629440	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	34	
629441	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	9 Month Operations	8	
629442	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Accumulated Fault Duty A Ph V	1.02	%
629443	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Accumulated Fault Duty B Ph V	.68	%
629444	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Accumulated Fault Duty C Ph V	.68	%
629445	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Amps A Ø	247.0	
629446	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Amps B Ø	258.0	
629447	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Amps C Ø	276.0	
629448	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Bushing Condition	Good	
629449	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Bushings Connection/Risers	Good	
629450	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
629451	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
629452	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
629453	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
629454	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6L	
629455	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
629456	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
629457	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC As Left Counter	114912	
629458	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC As Found Counter	114912	
629459	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
629460	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	General Comments		
629461	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
629462	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
629463	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
629464	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	General Comments		
629465	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
629466	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
629467	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
629468	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
629469	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
629470	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
629471	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Clear of Trash?	y	
629472	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
629473	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
629474	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
629475	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
629476	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
629477	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
629478	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
629479	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
629480	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
629481	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
629482	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
629483	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Ambient Temp	27	°F
629484	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
629485	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
629486	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
629487	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
629488	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
629489	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
629490	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
629491	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
629492	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
629493	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
629494	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	General Comments		
629495	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
629496	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
629497	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Foundation Condition	Good	
629498	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
629499	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
629500	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
629501	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
629502	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
629503	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
629504	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
629505	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
629506	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
629507	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
629508	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
629509	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
629510	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
629511	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
629512	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
629513	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	9 Month Operations	1	
629514	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
629515	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
629516	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
629517	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Amps A Ø	68.0	
629518	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Amps B Ø	50.0	
629519	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Amps C Ø	82.0	
629520	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Bushing Condition	Good	
629521	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Bushings Connection/Risers	Good	
629522	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
629523	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000277	PowerFuse	P-14KV BUS SEC 1-A POT	Disconnect Powerfuse Inspection	General Comments	OK	
629524	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000277	PowerFuse	P-14KV BUS SEC 1-A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
629525	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
629526	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
629527	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Cabinet Paint Condition	Good	
629528	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Equipment Properly Labeled?	y	
629529	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
629530	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
629531	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
629532	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Operations A Ø	0	
629533	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Operations B Ø	0	
629534	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Operations C Ø	0	
629535	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Operations Ground	0	
629536	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Follow-up Action Required?	n	
629537	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Follow-up Action Required?	n	
629538	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Foundation Condition	Good	
629539	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	General Comments		
629540	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	General Comments		
629541	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Grounds in Place?	y	
629542	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Maintenance Operations	0	
629543	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Moisture and Leak Free?	y	
629544	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Operations Counter AF	226	
629545	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Operations Counter AL	226	
629546	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
629547	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Switching Operations	0	
629548	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Tank Paint Condition	Good	
629549	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Unknown Operations	0	
629550	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	LTCC000107	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
629551	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	LTCC000107	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
629552	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	LTCC000107	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
629553	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	LTCC000107	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
629554	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	LTCC000107	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
629555	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	LTCC000107	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
629556	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	General Comments		
629557	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	All Connections OK?	y	
629558	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
629559	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Cabinet Paint Condition	Good	
629560	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Equipment Properly Labeled?	y	
629561	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Adjusted Amps A Phase V	4.56	
629562	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
629563	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
629564	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Operations A Ø	1	
629565	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Operations B Ø	0	
629566	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Operations C Ø	0	
629567	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Operations Ground	0	
629568	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Follow-up Action Required?	n	
629569	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Follow-up Action Required?	n	
629570	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Foundation Condition	Good	
629571	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	General Comments		
629572	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	General Comments		
629573	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Grounds in Place?	y	
629574	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Maintenance Operations	0	
629575	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Moisture and Leak Free?	y	
629576	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Operations Counter AF	234	
629577	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Operations Counter AL	234	
629578	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
629579	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Switching Operations	0	
629580	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Tank Paint Condition	Good	
629581	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Unknown Operations	0	
629582	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
629583	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
629584	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
629585	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC Operations Since Last Insp	76	
629586	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC Min Tap Position	4L	
629587	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
629588	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC Current Tap Position	1L	
629589	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
629590	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC As Left Counter	524379	
629591	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC As Found Counter	524368	
629592	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	General Comments	ok	
629593	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	LTCC000107	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
629594	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	LTCC000107	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
629595	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	General Comments	ok	
629596	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
629597	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	Follow-up Action Required?	n	
629598	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
629599	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
629600	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
629601	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
629602	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
629603	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
629604	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
629605	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
629606	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
629607	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
629608	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
629609	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000281	PowerFuse	P-1381 POT	Disconnect Powerfuse Inspection	General Comments	OK	
629610	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000281	PowerFuse	P-1381 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
629611	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
629612	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
629613	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125	volts
629614	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Regulator As Left Counter	65827	
629615	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
629616	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
629617	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Tank Leaks	None	
629618	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
629619	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
629620	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.39	%
629621	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.91	%
629622	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.91	%
629623	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	80	
629624	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	90	
629625	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	90	
629626	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
629627	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
629628	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
629629	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
629630	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
629631	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
629632	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
629633	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
629634	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
629635	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
629636	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
629637	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
629638	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
629639	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
629640	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
629641	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
629642	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
629643	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Ambient Temperature	32	°F
629644	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Bushings Connection/Risers	Good	
629645	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
629646	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
629647	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Cabinet Paint Condition	Good	
629648	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Equipment Properly Labeled?	y	
629649	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Fault Operations	0	
629650	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Follow-up Action Required?	n	
629651	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Follow-up Action Required?	n	
629652	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Foundation Condition	Good	
629653	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Gauge(s) Condition	Good	
629654	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	General Comments	ok	
629655	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	General Comments	ok	
629656	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Grounds in Place?	y	
629657	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Heaters (All) Functioning?	y	
629658	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Maintenance Operations	0	
629659	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Foundation Condition	Good	
629660	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Follow-up Action Required?	n	
629661	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Follow-up Action Required?	n	
629662	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Operations Ground	0	
629663	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Operations C Ø	0	
629664	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
629665	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
629666	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
629667	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
629668	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
629669	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
629670	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
629671	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Readings	General Comments		
629672	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
629673	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
629674	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
629675	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
629676	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
629677	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
629678	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
629679	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
629680	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
629681	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
629682	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
629683	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
629684	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
629685	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
629686	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
629687	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	General Comments		
629688	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
629689	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Max Tap Position	10L	
629690	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Min Tap Position	Neutral	
629691	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
629692	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
629693	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
629694	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
629695	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125	volts
629696	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Regulator As Left Counter	33777	
629697	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
629698	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
629699	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Tank Leaks	None	
629700	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
629701	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
629702	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
629703	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
629704	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
629705	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
629706	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
629707	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
629708	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
629709	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
629710	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
629711	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	General Comments		
629712	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
629713	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Max Tap Position	10L	
629714	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Min Tap Position	Neutral	
629715	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
629716	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
629717	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
629718	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
629719	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Foundation Condition	Good	
629720	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
629721	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
629722	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
629723	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
629724	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
629725	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
629726	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
629727	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Vegetation	None	
629728	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
629729	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
629730	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	General Comments		
629731	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
629732	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
629733	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
629734	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
629735	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
629736	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
629737	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Amps A Ø	80	
629738	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Amps B Ø	85	
629739	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Amps C Ø	80	
629740	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
629741	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
629742	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
629743	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
629744	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
629745	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
629746	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
629747	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
629748	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
629749	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
629750	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	General Comments		
629751	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
629752	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
629753	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Operations Counter	1820	
629754	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
629755	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Tank Leaks	None	
629756	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
629757	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	47	
629758	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	51	
629759	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
629760	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
629761	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
629762	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
629763	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
629764	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
629765	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
629766	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
629767	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
629768	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
629769	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	339	
629770	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Operations B Ø	0	
629771	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Moisture and Leak Free?	y	
629772	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Num Operations Last 9 Months	2	
629773	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Operations Counter AF	60	
629774	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Operations Counter AL	60	
629775	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	SF6 Bushing Condition	Good	
629776	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	SF6 Pressure	68	psi

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
629777	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
629778	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Switching Operations	0	
629779	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Tank Paint Condition	Good	
629780	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Operations A Ø	0	
629781	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Adjusted Amps C Phase V	0	
629782	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Adjusted Amps B Phase V	0	
629783	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Adjusted Amps A Phase V	0	
629784	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Equipment Properly Labeled?	y	
629785	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Cabinet Paint Condition	Good	
629786	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
629787	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
629788	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
629789	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
629790	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
629791	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Bushings Connection/Risers	Good	
629792	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Bushing Condition	Good	
629793	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Amps C Ø	137	
629794	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
629795	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
629796	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
629797	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
629798	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
629799	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
629800	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	138	
629801	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	142	
629802	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
629803	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
629804	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
629805	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
629806	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Amps B Ø	124	
629807	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Amps A Ø	150	
629808	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Accumulated Fault Duty C Ph V	.37	%
629809	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Accumulated Fault Duty B Ph V	.37	%
629810	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Accumulated Fault Duty A Ph V	.74	%
629811	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	9 Month Operations	1	
629812	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
629813	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
629814	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
629815	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
629816	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
629817	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
629818	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
629819	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
629820	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
629821	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
629822	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	General Comments		
629823	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
629824	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
629825	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
629826	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
629827	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
629828	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
629829	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
629830	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
629831	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
629832	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
629833	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
629834	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
629835	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
629836	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
629837	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
629838	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
629839	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
629840	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
629841	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
629842	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
629843	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
629844	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
629845	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	9 Month Operations	7	
629846	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Accumulated Fault Duty A Ph V	1.95	%
629847	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Accumulated Fault Duty B Ph V	3.25	%
629848	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Accumulated Fault Duty C Ph V	1.3	%
629849	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Amps A Ø	10	
629850	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Amps B Ø	10	
629851	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Amps C Ø	15	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
629852	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Bushing Condition	Good	
629853	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Bushings Connection/Risers	Good	
629854	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
629855	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
629856	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
629857	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Cabinet Paint Condition	Good	
629858	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Equipment Properly Labeled?	y	
629859	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Adjusted Amps A Phase V	0	
629860	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
629861	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
629862	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
629863	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
629864	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
629865	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
629866	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
629867	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
629868	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	General Comments		
629869	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
629870	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
629871	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Foundation Condition	Good	
629872	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
629873	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
629874	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
629875	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
629876	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
629877	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
629878	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
629879	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	All Connections OK?	y	
629880	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	Follow-up Action Required?	n	
629881	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	General Comments	ok	
629882	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	LTC Operation Checked?	y	
629883	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
629884	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
629885	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
629886	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	VRR Time Delay	30	Seconds
629887	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
629888	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	General Comments		
629889	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
629890	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
629891	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Foundation Condition	Good	
629892	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
629893	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
629894	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
629895	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
629896	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
629897	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
629898	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
629899	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
629900	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
629901	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
629902	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120	
629903	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120	
629904	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100	
629905	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.43	%
629906	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	3.82	%
629907	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.87	%
629908	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
629909	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
629910	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	Reset Tap Drag Hands	Reset	
629911	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
629912	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	LTC Operations Since Last Insp	0	
629913	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	LTC Min Tap Position	4R	
629914	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	LTC Max Tap Position	8R	
629915	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	LTC Current Tap Position	6R	
629916	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
629917	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	LTC As Left Counter	90954	
629918	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	LTC As Found Counter	90954	
629919	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	General Comments	LTC Veeder counter not working	
629920	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Mechanism Patrol Inspection	General Comments		
629921	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	Follow-up Action Required?	y	
629922	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
629923	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
629924	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
629925	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
629926	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
629927	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	844	
629928	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	844	
629929	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
629930	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
629931	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
629932	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Amps A Ø	30.0	
629933	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Amps B Ø	100.0	
629934	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Amps C Ø	80.0	
629935	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
629936	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
629937	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
629938	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
629939	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Operations A Ø	0	
629940	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Operations B Ø	0	
629941	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Operations C Ø	0	
629942	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Operations Ground	0	
629943	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Patrol Inspection	Follow-up Action Required?	n	
629944	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Follow-up Action Required?	n	
629945	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
629946	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Amps A Ø	180.0	
629947	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Amps B Ø	140.0	
629948	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Amps C Ø	140.0	
629949	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Bushing Condition	Good	
629950	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Bushings Connection/Risers	Good	
629951	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
629952	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
629953	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Patrol Inspection	General Comments		
629954	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	General Comments		
629955	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
629956	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Maintenance Operations	0	
629957	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Operations Counter AF	323	
629958	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Operations Counter AL	323	
629959	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Switching Operations	0	
629960	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Unknown Operations	0	
629961	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	9 Month Operations	2	
629962	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Accumulated Fault Duty A Ph V	1.18	%
629963	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Accumulated Fault Duty B Ph V	1.18	%
629964	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
629965	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Amps A Ø	100.0	
629966	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Amps B Ø	100.0	
629967	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Amps C Ø	100.0	
629968	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
629969	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
629970	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
629971	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Cabinet Paint Condition	Good	
629972	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Equipment Properly Labeled?	y	
629973	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
629974	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
629975	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
629976	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Fault Operations A Ø	0	
629977	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Fault Operations B Ø	0	
629978	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Fault Operations C Ø	0	
629979	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Fault Operations Ground	0	
629980	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Follow-up Action Required?	n	
629981	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Follow-up Action Required?	n	
629982	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
629983	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
629984	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
629985	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
629986	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
629987	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Adjusted Amps B Phase V	0	
629988	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Adjusted Amps C Phase V	0	
629989	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Operations A Ø	0	
629990	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Operations B Ø	0	
629991	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Operations C Ø	0	
629992	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Operations Ground	0	
629993	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Follow-up Action Required?	n	
629994	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Follow-up Action Required?	n	
629995	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Foundation Condition	Good	
629996	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	General Comments		
629997	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	General Comments		
629998	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Grounds in Place?	y	
629999	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Heaters (All) Functioning?	y	
630000	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Maintenance Operations	0	
630001	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
630002	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Operations Counter AF	187	
630003	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Operations Counter AL	187	
630004	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Switching Operations	0	
630005	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Tank Paint Condition	Good	
630006	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Unknown Operations	0	
630007	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
630008	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
630009	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	3.25	%
630010	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	4.88	%
630011	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	4.06	%
630012	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
630013	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
630014	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
630015	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
630016	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
630017	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
630018	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
630019	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
630020	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	General Comments		
630021	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
630022	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
630023	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
630024	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
630025	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
630026	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
630027	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
630028	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
630029	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
630030	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
630031	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	9 Months Operations	0	
630032	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	9 Month Operations	1	
630033	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
630034	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
630035	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
630036	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
630037	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
630038	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
630039	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
630040	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
630041	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Readings	General Comments		
630042	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	General Comments		
630043	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	LTC Operation Checked?	y	
630044	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
630045	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
630046	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
630047	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
630048	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	VRR Time Delay	30	Seconds
630049	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Follow-up Action Required?	n	
630050	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Foundation Condition	Good	
630051	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	General Comments		
630052	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	General Comments		
630053	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Grounds in Place?	y	
630054	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Heaters (All) Functioning?	y	
630055	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Maintenance Operations	0	
630056	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Moisture and Leak Free?	y	
630057	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Operations Counter AF	261	
630058	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Operations Counter AL	261	
630059	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
630060	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
630061	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
630062	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
630063	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
630064	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
630065	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
630066	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
630067	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
630068	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
630069	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
630070	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
630071	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
630072	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	General Comments	ok	
630073	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
630074	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Switching Operations	0	
630075	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Tank Paint Condition	Good	
630076	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
630077	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCC000145	LTCControl	P-TRANS 2	LTC Control Insp	All Connections OK?	y	
630078	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCC000145	LTCControl	P-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
630079	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCC000145	LTCControl	P-TRANS 2	LTC Control Insp	General Comments		
630080	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCC000145	LTCControl	P-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
630081	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Unknown Operations	0	
630082	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Switching Operations	0	
630083	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Operations Counter AL	296	
630084	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Operations Counter AF	296	
630085	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Maintenance Operations	0	
630086	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
630087	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	General Comments		
630088	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	Follow-up Action Required?	n	
630089	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	General Comments		
630090	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	LTC Operation Checked?	y	
630091	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
630092	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
630093	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
630094	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
630095	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	VRR Time Delay	30	Seconds
630096	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	All Connections OK?	y	
630097	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	Follow-up Action Required?	n	
630098	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	General Comments		
630099	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	LTC Operation Checked?	y	
630100	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	LTC Output Voltage Level	12.0	VAC
630101	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
630102	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
630103	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	VRR Time Delay	30	Seconds
630104	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
630105	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	Follow-up Action Required?	n	
630106	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	All Connections OK?	y	
630107	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	9 Month Operations	4	
630108	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Accumulated Fault Duty A Ph V	10.41	%
630109	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Accumulated Fault Duty B Ph V	11.06	%
630110	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Accumulated Fault Duty C Ph V	7.81	%
630111	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Amps A Ø	180	
630112	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Amps B Ø	140	
630113	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Amps C Ø	100	
630114	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	20	
630115	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	10	
630116	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	10	
630117	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
630118	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Bushing Condition	Good	
630119	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Bushings Connection/Risers	Good	
630120	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
630121	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
630122	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
630123	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Cabinet Paint Condition	Good	
630124	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Equipment Properly Labeled?	y	
630125	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Adjusted Amps A Phase V	0	
630126	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	Follow-up Action Required?	n	
630127	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Adjusted Amps B Phase V	0	
630128	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Adjusted Amps C Phase V	0	
630129	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Operations A Ø	0	
630130	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Operations B Ø	0	
630131	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Operations C Ø	0	
630132	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Operations Ground	0	
630133	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Follow-up Action Required?	n	
630134	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
630135	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
630136	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
630137	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
630138	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
630139	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
630140	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
630141	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	General Comments		
630142	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	General Comments		
630143	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
630144	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
630145	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Maintenance Operations	0	
630146	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
630147	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Operations Counter AF	160	
630148	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Operations Counter AL	160	
630149	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
630150	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Switching Operations	0	
630151	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
630152	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Unknown Operations	0	
630153	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
630154	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
630155	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
630156	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
630157	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	392	
630158	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	388	
630159	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
630160	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
630161	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
630162	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
630163	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
630164	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
630165	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
630166	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
630167	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
630168	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
630169	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
630170	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
630171	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
630172	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
630173	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Amps C Ø	100.0	
630174	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Amps B Ø	130.0	
630175	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Amps A Ø	110.0	
630176	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
630177	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
630178	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
630179	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
630180	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	9 Months Operations	0	
630181	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
630182	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
630183	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
630184	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
630185	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
630186	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
630187	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
630188	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
630189	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
630190	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
630191	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
630192	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
630193	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
630194	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Patrol Inspection	General Comments		
630195	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Follow-up Action Required?	n	
630196	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Patrol Inspection	Follow-up Action Required?	n	
630197	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Operations Ground	0	
630198	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Operations C Ø	0	
630199	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Operations B Ø	0	
630200	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Operations A Ø	0	
630201	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
630202	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
630203	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
630204	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	9 Month Operations	2	
630205	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
630206	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
630207	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
630208	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
630209	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
630210	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
630211	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
630212	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
630213	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1640	
630214	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1640	
630215	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
630216	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
630217	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
630218	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
630219	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0127	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
630220	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	Follow-up Action Required?	n	
630221	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
630222	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	General Comments		
630223	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	General Comments		
630224	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC As Found Counter	3725	
630225	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC As Left Counter	3728	
630226	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
630227	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Amps A Ø	0.0	
630228	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Amps B Ø	0.0	
630229	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Amps C Ø	0.0	
630230	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
630231	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
630232	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
630233	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
630234	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
630235	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
630236	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
630237	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
630238	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
630239	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
630240	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Operations A Ø	0	
630241	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Operations B Ø	0	
630242	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Operations C Ø	0	
630243	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Operations Ground	0	
630244	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
630245	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Follow-up Action Required?	n	
630246	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
630247	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
630248	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	33	°F
630249	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
630250	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Unknown Operations	0	
630251	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Tank Paint Condition	Good	
630252	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Switching Operations	0	
630253	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
630254	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.2	VDC
630255	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.1	VDC
630256	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
630257	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
630258	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
630259	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
630260	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
630261	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
630262	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
630263	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	32	°F
630264	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
630265	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
630266	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	2236	
630267	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Unknown Operations	0	
630268	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Tank Paint Condition	Good	
630269	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Switching Operations	0	
630270	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
630271	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
630272	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
630273	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
630274	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
630275	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
630276	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
630277	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
630278	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	2236	
630279	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
630280	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
630281	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
630282	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
630283	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
630284	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Operations Counter AL	339	
630285	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Operations Counter AF	339	
630286	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Moisture and Leak Free?	y	
630287	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
630288	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
630289	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Winding Temp Present	40	°C
630290	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
630291	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
630292	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
630293	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	General Comments		
630294	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	General Comments		
630295	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
630296	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
630297	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
630298	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
630299	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
630300	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
630301	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Oil Temp Max	55	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
630302	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Oil Temp Present	30	°C
630303	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
630304	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
630305	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
630306	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
630307	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
630308	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
630309	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
630310	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
630311	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Totalizer Meter Reading	.7872	
630312	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
630313	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
630314	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
630315	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
630316	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Patrol Inspection	General Comments		
630317	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
630318	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
630319	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	3.0	VDC
630320	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	3.0	VDC
630321	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
630322	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
630323	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
630324	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
630325	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
630326	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
630327	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
630328	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
630329	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
630330	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	4R	
630331	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
630332	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
630333	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
630334	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
630335	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	General Comments		
630336	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
630337	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	10R	
630338	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	2L	
630339	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
630340	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
630341	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
630342	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
630343	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
630344	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	57044	
630345	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
630346	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
630347	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
630348	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
630349	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
630350	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
630351	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
630352	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
630353	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
630354	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
630355	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
630356	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
630357	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
630358	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Oil Temp Present	40	°C
630359	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Oil Temp Max	55	°C
630360	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
630361	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
630362	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	LTC Totalizer Reading	14169.60	kw
630363	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
630364	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	General Comments		
630365	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	General Comments		
630366	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
630367	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
630368	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
630369	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
630370	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
630371	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
630372	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
630373	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Bushings Connection/Risers	Good	
630374	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Bushing Condition	Good	
630375	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Amps C Ø	270	
630376	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Amps B Ø	264	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
630377	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Amps A Ø	294	
630378	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Accumulated Fault Duty C Ph V	.74	%
630379	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Accumulated Fault Duty B Ph V	.74	%
630380	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Accumulated Fault Duty A Ph V	.74	%
630381	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	9 Month Operations	1	
630382	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
630383	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
630384	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
630385	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
630386	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
630387	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
630388	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
630389	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
630390	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
630391	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
630392	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000300	PowerFuse	P-1382 POT	Disconnect Powerfuse Inspection	General Comments	OK	
630393	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000300	PowerFuse	P-1382 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
630394	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000299	PowerFuse	P-1393 POT	Disconnect Powerfuse Inspection	General Comments	OK	
630395	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Follow-up Action Required?	n	
630396	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
630397	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
630398	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
630399	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	9 Month Operations	5	
630400	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Accumulated Fault Duty A Ph V	4.47	%
630401	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Ambient Temperature	33	°F
630402	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
630403	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
630404	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
630405	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
630406	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
630407	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Oil Temp Present	26	°C
630408	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
630409	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
630410	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
630411	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
630412	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	416	
630413	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
630414	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5R	
630415	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
630416	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
630417	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
630418	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
630419	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Winding Temp Max	36	°C
630420	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Winding Temp Present	21	°C
630421	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC As Left Counter	200367	
630422	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC As Found Counter	200367	
630423	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	General Comments		
630424	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
630425	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Winding Temp Max	70	°C
630426	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Totalizer Meter Reading	.9840	
630427	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
630428	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
630429	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
630430	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
630431	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
630432	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
630433	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Maintenance Operations	0	
630434	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Heaters (All) Functioning?	y	
630435	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Grounds in Place?	y	
630436	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	General Comments		
630437	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	General Comments		
630438	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Foundation Condition	Good	
630439	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Follow-up Action Required?	n	
630440	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Follow-up Action Required?	n	
630441	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
630442	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Operations Ground	0	
630443	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Operations C Ø	0	
630444	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Operations B Ø	0	
630445	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
630446	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Operations Counter AL	623	
630447	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Operations Counter AF	623	
630448	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Moisture and Leak Free?	y	
630449	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Maintenance Operations	0	
630450	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Heaters (All) Functioning?	y	
630451	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
630452	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Operations A Ø	0	
630453	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Adjusted Amps C Phase V	0	
630454	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Adjusted Amps B Phase V	0	
630455	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Adjusted Amps A Phase V	0	
630456	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Equipment Properly Labeled?	y	
630457	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Cabinet Paint Condition	Good	
630458	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
630459	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Oil Temp Present	40	°C
630460	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Oil Temp Max	50	°C
630461	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
630462	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
630463	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	LTC Totalizer Reading	4184	kw
630464	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
630465	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	General Comments		
630466	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	General Comments		
630467	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Unknown Operations	1	
630468	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
630469	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
630470	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
630471	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
630472	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
630473	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
630474	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
630475	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
630476	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
630477	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
630478	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	General Comments	ok	
630479	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
630480	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
630481	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
630482	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1260.00	kw
630483	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	100.00	
630484	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
630485	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
630486	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
630487	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
630488	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
630489	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
630490	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
630491	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
630492	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
630493	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
630494	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
630495	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5250	
630496	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	60.0	
630497	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	60.0	
630498	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	60.0	
630499	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
630500	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
630501	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
630502	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Switching Operations	0	
630503	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
630504	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
630505	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
630506	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Follow-up Action Required?	n	
630507	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
630508	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
630509	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
630510	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
630511	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
630512	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
630513	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
630514	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
630515	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
630516	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
630517	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
630518	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
630519	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
630520	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
630521	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
630522	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20	
630523	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Totalizer Meter Reading	.523	
630524	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
630525	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	All Connections OK?	y	
630526	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
630527	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	General Comments		
630528	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	LTC Operation Checked?	y	
630529	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
630530	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
630531	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
630532	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	VRR Time Delay	30	Seconds
630533	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
630534	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
630535	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	Oil Temp Present	25	°C
630536	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	Oil Temp Max	70	°C
630537	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
630538	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
630539	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
630540	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	General Comments	Would not reset with a magnet	
630541	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
630542	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
630543	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
630544	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	y	
630545	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
630546	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
630547	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
630548	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
630549	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
630550	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
630551	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
630552	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
630553	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
630554	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
630555	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
630556	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
630557	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
630558	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
630559	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
630560	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
630561	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
630562	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
630563	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
630564	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
630565	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Accumulated Fault Duty A Ph V	11.38	%
630566	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Accumulated Fault Duty B Ph V	9.75	%
630567	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Accumulated Fault Duty C Ph V	13.00	%
630568	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Amps A Ø	60.0	
630569	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Amps B Ø	60.0	
630570	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Amps C Ø	60.0	
630571	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Bushing Condition	Good	
630572	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Bushings Connection/Risers	Good	
630573	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
630574	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
630575	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
630576	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Cabinet Paint Condition	Good	
630577	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Equipment Properly Labeled?	y	
630578	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
630579	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
630580	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
630581	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
630582	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
630583	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
630584	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Operations A Ø	0	
630585	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Operations B Ø	0	
630586	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Operations C Ø	0	
630587	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Operations Ground	0	
630588	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Follow-up Action Required?	n	
630589	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Follow-up Action Required?	n	
630590	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Foundation Condition	Good	
630591	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	General Comments		
630592	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	General Comments		
630593	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Grounds in Place?	y	
630594	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Heaters (All) Functioning?	y	
630595	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
630596	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
630597	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
630598	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
630599	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
630600	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
630601	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
630602	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Follow-up Action Required?	n	
630603	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Maintenance Operations	0	
630604	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Moisture and Leak Free?	y	
630605	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Operations Counter AF	462	
630606	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Operations Counter AL	462	
630607	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
630608	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Switching Operations	0	
630609	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Tank Paint Condition	Good	
630610	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Unknown Operations	0	
630611	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
630612	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
630613	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	General Comments	ok	
630614	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	General Comments	ok	
630615	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
630616	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	LTC Totalizer Reading	3778.56	kw
630617	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
630618	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
630619	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
630620	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
630621	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
630622	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
630623	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
630624	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
630625	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
630626	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
630627	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
630628	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
630629	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	General Comments		
630630	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
630631	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
630632	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
630633	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
630634	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
630635	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
630636	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
630637	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	6	
630638	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Operations Counter AL	765	
630639	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
630640	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
630641	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Operations Counter AF	765	
630642	1/11/2019 8:45	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
630643	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Maintenance Operations	0	
630644	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	General Comments		
630645	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Patrol Inspection	General Comments		
630646	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Follow-up Action Required?	n	
630647	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Patrol Inspection	Follow-up Action Required?	n	
630648	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Operations Ground	0	
630649	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Operations C Ø	0	
630650	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Operations B Ø	0	
630651	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Operations A Ø	0	
630652	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
630653	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
630654	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
630655	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
630656	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Amps C Ø	100.0	
630657	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Amps B Ø	100.0	
630658	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Amps A Ø	100.0	
630659	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Accumulated Fault Duty C Ph AM	16.86	%
630660	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Accumulated Fault Duty B Ph AM	8.43	%
630661	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Accumulated Fault Duty A Ph AM	24.09	%
630662	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	9 Months Operations	25	
630663	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	General Comments	ok	
630664	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
630665	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
630666	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
630667	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
630668	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
630669	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
630670	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	9 Month Operations	6	
630671	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
630672	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
630673	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
630674	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
630675	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
630676	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
630677	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
630678	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
630679	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
630680	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	General Comments		
630681	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
630682	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Max Tap Position	12L	
630683	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Min Tap Position	6R	
630684	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
630685	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
630686	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
630687	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
630688	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
630689	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Regulator As Left Counter	9179	
630690	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
630691	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
630692	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Tank Leaks	None	
630693	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
630694	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
630695	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
630696	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Clear of Trash?	y	
630697	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
630698	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
630699	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
630700	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
630701	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
630702	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
630703	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	General Comments	ok	
630704	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
630705	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
630706	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
630707	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Vegetation	None	
630708	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
630709	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Operations A Ø	0	
630710	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Operations B Ø	0	
630711	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Operations C Ø	0	
630712	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Operations Ground	0	
630713	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Follow-up Action Required?	n	
630714	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Follow-up Action Required?	n	
630715	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Foundation Condition	Good	
630716	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	General Comments		
630717	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	General Comments		
630718	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Grounds in Place?	y	
630719	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Heaters (All) Functioning?	y	
630720	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Maintenance Operations	0	
630721	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Moisture and Leak Free?	y	
630722	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Operations Counter AF	265	
630723	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Operations Counter AL	265	
630724	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
630725	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
630726	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Floor Swept?	y	
630727	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
630728	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
630729	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	General Comments	ok	
630730	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
630731	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
630732	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Panels Dusted?	y	
630733	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
630734	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
630735	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
630736	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
630737	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
630738	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
630739	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
630740	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
630741	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
630742	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
630743	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
630744	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
630745	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
630746	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
630747	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
630748	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
630749	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
630750	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
630751	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
630752	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
630753	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
630754	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
630755	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
630756	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
630757	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
630758	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	General Comments		
630759	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
630760	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Max Tap Position	12L	
630761	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Min Tap Position	6R	
630762	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
630763	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
630764	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
630765	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
630766	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
630767	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Regulator As Left Counter	8945	
630768	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
630769	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
630770	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Tank Leaks	None	
630771	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
630772	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
630773	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	General Comments	ok	
630774	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
630775	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
630776	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
630777	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Tank Leaks	None	
630778	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
630779	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
630780	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
630781	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
630782	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Bushings Connection/Risers	Good	
630783	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Bushing Condition	Good	
630784	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Amps C Ø	10	
630785	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Amps B Ø	20	
630786	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Amps A Ø	10	
630787	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Accumulated Fault Duty C Ph V	13.46	%
630788	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Accumulated Fault Duty B Ph V	13.47	%
630789	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Accumulated Fault Duty A Ph V	13.47	%
630790	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	9 Month Operations	0	
630791	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Unknown Operations	0	
630792	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
630793	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
630794	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
630795	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Maintenance Operations	0	
630796	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Operations Counter AF	810	
630797	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Operations Counter AL	810	
630798	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC Operations Since Last Insp	874	
630799	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
630800	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC Min Tap Position	9L	
630801	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC Max Tap Position	6R	
630802	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC Current Tap Position	3L	
630803	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
630804	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC As Left Counter	94336	
630805	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC As Found Counter	94336	
630806	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	General Comments	ltc leaking at weld for plumbing on top of compartment	
630807	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Unknown Operations	0	
630808	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Tank Paint Condition	Good	
630809	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Switching Operations	0	
630810	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Operations Counter AL	263	
630811	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Operations Counter AF	263	
630812	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Moisture and Leak Free?	y	
630813	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Maintenance Operations	0	
630814	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Heaters (All) Functioning?	y	
630815	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Switching Operations	0	
630816	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Unknown Operations	0	
630817	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Grounds in Place?	y	
630818	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	General Comments		
630819	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	General Comments		
630820	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	140.0	
630821	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	100.0	
630822	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	160.0	
630823	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
630824	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
630825	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
630826	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
630827	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
630828	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
630829	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	BB0065	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
630830	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Switching Operations	0	
630831	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Tank Paint Condition	Good	
630832	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
630833	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
630834	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	9 Months Operations	3	
630835	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Accumulated Fault Duty A Ph AM	2.41	%
630836	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Accumulated Fault Duty B Ph AM	2.41	%
630837	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Accumulated Fault Duty C Ph AM	1.20	%
630838	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Amps A Ø	10.0	
630839	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Amps B Ø	10.0	
630840	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Amps C Ø	10.0	
630841	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
630842	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
630843	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
630844	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
630845	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Operations A Ø	0	
630846	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Operations B Ø	0	
630847	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Operations C Ø	0	
630848	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
630849	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
630850	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
630851	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Current Tap Position	2L	
630852	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
630853	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
630854	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
630855	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
630856	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
630857	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
630858	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
630859	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Operations Ground	0	
630860	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Patrol Inspection	Follow-up Action Required?	n	
630861	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Follow-up Action Required?	n	
630862	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Patrol Inspection	General Comments		
630863	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	General Comments		
630864	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
630865	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
630866	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	2041	
630867	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	General Comments		
630868	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
630869	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Max Tap Position	13L	
630870	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Min Tap Position	5R	
630871	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
630872	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
630873	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	2041	
630874	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
630875	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
630876	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
630877	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
630878	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
630879	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
630880	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Regulator As Left Counter	8330	
630881	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
630882	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
630883	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
630884	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
630885	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
630886	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
630887	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
630888	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
630889	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
630890	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0209	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
630891	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0209	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
630892	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0209	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
630893	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0209	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
630894	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0209	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
630895	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0209	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
630896	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0209	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
630897	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0209	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
630898	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
630899	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
630900	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000297	PowerFuse	P-14KV TR 4-B POT	Disconnect Powerfuse Inspection	General Comments	Fuses pulled, Not In Service	
630901	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
630902	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
630903	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
630904	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
630905	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
630906	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	General Comments		
630907	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
630908	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
630909	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000297	PowerFuse	P-14KV TR 4-B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
630910	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
630911	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
630912	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
630913	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
630914	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000296	PowerFuse	P-TR 5 AUX PWR	Disconnect Powerfuse Inspection	General Comments	OK	
630915	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000296	PowerFuse	P-TR 5 AUX PWR	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
630916	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
630917	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
630918	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
630919	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
630920	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
630921	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
630922	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
630923	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000295	PowerFuse	P-14KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	OK	
630924	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000295	PowerFuse	P-14KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
630925	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
630926	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	General Comments		
630927	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
630928	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000293	PowerFuse	P-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
630929	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000293	PowerFuse	P-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
630930	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
630931	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000291	PowerFuse	P-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
630932	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
630933	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	190.0	
630934	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	180.0	
630935	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	4.11	%
630936	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
630937	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
630938	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
630939	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
630940	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
630941	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
630942	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
630943	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
630944	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000299	PowerFuse	P-1393 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
630945	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000298	PowerFuse	P-1385 POT	Disconnect Powerfuse Inspection	General Comments	OK	
630946	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000298	PowerFuse	P-1385 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
630947	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
630948	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
630949	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
630950	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
630951	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
630952	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Fault Operations	0	
630953	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Follow-up Action Required?	n	
630954	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Follow-up Action Required?	n	
630955	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Foundation Condition	Good	
630956	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
630957	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	General Comments		
630958	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	General Comments	y	
630959	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Grounds in Place?	y	
630960	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
630961	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Maintenance Operations	0	
630962	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
630963	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
630964	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Num Operations Last 9 Months	0	
630965	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Operations Counter AF	64	
630966	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Operations Counter AL	64	
630967	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
630968	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
630969	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
630970	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Switching Operations	0	
630971	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Tank Paint Condition	Good	
630972	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Accumulated Fault Duty B Ph V	2.68	%
630973	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	3	
630974	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1486	
630975	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1483	
630976	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
630977	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
630978	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
630979	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
630980	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
630981	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
630982	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
630983	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
630984	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
630985	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
630986	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
630987	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
630988	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
630989	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
630990	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
630991	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
630992	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
630993	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
630994	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
630995	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
630996	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
630997	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
630998	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
630999	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
631000	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	General Comments		
631001	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
631002	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
631003	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
631004	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
631005	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
631006	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	240	
631007	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	240	
631008	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
631009	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
631010	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
631011	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
631012	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
631013	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
631014	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
631015	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Vegetation	None	
631016	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
631017	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
631018	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
631019	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
631020	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	General Comments		
631021	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	General Comments		
631022	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Foundation Condition	Good	
631023	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Follow-up Action Required?	n	
631024	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Follow-up Action Required?	n	
631025	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Operations Ground	0	
631026	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Operations C Ø	0	
631027	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Operations B Ø	0	
631028	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Operations A Ø	0	
631029	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Adjusted Amps C Phase V	0	
631030	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Adjusted Amps B Phase V	0	
631031	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Adjusted Amps A Phase V	0	
631032	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Equipment Properly Labeled?	y	
631033	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Cabinet Paint Condition	Good	
631034	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
631035	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
631036	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
631037	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
631038	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
631039	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
631040	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
631041	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Evidence of Insects	None	
631042	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	4.11	%
631043	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	7.20	%
631044	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	13	
631045	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Accumulated Fault Duty C Ph V	4.47	%
631046	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Amps A Ø	60.0	
631047	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Amps B Ø	60.0	
631048	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Amps C Ø	60.0	
631049	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000291	PowerFuse	P-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
631050	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Bushing Condition	Good	
631051	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
631052	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
631053	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
631054	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
631055	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Cabinet Paint Condition	Good	
631056	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Equipment Properly Labeled?	y	
631057	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
631058	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000289	PowerFuse	P-STA SER 2	Disconnect Powerfuse Inspection	General Comments	OK	
631059	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000289	PowerFuse	P-STA SER 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
631060	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000288	PowerFuse	P-STA SER TRANS B	Disconnect Powerfuse Inspection	General Comments	OK	
631061	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000288	PowerFuse	P-STA SER TRANS B	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
631062	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000287	PowerFuse	P-BUS TIE REA 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
631063	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000287	PowerFuse	P-BUS TIE REA 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
631064	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Ambient Temp	22	°F
631065	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
631066	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000286	PowerFuse	P-1388 POT	Disconnect Powerfuse Inspection	General Comments	OK	
631067	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000286	PowerFuse	P-1388 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
631068	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
631069	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Clear of Trash?	y	
631070	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
631071	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
631072	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
631073	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
631074	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
631075	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
631076	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	General Comments		
631077	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
631078	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
631079	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
631080	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	3.08	%
631081	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.06	%
631082	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.06	%
631083	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	190.0	
631084	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	180.0	
631085	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
631086	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
631087	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
631088	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
631089	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
631090	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
631091	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
631092	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
631093	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
631094	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
631095	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Unknown Operations	0	
631096	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Tank Paint Condition	Good	
631097	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Switching Operations	0	
631098	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
631099	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Operations Counter AL	233	
631100	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Operations Counter AF	233	
631101	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Moisture and Leak Free?	y	
631102	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Maintenance Operations	0	
631103	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Heaters (All) Functioning?	y	
631104	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Grounds in Place?	y	
631105	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	General Comments		
631106	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	General Comments		
631107	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Foundation Condition	Good	
631108	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Follow-up Action Required?	n	
631109	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Follow-up Action Required?	n	
631110	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Operations Ground	0	
631111	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Operations C Ø	0	
631112	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Operations B Ø	0	
631113	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Operations A Ø	0	
631114	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
631115	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
631116	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
631117	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Equipment Properly Labeled?	y	
631118	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
631119	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
631120	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
631121	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
631122	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
631123	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
631124	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
631125	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
631126	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
631127	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
631128	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
631129	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
631130	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
631131	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	10	
631132	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	10	
631133	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	10	
631134	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
631135	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
631136	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
631137	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
631138	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	9 Month Operations	0	
631139	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
631140	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
631141	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
631142	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Amps A Ø	280.0	
631143	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Amps B Ø	250.0	
631144	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Amps C Ø	280.0	
631145	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Bushing Condition	Good	
631146	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
631147	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
631148	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Follow-up Action Required?	n	
631149	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
631150	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
631151	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
631152	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
631153	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
631154	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
631155	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Operations Counter AL	634	
631156	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
631157	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Switching Operations	0	
631158	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
631159	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
631160	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
631161	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
631162	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	6	
631163	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
631164	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
631165	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
631166	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
631167	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
631168	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
631169	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	769	
631170	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	769	
631171	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	10	
631172	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
631173	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
631174	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
631175	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
631176	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	General Comments		
631177	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	23	
631178	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC As Found Counter	44789	
631179	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC As Left Counter	44789	
631180	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
631181	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC Current Tap Position	8L	
631182	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC Max Tap Position	8L	
631183	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC Min Tap Position	15L	
631184	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC Operations Since Last Insp	772	
631185	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
631186	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
631187	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
631188	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	Follow-up Action Required?	n	
631189	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
631190	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	General Comments		
631191	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	General Comments		
631192	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC As Found Counter	136417	
631193	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC As Left Counter	136417	
631194	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
631195	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC Current Tap Position	5L	
631196	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC Max Tap Position	3L	
631197	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC Min Tap Position	6L	
631198	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC Operations Since Last Insp	581	
631199	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
631200	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
631201	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
631202	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
631203	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
631204	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
631205	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
631206	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
631207	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	144	
631208	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Vegetation	None	
631209	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
631210	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Cabinet Paint Condition	Good	
631211	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
631212	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
631213	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
631214	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Bushings Connection/Risers	Good	
631215	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	General Comments		
631216	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	General Comments		
631217	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Grounds in Place?	y	
631218	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
631219	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Maintenance Operations	0	
631220	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
631221	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Operations Counter AF	154	
631222	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Operations Counter AL	154	
631223	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
631224	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Switching Operations	0	
631225	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Tank Paint Condition	Good	
631226	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Bushing Condition	Good	
631227	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Amps C Ø	90.0	
631228	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Amps B Ø	160.0	
631229	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Amps A Ø	150.0	
631230	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Unknown Operations	0	
631231	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
631232	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
631233	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
631234	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	9 Month Operations	5	
631235	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
631236	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	General Comments		
631237	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
631238	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
631239	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
631240	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
631241	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
631242	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
631243	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
631244	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
631245	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Tank Leaks	None	
631246	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
631247	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
631248	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Regulator As Left Counter	110019	
631249	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
631250	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
631251	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
631252	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC Operations Since Last Insp	14	
631253	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
631254	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
631255	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
631256	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
631257	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
631258	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
631259	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
631260	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
631261	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Operations A Ø	0	
631262	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Operations B Ø	0	
631263	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Operations C Ø	0	
631264	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Operations Ground	0	
631265	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Follow-up Action Required?	n	
631266	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Follow-up Action Required?	n	
631267	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Foundation Condition	Good	
631268	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Tank Paint Condition	Good	
631269	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Unknown Operations	0	
631270	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
631271	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
631272	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
631273	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	350.0	
631274	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	360.0	
631275	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	400.0	
631276	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
631277	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
631278	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
631279	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
631280	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
631281	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
631282	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Current Tap Position	3R	
631283	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
631284	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
631285	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
631286	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
631287	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	General Comments		
631288	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
631289	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Max Tap Position	9L	
631290	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Min Tap Position	3R	
631291	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
631292	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
631293	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
631294	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
631295	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
631296	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Regulator As Left Counter	116162	
631297	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
631298	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
631299	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Tank Leaks	None	
631300	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
631301	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
631302	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
631303	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
631304	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
631305	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
631306	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Grounds in Place?	y	
631307	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	General Comments		
631308	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	General Comments		
631309	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Foundation Condition	Good	
631310	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Follow-up Action Required?	n	
631311	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Follow-up Action Required?	n	
631312	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Operations Ground	0	
631313	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Operations C Ø	0	
631314	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Operations B Ø	0	
631315	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Operations A Ø	0	
631316	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
631317	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
631318	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
631319	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Equipment Properly Labeled?	y	
631320	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Cabinet Paint Condition	Good	
631321	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
631322	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
631323	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
631324	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Bushings Connection/Risers	Good	
631325	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Bushing Condition	Good	
631326	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Amps C Ø	310.0	
631327	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Amps B Ø	250.0	
631328	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Amps A Ø	300.0	
631329	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Accumulated Fault Duty C Ph V	25.62	%
631330	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Accumulated Fault Duty B Ph V	25.62	%
631331	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Accumulated Fault Duty A Ph V	25.62	%
631332	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	9 Month Operations	8	
631333	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
631334	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	PF000094	PowerFuse	CO-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
631335	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	PF000094	PowerFuse	CO-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
631336	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
631337	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
631338	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
631339	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
631340	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
631341	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
631342	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
631343	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
631344	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
631345	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
631346	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
631347	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
631348	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	General Comments		
631349	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
631350	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
631351	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
631352	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
631353	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
631354	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
631355	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
631356	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
631357	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
631358	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
631359	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Regulator As Left Counter	129255	
631360	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
631361	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
631362	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
631363	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
631364	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
631365	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Min Tap Position	6R	
631366	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Max Tap Position	9L	
631367	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
631368	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	General Comments		
631369	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
631370	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
631371	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
631372	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
631373	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Current Tap Position	3R	
631374	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
631375	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
631376	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
631377	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
631378	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
631379	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
631380	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
631381	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
631382	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
631383	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
631384	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
631385	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
631386	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	General Comments		
631387	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
631388	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
631389	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	31	°F
631390	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
631391	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
631392	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
631393	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
631394	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
631395	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
631396	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
631397	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
631398	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	General Comments		
631399	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
631400	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
631401	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
631402	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
631403	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Unknown Operations	0	
631404	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Tank Paint Condition	Good	
631405	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Switching Operations	2	
631406	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
631407	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Operations Counter AL	341	
631408	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Operations Counter AF	341	
631409	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Moisture and Leak Free?	y	
631410	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Maintenance Operations	0	
631411	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Heaters (All) Functioning?	y	
631412	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	General Comments		
631413	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	9 Month Operations	4	
631414	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Accumulated Fault Duty A Ph V	9.51	%
631415	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Accumulated Fault Duty B Ph V	12.67	%
631416	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Accumulated Fault Duty C Ph V	8.71	%
631417	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Amps A Ø	10	
631418	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Amps B Ø	10	
631419	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Amps C Ø	10	
631420	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Bushing Condition	Good	
631421	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Bushings Connection/Risers	Good	
631422	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
631423	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
631424	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
631425	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Cabinet Paint Condition	Good	
631426	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
631427	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
631428	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Totalizer Meter Reading	.8838	
631429	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
631430	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
631431	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Equipment Properly Labeled?	y	
631432	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Adjusted Amps A Phase V	0	
631433	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Adjusted Amps B Phase V	0	
631434	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Adjusted Amps C Phase V	0	
631435	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Operations A Ø	0	
631436	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Operations B Ø	0	
631437	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Operations C Ø	0	
631438	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Operations Ground	0	
631439	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Follow-up Action Required?	n	
631440	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Follow-up Action Required?	n	
631441	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Foundation Condition	Good	
631442	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	General Comments		
631443	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	General Comments		
631444	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Grounds in Place?	y	
631445	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Heaters (All) Functioning?	y	
631446	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Maintenance Operations	0	
631447	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Moisture and Leak Free?	y	
631448	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Operations Counter AF	634	
631449	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
631450	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
631451	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
631452	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
631453	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
631454	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
631455	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
631456	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Oil Temp Present	30	°C
631457	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Oil Temp Max	35	°C
631458	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
631459	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
631460	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	LTC Totalizer Reading	8484.48	kw
631461	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
631462	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	General Comments		
631463	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	General Comments		
631464	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
631465	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
631466	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
631467	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
631468	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC Operations Since Last Insp	729	
631469	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
631470	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC Min Tap Position	12L	
631471	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC Max Tap Position	6R	
631472	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC Current Tap Position	2L	
631473	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
631474	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Vegetation	None	
631475	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
631476	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	General Comments	ok	
631477	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
631478	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
631479	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
631480	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
631481	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
631482	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
631483	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
631484	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
631485	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
631486	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
631487	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Clear of Trash?	y	
631488	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
631489	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
631490	1/11/2019 13:30	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
631491	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
631492	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC As Left Counter	33551	
631493	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC As Found Counter	33551	
631494	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	General Comments		
631495	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	General Comments		
631496	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
631497	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	Follow-up Action Required?	n	
631498	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
631499	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
631500	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
631501	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
631502	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
631503	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
631504	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
631505	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
631506	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
631507	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
631508	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
631509	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	PF000093	PowerFuse	CO-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
631510	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	PF000093	PowerFuse	CO-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
631511	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	PF000092	PowerFuse	CO-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
631512	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	PF000092	PowerFuse	CO-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
631513	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	PF000091	PowerFuse	CO-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
631514	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	PF000091	PowerFuse	CO-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
631515	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	Follow-up Action Required?	n	
631516	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
631517	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	General Comments		
631518	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
631519	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
631520	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
631521	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
631522	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
631523	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
631524	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	58	°F
631525	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
631526	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
631527	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
631528	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
631529	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
631530	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
631531	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
631532	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
631533	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
631534	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
631535	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
631536	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
631537	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Operations A Ø	0	
631538	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Operations B Ø	0	
631539	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Operations C Ø	0	
631540	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Operations Ground	0	
631541	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Follow-up Action Required?	n	
631542	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Follow-up Action Required?	n	
631543	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Foundation Condition	Good	
631544	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	General Comments		
631545	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	General Comments		
631546	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Grounds in Place?	y	
631547	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Heaters (All) Functioning?	y	
631548	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Maintenance Operations	0	
631549	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Moisture and Leak Free?	y	
631550	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Operations Counter AF	477	
631551	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Operations Counter AL	477	
631552	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
631553	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Switching Operations	0	
631554	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Tank Paint Condition	Good	
631555	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Unknown Operations	0	
631556	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
631557	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
631558	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	General Comments		
631559	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
631560	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
631561	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Totalizer Meter Reading	.5952	
631562	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
631563	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
631564	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000283	PowerFuse	P-14KV TR 4-A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
631565	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000282	PowerFuse	P-1383 POT	Disconnect Powerfuse Inspection	General Comments	OK	
631566	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000282	PowerFuse	P-1383 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
631567	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
631568	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Foundation Condition	Good	
631569	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
631570	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
631571	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
631572	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
631573	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
631574	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
631575	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
631576	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Clear of Trash?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
631577	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
631578	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
631579	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
631580	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
631581	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	General Comments		
631582	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
631583	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
631584	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
631585	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
631586	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
631587	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
631588	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
631589	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
631590	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
631591	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
631592	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
631593	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
631594	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
631595	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	9 Month Operations	5	
631596	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
631597	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
631598	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
631599	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Amps A Ø	380.0	
631600	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Amps B Ø	360.0	
631601	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Amps C Ø	480.0	
631602	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Bushing Condition	Good	
631603	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Bushings Connection/Risers	Good	
631604	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
631605	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
631606	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
631607	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Cabinet Paint Condition	Good	
631608	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Equipment Properly Labeled?	y	
631609	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
631610	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
631611	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	General Comments		
631612	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
631613	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.0	amps
631614	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
631615	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
631616	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
631617	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
631618	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
631619	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.0	VDC
631620	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Negative DC Ground	33.0	VDC
631621	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	General Comments		
631622	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
631623	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
631624	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	General Comments		
631625	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	General Comments		
631626	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Foundation Condition	Good	
631627	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
631628	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
631629	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
631630	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
631631	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
631632	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
631633	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
631634	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Follow-up Action Required?	n	
631635	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
631636	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
631637	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Follow-up Action Required?	n	
631638	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Operations Ground	0	
631639	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Operations C Ø	0	
631640	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Operations B Ø	0	
631641	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Operations A Ø	0	
631642	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
631643	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
631644	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
631645	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Equipment Properly Labeled?	y	
631646	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Cabinet Paint Condition	Good	
631647	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
631648	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
631649	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
631650	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Bushings Connection/Risers	Good	
631651	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
631652	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Amps C Ø	40.0	
631653	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Amps B Ø	10.0	
631654	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Amps A Ø	0.0	
631655	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Accumulated Fault Duty C Ph V	2.63	%
631656	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Accumulated Fault Duty B Ph V	2.63	%
631657	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Accumulated Fault Duty A Ph V	2.85	%
631658	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	9 Month Operations	4	
631659	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
631660	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	General Comments		
631661	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
631662	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
631663	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
631664	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
631665	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
631666	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
631667	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
631668	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
631669	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.1	VDC
631670	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.1	VDC
631671	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF001154	PowerFuse	P-1387 POT	Disconnect Powerfuse Inspection	General Comments	OK	
631672	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF001154	PowerFuse	P-1387 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
631673	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCC000006	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
631674	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCC000006	LTCControl	Retired Distribution	LTC Control Insp	General Comments	Will not go back in service, can it be removed from insp?	
631675	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCC000006	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	y	
631676	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCC000006	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	n	
631677	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
631678	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
631679	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
631680	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
631681	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
631682	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
631683	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
631684	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
631685	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
631686	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
631687	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
631688	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
631689	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
631690	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
631691	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
631692	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
631693	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
631694	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
631695	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
631696	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
631697	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	General Comments		
631698	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
631699	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
631700	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
631701	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
631702	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
631703	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
631704	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
631705	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
631706	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
631707	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
631708	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
631709	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
631710	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
631711	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
631712	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
631713	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
631714	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
631715	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
631716	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
631717	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
631718	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF001155	PowerFuse	P-1391 POT	Disconnect Powerfuse Inspection	General Comments	OK	
631719	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF001155	PowerFuse	P-1391 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
631720	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Unknown Operations	0	
631721	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Tank Paint Condition	Good	
631722	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Switching Operations	0	
631723	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
631724	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Operations Counter AL	216	
631725	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Operations Counter AF	216	
631726	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
631727	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Maintenance Operations	1	
631728	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Heaters (All) Functioning?	y	
631729	1/11/2019 15:24	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Grounds in Place?	y	
631730	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
631731	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
631732	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
631733	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	General Comments		
631734	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
631735	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Max Tap Position	12L	
631736	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Min Tap Position	2L	
631737	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
631738	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
631739	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC Max Tap Position	4R	
631740	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC Current Tap Position	3R	
631741	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
631742	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC As Left Counter	73017	
631743	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC As Found Counter	73000	
631744	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	General Comments	ok	
631745	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	General Comments	ok	
631746	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
631747	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	Follow-up Action Required?	n	
631748	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
631749	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
631750	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125	volts
631751	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Regulator As Left Counter	21970	
631752	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
631753	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
631754	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Tank Leaks	None	
631755	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
631756	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	144	
631757	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
631758	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
631759	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
631760	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
631761	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
631762	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC Operations Since Last Insp	401	
631763	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC Min Tap Position	8L	
631764	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC Max Tap Position	3R	
631765	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC Current Tap Position	2L	
631766	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
631767	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC As Left Counter	77069	
631768	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC As Found Counter	77068	
631769	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	General Comments		
631770	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	General Comments		
631771	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
631772	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	Follow-up Action Required?	n	
631773	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
631774	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
631775	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
631776	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
631777	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
631778	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
631779	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
631780	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
631781	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
631782	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
631783	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
631784	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
631785	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
631786	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
631787	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
631788	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
631789	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Min Tap Position	1L	
631790	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Max Tap Position	12L	
631791	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
631792	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	General Comments		
631793	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
631794	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
631795	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
631796	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
631797	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
631798	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
631799	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
631800	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
631801	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
631802	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
631803	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
631804	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
631805	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
631806	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
631807	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
631808	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
631809	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	General Comments	ok	
631810	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
631811	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
631812	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
631813	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
631814	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
631815	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
631816	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
631817	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
631818	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Regulator As Left Counter	67506	
631819	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
631820	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Tank Leaks	None	
631821	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
631822	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
631823	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
631824	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
631825	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Clear of Trash?	y	
631826	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
631827	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
631828	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC Min Tap Position	1R	
631829	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
631830	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
631831	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
631832	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
631833	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
631834	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
631835	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
631836	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
631837	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4602	
631838	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000283	PowerFuse	P-14KV TR 4-A POT	Disconnect Powerfuse Inspection	General Comments	OK	
631839	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
631840	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
631841	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
631842	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
631843	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
631844	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
631845	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
631846	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
631847	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.5	VDC
631848	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	26.7	VDC
631849	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
631850	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
631851	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Dry Cell Battery Install Date	2016-05-05 00:00:00.000000	
631852	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
631853	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
631854	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
631855	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
631856	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Battery Bank Volts	53.3	VDC
631857	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	22	°F
631858	1/11/2019 9:35	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
631859	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
631860	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
631861	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
631862	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
631863	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
631864	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
631865	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Follow-up Action Required?	n	
631866	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
631867	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
631868	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	General Comments	ok	
631869	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	General Comments	ok	
631870	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
631871	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	LTC Totalizer Reading	1904.64	kw
631872	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
631873	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
631874	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Oil Temp Max	40	°C
631875	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Oil Temp Present	30	°C
631876	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
631877	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
631878	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
631879	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
631880	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
631881	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
631882	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
631883	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
631884	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Vegetation	None	
631885	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
631886	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
631887	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	General Comments		
631888	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
631889	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
631890	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
631891	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
631892	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
631893	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
631894	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
631895	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
631896	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
631897	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
631898	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
631899	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
631900	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
631901	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
631902	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
631903	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	General Comments		
631904	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
631905	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
631906	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.4	psi
631907	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
631908	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
631909	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
631910	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
631911	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
631912	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
631913	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
631914	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
631915	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
631916	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
631917	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
631918	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
631919	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
631920	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
631921	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
631922	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
631923	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
631924	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	General Comments		
631925	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	General Comments		
631926	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
631927	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
631928	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
631929	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
631930	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4417.92	kw
631931	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50	
631932	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45	
631933	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Oil Temp Max	25	°C
631934	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
631935	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
631936	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
631937	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
631938	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
631939	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
631940	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
631941	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
631942	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
631943	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
631944	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
631945	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Equipment Properly Labeled?	y	
631946	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Cabinet Paint Condition	Good	
631947	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Operations Counter AF	176	
631948	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Foundation Condition	Good	
631949	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	General Comments		
631950	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	General Comments		
631951	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
631952	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Heaters (All) Functioning?	y	
631953	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Maintenance Operations	0	
631954	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Moisture and Leak Free?	y	
631955	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Operations Counter AF	99987	
631956	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
631957	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
631958	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Maintenance Operations	0	
631959	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
631960	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Grounds in Place?	y	
631961	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	General Comments		
631962	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	General Comments		
631963	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Foundation Condition	Good	
631964	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Follow-up Action Required?	n	
631965	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Follow-up Action Required?	n	
631966	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Operations Ground	0	
631967	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Operations C Ø	0	
631968	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Operations B Ø	0	
631969	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
631970	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
631971	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
631972	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
631973	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Trash Emptied?	y	
631974	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
631975	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Panels Dusted?	y	
631976	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
631977	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
631978	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	General Comments		
631979	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
631980	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
631981	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Floor Swept?	y	
631982	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
631983	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
631984	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Evidence of Insects	None	
631985	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
631986	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
631987	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
631988	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
631989	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
631990	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
631991	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Bushings Connection/Risers	Good	
631992	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Bushing Condition	Good	
631993	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Amps C Ø	0.0	
631994	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Amps B Ø	0.0	
631995	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
631996	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
631997	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
631998	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
631999	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
632000	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
632001	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
632002	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
632003	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
632004	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
632005	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
632006	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
632007	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
632008	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
632009	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
632010	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
632011	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
632012	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
632013	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
632014	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
632015	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
632016	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
632017	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
632018	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	240.0	
632019	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	235.0	
632020	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Unknown Operations	0	
632021	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Tank Paint Condition	Good	
632022	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Switching Operations	0	
632023	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
632024	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Operations Counter AL	70	
632025	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Operations Counter AF	70	
632026	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
632027	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Maintenance Operations	0	
632028	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Heaters (All) Functioning?	y	
632029	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Grounds in Place?	y	
632030	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	General Comments	ok	
632031	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	General Comments	ok	
632032	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Foundation Condition	Good	
632033	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Follow-up Action Required?	n	
632034	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Follow-up Action Required?	n	
632035	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	250.0	
632036	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.16	%
632037	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
632038	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.16	%
632039	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
632040	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Unknown Operations	0	
632041	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Tank Paint Condition	Good	
632042	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Switching Operations	0	
632043	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Operations Counter AL	176	
632044	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Operations Ground	0	
632045	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Operations C Ø	0	
632046	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Operations B Ø	0	
632047	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Operations A Ø	0	
632048	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Maintenance Operations	0	
632049	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Heaters (All) Functioning?	y	
632050	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Grounds in Place?	y	
632051	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	General Comments		
632052	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	General Comments		
632053	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Foundation Condition	Good	
632054	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Follow-up Action Required?	n	
632055	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Follow-up Action Required?	n	
632056	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Operations Ground	0	
632057	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Operations C Ø	0	
632058	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Operations B Ø	0	
632059	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Operations A Ø	0	
632060	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
632061	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
632062	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
632063	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Unknown Operations	0	
632064	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Switching Operations	0	
632065	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Operations Counter AL	249	
632066	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Operations Counter AF	249	
632067	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Maintenance Operations	0	
632068	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	General Comments		
632069	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Equipment Properly Labeled?	y	
632070	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Cabinet Paint Condition	Good	
632071	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
632072	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
632073	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
632074	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Bushings Connection/Risers	Good	
632075	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Bushing Condition	Good	
632076	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Amps C Ø	180.0	
632077	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Patrol Inspection	General Comments		
632078	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
632079	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
632080	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
632081	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
632082	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Clear of Trash?	y	
632083	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
632084	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
632085	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
632086	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
632087	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
632088	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
632089	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	General Comments	ok	
632090	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
632091	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Vegetation	None	
632092	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
632093	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
632094	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	General Comments		
632095	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
632096	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
632097	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
632098	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
632099	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
632100	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Follow-up Action Required?	n	
632101	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Amps A Ø	0.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
632102	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Operations A Ø	0	
632103	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
632104	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
632105	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
632106	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
632107	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
632108	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
632109	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
632110	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
632111	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
632112	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Accumulated Fault Duty C Ph V	7.17	%
632113	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Accumulated Fault Duty B Ph V	7.17	%
632114	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Accumulated Fault Duty A Ph V	7.17	%
632115	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	9 Month Operations	2	
632116	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Bushing Condition	Good	
632117	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Amps C Ø	490.0	
632118	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Amps B Ø	420.0	
632119	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Amps A Ø	445.0	
632120	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Accumulated Fault Duty C Ph V	3.24	%
632121	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Accumulated Fault Duty B Ph V	2.16	%
632122	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Accumulated Fault Duty A Ph V	2.16	%
632123	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	9 Month Operations	2	
632124	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
632125	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
632126	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
632127	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
632128	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
632129	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
632130	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
632131	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
632132	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
632133	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
632134	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
632135	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	General Comments		
632136	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
632137	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
632138	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Foundation Condition	Good	
632139	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
632140	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
632141	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
632142	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
632143	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
632144	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCC000147	LTCControl	P-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
632145	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCC000147	LTCControl	P-TRANS 1	LTC Control Insp	General Comments		
632146	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCC000147	LTCControl	P-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
632147	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCC000147	LTCControl	P-TRANS 1	LTC Control Insp	All Connections OK?	y	
632148	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Unknown Operations	0	
632149	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Tank Paint Condition	Good	
632150	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Switching Operations	3	
632151	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Operations Counter AL	358	
632152	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Operations Counter AF	358	
632153	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Moisture and Leak Free?	y	
632154	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
632155	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
632156	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
632157	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
632158	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
632159	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
632160	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
632161	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
632162	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
632163	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
632164	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	General Comments		
632165	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
632166	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Max Tap Position	9L	
632167	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Min Tap Position	3R	
632168	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
632169	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
632170	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
632171	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
632172	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
632173	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Regulator As Left Counter	42193	
632174	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
632175	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
632176	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Tank Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
632177	1/11/2019 7:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
632178	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Switching Operations	0	
632179	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
632180	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Unknown Operations	0	
632181	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
632182	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
632183	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
632184	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
632185	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
632186	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
632187	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
632188	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
632189	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
632190	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
632191	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	General Comments		
632192	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
632193	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Max Tap Position	11L	
632194	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Min Tap Position	12R	
632195	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
632196	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
632197	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
632198	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
632199	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
632200	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Regulator As Left Counter	76176	
632201	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
632202	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
632203	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Tank Leaks	None	
632204	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
632205	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC Min Tap Position	1L	
632206	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	LTCC000323	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
632207	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	General Comments		
632208	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	General Comments		
632209	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Grounds in Place?	y	
632210	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Heaters (All) Functioning?	y	
632211	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Maintenance Operations	0	
632212	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
632213	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Cabinet Paint Condition	Good	
632214	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Equipment Properly Labeled?	y	
632215	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
632216	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
632217	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
632218	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Operations A Ø	0	
632219	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Operations B Ø	0	
632220	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Moisture and Leak Free?	y	
632221	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Operations Counter AF	136	
632222	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Operations Counter AL	136	
632223	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Switching Operations	0	
632224	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Tank Paint Condition	Good	
632225	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Unknown Operations	0	
632226	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC Current Tap Position	5L	
632227	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC Max Tap Position	12L	
632228	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	9 Month Operations	2	
632229	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
632230	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
632231	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
632232	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Amps A Ø	400.0	
632233	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Amps B Ø	420.0	
632234	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Amps C Ø	440.0	
632235	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
632236	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
632237	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
632238	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
632239	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
632240	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
632241	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
632242	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
632243	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
632244	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
632245	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
632246	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
632247	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
632248	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Operations Ground	0	
632249	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
632250	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
632251	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
632252	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	General Comments		
632253	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	General Comments		
632254	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
632255	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
632256	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Maintenance Operations	0	
632257	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
632258	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Operations Counter AF	169	
632259	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Operations Counter AL	169	
632260	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Amps C Ø	120.0	
632261	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Bushing Condition	Good	
632262	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Bushings Connection/Risers	Good	
632263	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
632264	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
632265	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
632266	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Cabinet Paint Condition	Good	
632267	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Equipment Properly Labeled?	y	
632268	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
632269	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
632270	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
632271	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Operations A Ø	0	
632272	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Operations B Ø	0	
632273	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Operations C Ø	0	
632274	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Operations Ground	0	
632275	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Follow-up Action Required?	n	
632276	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Follow-up Action Required?	n	
632277	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Foundation Condition	Good	
632278	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	General Comments		
632279	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	General Comments		
632280	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Grounds in Place?	y	
632281	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Heaters (All) Functioning?	y	
632282	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Maintenance Operations	0	
632283	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Moisture and Leak Free?	y	
632284	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Operations Counter AF	55	
632285	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Operations Counter AL	55	
632286	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
632287	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Switching Operations	0	
632288	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Tank Paint Condition	Good	
632289	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Unknown Operations	0	
632290	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
632291	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
632292	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
632293	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
632294	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
632295	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
632296	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF001133	PowerFuse	P-1394 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
632297	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF001133	PowerFuse	P-1394 POT	Disconnect Powerfuse Inspection	General Comments	OK	
632298	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
632299	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC Operations Since Last Insp	510	
632300	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
632301	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
632302	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
632303	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Operations C Ø	0	
632304	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Operations Ground	0	
632305	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Follow-up Action Required?	n	
632306	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Follow-up Action Required?	n	
632307	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
632308	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
632309	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
632310	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
632311	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	386	
632312	1/11/2019 12:03	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	386	
632313	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	LTCC000323	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
632314	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
632315	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
632316	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
632317	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
632318	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
632319	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
632320	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
632321	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
632322	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
632323	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
632324	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	General Comments		
632325	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
632326	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Max Tap Position	13L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
632327	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Min Tap Position	1R	
632328	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
632329	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
632330	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
632331	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
632332	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
632333	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Regulator As Left Counter	18684	
632334	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
632335	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
632336	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Tank Leaks	None	
632337	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
632338	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
632339	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
632340	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
632341	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	LTCC000323	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
632342	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	LTCC000323	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
632343	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	LTCC000323	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
632344	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	LTCC000323	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
632345	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	LTCC000323	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
632346	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	LTCC000323	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
632347	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
632348	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
632349	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
632350	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Foundation Condition	Good	
632351	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
632352	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
632353	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	General Comments		
632354	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
632355	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
632356	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
632357	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
632358	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
632359	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
632360	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	9 Month Operations	2	
632361	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Accumulated Fault Duty A Ph V	.69	%
632362	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
632363	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
632364	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Amps A Ø	125.0	
632365	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Amps B Ø	120.0	
632366	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
632367	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.48	%
632368	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.48	%
632369	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	510	
632370	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	520	
632371	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	520	
632372	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
632373	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
632374	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
632375	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
632376	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Oil Temp Present	30	°C
632377	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
632378	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Clear of Trash?	y	
632379	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
632380	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
632381	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
632382	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
632383	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
632384	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
632385	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
632386	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Patrol Inspection	Follow-up Action Required?	n	
632387	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Follow-up Action Required?	n	
632388	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Patrol Inspection	General Comments		
632389	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	General Comments		
632390	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Maintenance Operations	0	
632391	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Operations Counter AL	1378	
632392	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Switching Operations	0	
632393	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
632394	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
632395	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
632396	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
632397	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
632398	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
632399	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
632400	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
632401	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
632402	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
632403	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
632404	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Operations Counter AF	443	
632405	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Operations Counter AL	443	
632406	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Switching Operations	0	
632407	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Unknown Operations	1	
632408	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
632409	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
632410	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
632411	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
632412	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
632413	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
632414	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
632415	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
632416	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
632417	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Unknown Operations	1	
632418	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	9 Month Operations	6	
632419	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Accumulated Fault Duty C Ph AM	7.23	%
632420	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Amps A Ø	75.0	
632421	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Amps B Ø	50.0	
632422	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Amps C Ø	100.0	
632423	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
632424	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
632425	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
632426	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
632427	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Operations A Ø	0	
632428	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Operations B Ø	0	
632429	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Operations C Ø	0	
632430	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Operations Ground	0	
632431	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	LTC Totalizer Reading	5683.2	kw
632432	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
632433	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Patrol Inspection	Follow-up Action Required?	n	
632434	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Follow-up Action Required?	n	
632435	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
632436	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Oil Temp Max	45	°C
632437	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Patrol Inspection	General Comments		
632438	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Operations Counter AL	99987	
632439	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
632440	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Switching Operations	0	
632441	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Tank Paint Condition	Good	
632442	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
632443	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Vegetation	None	
632444	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
632445	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
632446	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
632447	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	General Comments		
632448	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Unknown Operations	0	
632449	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	General Comments		
632450	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Maintenance Operations	0	
632451	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Operations Counter AF	1378	
632452	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
632453	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
632454	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
632455	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
632456	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	9 Month Operations	13	
632457	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Accumulated Fault Duty A Ph V	6.42	%
632458	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Accumulated Fault Duty B Ph V	12.85	%
632459	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Accumulated Fault Duty C Ph V	4.02	%
632460	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Amps A Ø	100.0	
632461	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Amps B Ø	100.0	
632462	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Amps C Ø	125.0	
632463	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Patrol Inspection	Equipment Properly Labeled?	y	
632464	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
632465	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
632466	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
632467	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Operations A Ø	0	
632468	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Operations B Ø	0	
632469	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Operations C Ø	0	
632470	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Operations Ground	0	
632471	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
632472	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
632473	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
632474	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
632475	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
632476	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
632477	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Switching Operations	0	
632478	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Tank Paint Condition	Good	
632479	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Unknown Operations	0	
632480	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
632481	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
632482	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
632483	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
632484	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
632485	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
632486	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
632487	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
632488	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
632489	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
632490	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
632491	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
632492	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
632493	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
632494	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
632495	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
632496	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
632497	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
632498	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
632499	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	General Comments		
632500	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
632501	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
632502	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
632503	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
632504	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
632505	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
632506	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Foundation Condition	Good	
632507	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
632508	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
632509	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	General Comments		
632510	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
632511	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
632512	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
632513	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
632514	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
632515	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
632516	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
632517	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
632518	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
632519	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
632520	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
632521	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
632522	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
632523	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Tank Leaks	None	
632524	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
632525	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
632526	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	General Comments		
632527	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
632528	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
632529	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
632530	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
632531	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
632532	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
632533	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
632534	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
632535	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
632536	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
632537	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
632538	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
632539	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
632540	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
632541	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Totalizer Meter Reading	.592	
632542	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
632543	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
632544	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Accumulated Fault Duty A Ph V	.45	%
632545	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Accumulated Fault Duty B Ph V	.45	%
632546	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
632547	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Amps A Ø	155.0	
632548	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Amps B Ø	145.0	
632549	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Amps C Ø	180.0	
632550	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Bushing Condition	Good	
632551	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
632552	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
632553	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
632554	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
632555	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Cabinet Paint Condition	Good	
632556	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Equipment Properly Labeled?	y	
632557	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
632558	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
632559	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
632560	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Operations A Ø	0	
632561	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Operations B Ø	0	
632562	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Operations C Ø	0	
632563	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Operations Ground	0	
632564	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Follow-up Action Required?	n	
632565	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Follow-up Action Required?	n	
632566	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Foundation Condition	Good	
632567	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	General Comments		
632568	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	General Comments		
632569	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
632570	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	600	
632571	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	60	
632572	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Grounds in Place?	y	
632573	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Heaters (All) Functioning?	y	
632574	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Maintenance Operations	0	
632575	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Moisture and Leak Free?	y	
632576	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Operations Counter AF	216	
632577	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Operations Counter AL	216	
632578	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
632579	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
632580	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
632581	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
632582	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
632583	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
632584	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	General Comments		
632585	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
632586	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
632587	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Vegetation	None	
632588	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
632589	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
632590	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
632591	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
632592	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
632593	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
632594	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
632595	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
632596	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
632597	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
632598	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
632599	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
632600	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
632601	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
632602	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
632603	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
632604	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Foundation Condition	Good	
632605	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
632606	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
632607	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	General Comments		
632608	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
632609	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
632610	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
632611	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
632612	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
632613	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
632614	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
632615	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
632616	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
632617	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
632618	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
632619	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
632620	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
632621	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
632622	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
632623	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
632624	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	General Comments		
632625	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
632626	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Ambient Temp	36	°F

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
632627	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
632628	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
632629	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Clear of Trash?	y	
632630	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
632631	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Patrol Inspection	Follow-up Action Required?	n	
632632	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Operations Ground	0	
632633	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Operations C Ø	0	
632634	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Operations B Ø	0	
632635	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
632636	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
632637	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	3	
632638	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	3	
632639	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
632640	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Amps B Ø	180.0	
632641	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Amps A Ø	180.0	
632642	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Accumulated Fault Duty C Ph V	.89	%
632643	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
632644	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
632645	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	9 Month Operations	11	
632646	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
632647	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
632648	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
632649	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
632650	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
632651	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
632652	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
632653	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
632654	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
632655	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
632656	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
632657	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
632658	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
632659	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
632660	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
632661	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	7.80	%
632662	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	7.80	%
632663	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	7.80	%
632664	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	8	
632665	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
632666	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
632667	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Clear of Trash?	y	
632668	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
632669	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
632670	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
632671	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
632672	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
632673	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
632674	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	General Comments		
632675	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
632676	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
632677	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
632678	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Vegetation	None	
632679	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
632680	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Ambient Temp	25	°F
632681	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
632682	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
632683	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Clear of Trash?	y	
632684	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	General Comments		
632685	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	Follow-up Action Required?	n	
632686	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	All Connections OK?	y	
632687	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
632688	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
632689	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Amps C Ø	200.0	
632690	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
632691	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
632692	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Amps B Ø	200.0	
632693	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
632694	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
632695	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
632696	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
632697	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
632698	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Follow-up Action Required?	n	
632699	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
632700	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Amps A Ø	200.0	
632701	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Accumulated Fault Duty C Ph V	2.41	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
632702	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Accumulated Fault Duty B Ph V	2.41	%
632703	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Accumulated Fault Duty A Ph V	4.02	%
632704	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	9 Month Operations	0	
632705	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
632706	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	General Comments		
632707	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
632708	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
632709	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
632710	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
632711	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
632712	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
632713	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
632714	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
632715	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
632716	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
632717	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
632718	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
632719	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
632720	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
632721	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	General Comments		
632722	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
632723	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
632724	1/11/2019 8:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.48	%
632725	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	VRR Time Delay	30	Seconds
632726	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
632727	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
632728	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
632729	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
632730	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	LTC Operation Checked?	y	
632731	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	General Comments		
632732	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	Follow-up Action Required?	n	
632733	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	All Connections OK?	y	
632734	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	9 Months Operations	12	
632735	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Accumulated Fault Duty A Ph AM	18.07	%
632736	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Accumulated Fault Duty B Ph AM	16.86	%
632737	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
632738	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
632739	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
632740	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
632741	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
632742	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	General Comments		
632743	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
632744	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
632745	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Vegetation	None	
632746	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
632747	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Operations A Ø	0	
632748	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
632749	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
632750	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
632751	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
632752	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
632753	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
632754	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
632755	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
632756	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Foundation Condition	Good	
632757	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
632758	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
632759	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	General Comments		
632760	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
632761	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
632762	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
632763	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Patrol Inspection	Equipment Properly Labeled?	y	
632764	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
632765	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
632766	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
632767	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
632768	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
632769	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
632770	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
632771	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
632772	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
632773	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
632774	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
632775	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
632776	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
632777	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
632778	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	General Comments	ok	
632779	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
632780	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Foundation Condition	Good	
632781	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
632782	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
632783	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
632784	1/11/2019 16:27	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
632785	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	VRR Time Delay	30	Seconds
632786	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
632787	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
632788	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
632789	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	LTC Operation Checked?	y	
632790	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
632791	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Follow-up Action Required?	n	
632792	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
632793	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
632794	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
632795	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
632796	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
632797	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	y	
632798	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
632799	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
632800	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments	Will not go back in service, can it be removed from insp?	
632801	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments	Will not go back in service, can it be removed from insp?	
632802	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	35242	
632803	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
632804	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
632805	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
632806	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
632807	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	330.0	
632808	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	330.0	
632809	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	330.0	
632810	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
632811	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
632812	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
632813	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
632814	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
632815	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
632816	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
632817	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
632818	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
632819	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
632820	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
632821	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
632822	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
632823	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
632824	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Foundation Condition	Good	
632825	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Follow-up Action Required?	n	
632826	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Follow-up Action Required?	n	
632827	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
632828	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
632829	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
632830	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
632831	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
632832	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
632833	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
632834	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
632835	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
632836	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
632837	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
632838	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Regulator As Left Counter	105033	
632839	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
632840	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
632841	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	35242	
632842	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Operations Ground	0	
632843	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
632844	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
632845	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
632846	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Operations C Ø	0	
632847	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Operations B Ø	0	
632848	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Operations A Ø	0	
632849	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
632850	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
632851	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
632852	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000294	PowerFuse	P-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
632853	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000294	PowerFuse	P-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
632854	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
632855	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
632856	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
632857	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
632858	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
632859	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
632860	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
632861	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
632862	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
632863	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Bushings Connection/Risers	Good	
632864	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Bushing Condition	Good	
632865	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Amps C Ø	80.0	
632866	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Amps B Ø	100.0	
632867	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Amps A Ø	95.0	
632868	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Accumulated Fault Duty C Ph V	1.91	%
632869	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Accumulated Fault Duty B Ph V	2.39	%
632870	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Accumulated Fault Duty A Ph V	6.69	%
632871	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
632872	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
632873	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
632874	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	9 Month Operations	6	
632875	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
632876	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
632877	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	General Comments		
632878	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
632879	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
632880	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Totalizer Meter Reading	.4278	
632881	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
632882	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
632883	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
632884	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
632885	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
632886	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
632887	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
632888	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
632889	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Oil Temp Present	25	°C
632890	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Oil Temp Max	50	°C
632891	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
632892	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
632893	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	40	°C
632894	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	25	°C
632895	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
632896	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	25	°C
632897	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	50	°C
632898	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	25	°C
632899	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
632900	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
632901	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
632902	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
632903	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
632904	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
632905	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
632906	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
632907	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
632908	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
632909	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
632910	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
632911	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
632912	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
632913	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
632914	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	LTC Totalizer Reading	3080.16	kw
632915	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
632916	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	General Comments		
632917	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	General Comments		
632918	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
632919	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
632920	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
632921	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
632922	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
632923	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
632924	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Oil Temp Present	30	°C
632925	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Oil Temp Max	50	°C
632926	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
632927	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
632928	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	9 Month Operations	3	
632929	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Accumulated Fault Duty A Ph V	12.84	%
632930	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Accumulated Fault Duty B Ph V	11.85	%
632931	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Accumulated Fault Duty C Ph V	11.85	%
632932	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Amps A Ø	150.0	
632933	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
632934	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
632935	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
632936	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
632937	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
632938	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
632939	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Amps B Ø	180.0	
632940	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Amps C Ø	190.0	
632941	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
632942	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	LTC Totalizer Reading	595.20	kw
632943	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
632944	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Bushing Condition	Good	
632945	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Bushings Connection/Risers	Good	
632946	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
632947	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
632948	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
632949	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Grounds in Place?	y	
632950	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Heaters (All) Functioning?	y	
632951	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Maintenance Operations	0	
632952	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Moisture and Leak Free?	y	
632953	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Operations Counter AF	264	
632954	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Operations Counter AL	266	
632955	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Switching Operations	2	
632956	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Tank Paint Condition	Good	
632957	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Unknown Operations	0	
632958	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
632959	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
632960	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
632961	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
632962	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
632963	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
632964	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
632965	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
632966	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
632967	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	All Connections OK?	y	
632968	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
632969	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Amps A Ø	0.0	
632970	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Cabinet Paint Condition	Good	
632971	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Equipment Properly Labeled?	y	
632972	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
632973	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
632974	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Operations A Ø	0	
632975	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Battery Overall Condition	Good	
632976	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
632977	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
632978	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
632979	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Cell Electrolyte Level	Water Added	If low,note cell #~'s
632980	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Operations B Ø	0	
632981	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Operations C Ø	0	
632982	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Operations Ground	0	
632983	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Follow-up Action Required?	n	
632984	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
632985	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
632986	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
632987	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
632988	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
632989	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
632990	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Operations A Ø	0	
632991	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Operations B Ø	0	
632992	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
632993	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
632994	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Tank Leaks	None	
632995	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
632996	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Operations C Ø	0	
632997	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Foundation Condition	Good	
632998	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	General Comments		
632999	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	General Comments		
633000	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	All Connections OK?	y	
633001	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
633002	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
633003	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Follow-up Action Required?	n	
633004	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
633005	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	Follow-up Action Required?	n	
633006	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	General Comments	ok	
633007	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	LTC Operation Checked?	y	
633008	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	LTC Output Voltage Level	113.5	VAC
633009	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	VRR Base Voltage AF	112.0	VAC
633010	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	VRR Base Voltage AL	112.0	VAC
633011	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
633012	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
633013	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
633014	1/11/2019 11:02	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	VRR Time Delay	30	Seconds
633015	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	General Comments		
633016	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
633017	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
633018	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
633019	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1450	psi
633020	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	Oil Temp Max	36	°C
633021	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	Oil Temp Present	12	°C
633022	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
633023	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
633024	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
633025	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
633026	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
633027	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
633028	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
633029	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
633030	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
633031	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
633032	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
633033	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	37	°C
633034	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	12	°C
633035	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
633036	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	37	°C
633037	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Cabinet Paint Condition	Good	
633038	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Equipment Properly Labeled?	y	
633039	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	12	°C
633040	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	37	°C
633041	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
633042	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	13	°C
633043	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
633044	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
633045	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Totalizer Meter Reading	.1860	
633046	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
633047	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
633048	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
633049	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
633050	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
633051	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	7L	
633052	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	366	
633053	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
633054	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
633055	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
633056	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
633057	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	29	°F
633058	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
633059	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
633060	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments	Will not go back in service, can it be removed from insp?	
633061	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments	Will not go back in service, can it be removed from insp?	
633062	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
633063	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
633064	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	59102	
633065	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	59102	
633066	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
633067	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	2R	
633068	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
633069	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
633070	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
633071	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
633072	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
633073	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	2R	
633074	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000290	PowerFuse	P-STA SER 1	Disconnect Powerfuse Inspection	General Comments	OK	
633075	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000290	PowerFuse	P-STA SER 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
633076	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	2R	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
633077	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	0	
633078	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
633079	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
633080	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
633081	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	LTCC000252	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
633082	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	General Comments		
633083	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	General Comments		
633084	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
633085	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
633086	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
633087	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
633088	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	8572.80	kw
633089	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
633090	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
633091	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
633092	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
633093	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
633094	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
633095	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
633096	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
633097	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
633098	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	LTCC000252	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
633099	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	LTCC000252	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
633100	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	LTCC000252	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
633101	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	LTCC000252	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
633102	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
633103	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
633104	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	LTCC000252	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
633105	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	LTCC000252	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
633106	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	LTCC000252	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
633107	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6830	
633108	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
633109	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
633110	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
633111	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
633112	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
633113	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
633114	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
633115	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
633116	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Tank Leaks	None	
633117	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	LTC Max Tap Position	11R	
633118	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10R	
633119	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
633120	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
633121	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
633122	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
633123	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
633124	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
633125	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
633126	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
633127	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
633128	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
633129	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	7475	
633130	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	7475	
633131	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9R	
633132	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
633133	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
633134	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
633135	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
633136	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
633137	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
633138	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	LTC As Left Counter	300451	
633139	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	LTC As Found Counter	300451	
633140	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	2 gauges read full & 1 gauge reads OK	
633141	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	General Comments		
633142	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
633143	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
633144	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
633145	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	9 Month Operations	4	
633146	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
633147	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
633148	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
633149	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
633150	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
633151	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
633152	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
633153	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Amps A Ø	0.0	
633154	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Amps B Ø	0.0	
633155	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Amps C Ø	0.0	
633156	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
633157	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
633158	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
633159	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
633160	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
633161	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
633162	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
633163	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
633164	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
633165	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	170	
633166	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Regulator As Left Counter	116808	
633167	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
633168	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
633169	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	High	
633170	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
633171	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
633172	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	General Comments		
633173	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
633174	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	42668	
633175	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	42668	
633176	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
633177	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	1L	
633178	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	5L	
633179	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Operations Counter AF	483	
633180	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Moisture and Leak Free?	y	
633181	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Maintenance Operations	0	
633182	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
633183	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Heaters (All) Functioning?	y	
633184	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
633185	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
633186	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
633187	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Operations Since Last Insp	1084	
633188	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Min Tap Position	3L	
633189	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
633190	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
633191	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
633192	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
633193	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
633194	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
633195	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
633196	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
633197	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
633198	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
633199	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	General Comments		
633200	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
633201	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Max Tap Position	13L	
633202	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Min Tap Position	1L	
633203	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
633204	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
633205	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Max Tap Position	12L	
633206	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Current Tap Position	4L	
633207	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
633208	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC As Left Counter	21785	
633209	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC As Found Counter	21783	
633210	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	General Comments		
633211	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	General Comments		
633212	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
633213	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	Follow-up Action Required?	n	
633214	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
633215	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
633216	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Unknown Operations	0	
633217	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Tank Paint Condition	Good	
633218	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Switching Operations	0	
633219	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
633220	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Operations Counter AL	99936	
633221	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Operations Counter AF	99935	
633222	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Moisture and Leak Free?	y	
633223	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Maintenance Operations	1	
633224	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Heaters (All) Functioning?	y	
633225	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Grounds in Place?	y	
633226	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	General Comments	ok	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
633227	1/11/2019 15:25	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	General Comments	ok	
633228	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
633229	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	General Comments		
633230	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
633231	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Follow-up Action Required?	n	
633232	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Follow-up Action Required?	n	
633233	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Operations Ground	0	
633234	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Operations C Ø	0	
633235	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Operations B Ø	0	
633236	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Operations A Ø	0	
633237	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
633238	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
633239	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
633240	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Equipment Properly Labeled?	y	
633241	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Cabinet Paint Condition	Good	
633242	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
633243	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
633244	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
633245	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
633246	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
633247	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
633248	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
633249	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
633250	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
633251	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
633252	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
633253	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
633254	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
633255	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
633256	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
633257	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
633258	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
633259	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
633260	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
633261	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
633262	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
633263	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	96.00	
633264	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1639.20	kw
633265	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
633266	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
633267	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
633268	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	General Comments		
633269	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	General Comments		
633270	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
633271	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
633272	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
633273	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
633274	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
633275	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
633276	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	9 Month Operations	5	
633277	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
633278	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
633279	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
633280	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Top Oil Temperature Max	42	°C
633281	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Top Oil Temperature Present	27	°C
633282	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
633283	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8930	
633284	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Winding Temp Max	30	°C
633285	1/11/2019 14:04	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Winding Temp Present	30	°C
633286	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
633287	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
633288	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
633289	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
633290	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
633291	1/11/2019 11:09	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
633292	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
633293	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Min Tap Position	2R	
633294	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Max Tap Position	9L	
633295	1/11/2019 6:23	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
633296	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
633297	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
633298	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	General Comments		
633299	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitro, Bottle empty	
633300	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
633301	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
633302	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Unknown Operations	0	
633303	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Tank Paint Condition	Good	
633304	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Switching Operations	0	
633305	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
633306	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
633307	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
633308	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Operations Counter AL	483	
633309	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Bushings Connection/Risers	Good	
633310	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Bushing Condition	Good	
633311	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
633312	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
633313	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
633314	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
633315	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
633316	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	LTC As Left Counter	48738	
633317	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	LTC As Found Counter	48738	
633318	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
633319	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	General Comments		
633320	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
633321	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
633322	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
633323	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
633324	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
633325	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	123	
633326	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
633327	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
633328	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
633329	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
633330	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
633331	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
633332	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
633333	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
633334	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Amps C Ø	180.0	
633335	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Amps B Ø	200.0	
633336	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Amps A Ø	180.0	
633337	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
633338	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
633339	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Follow-up Action Required?	n	
633340	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Tank Leaks	None	
633341	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Tank Paint Condition	Good	
633342	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Unknown Operations	0	
633343	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
633344	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
633345	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
633346	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	General Comments		
633347	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	General Comments		
633348	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
633349	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	LTC Totalizer Reading	3255.84	kw
633350	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	123	
633351	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
633352	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
633353	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Oil Temp Max	65	°C
633354	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	26	°F
633355	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
633356	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
633357	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
633358	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
633359	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
633360	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
633361	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
633362	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
633363	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
633364	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
633365	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
633366	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
633367	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
633368	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
633369	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	150	
633370	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	125	
633371	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	170	
633372	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
633373	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	y	
633374	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
633375	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
633376	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Tank Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
633377	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
633378	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	Follow-up Action Required?	n	
633379	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
633380	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	General Comments		
633381	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	General Comments	indicator not working	
633382	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC As Found Counter	203990	
633383	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
633384	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
633385	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5L	
633386	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
633387	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
633388	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	290	
633389	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
633390	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC As Left Counter	203993	
633391	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
633392	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Current Tap Position	4L	
633393	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	General Comments		
633394	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Grounds in Place?	y	
633395	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Maintenance Operations	0	
633396	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
633397	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
633398	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
633399	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
633400	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Number of Ops last 9 Months	15	
633401	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC Current Tap Position	1R	
633402	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
633403	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC As Left Counter	292562	
633404	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Max Tap Position	4L	
633405	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Operations Counter AF	826	
633406	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Operations Counter AL	826	
633407	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Switching Operations	1	
633408	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
633409	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
633410	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
633411	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
633412	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Oil Temp Present	50	°C
633413	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Min Tap Position	4L	
633414	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Operations Since Last Insp	863	
633415	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
633416	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
633417	1/11/2019 7:39	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
633418	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
633419	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
633420	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC As Found Counter	292550	
633421	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	General Comments	OK	
633422	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	General Comments	ok	
633423	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
633424	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	Follow-up Action Required?	n	
633425	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
633426	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
633427	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
633428	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	General Comments		
633429	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
633430	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
633431	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
633432	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
633433	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
633434	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
633435	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
633436	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
633437	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
633438	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
633439	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
633440	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
633441	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000292	PowerFuse	P-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
633442	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	PF000292	PowerFuse	P-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
633443	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
633444	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
633445	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
633446	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
633447	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
633448	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
633449	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Follow-up Action Required?	n	
633450	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
633451	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
633452	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	General Comments		
633453	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	General Comments		
633454	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
633455	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	LTC Totalizer Reading	8219.52	kw
633456	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
633457	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
633458	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
633459	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
633460	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
633461	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
633462	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
633463	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
633464	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Oil Temp Max	35	°C
633465	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Oil Temp Present	30	°C
633466	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
633467	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
633468	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
633469	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
633470	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
633471	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
633472	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
633473	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
633474	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
633475	1/11/2019 8:35	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
633476	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
633477	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
633478	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Totalizer Meter Reading	.8562	
633479	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
633480	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
633481	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
633482	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Grounds in Place?	y	
633483	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
633484	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
633485	1/11/2019 12:58	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
633486	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
633487	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
633488	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
633489	1/11/2019 14:10	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
633490	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Min Tap Position	4R	
633491	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
633492	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
633493	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
633494	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
633495	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
633496	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
633497	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	General Comments		
633498	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
633499	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Max Tap Position	11L	
633500	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
633501	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	y	
633502	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
633503	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Amps A Ø	43.0	
633504	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Amps B Ø	36.0	
633505	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Amps C Ø	31.0	
633506	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
633507	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
633508	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
633509	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
633510	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
633511	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
633512	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
633513	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
633514	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
633515	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	General Comments	ok	
633516	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
633517	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
633518	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Operations Counter	109	
633519	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
633520	1/11/2019 9:57	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
633521	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
633522	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
633523	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
633524	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
633525	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
633526	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
633527	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
633528	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
633529	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
633530	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
633531	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
633532	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
633533	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
633534	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	348	
633535	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	348	
633536	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
633537	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
633538	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
633539	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
633540	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
633541	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	5	
633542	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
633543	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
633544	1/11/2019 9:40	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
633545	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	General Comments		
633546	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	General Comments		
633547	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	-352323860	
633548	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
633549	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	LTC As Left Counter	56509	
633550	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
633551	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	23	VDC
633552	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	3	VDC
633553	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
633554	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
633555	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	6.0	VDC
633556	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	34.0	VDC
633557	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
633558	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
633559	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
633560	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
633561	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
633562	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
633563	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
633564	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
633565	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
633566	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
633567	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
633568	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	LTC Current Tap Position	6R	
633569	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	LTC Max Tap Position	6R	
633570	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	LTC Min Tap Position	6R	
633571	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
633572	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	16	
633573	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
633574	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
633575	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
633576	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
633577	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
633578	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
633579	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
633580	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
633581	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
633582	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	General Comments		
633583	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	General Comments		
633584	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
633585	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
633586	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
633587	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
633588	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	2030	
633589	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	General Comments		
633590	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	needs desiccant	
633591	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
633592	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Maintenance Operations	0	
633593	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
633594	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Operations Counter AF	182	
633595	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Operations Counter AL	184	
633596	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Switching Operations	2	
633597	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
633598	1/11/2019 12:37	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Unknown Operations	0	
633599	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	2030	
633600	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	11	
633601	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
633602	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Foundation Condition	Good	
633603	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Readings	X2 Winding Temp Present	0	°C
633604	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Readings	X2 Winding Temp Max	0	°C
633605	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
633606	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	85.00	
633607	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
633608	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
633609	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
633610	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
633611	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
633612	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Follow-up Action Required?	n	
633613	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Fault Operations	0	
633614	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
633615	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
633616	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
633617	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
633618	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Operational?	y	
633619	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
633620	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	General Comments		
633621	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	5	
633622	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
633623	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6R	
633624	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6R	
633625	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
633626	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	0	°C
633627	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	0	°C
633628	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
633629	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
633630	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
633631	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
633632	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments	Will not go back in service, can it be removed from insp?	
633633	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments	Will not go back in service, can it be removed from insp?	
633634	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
633635	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	LTC Min Tap Position	6R	
633636	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	252	
633637	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
633638	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	5R	
633639	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
633640	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	5R	
633641	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	5R	
633642	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
633643	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
633644	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
633645	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
633646	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
633647	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
633648	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
633649	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	General Comments		
633650	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
633651	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
633652	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
633653	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Follow-up Action Required?	n	
633654	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	LTC As Found Counter	56509	
633655	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
633656	1/11/2019 14:48	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
633657	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
633658	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC As Found Counter	17432	
633659	1/11/2019 13:51	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC As Left Counter	17432	
633660	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
633661	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
633662	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
633663	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC Min Tap Position	1L	
633664	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC Max Tap Position	4R	
633665	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
633666	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Tank Leaks	None	
633667	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
633668	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Regulator As Left Counter	114171	
633669	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Amps B Ø	0.0	
633670	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Amps C Ø	0.0	
633671	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
633672	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
633673	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
633674	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
633675	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
633676	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Positive DC Ground	0.0	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
633677	1/11/2019 6:31	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
633678	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	26	°F
633679	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
633680	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
633681	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	General Comments	Added water to all cells	
633682	1/11/2019 11:09	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
633683	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Bushing Condition	Good	
633684	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Bushing Oil Level	Good	
633685	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
633686	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
633687	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
633688	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
633689	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
633690	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
633691	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
633692	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
633693	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Follow-up Action Required?	n	
633694	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
633695	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
633696	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
633697	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
633698	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
633699	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
633700	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Eyewash Solution	Good	
633701	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
633702	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
633703	1/11/2019 13:58	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Totalizer Meter Reading	1.3566	
633704	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
633705	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
633706	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
633707	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
633708	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
633709	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
633710	1/11/2019 10:19	Distribution	Lebanon Industrial Quarterly Inspection	BAT000591	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
633711	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
633712	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
633713	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Follow-up Action Required?	n	
633714	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
633715	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Foundation Condition	Good	
633716	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	General Comments		
633717	1/11/2019 10:22	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	General Comments		
633718	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
633719	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
633720	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
633721	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	General Comments		
633722	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
633723	1/14/2019 11:43	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
633724	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
633725	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
633726	1/11/2019 9:19	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC Operations Since Last Insp	88	
633727	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
633728	1/11/2019 6:41	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
633729	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	LTCC000828	LTCControl	863-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
633730	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	LTCC000828	LTCControl	863-1	LTC Control Insp	All Connections OK?	y	
633731	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	LTCC000828	LTCControl	863-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
633732	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	LTCC000828	LTCControl	863-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
633733	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	LTCC000828	LTCControl	863-1	LTC Control Insp	LTC Operation Checked?	y	
633734	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	LTCC000828	LTCControl	863-1	LTC Control Insp	General Comments	ok	
633735	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	LTCC000828	LTCControl	863-1	LTC Control Insp	Follow-up Action Required?	n	
633736	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	LTCC000828	LTCControl	863-1	LTC Control Insp	VRR Time Delay	30	Seconds
633737	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BCH000422	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
633738	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BCH000422	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
633739	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BCH000422	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.7	VDC
633740	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
633741	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
633742	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
633743	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
633744	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
633745	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
633746	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Percent Thermal Load C Ø Max	80	%
633747	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Commissioning Inspection	Commissioning Steps Complete	y	
633748	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	92.50	
633749	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
633750	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Energization Inspection	Cascade Nameplate Correct	y	
633751	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
633752	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
633753	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	80	%
633754	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Percent Thermal Load A Ø Max	80	%
633755	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
633756	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
633757	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
633758	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Oil Temp Present	10	°C
633759	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
633760	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
633761	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
633762	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
633763	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
633764	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
633765	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
633766	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
633767	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Accumulated Fault Duty C Ph AM	10.92	%
633768	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
633769	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.800	millivolts
633770	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Accumulated Fault Duty B Ph AM	15.77	%
633771	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
633772	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	General Comments		
633773	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
633774	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	H3 Winding Temp Max	80	°C
633775	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	9 Months Operations	11	
633776	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	H3 Winding Temp Present	15	°C
633777	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
633778	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Amps C Ø	60.0	
633779	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Amps B Ø	80.0	
633780	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Amps A Ø	100.0	
633781	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
633782	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Accumulated Fault Duty B Ph AM	1.2	%
633783	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Accumulated Fault Duty A Ph AM	1.2	%
633784	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	9 Months Operations	2	
633785	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Accumulated Fault Duty A Ph AM	12.13	%
633786	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
633787	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Operations Counter AF	131	
633788	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Maintenance Operations	0	
633789	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	General Comments		
633790	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Patrol Inspection	General Comments		
633791	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Oil Temp Max	140	°C
633792	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	400.00	
633793	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
633794	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
633795	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	417.50	
633796	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2580.48	kw
633797	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Follow-up Action Required?	n	
633798	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
633799	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Patrol Inspection	Follow-up Action Required?	n	
633800	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Operations Ground	0	
633801	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Operations C Ø	0	
633802	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Operations B Ø	0	
633803	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Oil Temp Present	19	°C
633804	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Operations A Ø	0	
633805	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
633806	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
633807	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
633808	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
633809	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
633810	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
633811	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
633812	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
633813	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Amps C Ø	200.0	
633814	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
633815	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Amps B Ø	200.0	
633816	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Operations Counter AL	131	
633817	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
633818	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Switching Operations	1	
633819	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
633820	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
633821	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Regulator As Left Counter	21830	
633822	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
633823	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
633824	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Amps A Ø	200.0	
633825	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Tank Leaks	None	
633826	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
633827	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
633828	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
633829	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Unknown Operations	0	
633830	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
633831	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
633832	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	General Comments		
633833	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
633834	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
633835	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
633836	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
633837	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
633838	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	General Comments		
633839	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
633840	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
633841	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
633842	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
633843	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
633844	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
633845	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
633846	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
633847	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
633848	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
633849	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
633850	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
633851	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
633852	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
633853	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
633854	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
633855	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
633856	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
633857	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
633858	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
633859	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Operations B Ø	0	
633860	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Operations C Ø	0	
633861	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Operations Ground	0	
633862	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Follow-up Action Required?	n	
633863	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
633864	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	General Comments	.	
633865	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Maintenance Operations	0	
633866	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Operations Counter AF	818	
633867	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Unknown Operations	0	
633868	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Switching Operations	0	
633869	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Operations Counter AL	1431	
633870	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Operations Counter AF	1431	
633871	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Maintenance Operations	0	
633872	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
633873	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
633874	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
633875	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	General Comments	A,B and C phase IOC	
633876	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Patrol Inspection	General Comments		
633877	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
633878	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Follow-up Action Required?	n	
633879	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Operations Counter AL	818	
633880	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Switching Operations	2	
633881	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Unknown Operations	0	
633882	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
633883	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
633884	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
633885	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
633886	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
633887	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
633888	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Patrol Inspection	Follow-up Action Required?	n	
633889	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Operations Ground	0	
633890	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Operations C Ø	1	
633891	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Operations B Ø	1	
633892	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Operations A Ø	1	
633893	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
633894	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
633895	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	5R	
633896	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
633897	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
633898	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
633899	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
633900	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
633901	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
633902	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
633903	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
633904	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
633905	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
633906	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Amps C Ø	12.0	
633907	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Amps B Ø	12.0	
633908	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
633909	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
633910	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
633911	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
633912	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
633913	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	225.00	
633914	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	General Comments		
633915	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Foundation Condition	Good	
633916	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
633917	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
633918	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
633919	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
633920	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
633921	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
633922	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
633923	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
633924	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Unknown Operations	0	
633925	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Switching Operations	0	
633926	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Operations Counter AL	873	
633927	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Operations Counter AF	873	
633928	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
633929	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
633930	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
633931	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
633932	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Panel Lights OK?	y	
633933	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
633934	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Annual Control Inspection	Ground Lead 3 Resistance Set 2	0.0	Micro Ohms
633935	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
633936	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
633937	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
633938	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
633939	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
633940	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
633941	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
633942	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Maintenance Operations	0	
633943	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	General Comments	IOC on A & B Phase	
633944	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	9 Months Operations	3	
633945	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
633946	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
633947	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Accumulated Fault Duty C Ph AM	1.2	%
633948	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Amps A Ø	200.0	
633949	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
633950	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Amps B Ø	200.0	
633951	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Amps C Ø	200.0	
633952	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
633953	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
633954	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
633955	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
633956	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
633957	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Operations A Ø	0	
633958	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
633959	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	6R	
633960	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	4L	
633961	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
633962	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
633963	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
633964	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
633965	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
633966	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	General Comments	ok	
633967	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
633968	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
633969	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
633970	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
633971	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
633972	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
633973	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
633974	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
633975	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
633976	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
633977	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
633978	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
633979	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
633980	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
633981	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Unknown Operations	0	
633982	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Switching Operations	0	
633983	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Operations Counter AL	1273	
633984	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Operations Counter AF	1273	
633985	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Maintenance Operations	0	
633986	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	General Comments		
633987	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Follow-up Action Required?	n	
633988	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Operations Ground	0	
633989	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Operations C Ø	0	
633990	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Operations B Ø	0	
633991	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Operations A Ø	0	
633992	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
633993	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
633994	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
633995	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
633996	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
633997	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
633998	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
633999	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
634000	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	General Comments		
634001	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
634002	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
634003	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.0	amps
634004	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
634005	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
634006	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
634007	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Amps A Ø	12.0	
634008	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Follow-up Action Required?	n	
634009	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Operations Ground	0	
634010	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Operations C Ø	0	
634011	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Operations B Ø	1	
634012	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
634013	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
634014	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Operations A Ø	1	
634015	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
634016	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
634017	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
634018	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
634019	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
634020	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Amps C Ø	300.0	
634021	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
634022	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Annual Control Inspection	Ground Lead 3 Resistance Set 1	0.0	Micro Ohms
634023	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Annual Control Inspection	Ground Lead 2 Resistance Set 2	0.0	Micro Ohms
634024	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Annual Control Inspection	Ground Lead 2 Resistance Set 1	0.0	Micro Ohms
634025	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Annual Control Inspection	Ground Lead 1 Resistance Set 2	0.0	Micro Ohms
634026	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Annual Control Inspection	Ground Lead 1 Resistance Set 1	0.0	Micro Ohms
634027	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Commissioning Inspection	General Comments	this needs to be removed.	
634028	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Energization Inspection	General Comments	this needs to be removed	
634029	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Annual Control Inspection	General Comments	this needs to be removed	
634030	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	General Comments		
634031	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
634032	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Annual Control Inspection	Follow-up Action Required?	y	
634033	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
634034	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
634035	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
634036	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Amps B Ø	190.0	
634037	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Energization Inspection	Energization Steps Complete	y	
634038	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Amps A Ø	380.0	
634039	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Accumulated Fault Duty C Ph AM	9.64	%
634040	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Accumulated Fault Duty B Ph AM	10.84	%
634041	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Accumulated Fault Duty A Ph AM	10.84	%
634042	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
634043	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	9 Months Operations	26	
634044	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Accumulated Fault Duty C Ph AM	9.64	%
634045	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Accumulated Fault Duty B Ph AM	18.07	%
634046	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Accumulated Fault Duty A Ph AM	16.86	%
634047	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	9 Months Operations	22	
634048	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
634049	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
634050	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
634051	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
634052	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Mechanism Patrol Inspection	General Comments		
634053	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	General Comments		
634054	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
634055	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
634056	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
634057	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
634058	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
634059	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
634060	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
634061	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
634062	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
634063	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
634064	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
634065	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
634066	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
634067	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
634068	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
634069	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
634070	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
634071	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
634072	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	9 Months Operations	9	
634073	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
634074	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
634075	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
634076	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
634077	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	General Comments		
634078	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	Follow-up Action Required?	n	
634079	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
634080	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	General Comments		
634081	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	General Comments		
634082	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
634083	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
634084	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	35.0	
634085	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	43.0	
634086	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	47.0	
634087	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
634088	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC As Found Counter	407686	
634089	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
634090	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
634091	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
634092	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
634093	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
634094	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
634095	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
634096	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
634097	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
634098	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
634099	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
634100	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
634101	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	General Comments		
634102	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
634103	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
634104	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
634105	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
634106	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Tank Leaks	None	
634107	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
634108	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
634109	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
634110	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
634111	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
634112	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
634113	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
634114	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
634115	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Operations Ground	0	
634116	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Patrol Inspection	Follow-up Action Required?	n	
634117	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Follow-up Action Required?	n	
634118	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Patrol Inspection	General Comments		
634119	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Accumulated Fault Duty A Ph AM	8.54	%
634120	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
634121	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	General Comments		
634122	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
634123	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
634124	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
634125	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LTCC000401	LTCControl	AB-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
634126	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LTCC000401	LTCControl	AB-TRANS 1	LTC Control Insp	General Comments	ok	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
634127	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LTCC000401	LTCControl	AB-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
634128	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
634129	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
634130	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Bushing Condition	Good	
634131	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
634132	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
634133	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
634134	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
634135	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
634136	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
634137	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
634138	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
634139	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
634140	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Grounds in Place?	y	
634141	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	General Comments		
634142	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
634143	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
634144	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Fans Condition	Good	
634145	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
634146	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Bushing Condition	Good	
634147	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
634148	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
634149	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
634150	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4L	
634151	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
634152	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
634153	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC As Left Counter	36101	
634154	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Follow-up Action Required?	n	
634155	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Foundation Condition	Good	
634156	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	General Comments		
634157	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	General Comments		
634158	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Grounds in Place?	y	
634159	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
634160	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Maintenance Operations	0	
634161	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC As Found Counter	36101	
634162	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
634163	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	General Comments		
634164	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
634165	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
634166	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Broom on Site?	y	
634167	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
634168	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
634169	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
634170	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
634171	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Evidence of Insects	None	
634172	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
634173	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
634174	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
634175	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
634176	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	45	°C
634177	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
634178	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Operations Counter AF	244	
634179	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Floor Swept?	y	
634180	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
634181	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
634182	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	General Comments	restroom out of order	
634183	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
634184	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
634185	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Panels Dusted?	y	
634186	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Restroom Clean & OK?	n	
634187	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
634188	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
634189	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Trash Emptied?	y	
634190	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
634191	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
634192	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	55	°C
634193	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	42	°C
634194	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
634195	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
634196	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
634197	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
634198	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC As Found Counter	7649	
634199	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC As Left Counter	7649	
634200	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
634201	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
634202	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6L	
634203	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
634204	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
634205	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	514	
634206	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
634207	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Operations A Ø	0	
634208	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Operations B Ø	0	
634209	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Operations C Ø	0	
634210	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Operations Ground	0	
634211	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Follow-up Action Required?	n	
634212	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
634213	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC As Left Counter	407686	
634214	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
634215	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC Current Tap Position	9L	
634216	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
634217	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
634218	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
634219	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
634220	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC Max Tap Position	1L	
634221	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC Min Tap Position	16L	
634222	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
634223	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
634224	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
634225	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
634226	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Adequate	
634227	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
634228	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	General Comments		
634229	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
634230	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
634231	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
634232	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
634233	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
634234	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
634235	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
634236	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
634237	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
634238	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
634239	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	772	
634240	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
634241	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	PF000195	PowerFuse	LO-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
634242	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	General Comments		
634243	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
634244	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
634245	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
634246	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
634247	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
634248	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	38	°C
634249	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	68	°C
634250	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Patrol Inspection	General Comments		
634251	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Follow-up Action Required?	n	
634252	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
634253	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations Ground	0	
634254	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations C Ø	0	
634255	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations B Ø	0	
634256	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations A Ø	0	
634257	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
634258	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
634259	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LTCC000226	LTCControl	AB-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
634260	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LTCC000226	LTCControl	AB-TRANS 2	LTC Control Insp	General Comments		
634261	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LTCC000226	LTCControl	AB-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
634262	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
634263	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
634264	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Amps C Ø	100.0	
634265	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Amps B Ø	100.0	
634266	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
634267	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
634268	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
634269	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
634270	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Amps A Ø	50.0	
634271	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
634272	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Unknown Operations	0	
634273	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Switching Operations	0	
634274	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Operations Counter AL	79	
634275	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Operations Counter AF	79	
634276	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
634277	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	General Comments	this is the correct VC	
634278	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
634279	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
634280	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
634281	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Patrol Inspection	General Comments		
634282	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Follow-up Action Required?	n	
634283	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Patrol Inspection	Follow-up Action Required?	n	
634284	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Operations Ground	0	
634285	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Operations C Ø	0	
634286	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Operations B Ø	0	
634287	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	425	
634288	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
634289	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
634290	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
634291	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
634292	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
634293	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
634294	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
634295	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Operations A Ø	0	
634296	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Operations B Ø	0	
634297	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Operations C Ø	0	
634298	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Operations Ground	0	
634299	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Patrol Inspection	Follow-up Action Required?	n	
634300	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Follow-up Action Required?	n	
634301	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Patrol Inspection	General Comments		
634302	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	General Comments		
634303	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Maintenance Operations	0	
634304	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Operations Counter AF	796	
634305	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Operations Counter AL	796	
634306	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Switching Operations	0	
634307	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Unknown Operations	0	
634308	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Switching Operations	0	
634309	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Unknown Operations	0	
634310	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Ambient Temp	29	°F
634311	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
634312	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
634313	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Clear of Trash?	y	
634314	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
634315	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
634316	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
634317	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
634318	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
634319	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
634320	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	General Comments	ok	
634321	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
634322	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Vegetation	None	
634323	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
634324	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Unknown Operations	0	
634325	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Switching Operations	0	
634326	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	PF000196	PowerFuse	LO-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
634327	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	PF000196	PowerFuse	LO-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
634328	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Operations Counter AL	273	
634329	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Operations Counter AF	273	
634330	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Maintenance Operations	0	
634331	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
634332	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	PF000195	PowerFuse	LO-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
634333	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
634334	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
634335	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
634336	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
634337	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
634338	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
634339	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
634340	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
634341	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
634342	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
634343	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
634344	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
634345	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
634346	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
634347	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
634348	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	9 Month Operations	2	
634349	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Accumulated Fault Duty A Ph V	2.87	%
634350	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Accumulated Fault Duty B Ph V	7.89	%
634351	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
634352	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
634353	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
634354	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
634355	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
634356	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments		
634357	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
634358	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
634359	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
634360	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
634361	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Accumulated Fault Duty C Ph V	2.87	%
634362	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Amps A Ø	100.0	
634363	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Amps B Ø	100.0	
634364	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Amps C Ø	100.0	
634365	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Patrol Inspection	Equipment Properly Labeled?	y	
634366	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
634367	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
634368	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
634369	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Operations A Ø	0	
634370	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Operations B Ø	0	
634371	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Operations C Ø	0	
634372	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
634373	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
634374	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
634375	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Operations Counter	160	
634376	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
634377	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
634378	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	General Comments	ok	
634379	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Operations A Ø	0	
634380	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
634381	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
634382	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
634383	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
634384	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	General Comments		
634385	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
634386	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Foundation Condition	Good	
634387	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
634388	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
634389	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	9 Month Operations	0	
634390	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
634391	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
634392	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
634393	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Amps A Ø	200.0	
634394	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Amps B Ø	250.0	
634395	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Amps C Ø	250.0	
634396	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
634397	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
634398	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
634399	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	General Comments		
634400	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
634401	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC As Found Counter	26164	
634402	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC As Left Counter	26164	
634403	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
634404	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC Current Tap Position	11L	
634405	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC Max Tap Position	9L	
634406	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC Min Tap Position	13L	
634407	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	149	
634408	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Patrol Inspection	Equipment Properly Labeled?	y	
634409	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Amps C Ø	158.0	
634410	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Amps B Ø	153.0	
634411	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Amps A Ø	167.0	
634412	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Accumulated Fault Duty C Ph V	13.63	%
634413	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Accumulated Fault Duty B Ph V	12.20	%
634414	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Accumulated Fault Duty A Ph V	16.50	%
634415	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	9 Month Operations	13	
634416	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
634417	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
634418	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
634419	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
634420	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	General Comments		
634421	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
634422	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
634423	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
634424	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
634425	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
634426	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
634427	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
634428	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Tank Leaks	None	
634429	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
634430	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	9 Months Operations	11	
634431	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Accumulated Fault Duty A Ph AM	4.82	%
634432	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Accumulated Fault Duty B Ph AM	4.82	%
634433	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
634434	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
634435	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
634436	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
634437	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
634438	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
634439	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
634440	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
634441	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
634442	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
634443	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	General Comments		
634444	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
634445	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
634446	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
634447	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
634448	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
634449	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Unknown Operations	0	
634450	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Tank Paint Condition	Good	
634451	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Switching Operations	0	
634452	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
634453	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Operations Counter AL	195	
634454	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
634455	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Operations Counter AF	195	
634456	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Moisture and Leak Free?	y	
634457	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
634458	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
634459	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	271.00	
634460	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
634461	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
634462	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Maintenance Operations	0	
634463	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
634464	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
634465	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Amps C Ø	75.0	
634466	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Amps B Ø	110.0	
634467	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Amps A Ø	100.0	
634468	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Accumulated Fault Duty C Ph AM	2.13	%
634469	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Accumulated Fault Duty B Ph AM	7.47	%
634470	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Accumulated Fault Duty A Ph AM	7.47	%
634471	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
634472	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
634473	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
634474	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
634475	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
634476	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Operations Counter AL	484	
634477	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Operations Counter AF	484	
634478	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Maintenance Operations	0	
634479	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
634480	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	General Comments		
634481	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Patrol Inspection	General Comments		
634482	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Follow-up Action Required?	n	
634483	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
634484	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
634485	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
634486	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
634487	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Operations Ground	0	
634488	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Operations C Ø	0	
634489	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Operations B Ø	0	
634490	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Operations A Ø	0	
634491	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
634492	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
634493	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
634494	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
634495	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
634496	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
634497	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
634498	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
634499	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
634500	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
634501	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
634502	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
634503	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
634504	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
634505	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
634506	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
634507	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
634508	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
634509	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
634510	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
634511	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
634512	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
634513	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
634514	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
634515	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
634516	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
634517	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
634518	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
634519	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
634520	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
634521	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
634522	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Vegetation	None	
634523	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
634524	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	170686	
634525	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
634526	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
634527	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
634528	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
634529	1/10/2019 14:26	Distribution	Beargrass Quarterly Inspection	PF000017	PowerFuse	BG-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
634530	1/10/2019 14:26	Distribution	Beargrass Quarterly Inspection	PF000017	PowerFuse	BG-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
634531	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Unknown Operations	0	
634532	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Switching Operations	0	
634533	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
634534	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LTCC000182	LTCControl	WH-TRANS 3	LTC Control Insp	All Connections OK?	y	
634535	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LTCC000182	LTCControl	WH-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
634536	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LTCC000182	LTCControl	WH-TRANS 3	LTC Control Insp	General Comments		
634537	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	PF000425	PowerFuse	WH-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
634538	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	PF000425	PowerFuse	WH-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
634539	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
634540	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
634541	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8064	
634542	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
634543	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
634544	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Reg Oil Level	Very Low	
634545	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
634546	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
634547	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Operations Counter AL	861	
634548	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Operations Counter AF	861	
634549	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Maintenance Operations	0	
634550	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	General Comments	1 operation unaccounted for	
634551	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Follow-up Action Required?	y	
634552	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Operations Ground	0	
634553	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Operations C Ø	0	
634554	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Operations B Ø	0	
634555	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Operations A Ø	0	
634556	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
634557	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
634558	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
634559	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
634560	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
634561	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
634562	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
634563	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
634564	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
634565	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
634566	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
634567	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
634568	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Accumulated Fault Duty C Ph AM	3.61	%
634569	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Amps A Ø	400.0	
634570	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Amps B Ø	390.0	
634571	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Amps C Ø	400.0	
634572	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
634573	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	9 Months Operations	12	
634574	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
634575	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
634576	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
634577	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
634578	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
634579	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
634580	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
634581	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
634582	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
634583	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
634584	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
634585	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
634586	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
634587	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	General Comments		
634588	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
634589	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Ambient Temp	27	°F
634590	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
634591	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
634592	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Clear of Trash?	y	
634593	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
634594	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
634595	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
634596	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
634597	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
634598	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
634599	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
634600	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
634601	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
634602	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
634603	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
634604	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
634605	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
634606	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
634607	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
634608	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
634609	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	General Comments		
634610	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
634611	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
634612	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
634613	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
634614	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
634615	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
634616	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
634617	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	General Comments		
634618	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
634619	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
634620	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
634621	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	General Comments		
634622	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
634623	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
634624	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
634625	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
634626	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
634627	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
634628	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
634629	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
634630	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
634631	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
634632	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
634633	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
634634	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
634635	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
634636	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
634637	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
634638	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
634639	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
634640	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
634641	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
634642	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
634643	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
634644	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
634645	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
634646	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
634647	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
634648	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
634649	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
634650	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
634651	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
634652	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
634653	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
634654	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
634655	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
634656	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
634657	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
634658	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
634659	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Operations Counter AL	244	
634660	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
634661	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Switching Operations	0	
634662	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Tank Paint Condition	Good	
634663	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
634664	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	60	°C
634665	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
634666	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
634667	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
634668	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
634669	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
634670	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
634671	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
634672	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Unknown Operations	0	
634673	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
634674	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
634675	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
634676	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
634677	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
634678	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
634679	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
634680	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
634681	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
634682	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	General Comments		
634683	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
634684	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
634685	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
634686	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
634687	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
634688	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
634689	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
634690	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
634691	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
634692	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
634693	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
634694	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
634695	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
634696	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
634697	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
634698	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
634699	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
634700	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
634701	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
634702	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
634703	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
634704	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
634705	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
634706	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
634707	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Regulator As Left Counter	17373	
634708	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
634709	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
634710	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
634711	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	PF000427	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
634712	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	PF000427	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	General Comments	ok	
634713	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
634714	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
634715	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
634716	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
634717	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Totalizer Meter Multiplier	2800	
634718	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Totalizer Meter Reading	.0376	
634719	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
634720	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
634721	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
634722	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
634723	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
634724	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
634725	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
634726	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
634727	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments	ok	
634728	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
634729	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
634730	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Unknown Operations	0	
634731	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Switching Operations	0	
634732	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
634733	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
634734	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
634735	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
634736	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
634737	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
634738	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
634739	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
634740	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
634741	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	PF000267	PowerFuse	OX-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
634742	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	PF000267	PowerFuse	OX-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
634743	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
634744	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
634745	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
634746	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
634747	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
634748	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
634749	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
634750	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
634751	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
634752	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	General Comments		
634753	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
634754	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
634755	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
634756	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
634757	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
634758	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	General Comments		
634759	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Maintenance Operations	0	
634760	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Operations Counter AF	375	
634761	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Operations Counter AL	375	
634762	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Switching Operations	0	
634763	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
634764	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
634765	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
634766	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
634767	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Fans Operational?	n	
634768	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
634769	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Follow-up Action Required?	n	
634770	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Unknown Operations	0	
634771	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	Oil Temp Present	38	°C
634772	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	Oil Temp Max	57	°C
634773	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
634774	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
634775	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	General Comments		
634776	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	General Comments		
634777	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
634778	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	LTC Totalizer Reading	105.28	kw
634779	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
634780	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
634781	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
634782	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
634783	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
634784	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	General Comments		
634785	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Oil Temp Max	45	°C
634786	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Oil Temp Present	20	°C
634787	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
634788	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
634789	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
634790	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
634791	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
634792	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
634793	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
634794	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
634795	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
634796	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
634797	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
634798	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	0	
634799	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
634800	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
634801	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
634802	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
634803	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
634804	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
634805	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
634806	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
634807	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
634808	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Operations A Ø	0	
634809	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Operations B Ø	0	
634810	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
634811	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
634812	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
634813	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
634814	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
634815	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
634816	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
634817	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
634818	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
634819	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
634820	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
634821	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
634822	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
634823	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	99982	
634824	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	99982	
634825	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
634826	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
634827	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Unknown Operations	0	
634828	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Tank Paint Condition	Good	
634829	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Switching Operations	0	
634830	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
634831	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Operations Counter AL	531	
634832	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Operations Counter AF	531	
634833	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
634834	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Maintenance Operations	0	
634835	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
634836	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Grounds in Place?	y	
634837	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	9 Months Operations	6	
634838	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
634839	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
634840	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
634841	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
634842	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
634843	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
634844	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
634845	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
634846	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
634847	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
634848	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
634849	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
634850	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
634851	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
634852	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
634853	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
634854	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
634855	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
634856	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
634857	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
634858	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
634859	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
634860	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
634861	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
634862	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
634863	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
634864	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
634865	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
634866	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
634867	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	40314	
634868	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
634869	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	PF000030	PowerFuse	AB-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
634870	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	PF000030	PowerFuse	AB-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
634871	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	PF000029	PowerFuse	AB-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
634872	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	PF000029	PowerFuse	AB-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
634873	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	PF000028	PowerFuse	AB-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
634874	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	PF000028	PowerFuse	AB-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
634875	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
634876	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Amps C Ø	240.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
634877	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Bushing Condition	Good	
634878	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Bushings Connection/Risers	Good	
634879	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
634880	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
634881	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
634882	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Cabinet Paint Condition	Good	
634883	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Equipment Properly Labeled?	y	
634884	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
634885	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
634886	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
634887	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
634888	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	General Comments		
634889	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
634890	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	General Comments	ok	
634891	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	General Comments	ok	
634892	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Foundation Condition	Good	
634893	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Follow-up Action Required?	n	
634894	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
634895	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
634896	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
634897	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
634898	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
634899	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
634900	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
634901	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Foundation Condition	Good	
634902	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	General Comments		
634903	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	General Comments		
634904	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Grounds in Place?	y	
634905	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Heaters (All) Functioning?	y	
634906	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Maintenance Operations	1	
634907	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
634908	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
634909	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
634910	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
634911	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
634912	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	General Comments	ok	
634913	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
634914	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
634915	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Foundation Condition	Good	
634916	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
634917	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
634918	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
634919	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
634920	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
634921	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
634922	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Follow-up Action Required?	n	
634923	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Operations Ground	0	
634924	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Operations C Ø	0	
634925	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Operations B Ø	0	
634926	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Operations A Ø	0	
634927	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
634928	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Vegetation	None	
634929	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
634930	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	General Comments	pl	
634931	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
634932	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
634933	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
634934	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
634935	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
634936	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
634937	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
634938	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
634939	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
634940	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
634941	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
634942	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Accumulated Fault Duty A Ph AM	3.64	%
634943	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Accumulated Fault Duty B Ph AM	8.49	%
634944	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	General Comments		
634945	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	General Comments		
634946	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Foundation Condition	Good	
634947	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Follow-up Action Required?	n	
634948	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
634949	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Follow-up Action Required?	n	
634950	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Unknown Operations	0	
634951	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
634952	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Switching Operations	0	
634953	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Accumulated Fault Duty C Ph AM	8.49	%
634954	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Amps A Ø	280.0	
634955	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Operations C Ø	0	
634956	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Operations Ground	0	
634957	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Follow-up Action Required?	n	
634958	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Follow-up Action Required?	n	
634959	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Amps B Ø	300.0	
634960	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Amps C Ø	400.0	
634961	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
634962	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
634963	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
634964	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
634965	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Operations A Ø	0	
634966	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Operations B Ø	0	
634967	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Operations C Ø	0	
634968	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Operations Ground	0	
634969	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Patrol Inspection	Follow-up Action Required?	n	
634970	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Follow-up Action Required?	n	
634971	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Patrol Inspection	General Comments		
634972	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	General Comments	ok	
634973	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Maintenance Operations	0	
634974	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Operations Counter AF	116	
634975	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Operations Counter AL	116	
634976	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Switching Operations	2	
634977	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Unknown Operations	0	
634978	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
634979	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Operations Counter AL	180	
634980	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Operations Counter AF	180	
634981	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Moisture and Leak Free?	y	
634982	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Maintenance Operations	1	
634983	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Heaters (All) Functioning?	y	
634984	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Grounds in Place?	y	
634985	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Accumulated Fault Duty C Ph V	1.10	%
634986	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Accumulated Fault Duty B Ph V	1.10	%
634987	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Accumulated Fault Duty A Ph V	2.19	%
634988	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	9 Month Operations	4	
634989	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Unknown Operations	0	
634990	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Tank Paint Condition	Good	
634991	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Switching Operations	0	
634992	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
634993	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Operations Counter AL	229	
634994	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Operations Counter AF	229	
634995	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Moisture and Leak Free?	y	
634996	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Maintenance Operations	0	
634997	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Heaters (All) Functioning?	y	
634998	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Grounds in Place?	y	
634999	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	General Comments		
635000	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	General Comments		
635001	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Foundation Condition	Good	
635002	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Follow-up Action Required?	n	
635003	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Follow-up Action Required?	n	
635004	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Operations Ground	0	
635005	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
635006	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
635007	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
635008	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
635009	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
635010	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
635011	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
635012	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
635013	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
635014	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
635015	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
635016	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
635017	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
635018	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
635019	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
635020	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
635021	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
635022	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
635023	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
635024	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
635025	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
635026	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
635027	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	4	
635028	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Operations C Ø	0	
635029	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Operations B Ø	0	
635030	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Operations A Ø	0	
635031	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
635032	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Amps C Ø	80.0	
635033	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Amps B Ø	80.0	
635034	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Amps A Ø	120.0	
635035	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Accumulated Fault Duty C Ph V	1.32	%
635036	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Accumulated Fault Duty B Ph V	1.32	%
635037	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Unknown Operations	0	
635038	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Tank Paint Condition	Good	
635039	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Switching Operations	0	
635040	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
635041	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
635042	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
635043	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
635044	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	525	
635045	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	525	
635046	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
635047	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
635048	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
635049	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
635050	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
635051	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
635052	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
635053	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Operations Counter AL	210	
635054	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Operations Counter AF	210	
635055	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Moisture and Leak Free?	y	
635056	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Maintenance Operations	0	
635057	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Grounds in Place?	y	
635058	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	General Comments		
635059	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	General Comments		
635060	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Foundation Condition	Good	
635061	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Follow-up Action Required?	n	
635062	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Follow-up Action Required?	n	
635063	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Operations Ground	0	
635064	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Operations C Ø	0	
635065	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Operations B Ø	0	
635066	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Operations A Ø	0	
635067	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
635068	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
635069	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
635070	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Equipment Properly Labeled?	y	
635071	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Cabinet Paint Condition	Good	
635072	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
635073	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
635074	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
635075	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Bushings Connection/Risers	Good	
635076	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Bushing Condition	Good	
635077	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Amps C Ø	0.0	
635078	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Amps B Ø	0.0	
635079	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Amps A Ø	0.0	
635080	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
635081	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
635082	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
635083	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
635084	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
635085	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
635086	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
635087	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
635088	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
635089	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
635090	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
635091	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
635092	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
635093	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	General Comments	ok	
635094	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments	ok	
635095	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	1002	
635096	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Operations Ground	0	
635097	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	1012	
635098	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
635099	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	3L	
635100	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	2L	
635101	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	8L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
635102	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
635103	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	157	
635104	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
635105	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
635106	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
635107	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
635108	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
635109	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Patrol Inspection	General Comments		
635110	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	General Comments		
635111	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Maintenance Operations	0	
635112	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Operations Counter AF	205	
635113	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Operations Counter AL	205	
635114	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Switching Operations	0	
635115	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Unknown Operations	0	
635116	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
635117	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
635118	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
635119	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	PF000269	PowerFuse	OX-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
635120	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
635121	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
635122	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	PF000269	PowerFuse	OX-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
635123	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
635124	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
635125	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
635126	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	4L	
635127	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	10L	
635128	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
635129	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
635130	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Equipment Properly Labeled?	y	
635131	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Cabinet Paint Condition	Good	
635132	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
635133	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
635134	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
635135	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Bushings Connection/Risers	Good	
635136	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Bushing Condition	Good	
635137	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Amps C Ø	100.0	
635138	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Amps B Ø	90.0	
635139	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Amps A Ø	100.0	
635140	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
635141	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
635142	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
635143	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	9 Month Operations	4	
635144	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
635145	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
635146	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
635147	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
635148	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
635149	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
635150	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
635151	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
635152	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	General Comments		
635153	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
635154	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
635155	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Vegetation	None	
635156	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
635157	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
635158	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
635159	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
635160	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
635161	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
635162	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
635163	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
635164	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
635165	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
635166	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	5L	
635167	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
635168	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	9 Month Operations	3	
635169	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
635170	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	3.47	%
635171	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
635172	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Amps A Ø	500.0	
635173	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Amps B Ø	500.0	
635174	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Amps C Ø	500.0	
635175	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
635176	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Operations Counter	431	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
635177	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
635178	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	General Comments		
635179	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
635180	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
635181	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Accumulated Fault Duty A Ph AM	15.95	%
635182	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	9 Months Operations	15	
635183	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	VRR Time Delay	60	Seconds
635184	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
635185	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
635186	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
635187	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Switching Operations	0	
635188	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Tank Paint Condition	Good	
635189	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Unknown Operations	0	
635190	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
635191	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
635192	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
635193	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	LTC Operation Checked?	n	
635194	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	General Comments		
635195	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	Follow-up Action Required?	n	
635196	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	All Connections OK?	y	
635197	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
635198	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
635199	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
635200	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Amps A Ø	100.0	
635201	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Amps B Ø	100.0	
635202	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Amps C Ø	100.0	
635203	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Patrol Inspection	Equipment Properly Labeled?	y	
635204	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
635205	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
635206	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
635207	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Operations A Ø	1	
635208	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Operations B Ø	1	
635209	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Operations C Ø	0	
635210	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Operations Ground	0	
635211	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Patrol Inspection	Follow-up Action Required?	n	
635212	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Follow-up Action Required?	n	
635213	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Patrol Inspection	General Comments		
635214	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	General Comments	A&B phase IOC	
635215	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
635216	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
635217	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
635218	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Amps C Ø	27.0	
635219	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Amps B Ø	34.0	
635220	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Amps A Ø	36.0	
635221	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
635222	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
635223	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
635224	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
635225	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
635226	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
635227	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
635228	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Amps C Ø	40.0	
635229	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Amps B Ø	100.0	
635230	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	9 Month Operations	2	
635231	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Accumulated Fault Duty A Ph V	1.47	%
635232	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Accumulated Fault Duty B Ph V	1.47	%
635233	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Accumulated Fault Duty C Ph V	1.47	%
635234	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Amps A Ø	168.0	
635235	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Amps B Ø	156.0	
635236	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Amps C Ø	146.0	
635237	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Bushing Condition	Good	
635238	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Bushings Connection/Risers	Good	
635239	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
635240	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
635241	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
635242	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Cabinet Paint Condition	Good	
635243	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Equipment Properly Labeled?	y	
635244	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
635245	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
635246	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
635247	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Operations A Ø	0	
635248	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Operations B Ø	0	
635249	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Operations C Ø	0	
635250	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Operations Ground	0	
635251	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
635252	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Follow-up Action Required?	n	
635253	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Foundation Condition	Good	
635254	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	General Comments		
635255	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	9 Month Operations	15	
635256	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Amps A Ø	400.0	
635257	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Accumulated Fault Duty C Ph AM	5.32	%
635258	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	General Comments		
635259	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Grounds in Place?	y	
635260	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
635261	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Heaters (All) Functioning?	y	
635262	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Maintenance Operations	2	
635263	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Moisture and Leak Free?	y	
635264	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Operations Counter AF	171	
635265	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Operations Counter AL	171	
635266	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Accumulated Fault Duty B Ph AM	13.29	%
635267	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Accumulated Fault Duty A Ph V	15.78	%
635268	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Accumulated Fault Duty B Ph V	15.07	%
635269	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Accumulated Fault Duty C Ph V	10.76	%
635270	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
635271	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Clear of Trash?	y	
635272	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
635273	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
635274	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1547.52	kw
635275	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	116.00	
635276	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
635277	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Oil Temp Max	80	°C
635278	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Oil Temp Present	55	°C
635279	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
635280	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
635281	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
635282	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
635283	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
635284	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
635285	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
635286	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
635287	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
635288	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
635289	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
635290	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
635291	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
635292	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
635293	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
635294	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
635295	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Tank Leaks	None	
635296	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
635297	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
635298	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Regulator As Left Counter	185282	
635299	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
635300	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
635301	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
635302	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
635303	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
635304	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
635305	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
635306	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
635307	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	General Comments		
635308	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
635309	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
635310	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
635311	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
635312	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
635313	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
635314	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
635315	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
635316	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
635317	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
635318	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
635319	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
635320	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
635321	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
635322	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
635323	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
635324	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
635325	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
635326	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
635327	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
635328	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
635329	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
635330	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
635331	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
635332	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.1	VDC
635333	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.9	VDC
635334	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
635335	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
635336	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
635337	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
635338	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
635339	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
635340	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
635341	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
635342	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	29	°F
635343	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Maintenance Operations	0	
635344	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Operations Counter AF	49	
635345	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Operations Counter AL	49	
635346	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
635347	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Switching Operations	0	
635348	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Unknown Operations	0	
635349	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
635350	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Vegetation	None	
635351	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Exp Boom Corrected	
635352	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	General Comments		
635353	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
635354	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
635355	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	General Comments		
635356	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	General Comments		
635357	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
635358	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
635359	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
635360	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4836	
635361	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
635362	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
635363	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
635364	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
635365	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
635366	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Operations Counter AL	952	
635367	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Operations Counter AF	952	
635368	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Maintenance Operations	0	
635369	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	General Comments		
635370	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Patrol Inspection	General Comments		
635371	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Follow-up Action Required?	n	
635372	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Patrol Inspection	Follow-up Action Required?	n	
635373	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Unknown Operations	0	
635374	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Operations Ground	0	
635375	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Operations C Ø	0	
635376	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Operations B Ø	0	
635377	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Operations A Ø	0	
635378	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Clear of Trash?	y	
635379	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
635380	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
635381	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
635382	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	9 Month Operations	0	
635383	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Accumulated Fault Duty A Ph V	1.32	%
635384	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
635385	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
635386	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
635387	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
635388	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
635389	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
635390	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
635391	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
635392	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
635393	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
635394	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
635395	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
635396	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
635397	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
635398	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
635399	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
635400	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
635401	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
635402	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
635403	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
635404	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
635405	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
635406	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
635407	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	General Comments		
635408	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
635409	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
635410	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
635411	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
635412	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
635413	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
635414	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
635415	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
635416	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Equipment Properly Labeled?	y	
635417	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Cabinet Paint Condition	Good	
635418	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
635419	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
635420	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
635421	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Bushings Connection/Risers	Good	
635422	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Bushing Condition	Good	
635423	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Amps C Ø	21.0	
635424	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Amps B Ø	9.0	
635425	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Amps A Ø	8.0	
635426	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Accumulated Fault Duty C Ph V	.60	%
635427	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
635428	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
635429	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	General Comments		
635430	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
635431	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
635432	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
635433	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
635434	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
635435	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
635436	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
635437	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
635438	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
635439	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Accumulated Fault Duty B Ph V	.45	%
635440	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Accumulated Fault Duty A Ph V	.60	%
635441	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	9 Month Operations	5	
635442	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Operations Ground	0	
635443	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Operations C Ø	0	
635444	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Operations B Ø	0	
635445	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Moisture and Leak Free?	y	
635446	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Operations Counter AF	132	
635447	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Operations Counter AL	132	
635448	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
635449	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Switching Operations	0	
635450	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Tank Paint Condition	Good	
635451	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Operations A Ø	0	
635452	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
635453	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
635454	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
635455	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
635456	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
635457	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
635458	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
635459	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Unknown Operations	0	
635460	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Switching Operations	1	
635461	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Operations B Ø	0	
635462	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Operations A Ø	0	
635463	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
635464	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
635465	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
635466	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
635467	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Amps C Ø	0.0	
635468	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Amps B Ø	0.0	
635469	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Amps A Ø	0.0	
635470	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Bushing Condition	Good	
635471	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Amps C Ø	500.0	
635472	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Amps B Ø	500.0	
635473	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Amps A Ø	450.0	
635474	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Accumulated Fault Duty C Ph AM	1.33	%
635475	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
635476	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
635477	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	9 Months Operations	5	
635478	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
635479	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
635480	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
635481	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	9 Month Operations	0	
635482	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
635483	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
635484	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
635485	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
635486	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
635487	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
635488	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
635489	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
635490	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
635491	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
635492	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
635493	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
635494	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
635495	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
635496	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
635497	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
635498	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
635499	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
635500	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
635501	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
635502	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
635503	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
635504	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
635505	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
635506	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
635507	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
635508	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
635509	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
635510	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
635511	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
635512	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
635513	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
635514	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
635515	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
635516	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Unknown Operations	0	
635517	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Switching Operations	4	
635518	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Operations Counter AL	30	
635519	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Operations Counter AF	30	
635520	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Maintenance Operations	0	
635521	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
635522	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	General Comments		
635523	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
635524	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
635525	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
635526	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
635527	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
635528	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
635529	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
635530	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
635531	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
635532	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
635533	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
635534	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
635535	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
635536	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
635537	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	General Comments	ok	
635538	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
635539	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
635540	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
635541	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
635542	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
635543	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
635544	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
635545	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
635546	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
635547	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
635548	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
635549	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
635550	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
635551	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
635552	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Patrol Inspection	General Comments		
635553	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Follow-up Action Required?	n	
635554	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Patrol Inspection	Follow-up Action Required?	n	
635555	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Operations Ground	0	
635556	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Operations C Ø	0	
635557	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
635558	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Broom on Site?	y	
635559	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
635560	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
635561	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
635562	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
635563	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Evidence of Insects	None	
635564	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
635565	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
635566	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Floor Swept?	y	
635567	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
635568	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Follow-up Action Required?	n	
635569	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
635570	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
635571	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
635572	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
635573	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
635574	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Amps A Ø	66.0	
635575	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Amps B Ø	61.0	
635576	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
635577	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
635578	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
635579	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
635580	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
635581	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
635582	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
635583	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
635584	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
635585	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
635586	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
635587	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
635588	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
635589	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
635590	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
635591	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
635592	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
635593	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
635594	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
635595	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
635596	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
635597	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	General Comments		
635598	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
635599	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
635600	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
635601	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
635602	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
635603	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
635604	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
635605	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
635606	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
635607	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
635608	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
635609	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
635610	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	Oil Temp Present	25	°C
635611	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
635612	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
635613	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
635614	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
635615	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
635616	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	General Comments		
635617	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
635618	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
635619	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
635620	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
635621	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
635622	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
635623	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
635624	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
635625	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
635626	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
635627	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
635628	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
635629	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
635630	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
635631	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
635632	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
635633	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
635634	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
635635	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
635636	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
635637	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
635638	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
635639	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
635640	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
635641	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
635642	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
635643	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	General Comments		
635644	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
635645	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
635646	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
635647	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
635648	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
635649	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
635650	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
635651	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
635652	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
635653	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Unknown Operations	0	
635654	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Switching Operations	0	
635655	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Operations Counter AL	402	
635656	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Operations Counter AF	402	
635657	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
635658	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
635659	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
635660	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
635661	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
635662	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
635663	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
635664	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
635665	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Maintenance Operations	0	
635666	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
635667	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	General Comments		
635668	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
635669	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BCH001097	Charger	437-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	56.0	VDC
635670	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BCH001097	Charger	437-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	56.0	VDC
635671	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BCH001097	Charger	437-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
635672	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BCH001097	Charger	437-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
635673	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Tank Leaks	None	
635674	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
635675	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
635676	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
635677	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
635678	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
635679	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.4	VDC
635680	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.4	VDC
635681	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
635682	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Patrol Inspection	General Comments		
635683	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Follow-up Action Required?	n	
635684	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
635685	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations Ground	0	
635686	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations C Ø	0	
635687	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations B Ø	0	
635688	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations A Ø	0	
635689	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
635690	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
635691	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Heaters (All) Functioning?	y	
635692	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Grounds in Place?	y	
635693	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	General Comments	ok	
635694	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	General Comments	ok	
635695	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Foundation Condition	Good	
635696	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
635697	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
635698	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Amps C Ø	80.0	
635699	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
635700	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	General Comments		
635701	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
635702	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC As Found Counter	485500	
635703	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC As Left Counter	485500	
635704	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
635705	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
635706	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
635707	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
635708	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
635709	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
635710	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Panels Dusted?	y	
635711	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
635712	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
635713	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
635714	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
635715	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
635716	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Current Tap Position	10R	
635717	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
635718	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
635719	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
635720	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	General Comments		
635721	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
635722	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
635723	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
635724	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
635725	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
635726	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
635727	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Amps C Ø	58.0	
635728	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
635729	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
635730	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
635731	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
635732	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
635733	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
635734	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
635735	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
635736	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
635737	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	General Comments		
635738	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
635739	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
635740	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Operations Counter	3	
635741	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
635742	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Tank Leaks	None	
635743	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
635744	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
635745	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	28	°F
635746	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
635747	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Amps C Ø	140.0	
635748	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
635749	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
635750	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	General Comments		
635751	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
635752	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
635753	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
635754	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
635755	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
635756	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
635757	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
635758	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
635759	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
635760	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	General Comments		
635761	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
635762	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
635763	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
635764	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
635765	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
635766	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
635767	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
635768	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
635769	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
635770	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
635771	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Operations A Ø	0	
635772	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
635773	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
635774	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
635775	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	General Comments		
635776	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
635777	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
635778	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
635779	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Tank Leaks	None	
635780	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
635781	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Operations B Ø	0	
635782	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Operations C Ø	0	
635783	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Operations Ground	0	
635784	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
635785	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Follow-up Action Required?	n	
635786	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Patrol Inspection	General Comments		
635787	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	General Comments		
635788	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
635789	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Maintenance Operations	0	
635790	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Operations Counter AF	489	
635791	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Operations Counter AL	489	
635792	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Switching Operations	0	
635793	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Unknown Operations	0	
635794	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
635795	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	X3 Winding Temp Max	65	°C
635796	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	X2 Winding Temp Max	65	°C
635797	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
635798	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
635799	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000054	LTCMechanism	EOC-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
635800	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
635801	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
635802	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
635803	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
635804	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	General Comments		
635805	1/10/2019 13:43	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
635806	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000054	LTCMechanism	EOC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
635807	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000054	LTCMechanism	EOC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
635808	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000054	LTCMechanism	EOC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
635809	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
635810	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
635811	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
635812	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000054	LTCMechanism	EOC-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
635813	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000054	LTCMechanism	EOC-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
635814	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
635815	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
635816	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Winding Temp Max	65	°C
635817	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Totalizer Meter Reading	.4030	
635818	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
635819	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
635820	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
635821	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
635822	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
635823	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	9 Months Operations	0	
635824	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
635825	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
635826	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
635827	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
635828	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Amps A Ø	130.0	
635829	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
635830	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
635831	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
635832	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
635833	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
635834	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
635835	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
635836	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
635837	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
635838	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Current Tap Position	9R	
635839	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
635840	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
635841	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Amps B Ø	150.0	
635842	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
635843	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	General Comments		
635844	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
635845	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
635846	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
635847	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
635848	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	4L	
635849	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
635850	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
635851	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
635852	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
635853	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
635854	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
635855	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	2L	
635856	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	11L	
635857	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
635858	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
635859	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	20	°C
635860	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	42	°C
635861	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	25	°C
635862	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	40	°C
635863	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	25	°C
635864	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	45	°C
635865	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
635866	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
635867	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
635868	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
635869	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
635870	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
635871	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
635872	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
635873	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	100572	
635874	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
635875	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
635876	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
635877	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
635878	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
635879	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
635880	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
635881	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
635882	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
635883	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
635884	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
635885	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
635886	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	33	°F
635887	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
635888	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
635889	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
635890	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
635891	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
635892	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
635893	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
635894	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
635895	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
635896	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
635897	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
635898	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
635899	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
635900	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
635901	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
635902	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
635903	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
635904	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
635905	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
635906	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Oil Temp Max	60	°C
635907	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
635908	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
635909	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
635910	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
635911	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
635912	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
635913	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.1	VDC
635914	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
635915	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LTCC000387	LTCControl	WH-TRANS 2	LTC Control Insp	General Comments		
635916	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LTCC000387	LTCControl	WH-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
635917	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LTCC000387	LTCControl	WH-TRANS 2	LTC Control Insp	All Connections OK?	y	
635918	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
635919	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
635920	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	LTC Totalizer Reading	9672.00	kw
635921	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
635922	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	General Comments		
635923	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.1	VDC
635924	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
635925	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
635926	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
635927	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
635928	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
635929	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	236	
635930	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
635931	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC Min Tap Position	14L	
635932	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
635933	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC Max Tap Position	8L	
635934	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
635935	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
635936	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC As Left Counter	15215	
635937	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC As Found Counter	15215	
635938	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
635939	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
635940	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
635941	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
635942	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
635943	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
635944	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	General Comments		
635945	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
635946	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Vegetation	None	
635947	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
635948	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
635949	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
635950	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
635951	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Mechanism Patrol Inspection	General Comments		
635952	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
635953	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
635954	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
635955	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
635956	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
635957	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
635958	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
635959	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Foundation Condition	Good	
635960	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
635961	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
635962	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	General Comments		
635963	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
635964	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
635965	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
635966	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
635967	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
635968	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
635969	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
635970	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
635971	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
635972	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
635973	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
635974	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
635975	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	15	°C
635976	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	30	°C
635977	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
635978	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	205.00	
635979	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
635980	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
635981	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments	ok	
635982	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	ok	
635983	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
635984	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
635985	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Clear of Trash?	y	
635986	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
635987	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
635988	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
635989	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
635990	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
635991	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LTCC000215	LTCControl	OX-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
635992	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LTCC000215	LTCControl	OX-TRANS 2	LTC Control Insp	General Comments		
635993	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LTCC000215	LTCControl	OX-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
635994	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LTCC000215	LTCControl	OX-TRANS 2	LTC Control Insp	All Connections OK?	y	
635995	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	9 Month Operations	1	
635996	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
635997	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
635998	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
635999	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Amps A Ø	60.0	
636000	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Amps B Ø	180.0	
636001	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
636002	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
636003	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
636004	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
636005	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
636006	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
636007	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
636008	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
636009	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
636010	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
636011	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
636012	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
636013	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
636014	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
636015	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
636016	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
636017	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
636018	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1159	
636019	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
636020	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
636021	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
636022	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
636023	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
636024	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
636025	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	General Comments		
636026	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
636027	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
636028	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
636029	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	General Comments		
636030	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
636031	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
636032	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
636033	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
636034	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	5R	
636035	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
636036	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Ambient Temp	28	°F
636037	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Trash Emptied?	y	
636038	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
636039	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
636040	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
636041	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
636042	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
636043	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
636044	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
636045	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
636046	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
636047	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	4L	
636048	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
636049	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
636050	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
636051	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Operations Ground	0	
636052	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Operations C Ø	0	
636053	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Operations B Ø	0	
636054	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Operations A Ø	0	
636055	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
636056	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
636057	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
636058	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Equipment Properly Labeled?	y	
636059	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Cabinet Paint Condition	Good	
636060	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
636061	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
636062	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
636063	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Bushings Connection/Risers	Good	
636064	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
636065	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
636066	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	272989	
636067	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
636068	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
636069	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
636070	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
636071	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
636072	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Clear of Trash?	y	
636073	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
636074	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
636075	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
636076	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
636077	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
636078	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
636079	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Bushing Condition	Good	
636080	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
636081	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
636082	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
636083	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
636084	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
636085	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
636086	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
636087	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
636088	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
636089	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Broom on Site?	y	
636090	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
636091	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
636092	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
636093	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
636094	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Evidence of Insects	None	
636095	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
636096	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
636097	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
636098	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
636099	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
636100	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	4R	
636101	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Vegetation	None	
636102	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
636103	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
636104	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
636105	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
636106	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
636107	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	General Comments		
636108	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
636109	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
636110	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
636111	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Clear of Trash?	y	
636112	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
636113	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Floor Swept?	y	
636114	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
636115	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
636116	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	General Comments		
636117	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
636118	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
636119	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Panels Dusted?	y	
636120	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
636121	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
636122	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
636123	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
636124	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
636125	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
636126	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
636127	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
636128	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
636129	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
636130	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
636131	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
636132	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1R	
636133	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
636134	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
636135	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
636136	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
636137	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
636138	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
636139	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Tank Leaks	None	
636140	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
636141	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Regulator As Left Counter	113303	
636142	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
636143	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
636144	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
636145	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Amps A Ø	32.0	
636146	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Amps B Ø	29.0	
636147	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Amps C Ø	36.0	
636148	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
636149	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
636150	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
636151	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
636152	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
636153	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
636154	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
636155	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
636156	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
636157	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
636158	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	General Comments	ok	
636159	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
636160	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
636161	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Operations Counter	107	
636162	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
636163	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Tank Leaks	None	
636164	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
636165	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
636166	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
636167	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
636168	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
636169	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	General Comments	ok	
636170	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
636171	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
636172	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
636173	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
636174	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
636175	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Amps B Ø	50.0	
636176	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Amps A Ø	60.0	
636177	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
636178	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
636179	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
636180	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	9 Months Operations	2	
636181	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
636182	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
636183	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
636184	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
636185	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
636186	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
636187	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
636188	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
636189	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
636190	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
636191	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
636192	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
636193	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
636194	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
636195	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Ambient Temp	25	°F
636196	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
636197	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
636198	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Clear of Trash?	y	
636199	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
636200	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
636201	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
636202	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
636203	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
636204	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
636205	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	General Comments		
636206	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Exp Boom Corrected	
636207	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Vegetation	None	
636208	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
636209	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
636210	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
636211	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
636212	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	255463	
636213	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
636214	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
636215	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
636216	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
636217	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	16L	
636218	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	16R	
636219	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
636220	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	drag hands dont work	
636221	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
636222	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
636223	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
636224	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
636225	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
636226	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
636227	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
636228	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
636229	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
636230	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
636231	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
636232	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
636233	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
636234	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
636235	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
636236	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
636237	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
636238	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
636239	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
636240	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
636241	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
636242	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
636243	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
636244	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
636245	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
636246	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
636247	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
636248	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
636249	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
636250	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	General Comments		
636251	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	General Comments	needs nitro	
636252	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
636253	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
636254	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
636255	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	Oil Temp Max	60	°C
636256	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	Oil Temp Present	10	°C
636257	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
636258	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
636259	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
636260	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
636261	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
636262	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
636263	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
636264	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
636265	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
636266	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
636267	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
636268	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
636269	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
636270	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
636271	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
636272	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
636273	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
636274	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
636275	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
636276	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Unknown Operations	0	
636277	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Switching Operations	0	
636278	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Operations Counter AL	626	
636279	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Operations Counter AF	626	
636280	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Maintenance Operations	0	
636281	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	General Comments	A phase IOC vc did not change from last insp needs to be checked	
636282	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Patrol Inspection	General Comments		
636283	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Follow-up Action Required?	y	
636284	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Patrol Inspection	Follow-up Action Required?	n	
636285	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Operations Ground	0	
636286	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Operations C Ø	0	
636287	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Operations B Ø	0	
636288	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Operations A Ø	1	
636289	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
636290	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
636291	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
636292	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Patrol Inspection	Equipment Properly Labeled?	y	
636293	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Amps C Ø	100.0	
636294	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Amps B Ø	100.0	
636295	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Amps A Ø	100.0	
636296	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Accumulated Fault Duty C Ph V	17.22	%
636297	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Accumulated Fault Duty B Ph V	30.85	%
636298	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Accumulated Fault Duty A Ph V	22.96	%
636299	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	9 Month Operations	6	
636300	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
636301	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Trash Emptied?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
636302	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Follow-up Action Required?	n	
636303	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Follow-up Action Required?	n	
636304	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
636305	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
636306	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
636307	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
636308	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
636309	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
636310	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
636311	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
636312	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
636313	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
636314	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
636315	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
636316	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
636317	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
636318	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
636319	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Switching Operations	0	
636320	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Operations Counter AL	99996	
636321	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
636322	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
636323	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Patrol Inspection	Equipment Properly Labeled?	y	
636324	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
636325	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Patrol Inspection	General Comments		
636326	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	General Comments		
636327	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Maintenance Operations	0	
636328	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Operations Counter AF	111	
636329	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Operations Counter AL	111	
636330	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
636331	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Accumulated Fault Duty C Ph V	3.36	%
636332	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Accumulated Fault Duty B Ph V	3.41	%
636333	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Accumulated Fault Duty A Ph V	3.36	%
636334	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Switching Operations	0	
636335	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Unknown Operations	0	
636336	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
636337	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
636338	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
636339	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	93	
636340	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
636341	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
636342	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC Max Tap Position	7L	
636343	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11L	
636344	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
636345	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC As Left Counter	92836	
636346	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC As Found Counter	92836	
636347	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	needs desicant filter on top of LTC	
636348	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	General Comments		
636349	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
636350	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
636351	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Clear of Trash?	y	
636352	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
636353	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
636354	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
636355	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
636356	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
636357	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
636358	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
636359	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
636360	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
636361	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
636362	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
636363	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
636364	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
636365	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Amps C Ø	540.0	
636366	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Amps B Ø	450.0	
636367	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Amps A Ø	500.0	
636368	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Accumulated Fault Duty C Ph V	33.97	%
636369	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Accumulated Fault Duty B Ph V	55.01	%
636370	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Operations Counter AF	99996	
636371	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Accumulated Fault Duty A Ph V	42.87	%
636372	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	9 Month Operations	43	
636373	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
636374	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
636375	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
636376	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
636377	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
636378	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
636379	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	9 Month Operations	8	
636380	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
636381	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Maintenance Operations	0	
636382	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	General Comments	R&C	
636383	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Patrol Inspection	General Comments		
636384	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	General Comments	R&C	
636385	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
636386	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Operations B Ø	1	
636387	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Operations A Ø	1	
636388	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
636389	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
636390	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
636391	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
636392	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Amps A Ø	0.0	
636393	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Amps B Ø	0.0	
636394	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
636395	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	LTC Operation Checked?	y	
636396	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	General Comments		
636397	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	Follow-up Action Required?	n	
636398	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	All Connections OK?	y	
636399	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Amps C Ø	0.0	
636400	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Patrol Inspection	Equipment Properly Labeled?	y	
636401	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
636402	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
636403	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
636404	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Operations A Ø	0	
636405	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Operations B Ø	0	
636406	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Operations C Ø	0	
636407	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Operations Ground	0	
636408	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
636409	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Patrol Inspection	Follow-up Action Required?	n	
636410	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Follow-up Action Required?	n	
636411	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0284	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
636412	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0284	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
636413	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0284	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
636414	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
636415	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
636416	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
636417	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
636418	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
636419	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
636420	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Foundation Condition	Good	
636421	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
636422	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
636423	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
636424	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
636425	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	9 Months Operations	0	
636426	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
636427	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
636428	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
636429	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Amps A Ø	400.0	
636430	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Amps B Ø	400.0	
636431	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Amps C Ø	400.0	
636432	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
636433	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
636434	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
636435	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
636436	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
636437	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
636438	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
636439	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
636440	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
636441	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
636442	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
636443	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
636444	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
636445	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	General Comments	ok	
636446	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
636447	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
636448	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
636449	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
636450	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
636451	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
636452	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
636453	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	40.0	
636454	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
636455	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
636456	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	General Comments		
636457	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
636458	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
636459	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
636460	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
636461	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
636462	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
636463	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
636464	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Ambient Temp	29	°F
636465	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
636466	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Clear of Trash?	y	
636467	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
636468	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
636469	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
636470	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
636471	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
636472	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
636473	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
636474	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0284	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
636475	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0284	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
636476	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
636477	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
636478	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Vegetation	None	
636479	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
636480	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
636481	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
636482	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
636483	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
636484	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
636485	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
636486	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
636487	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	General Comments		
636488	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
636489	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
636490	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
636491	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	1398.24	kw
636492	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
636493	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
636494	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Max	55	°C
636495	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Present	25	°C
636496	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
636497	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
636498	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
636499	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
636500	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	10	°C
636501	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	10	°C
636502	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
636503	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
636504	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
636505	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
636506	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
636507	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
636508	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
636509	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
636510	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
636511	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
636512	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
636513	1/10/2019 12:33	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	1.1652	
636514	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
636515	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
636516	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
636517	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
636518	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
636519	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
636520	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Maintenance Operations	0	
636521	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
636522	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Operations Counter AF	1167	
636523	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Operations Counter AL	1167	
636524	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Switching Operations	0	
636525	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Unknown Operations	0	
636526	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
636527	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	General Comments	Section of barbed wire Broken	
636528	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
636529	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
636530	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
636531	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
636532	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
636533	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
636534	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
636535	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
636536	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
636537	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
636538	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
636539	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
636540	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
636541	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
636542	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
636543	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Vegetation	None	
636544	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
636545	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
636546	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
636547	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
636548	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
636549	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
636550	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
636551	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
636552	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
636553	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
636554	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
636555	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
636556	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
636557	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
636558	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
636559	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
636560	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
636561	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
636562	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	9 Months Operations	0	
636563	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
636564	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
636565	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
636566	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Amps A Ø	0.0	
636567	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Amps B Ø	0.0	
636568	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
636569	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
636570	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
636571	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
636572	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
636573	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC Operations Since Last Insp	359	
636574	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC Min Tap Position	10L	
636575	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC Max Tap Position	3R	
636576	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC Current Tap Position	4L	
636577	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC As Left Counter	15702	
636578	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC As Found Counter	15702	
636579	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	General Comments		
636580	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	Follow-up Action Required?	n	
636581	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
636582	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
636583	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
636584	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Amps C Ø	0.0	
636585	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
636586	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	60.0	
636587	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
636588	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
636589	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
636590	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
636591	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	PF000426	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	General Comments	ok	
636592	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	PF000426	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
636593	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
636594	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
636595	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
636596	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
636597	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
636598	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Accumulated Fault Duty C Ph V	3.31	%
636599	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Amps A Ø	110.0	
636600	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Amps B Ø	170.0	
636601	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Amps C Ø	130.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
636602	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Bushing Condition	Good	
636603	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Bushings Connection/Risers	Good	
636604	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
636605	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
636606	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
636607	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Cabinet Paint Condition	Good	
636608	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
636609	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Equipment Properly Labeled?	y	
636610	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Amps C Ø	0.0	
636611	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Amps B Ø	0.0	
636612	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Amps A Ø	0.0	
636613	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
636614	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
636615	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
636616	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
636617	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Operations A Ø	0	
636618	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Operations B Ø	0	
636619	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Operations C Ø	0	
636620	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Operations Ground	0	
636621	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Follow-up Action Required?	n	
636622	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
636623	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
636624	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
636625	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
636626	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.5544	
636627	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.000	millivolts
636628	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.3	VDC
636629	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
636630	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
636631	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
636632	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
636633	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
636634	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
636635	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
636636	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
636637	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
636638	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.3	VDC
636639	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	General Comments		
636640	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
636641	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Follow-up Action Required?	n	
636642	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Foundation Condition	Good	
636643	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	General Comments	ok	
636644	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	General Comments	ok	
636645	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Grounds in Place?	y	
636646	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Heaters (All) Functioning?	y	
636647	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Maintenance Operations	0	
636648	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Unknown Operations	0	
636649	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Switching Operations	0	
636650	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Operations Counter AL	218	
636651	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Operations Counter AF	218	
636652	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Maintenance Operations	0	
636653	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	General Comments	ok	
636654	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
636655	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
636656	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
636657	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
636658	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
636659	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
636660	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
636661	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
636662	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
636663	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	115.00	
636664	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
636665	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
636666	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
636667	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
636668	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
636669	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
636670	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	General Comments	no 911 signage	
636671	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
636672	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
636673	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
636674	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Operations Counter AL	336	
636675	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Operations Counter AF	336	
636676	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
636677	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
636678	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	General Comments		
636679	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
636680	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
636681	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
636682	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
636683	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
636684	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
636685	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
636686	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
636687	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
636688	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
636689	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
636690	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
636691	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
636692	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
636693	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
636694	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
636695	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
636696	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
636697	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
636698	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
636699	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
636700	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
636701	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
636702	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
636703	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
636704	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
636705	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
636706	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
636707	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
636708	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
636709	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
636710	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
636711	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
636712	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
636713	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
636714	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
636715	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
636716	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
636717	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
636718	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
636719	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
636720	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
636721	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
636722	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
636723	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Moisture and Leak Free?	y	
636724	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Operations Counter AF	150	
636725	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Operations Counter AL	150	
636726	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
636727	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Switching Operations	0	
636728	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Tank Paint Condition	Good	
636729	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Unknown Operations	0	
636730	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Follow-up Action Required?	n	
636731	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
636732	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
636733	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations Ground	0	
636734	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
636735	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
636736	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
636737	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
636738	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
636739	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
636740	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations C Ø	0	
636741	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations B Ø	0	
636742	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations A Ø	0	
636743	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
636744	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
636745	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
636746	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
636747	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	General Comments		
636748	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
636749	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
636750	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
636751	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
636752	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
636753	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
636754	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
636755	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
636756	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
636757	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
636758	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
636759	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
636760	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
636761	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
636762	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	General Comments		
636763	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
636764	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
636765	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
636766	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
636767	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
636768	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
636769	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
636770	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
636771	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
636772	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
636773	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
636774	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
636775	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
636776	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
636777	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
636778	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	VRR Time Delay	30	Seconds
636779	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
636780	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
636781	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
636782	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	PF000031	PowerFuse	AB-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
636783	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	PF000031	PowerFuse	AB-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
636784	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
636785	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	9 Month Operations	0	
636786	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
636787	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
636788	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
636789	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
636790	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	3.0	amps
636791	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
636792	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
636793	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
636794	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
636795	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Tank Leaks	None	
636796	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
636797	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Regulator As Left Counter	60037	
636798	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
636799	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
636800	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
636801	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
636802	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
636803	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
636804	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	General Comments		
636805	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
636806	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
636807	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
636808	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
636809	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	General Comments		
636810	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
636811	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Ambient Temp	24	°F
636812	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
636813	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
636814	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
636815	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
636816	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
636817	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
636818	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
636819	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
636820	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Clear of Trash?	y	
636821	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
636822	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
636823	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.200	millivolts
636824	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
636825	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
636826	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
636827	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
636828	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
636829	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
636830	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
636831	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
636832	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
636833	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
636834	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
636835	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Tank Leaks	None	
636836	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
636837	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
636838	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
636839	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
636840	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
636841	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
636842	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Regulator As Left Counter	109676	
636843	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
636844	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
636845	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
636846	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
636847	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
636848	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
636849	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Max Tap Position	5L	
636850	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
636851	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	General Comments		
636852	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
636853	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
636854	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	40.0	
636855	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	20	°C
636856	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
636857	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
636858	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
636859	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
636860	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
636861	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
636862	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
636863	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
636864	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
636865	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
636866	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
636867	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
636868	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.6768	
636869	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	200	
636870	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
636871	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
636872	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
636873	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
636874	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
636875	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	549	
636876	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Amps B Ø	300.0	
636877	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Amps A Ø	280.0	
636878	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
636879	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
636880	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
636881	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Accumulated Fault Duty C Ph AM	10.92	%
636882	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Accumulated Fault Duty B Ph AM	13.35	%
636883	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Accumulated Fault Duty A Ph AM	13.35	%
636884	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	9 Months Operations	7	
636885	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
636886	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
636887	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
636888	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
636889	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	9 Months Operations	0	
636890	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	General Comments		
636891	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
636892	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
636893	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
636894	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
636895	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
636896	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
636897	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC As Left Counter	183062	
636898	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC As Found Counter	183062	
636899	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
636900	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
636901	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
636902	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
636903	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
636904	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
636905	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
636906	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
636907	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
636908	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
636909	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
636910	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	needs desicant filter on top of LTC	
636911	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	General Comments		
636912	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
636913	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
636914	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
636915	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
636916	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
636917	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
636918	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
636919	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
636920	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
636921	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Foundation Condition	Good	
636922	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Operations B Ø	0	
636923	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Operations A Ø	0	
636924	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
636925	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
636926	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Unknown Operations	0	
636927	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Switching Operations	0	
636928	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
636929	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
636930	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Amps C Ø	0.0	
636931	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Operations Counter AL	292	
636932	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Operations Counter AF	292	
636933	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Maintenance Operations	0	
636934	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	General Comments		
636935	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Patrol Inspection	General Comments		
636936	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Follow-up Action Required?	n	
636937	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Patrol Inspection	Follow-up Action Required?	n	
636938	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Operations Ground	0	
636939	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Operations C Ø	0	
636940	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Amps B Ø	0.0	
636941	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Amps A Ø	0.0	
636942	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
636943	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
636944	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Operations B Ø	1	
636945	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Operations A Ø	1	
636946	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
636947	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
636948	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
636949	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
636950	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Amps C Ø	400.0	
636951	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
636952	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
636953	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
636954	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
636955	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
636956	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
636957	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Unknown Operations	0	
636958	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Switching Operations	0	
636959	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Operations Counter AL	219	
636960	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Operations Counter AF	219	
636961	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
636962	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	ok	
636963	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments	ok	
636964	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
636965	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
636966	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	30.00	
636967	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Maintenance Operations	0	
636968	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	General Comments		
636969	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Patrol Inspection	General Comments		
636970	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Follow-up Action Required?	n	
636971	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Patrol Inspection	Follow-up Action Required?	n	
636972	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Operations Ground	0	
636973	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Operations C Ø	0	
636974	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Operations B Ø	0	
636975	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Operations A Ø	0	
636976	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
636977	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
636978	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
636979	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
636980	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Patrol Inspection	Equipment Properly Labeled?	y	
636981	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Amps C Ø	400.0	
636982	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Amps B Ø	420.0	
636983	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Amps A Ø	400.0	
636984	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Accumulated Fault Duty C Ph V	16.74	%
636985	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Accumulated Fault Duty B Ph V	23.12	%
636986	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Accumulated Fault Duty A Ph V	32.68	%
636987	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	9 Month Operations	42	
636988	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
636989	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
636990	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
636991	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
636992	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
636993	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
636994	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Amps C Ø	400.0	
636995	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Amps B Ø	400.0	
636996	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Amps A Ø	400.0	
636997	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
636998	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
636999	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
637000	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	9 Months Operations	0	
637001	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Operations Ground	0	
637002	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Operations C Ø	0	
637003	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Operations B Ø	0	
637004	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Operations A Ø	0	
637005	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
637006	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
637007	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
637008	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Equipment Properly Labeled?	y	
637009	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Cabinet Paint Condition	Good	
637010	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
637011	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
637012	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
637013	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Bushings Connection/Risers	Good	
637014	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Bushing Condition	Good	
637015	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
637016	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
637017	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
637018	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Amps C Ø	66.0	
637019	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Amps B Ø	67.0	
637020	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Amps A Ø	79.0	
637021	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Accumulated Fault Duty C Ph V	4.43	%
637022	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Accumulated Fault Duty B Ph V	4.43	%
637023	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Accumulated Fault Duty A Ph V	4.85	%
637024	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	9 Month Operations	5	
637025	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
637026	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	General Comments		
637027	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	General Comments		
637028	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
637029	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
637030	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
637031	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
637032	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
637033	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
637034	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
637035	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
637036	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
637037	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
637038	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
637039	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
637040	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
637041	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
637042	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
637043	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
637044	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
637045	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
637046	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
637047	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
637048	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
637049	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
637050	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
637051	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
637052	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
637053	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
637054	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
637055	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
637056	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
637057	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	9 Month Operations	1	
637058	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
637059	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	General Comments		
637060	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
637061	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
637062	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
637063	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
637064	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Unknown Operations	0	
637065	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Tank Paint Condition	Good	
637066	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Switching Operations	0	
637067	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
637068	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Operations Counter AL	191	
637069	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Accumulated Fault Duty A Ph V	.45	%
637070	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Accumulated Fault Duty B Ph V	.45	%
637071	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Accumulated Fault Duty C Ph V	.45	%
637072	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Operations Counter AF	191	
637073	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Moisture and Leak Free?	y	
637074	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Maintenance Operations	1	
637075	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Unknown Operations	0	
637076	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
637077	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
637078	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
637079	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Switching Operations	0	
637080	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Operations Counter AL	253	
637081	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Operations Counter AF	253	
637082	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Maintenance Operations	0	
637083	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	General Comments		
637084	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Patrol Inspection	General Comments		
637085	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
637086	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
637087	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Operations Ground	0	
637088	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
637089	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
637090	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
637091	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
637092	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
637093	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
637094	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
637095	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
637096	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Amps C Ø	480.0	
637097	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Amps B Ø	500.0	
637098	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Amps A Ø	480.0	
637099	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
637100	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
637101	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
637102	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
637103	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
637104	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
637105	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	1.93	%
637106	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	1.93	%
637107	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	1.93	%
637108	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	9 Month Operations	4	
637109	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Heaters (All) Functioning?	y	
637110	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
637111	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Grounds in Place?	y	
637112	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	General Comments	ok	
637113	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	General Comments	ok	
637114	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Foundation Condition	Good	
637115	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
637116	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
637117	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
637118	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
637119	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	135.36	kw
637120	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Follow-up Action Required?	n	
637121	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
637122	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Follow-up Action Required?	n	
637123	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Amps B Ø	40.0	
637124	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Amps C Ø	82.0	
637125	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Bushing Condition	Good	
637126	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
637127	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
637128	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
637129	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
637130	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Maintenance Operations	0	
637131	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Operations Counter AF	1342	
637132	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Operations Counter AL	1342	
637133	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Switching Operations	0	
637134	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Unknown Operations	0	
637135	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Cabinet Paint Condition	Good	
637136	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
637137	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Unknown Operations	0	
637138	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
637139	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Vegetation	None	
637140	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
637141	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	General Comments		
637142	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
637143	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
637144	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
637145	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
637146	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Switching Operations	0	
637147	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Operations Counter AL	123	
637148	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Operations Counter AF	123	
637149	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
637150	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
637151	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
637152	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Unknown Operations	0	
637153	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Tank Paint Condition	Good	
637154	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Switching Operations	0	
637155	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
637156	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Operations Counter AL	148	
637157	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Operations Counter AF	148	
637158	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Equipment Properly Labeled?	y	
637159	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
637160	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
637161	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
637162	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	General Comments		
637163	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Moisture and Leak Free?	y	
637164	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Maintenance Operations	1	
637165	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Heaters (All) Functioning?	y	
637166	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Regulator As Left Counter	66267	
637167	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Readings	General Comments		
637168	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
637169	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
637170	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	205.00	
637171	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
637172	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
637173	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
637174	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Grounds in Place?	y	
637175	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
637176	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
637177	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Tank Leaks	None	
637178	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
637179	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	General Comments	ok	
637180	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	General Comments	ok	
637181	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Foundation Condition	Good	
637182	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Follow-up Action Required?	n	
637183	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Follow-up Action Required?	n	
637184	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Operations Ground	0	
637185	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Operations C Ø	0	
637186	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Operations B Ø	0	
637187	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Operations A Ø	0	
637188	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
637189	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
637190	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
637191	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
637192	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
637193	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
637194	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	General Comments		
637195	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
637196	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	20	°C
637197	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
637198	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
637199	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
637200	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
637201	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
637202	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
637203	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
637204	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
637205	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
637206	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
637207	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
637208	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
637209	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
637210	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
637211	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	40	°C
637212	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
637213	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
637214	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	25	°C
637215	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	40	°C
637216	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
637217	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
637218	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
637219	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
637220	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
637221	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
637222	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
637223	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
637224	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
637225	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
637226	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
637227	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
637228	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
637229	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
637230	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
637231	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
637232	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
637233	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
637234	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	General Comments	drag hands on LTC do not reset, nitro bottle at 0	
637235	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	General Comments		
637236	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
637237	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
637238	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
637239	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
637240	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
637241	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
637242	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
637243	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	9 Month Operations	9	
637244	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Accumulated Fault Duty A Ph V	.52	%
637245	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
637246	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Operations A Ø	0	
637247	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Accumulated Fault Duty B Ph V	.52	%
637248	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Accumulated Fault Duty C Ph V	.60	%
637249	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Operations B Ø	0	
637250	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Operations C Ø	0	
637251	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Operations Ground	0	
637252	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Patrol Inspection	Follow-up Action Required?	n	
637253	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Follow-up Action Required?	n	
637254	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Patrol Inspection	General Comments		
637255	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	General Comments	R&C	
637256	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Amps A Ø	55.0	
637257	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
637258	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
637259	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
637260	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
637261	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
637262	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
637263	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Bushings Connection/Risers	Good	
637264	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Bushing Condition	Good	
637265	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Amps C Ø	50.0	
637266	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Amps B Ø	50.0	
637267	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
637268	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Vegetation	None	
637269	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
637270	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
637271	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	General Comments	ok	
637272	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
637273	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
637274	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
637275	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Unknown Operations	0	
637276	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Switching Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
637277	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Operations Counter AL	118	
637278	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Operations Counter AF	118	
637279	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Maintenance Operations	0	
637280	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	General Comments		
637281	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Patrol Inspection	General Comments		
637282	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Follow-up Action Required?	n	
637283	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Amps A Ø	50.0	
637284	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Patrol Inspection	Follow-up Action Required?	n	
637285	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Operations Ground	0	
637286	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Operations C Ø	0	
637287	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Operations B Ø	0	
637288	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Operations A Ø	0	
637289	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
637290	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
637291	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
637292	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Patrol Inspection	Equipment Properly Labeled?	y	
637293	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Amps C Ø	100.0	
637294	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Amps B Ø	100.0	
637295	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Amps A Ø	100.0	
637296	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
637297	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
637298	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
637299	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	9 Month Operations	0	
637300	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Follow-up Action Required?	n	
637301	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Follow-up Action Required?	n	
637302	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Foundation Condition	Good	
637303	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	General Comments	ok	
637304	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	General Comments	ok	
637305	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Grounds in Place?	y	
637306	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Heaters (All) Functioning?	y	
637307	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	PF000268	PowerFuse	OX-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
637308	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	PF000268	PowerFuse	OX-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
637309	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	PF000266	PowerFuse	OX-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
637310	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	PF000266	PowerFuse	OX-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
637311	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Maintenance Operations	1	
637312	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Moisture and Leak Free?	y	
637313	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Operations Counter AF	160	
637314	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Operations Counter AL	0	
637315	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
637316	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Switching Operations	0	
637317	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Tank Paint Condition	Good	
637318	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Unknown Operations	0	
637319	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Patrol Inspection	General Comments		
637320	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Follow-up Action Required?	n	
637321	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Patrol Inspection	Follow-up Action Required?	n	
637322	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Operations Ground	0	
637323	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Operations C Ø	0	
637324	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
637325	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Equipment Properly Labeled?	y	
637326	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Cabinet Paint Condition	Good	
637327	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
637328	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
637329	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Clear of Trash?	y	
637330	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
637331	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
637332	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Unknown Operations	0	
637333	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Switching Operations	0	
637334	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Operations Counter AL	669	
637335	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Operations Counter AF	669	
637336	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Maintenance Operations	0	
637337	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	General Comments		
637338	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Patrol Inspection	General Comments		
637339	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
637340	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
637341	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
637342	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
637343	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
637344	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Maintenance Operations	0	
637345	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	General Comments		
637346	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Patrol Inspection	General Comments		
637347	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Follow-up Action Required?	n	
637348	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Patrol Inspection	Follow-up Action Required?	n	
637349	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Operations Ground	0	
637350	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
637351	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
637352	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Operations B Ø	0	
637353	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Operations A Ø	0	
637354	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
637355	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
637356	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
637357	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Patrol Inspection	Equipment Properly Labeled?	y	
637358	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Amps C Ø	100.0	
637359	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Amps B Ø	100.0	
637360	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Amps A Ø	100.0	
637361	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
637362	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
637363	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
637364	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
637365	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
637366	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Accumulated Fault Duty C Ph V	1.59	%
637367	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Accumulated Fault Duty B Ph V	1.59	%
637368	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Accumulated Fault Duty A Ph V	1.59	%
637369	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	9 Month Operations	0	
637370	1/10/2019 11:00	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
637371	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
637372	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
637373	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
637374	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
637375	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
637376	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
637377	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
637378	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
637379	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
637380	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
637381	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
637382	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
637383	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
637384	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Operations A Ø	0	
637385	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Operations B Ø	0	
637386	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Operations C Ø	0	
637387	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
637388	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
637389	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
637390	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Operations Ground	0	
637391	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
637392	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
637393	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
637394	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
637395	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
637396	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
637397	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
637398	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
637399	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
637400	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	General Comments		
637401	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
637402	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
637403	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	General Comments	ok	
637404	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
637405	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5070	
637406	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
637407	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
637408	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
637409	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
637410	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
637411	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
637412	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
637413	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
637414	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
637415	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
637416	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
637417	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
637418	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
637419	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
637420	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	General Comments	ok	
637421	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
637422	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
637423	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
637424	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
637425	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
637426	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
637427	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
637428	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
637429	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Regulator As Left Counter	11134	
637430	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
637431	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
637432	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
637433	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
637434	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Tank Leaks	None	
637435	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
637436	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
637437	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
637438	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
637439	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
637440	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Readings	General Comments		
637441	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
637442	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
637443	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
637444	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
637445	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
637446	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
637447	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
637448	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
637449	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
637450	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
637451	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
637452	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	General Comments		
637453	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
637454	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
637455	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
637456	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
637457	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
637458	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
637459	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
637460	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
637461	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
637462	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
637463	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
637464	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
637465	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
637466	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
637467	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	247.50	
637468	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
637469	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
637470	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
637471	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
637472	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
637473	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
637474	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	78	°C
637475	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	30	°C
637476	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
637477	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
637478	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
637479	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
637480	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
637481	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	1	
637482	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
637483	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
637484	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
637485	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
637486	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
637487	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
637488	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
637489	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
637490	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
637491	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
637492	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
637493	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
637494	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
637495	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
637496	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
637497	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1326	
637498	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1326	
637499	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	6	
637500	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
637501	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
637502	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
637503	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
637504	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
637505	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
637506	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
637507	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
637508	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
637509	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
637510	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
637511	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
637512	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
637513	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
637514	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
637515	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
637516	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	General Comments	ok	
637517	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
637518	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Vegetation	None	
637519	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Operations Counter AF	511	
637520	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Maintenance Operations	0	
637521	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	General Comments	A.B PHASE IOC	
637522	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
637523	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
637524	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
637525	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
637526	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
637527	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
637528	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
637529	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
637530	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
637531	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
637532	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
637533	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
637534	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
637535	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
637536	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
637537	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
637538	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
637539	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
637540	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
637541	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
637542	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
637543	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
637544	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
637545	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
637546	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
637547	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
637548	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
637549	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	General Comments	ok	
637550	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
637551	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
637552	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
637553	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
637554	1/10/2019 14:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
637555	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Operations B Ø	0	
637556	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Operations A Ø	0	
637557	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
637558	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
637559	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Ambient Temp	29	°F
637560	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
637561	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
637562	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Clear of Trash?	y	
637563	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
637564	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
637565	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
637566	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	BCH000429	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.9	VDC
637567	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	BCH000429	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
637568	1/10/2019 13:06	Distribution	Providence East Quarterly Inspection	BCH000429	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
637569	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
637570	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
637571	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
637572	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
637573	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
637574	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
637575	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
637576	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
637577	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
637578	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
637579	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
637580	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
637581	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
637582	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
637583	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Amps C Ø	160.0	
637584	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Amps B Ø	180.0	
637585	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Amps A Ø	200.0	
637586	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Accumulated Fault Duty C Ph AM	27.91	%
637587	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Accumulated Fault Duty B Ph AM	25.25	%
637588	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Accumulated Fault Duty A Ph AM	19.93	%
637589	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	9 Months Operations	17	
637590	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
637591	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
637592	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
637593	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
637594	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
637595	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
637596	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
637597	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
637598	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	General Comments		
637599	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	General Comments	needs nitro.	
637600	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
637601	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
637602	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
637603	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	Oil Temp Max	30	°C
637604	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	Oil Temp Present	15	°C
637605	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
637606	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
637607	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
637608	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
637609	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
637610	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
637611	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
637612	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	General Comments	ok	
637613	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
637614	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
637615	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
637616	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
637617	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
637618	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1825.20	kw
637619	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	226.00	
637620	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
637621	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Oil Temp Max	80	°C
637622	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
637623	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitro	
637624	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
637625	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
637626	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
637627	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	Oil Temp Max	68	°C
637628	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	Oil Temp Present	28	°C
637629	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
637630	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
637631	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
637632	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
637633	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
637634	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
637635	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
637636	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
637637	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
637638	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
637639	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
637640	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
637641	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
637642	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	General Comments		
637643	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Patrol Inspection	General Comments		
637644	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Follow-up Action Required?	n	
637645	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
637646	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
637647	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
637648	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
637649	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
637650	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
637651	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
637652	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
637653	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
637654	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
637655	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
637656	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
637657	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
637658	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
637659	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
637660	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
637661	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
637662	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
637663	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
637664	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
637665	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
637666	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
637667	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
637668	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
637669	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
637670	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
637671	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
637672	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
637673	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
637674	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	General Comments		
637675	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
637676	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
637677	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Operations Counter AL	511	
637678	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Operations Counter AL	871	
637679	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
637680	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4L	
637681	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
637682	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
637683	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC As Left Counter	94175	
637684	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC As Found Counter	94175	
637685	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
637686	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	General Comments		
637687	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
637688	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Foundation Condition	Good	
637689	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
637690	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
637691	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
637692	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
637693	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
637694	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
637695	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	General Comments		
637696	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
637697	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
637698	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
637699	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
637700	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
637701	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
637702	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Operations Counter AF	871	
637703	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Maintenance Operations	0	
637704	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
637705	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
637706	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
637707	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
637708	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
637709	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
637710	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
637711	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
637712	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
637713	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
637714	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	General Comments		
637715	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
637716	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
637717	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
637718	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1800	psi
637719	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
637720	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	Oil Temp Max	30	°C
637721	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
637722	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
637723	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
637724	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
637725	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
637726	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
637727	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
637728	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
637729	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
637730	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Amps C Ø	140.0	
637731	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Amps B Ø	150.0	
637732	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Amps A Ø	130.0	
637733	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
637734	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Accumulated Fault Duty B Ph AM	9.30	%
637735	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Accumulated Fault Duty A Ph AM	10.63	%
637736	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	9 Months Operations	1	
637737	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
637738	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
637739	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
637740	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Patrol Inspection	Follow-up Action Required?	n	
637741	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
637742	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
637743	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
637744	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
637745	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000076	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
637746	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000076	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
637747	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000076	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
637748	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000076	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
637749	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	LTCM000076	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
637750	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
637751	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Operations Ground	0	
637752	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
637753	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
637754	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
637755	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
637756	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
637757	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
637758	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
637759	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
637760	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
637761	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
637762	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	32	°F
637763	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
637764	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
637765	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
637766	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Operations C Ø	0	
637767	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Switching Operations	0	
637768	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Unknown Operations	0	
637769	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
637770	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
637771	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
637772	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
637773	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
637774	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
637775	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
637776	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
637777	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
637778	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Unknown Operations	0	
637779	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Switching Operations	0	
637780	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Operations Counter AL	326	
637781	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Operations Counter AF	326	
637782	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Maintenance Operations	0	
637783	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
637784	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	General Comments		
637785	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
637786	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
637787	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Patrol Inspection	General Comments		
637788	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Follow-up Action Required?	n	
637789	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
637790	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
637791	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
637792	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Operations Ground	0	
637793	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Operations C Ø	0	
637794	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Operations B Ø	0	
637795	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Operations A Ø	0	
637796	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
637797	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
637798	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
637799	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
637800	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
637801	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
637802	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
637803	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
637804	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
637805	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
637806	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
637807	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
637808	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
637809	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
637810	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
637811	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
637812	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Amps C Ø	0.0	
637813	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Amps B Ø	0.0	
637814	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
637815	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
637816	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
637817	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Amps A Ø	0.0	
637818	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	9 Months Operations	18	
637819	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	General Comments		
637820	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
637821	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	35	°C
637822	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	25	°C
637823	1/10/2019 14:43	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
637824	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
637825	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
637826	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
637827	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
637828	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
637829	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	132840	
637830	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
637831	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
637832	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
637833	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
637834	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
637835	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
637836	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	4R	
637837	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
637838	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	55	°C
637839	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
637840	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
637841	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	38	°C
637842	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
637843	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
637844	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
637845	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
637846	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
637847	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
637848	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
637849	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
637850	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
637851	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	50	°C
637852	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	38	°C
637853	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
637854	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
637855	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
637856	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2R	
637857	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
637858	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
637859	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
637860	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
637861	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
637862	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	42	°C
637863	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
637864	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
637865	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
637866	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
637867	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
637868	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
637869	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
637870	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
637871	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	34	°F
637872	1/10/2019 9:49	Distribution	Loudon Avenue Storage Lot Quarterly Inspe	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
637873	1/10/2019 9:49	Distribution	Loudon Avenue Storage Lot Quarterly Inspe	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
637874	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
637875	1/10/2019 9:49	Distribution	Loudon Avenue Storage Lot Quarterly Inspe	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Cabinet Paint Condition	Good	
637876	1/10/2019 9:49	Distribution	Loudon Avenue Storage Lot Quarterly Inspe	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
637877	1/10/2019 9:49	Distribution	Loudon Avenue Storage Lot Quarterly Inspe	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Follow-up Action Required?	n	
637878	1/10/2019 9:49	Distribution	Loudon Avenue Storage Lot Quarterly Inspe	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Gauge(s) Condition	Good	
637879	1/10/2019 9:49	Distribution	Loudon Avenue Storage Lot Quarterly Inspe	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	General Comments	y	
637880	1/10/2019 9:49	Distribution	Loudon Avenue Storage Lot Quarterly Inspe	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Moisture and Leak Free?	y	
637881	1/10/2019 9:49	Distribution	Loudon Avenue Storage Lot Quarterly Inspe	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	SF6 Bushing Condition	Good	
637882	1/10/2019 9:49	Distribution	Loudon Avenue Storage Lot Quarterly Inspe	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	SF6 Pressure	10	psi
637883	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
637884	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
637885	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
637886	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
637887	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
637888	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Foundation Condition	Good	
637889	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
637890	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
637891	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	General Comments	ok	
637892	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
637893	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Follow-up Action Required?	n	
637894	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Patrol Inspection	Follow-up Action Required?	n	
637895	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Operations Ground	0	
637896	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Operations C Ø	0	
637897	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
637898	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
637899	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
637900	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
637901	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
637902	1/10/2019 9:49	Distribution	Loudon Avenue Storage Lot Quarterly Inspe	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Tank Paint Condition	Good	
637903	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
637904	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
637905	1/10/2019 11:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
637906	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
637907	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
637908	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
637909	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	ok	
637910	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments	ok	
637911	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
637912	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
637913	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	665.28	kw
637914	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	55.00	
637915	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
637916	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	30	°C
637917	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	15	°C
637918	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
637919	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
637920	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
637921	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
637922	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
637923	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
637924	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
637925	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
637926	1/10/2019 7:08	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Unknown Operations	0	
637927	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
637928	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
637929	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
637930	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
637931	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
637932	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
637933	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
637934	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
637935	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
637936	1/10/2019 9:37	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
637937	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
637938	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
637939	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
637940	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
637941	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
637942	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
637943	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
637944	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
637945	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
637946	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
637947	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
637948	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
637949	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
637950	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
637951	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
637952	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
637953	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
637954	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
637955	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
637956	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	Oil Temp Present	18	°C
637957	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	Oil Temp Max	18	°C
637958	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
637959	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
637960	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
637961	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
637962	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
637963	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
637964	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
637965	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
637966	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
637967	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
637968	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
637969	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
637970	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
637971	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	ok	
637972	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments	ok	
637973	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
637974	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
637975	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	75.00	
637976	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
637977	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	60	°C
637978	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
637979	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	General Comments		
637980	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
637981	1/10/2019 8:41	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
637982	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	15	°C
637983	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
637984	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
637985	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
637986	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
637987	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
637988	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	9 Month Operations	4	
637989	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Accumulated Fault Duty A Ph V	3.31	%
637990	1/10/2019 12:57	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Accumulated Fault Duty B Ph V	3.31	%
637991	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
637992	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Reading	.4566	
637993	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
637994	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
637995	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
637996	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	60	°C
637997	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	30	°C
637998	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
637999	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
638000	1/11/2019 9:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Patrol Inspection	General Comments		
638001	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
638002	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	1.3	VDC
638003	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	1.1	VDC
638004	1/10/2019 12:08	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
638005	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
638006	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
638007	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
638008	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
638009	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
638010	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
638011	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
638012	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
638013	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
638014	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
638015	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
638016	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
638017	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	LTC Totalizer Reading	3287.52	kw
638018	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	1351	
638019	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
638020	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
638021	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
638022	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
638023	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments	ok	
638024	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
638025	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
638026	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
638027	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments	ok	
638028	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments	Center bushing leaking oil.	
638029	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
638030	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
638031	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
638032	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
638033	1/10/2019 13:14	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
638034	1/10/2019 11:26	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
638035	1/10/2019 9:49	Distribution	Loudon Avenue Storage Lot Quarterly Inspe	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Ambient Temperature	23	°F
638036	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Moisture and Leak Free?	y	
638037	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
638038	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Tank Paint Condition	Good	
638039	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
638040	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
638041	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
638042	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Heaters (All) Functioning?	y	
638043	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
638044	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
638045	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
638046	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
638047	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
638048	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
638049	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
638050	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
638051	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
638052	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
638053	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	General Comments		
638054	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	General Comments		
638055	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
638056	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
638057	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
638058	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1186.56	kw
638059	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
638060	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
638061	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Oil Temp Max	70	°C
638062	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	9 Month Operations	0	
638063	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
638064	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	2.01	%
638065	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
638066	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Amps A Ø	885.0	
638067	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
638068	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	General Comments		
638069	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	General Comments		
638070	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC As Found Counter	64038	
638071	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC As Left Counter	64049	
638072	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	PF000173	PowerFuse	HB-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
638073	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
638074	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	PF000173	PowerFuse	HB-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
638075	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
638076	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Vegetation	None	
638077	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
638078	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Warning Signs OK?	y	
638079	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
638080	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Tank Leaks	None	
638081	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
638082	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
638083	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
638084	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
638085	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	General Comments		
638086	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
638087	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Grounds in Place?	y	
638088	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	General Comments		
638089	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
638090	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
638091	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Foundation Condition	Good	
638092	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Follow-up Action Required?	n	
638093	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
638094	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
638095	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
638096	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
638097	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
638098	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC Current Tap Position	6L	
638099	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
638100	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
638101	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
638102	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Bushings Connection/Risers	Good	
638103	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC Max Tap Position	8R	
638104	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Cabinet Paint Condition	Good	
638105	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Equipment Properly Labeled?	y	
638106	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC Min Tap Position	8L	
638107	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
638108	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
638109	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
638110	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Bushing Condition	Good	
638111	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	All Connections OK?	y	
638112	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
638113	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
638114	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC Operations Since Last Insp	610	
638115	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
638116	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Follow-up Action Required?	n	
638117	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Foundation Condition	Good	
638118	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
638119	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	General Comments		
638120	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Grounds in Place?	y	
638121	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC Operations Since Last Insp	656	
638122	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
638123	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Accumulated Fault Duty C Ph V	16.74	%
638124	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	9 Months Operations	28	
638125	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Accumulated Fault Duty A Ph AM	40.95	%
638126	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Accumulated Fault Duty B Ph AM	55.41	%
638127	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Accumulated Fault Duty C Ph AM	42.16	%
638128	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Amps A Ø	230.0	
638129	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
638130	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
638131	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
638132	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	5	
638133	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
638134	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Accumulated Fault Duty B Ph V	26.31	%
638135	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Accumulated Fault Duty A Ph V	25.51	%
638136	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	BCH001165	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
638137	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
638138	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Bushings Connection/Risers	Good	
638139	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Bushing Condition	Good	
638140	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
638141	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
638142	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
638143	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	BCH001165	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	changed battery charger during QI	
638144	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
638145	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
638146	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	9 Month Operations	2	
638147	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
638148	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
638149	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
638150	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Amps A Ø	43.0	
638151	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Amps B Ø	24.0	
638152	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Amps C Ø	85.0	
638153	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Bushing Condition	Good	
638154	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC As Found Counter	50546	
638155	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Bushings Connection/Risers	Good	
638156	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
638157	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
638158	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
638159	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Cabinet Paint Condition	Good	
638160	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	General Comments		
638161	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	General Comments		
638162	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
638163	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	9 Month Operations	6	
638164	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Equipment Properly Labeled?	y	
638165	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
638166	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
638167	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
638168	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
638169	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
638170	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
638171	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
638172	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
638173	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
638174	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
638175	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Oil Temp Present	36	°C
638176	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
638177	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	General Comments		
638178	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	General Comments		
638179	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
638180	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Vegetation	None	
638181	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
638182	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
638183	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
638184	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
638185	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
638186	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
638187	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
638188	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
638189	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Amps A Ø	56.0	
638190	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
638191	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
638192	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
638193	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4944	
638194	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Tank Paint Condition	Good	
638195	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
638196	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Amps B Ø	850.0	
638197	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Amps C Ø	830.0	
638198	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
638199	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
638200	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
638201	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
638202	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Moisture and Leak Free?	y	
638203	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Heaters (All) Functioning?	y	
638204	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Grounds in Place?	y	
638205	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	General Comments		
638206	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Foundation Condition	Good	
638207	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Follow-up Action Required?	n	
638208	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Equipment Properly Labeled?	y	
638209	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
638210	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
638211	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
638212	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
638213	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Cabinet Paint Condition	Good	
638214	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
638215	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
638216	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
638217	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
638218	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
638219	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
638220	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
638221	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
638222	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC Min Tap Position	15L	
638223	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC Max Tap Position	5L	
638224	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC Current Tap Position	9L	
638225	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
638226	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC As Left Counter	50554	
638227	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
638228	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Moisture and Leak Free?	y	
638229	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Heaters (All) Functioning?	y	
638230	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
638231	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
638232	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
638233	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
638234	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
638235	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
638236	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC As Found Counter	13325	
638237	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC As Left Counter	13325	
638238	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
638239	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Current Tap Position	10L	
638240	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Max Tap Position	1L	
638241	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
638242	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
638243	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
638244	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
638245	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	60	°C
638246	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
638247	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
638248	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
638249	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
638250	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
638251	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
638252	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
638253	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
638254	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations Ground	0	
638255	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
638256	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	Oil Temp Present	25	°C
638257	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
638258	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
638259	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
638260	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
638261	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	General Comments		
638262	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
638263	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
638264	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
638265	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	VRR Time Delay	45	Seconds
638266	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
638267	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Accumulated Fault Duty A Ph V	5.58	%
638268	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	9 Month Operations	82	
638269	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
638270	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
638271	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
638272	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Foundation Condition	Good	
638273	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
638274	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
638275	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
638276	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
638277	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
638278	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
638279	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
638280	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
638281	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Unknown Operations	0	
638282	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Switching Operations	0	
638283	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Operations Counter AL	399	
638284	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Operations Counter AF	399	
638285	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Maintenance Operations	0	
638286	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	General Comments		
638287	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Patrol Inspection	General Comments		
638288	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Follow-up Action Required?	n	
638289	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Patrol Inspection	Follow-up Action Required?	n	
638290	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations Ground	0	
638291	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations C Ø	0	
638292	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations B Ø	0	
638293	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations A Ø	0	
638294	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
638295	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
638296	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
638297	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Patrol Inspection	Equipment Properly Labeled?	y	
638298	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Amps C Ø	233.0	
638299	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Amps B Ø	242.0	
638300	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Amps A Ø	259.0	
638301	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
638302	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
638303	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
638304	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Cabinet Paint Condition	Good	
638305	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	PF000251	PowerFuse	ML-12KV TR 6 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
638306	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	PF000251	PowerFuse	ML-12KV TR 6 POT	Disconnect Powerfuse Inspection	General Comments	ok	
638307	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	29	
638308	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Equipment Properly Labeled?	y	
638309	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
638310	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
638311	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
638312	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	Follow-up Action Required?	n	
638313	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
638314	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	General Comments		
638315	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	General Comments		
638316	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
638317	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
638318	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
638319	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Follow-up Action Required?	n	
638320	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Foundation Condition	Good	
638321	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	General Comments		
638322	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Grounds in Place?	y	
638323	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Amps C Ø	400.0	
638324	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Amps B Ø	410.0	
638325	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Tank Paint Condition	Good	
638326	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
638327	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Tank Leaks	None	
638328	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
638329	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Operations Counter	1986	
638330	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
638331	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
638332	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	General Comments		
638333	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
638334	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
638335	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Accumulated Fault Duty C Ph AM	9.64	%
638336	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Accumulated Fault Duty B Ph AM	7.23	%
638337	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Accumulated Fault Duty A Ph AM	8.43	%
638338	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	9 Months Operations	6	
638339	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	PF000252	PowerFuse	ML-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
638340	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
638341	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Patrol Inspection	General Comments		
638342	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations C Ø	0	
638343	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations Ground	0	
638344	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	PF000250	PowerFuse	ML-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
638345	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	PF000250	PowerFuse	ML-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
638346	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	General Comments		
638347	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Maintenance Operations	0	
638348	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	PF000249	PowerFuse	ML-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	ok	
638349	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	PF000249	PowerFuse	ML-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
638350	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Operations Counter AF	365	
638351	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Operations Counter AL	365	
638352	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	PF000248	PowerFuse	ML-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
638353	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	PF000248	PowerFuse	ML-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
638354	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Switching Operations	0	
638355	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Unknown Operations	0	
638356	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Bushing Condition	Good	
638357	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Patrol Inspection	Follow-up Action Required?	n	
638358	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	PF000170	PowerFuse	HB-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
638359	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	PF000170	PowerFuse	HB-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
638360	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
638361	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
638362	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	Follow-up Action Required?	n	
638363	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
638364	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
638365	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
638366	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Amps C Ø	50.0	
638367	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Amps B Ø	56.0	
638368	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	All Connections OK?	y	
638369	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
638370	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	PF000171	PowerFuse	HB-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
638371	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	PF000171	PowerFuse	HB-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
638372	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	PF000172	PowerFuse	HB-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
638373	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	PF000172	PowerFuse	HB-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
638374	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
638375	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
638376	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	309	
638377	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	Follow-up Action Required?	n	
638378	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	309	
638379	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
638380	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
638381	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
638382	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
638383	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Patrol Inspection	Equipment Properly Labeled?	y	
638384	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Amps C Ø	37.0	
638385	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Amps B Ø	39.0	
638386	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Amps A Ø	42.0	
638387	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
638388	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
638389	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
638390	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
638391	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
638392	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
638393	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
638394	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
638395	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	LTC Operation Checked?	y	
638396	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	49.38	%
638397	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	15.66	%
638398	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	340.0	
638399	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
638400	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
638401	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
638402	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Bushings Connection/Risers	Good	
638403	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
638404	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	General Comments		
638405	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Ambient Temp	38	°F
638406	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
638407	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Clear of Trash?	y	
638408	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
638409	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
638410	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
638411	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
638412	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
638413	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	9 Month Operations	9	
638414	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Accumulated Fault Duty A Ph V	22.32	%
638415	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
638416	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
638417	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
638418	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Accumulated Fault Duty B Ph V	22.32	%
638419	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Accumulated Fault Duty C Ph V	18.33	%
638420	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Amps A Ø	169.0	
638421	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Amps B Ø	158.0	
638422	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Min Tap Position	11L	
638423	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
638424	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Operations Since Last Insp	319	
638425	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
638426	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
638427	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
638428	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
638429	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Amps C Ø	160.0	
638430	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
638431	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
638432	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
638433	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
638434	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations B Ø	0	
638435	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	PF000252	PowerFuse	ML-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
638436	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Follow-up Action Required?	n	
638437	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Patrol Inspection	Follow-up Action Required?	n	
638438	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations Ground	0	
638439	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations C Ø	0	
638440	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations B Ø	0	
638441	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations A Ø	0	
638442	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Amps A Ø	380.0	
638443	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
638444	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
638445	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	7	
638446	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	General Comments	this is the correct VC	
638447	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
638448	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations C Ø	0	
638449	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
638450	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
638451	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations A Ø	0	
638452	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations B Ø	0	
638453	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations C Ø	0	
638454	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations Ground	0	
638455	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Patrol Inspection	Follow-up Action Required?	n	
638456	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
638457	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations Ground	0	
638458	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Patrol Inspection	Follow-up Action Required?	n	
638459	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Follow-up Action Required?	n	
638460	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
638461	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	78.26	
638462	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
638463	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
638464	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
638465	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	390.0	
638466	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	400.0	
638467	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	430.0	
638468	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	20.48	%
638469	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
638470	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
638471	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
638472	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	26.50	%
638473	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	16.86	%
638474	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	14	
638475	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
638476	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
638477	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Amps C Ø	180.0	
638478	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Amps B Ø	200.0	
638479	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Amps A Ø	200.0	
638480	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
638481	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
638482	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
638483	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
638484	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
638485	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
638486	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
638487	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Accumulated Fault Duty C Ph AM	1.20	%
638488	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Accumulated Fault Duty B Ph AM	2.41	%
638489	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Accumulated Fault Duty A Ph AM	3.61	%
638490	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	9 Months Operations	2	
638491	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Ambient Temp	42	°F
638492	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
638493	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Clear of Trash?	y	
638494	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
638495	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
638496	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
638497	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
638498	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Patrol Inspection	General Comments		
638499	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Operations Counter AL	563	
638500	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Patrol Inspection	General Comments		
638501	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	General Comments		
638502	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Maintenance Operations	0	
638503	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Operations Counter AF	103	
638504	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Operations Counter AL	103	
638505	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Switching Operations	0	
638506	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Unknown Operations	0	
638507	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Operations Counter AF	563	
638508	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Maintenance Operations	0	
638509	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
638510	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
638511	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Vent Fans OK?	y	
638512	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
638513	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
638514	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
638515	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	485	
638516	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
638517	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
638518	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
638519	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	9 Month Operations	0	
638520	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
638521	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
638522	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	485	
638523	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
638524	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
638525	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
638526	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
638527	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
638528	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
638529	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
638530	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
638531	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
638532	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
638533	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	General Comments		
638534	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
638535	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
638536	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Unknown Operations	0	
638537	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Switching Operations	0	
638538	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	9 Month Operations	1	
638539	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Operations Counter AL	371	
638540	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Accumulated Fault Duty A Ph V	68.56	%
638541	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Accumulated Fault Duty B Ph V	74.14	%
638542	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	Follow-up Action Required?	n	
638543	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Accumulated Fault Duty C Ph V	72.54	%
638544	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Amps A Ø	120.0	
638545	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Amps B Ø	120.0	
638546	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Amps C Ø	120.0	
638547	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Patrol Inspection	Equipment Properly Labeled?	y	
638548	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
638549	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Operations Counter AF	371	
638550	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Maintenance Operations	0	
638551	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
638552	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
638553	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations A Ø	0	
638554	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations B Ø	0	
638555	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
638556	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
638557	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
638558	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
638559	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
638560	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
638561	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
638562	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
638563	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
638564	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	9 Month Operations	0	
638565	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
638566	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
638567	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
638568	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	5.78	%
638569	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	3.85	%
638570	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
638571	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
638572	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Regulator As Left Counter	473038	
638573	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
638574	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
638575	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Tank Leaks	None	
638576	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
638577	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
638578	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
638579	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Switching Operations	0	
638580	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Unknown Operations	0	
638581	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
638582	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	403	
638583	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
638584	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
638585	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
638586	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
638587	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
638588	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
638589	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
638590	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
638591	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
638592	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
638593	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
638594	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	General Comments		
638595	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Maintenance Operations	0	
638596	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Operations Counter AF	544	
638597	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
638598	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
638599	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
638600	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Operations Counter AL	544	
638601	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	375	
638602	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	14.9	
638603	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	22.3	
638604	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	334	
638605	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
638606	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
638607	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
638608	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	37	°C
638609	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
638610	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	16.7	
638611	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Follow-up Action Required?	n	
638612	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Patrol Inspection	Follow-up Action Required?	n	
638613	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations Ground	0	
638614	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations C Ø	0	
638615	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations B Ø	0	
638616	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations A Ø	0	
638617	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
638618	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
638619	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
638620	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
638621	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Amps C Ø	400.0	
638622	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Amps B Ø	400.0	
638623	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Amps A Ø	400.0	
638624	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
638625	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Amps A Ø	0.0	
638626	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Accumulated Fault Duty C Ph AM	13.25	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
638627	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Accumulated Fault Duty B Ph AM	14.45	%
638628	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Accumulated Fault Duty A Ph AM	12.05	%
638629	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	9 Months Operations	0	
638630	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
638631	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Amps B Ø	0.0	
638632	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Amps C Ø	0.0	
638633	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
638634	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
638635	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
638636	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
638637	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
638638	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
638639	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
638640	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
638641	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
638642	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Patrol Inspection	Equipment Properly Labeled?	y	
638643	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
638644	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
638645	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
638646	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
638647	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	General Comments		
638648	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations A Ø	0	
638649	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Patrol Inspection	General Comments		
638650	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
638651	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
638652	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
638653	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
638654	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
638655	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Follow-up Action Required?	n	
638656	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
638657	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Patrol Inspection	General Comments		
638658	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	General Comments		
638659	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
638660	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
638661	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
638662	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
638663	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
638664	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
638665	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
638666	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
638667	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	BCH001165	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.250	millivolts
638668	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	General Comments		
638669	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	General Comments		
638670	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Patrol Inspection	General Comments		
638671	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Follow-up Action Required?	n	
638672	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Patrol Inspection	Follow-up Action Required?	n	
638673	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations Ground	0	
638674	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations C Ø	0	
638675	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
638676	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
638677	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	55	°C
638678	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Unknown Operations	0	
638679	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Switching Operations	1	
638680	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	35	°C
638681	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
638682	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
638683	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
638684	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	55	°C
638685	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
638686	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	35	°C
638687	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Amps C Ø	575.0	
638688	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Amps B Ø	590.0	
638689	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
638690	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
638691	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	General Comments	ok	
638692	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
638693	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
638694	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Amps A Ø	627.0	
638695	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
638696	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	3.85	%
638697	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Follow-up Action Required?	n	
638698	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
638699	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
638700	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
638701	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
638702	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
638703	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
638704	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
638705	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
638706	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
638707	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
638708	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
638709	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations B Ø	0	
638710	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations A Ø	0	
638711	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
638712	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
638713	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
638714	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
638715	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
638716	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
638717	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
638718	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
638719	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
638720	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	PF000362	PowerFuse	TT-34KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
638721	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
638722	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
638723	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
638724	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
638725	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Operations A Ø	0	
638726	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Operations B Ø	0	
638727	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Operations C Ø	0	
638728	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Operations Ground	0	
638729	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Follow-up Action Required?	n	
638730	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Follow-up Action Required?	n	
638731	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Foundation Condition	Good	
638732	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	General Comments		
638733	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	General Comments		
638734	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Grounds in Place?	y	
638735	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Maintenance Operations	0	
638736	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Moisture and Leak Free?	y	
638737	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Operations Counter AF	147	
638738	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Operations Counter AL	148	
638739	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Switching Operations	1	
638740	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Tank Paint Condition	Good	
638741	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Unknown Operations	0	
638742	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	BCH001165	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
638743	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	BCH001165	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
638744	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	BCH001165	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
638745	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
638746	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	needs desicant filter ontop of ltc	
638747	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
638748	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
638749	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	BCH001165	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
638750	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
638751	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
638752	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
638753	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
638754	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
638755	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
638756	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
638757	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
638758	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
638759	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
638760	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
638761	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
638762	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
638763	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
638764	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
638765	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
638766	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	55.90	
638767	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
638768	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
638769	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
638770	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
638771	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
638772	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
638773	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
638774	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	340.0	
638775	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	330.0	
638776	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
638777	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Switching Operations	0	
638778	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	38	°C
638779	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	38	°C
638780	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
638781	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Panel Lights OK?	y	
638782	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Panels Dusted?	y	
638783	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
638784	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	37.34	%
638785	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	19	
638786	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Operations Counter AF	123	
638787	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Operations Counter AL	123	
638788	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
638789	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
638790	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
638791	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
638792	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
638793	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
638794	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
638795	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
638796	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Amps B Ø	240.0	
638797	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Amps C Ø	250.0	
638798	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
638799	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
638800	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
638801	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
638802	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations A Ø	0	
638803	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations B Ø	0	
638804	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations C Ø	0	
638805	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations Ground	0	
638806	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Patrol Inspection	Follow-up Action Required?	n	
638807	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Follow-up Action Required?	n	
638808	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
638809	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	52	°C
638810	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB1336	BreakerVacuum	HB-Sec 1 Spare Vac Bkr	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
638811	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB1336	BreakerVacuum	HB-Sec 1 Spare Vac Bkr	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
638812	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB1336	BreakerVacuum	HB-Sec 1 Spare Vac Bkr	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
638813	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB1336	BreakerVacuum	HB-Sec 1 Spare Vac Bkr	VCB Readings	9 Month Operations	0	
638814	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
638815	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
638816	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
638817	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations Ground	0	
638818	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
638819	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
638820	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	38	°C
638821	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BCH000206	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	11.800	millivolts
638822	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BCH000206	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
638823	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Patrol Inspection	General Comments		
638824	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	General Comments		
638825	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Maintenance Operations	0	
638826	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Operations Counter AF	560	
638827	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Operations Counter AL	560	
638828	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Switching Operations	0	
638829	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Unknown Operations	0	
638830	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BCH000206	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
638831	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BCH000206	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
638832	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BCH000206	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
638833	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BCH000206	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
638834	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	52	°C
638835	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
638836	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
638837	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	PF000362	PowerFuse	TT-34KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
638838	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
638839	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	9 Month Operations	2	
638840	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	PF000361	PowerFuse	TT-34KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
638841	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	PF000361	PowerFuse	TT-34KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
638842	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
638843	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	PF000360	PowerFuse	TT-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
638844	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	PF000360	PowerFuse	TT-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
638845	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
638846	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
638847	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Amps A Ø	77.0	
638848	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Amps B Ø	61.0	
638849	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Amps C Ø	61.0	
638850	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Bushing Condition	Good	
638851	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
638852	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
638853	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
638854	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
638855	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Cabinet Paint Condition	Good	
638856	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Equipment Properly Labeled?	y	
638857	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
638858	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
638859	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
638860	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
638861	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Operations A Ø	0	
638862	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Operations B Ø	0	
638863	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Operations C Ø	0	
638864	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
638865	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Door Alarms OK?	y	
638866	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
638867	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
638868	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Evidence of Insects	None	
638869	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
638870	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
638871	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Follow-up Action Required?	n	
638872	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
638873	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	General Comments		
638874	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
638875	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Operations Ground	0	
638876	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Follow-up Action Required?	n	
638877	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Follow-up Action Required?	n	
638878	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Foundation Condition	Good	
638879	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	General Comments		
638880	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	General Comments		
638881	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Grounds in Place?	y	
638882	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Maintenance Operations	0	
638883	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Moisture and Leak Free?	y	
638884	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Operations Counter AF	198	
638885	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Operations Counter AL	199	
638886	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Switching Operations	1	
638887	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Tank Paint Condition	Good	
638888	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Unknown Operations	0	
638889	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Patrol Inspection	General Comments		
638890	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	General Comments	R&C	
638891	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Maintenance Operations	0	
638892	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
638893	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
638894	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
638895	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
638896	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
638897	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
638898	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
638899	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
638900	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Tank Leaks	None	
638901	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
638902	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
638903	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	2.41	%
638904	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	9.64	%
638905	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	9.64	%
638906	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
638907	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
638908	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Unknown Operations	0	
638909	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
638910	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X1 Winding Temp Max	74	°C
638911	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X1 Winding Temp Present	40	°C
638912	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X2 Winding Temp Max	90	°C
638913	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X2 Winding Temp Present	40	°C
638914	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X3 Winding Temp Max	70	°C
638915	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X3 Winding Temp Present	40	°C
638916	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	General Comments		
638917	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	General Comments		
638918	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
638919	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
638920	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Follow-up Action Required?	n	
638921	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
638922	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
638923	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	5	
638924	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
638925	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
638926	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Door Alarms OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
638927	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Unknown Operations	0	
638928	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Switching Operations	1	
638929	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Operations Counter AL	196	
638930	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Operations Counter AF	196	
638931	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Maintenance Operations	0	
638932	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	General Comments		
638933	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
638934	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
638935	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
638936	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
638937	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
638938	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Operations Counter AF	439	
638939	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Operations Counter AL	439	
638940	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	LTC Totalizer Reading	3571.20	kw
638941	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
638942	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
638943	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
638944	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
638945	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
638946	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
638947	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
638948	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Foundation Condition	Good	
638949	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
638950	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
638951	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	General Comments		
638952	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
638953	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
638954	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
638955	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
638956	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
638957	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Switching Operations	0	
638958	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Unknown Operations	0	
638959	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
638960	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Patrol Inspection	General Comments		
638961	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	General Comments		
638962	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Maintenance Operations	0	
638963	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Operations Counter AF	353	
638964	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Operations Counter AL	353	
638965	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Switching Operations	0	
638966	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
638967	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
638968	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	General Comments		
638969	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	General Comments		
638970	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
638971	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
638972	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
638973	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	Oil Temp Max	65	°C
638974	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	Oil Temp Present	40	°C
638975	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
638976	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	270.0	
638977	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	280.0	
638978	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	260.0	
638979	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
638980	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
638981	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	General Comments		
638982	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
638983	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
638984	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
638985	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
638986	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
638987	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	44	
638988	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	8.43	%
638989	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	43.36	%
638990	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	4.82	%
638991	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	General Comments		
638992	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
638993	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
638994	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
638995	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
638996	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
638997	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
638998	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
638999	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
639000	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
639001	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
639002	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	General Comments		
639003	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
639004	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
639005	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	23.10	%
639006	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	23.10	%
639007	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	23.10	%
639008	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	9	
639009	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
639010	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
639011	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
639012	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
639013	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
639014	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
639015	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
639016	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
639017	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Panels Dusted?	y	
639018	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	29	
639019	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
639020	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
639021	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
639022	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
639023	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
639024	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
639025	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Patrol Inspection	General Comments		
639026	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Follow-up Action Required?	n	
639027	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Patrol Inspection	Follow-up Action Required?	n	
639028	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Operations Ground	0	
639029	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Bushing Condition	Good	
639030	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	All Connections OK?	y	
639031	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Operations C Ø	0	
639032	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Operations B Ø	0	
639033	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Operations A Ø	0	
639034	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
639035	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
639036	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
639037	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Patrol Inspection	Equipment Properly Labeled?	y	
639038	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Amps C Ø	400.0	
639039	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	9 Months Operations	10	
639040	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Accumulated Fault Duty A Ph AM	22.89	%
639041	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Accumulated Fault Duty B Ph AM	20.48	%
639042	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Accumulated Fault Duty C Ph AM	15.66	%
639043	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Amps A Ø	200.0	
639044	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Amps B Ø	200.0	
639045	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Amps C Ø	200.0	
639046	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
639047	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
639048	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
639049	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
639050	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations A Ø	0	
639051	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Amps B Ø	420.0	
639052	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Amps A Ø	280.0	
639053	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations B Ø	0	
639054	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations C Ø	0	
639055	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations Ground	0	
639056	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Patrol Inspection	Follow-up Action Required?	n	
639057	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
639058	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
639059	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
639060	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Accumulated Fault Duty A Ph V	1.59	%
639061	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	9 Month Operations	1	
639062	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
639063	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Evidence of Insects	None	
639064	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
639065	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
639066	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Floor Swept?	y	
639067	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
639068	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	9 Month Operations	0	
639069	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Maintenance Operations	0	
639070	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Operations Counter AF	35	
639071	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
639072	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
639073	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
639074	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
639075	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
639076	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
639077	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
639078	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Operations Counter AL	35	
639079	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Switching Operations	0	
639080	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Unknown Operations	0	
639081	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
639082	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
639083	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	General Comments		
639084	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
639085	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC As Found Counter	20425	
639086	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
639087	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
639088	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
639089	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	444	
639090	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Min Tap Position	8L	
639091	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Max Tap Position	4R	
639092	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Current Tap Position	6L	
639093	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
639094	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC As Left Counter	74621	
639095	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC As Found Counter	74621	
639096	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
639097	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	General Comments		
639098	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
639099	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
639100	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
639101	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	2	
639102	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	323	
639103	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	323	
639104	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC As Left Counter	20535	
639105	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
639106	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC Current Tap Position	13L	
639107	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC Max Tap Position	9L	
639108	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC Min Tap Position	15L	
639109	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	177	
639110	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
639111	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
639112	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	General Comments		
639113	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	General Comments		
639114	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
639115	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
639116	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Follow-up Action Required?	n	
639117	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
639118	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
639119	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
639120	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
639121	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
639122	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
639123	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
639124	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
639125	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
639126	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
639127	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations Ground	0	
639128	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations C Ø	0	
639129	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
639130	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
639131	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
639132	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
639133	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations B Ø	0	
639134	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations A Ø	0	
639135	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
639136	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations Ground	0	
639137	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Patrol Inspection	Follow-up Action Required?	n	
639138	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Follow-up Action Required?	n	
639139	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Patrol Inspection	General Comments		
639140	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
639141	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	General Comments		
639142	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
639143	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
639144	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Patrol Inspection	Equipment Properly Labeled?	y	
639145	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Amps C Ø	475.0	
639146	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Amps B Ø	520.0	
639147	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Amps A Ø	480.0	
639148	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
639149	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
639150	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Broom on Site?	y	
639151	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
639152	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
639153	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Accumulated Fault Duty C Ph V	1.59	%
639154	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Accumulated Fault Duty B Ph V	.80	%
639155	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
639156	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations A Ø	0	
639157	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
639158	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	General Comments		
639159	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
639160	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
639161	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
639162	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Amps C Ø	52.0	
639163	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Amps B Ø	52.0	
639164	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Amps A Ø	52.0	
639165	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Accumulated Fault Duty C Ph V	.80	%
639166	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Accumulated Fault Duty B Ph V	.80	%
639167	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Accumulated Fault Duty A Ph V	.80	%
639168	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	9 Month Operations	0	
639169	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
639170	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Operations A Ø	0	
639171	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Operations B Ø	0	
639172	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Operations C Ø	0	
639173	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Operations Ground	0	
639174	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Follow-up Action Required?	n	
639175	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	General Comments	ok	
639176	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
639177	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
639178	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Foundation Condition	Good	
639179	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Follow-up Action Required?	n	
639180	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
639181	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
639182	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Condition	Good	
639183	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
639184	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
639185	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
639186	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
639187	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
639188	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Totalizer Meter Reading	.4960	
639189	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
639190	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
639191	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
639192	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
639193	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
639194	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
639195	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
639196	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
639197	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Oil Temp Present	25	°C
639198	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Maintenance Operations	0	
639199	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Oil Temp Max	65	°C
639200	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
639201	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
639202	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Accumulated Fault Duty A Ph V	5.69	%
639203	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
639204	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
639205	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Accumulated Fault Duty B Ph V	4.98	%
639206	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Accumulated Fault Duty C Ph V	4.98	%
639207	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Amps A Ø	100.0	
639208	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Amps B Ø	100.0	
639209	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
639210	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Fans Condition	Good	
639211	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Fans Operational?	y	
639212	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
639213	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	Follow-up Action Required?	n	
639214	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Amps C Ø	100.0	
639215	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
639216	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
639217	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
639218	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
639219	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	General Comments		
639220	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
639221	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
639222	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
639223	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
639224	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
639225	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
639226	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
639227	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
639228	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
639229	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Unknown Operations	0	
639230	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Switching Operations	0	
639231	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Operations Counter AL	230	
639232	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Operations Counter AF	230	
639233	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
639234	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
639235	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Grounds in Place?	y	
639236	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Maintenance Operations	0	
639237	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	General Comments		
639238	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Patrol Inspection	General Comments		
639239	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Follow-up Action Required?	n	
639240	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Patrol Inspection	Follow-up Action Required?	n	
639241	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations Ground	0	
639242	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations C Ø	0	
639243	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations B Ø	0	
639244	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
639245	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
639246	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Foundation Condition	Good	
639247	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
639248	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
639249	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
639250	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
639251	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
639252	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
639253	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
639254	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
639255	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
639256	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	VRR Time Delay	60	Seconds
639257	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
639258	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
639259	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
639260	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
639261	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
639262	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
639263	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
639264	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
639265	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
639266	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	LTC Operation Checked?	y	
639267	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	General Comments		
639268	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	Follow-up Action Required?	n	
639269	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	All Connections OK?	y	
639270	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
639271	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	9 Month Operations	5	
639272	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
639273	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Accumulated Fault Duty B Ph V	4.78	%
639274	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Accumulated Fault Duty C Ph V	.80	%
639275	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Amps A Ø	320.0	
639276	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Amps B Ø	260.0	
639277	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Amps C Ø	320.0	
639278	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Patrol Inspection	Equipment Properly Labeled?	y	
639279	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
639280	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
639281	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
639282	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Operations A Ø	0	
639283	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Operations B Ø	0	
639284	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Operations C Ø	0	
639285	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Operations Ground	0	
639286	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Patrol Inspection	Follow-up Action Required?	n	
639287	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Amps B Ø	490.0	
639288	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Tank Paint Condition	Good	
639289	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
639290	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
639291	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
639292	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Regulator As Left Counter	5256	
639293	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
639294	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
639295	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Moisture and Leak Free?	y	
639296	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Heaters (All) Functioning?	y	
639297	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
639298	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	38	°C
639299	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	38	°C
639300	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	38	°C
639301	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	38	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
639302	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	32	°C
639303	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Unknown Operations	0	
639304	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Switching Operations	4	
639305	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Operations Counter AL	178	
639306	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Operations Counter AF	178	
639307	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Maintenance Operations	0	
639308	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	General Comments		
639309	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Patrol Inspection	General Comments		
639310	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Follow-up Action Required?	n	
639311	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Patrol Inspection	Follow-up Action Required?	n	
639312	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Operations Ground	0	
639313	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Operations C Ø	0	
639314	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Operations B Ø	0	
639315	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Operations A Ø	0	
639316	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
639317	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
639318	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
639319	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
639320	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Tank Paint Condition	Good	
639321	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Switching Operations	1	
639322	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
639323	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	125	
639324	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	125	
639325	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
639326	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
639327	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Patrol Inspection	Equipment Properly Labeled?	y	
639328	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Amps C Ø	430.0	
639329	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
639330	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Grounds in Place?	y	
639331	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	General Comments		
639332	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
639333	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
639334	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
639335	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
639336	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
639337	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
639338	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
639339	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
639340	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
639341	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations	2	
639342	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
639343	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Maintenance Operations	0	
639344	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Operations Counter AF	1	
639345	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Operations Counter AL	1	
639346	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Max Tap Position	8R	
639347	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Switching Operations	0	
639348	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
639349	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
639350	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Unknown Operations	0	
639351	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
639352	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
639353	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	General Comments		
639354	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
639355	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	H2 Winding Temp Max	20	°C
639356	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	H2 Winding Temp Present	20	°C
639357	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
639358	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
639359	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Grounds in Place?	y	
639360	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	General Comments		
639361	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
639362	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
639363	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
639364	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
639365	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
639366	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
639367	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	256	
639368	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC Min Tap Position	14L	
639369	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6L	
639370	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
639371	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
639372	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC As Left Counter	26349	
639373	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC As Found Counter	26349	
639374	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
639375	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	General Comments		
639376	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Amps A Ø	400.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
639377	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Accumulated Fault Duty C Ph V	15.15	%
639378	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Accumulated Fault Duty B Ph V	7.17	%
639379	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Accumulated Fault Duty A Ph V	7.17	%
639380	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	9 Month Operations	33	
639381	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	32	°C
639382	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
639383	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
639384	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
639385	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
639386	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
639387	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
639388	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
639389	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Follow-up Action Required?	n	
639390	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Patrol Inspection	General Comments		
639391	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	General Comments		
639392	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Maintenance Operations	0	
639393	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
639394	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
639395	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
639396	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
639397	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	Oil Temp Present	25	°C
639398	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	Oil Temp Max	55	°C
639399	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1800	psi
639400	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Operations Counter AF	51	
639401	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Operations Counter AL	51	
639402	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Switching Operations	0	
639403	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Unknown Operations	0	
639404	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
639405	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
639406	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
639407	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
639408	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
639409	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
639410	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
639411	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
639412	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
639413	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Bushing Condition	Good	
639414	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
639415	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
639416	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
639417	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	830.0	
639418	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	850.0	
639419	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	900.0	
639420	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	General Comments		
639421	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Grounds in Place?	y	
639422	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
639423	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
639424	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
639425	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Tank Paint Condition	Good	
639426	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
639427	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
639428	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
639429	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Switching Operations	0	
639430	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Operations Counter AL	163	
639431	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
639432	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
639433	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
639434	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
639435	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
639436	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
639437	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
639438	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
639439	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
639440	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
639441	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
639442	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
639443	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
639444	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
639445	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Operations Counter AF	163	
639446	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Maintenance Operations	0	
639447	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	General Comments		
639448	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Patrol Inspection	General Comments		
639449	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Follow-up Action Required?	n	
639450	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Patrol Inspection	Follow-up Action Required?	n	
639451	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
639452	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Operations C Ø	0	
639453	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
639454	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
639455	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	150.0	
639456	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Operations B Ø	6	
639457	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Operations A Ø	0	
639458	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
639459	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Adjusted Amps B Phase V	67.08	
639460	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
639461	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
639462	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
639463	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Patrol Inspection	Equipment Properly Labeled?	y	
639464	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
639465	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
639466	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
639467	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
639468	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
639469	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
639470	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
639471	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Foundation Condition	Cracked	
639472	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
639473	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Trash Emptied?	y	
639474	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
639475	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	General Comments		
639476	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
639477	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
639478	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
639479	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
639480	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
639481	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
639482	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
639483	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
639484	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
639485	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Regulator As Left Counter	108316	
639486	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
639487	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
639488	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Tank Leaks	None	
639489	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
639490	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Bushing Condition	Good	
639491	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
639492	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
639493	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
639494	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
639495	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
639496	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
639497	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Follow-up Action Required?	n	
639498	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Foundation Condition	Good	
639499	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Follow-up Action Required?	n	
639500	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Patrol Inspection	General Comments		
639501	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	General Comments		
639502	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Maintenance Operations	0	
639503	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Unknown Operations	0	
639504	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Operations Counter AF	317	
639505	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Operations Counter AL	317	
639506	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Switching Operations	0	
639507	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Unknown Operations	0	
639508	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1519	
639509	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1519	
639510	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
639511	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
639512	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
639513	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
639514	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
639515	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
639516	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Tank Paint Condition	Good	
639517	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
639518	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Moisture and Leak Free?	y	
639519	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Heaters (All) Functioning?	y	
639520	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Grounds in Place?	y	
639521	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	General Comments		
639522	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Foundation Condition	Good	
639523	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Follow-up Action Required?	n	
639524	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Equipment Properly Labeled?	y	
639525	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Cabinet Paint Condition	Good	
639526	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
639527	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
639528	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
639529	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
639530	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
639531	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
639532	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
639533	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
639534	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
639535	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
639536	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
639537	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	General Comments		
639538	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Bushings Connection/Risers	Good	
639539	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Bushing Condition	Good	
639540	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
639541	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
639542	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
639543	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
639544	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
639545	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
639546	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
639547	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
639548	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
639549	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
639550	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
639551	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Tank Leaks	None	
639552	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Amps C Ø	450.0	
639553	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Amps B Ø	420.0	
639554	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Amps A Ø	480.0	
639555	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Accumulated Fault Duty C Ph V	3.19	%
639556	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
639557	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
639558	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Accumulated Fault Duty B Ph V	16.74	%
639559	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Accumulated Fault Duty A Ph V	7.97	%
639560	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	243	
639561	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	243	
639562	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
639563	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
639564	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	
639565	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	8.43	%
639566	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	12.05	%
639567	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	10.84	%
639568	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	9	
639569	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	9 Month Operations	12	
639570	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
639571	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
639572	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	330.0	
639573	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	330.0	
639574	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	320.0	
639575	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
639576	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
639577	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
639578	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
639579	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
639580	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
639581	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
639582	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
639583	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
639584	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
639585	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
639586	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
639587	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
639588	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
639589	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
639590	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
639591	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
639592	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
639593	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
639594	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
639595	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
639596	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
639597	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
639598	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
639599	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations C Ø	0	
639600	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
639601	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
639602	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
639603	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
639604	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
639605	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
639606	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
639607	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
639608	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
639609	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	General Comments		
639610	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
639611	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
639612	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
639613	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
639614	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
639615	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
639616	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Bushing Condition	Good	
639617	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations B Ø	0	
639618	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
639619	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations A Ø	0	
639620	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
639621	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
639622	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	Oil Temp Present	32	°C
639623	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
639624	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
639625	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
639626	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
639627	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
639628	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
639629	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LTCC000038	LTCControl	HB-TRANS 2	LTC Control Insp	All Connections OK?	y	
639630	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Vegetation	None	
639631	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
639632	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	Oil Temp Max	57	°C
639633	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
639634	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
639635	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
639636	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Cabinet Paint Condition	Good	
639637	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Equipment Properly Labeled?	y	
639638	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Follow-up Action Required?	n	
639639	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Foundation Condition	Good	
639640	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Vegetation	None	
639641	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
639642	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
639643	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
639644	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
639645	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
639646	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
639647	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations A Ø	0	
639648	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations B Ø	0	
639649	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations C Ø	0	
639650	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations Ground	0	
639651	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Patrol Inspection	Follow-up Action Required?	n	
639652	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
639653	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
639654	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
639655	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
639656	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
639657	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Follow-up Action Required?	n	
639658	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
639659	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
639660	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
639661	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
639662	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
639663	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Amps C Ø	522.0	
639664	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Amps B Ø	514.0	
639665	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Amps A Ø	499.0	
639666	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
639667	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	General Comments	barbwire and gate posts rusty. Briar limbs growing over one corner of the fence. Some tree limbs starting to grow over the top of the	
639668	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
639669	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
639670	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	General Comments		
639671	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
639672	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
639673	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	General Comments	SOME FENCE POST, FABRIC AND TOP RAIL GETTING RUST	
639674	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
639675	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
639676	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
639677	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
639678	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
639679	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
639680	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
639681	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
639682	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
639683	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
639684	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
639685	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
639686	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
639687	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
639688	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Operations Counter	1486	
639689	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
639690	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
639691	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
639692	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
639693	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
639694	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
639695	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LTCC000038	LTCControl	HB-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
639696	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LTCC000038	LTCControl	HB-TRANS 2	LTC Control Insp	General Comments		
639697	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LTCC000038	LTCControl	HB-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
639698	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
639699	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
639700	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	General Comments		
639701	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
639702	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
639703	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
639704	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
639705	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
639706	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
639707	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Tank Leaks	None	
639708	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
639709	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
639710	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
639711	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
639712	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
639713	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
639714	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
639715	1/9/2019 12:33	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
639716	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
639717	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	9 Months Operations	0	
639718	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Clear of Trash?	y	
639719	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
639720	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
639721	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
639722	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
639723	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
639724	1/9/2019 13:44	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
639725	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
639726	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	50.00	
639727	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
639728	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
639729	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
639730	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
639731	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
639732	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
639733	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
639734	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
639735	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
639736	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
639737	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
639738	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
639739	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Operations Counter AF	549	
639740	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
639741	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
639742	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
639743	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	General Comments		
639744	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
639745	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
639746	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
639747	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
639748	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
639749	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
639750	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
639751	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
639752	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
639753	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
639754	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
639755	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
639756	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Maintenance Operations	0	
639757	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	General Comments		
639758	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Patrol Inspection	General Comments		
639759	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Amps A Ø	22.0	
639760	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
639761	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LTCC000573	LTCControl	HB-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
639762	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
639763	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
639764	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LTCC000573	LTCControl	HB-TRANS 1	LTC Control Insp	General Comments		
639765	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
639766	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Amps B Ø	20.0	
639767	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
639768	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LTCC000573	LTCControl	HB-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
639769	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	9 Month Operations	1	
639770	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Unknown Operations	0	
639771	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Amps C Ø	26.0	
639772	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Switching Operations	0	
639773	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
639774	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
639775	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
639776	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
639777	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
639778	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Operations Counter AL	151	
639779	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
639780	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
639781	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Operations Counter AF	151	
639782	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Maintenance Operations	0	
639783	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	General Comments		
639784	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Patrol Inspection	General Comments		
639785	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Follow-up Action Required?	n	
639786	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Patrol Inspection	Follow-up Action Required?	n	
639787	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
639788	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
639789	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
639790	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Totalizer Meter Reading	.1060	
639791	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
639792	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
639793	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
639794	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
639795	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
639796	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
639797	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
639798	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	LTC Totalizer Reading	1017.60	kw
639799	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
639800	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Warning Signs OK?	y	
639801	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
639802	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
639803	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
639804	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Bushings Connection/Risers	Good	
639805	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
639806	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
639807	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
639808	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
639809	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
639810	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Oil Temp Max	22	°C
639811	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
639812	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
639813	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
639814	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	General Comments		
639815	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
639816	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Clear of Trash?	y	
639817	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
639818	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
639819	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	70	
639820	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
639821	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Oil Temp Present	9	°C
639822	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	70	
639823	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	3	
639824	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
639825	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
639826	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
639827	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Tank Leaks	None	
639828	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
639829	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
639830	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Operations Counter AL	549	
639831	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Switching Operations	0	
639832	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
639833	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
639834	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
639835	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
639836	1/9/2019 13:23	Distribution	Hurstbourne Quarterly Inspection	LTCC000573	LTCControl	HB-TRANS 1	LTC Control Insp	All Connections OK?	y	
639837	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
639838	1/4/2019 7:39	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Unknown Operations	0	
639839	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
639840	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
639841	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
639842	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	General Comments		
639843	1/9/2019 11:39	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
639844	1/9/2019 14:35	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
639845	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
639846	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
639847	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
639848	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
639849	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
639850	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
639851	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
639852	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
639853	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
639854	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	4L	
639855	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2R	
639856	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
639857	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
639858	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	4R	
639859	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	595872	
639860	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
639861	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
639862	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
639863	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
639864	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
639865	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
639866	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
639867	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
639868	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
639869	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
639870	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
639871	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	2L	
639872	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
639873	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
639874	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
639875	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
639876	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
639877	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
639878	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	13586	
639879	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	5R	
639880	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
639881	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
639882	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
639883	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
639884	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
639885	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
639886	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
639887	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2R	
639888	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
639889	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
639890	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
639891	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
639892	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
639893	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
639894	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
639895	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
639896	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
639897	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
639898	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
639899	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	4R	
639900	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
639901	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
639902	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	81699	
639903	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
639904	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
639905	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
639906	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	3L	
639907	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
639908	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
639909	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
639910	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1R	
639911	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
639912	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	34.0	
639913	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	50.0	
639914	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	61.0	
639915	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
639916	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
639917	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
639918	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
639919	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
639920	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments	ok	
639921	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
639922	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	518	
639923	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
639924	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
639925	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BCH000306	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
639926	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BCH000306	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
639927	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BCH000306	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
639928	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BCH000306	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
639929	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BCH000306	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
639930	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
639931	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	31.12	%
639932	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	31.12	%
639933	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	31.12	%
639934	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
639935	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
639936	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
639937	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	81.00	
639938	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	81.00	
639939	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	81.00	
639940	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
639941	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
639942	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
639943	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	3	
639944	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
639945	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	86	
639946	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	86	
639947	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
639948	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
639949	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
639950	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
639951	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
639952	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
639953	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
639954	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
639955	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	R&C	
639956	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	54	
639957	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
639958	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
639959	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
639960	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
639961	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
639962	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
639963	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
639964	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
639965	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
639966	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
639967	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
639968	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
639969	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
639970	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
639971	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
639972	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
639973	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	54	
639974	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
639975	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
639976	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
639977	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
639978	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
639979	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
639980	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
639981	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	237	
639982	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	237	
639983	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
639984	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	3.99	%
639985	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	3.99	%
639986	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	3.99	%
639987	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	5	
639988	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
639989	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
639990	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
639991	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
639992	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	50.0	
639993	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	50.0	
639994	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	50.0	
639995	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
639996	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
639997	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
639998	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
639999	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
640000	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
640001	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
640002	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	50.0	
640003	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	21	
640004	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
640005	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
640006	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
640007	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	21	
640008	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	50.0	
640009	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
640010	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	50.0	
640011	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
640012	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
640013	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
640014	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	19	
640015	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	15.95	%
640016	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	33.22	%
640017	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
640018	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
640019	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
640020	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
640021	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
640022	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	21.26	%
640023	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
640024	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
640025	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
640026	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	
640027	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	40	
640028	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
640029	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
640030	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
640031	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
640032	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	22.59	%
640033	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
640034	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
640035	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
640036	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
640037	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
640038	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	19.93	%
640039	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
640040	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	342	
640041	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
640042	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	342	
640043	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	100.0	
640044	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
640045	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
640046	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	30.56	%
640047	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
640048	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
640049	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
640050	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
640051	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
640052	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
640053	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	3.11	%
640054	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	1	
640055	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
640056	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	3.11	%
640057	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	3.11	%
640058	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	200.0	
640059	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	152	
640060	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
640061	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
640062	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
640063	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	152	
640064	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
640065	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	240.0	
640066	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	260.0	
640067	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	27.00	
640068	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	27.00	
640069	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
640070	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	27.00	
640071	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
640072	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
640073	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
640074	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
640075	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	429	
640076	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	429	
640077	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
640078	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	8	
640079	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	89.44	
640080	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	89.44	
640081	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	89.44	
640082	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
640083	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	50.0	
640084	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
640085	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
640086	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	50.0	
640087	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	50.0	
640088	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
640089	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	24.09	%
640090	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	27.70	%
640091	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
640092	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	25	
640093	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	22.89	%
640094	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
640095	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
640096	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
640097	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
640098	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
640099	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	100.0	
640100	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	12	
640101	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
640102	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99	
640103	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99	
640104	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
640105	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
640106	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
640107	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	53	
640108	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	36.14	%
640109	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	33.73	%
640110	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	20.48	%
640111	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	
640112	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
640113	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	134.16	
640114	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	134.16	
640115	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	134.16	
640116	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
640117	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
640118	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
640119	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
640120	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
640121	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
640122	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	1	
640123	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
640124	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	345	
640125	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	345	
640126	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
640127	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
640128	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
640129	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
640130	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
640131	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	6	
640132	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
640133	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	7.23	%
640134	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
640135	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
640136	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
640137	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
640138	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	9.64	%
640139	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	3.61	%
640140	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	50.0	
640141	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	50.0	
640142	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	50.0	
640143	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
640144	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
640145	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
640146	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	50.0	
640147	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
640148	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	1.20	%
640149	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
640150	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
640151	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
640152	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
640153	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	50.0	
640154	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
640155	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
640156	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	181	
640157	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	181	
640158	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
640159	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
640160	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	50.0	
640161	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
640162	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
640163	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
640164	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
640165	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
640166	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
640167	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
640168	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
640169	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
640170	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
640171	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
640172	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
640173	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
640174	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	2.60	%
640175	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	203	
640176	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
640177	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
640178	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
640179	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	2.60	%
640180	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
640181	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	2.60	%
640182	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	260.0	
640183	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	250.0	
640184	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	250.0	
640185	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	27.00	
640186	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	27.00	
640187	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
640188	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	27.00	
640189	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	1	
640190	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	203	
640191	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
640192	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
640193	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
640194	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LTCC000116	LTCControl	SSC-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
640195	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LTCC000116	LTCControl	SSC-Offline-Distribution	LTC Control Insp	General Comments		
640196	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LTCC000116	LTCControl	SSC-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
640197	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LTCC000116	LTCControl	SSC-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
640198	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
640199	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
640200	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
640201	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
640202	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
640203	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
640204	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
640205	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
640206	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
640207	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
640208	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
640209	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
640210	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
640211	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LTCC000117	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
640212	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LTCC000117	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
640213	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LTCC000117	LTCControl	Retired Distribution	LTC Control Insp	General Comments	OK	
640214	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	4	
640215	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	18.6	
640216	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	21.4	
640217	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
640218	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
640219	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
640220	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
640221	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
640222	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
640223	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
640224	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	24	
640225	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
640226	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	19.8	
640227	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
640228	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	3	
640229	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Ambient Temp	66	°F
640230	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
640231	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	8.3	VDC
640232	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
640233	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
640234	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	10.0	VDC
640235	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
640236	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
640237	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
640238	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	General Comments		
640239	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	60	°C
640240	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	General Comments	ok	
640241	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
640242	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
640243	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
640244	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	General Comments		
640245	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
640246	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
640247	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	General Comments	low oil	
640248	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
640249	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
640250	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
640251	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
640252	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
640253	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
640254	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	General Comments		
640255	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
640256	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Panels Dusted?	y	
640257	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
640258	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
640259	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
640260	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
640261	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
640262	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Operations Counter	217	
640263	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
640264	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	General Comments		
640265	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Foundation Condition	Good	
640266	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
640267	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Follow-up Action Required?	n	
640268	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Follow-up Action Required?	n	
640269	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Operations Ground	0	
640270	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Operations C Ø	0	
640271	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Operations B Ø	0	
640272	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Operations A Ø	0	
640273	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
640274	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
640275	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	General Comments	ok	
640276	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
640277	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
640278	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
640279	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Equipment Properly Labeled?	y	
640280	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Operations Counter	151	
640281	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Follow-up Action Required?	n	
640282	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
640283	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
640284	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Positive DC Ground	55.0	VDC
640285	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Negative DC Ground	53.0	VDC
640286	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	General Comments	ok	
640287	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Patrol Inspection	General Comments	ok	
640288	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
640289	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Operations Counter AF	198	
640290	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Operations Counter AL	198	
640291	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Grounds in Place?	y	
640292	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	General Comments		
640293	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
640294	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Switching Operations	0	
640295	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Tank Paint Condition	Good	
640296	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
640297	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
640298	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
640299	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
640300	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
640301	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
640302	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
640303	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
640304	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
640305	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
640306	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Clear of Trash?	y	
640307	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
640308	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
640309	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
640310	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
640311	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
640312	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
640313	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
640314	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
640315	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	General Comments		
640316	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Grounds in Place?	y	
640317	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Heaters (All) Functioning?	y	
640318	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
640319	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Operations Counter	291	
640320	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Maintenance Operations	1	
640321	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
640322	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
640323	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
640324	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
640325	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	BAT000391	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
640326	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	BAT000391	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.1	VDC
640327	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	BAT000391	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.3	VDC
640328	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	BAT000391	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
640329	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
640330	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
640331	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
640332	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
640333	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
640334	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
640335	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
640336	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
640337	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
640338	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
640339	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
640340	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
640341	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Amps A Ø	6.0	
640342	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
640343	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
640344	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
640345	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
640346	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
640347	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
640348	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
640349	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
640350	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Unknown Operations	0	
640351	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
640352	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
640353	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
640354	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
640355	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Switching Operations	0	
640356	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
640357	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Operations Counter AL	256	
640358	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Operations Counter AF	256	
640359	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Moisture and Leak Free?	y	
640360	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	General Comments	ok	
640361	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
640362	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
640363	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
640364	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
640365	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
640366	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
640367	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
640368	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
640369	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
640370	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
640371	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
640372	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
640373	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
640374	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
640375	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
640376	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
640377	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
640378	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
640379	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
640380	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	Oil Temp Present	37	°C
640381	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
640382	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Tank Leaks	None	
640383	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
640384	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
640385	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
640386	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	9 Month Operations	1	
640387	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
640388	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
640389	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
640390	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Regulator As Left Counter	53476	
640391	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
640392	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	9 Month Operations	12	
640393	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
640394	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
640395	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Accumulated Fault Duty B Ph V	1.35	%
640396	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
640397	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
640398	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Amps A Ø	529.0	
640399	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Amps B Ø	599.0	
640400	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Amps C Ø	508.0	
640401	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Bushing Condition	Good	
640402	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Tank Leaks	None	
640403	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
640404	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Panels Dusted?	y	
640405	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
640406	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
640407	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	General Comments		
640408	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
640409	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
640410	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
640411	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
640412	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Floor Swept?	y	
640413	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
640414	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Amps A Ø	120.0	
640415	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
640416	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
640417	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
640418	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
640419	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
640420	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	General Comments	ok	
640421	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Amps B Ø	120.0	
640422	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Amps C Ø	120.0	
640423	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Bushing Condition	Good	
640424	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Bushings Connection/Risers	Good	
640425	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
640426	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Evidence of Insects	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
640427	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
640428	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Maintenance Operations	0	
640429	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
640430	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
640431	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	General Comments	ok	
640432	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	General Comments	ok	
640433	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
640434	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
640435	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
640436	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
640437	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
640438	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
640439	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
640440	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
640441	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
640442	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
640443	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
640444	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
640445	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
640446	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
640447	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Accumulated Fault Duty C Ph V	10.00	%
640448	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Accumulated Fault Duty B Ph V	11.82	%
640449	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Accumulated Fault Duty A Ph V	6.37	%
640450	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	9 Month Operations	9	
640451	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
640452	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
640453	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
640454	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Trash Emptied?	y	
640455	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
640456	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
640457	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	General Comments		
640458	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
640459	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
640460	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
640461	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	General Comments	low oil	
640462	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
640463	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
640464	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
640465	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
640466	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
640467	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
640468	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Floor Swept?	y	
640469	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
640470	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
640471	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
640472	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
640473	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
640474	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Clear of Trash?	y	
640475	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
640476	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
640477	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
640478	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Evidence of Insects	None	
640479	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
640480	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
640481	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
640482	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
640483	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
640484	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
640485	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
640486	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
640487	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
640488	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
640489	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
640490	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	General Comments	ok	
640491	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Unknown Operations	0	
640492	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
640493	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
640494	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Cabinet Paint Condition	Good	
640495	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Switching Operations	0	
640496	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Operations Counter AL	260	
640497	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Operations Counter AF	260	
640498	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
640499	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
640500	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
640501	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
640502	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
640503	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
640504	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
640505	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
640506	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
640507	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
640508	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
640509	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
640510	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
640511	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
640512	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Moisture and Leak Free?	y	
640513	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Operations Counter AF	342	
640514	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
640515	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Operations Counter AL	346	
640516	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
640517	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Switching Operations	4	
640518	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
640519	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
640520	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	360.0	
640521	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
640522	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
640523	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Tank Leaks	None	
640524	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
640525	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
640526	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Equipment Properly Labeled?	y	
640527	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Cabinet Paint Condition	Good	
640528	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
640529	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	420.0	
640530	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	400.0	
640531	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
640532	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
640533	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
640534	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
640535	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
640536	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Tank Leaks	None	
640537	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
640538	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Operations Counter	2333	
640539	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
640540	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
640541	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	General Comments		
640542	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
640543	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
640544	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
640545	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
640546	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
640547	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
640548	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	7.23	%
640549	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Bushings Connection/Risers	Good	
640550	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Accumulated Fault Duty B Ph V	9.53	%
640551	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Accumulated Fault Duty C Ph V	6.80	%
640552	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
640553	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
640554	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
640555	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
640556	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Amps A Ø	60.0	
640557	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Amps B Ø	80.0	
640558	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Amps C Ø	65.0	
640559	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Bushing Condition	Good	
640560	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
640561	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Bushings Connection/Risers	Good	
640562	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
640563	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Amps C Ø	5.0	
640564	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Amps B Ø	6.0	
640565	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Amps A Ø	4.0	
640566	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
640567	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	General Comments	ok	
640568	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Bushing Condition	Good	
640569	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Amps C Ø	50.0	
640570	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
640571	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
640572	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
640573	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Unknown Operations	0	
640574	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
640575	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
640576	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
640577	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Amps A Ø	50.0	
640578	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
640579	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Accumulated Fault Duty C Ph V	6.83	%
640580	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
640581	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Amps A Ø	52.0	
640582	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
640583	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Amps B Ø	32.0	
640584	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
640585	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Oil Temp Present	40	°C
640586	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
640587	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
640588	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
640589	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Amps C Ø	41.0	
640590	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Accumulated Fault Duty B Ph V	6.83	%
640591	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
640592	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
640593	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Accumulated Fault Duty A Ph V	7.32	%
640594	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	9 Month Operations	2	
640595	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Grounds in Place?	y	
640596	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Heaters (All) Functioning?	y	
640597	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Maintenance Operations	0	
640598	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
640599	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
640600	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
640601	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
640602	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
640603	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
640604	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
640605	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	General Comments		
640606	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
640607	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Operations Counter	483	
640608	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
640609	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
640610	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Amps A Ø	13.5	
640611	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Amps B Ø	13.4	
640612	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Amps C Ø	7.7	
640613	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
640614	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
640615	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	20.79	%
640616	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
640617	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
640618	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
640619	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	General Comments	ok	
640620	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
640621	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	General Comments	37	
640622	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	General Comments		
640623	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
640624	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
640625	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
640626	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
640627	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
640628	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
640629	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
640630	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Amps C Ø	28.0	
640631	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	General Comments	ok	
640632	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Amps B Ø	31.0	
640633	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Amps A Ø	30.0	
640634	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
640635	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
640636	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
640637	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
640638	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
640639	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
640640	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	804	
640641	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Operations A Ø	0	
640642	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
640643	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
640644	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
640645	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC Operations Since Last Insp	239	
640646	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
640647	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC Min Tap Position	1L	
640648	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
640649	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Foundation Condition	Good	
640650	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC Current Tap Position	12L	
640651	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
640652	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	17.82	%
640653	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	16.34	%
640654	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	30.0	
640655	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	30.0	
640656	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
640657	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
640658	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
640659	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
640660	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	30.0	
640661	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
640662	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
640663	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Equipment Properly Labeled?	y	
640664	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
640665	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
640666	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
640667	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
640668	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
640669	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
640670	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
640671	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
640672	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
640673	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
640674	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
640675	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	1217	
640676	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
640677	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	General Comments	didn't have amp meter	
640678	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
640679	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
640680	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
640681	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
640682	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
640683	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
640684	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
640685	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
640686	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
640687	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	42	
640688	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Amps B Ø	60.0	
640689	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Amps A Ø	100.0	
640690	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Operations Counter	778	
640691	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
640692	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
640693	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	867	
640694	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
640695	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Accumulated Fault Duty C Ph V	7.17	%
640696	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Accumulated Fault Duty B Ph V	9.07	%
640697	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Accumulated Fault Duty A Ph V	7.17	%
640698	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	9 Month Operations	2	
640699	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
640700	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
640701	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
640702	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
640703	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
640704	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
640705	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
640706	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
640707	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Vegetation	None	
640708	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
640709	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
640710	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
640711	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
640712	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
640713	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	General Comments		
640714	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
640715	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	300.0	
640716	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
640717	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
640718	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Cabinet Paint Condition	Good	
640719	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	24.09	%
640720	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	24.09	%
640721	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
640722	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
640723	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	33	
640724	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
640725	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
640726	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Operations Counter	398	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
640727	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
640728	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
640729	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
640730	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
640731	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
640732	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Tank Paint Condition	Good	
640733	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Unknown Operations	0	
640734	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
640735	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	General Comments		
640736	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
640737	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Operations Counter	197	
640738	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
640739	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
640740	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
640741	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
640742	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	General Comments		
640743	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
640744	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
640745	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
640746	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
640747	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LTCC000433	LTCControl	HC-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
640748	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
640749	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Operations Counter	3	
640750	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
640751	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Tank Leaks	None	
640752	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
640753	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
640754	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
640755	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
640756	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
640757	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
640758	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
640759	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
640760	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
640761	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
640762	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
640763	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
640764	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Min Tap Position	13L	
640765	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
640766	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
640767	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
640768	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
640769	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
640770	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
640771	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Regulator As Left Counter	32740	
640772	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	9 Month Operations	3	
640773	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
640774	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Amps A Ø	90.0	
640775	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Amps B Ø	80.0	
640776	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Amps C Ø	90.0	
640777	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Bushing Condition	Good	
640778	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
640779	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
640780	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Bushings Connection/Risers	Good	
640781	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
640782	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
640783	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
640784	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
640785	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
640786	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Tank Leaks	None	
640787	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
640788	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
640789	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
640790	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
640791	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Cabinet Paint Condition	Good	
640792	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Equipment Properly Labeled?	y	
640793	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
640794	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
640795	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
640796	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
640797	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
640798	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
640799	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
640800	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	General Comments		
640801	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
640802	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
640803	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Operations B Ø	0	
640804	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
640805	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Operations C Ø	0	
640806	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	BAT000391	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
640807	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Patrol Inspection	Follow-up Action Required?	n	
640808	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Operations Ground	0	
640809	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Operations C Ø	0	
640810	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Operations B Ø	0	
640811	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Operations A Ø	0	
640812	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
640813	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
640814	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
640815	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
640816	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Amps C Ø	100.0	
640817	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Amps B Ø	75.0	
640818	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
640819	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Amps A Ø	100.0	
640820	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
640821	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Accumulated Fault Duty C Ph AM	11.96	%
640822	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Accumulated Fault Duty B Ph AM	15.95	%
640823	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Accumulated Fault Duty A Ph AM	10.63	%
640824	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
640825	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
640826	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
640827	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
640828	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
640829	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
640830	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
640831	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	General Comments	OK	
640832	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
640833	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
640834	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	BAT000391	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
640835	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
640836	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
640837	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
640838	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
640839	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
640840	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
640841	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
640842	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
640843	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
640844	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
640845	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
640846	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
640847	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	BAT000391	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
640848	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	BAT000391	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
640849	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
640850	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
640851	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	General Comments		
640852	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Foundation Condition	Good	
640853	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Follow-up Action Required?	n	
640854	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Follow-up Action Required?	n	
640855	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Operations Ground	0	
640856	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Operations C Ø	0	
640857	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Operations B Ø	0	
640858	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Operations A Ø	0	
640859	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
640860	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
640861	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
640862	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LTCC000433	LTCControl	HC-TRANS 2	LTC Control Insp	All Connections OK?	y	
640863	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LTCC000433	LTCControl	HC-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
640864	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LTCC000433	LTCControl	HC-TRANS 2	LTC Control Insp	General Comments	ok	
640865	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Foundation Condition	Good	
640866	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Follow-up Action Required?	n	
640867	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Follow-up Action Required?	n	
640868	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Operations Ground	0	
640869	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Operations C Ø	0	
640870	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
640871	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
640872	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Operations B Ø	0	
640873	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Operations A Ø	0	
640874	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
640875	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
640876	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
640877	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
640878	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
640879	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
640880	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
640881	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
640882	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
640883	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
640884	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
640885	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
640886	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	1	
640887	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
640888	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
640889	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
640890	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
640891	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
640892	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Accumulated Fault Duty A Ph V	12.70	%
640893	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Oil Temp Max	50	°C
640894	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
640895	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
640896	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
640897	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Totalizer Meter Reading	.9018	
640898	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
640899	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
640900	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Equipment Properly Labeled?	y	
640901	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	300	
640902	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
640903	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
640904	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
640905	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
640906	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
640907	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
640908	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
640909	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
640910	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
640911	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
640912	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
640913	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
640914	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
640915	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
640916	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Cabinet Paint Condition	Good	
640917	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
640918	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
640919	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
640920	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Bushings Connection/Risers	Good	
640921	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Bushing Condition	Good	
640922	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Amps C Ø	100.0	
640923	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Amps B Ø	100.0	
640924	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	BAT000391	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
640925	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
640926	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	270.54	kw
640927	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
640928	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
640929	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Regulator As Left Counter	58633	
640930	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
640931	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
640932	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	BAT000391	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
640933	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	BAT000391	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	64	°F
640934	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Amps A Ø	30.0	
640935	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Amps B Ø	60.0	
640936	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Amps C Ø	30.0	
640937	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Tank Leaks	None	
640938	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
640939	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	Oil Temp Present	36	°C
640940	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
640941	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
640942	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	BAT000391	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
640943	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Operations Ground	0	
640944	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
640945	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
640946	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
640947	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Tank Leaks	None	
640948	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
640949	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Follow-up Action Required?	n	
640950	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Follow-up Action Required?	n	
640951	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
640952	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	General Comments		
640953	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	General Comments		
640954	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	Oil Temp Max	37	°C
640955	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Unknown Operations	0	
640956	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Tank Paint Condition	Good	
640957	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Switching Operations	0	
640958	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
640959	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Operations Counter AL	226	
640960	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Operations Counter AF	226	
640961	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
640962	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Moisture and Leak Free?	y	
640963	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Maintenance Operations	0	
640964	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
640965	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Heaters (All) Functioning?	y	
640966	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Grounds in Place?	y	
640967	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	General Comments	ok	
640968	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
640969	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
640970	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
640971	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
640972	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
640973	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
640974	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	694	
640975	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	694	
640976	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
640977	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
640978	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
640979	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
640980	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
640981	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
640982	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	General Comments	ok	
640983	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
640984	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Accumulated Fault Duty A Ph V	0	%
640985	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Accumulated Fault Duty B Ph V	2.38	%
640986	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Accumulated Fault Duty C Ph V	.79	%
640987	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
640988	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
640989	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	General Comments		
640990	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
640991	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
640992	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
640993	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
640994	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
640995	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
640996	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
640997	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	General Comments		
640998	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
640999	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
641000	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
641001	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Oil Temp Present	30	°C
641002	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Oil Temp Max	35	°C
641003	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
641004	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
641005	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	LTC Totalizer Reading	7629.12	kw
641006	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
641007	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	General Comments		
641008	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	General Comments		
641009	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
641010	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
641011	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Follow-up Action Required?	n	
641012	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
641013	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
641014	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
641015	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
641016	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
641017	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
641018	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
641019	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	Follow-up Action Required?	n	
641020	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
641021	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	General Comments		
641022	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
641023	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	General Comments		
641024	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC As Found Counter	48191	
641025	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC As Left Counter	48197	
641026	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
641027	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
641028	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
641029	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
641030	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
641031	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
641032	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
641033	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
641034	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
641035	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
641036	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
641037	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
641038	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
641039	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
641040	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
641041	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
641042	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
641043	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
641044	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
641045	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
641046	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	ok	
641047	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
641048	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
641049	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Amps A Ø	20	
641050	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
641051	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Amps B Ø	20	
641052	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
641053	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
641054	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
641055	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
641056	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Unknown Operations	0	
641057	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Tank Paint Condition	Good	
641058	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Amps C Ø	25	
641059	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BAT000317	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
641060	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BAT000317	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
641061	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BAT000317	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	10.3	VDC
641062	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BAT000317	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	11.6	VDC
641063	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Totalizer Meter Reading	.5298	
641064	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
641065	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
641066	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
641067	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
641068	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
641069	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
641070	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Tank Leaks	None	
641071	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
641072	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
641073	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Regulator As Left Counter	59563	
641074	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
641075	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
641076	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
641077	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
641078	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
641079	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
641080	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
641081	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
641082	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
641083	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
641084	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
641085	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
641086	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
641087	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	General Comments	ok	
641088	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
641089	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
641090	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
641091	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
641092	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC Operations Since Last Insp	467	
641093	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
641094	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC Min Tap Position	8L	
641095	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC Max Tap Position	3R	
641096	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC Current Tap Position	5L	
641097	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
641098	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC As Left Counter	149324	
641099	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
641100	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
641101	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Current Tap Position	9L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
641102	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
641103	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
641104	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
641105	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC Min Tap Position	15L	
641106	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
641107	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	560	
641108	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
641109	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
641110	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
641111	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
641112	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	9 Month Operations	6	
641113	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
641114	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
641115	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Clear of Trash?	y	
641116	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
641117	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
641118	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
641119	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
641120	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
641121	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
641122	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
641123	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
641124	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
641125	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
641126	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
641127	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	General Comments	ok	
641128	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
641129	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
641130	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.600	millivolts
641131	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	As Found Float Voltage	54.7	VDC
641132	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	As Left Float Voltage	54.7	VDC
641133	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Unknown Operations	0	
641134	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	Follow-up Action Required?	n	
641135	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
641136	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	General Comments		
641137	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	General Comments		
641138	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC As Found Counter	149324	
641139	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
641140	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
641141	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	Follow-up Action Required?	n	
641142	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	General Comments	ok	
641143	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
641144	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	BAT001278	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
641145	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	BAT001278	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
641146	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	BAT001278	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
641147	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	BAT001278	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
641148	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	BAT001278	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
641149	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	BAT001278	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
641150	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	BAT001278	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
641151	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3R	
641152	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC Current Tap Position	13L	
641153	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
641154	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC As Left Counter	88060	
641155	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC As Found Counter	88060	
641156	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	ok	
641157	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	General Comments	ok	
641158	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
641159	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
641160	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	Follow-up Action Required?	n	
641161	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
641162	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	General Comments		
641163	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	General Comments		
641164	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC As Found Counter	2831	
641165	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Oil Temp Present	35	°C
641166	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
641167	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
641168	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
641169	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
641170	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Totalizer Meter Reading	.6610	
641171	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
641172	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Tank Leaks	None	
641173	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
641174	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
641175	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Regulator As Left Counter	84963	
641176	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
641177	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
641178	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
641179	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
641180	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
641181	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
641182	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
641183	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
641184	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
641185	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	268	
641186	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
641187	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
641188	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
641189	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
641190	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Trash Emptied?	y	
641191	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
641192	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
641193	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
641194	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
641195	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
641196	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
641197	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
641198	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
641199	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
641200	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
641201	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
641202	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
641203	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
641204	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
641205	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
641206	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
641207	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
641208	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
641209	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	163	
641210	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
641211	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
641212	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
641213	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	General Comments	Didn't have amp meter	
641214	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Clear of Trash?	y	
641215	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
641216	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
641217	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
641218	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
641219	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
641220	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
641221	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
641222	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
641223	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
641224	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	General Comments		
641225	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BAT000317	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
641226	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BAT000317	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
641227	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
641228	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
641229	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
641230	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Operations Counter	942	
641231	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
641232	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BAT000317	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
641233	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BAT000317	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
641234	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BAT000317	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
641235	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
641236	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	General Comments		
641237	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BAT000317	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
641238	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BAT000317	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
641239	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC Min Tap Position	3L	
641240	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BAT000317	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
641241	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BAT000317	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
641242	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BAT000317	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
641243	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
641244	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Switching Operations	0	
641245	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
641246	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
641247	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
641248	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Operations Counter AL	266	
641249	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Operations Counter AF	266	
641250	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
641251	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
641252	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	General Comments		
641253	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
641254	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
641255	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
641256	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
641257	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC Operations Since Last Insp	145	
641258	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Moisture and Leak Free?	y	
641259	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Maintenance Operations	1	
641260	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Heaters (All) Functioning?	y	
641261	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Grounds in Place?	y	
641262	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	General Comments		
641263	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	General Comments		
641264	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Foundation Condition	Good	
641265	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	BAT001278	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
641266	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Oil Temp Max	36	°C
641267	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Bushings Connection/Risers	Good	
641268	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
641269	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	117.50	
641270	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Bushing Condition	Good	
641271	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
641272	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
641273	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
641274	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	General Comments		
641275	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
641276	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
641277	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
641278	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
641279	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
641280	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	793.20	kw
641281	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
641282	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
641283	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
641284	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
641285	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Vegetation	None	
641286	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
641287	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
641288	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	General Comments		
641289	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	General Comments		
641290	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
641291	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
641292	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
641293	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
641294	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
641295	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
641296	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
641297	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
641298	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
641299	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
641300	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
641301	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Operations B Ø	0	
641302	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Operations C Ø	0	
641303	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Operations Ground	0	
641304	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Follow-up Action Required?	n	
641305	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Follow-up Action Required?	n	
641306	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Equipment Properly Labeled?	y	
641307	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
641308	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
641309	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
641310	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Amps B Ø	70.0	
641311	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Amps A Ø	120.0	
641312	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
641313	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Operations A Ø	0	
641314	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Operations B Ø	0	
641315	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Operations C Ø	0	
641316	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Operations Ground	0	
641317	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Follow-up Action Required?	n	
641318	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Follow-up Action Required?	n	
641319	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
641320	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Accumulated Fault Duty C Ph V	1.31	%
641321	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
641322	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
641323	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Panels Dusted?	y	
641324	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Accumulated Fault Duty B Ph V	1.31	%
641325	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Accumulated Fault Duty A Ph V	1.31	%
641326	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	9 Month Operations	2	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
641327	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Patrol Inspection	Follow-up Action Required?	n	
641328	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Operations Ground	0	
641329	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
641330	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
641331	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	General Comments	ok	
641332	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
641333	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
641334	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Floor Swept?	y	
641335	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
641336	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
641337	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Operations C Ø	0	
641338	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
641339	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
641340	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
641341	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Unknown Operations	0	
641342	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
641343	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Foundation Condition	Good	
641344	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	General Comments	ok	
641345	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Foundation Condition	Good	
641346	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
641347	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
641348	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
641349	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
641350	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
641351	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	General Comments	ok	
641352	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Grounds in Place?	y	
641353	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Switching Operations	1	
641354	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
641355	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Operations Counter AL	168	
641356	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Operations Counter AF	167	
641357	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
641358	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	106	
641359	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	106	
641360	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
641361	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	1	
641362	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Maintenance Operations	0	
641363	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
641364	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Operations B Ø	0	
641365	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Operations A Ø	0	
641366	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
641367	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	9 Month Operations	32	
641368	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Accumulated Fault Duty A Ph V	1.70	%
641369	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Accumulated Fault Duty B Ph V	2.37	%
641370	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Accumulated Fault Duty C Ph V	2.15	%
641371	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Bushing Condition	Good	
641372	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Bushings Connection/Risers	Good	
641373	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
641374	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
641375	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
641376	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Amps C Ø	200.0	
641377	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Amps B Ø	200.0	
641378	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Amps A Ø	200.0	
641379	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Accumulated Fault Duty C Ph AM	31.89	%
641380	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
641381	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
641382	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	General Comments		
641383	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
641384	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Accumulated Fault Duty B Ph AM	27.91	%
641385	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Accumulated Fault Duty A Ph AM	34.55	%
641386	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
641387	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	General Comments		
641388	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
641389	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
641390	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
641391	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
641392	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
641393	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
641394	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
641395	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
641396	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Regulator As Left Counter	40709	
641397	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
641398	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	General Comments	ok	
641399	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Tank Leaks	None	
641400	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
641401	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
641402	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
641403	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
641404	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
641405	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
641406	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
641407	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
641408	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
641409	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
641410	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
641411	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
641412	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
641413	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
641414	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
641415	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
641416	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
641417	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
641418	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
641419	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
641420	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
641421	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
641422	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Clear of Trash?	y	
641423	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
641424	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
641425	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
641426	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Cabinet Paint Condition	Good	
641427	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Amps C Ø	100.0	
641428	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
641429	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Bushing Condition	Good	
641430	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Bushings Connection/Risers	Good	
641431	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
641432	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
641433	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
641434	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	BCH001222	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.400	millivolts
641435	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
641436	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
641437	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
641438	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Follow-up Action Required?	n	
641439	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Patrol Inspection	General Comments	ok	
641440	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	General Comments	ok	
641441	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Maintenance Operations	0	
641442	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Operations Counter AF	65700	
641443	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
641444	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
641445	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
641446	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
641447	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Vegetation	None	
641448	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
641449	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	58	°F
641450	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
641451	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
641452	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
641453	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	BCH001222	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
641454	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	BCH001222	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
641455	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	BCH001222	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
641456	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	BCH001222	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
641457	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	BCH001222	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
641458	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Operations Counter AL	65700	
641459	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Switching Operations	0	
641460	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Unknown Operations	0	
641461	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
641462	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
641463	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
641464	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
641465	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
641466	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Vegetation	None	
641467	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
641468	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
641469	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
641470	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
641471	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
641472	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
641473	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
641474	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
641475	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
641476	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Min Tap Position	12L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
641477	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
641478	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
641479	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
641480	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
641481	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	General Comments	ok	
641482	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
641483	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
641484	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	ok	
641485	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments	ok	
641486	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
641487	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
641488	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
641489	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
641490	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	General Comments	ok	
641491	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
641492	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
641493	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
641494	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
641495	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
641496	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
641497	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
641498	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
641499	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
641500	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
641501	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
641502	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
641503	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
641504	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
641505	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
641506	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
641507	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Winding Temp Max	40	°C
641508	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Winding Temp Present	40	°C
641509	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
641510	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
641511	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
641512	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
641513	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
641514	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
641515	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
641516	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
641517	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
641518	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
641519	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
641520	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
641521	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Tank Paint Condition	Good	
641522	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Switching Operations	0	
641523	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
641524	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
641525	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
641526	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
641527	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
641528	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
641529	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
641530	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
641531	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
641532	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
641533	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
641534	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
641535	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
641536	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
641537	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
641538	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
641539	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
641540	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
641541	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
641542	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
641543	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
641544	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
641545	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
641546	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
641547	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
641548	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	9 Months Operations	4	
641549	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
641550	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
641551	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
641552	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
641553	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Tank Leaks	None	
641554	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
641555	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Equipment Properly Labeled?	y	
641556	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
641557	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
641558	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
641559	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Operations A Ø	0	
641560	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Operations B Ø	0	
641561	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Operations C Ø	0	
641562	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Operations Ground	0	
641563	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
641564	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Follow-up Action Required?	n	
641565	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Follow-up Action Required?	n	
641566	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Foundation Condition	Good	
641567	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	General Comments		
641568	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Regulator As Left Counter	158751	
641569	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	General Comments		
641570	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Grounds in Place?	y	
641571	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Heaters (All) Functioning?	y	
641572	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Maintenance Operations	0	
641573	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Moisture and Leak Free?	y	
641574	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Operations Counter AF	219	
641575	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Operations Counter AL	219	
641576	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
641577	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
641578	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
641579	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	General Comments		
641580	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Heaters (All) Functioning?	y	
641581	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Maintenance Operations	0	
641582	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Moisture and Leak Free?	y	
641583	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Operations Counter AF	182	
641584	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Operations Counter AL	182	
641585	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
641586	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
641587	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
641588	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
641589	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Vegetation	None	
641590	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
641591	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
641592	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
641593	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
641594	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
641595	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
641596	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
641597	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
641598	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
641599	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
641600	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.400	millivolts
641601	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
641602	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
641603	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	5.0	amps
641604	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
641605	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
641606	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
641607	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
641608	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
641609	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
641610	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
641611	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Evidence of Insects	None	
641612	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Unknown Operations	0	
641613	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Tank Paint Condition	Good	
641614	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Switching Operations	17	
641615	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
641616	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
641617	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
641618	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
641619	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
641620	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
641621	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
641622	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
641623	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
641624	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
641625	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
641626	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
641627	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	General Comments		
641628	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
641629	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
641630	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
641631	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
641632	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Regulator As Left Counter	17814	
641633	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
641634	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
641635	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
641636	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
641637	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
641638	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
641639	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Regulator As Left Counter	28559	
641640	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
641641	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
641642	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
641643	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
641644	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
641645	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
641646	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
641647	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
641648	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Totalizer Meter Reading	.5142	
641649	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	TV Winding Temp Max	0	°C
641650	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	TV Winding Temp Present	0	°C
641651	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
641652	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Min Tap Position	1L	
641653	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	10	
641654	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
641655	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Max Tap Position	8R	
641656	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
641657	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	General Comments	ok	
641658	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
641659	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
641660	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
641661	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
641662	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
641663	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
641664	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
641665	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC Operations Since Last Insp	290	
641666	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
641667	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
641668	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	Follow-up Action Required?	n	
641669	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
641670	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	General Comments		
641671	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
641672	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
641673	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Current Tap Position	5R	
641674	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
641675	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
641676	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
641677	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
641678	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
641679	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
641680	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
641681	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
641682	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	9 Months Operations	1	
641683	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
641684	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.9	VDC
641685	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.9	VDC
641686	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
641687	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
641688	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
641689	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Adequate	
641690	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	Follow-up Action Required?	n	
641691	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BCH000438	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.2	VDC
641692	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BCH000438	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
641693	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BCH000438	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
641694	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Operations A Ø	0	
641695	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
641696	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
641697	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
641698	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	General Comments		
641699	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Foundation Condition	Good	
641700	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	General Comments		
641701	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC As Found Counter	15193	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
641702	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC As Left Counter	15193	
641703	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
641704	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
641705	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC Operations Since Last Insp	886	
641706	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
641707	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Vegetation	None	
641708	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC Min Tap Position	8L	
641709	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
641710	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
641711	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
641712	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
641713	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
641714	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
641715	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
641716	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
641717	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	General Comments		
641718	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	General Comments		
641719	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
641720	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	HV Winding Temp Max	0	°C
641721	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	HV Winding Temp Present	0	°C
641722	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	LTC Totalizer Reading	4936.32	kw
641723	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	LV Winding Temp Max	0	°C
641724	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	LV Winding Temp Present	0	°C
641725	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
641726	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
641727	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Regulator As Left Counter	56377	
641728	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
641729	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
641730	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Tank Leaks	None	
641731	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
641732	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Operations C Ø	0	
641733	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Operations Ground	0	
641734	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
641735	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
641736	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
641737	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
641738	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Follow-up Action Required?	n	
641739	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
641740	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Oil Temp Max	72	°C
641741	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Oil Temp Present	30	°C
641742	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
641743	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Follow-up Action Required?	n	
641744	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
641745	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	BCH000453	Charger	822-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.8	VDC
641746	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	BCH000453	Charger	822-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
641747	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	BCH000453	Charger	822-Battery Charger	Battery Charger Patrol Insp	General Comments		
641748	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
641749	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
641750	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Vegetation	None	
641751	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
641752	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
641753	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
641754	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
641755	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
641756	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
641757	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
641758	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
641759	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
641760	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
641761	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
641762	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
641763	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
641764	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
641765	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Tank Leaks	None	
641766	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Tank Leaks	None	
641767	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
641768	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
641769	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
641770	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
641771	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
641772	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
641773	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	General Comments	ok	
641774	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
641775	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
641776	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
641777	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
641778	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
641779	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
641780	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC Min Tap Position	14L	
641781	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC Max Tap Position	2L	
641782	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	General Comments		
641783	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Foundation Condition	Good	
641784	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC Current Tap Position	11L	
641785	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
641786	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC As Left Counter	2839	
641787	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
641788	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
641789	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
641790	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	BCH000448	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
641791	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	BCH000448	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
641792	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	BCH000448	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.7	VDC
641793	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
641794	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	General Comments	ok	
641795	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
641796	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
641797	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ok	
641798	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
641799	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
641800	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
641801	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
641802	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
641803	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
641804	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
641805	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
641806	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
641807	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
641808	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
641809	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	200.0	
641810	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	200.0	
641811	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
641812	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	General Comments		
641813	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
641814	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
641815	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
641816	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
641817	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
641818	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	General Comments		
641819	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
641820	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
641821	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
641822	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
641823	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
641824	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
641825	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
641826	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
641827	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
641828	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
641829	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
641830	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
641831	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Maintenance Operations	0	
641832	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Moisture and Leak Free?	y	
641833	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Operations Counter AF	314	
641834	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
641835	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
641836	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
641837	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Operations Counter AL	318	
641838	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
641839	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Switching Operations	5	
641840	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Tank Paint Condition	Good	
641841	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Unknown Operations	0	
641842	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
641843	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
641844	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
641845	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
641846	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
641847	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
641848	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Reg Operation Checked?	n	
641849	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Moisture and Leak Free?	y	
641850	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Maintenance Operations	0	
641851	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Heaters (All) Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
641852	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Grounds in Place?	y	
641853	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	General Comments		
641854	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
641855	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
641856	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Amps C Ø	1.0	
641857	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Amps B Ø	5.0	
641858	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Amps A Ø	6.0	
641859	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Broom on Site?	y	
641860	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
641861	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
641862	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
641863	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
641864	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
641865	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Operations Counter	174	
641866	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
641867	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	General Comments		
641868	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
641869	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
641870	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
641871	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
641872	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
641873	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
641874	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
641875	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
641876	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	General Comments	ok	
641877	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	General Comments	ok	
641878	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
641879	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
641880	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
641881	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
641882	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
641883	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
641884	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
641885	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
641886	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
641887	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
641888	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Clear of Trash?	y	
641889	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
641890	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
641891	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
641892	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
641893	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	General Comments	no 911 sign	
641894	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
641895	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
641896	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
641897	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
641898	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
641899	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
641900	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
641901	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
641902	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
641903	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
641904	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
641905	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
641906	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
641907	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
641908	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Amps C Ø	24.0	
641909	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Amps B Ø	18.0	
641910	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
641911	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
641912	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
641913	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
641914	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
641915	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
641916	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
641917	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
641918	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
641919	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
641920	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
641921	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
641922	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
641923	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Clear of Trash?	y	
641924	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
641925	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
641926	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
641927	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
641928	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
641929	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
641930	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
641931	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
641932	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
641933	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
641934	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
641935	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	General Comments		
641936	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC As Found Counter	248871	
641937	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC As Left Counter	248880	
641938	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
641939	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
641940	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC Current Tap Position	3L	
641941	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC Max Tap Position	12R	
641942	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Amps A Ø	17.0	
641943	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
641944	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	General Comments	OK	
641945	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
641946	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
641947	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
641948	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
641949	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
641950	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
641951	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
641952	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
641953	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
641954	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
641955	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
641956	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
641957	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	General Comments		
641958	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
641959	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
641960	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
641961	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
641962	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
641963	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
641964	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	General Comments		
641965	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
641966	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Follow-up Action Required?	n	
641967	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
641968	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	55	°C
641969	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	34	°C
641970	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
641971	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
641972	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Amps A Ø	49.0	
641973	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Amps B Ø	49.0	
641974	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Amps C Ø	48.0	
641975	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
641976	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
641977	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
641978	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
641979	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Operations Ground	0	
641980	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Operations C Ø	0	
641981	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Operations B Ø	0	
641982	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Operations A Ø	0	
641983	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
641984	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
641985	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
641986	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
641987	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
641988	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
641989	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
641990	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
641991	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
641992	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
641993	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
641994	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	General Comments		
641995	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
641996	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
641997	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
641998	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
641999	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
642000	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
642001	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
642002	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
642003	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
642004	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
642005	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
642006	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
642007	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
642008	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
642009	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
642010	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
642011	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
642012	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
642013	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
642014	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
642015	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
642016	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
642017	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
642018	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
642019	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
642020	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
642021	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
642022	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Equipment Properly Labeled?	y	
642023	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Cabinet Paint Condition	Good	
642024	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
642025	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
642026	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
642027	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
642028	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
642029	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
642030	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
642031	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
642032	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
642033	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
642034	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
642035	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	LTCC000805	LTCControl	401-1	LTC Control Insp	All Connections OK?	y	
642036	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	218	
642037	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
642038	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
642039	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	469	
642040	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	469	
642041	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
642042	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	A,B,C PHASE IOC	
642043	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	LTCC000805	LTCControl	401-1	LTC Control Insp	Follow-up Action Required?	n	
642044	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	LTCC000805	LTCControl	401-1	LTC Control Insp	General Comments	ok	
642045	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	LTCC000805	LTCControl	401-1	LTC Control Insp	LTC Operation Checked?	y	
642046	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	LTCC000805	LTCControl	401-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
642047	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	LTCC000805	LTCControl	401-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
642048	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	LTCC000805	LTCControl	401-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
642049	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	LTCC000805	LTCControl	401-1	LTC Control Insp	VRR Time Delay	30	Seconds
642050	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
642051	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Panels Dusted?	y	
642052	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
642053	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
642054	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	General Comments	ok	
642055	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
642056	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
642057	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Floor Swept?	y	
642058	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
642059	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
642060	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	BAT001278	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
642061	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	BAT001278	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
642062	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	BAT001278	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
642063	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	BAT001278	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
642064	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	BAT001278	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
642065	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	BAT001278	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
642066	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
642067	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
642068	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	253	
642069	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
642070	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
642071	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.2	VDC
642072	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	253	
642073	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
642074	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
642075	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
642076	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
642077	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
642078	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
642079	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.4	VDC
642080	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
642081	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
642082	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Broom on Site?	y	
642083	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	17	
642084	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	13.25	%
642085	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	18.07	%
642086	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	24.09	%
642087	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	350.0	
642088	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	300.0	
642089	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	250.0	
642090	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
642091	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	22.36	
642092	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	22.36	
642093	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	22.36	
642094	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	2	
642095	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	2	
642096	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	2	
642097	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
642098	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
642099	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
642100	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
642101	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	VRR Time Delay	30	Seconds
642102	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
642103	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
642104	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
642105	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	LTC Operation Checked?	y	
642106	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	General Comments	ok	
642107	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	Follow-up Action Required?	n	
642108	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	All Connections OK?	y	
642109	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
642110	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
642111	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
642112	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
642113	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Evidence of Insects	None	
642114	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Follow-up Action Required?	n	
642115	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
642116	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
642117	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
642118	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
642119	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
642120	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
642121	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
642122	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
642123	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
642124	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
642125	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
642126	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	General Comments		
642127	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
642128	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
642129	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	LTCC000352	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
642130	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
642131	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	General Comments		
642132	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
642133	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	LTCC000352	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
642134	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	LTCC000352	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
642135	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	General Comments	low oil	
642136	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
642137	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
642138	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
642139	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
642140	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
642141	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
642142	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	LTCC000352	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
642143	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	LTCC000352	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
642144	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	LTCC000352	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
642145	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	LTCC000352	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
642146	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	LTCC000352	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
642147	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	LTCC000352	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
642148	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
642149	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
642150	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
642151	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
642152	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
642153	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
642154	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
642155	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	General Comments		
642156	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
642157	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
642158	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
642159	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
642160	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
642161	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
642162	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
642163	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
642164	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
642165	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
642166	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
642167	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
642168	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
642169	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
642170	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
642171	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
642172	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	General Comments		
642173	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
642174	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
642175	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Operations Counter	5	
642176	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
642177	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Tank Leaks	None	
642178	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
642179	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
642180	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
642181	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.9	VDC
642182	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
642183	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	General Comments	ok	
642184	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
642185	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
642186	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
642187	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
642188	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
642189	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
642190	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
642191	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
642192	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
642193	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
642194	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
642195	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Foundation Condition	Good	
642196	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
642197	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
642198	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	112142	
642199	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
642200	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
642201	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Unknown Operations	0	
642202	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
642203	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
642204	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
642205	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
642206	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Tank Paint Condition	Good	
642207	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Switching Operations	1	
642208	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Operations Counter AL	186	
642209	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
642210	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
642211	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
642212	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
642213	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
642214	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
642215	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
642216	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
642217	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	Neutral	
642218	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
642219	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
642220	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
642221	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
642222	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
642223	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Amps C Ø	360.0	
642224	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Adjusted Amps A Phase V	0	
642225	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
642226	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	Neutral	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
642227	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
642228	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Operations Counter AF	185	
642229	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
642230	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Maintenance Operations	0	
642231	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
642232	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Grounds in Place?	y	
642233	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	General Comments		
642234	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	General Comments		
642235	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
642236	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
642237	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
642238	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
642239	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
642240	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
642241	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
642242	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
642243	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
642244	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
642245	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
642246	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
642247	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
642248	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
642249	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
642250	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
642251	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Operations B Ø	0	
642252	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Operations A Ø	0	
642253	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Adjusted Amps C Phase V	0	
642254	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	9 Month Operations	1	
642255	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
642256	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	General Comments	ok	
642257	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
642258	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
642259	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Amps A Ø	360.0	
642260	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Amps B Ø	380.0	
642261	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Adjusted Amps B Phase V	0	
642262	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
642263	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
642264	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
642265	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	Head not workin	
642266	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
642267	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
642268	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
642269	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
642270	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Operations B Ø	0	
642271	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Operations C Ø	0	
642272	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Operations Ground	0	
642273	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Follow-up Action Required?	n	
642274	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Follow-up Action Required?	n	
642275	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Foundation Condition	Good	
642276	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
642277	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Unknown Operations	0	
642278	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Tank Paint Condition	Good	
642279	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Switching Operations	5	
642280	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
642281	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Operations Counter AL	183	
642282	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Operations Counter AF	179	
642283	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Moisture and Leak Free?	y	
642284	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Maintenance Operations	0	
642285	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Grounds in Place?	y	
642286	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	General Comments		
642287	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	General Comments		
642288	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Foundation Condition	Good	
642289	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Follow-up Action Required?	n	
642290	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Follow-up Action Required?	n	
642291	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Operations Ground	0	
642292	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Operations C Ø	0	
642293	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Operations B Ø	0	
642294	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Operations A Ø	0	
642295	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
642296	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
642297	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
642298	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Equipment Properly Labeled?	y	
642299	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Cabinet Paint Condition	Good	
642300	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
642301	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
642302	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
642303	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Bushings Connection/Risers	Good	
642304	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Bushing Condition	Good	
642305	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Amps C Ø	140.0	
642306	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Amps B Ø	140.0	
642307	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Amps A Ø	140.0	
642308	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Accumulated Fault Duty C Ph V	4.73	%
642309	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
642310	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
642311	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	9 Month Operations	10	
642312	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
642313	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	PF000167	PowerFuse	HC-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
642314	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	PF000167	PowerFuse	HC-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
642315	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	9 Month Operations	2	
642316	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Accumulated Fault Duty A Ph V	1.17	%
642317	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Accumulated Fault Duty B Ph V	1.17	%
642318	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Accumulated Fault Duty C Ph V	1.17	%
642319	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Amps A Ø	41.0	
642320	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Amps B Ø	35.0	
642321	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Amps C Ø	45.0	
642322	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Bushing Condition	Good	
642323	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Bushings Connection/Risers	Good	
642324	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
642325	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
642326	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
642327	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Cabinet Paint Condition	Good	
642328	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Equipment Properly Labeled?	y	
642329	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	259.0	
642330	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	255.0	
642331	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
642332	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
642333	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
642334	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
642335	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
642336	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
642337	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
642338	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
642339	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
642340	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
642341	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
642342	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ok	
642343	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
642344	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	745	
642345	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	745	
642346	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
642347	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
642348	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
642349	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
642350	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
642351	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Clear of Trash?	y	
642352	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
642353	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
642354	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
642355	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
642356	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
642357	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
642358	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	General Comments		
642359	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
642360	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Vegetation	None	
642361	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
642362	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
642363	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
642364	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
642365	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
642366	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
642367	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
642368	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Foundation Condition	Good	
642369	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
642370	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
642371	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	General Comments		
642372	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
642373	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
642374	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
642375	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
642376	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
642377	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
642378	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
642379	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
642380	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
642381	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
642382	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
642383	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Operations A Ø	0	
642384	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Operations B Ø	0	
642385	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Operations C Ø	0	
642386	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Operations Ground	0	
642387	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Follow-up Action Required?	n	
642388	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Follow-up Action Required?	n	
642389	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Foundation Condition	Good	
642390	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	General Comments	ok	
642391	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	General Comments	OK	
642392	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Grounds in Place?	y	
642393	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Heaters (All) Functioning?	y	
642394	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Maintenance Operations	2	
642395	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Moisture and Leak Free?	y	
642396	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Operations Counter AF	176	
642397	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Operations Counter AL	176	
642398	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
642399	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Switching Operations	0	
642400	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Tank Paint Condition	Good	
642401	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Unknown Operations	0	
642402	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
642403	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
642404	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
642405	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Clear of Trash?	y	
642406	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
642407	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
642408	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
642409	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
642410	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
642411	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
642412	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	General Comments	ok	
642413	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
642414	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	17	
642415	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
642416	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
642417	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
642418	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	200.0	
642419	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	200.0	
642420	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	300.0	
642421	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
642422	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
642423	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
642424	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
642425	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
642426	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
642427	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
642428	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
642429	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
642430	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
642431	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
642432	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ok	
642433	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
642434	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	120	
642435	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	120	
642436	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
642437	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
642438	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
642439	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
642440	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Operations A Ø	0	
642441	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Operations B Ø	0	
642442	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Operations C Ø	0	
642443	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Operations Ground	0	
642444	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Follow-up Action Required?	n	
642445	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Follow-up Action Required?	n	
642446	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Foundation Condition	Good	
642447	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	General Comments	ok	
642448	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	General Comments	ok	
642449	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Grounds in Place?	y	
642450	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Heaters (All) Functioning?	y	
642451	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Maintenance Operations	2	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
642452	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Moisture and Leak Free?	y	
642453	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Operations Counter AF	202	
642454	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Operations Counter AL	202	
642455	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
642456	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Switching Operations	0	
642457	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Tank Paint Condition	Good	
642458	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Unknown Operations	0	
642459	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
642460	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
642461	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
642462	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
642463	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
642464	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
642465	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
642466	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
642467	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
642468	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
642469	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
642470	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
642471	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
642472	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	General Comments	no 911 sign	
642473	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
642474	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	9 Month Operations	2	
642475	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Accumulated Fault Duty A Ph V	.59	%
642476	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Accumulated Fault Duty B Ph V	.59	%
642477	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Accumulated Fault Duty C Ph V	.59	%
642478	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Amps A Ø	25.0	
642479	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Amps B Ø	29.0	
642480	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Amps C Ø	22.0	
642481	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Bushing Condition	Good	
642482	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Bushings Connection/Risers	Good	
642483	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
642484	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
642485	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
642486	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Cabinet Paint Condition	Good	
642487	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Equipment Properly Labeled?	y	
642488	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
642489	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
642490	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
642491	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
642492	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Tank Leaks	None	
642493	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
642494	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
642495	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
642496	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
642497	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
642498	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments	ok	
642499	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	ok	
642500	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
642501	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
642502	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
642503	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
642504	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	168	
642505	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	168	
642506	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
642507	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
642508	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
642509	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
642510	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
642511	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
642512	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
642513	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	n	
642514	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
642515	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Evidence of Insects	None	
642516	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
642517	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
642518	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Floor Swept?	y	
642519	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
642520	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
642521	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	General Comments		
642522	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
642523	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Panels Dusted?	y	
642524	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Trash Emptied?	n	
642525	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
642526	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
642527	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
642528	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
642529	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
642530	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
642531	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
642532	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
642533	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
642534	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
642535	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
642536	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
642537	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
642538	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
642539	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
642540	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
642541	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
642542	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
642543	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
642544	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Clear of Trash?	y	
642545	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
642546	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
642547	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Current Tap Position	6L	
642548	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
642549	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
642550	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
642551	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
642552	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	General Comments		
642553	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
642554	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Max Tap Position	1R	
642555	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Min Tap Position	10L	
642556	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
642557	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
642558	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
642559	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
642560	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
642561	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Regulator As Left Counter	142901	
642562	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
642563	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
642564	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Tank Leaks	None	
642565	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
642566	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
642567	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
642568	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
642569	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
642570	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
642571	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Clear of Trash?	y	
642572	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
642573	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
642574	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
642575	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
642576	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
642577	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
642578	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
642579	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
642580	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Current Tap Position	8L	
642581	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
642582	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
642583	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
642584	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
642585	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
642586	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
642587	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
642588	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	General Comments		
642589	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
642590	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Max Tap Position	1R	
642591	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Min Tap Position	12L	
642592	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
642593	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
642594	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
642595	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
642596	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
642597	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Regulator As Left Counter	153483	
642598	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
642599	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
642600	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
642601	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
642602	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
642603	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
642604	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
642605	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
642606	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
642607	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
642608	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
642609	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
642610	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
642611	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
642612	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
642613	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
642614	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
642615	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
642616	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
642617	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
642618	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
642619	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
642620	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
642621	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
642622	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
642623	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
642624	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
642625	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
642626	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	0	
642627	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
642628	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
642629	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC Max Tap Position	8R	
642630	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
642631	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
642632	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC As Left Counter	65620	
642633	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC As Found Counter	65620	
642634	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
642635	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
642636	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	General Comments	ok	
642637	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
642638	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Foundation Condition	Good	
642639	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
642640	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
642641	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
642642	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
642643	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
642644	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
642645	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	General Comments		
642646	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
642647	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
642648	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
642649	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
642650	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
642651	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
642652	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	259.0	
642653	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
642654	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
642655	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
642656	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
642657	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
642658	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	General Comments		
642659	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
642660	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Vegetation	None	
642661	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
642662	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
642663	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
642664	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
642665	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
642666	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
642667	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
642668	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Foundation Condition	Good	
642669	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
642670	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
642671	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	General Comments		
642672	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
642673	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
642674	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
642675	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
642676	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
642677	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
642678	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
642679	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
642680	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
642681	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
642682	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
642683	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
642684	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	PF000100	PowerFuse	DX-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
642685	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	PF000100	PowerFuse	DX-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
642686	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
642687	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
642688	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Winding Temp Present	30	°C
642689	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Winding Temp Max	40	°C
642690	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Totalizer Meter Reading	.5680	
642691	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
642692	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
642693	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
642694	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
642695	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
642696	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
642697	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
642698	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
642699	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Oil Temp Present	30	°C
642700	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Oil Temp Max	40	°C
642701	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
642702	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
642703	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	LTC Totalizer Reading	5452.80	kw
642704	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
642705	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	General Comments		
642706	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	General Comments		
642707	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
642708	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
642709	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
642710	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
642711	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
642712	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
642713	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.5030	
642714	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
642715	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
642716	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.5	volts
642717	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Regulator As Left Counter	26523	
642718	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
642719	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Tank Leaks	None	
642720	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
642721	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
642722	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
642723	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
642724	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
642725	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
642726	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LTCC000536	LTCControl	CF-TRANS 1	LTC Control Insp	General Comments	ok	
642727	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LTCC000536	LTCControl	CF-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
642728	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LTCC000536	LTCControl	CF-TRANS 1	LTC Control Insp	All Connections OK?	y	
642729	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
642730	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
642731	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
642732	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
642733	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
642734	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
642735	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
642736	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
642737	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
642738	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
642739	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
642740	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
642741	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
642742	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
642743	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
642744	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
642745	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	General Comments		
642746	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
642747	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
642748	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
642749	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1050	psi
642750	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
642751	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	Oil Temp Present	37	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
642752	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
642753	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
642754	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
642755	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
642756	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
642757	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
642758	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
642759	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
642760	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
642761	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1605.60	kw
642762	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
642763	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
642764	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
642765	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
642766	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
642767	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
642768	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
642769	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
642770	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
642771	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
642772	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
642773	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
642774	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
642775	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
642776	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
642777	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
642778	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
642779	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
642780	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
642781	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
642782	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
642783	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	General Comments		
642784	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
642785	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
642786	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
642787	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
642788	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
642789	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
642790	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6690	
642791	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
642792	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
642793	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
642794	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
642795	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
642796	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
642797	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
642798	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
642799	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
642800	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
642801	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
642802	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	General Comments	OK	
642803	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	General Comments	OK	
642804	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
642805	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
642806	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
642807	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3607.20	kw
642808	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
642809	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
642810	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
642811	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
642812	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
642813	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
642814	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
642815	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
642816	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	500.0	
642817	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	525.0	
642818	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	500.0	
642819	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
642820	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
642821	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	General Comments	ok	
642822	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
642823	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
642824	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
642825	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
642826	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
642827	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
642828	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
642829	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
642830	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
642831	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
642832	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
642833	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
642834	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
642835	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	2.60	%
642836	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
642837	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
642838	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
642839	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
642840	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
642841	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
642842	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
642843	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
642844	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
642845	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
642846	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
642847	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
642848	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
642849	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
642850	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
642851	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
642852	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
642853	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
642854	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
642855	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	General Comments		
642856	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
642857	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
642858	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
642859	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	Oil Temp Max	80	°C
642860	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
642861	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
642862	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
642863	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
642864	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
642865	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
642866	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
642867	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
642868	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
642869	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
642870	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
642871	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
642872	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
642873	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
642874	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
642875	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
642876	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
642877	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	60	°C
642878	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
642879	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
642880	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	54	°C
642881	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
642882	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	60	°C
642883	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	35	°C
642884	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	VRR Time Delay	30	Seconds
642885	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
642886	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
642887	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
642888	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
642889	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
642890	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	LTC Operation Checked?	y	
642891	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	General Comments		
642892	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	Follow-up Action Required?	n	
642893	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	All Connections OK?	y	
642894	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
642895	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
642896	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
642897	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
642898	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	General Comments	ok	
642899	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
642900	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
642901	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
642902	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
642903	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
642904	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
642905	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
642906	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
642907	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
642908	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
642909	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	86	
642910	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	86	
642911	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
642912	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
642913	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
642914	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
642915	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
642916	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
642917	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
642918	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
642919	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
642920	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
642921	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
642922	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
642923	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
642924	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
642925	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	278	
642926	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	278	
642927	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
642928	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
642929	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
642930	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
642931	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
642932	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
642933	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
642934	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
642935	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
642936	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
642937	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
642938	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
642939	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
642940	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
642941	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
642942	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	General Comments	repaired berm as well as i could...needs more gravel	
642943	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Exp Boom Corrected	
642944	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Vegetation	None	
642945	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
642946	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
642947	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
642948	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
642949	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
642950	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
642951	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
642952	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
642953	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
642954	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
642955	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
642956	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
642957	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
642958	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
642959	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
642960	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
642961	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
642962	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
642963	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
642964	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
642965	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
642966	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
642967	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
642968	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	General Comments		
642969	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
642970	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
642971	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
642972	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
642973	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
642974	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
642975	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
642976	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
642977	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Vegetation	None	
642978	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
642979	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
642980	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
642981	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Operations Counter	216	
642982	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
642983	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
642984	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	General Comments	ok	
642985	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
642986	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
642987	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
642988	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
642989	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
642990	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
642991	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
642992	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
642993	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
642994	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
642995	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Amps C Ø	85.0	
642996	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Amps B Ø	95.0	
642997	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Amps A Ø	82.0	
642998	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
642999	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
643000	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Clear of Trash?	y	
643001	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
643002	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
643003	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
643004	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
643005	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
643006	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
643007	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	380.0	
643008	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	250.0	
643009	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	380.0	
643010	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
643011	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
643012	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
643013	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
643014	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
643015	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
643016	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
643017	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
643018	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
643019	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
643020	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
643021	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
643022	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
643023	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
643024	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
643025	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
643026	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
643027	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
643028	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
643029	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
643030	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
643031	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
643032	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
643033	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
643034	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
643035	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
643036	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
643037	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
643038	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC Operations Since Last Insp	68	
643039	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC Min Tap Position	10L	
643040	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
643041	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC Current Tap Position	5L	
643042	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
643043	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC As Left Counter	14466	
643044	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC As Found Counter	14466	
643045	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	General Comments		
643046	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	General Comments		
643047	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
643048	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	Follow-up Action Required?	n	
643049	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
643050	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
643051	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
643052	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
643053	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
643054	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
643055	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
643056	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
643057	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	80	°C
643058	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
643059	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	85	°C
643060	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
643061	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	80	°C
643062	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	°C
643063	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	LTCC000278	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
643064	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	LTCC000278	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
643065	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	LTCC000278	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
643066	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	LTCC000278	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
643067	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	LTCC000278	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
643068	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	LTCC000278	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
643069	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	LTCC000278	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
643070	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	LTCC000278	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
643071	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	LTCC000278	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
643072	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
643073	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
643074	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
643075	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
643076	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
643077	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
643078	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
643079	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
643080	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
643081	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	General Comments		
643082	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	General Comments		
643083	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
643084	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
643085	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Regulator As Left Counter	55956	
643086	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
643087	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
643088	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Tank Leaks	None	
643089	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
643090	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
643091	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
643092	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	292	
643093	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
643094	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC Max Tap Position	Neutral	
643095	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC Current Tap Position	11L	
643096	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
643097	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC As Left Counter	64801	
643098	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC As Found Counter	64801	
643099	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
643100	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	General Comments		
643101	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
643102	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
643103	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
643104	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
643105	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
643106	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
643107	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
643108	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
643109	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
643110	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
643111	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
643112	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
643113	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
643114	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
643115	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
643116	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
643117	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
643118	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	7	
643119	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	14L	
643120	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
643121	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11L	
643122	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
643123	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC As Left Counter	132754	
643124	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC As Found Counter	132754	
643125	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
643126	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
643127	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
643128	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
643129	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
643130	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
643131	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
643132	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
643133	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
643134	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	General Comments	X1 alarm wires are unhooked still	
643135	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
643136	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
643137	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
643138	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
643139	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
643140	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
643141	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
643142	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
643143	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	General Comments		
643144	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
643145	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
643146	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
643147	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
643148	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
643149	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
643150	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	General Comments		
643151	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
643152	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
643153	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
643154	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
643155	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
643156	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
643157	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
643158	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
643159	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
643160	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Foundation Condition	Good	
643161	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
643162	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
643163	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
643164	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
643165	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
643166	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
643167	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
643168	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
643169	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
643170	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
643171	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	LTC Totalizer Reading	3586.56	kw
643172	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
643173	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	General Comments		
643174	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	General Comments		
643175	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
643176	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
643177	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Follow-up Action Required?	n	
643178	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
643179	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
643180	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
643181	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
643182	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
643183	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
643184	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
643185	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
643186	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
643187	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
643188	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	General Comments		
643189	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	General Comments		
643190	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
643191	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
643192	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
643193	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
643194	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
643195	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
643196	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Regulator As Left Counter	38720	
643197	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
643198	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Tank Leaks	None	
643199	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
643200	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
643201	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
643202	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	General Comments	ok	
643203	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
643204	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
643205	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
643206	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
643207	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
643208	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
643209	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
643210	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
643211	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
643212	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
643213	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
643214	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
643215	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
643216	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
643217	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
643218	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
643219	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	General Comments	ok	
643220	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	ok	
643221	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC As Found Counter	18337	
643222	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC As Left Counter	18337	
643223	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
643224	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
643225	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2R	
643226	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
643227	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	455	
643228	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
643229	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
643230	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
643231	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
643232	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
643233	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
643234	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Totalizer Meter Reading	1.1208	
643235	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
643236	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Top Oil Temperature Present	35	°C
643237	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Top Oil Temperature Max	50	°C
643238	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
643239	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
643240	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
643241	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
643242	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
643243	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
643244	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
643245	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Patrol Inspection	General Comments	ok	
643246	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Follow-up Action Required?	n	
643247	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
643248	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.91	%
643249	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	.91	%
643250	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
643251	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Patrol Inspection	Follow-up Action Required?	n	
643252	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Operations Ground	0	
643253	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Operations C Ø	0	
643254	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Operations B Ø	0	
643255	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Operations A Ø	0	
643256	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
643257	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
643258	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
643259	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
643260	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Amps C Ø	210.0	
643261	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Amps B Ø	350.0	
643262	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Amps A Ø	300.0	
643263	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Accumulated Fault Duty C Ph AM	23.92	%
643264	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Accumulated Fault Duty B Ph AM	27.91	%
643265	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Accumulated Fault Duty A Ph AM	26.58	%
643266	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	9 Months Operations	2	
643267	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
643268	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
643269	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
643270	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
643271	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
643272	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
643273	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
643274	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
643275	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
643276	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
643277	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
643278	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
643279	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
643280	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
643281	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
643282	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
643283	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
643284	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
643285	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
643286	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
643287	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
643288	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
643289	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
643290	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
643291	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
643292	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
643293	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	800	
643294	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	803	
643295	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
643296	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	3	
643297	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
643298	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
643299	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
643300	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
643301	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	100.00	
643302	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1008.00	kw
643303	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
643304	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
643305	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
643306	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
643307	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
643308	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
643309	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
643310	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
643311	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
643312	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
643313	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
643314	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
643315	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
643316	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
643317	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
643318	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
643319	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
643320	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
643321	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
643322	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3150	
643323	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Unknown Operations	0	
643324	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Switching Operations	0	
643325	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Operations Counter AL	55	
643326	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
643327	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	General Comments		
643328	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
643329	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
643330	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
643331	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
643332	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
643333	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
643334	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
643335	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
643336	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
643337	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
643338	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	All Connections OK?	y	
643339	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	Follow-up Action Required?	n	
643340	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	General Comments		
643341	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	LTC Operation Checked?	y	
643342	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
643343	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
643344	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
643345	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
643346	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	VRR Time Delay	30	Seconds
643347	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
643348	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
643349	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
643350	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Operations Counter AF	55	
643351	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
643352	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	General Comments	ok	
643353	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
643354	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Cabinet Paint Condition	Good	
643355	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Equipment Properly Labeled?	y	
643356	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Follow-up Action Required?	n	
643357	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Foundation Condition	Good	
643358	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	General Comments	ok	
643359	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Grounds in Place?	y	
643360	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Heaters (All) Functioning?	y	
643361	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Moisture and Leak Free?	y	
643362	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
643363	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Tank Paint Condition	Good	
643364	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
643365	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
643366	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
643367	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	General Comments		
643368	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
643369	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
643370	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
643371	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
643372	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
643373	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
643374	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
643375	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
643376	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
643377	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
643378	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
643379	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
643380	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
643381	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
643382	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
643383	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Clear of Trash?	y	
643384	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
643385	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
643386	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
643387	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
643388	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
643389	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
643390	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	General Comments		
643391	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
643392	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
643393	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
643394	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	n	
643395	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	n	
643396	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Vegetation	None	
643397	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
643398	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
643399	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	General Comments		
643400	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
643401	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
643402	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
643403	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
643404	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BCH000573	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
643405	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BCH000573	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
643406	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BCH000573	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
643407	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Maintenance Operations	1	
643408	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Heaters (All) Functioning?	y	
643409	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Grounds in Place?	y	
643410	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	General Comments		
643411	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	General Comments		
643412	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Foundation Condition	Good	
643413	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Follow-up Action Required?	n	
643414	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Follow-up Action Required?	n	
643415	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Operations Ground	0	
643416	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Operations C Ø	0	
643417	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Operations B Ø	0	
643418	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Operations A Ø	0	
643419	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
643420	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
643421	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
643422	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Equipment Properly Labeled?	y	
643423	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Cabinet Paint Condition	Good	
643424	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
643425	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
643426	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
643427	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Bushings Connection/Risers	Good	
643428	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Bushing Condition	Good	
643429	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Amps C Ø	40.0	
643430	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Amps B Ø	5.0	
643431	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Amps A Ø	20.0	
643432	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Accumulated Fault Duty C Ph V	.29	%
643433	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Accumulated Fault Duty B Ph V	.29	%
643434	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Accumulated Fault Duty A Ph V	.43	%
643435	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	9 Month Operations	5	
643436	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
643437	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Tank Leaks	None	
643438	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
643439	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
643440	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
643441	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
643442	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
643443	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
643444	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
643445	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
643446	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
643447	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
643448	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	General Comments		
643449	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
643450	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
643451	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
643452	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
643453	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
643454	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
643455	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
643456	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
643457	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Bushing Condition	Good	
643458	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Bushings Connection/Risers	Good	
643459	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
643460	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
643461	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
643462	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
643463	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
643464	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
643465	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
643466	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
643467	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
643468	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
643469	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
643470	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
643471	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
643472	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
643473	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
643474	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Regulator As Left Counter	145423	
643475	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
643476	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
643477	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Tank Leaks	None	
643478	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
643479	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
643480	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
643481	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
643482	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	YD000189	Yard	560-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
643483	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	YD000189	Yard	560-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
643484	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	YD000189	Yard	560-Yard	Yard Patrol Inspection	Clear of Trash?	y	
643485	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	YD000189	Yard	560-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
643486	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	YD000189	Yard	560-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
643487	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	YD000189	Yard	560-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
643488	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	YD000189	Yard	560-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
643489	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	YD000189	Yard	560-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
643490	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	YD000189	Yard	560-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
643491	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	YD000189	Yard	560-Yard	Yard Patrol Inspection	General Comments	drive grown up with vegetation	
643492	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	YD000189	Yard	560-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
643493	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	YD000189	Yard	560-Yard	Yard Patrol Inspection	Vegetation	None	
643494	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	YD000189	Yard	560-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
643495	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
643496	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
643497	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
643498	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
643499	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
643500	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
643501	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
643502	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
643503	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
643504	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
643505	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
643506	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
643507	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
643508	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	General Comments	OK	
643509	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
643510	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
643511	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
643512	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
643513	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
643514	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
643515	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BCH000573	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
643516	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BCH000573	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
643517	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BCH000573	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
643518	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BCH000573	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
643519	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	42	°C
643520	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	53	°C
643521	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	55	°C
643522	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	65	°C
643523	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
643524	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	55	°C
643525	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
643526	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
643527	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
643528	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
643529	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
643530	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
643531	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
643532	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
643533	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
643534	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
643535	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
643536	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
643537	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
643538	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
643539	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	General Comments	ok	
643540	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	General Comments	ok	
643541	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
643542	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
643543	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
643544	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
643545	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
643546	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
643547	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
643548	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Current Tap Position	6L	
643549	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
643550	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
643551	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
643552	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
643553	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
643554	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
643555	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
643556	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
643557	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	General Comments		
643558	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
643559	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Max Tap Position	1R	
643560	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Min Tap Position	10L	
643561	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
643562	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
643563	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
643564	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
643565	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
643566	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
643567	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
643568	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
643569	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
643570	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
643571	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
643572	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
643573	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
643574	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	520	
643575	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	520	
643576	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
643577	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
643578	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
643579	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
643580	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
643581	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
643582	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
643583	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
643584	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
643585	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
643586	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
643587	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	General Comments		
643588	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
643589	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
643590	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
643591	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
643592	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
643593	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
643594	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
643595	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
643596	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
643597	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
643598	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
643599	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
643600	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
643601	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
643602	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
643603	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
643604	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
643605	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
643606	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
643607	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	General Comments		
643608	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	General Comments		
643609	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
643610	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
643611	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	200.00	
643612	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	354.24	kw
643613	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
643614	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
643615	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
643616	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
643617	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
643618	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
643619	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
643620	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
643621	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
643622	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
643623	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
643624	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
643625	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
643626	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
643627	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	General Comments		
643628	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
643629	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
643630	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
643631	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
643632	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
643633	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
643634	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
643635	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
643636	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
643637	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
643638	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
643639	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
643640	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
643641	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	80496	
643642	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
643643	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
643644	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
643645	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
643646	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
643647	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	4L	
643648	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	9R	
643649	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
643650	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	General Comments		
643651	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
643652	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
643653	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
643654	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
643655	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1R	
643656	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
643657	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
643658	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
643659	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
643660	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
643661	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	59	
643662	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
643663	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
643664	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
643665	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	470.0	
643666	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	50.0	
643667	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	500.0	
643668	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
643669	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
643670	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
643671	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
643672	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
643673	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
643674	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
643675	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
643676	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	20.48	%
643677	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	22	
643678	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
643679	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
643680	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	2	
643681	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
643682	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
643683	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
643684	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0492	
643685	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	1	
643686	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
643687	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
643688	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
643689	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
643690	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
643691	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
643692	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
643693	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
643694	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
643695	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
643696	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
643697	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Site Service Trans Condition	Exterior Stains	
643698	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
643699	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
643700	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
643701	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
643702	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
643703	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
643704	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
643705	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
643706	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	General Comments		
643707	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
643708	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
643709	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
643710	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
643711	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
643712	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
643713	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
643714	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
643715	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
643716	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
643717	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
643718	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Vegetation	None	
643719	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Exp Boom Needs Corr	
643720	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	General Comments		
643721	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
643722	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
643723	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
643724	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
643725	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
643726	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
643727	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
643728	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
643729	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
643730	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
643731	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	416	
643732	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	416	
643733	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
643734	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
643735	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
643736	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
643737	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
643738	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
643739	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
643740	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
643741	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
643742	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	4.46	%
643743	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.97	%
643744	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.97	%
643745	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	17.0	
643746	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	21.0	
643747	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	19.0	
643748	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
643749	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
643750	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
643751	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
643752	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
643753	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
643754	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
643755	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	39.85	
643756	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	39.85	
643757	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	39.85	
643758	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
643759	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
643760	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
643761	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
643762	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
643763	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
643764	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
643765	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments	ok	
643766	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	ok	
643767	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
643768	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
643769	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
643770	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
643771	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
643772	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
643773	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
643774	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
643775	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
643776	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	220.0	
643777	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	220.0	
643778	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	163	
643779	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	163	
643780	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
643781	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	300.0	
643782	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	4.82	%
643783	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	12.05	%
643784	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
643785	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
643786	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
643787	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
643788	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
643789	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	Oil Temp Max	50	°C
643790	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	Oil Temp Present	35	°C
643791	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
643792	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
643793	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
643794	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
643795	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
643796	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
643797	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
643798	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
643799	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
643800	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
643801	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
643802	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
643803	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Foundation Condition	Good	
643804	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
643805	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
643806	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	General Comments	ok	
643807	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
643808	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
643809	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
643810	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
643811	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
643812	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
643813	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
643814	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
643815	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
643816	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
643817	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
643818	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
643819	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
643820	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.1	VDC
643821	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.1	VDC
643822	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
643823	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
643824	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
643825	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	General Comments		
643826	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
643827	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
643828	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
643829	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
643830	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	General Comments	ok	
643831	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
643832	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BCH001057	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
643833	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BCH001057	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
643834	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BCH001057	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
643835	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BCH001057	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
643836	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BCH001057	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
643837	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BCH001057	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
643838	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
643839	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Vegetation	None	
643840	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
643841	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
643842	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	General Comments	ok	
643843	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
643844	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
643845	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
643846	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
643847	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
643848	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
643849	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Clear of Trash?	y	
643850	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
643851	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
643852	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Ambient Temp	59	°F
643853	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
643854	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
643855	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
643856	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
643857	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
643858	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
643859	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
643860	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
643861	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
643862	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
643863	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
643864	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.3	VDC
643865	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
643866	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
643867	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
643868	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
643869	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
643870	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
643871	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	122.0	VAC
643872	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
643873	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
643874	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
643875	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
643876	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
643877	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
643878	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
643879	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
643880	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
643881	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
643882	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
643883	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
643884	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
643885	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
643886	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
643887	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
643888	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
643889	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
643890	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
643891	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	General Comments		
643892	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
643893	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
643894	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
643895	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
643896	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Regulator As Left Counter	157520	
643897	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
643898	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
643899	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Tank Leaks	None	
643900	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
643901	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
643902	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
643903	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
643904	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
643905	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
643906	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
643907	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
643908	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
643909	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
643910	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
643911	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	General Comments		
643912	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
643913	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
643914	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
643915	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
643916	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
643917	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
643918	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
643919	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
643920	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Regulator As Left Counter	51163	
643921	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
643922	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
643923	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
643924	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
643925	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
643926	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
643927	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	Oil Temp Max	58	°C
643928	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	Oil Temp Present	35	°C
643929	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
643930	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
643931	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
643932	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
643933	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Tank Leaks	None	
643934	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
643935	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
643936	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
643937	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
643938	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
643939	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Tank Leaks	None	
643940	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
643941	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
643942	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Regulator As Left Counter	224961	
643943	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
643944	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
643945	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
643946	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001093	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
643947	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001093	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	59	°F
643948	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001093	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
643949	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001093	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
643950	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001093	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
643951	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001093	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
643952	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001093	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
643953	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001093	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
643954	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001093	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
643955	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001093	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
643956	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001093	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	25.5	VDC
643957	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001093	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	25.0	VDC
643958	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001093	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
643959	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001093	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
643960	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
643961	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
643962	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
643963	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
643964	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
643965	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
643966	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
643967	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
643968	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
643969	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
643970	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	General Comments		
643971	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
643972	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	BAT001096	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
643973	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	BAT001096	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	63	°F
643974	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	BAT001096	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
643975	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	BAT001096	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
643976	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	BAT001096	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
643977	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	BAT001096	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
643978	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
643979	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
643980	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
643981	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	BAT001096	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
643982	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	BAT001096	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
643983	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	BAT001096	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
643984	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	BAT001096	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	26.9	VDC
643985	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
643986	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
643987	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
643988	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
643989	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
643990	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
643991	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
643992	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	BAT001096	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
643993	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	BAT001096	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
643994	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	BAT001096	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
643995	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	General Comments		
643996	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
643997	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
643998	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
643999	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
644000	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
644001	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
644002	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	General Comments		
644003	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
644004	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
644005	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
644006	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
644007	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
644008	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
644009	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
644010	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
644011	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
644012	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
644013	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
644014	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
644015	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Accumulated Fault Duty C Ph V	1.48	%
644016	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Accumulated Fault Duty B Ph V	1.48	%
644017	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Accumulated Fault Duty A Ph V	1.48	%
644018	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	9 Month Operations	2	
644019	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
644020	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Follow-up Action Required?	n	
644021	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	General Comments	ok	
644022	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	LTC Totalizer Reading	6399.36	kw
644023	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Oil Temp Max	35	°C
644024	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Oil Temp Present	35	°C
644025	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
644026	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Totalizer Meter Reading	.6666	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
644027	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
644028	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
644029	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Totalizer Meter Reading	.7104	
644030	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
644031	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
644032	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
644033	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
644034	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	3075	
644035	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	3075	
644036	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
644037	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ok	
644038	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
644039	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
644040	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
644041	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
644042	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
644043	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
644044	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
644045	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
644046	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
644047	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Oil Temp Present	35	°C
644048	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Oil Temp Max	50	°C
644049	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
644050	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
644051	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	1704.96	kw
644052	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
644053	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
644054	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
644055	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
644056	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	General Comments		
644057	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	General Comments		
644058	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Foundation Condition	Good	
644059	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Follow-up Action Required?	n	
644060	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Follow-up Action Required?	n	
644061	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Operations Ground	0	
644062	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Operations C Ø	0	
644063	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Cabinet Paint Condition	Good	
644064	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Equipment Properly Labeled?	y	
644065	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
644066	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
644067	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
644068	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Operations A Ø	0	
644069	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Operations B Ø	0	
644070	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Operations C Ø	0	
644071	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Operations Ground	0	
644072	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Follow-up Action Required?	n	
644073	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Follow-up Action Required?	n	
644074	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Foundation Condition	Good	
644075	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	General Comments		
644076	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	General Comments		
644077	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Grounds in Place?	y	
644078	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Heaters (All) Functioning?	y	
644079	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Maintenance Operations	2	
644080	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Moisture and Leak Free?	y	
644081	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Operations Counter AF	149	
644082	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Operations Counter AL	149	
644083	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
644084	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Switching Operations	0	
644085	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Tank Paint Condition	Good	
644086	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Unknown Operations	0	
644087	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Operations B Ø	0	
644088	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Operations A Ø	0	
644089	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
644090	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
644091	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
644092	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Equipment Properly Labeled?	y	
644093	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Cabinet Paint Condition	Good	
644094	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
644095	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
644096	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
644097	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Bushings Connection/Risers	Good	
644098	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Bushing Condition	Good	
644099	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Amps C Ø	0.0	
644100	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Amps B Ø	0.0	
644101	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Amps A Ø	0.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
644102	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
644103	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
644104	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
644105	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
644106	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Foundation Condition	Good	
644107	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
644108	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
644109	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
644110	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
644111	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
644112	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
644113	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Vegetation	None	
644114	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
644115	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	General Comments		
644116	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
644117	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
644118	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
644119	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
644120	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
644121	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
644122	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Clear of Trash?	y	
644123	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
644124	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
644125	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
644126	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	General Comments		
644127	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
644128	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
644129	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
644130	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
644131	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
644132	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
644133	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
644134	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
644135	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
644136	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
644137	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
644138	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
644139	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
644140	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
644141	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
644142	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
644143	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
644144	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
644145	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
644146	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Tank Leaks	None	
644147	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
644148	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
644149	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Regulator As Left Counter	7109	
644150	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
644151	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
644152	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
644153	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
644154	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
644155	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
644156	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
644157	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
644158	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	General Comments		
644159	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
644160	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
644161	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
644162	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
644163	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	General Comments		
644164	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	General Comments		
644165	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
644166	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
644167	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
644168	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
644169	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
644170	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
644171	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
644172	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
644173	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
644174	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
644175	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
644176	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
644177	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
644178	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
644179	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
644180	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
644181	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
644182	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
644183	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	75.0	
644184	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	75.0	
644185	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	75.0	
644186	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
644187	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
644188	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
644189	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
644190	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
644191	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Vegetation	None	
644192	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
644193	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
644194	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	General Comments	ok	
644195	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
644196	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
644197	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
644198	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
644199	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
644200	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
644201	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Clear of Trash?	y	
644202	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
644203	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
644204	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
644205	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
644206	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	General Comments	ok	
644207	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
644208	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
644209	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
644210	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
644211	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
644212	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
644213	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
644214	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
644215	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	PF000096	PowerFuse	DA-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
644216	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	PF000096	PowerFuse	DA-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
644217	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	PF000095	PowerFuse	DA-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
644218	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	PF000095	PowerFuse	DA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
644219	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Foundation Condition	Good	
644220	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	General Comments		
644221	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	General Comments		
644222	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Grounds in Place?	y	
644223	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Heaters (All) Functioning?	y	
644224	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Maintenance Operations	0	
644225	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Moisture and Leak Free?	y	
644226	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Operations Counter AF	228	
644227	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Operations Counter AL	230	
644228	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
644229	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Switching Operations	2	
644230	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Tank Paint Condition	Good	
644231	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Unknown Operations	0	
644232	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	LTCC000420	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
644233	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	LTCC000420	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
644234	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	LTCC000420	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
644235	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	LTCC000420	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
644236	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	LTCC000420	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
644237	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	LTCC000420	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
644238	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	LTCC000420	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
644239	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	LTCC000420	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
644240	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
644241	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
644242	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	199	
644243	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
644244	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments	Didn't have amp meter	
644245	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
644246	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
644247	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
644248	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
644249	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
644250	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
644251	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
644252	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Vegetation	None	
644253	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
644254	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	General Comments		
644255	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
644256	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
644257	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
644258	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
644259	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
644260	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
644261	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Clear of Trash?	y	
644262	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
644263	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
644264	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
644265	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
644266	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
644267	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
644268	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
644269	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
644270	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
644271	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
644272	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Amps A Ø	0.0	
644273	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Amps B Ø	0.0	
644274	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Amps C Ø	0.0	
644275	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Bushing Condition	Good	
644276	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Bushings Connection/Risers	Good	
644277	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
644278	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
644279	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
644280	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Cabinet Paint Condition	Good	
644281	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Equipment Properly Labeled?	y	
644282	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
644283	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
644284	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
644285	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Operations A Ø	0	
644286	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Operations B Ø	0	
644287	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Operations C Ø	0	
644288	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Operations Ground	0	
644289	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Follow-up Action Required?	n	
644290	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Follow-up Action Required?	n	
644291	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Foundation Condition	Good	
644292	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	General Comments		
644293	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	General Comments		
644294	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Grounds in Place?	y	
644295	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	PF000108	PowerFuse	CF-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
644296	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	PF000107	PowerFuse	CF-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
644297	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	PF000107	PowerFuse	CF-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
644298	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	LTCC000581	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
644299	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	LTCC000581	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
644300	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	LTCC000581	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
644301	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	LTCC000581	LTCControl	930-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
644302	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	LTCC000581	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
644303	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	LTCC000581	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
644304	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	LTCC000581	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
644305	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	LTCC000581	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
644306	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	LTCC000581	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
644307	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Heaters (All) Functioning?	y	
644308	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Maintenance Operations	5	
644309	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Moisture and Leak Free?	y	
644310	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Operations Counter AF	818	
644311	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Operations Counter AL	823	
644312	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
644313	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Switching Operations	0	
644314	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Tank Paint Condition	Good	
644315	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Unknown Operations	0	
644316	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Operations B Ø	0	
644317	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Operations C Ø	0	
644318	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Operations Ground	0	
644319	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Follow-up Action Required?	n	
644320	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Follow-up Action Required?	n	
644321	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	PF000097	PowerFuse	DA-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
644322	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	PF000097	PowerFuse	DA-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
644323	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Heaters (All) Functioning?	y	
644324	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Grounds in Place?	y	
644325	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	General Comments		
644326	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
644327	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Foundation Condition	Good	
644328	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Follow-up Action Required?	n	
644329	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Follow-up Action Required?	n	
644330	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Operations Ground	0	
644331	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Operations C Ø	0	
644332	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Operations B Ø	0	
644333	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Operations A Ø	0	
644334	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Adjusted Amps C Phase V	0	
644335	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Adjusted Amps B Phase V	0	
644336	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Adjusted Amps A Phase V	0	
644337	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Equipment Properly Labeled?	y	
644338	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Cabinet Paint Condition	Good	
644339	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
644340	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
644341	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
644342	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Bushings Connection/Risers	Good	
644343	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Bushing Condition	Good	
644344	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Amps C Ø	10	
644345	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Amps B Ø	10	
644346	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
644347	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	General Comments		
644348	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
644349	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Vegetation	None	
644350	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
644351	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Amps A Ø	10	
644352	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Accumulated Fault Duty C Ph V	6.34	%
644353	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Accumulated Fault Duty B Ph V	5.55	%
644354	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Accumulated Fault Duty A Ph V	4.75	%
644355	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	9 Month Operations	9	
644356	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
644357	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
644358	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Unknown Operations	0	
644359	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Tank Paint Condition	Good	
644360	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Switching Operations	0	
644361	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
644362	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Operations Counter AL	198	
644363	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Operations Counter AF	198	
644364	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Moisture and Leak Free?	y	
644365	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Maintenance Operations	1	
644366	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Heaters (All) Functioning?	y	
644367	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Grounds in Place?	y	
644368	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	9 Month Operations	4	
644369	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Accumulated Fault Duty A Ph V	1.80	%
644370	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Accumulated Fault Duty B Ph V	1.80	%
644371	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Accumulated Fault Duty C Ph V	1.80	%
644372	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Amps A Ø	0.0	
644373	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Amps B Ø	0.0	
644374	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Amps C Ø	0.0	
644375	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Bushing Condition	Good	
644376	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Bushings Connection/Risers	Good	
644377	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
644378	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
644379	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
644380	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
644381	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
644382	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
644383	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
644384	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
644385	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	General Comments	tower foundation near battery house is crumbling	
644386	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
644387	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
644388	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Foundation Condition	Good	
644389	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
644390	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
644391	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
644392	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
644393	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
644394	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
644395	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
644396	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
644397	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
644398	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
644399	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
644400	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
644401	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
644402	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
644403	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	ok	
644404	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
644405	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
644406	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
644407	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
644408	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
644409	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
644410	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
644411	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
644412	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
644413	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
644414	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
644415	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
644416	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
644417	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Clear of Trash?	y	
644418	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
644419	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
644420	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
644421	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
644422	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
644423	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Unknown Operations	0	
644424	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Tank Paint Condition	Good	
644425	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Switching Operations	2	
644426	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
644427	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Operations Counter AL	708	
644428	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Operations Counter AF	708	
644429	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Moisture and Leak Free?	y	
644430	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Maintenance Operations	0	
644431	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
644432	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
644433	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
644434	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
644435	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
644436	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
644437	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
644438	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Unknown Operations	0	
644439	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Switching Operations	0	
644440	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Operations Counter AL	235	
644441	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Operations Counter AF	235	
644442	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Maintenance Operations	0	
644443	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	General Comments	ok	
644444	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Patrol Inspection	General Comments	ok	
644445	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Follow-up Action Required?	n	
644446	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Patrol Inspection	Follow-up Action Required?	n	
644447	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Operations Ground	0	
644448	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Operations C Ø	0	
644449	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Operations B Ø	0	
644450	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Operations A Ø	0	
644451	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
644452	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
644453	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
644454	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Patrol Inspection	Equipment Properly Labeled?	y	
644455	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Amps C Ø	110.0	
644456	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Amps B Ø	110.0	
644457	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Amps A Ø	110.0	
644458	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Accumulated Fault Duty C Ph V	28.56	%
644459	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Accumulated Fault Duty B Ph V	55.21	%
644460	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	9 Month Operations	2	
644461	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Accumulated Fault Duty A Ph V	0	%
644462	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Accumulated Fault Duty B Ph V	0	%
644463	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Accumulated Fault Duty C Ph V	0	%
644464	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Amps A Ø	60	
644465	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Amps B Ø	69	
644466	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Amps C Ø	46	
644467	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Bushing Condition	Good	
644468	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Bushings Connection/Risers	Good	
644469	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
644470	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
644471	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
644472	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Cabinet Paint Condition	Good	
644473	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Equipment Properly Labeled?	y	
644474	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Adjusted Amps A Phase V	0	
644475	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Adjusted Amps B Phase V	0	
644476	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Adjusted Amps C Phase V	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
644477	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Operations A Ø	0	
644478	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Operations B Ø	0	
644479	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Operations C Ø	0	
644480	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Operations Ground	0	
644481	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Follow-up Action Required?	n	
644482	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Follow-up Action Required?	n	
644483	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Foundation Condition	Good	
644484	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
644485	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
644486	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	General Comments	no 911 sign	
644487	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
644488	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
644489	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
644490	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
644491	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
644492	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
644493	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
644494	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
644495	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
644496	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
644497	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
644498	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
644499	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
644500	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
644501	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
644502	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
644503	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
644504	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	LTC Totalizer Reading	7617.60	kw
644505	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
644506	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	General Comments		
644507	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
644508	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
644509	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	General Comments		
644510	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
644511	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
644512	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Follow-up Action Required?	n	
644513	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
644514	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
644515	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
644516	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
644517	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
644518	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
644519	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
644520	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
644521	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
644522	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
644523	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
644524	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
644525	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
644526	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
644527	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ok	
644528	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
644529	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	431	
644530	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
644531	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
644532	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
644533	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	431	
644534	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
644535	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
644536	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
644537	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
644538	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Heaters (All) Functioning?	y	
644539	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Grounds in Place?	y	
644540	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	General Comments	ok	
644541	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	General Comments	ok	
644542	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Foundation Condition	Good	
644543	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Follow-up Action Required?	n	
644544	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Follow-up Action Required?	n	
644545	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Operations Ground	0	
644546	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Operations C Ø	0	
644547	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Operations B Ø	0	
644548	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Operations A Ø	0	
644549	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
644550	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
644551	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
644552	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Equipment Properly Labeled?	y	
644553	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Cabinet Paint Condition	Good	
644554	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
644555	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
644556	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
644557	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Bushings Connection/Risers	Good	
644558	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Bushing Condition	Good	
644559	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Amps C Ø	62.0	
644560	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Amps B Ø	62.0	
644561	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Amps A Ø	55.0	
644562	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
644563	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
644564	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
644565	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	9 Month Operations	2	
644566	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
644567	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Tank Leaks	None	
644568	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
644569	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
644570	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
644571	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
644572	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
644573	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
644574	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
644575	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
644576	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
644577	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
644578	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
644579	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	General Comments		
644580	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
644581	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
644582	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
644583	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
644584	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
644585	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
644586	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
644587	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
644588	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
644589	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
644590	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Tank Leaks	None	
644591	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
644592	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	General Comments		
644593	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	General Comments		
644594	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Grounds in Place?	y	
644595	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Heaters (All) Functioning?	y	
644596	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Accumulated Fault Duty A Ph V	53.31	%
644597	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	9 Month Operations	16	
644598	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
644599	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC As Left Counter	15921	
644600	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC As Found Counter	15909	
644601	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	General Comments	ok	
644602	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	General Comments	ok	
644603	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
644604	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	Follow-up Action Required?	n	
644605	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
644606	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
644607	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
644608	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
644609	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
644610	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
644611	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
644612	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
644613	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
644614	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
644615	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
644616	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Bushings Connection/Risers	Good	
644617	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Bushing Oil Level	Good	
644618	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Bushing Condition	Good	
644619	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Maintenance Operations	0	
644620	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Moisture and Leak Free?	y	
644621	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Operations Counter AF	168	
644622	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Operations Counter AL	168	
644623	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
644624	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Switching Operations	0	
644625	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Tank Paint Condition	Good	
644626	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
644627	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	General Comments		
644628	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
644629	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
644630	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
644631	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
644632	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
644633	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
644634	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
644635	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
644636	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Regulator As Left Counter	116766	
644637	1/8/2019 12:07	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
644638	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Unknown Operations	0	
644639	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Tank Paint Condition	Good	
644640	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Switching Operations	0	
644641	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
644642	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Operations Counter AL	182	
644643	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Operations Counter AF	182	
644644	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Moisture and Leak Free?	y	
644645	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Maintenance Operations	0	
644646	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
644647	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
644648	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
644649	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
644650	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
644651	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
644652	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
644653	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
644654	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
644655	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
644656	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
644657	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
644658	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Current Tap Position	6R	
644659	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
644660	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
644661	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
644662	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
644663	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	General Comments	ok	
644664	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
644665	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Max Tap Position	8R	
644666	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Min Tap Position	4R	
644667	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
644668	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
644669	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
644670	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
644671	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
644672	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Regulator As Left Counter	31601	
644673	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
644674	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
644675	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Tank Leaks	None	
644676	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
644677	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
644678	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
644679	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
644680	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
644681	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
644682	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
644683	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Unknown Operations	0	
644684	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
644685	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	General Comments		
644686	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
644687	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
644688	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
644689	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Winding Temp Present	30	°C
644690	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Winding Temp Max	30	°C
644691	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Totalizer Meter Reading	.3760	
644692	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
644693	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Top Oil Temperature Present	30	°C
644694	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Top Oil Temperature Max	40	°C
644695	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
644696	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
644697	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
644698	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
644699	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
644700	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
644701	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Fans Operational?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
644702	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Fans Condition	Good	
644703	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
644704	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
644705	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
644706	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
644707	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
644708	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
644709	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
644710	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
644711	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
644712	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
644713	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
644714	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
644715	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
644716	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
644717	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
644718	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	General Comments		
644719	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
644720	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
644721	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Foundation Condition	Good	
644722	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
644723	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
644724	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
644725	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
644726	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
644727	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
644728	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
644729	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
644730	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
644731	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
644732	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
644733	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
644734	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
644735	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	OK	
644736	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
644737	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
644738	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
644739	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
644740	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BCH001098	Charger	498-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
644741	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BCH001098	Charger	498-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
644742	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BCH001098	Charger	498-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
644743	1/8/2019 12:50	Distribution	Sixth Vein Quarterly Inspection	BCH001098	Charger	498-Battery Charger	Battery Charger Patrol Insp	General Comments	OK	
644744	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
644745	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
644746	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
644747	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
644748	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC Operations Since Last Insp	429	
644749	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC Min Tap Position	14L	
644750	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
644751	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC Max Tap Position	9L	
644752	1/9/2019 7:15	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC Current Tap Position	10L	
644753	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	General Comments		
644754	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Tank Oil Level	Good	
644755	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Tank Leaks	None	
644756	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Switching Operations	1	
644757	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Operations Counter AL	21	
644758	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Operations Counter AF	21	
644759	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Number of Ops last 9 Months	1	
644760	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Moisture and Leak Free?	y	
644761	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Maintenance Operations	0	
644762	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Hydraulic Pressure Acceptable?	y	
644763	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Hydraulic Oil Levels OK?	y	
644764	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Hydraulic Leaks	None	
644765	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Heaters (All) Functioning?	y	
644766	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
644767	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
644768	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Winding Temp Present	30	°C
644769	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Winding Temp Max	55	°C
644770	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Totalizer Meter Reading	.3174	
644771	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Grounds in Place?	y	
644772	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	General Comments		
644773	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	General Comments		
644774	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Gauge(s) Condition	Good	
644775	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Foundation Condition	Good	
644776	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
644777	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Follow-up Action Required?	n	
644778	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Fault Operations	0	
644779	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Equipment Properly Labeled?	y	
644780	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Cabinet Paint Condition	Good	
644781	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
644782	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
644783	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
644784	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Top Oil Temperature Present	30	°C
644785	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Top Oil Temperature Max	40	°C
644786	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
644787	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
644788	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Vegetation	None	
644789	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
644790	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	General Comments	ok	
644791	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
644792	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
644793	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
644794	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
644795	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
644796	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
644797	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Clear of Trash?	y	
644798	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
644799	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
644800	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
644801	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
644802	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
644803	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
644804	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
644805	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
644806	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
644807	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
644808	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
644809	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
644810	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
644811	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
644812	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	LTC Totalizer Reading	9024.00	kw
644813	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
644814	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
644815	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
644816	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
644817	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
644818	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
644819	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
644820	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
644821	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
644822	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
644823	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
644824	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
644825	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
644826	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
644827	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
644828	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
644829	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
644830	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
644831	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	General Comments		
644832	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	General Comments		
644833	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
644834	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
644835	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Follow-up Action Required?	n	
644836	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
644837	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
644838	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
644839	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
644840	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
644841	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
644842	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
644843	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
644844	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
644845	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
644846	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
644847	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
644848	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
644849	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
644850	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
644851	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
644852	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	General Comments	ok	
644853	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
644854	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
644855	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Foundation Condition	Good	
644856	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
644857	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
644858	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
644859	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
644860	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
644861	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Tank Paint Condition	Good	
644862	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Bushings Connection/Risers	Good	
644863	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Bushing Condition	Good	
644864	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Amps C Ø	60.0	
644865	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
644866	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
644867	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
644868	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
644869	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
644870	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
644871	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
644872	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
644873	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
644874	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
644875	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
644876	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
644877	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
644878	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	General Comments	Barbed wire is rusty, and trees are overhanging the fence	
644879	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
644880	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
644881	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
644882	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Reading	.3744	
644883	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
644884	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
644885	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
644886	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
644887	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
644888	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
644889	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
644890	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
644891	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	30	°C
644892	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	55	°C
644893	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
644894	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
644895	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	LTC Totalizer Reading	1198.08	kw
644896	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
644897	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	PF000115	PowerFuse	DA-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
644898	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	PF000115	PowerFuse	DA-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
644899	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments	ok	
644900	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments	ok	
644901	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
644902	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
644903	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
644904	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
644905	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
644906	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
644907	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
644908	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	General Comments	all of fence is getting rusty	
644909	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
644910	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
644911	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
644912	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
644913	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
644914	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
644915	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Foundation Condition	Good	
644916	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
644917	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
644918	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
644919	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
644920	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
644921	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	23	
644922	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	23	
644923	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
644924	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ok	
644925	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
644926	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
644927	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
644928	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
644929	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
644930	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
644931	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
644932	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
644933	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
644934	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
644935	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
644936	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	500.0	
644937	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	500.0	
644938	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	500.0	
644939	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
644940	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
644941	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
644942	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	13	
644943	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
644944	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
644945	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
644946	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
644947	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
644948	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
644949	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
644950	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
644951	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
644952	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
644953	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
644954	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
644955	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
644956	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
644957	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
644958	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	General Comments	ok	
644959	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
644960	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Operations A Ø	0	
644961	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
644962	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
644963	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
644964	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Equipment Properly Labeled?	y	
644965	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Cabinet Paint Condition	Good	
644966	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
644967	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
644968	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
644969	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
644970	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	PF000169	PowerFuse	HC-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
644971	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	PF000169	PowerFuse	HC-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
644972	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
644973	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
644974	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
644975	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
644976	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Vegetation	None	
644977	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
644978	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	General Comments	ok	
644979	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
644980	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
644981	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
644982	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
644983	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
644984	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
644985	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Clear of Trash?	y	
644986	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
644987	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
644988	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
644989	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
644990	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
644991	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
644992	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
644993	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Tank Leaks	None	
644994	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
644995	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
644996	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Regulator As Left Counter	12525	
644997	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
644998	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
644999	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
645000	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
645001	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
645002	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
645003	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	PF000168	PowerFuse	HC-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
645004	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	PF000168	PowerFuse	HC-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
645005	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	PF000166	PowerFuse	HC-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
645006	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	PF000166	PowerFuse	HC-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
645007	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
645008	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
645009	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	General Comments		
645010	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
645011	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
645012	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
645013	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
645014	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
645015	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
645016	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
645017	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
645018	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
645019	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
645020	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
645021	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
645022	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Totalizer Meter Reading	.2196	
645023	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
645024	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
645025	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
645026	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
645027	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
645028	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
645029	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
645030	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
645031	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Tank Leaks	None	
645032	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
645033	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
645034	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Regulator As Left Counter	12558	
645035	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
645036	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
645037	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
645038	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
645039	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
645040	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
645041	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
645042	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
645043	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
645044	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
645045	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
645046	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
645047	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
645048	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
645049	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
645050	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
645051	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
645052	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
645053	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
645054	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
645055	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
645056	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
645057	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
645058	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
645059	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	General Comments	ok	
645060	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
645061	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
645062	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Foundation Condition	Good	
645063	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
645064	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
645065	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
645066	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
645067	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
645068	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
645069	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
645070	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
645071	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
645072	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Max Tap Position	14R	
645073	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
645074	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	General Comments		
645075	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
645076	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
645077	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	General Comments		
645078	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	General Comments		
645079	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Foundation Condition	Good	
645080	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
645081	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
645082	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
645083	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
645084	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
645085	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
645086	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Follow-up Action Required?	n	
645087	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
645088	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
645089	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
645090	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
645091	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	General Comments		
645092	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
645093	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
645094	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
645095	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
645096	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
645097	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
645098	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
645099	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
645100	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Follow-up Action Required?	n	
645101	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	PF001203	PowerFuse	CF-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	ok	
645102	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	PF001203	PowerFuse	CF-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
645103	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Regulator As Left Counter	271398	
645104	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
645105	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Tank Leaks	None	
645106	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
645107	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
645108	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
645109	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	107	
645110	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
645111	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments	ok	
645112	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
645113	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
645114	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
645115	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
645116	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	6.0	
645117	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
645118	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
645119	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
645120	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	General Comments	Didnt have amp meter	
645121	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
645122	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
645123	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	PF000101	PowerFuse	DX-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
645124	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	PF000101	PowerFuse	DX-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
645125	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	216	
645126	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
645127	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
645128	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	180	
645129	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
645130	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
645131	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
645132	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
645133	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
645134	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	5.57	%
645135	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	5.88	%
645136	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	4.95	%
645137	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	95.0	
645138	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	95.0	
645139	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	95.0	
645140	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
645141	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
645142	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
645143	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
645144	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
645145	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
645146	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
645147	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
645148	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
645149	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	62	°C
645150	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	32	°C
645151	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	72	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
645152	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
645153	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	65	°C
645154	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	32	°C
645155	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
645156	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
645157	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
645158	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
645159	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
645160	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
645161	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
645162	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
645163	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
645164	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
645165	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
645166	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
645167	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
645168	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
645169	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	99945	
645170	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	99945	
645171	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
645172	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
645173	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
645174	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
645175	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Unknown Operations	0	
645176	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Tank Paint Condition	Good	
645177	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Switching Operations	4	
645178	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
645179	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Operations Counter AL	166	
645180	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Operations Counter AF	162	
645181	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Moisture and Leak Free?	y	
645182	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Maintenance Operations	0	
645183	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Heaters (All) Functioning?	y	
645184	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Grounds in Place?	y	
645185	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Clear of Trash?	y	
645186	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
645187	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
645188	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
645189	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
645190	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
645191	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
645192	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
645193	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
645194	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
645195	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
645196	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
645197	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	9 Month Operations	4	
645198	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Accumulated Fault Duty A Ph V	.22	%
645199	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Accumulated Fault Duty B Ph V	.22	%
645200	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Accumulated Fault Duty C Ph V	.30	%
645201	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Amps A Ø	21.0	
645202	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Amps B Ø	29.0	
645203	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
645204	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
645205	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
645206	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Amps C Ø	31.0	
645207	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Bushing Condition	Good	
645208	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Bushings Connection/Risers	Good	
645209	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
645210	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
645211	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
645212	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Cabinet Paint Condition	Good	
645213	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Equipment Properly Labeled?	y	
645214	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Adjusted Amps A Phase V	2.00	
645215	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Adjusted Amps B Phase V	2.00	
645216	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Adjusted Amps C Phase V	3.00	
645217	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Operations A Ø	0	
645218	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Operations B Ø	0	
645219	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Operations C Ø	1	
645220	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Operations Ground	0	
645221	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Follow-up Action Required?	n	
645222	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Follow-up Action Required?	n	
645223	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Foundation Condition	Good	
645224	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	General Comments		
645225	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	General Comments		
645226	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
645227	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Heaters (All) Functioning?	y	
645228	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Maintenance Operations	0	
645229	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Moisture and Leak Free?	y	
645230	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Operations Counter AF	170	
645231	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Operations Counter AL	170	
645232	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
645233	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Switching Operations	0	
645234	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Tank Paint Condition	Good	
645235	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Unknown Operations	2	
645236	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	General Comments		
645237	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
645238	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
645239	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
645240	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	205	
645241	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
645242	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
645243	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
645244	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
645245	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	General Comments		
645246	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
645247	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
645248	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
645249	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	171	
645250	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
645251	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
645252	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	191	
645253	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
645254	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
645255	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
645256	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	181	
645257	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Operations Ground	0	
645258	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Operations C Ø	0	
645259	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Operations B Ø	0	
645260	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
645261	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
645262	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
645263	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
645264	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
645265	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
645266	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
645267	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
645268	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
645269	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
645270	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
645271	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
645272	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
645273	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	General Comments		
645274	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
645275	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
645276	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Foundation Condition	Good	
645277	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
645278	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
645279	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
645280	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
645281	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
645282	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
645283	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
645284	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Vegetation	None	
645285	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
645286	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	General Comments		
645287	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
645288	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
645289	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
645290	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
645291	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
645292	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
645293	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
645294	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
645295	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	General Comments		
645296	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
645297	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
645298	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
645299	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
645300	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
645301	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
645302	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
645303	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
645304	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
645305	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
645306	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
645307	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
645308	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ok	
645309	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
645310	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	707	
645311	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	707	
645312	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
645313	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
645314	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Clear of Trash?	y	
645315	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
645316	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
645317	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
645318	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	General Comments		
645319	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
645320	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
645321	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
645322	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
645323	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
645324	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
645325	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
645326	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
645327	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
645328	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
645329	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
645330	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
645331	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
645332	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
645333	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
645334	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
645335	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
645336	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
645337	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
645338	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
645339	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
645340	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	111	
645341	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	111	
645342	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
645343	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ok	
645344	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
645345	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
645346	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
645347	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
645348	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	General Comments	ok	
645349	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
645350	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
645351	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
645352	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
645353	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
645354	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
645355	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
645356	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
645357	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
645358	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
645359	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
645360	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
645361	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
645362	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
645363	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Vegetation	None	
645364	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
645365	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
645366	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
645367	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
645368	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	General Comments	YARD LIGHT IN BACK CORNER NOT WORKING NEED BUCKET TRUCK.	
645369	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
645370	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
645371	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
645372	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
645373	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	11.69	%
645374	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	11.69	%
645375	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	11.69	%
645376	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	70.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
645377	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	70.0	
645378	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	70.0	
645379	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
645380	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
645381	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
645382	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
645383	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
645384	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
645385	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
645386	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
645387	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
645388	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
645389	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Tank Leaks	None	
645390	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
645391	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
645392	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Regulator As Left Counter	46587	
645393	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
645394	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
645395	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
645396	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
645397	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
645398	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
645399	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
645400	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
645401	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
645402	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
645403	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Operations Counter AL	620	
645404	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Operations Counter AF	616	
645405	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Moisture and Leak Free?	y	
645406	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Maintenance Operations	0	
645407	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Heaters (All) Functioning?	y	
645408	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Grounds in Place?	y	
645409	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	General Comments		
645410	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	General Comments		
645411	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Foundation Condition	Good	
645412	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Follow-up Action Required?	n	
645413	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Follow-up Action Required?	n	
645414	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Operations Ground	0	
645415	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Operations C Ø	0	
645416	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Operations B Ø	0	
645417	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Operations A Ø	0	
645418	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
645419	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
645420	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
645421	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Equipment Properly Labeled?	y	
645422	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Cabinet Paint Condition	Good	
645423	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
645424	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
645425	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
645426	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Bushings Connection/Risers	Good	
645427	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Bushing Condition	Good	
645428	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Amps C Ø	360.0	
645429	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Amps B Ø	380.0	
645430	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	9 Month Operations	4	
645431	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
645432	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
645433	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
645434	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Amps A Ø	265.0	
645435	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Amps B Ø	250.0	
645436	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Amps C Ø	235.0	
645437	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Bushing Condition	Good	
645438	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Bushings Connection/Risers	Good	
645439	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
645440	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
645441	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
645442	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Cabinet Paint Condition	Good	
645443	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Equipment Properly Labeled?	y	
645444	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
645445	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
645446	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
645447	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Operations A Ø	0	
645448	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Amps A Ø	360.0	
645449	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
645450	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Accumulated Fault Duty B Ph V	3.64	%
645451	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Accumulated Fault Duty A Ph V	3.64	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
645452	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	9 Month Operations	12	
645453	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	PF000108	PowerFuse	CF-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
645454	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	9 Month Operations	9	
645455	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Foundation Condition	Good	
645456	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
645457	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
645458	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	General Comments	ok	
645459	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
645460	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
645461	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
645462	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
645463	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
645464	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
645465	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
645466	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
645467	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
645468	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
645469	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
645470	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
645471	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Unknown Operations	0	
645472	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
645473	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
645474	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
645475	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
645476	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
645477	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
645478	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Tank Paint Condition	Good	
645479	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Switching Operations	4	
645480	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
645481	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
645482	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
645483	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	120.0	
645484	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	120.0	
645485	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	120.0	
645486	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	40.92	%
645487	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
645488	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	46.76	%
645489	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	43.84	%
645490	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	6	
645491	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
645492	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Broken skirts	
645493	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
645494	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
645495	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
645496	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
645497	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
645498	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
645499	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
645500	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	General Comments		
645501	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	General Comments		
645502	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
645503	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
645504	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
645505	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
645506	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	Oil Temp Max	40	°C
645507	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	Oil Temp Present	38	°C
645508	1/8/2019 9:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
645509	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
645510	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
645511	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
645512	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
645513	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
645514	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
645515	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
645516	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
645517	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Amps B Ø	80.0	
645518	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Amps A Ø	60.0	
645519	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Accumulated Fault Duty C Ph V	1.82	%
645520	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Accumulated Fault Duty B Ph V	1.82	%
645521	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Accumulated Fault Duty A Ph V	4.55	%
645522	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	9 Month Operations	8	
645523	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
645524	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Tank Leaks	None	
645525	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
645526	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
645527	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
645528	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
645529	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	General Comments	ok	
645530	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
645531	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
645532	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
645533	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
645534	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
645535	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
645536	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
645537	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
645538	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
645539	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
645540	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
645541	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
645542	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
645543	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
645544	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	General Comments	A manhole cover missing. the hole is 36 1/2 X 36 1/2 manhole cover needs to be bigger than that. the first one on left by the gate and	
645545	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Regulator As Left Counter	12123	
645546	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
645547	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
645548	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
645549	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
645550	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
645551	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
645552	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
645553	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
645554	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
645555	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
645556	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Foundation Condition	Good	
645557	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
645558	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
645559	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
645560	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
645561	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
645562	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
645563	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
645564	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
645565	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
645566	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
645567	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
645568	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
645569	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
645570	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
645571	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Oil Temp Present	32	°C
645572	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Oil Temp Max	79	°C
645573	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
645574	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
645575	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	LTC Totalizer Reading	1581.12	kw
645576	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
645577	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	General Comments	Added nitrogen	
645578	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	General Comments		
645579	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
645580	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Tank Leaks	None	
645581	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
645582	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Regulator As Left Counter	284590	
645583	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
645584	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
645585	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
645586	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
645587	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
645588	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
645589	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
645590	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
645591	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	General Comments		
645592	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
645593	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
645594	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
645595	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
645596	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
645597	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
645598	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
645599	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
645600	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
645601	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
645602	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
645603	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
645604	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Follow-up Action Required?	n	
645605	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
645606	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
645607	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
645608	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
645609	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
645610	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
645611	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
645612	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
645613	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
645614	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
645615	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
645616	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
645617	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Patrol Inspection	General Comments	ok	
645618	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Follow-up Action Required?	n	
645619	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Patrol Inspection	Follow-up Action Required?	n	
645620	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Operations Ground	0	
645621	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Operations C Ø	0	
645622	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Operations B Ø	0	
645623	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Operations A Ø	0	
645624	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
645625	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
645626	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
645627	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
645628	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Amps C Ø	450.0	
645629	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Amps B Ø	510.0	
645630	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Amps A Ø	450.0	
645631	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Accumulated Fault Duty C Ph AM	7.97	%
645632	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Accumulated Fault Duty B Ph AM	26.58	%
645633	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Accumulated Fault Duty A Ph AM	18.60	%
645634	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	9 Months Operations	3	
645635	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
645636	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
645637	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
645638	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Clear of Trash?	y	
645639	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
645640	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
645641	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
645642	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
645643	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
645644	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
645645	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	General Comments	ok	
645646	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
645647	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Vegetation	None	
645648	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
645649	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
645650	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
645651	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
645652	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
645653	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
645654	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
645655	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
645656	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
645657	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
645658	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
645659	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
645660	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
645661	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124	VAC
645662	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124	VAC
645663	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
645664	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
645665	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
645666	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
645667	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
645668	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
645669	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Foundation Condition	Good	
645670	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
645671	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
645672	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	32	
645673	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	28	
645674	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
645675	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
645676	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
645677	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
645678	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
645679	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
645680	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
645681	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
645682	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
645683	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
645684	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
645685	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
645686	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
645687	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
645688	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
645689	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
645690	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
645691	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
645692	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
645693	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
645694	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	General Comments	Max & Min hands are stuck	
645695	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
645696	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
645697	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
645698	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
645699	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
645700	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
645701	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
645702	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
645703	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
645704	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
645705	1/8/2019 13:28	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
645706	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
645707	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
645708	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
645709	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
645710	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
645711	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.400	millivolts
645712	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.6	VDC
645713	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.6	VDC
645714	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.7	amps
645715	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
645716	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
645717	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	General Comments		
645718	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
645719	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Unknown Operations	0	
645720	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Switching Operations	1	
645721	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Operations Counter AL	211	
645722	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Operations Counter AF	211	
645723	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Maintenance Operations	0	
645724	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	General Comments	ok	
645725	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
645726	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Oil Temp Max	30	°C
645727	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
645728	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
645729	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
645730	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
645731	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
645732	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
645733	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
645734	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
645735	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Compressor Oil Status	Good	
645736	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Leaks	None	
645737	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Pressure OK?	y	
645738	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
645739	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
645740	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
645741	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
645742	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
645743	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
645744	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
645745	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
645746	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
645747	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Regulator As Left Counter	300482	
645748	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
645749	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
645750	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
645751	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
645752	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
645753	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
645754	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Tank Leaks	None	
645755	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
645756	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
645757	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	Follow-up Action Required?	n	
645758	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
645759	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
645760	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	General Comments		
645761	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	General Comments		
645762	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
645763	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	LTC Totalizer Reading	2540.80	kw
645764	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
645765	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
645766	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Ambient Temperature	55	°F
645767	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
645768	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
645769	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
645770	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
645771	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
645772	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Fault Operations	0	
645773	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Follow-up Action Required?	n	
645774	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Follow-up Action Required?	n	
645775	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Foundation Condition	Good	
645776	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
645777	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	General Comments		
645778	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	General Comments		
645779	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
645780	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Regulator As Left Counter	34129	
645781	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
645782	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
645783	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Tank Leaks	None	
645784	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
645785	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
645786	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Vegetation	None	
645787	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	General Comments		
645788	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
645789	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
645790	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
645791	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
645792	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
645793	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
645794	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
645795	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
645796	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC Operations Since Last Insp	0	
645797	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
645798	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC Min Tap Position	3L	
645799	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
645800	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
645801	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
645802	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC As Left Counter	13897	
645803	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC As Found Counter	13885	
645804	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	General Comments		
645805	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	General Comments		
645806	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
645807	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	Follow-up Action Required?	n	
645808	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
645809	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	Follow-up Action Required?	n	
645810	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Unknown Operations	0	
645811	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Switching Operations	2	
645812	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Operations Counter AL	99768	
645813	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
645814	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
645815	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
645816	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
645817	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
645818	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
645819	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
645820	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC Operations Since Last Insp	137	
645821	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC Min Tap Position	9L	
645822	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC Max Tap Position	2L	
645823	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC Current Tap Position	5L	
645824	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
645825	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC As Left Counter	185032	
645826	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC As Found Counter	185030	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
645827	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	General Comments		
645828	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Operations Counter AF	99768	
645829	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Maintenance Operations	0	
645830	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	General Comments	ok	
645831	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Patrol Inspection	General Comments	ok	
645832	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
645833	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	General Comments		
645834	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
645835	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	Follow-up Action Required?	n	
645836	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
645837	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
645838	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
645839	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
645840	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
645841	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
645842	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
645843	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
645844	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
645845	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
645846	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
645847	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	General Comments	ok	
645848	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	General Comments	ok	
645849	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
645850	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
645851	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
645852	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
645853	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Operations Counter AL	52	
645854	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
645855	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
645856	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC Current Tap Position	11L	
645857	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC Max Tap Position	10L	
645858	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
645859	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Tank Leaks	None	
645860	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
645861	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
645862	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Regulator As Left Counter	56094	
645863	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
645864	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
645865	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Tank Leaks	None	
645866	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
645867	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
645868	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Regulator As Left Counter	29285	
645869	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
645870	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
645871	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
645872	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
645873	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
645874	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Min Tap Position	1L	
645875	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Max Tap Position	8R	
645876	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
645877	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	General Comments	ok	
645878	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
645879	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
645880	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
645881	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
645882	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Current Tap Position	5R	
645883	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
645884	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
645885	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
645886	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
645887	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
645888	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
645889	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
645890	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
645891	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
645892	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Min Tap Position	5L	
645893	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Max Tap Position	1R	
645894	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
645895	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	General Comments	ok	
645896	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
645897	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
645898	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
645899	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
645900	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Current Tap Position	3L	
645901	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
645902	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
645903	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
645904	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
645905	1/8/2019 12:01	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
645906	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC Min Tap Position	14L	
645907	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC Operations Since Last Insp	57	
645908	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
645909	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
645910	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
645911	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
645912	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
645913	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
645914	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
645915	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
645916	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
645917	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
645918	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
645919	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
645920	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
645921	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
645922	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
645923	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Tank Leaks	None	
645924	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
645925	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
645926	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Regulator As Left Counter	7068	
645927	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.0	volts
645928	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Clear of Trash?	y	
645929	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
645930	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
645931	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
645932	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Oil Temp Present	30	°C
645933	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
645934	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
645935	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
645936	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
645937	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
645938	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
645939	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
645940	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
645941	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
645942	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
645943	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
645944	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
645945	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
645946	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
645947	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
645948	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	10	
645949	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	26.30	%
645950	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	26.30	%
645951	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	23.38	%
645952	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
645953	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
645954	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	90.0	
645955	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
645956	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
645957	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
645958	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
645959	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Winding Temp Max	30	°C
645960	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Winding Temp Present	30	°C
645961	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
645962	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	Follow-up Action Required?	n	
645963	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
645964	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	General Comments	ok	
645965	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	General Comments	ok	
645966	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC As Found Counter	726	
645967	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC As Left Counter	733	
645968	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
645969	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
645970	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
645971	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
645972	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
645973	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
645974	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	90.0	
645975	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	90.0	
645976	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
645977	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
645978	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Maintenance Operations	0	
645979	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
645980	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Num Operations Last 9 Months	7	
645981	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Operations Counter AF	52	
645982	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
645983	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
645984	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
645985	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
645986	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
645987	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
645988	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
645989	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Vegetation	None	
645990	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
645991	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
645992	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
645993	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
645994	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
645995	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
645996	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
645997	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	120	
645998	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	120	
645999	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
646000	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
646001	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
646002	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	416	
646003	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
646004	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
646005	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
646006	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	102	
646007	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	102	
646008	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
646009	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ok	
646010	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
646011	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
646012	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
646013	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
646014	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
646015	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
646016	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
646017	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
646018	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
646019	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
646020	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
646021	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	400.0	
646022	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Operations A Ø	0	
646023	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Operations B Ø	0	
646024	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Operations C Ø	0	
646025	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Operations Ground	0	
646026	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
646027	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ok	
646028	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
646029	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
646030	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Patrol Inspection	Follow-up Action Required?	n	
646031	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Follow-up Action Required?	n	
646032	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Patrol Inspection	General Comments	ok	
646033	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	General Comments	ok	
646034	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Maintenance Operations	0	
646035	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Operations Counter AF	308	
646036	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Operations Counter AL	308	
646037	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Switching Operations	2	
646038	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Unknown Operations	0	
646039	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
646040	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
646041	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
646042	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	Follow-up Action Required?	n	
646043	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	All Connections OK?	y	
646044	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
646045	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
646046	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
646047	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Evidence of Insects	None	
646048	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
646049	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
646050	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
646051	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
646052	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
646053	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
646054	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Operations B Ø	0	
646055	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Operations A Ø	0	
646056	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
646057	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
646058	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
646059	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	VRR Time Delay	30	Seconds
646060	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
646061	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
646062	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
646063	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	LTC Operation Checked?	y	
646064	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	General Comments	ok	
646065	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
646066	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
646067	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
646068	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC Operations Since Last Insp	224	
646069	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
646070	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
646071	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	9 Months Operations	38	
646072	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Accumulated Fault Duty A Ph AM	21.26	%
646073	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Accumulated Fault Duty B Ph AM	21.26	%
646074	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
646075	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
646076	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
646077	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Accumulated Fault Duty C Ph AM	51.83	%
646078	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Amps A Ø	220.0	
646079	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
646080	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
646081	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
646082	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
646083	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
646084	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
646085	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Foundation Condition	Good	
646086	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
646087	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	General Comments		
646088	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
646089	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
646090	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
646091	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
646092	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
646093	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
646094	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Amps B Ø	210.0	
646095	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Amps C Ø	200.0	
646096	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
646097	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
646098	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
646099	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
646100	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
646101	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
646102	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
646103	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
646104	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Equipment Properly Labeled?	y	
646105	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Cabinet Paint Condition	Good	
646106	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
646107	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
646108	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
646109	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Bushings Connection/Risers	Good	
646110	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
646111	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
646112	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	300.0	
646113	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	200.0	
646114	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	200.0	
646115	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
646116	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
646117	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
646118	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
646119	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
646120	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
646121	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
646122	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
646123	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
646124	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	17	
646125	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
646126	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
646127	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	13	
646128	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
646129	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
646130	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
646131	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
646132	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
646133	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
646134	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	400.0	
646135	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	400.0	
646136	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
646137	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	1.22	%
646138	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
646139	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	17	
646140	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
646141	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
646142	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
646143	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	8L	
646144	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	2L	
646145	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	5L	
646146	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
646147	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	18129	
646148	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	18121	
646149	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments	ok	
646150	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments	ok	
646151	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
646152	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
646153	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC Min Tap Position	9L	
646154	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC Max Tap Position	2L	
646155	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
646156	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC Current Tap Position	5L	
646157	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
646158	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
646159	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
646160	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC As Left Counter	3644	
646161	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
646162	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	General Comments		
646163	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC As Found Counter	3634	
646164	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	General Comments	ok	
646165	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
646166	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	General Comments	ok	
646167	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
646168	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
646169	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
646170	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
646171	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
646172	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	General Comments		
646173	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
646174	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
646175	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
646176	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	General Comments		
646177	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
646178	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
646179	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
646180	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
646181	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
646182	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
646183	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Clear of Trash?	y	
646184	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
646185	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
646186	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
646187	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Bushing Condition	Good	
646188	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Amps C Ø	145.0	
646189	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Amps B Ø	151.0	
646190	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Amps A Ø	125.0	
646191	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Accumulated Fault Duty C Ph V	2.61	%
646192	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Accumulated Fault Duty B Ph V	2.61	%
646193	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Accumulated Fault Duty A Ph V	2.61	%
646194	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	9 Month Operations	3	
646195	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
646196	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Maintenance Operations	0	
646197	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
646198	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
646199	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
646200	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	General Comments		
646201	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
646202	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
646203	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
646204	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	616.32	kw
646205	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
646206	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
646207	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Oil Temp Max	32	°C
646208	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Oil Temp Present	32	°C
646209	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
646210	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
646211	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
646212	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
646213	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
646214	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
646215	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
646216	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
646217	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Totalizer Meter Reading	.5136	
646218	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
646219	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Operations Counter AF	722	
646220	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Operations Counter AL	723	
646221	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
646222	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Switching Operations	1	
646223	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Tank Paint Condition	Good	
646224	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
646225	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
646226	1/8/2019 8:46	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
646227	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
646228	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
646229	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
646230	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
646231	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
646232	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	200.0	
646233	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	200.0	
646234	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
646235	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
646236	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	200.0	
646237	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
646238	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
646239	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
646240	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
646241	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
646242	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
646243	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	VRR Time Delay	40	Seconds
646244	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	VRR Base Voltage AL	1124.0	VAC
646245	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
646246	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
646247	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	LTC Operation Checked?	n	
646248	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	General Comments		
646249	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	Follow-up Action Required?	n	
646250	1/8/2019 13:06	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	All Connections OK?	y	
646251	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
646252	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
646253	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Trash Emptied?	y	
646254	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
646255	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
646256	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
646257	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Panels Dusted?	y	
646258	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
646259	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	All Connections OK?	y	
646260	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
646261	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Battery Overall Condition	Good	
646262	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
646263	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
646264	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
646265	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
646266	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
646267	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
646268	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
646269	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
646270	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
646271	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Fans Operational?	n	
646272	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
646273	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
646274	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Eyewash Solution	Good	
646275	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Follow-up Action Required?	n	
646276	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
646277	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Negative DC Ground	0	VDC
646278	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Positive DC Ground	0	VDC
646279	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
646280	1/8/2019 15:49	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
646281	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
646282	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	Oil Temp Max	30	°C
646283	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	General Comments		
646284	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
646285	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Floor Swept?	y	
646286	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
646287	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
646288	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Evidence of Insects	None	
646289	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
646290	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
646291	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
646292	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
646293	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Broom on Site?	y	
646294	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
646295	1/8/2019 11:58	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
646296	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	Oil Temp Present	25	°C
646297	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
646298	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
646299	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
646300	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
646301	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Clear of Trash?	y	
646302	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
646303	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Number of Ops last 9 Months	2	
646304	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Operations Counter AF	99988	
646305	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Operations Counter AL	99988	
646306	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Pop-off Valve Tested Date	2019-01-08 00:00:00.000000	
646307	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Pressure Vessel Condition	Good	
646308	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Switching Operations	0	
646309	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank 1 Oil Level	Good	
646310	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank 2 Oil level	Good	
646311	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000571	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
646312	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000571	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
646313	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000571	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
646314	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000571	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
646315	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000571	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	n	
646316	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank 3 Oil Level	Good	
646317	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank Leaks	None	
646318	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank Paint Condition	Good	
646319	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Unknown Operations	0	
646320	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5154	
646321	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
646322	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
646323	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
646324	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
646325	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
646326	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
646327	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
646328	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
646329	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
646330	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
646331	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
646332	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
646333	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2473.92	kw
646334	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
646335	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000571	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
646336	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000571	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
646337	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000571	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
646338	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
646339	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
646340	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
646341	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
646342	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
646343	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
646344	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
646345	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
646346	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
646347	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
646348	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	40	°C
646349	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	65	°C
646350	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
646351	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	65	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
646352	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
646353	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
646354	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-2.5	psi
646355	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
646356	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	General Comments	ok	
646357	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
646358	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
646359	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
646360	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
646361	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
646362	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
646363	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
646364	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
646365	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
646366	1/8/2019 15:04	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
646367	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Tank Paint Condition	Good	
646368	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
646369	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
646370	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Switching Operations	2	
646371	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
646372	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
646373	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
646374	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
646375	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	General Comments		
646376	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
646377	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6798	
646378	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
646379	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
646380	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
646381	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
646382	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
646383	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Operations Counter AL	179	
646384	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Operations Counter AF	177	
646385	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Moisture and Leak Free?	y	
646386	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Maintenance Operations	0	
646387	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Grounds in Place?	y	
646388	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	General Comments		
646389	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	General Comments		
646390	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Foundation Condition	Good	
646391	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
646392	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
646393	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	General Comments		
646394	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	General Comments		
646395	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
646396	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
646397	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1719.12	kw
646398	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	530.00	
646399	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	510.00	
646400	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Oil Temp Max	100	°C
646401	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Oil Temp Present	39	°C
646402	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
646403	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
646404	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
646405	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Follow-up Action Required?	n	
646406	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Follow-up Action Required?	n	
646407	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Operations Ground	0	
646408	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Operations C Ø	0	
646409	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Operations B Ø	0	
646410	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Operations A Ø	0	
646411	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
646412	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
646413	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
646414	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Equipment Properly Labeled?	y	
646415	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Cabinet Paint Condition	Good	
646416	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
646417	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
646418	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
646419	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Bushings Connection/Risers	Good	
646420	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Bushing Condition	Good	
646421	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Amps C Ø	100.0	
646422	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Amps B Ø	90.0	
646423	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Amps A Ø	90.0	
646424	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
646425	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
646426	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
646427	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	9 Month Operations	4	
646428	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
646429	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
646430	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
646431	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
646432	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
646433	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
646434	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
646435	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
646436	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
646437	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
646438	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
646439	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
646440	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	General Comments		
646441	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
646442	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Vegetation	None	
646443	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
646444	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	Totalizer Meter Reading	.7940	
646445	1/8/2019 11:59	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
646446	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
646447	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
646448	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Unknown Operations	0	
646449	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
646450	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
646451	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
646452	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
646453	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
646454	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
646455	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
646456	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
646457	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
646458	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
646459	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
646460	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
646461	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
646462	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
646463	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
646464	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
646465	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
646466	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
646467	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
646468	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
646469	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	General Comments	barb wire is broken on NE fence	
646470	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
646471	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
646472	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
646473	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
646474	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
646475	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	General Comments		
646476	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
646477	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
646478	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
646479	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
646480	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	General Comments		
646481	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
646482	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
646483	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
646484	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	543.84	kw
646485	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
646486	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4524	
646487	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3800	
646488	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
646489	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
646490	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
646491	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
646492	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
646493	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
646494	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
646495	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Oil Temp Present	32	°C
646496	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ok	
646497	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
646498	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	116	
646499	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	General Comments		
646500	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
646501	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
646502	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
646503	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
646504	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
646505	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
646506	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
646507	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
646508	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	116	
646509	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
646510	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
646511	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
646512	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
646513	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
646514	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
646515	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
646516	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
646517	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
646518	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Oil Temp Present	38	°C
646519	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Oil Temp Max	68	°C
646520	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
646521	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	55.00	
646522	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1959.84	kw
646523	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
646524	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
646525	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
646526	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	General Comments		
646527	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	General Comments		
646528	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
646529	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
646530	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
646531	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
646532	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
646533	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
646534	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
646535	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
646536	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
646537	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
646538	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
646539	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
646540	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Amps C Ø	550.0	
646541	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
646542	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
646543	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
646544	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
646545	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
646546	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
646547	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
646548	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
646549	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
646550	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
646551	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Switching Operations	0	
646552	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Tank Paint Condition	Good	
646553	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Amps B Ø	550.0	
646554	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Amps A Ø	550.0	
646555	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	2.89	%
646556	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	2.89	%
646557	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	2.89	%
646558	1/8/2019 9:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	9 Months Operations	2	
646559	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
646560	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
646561	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
646562	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
646563	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
646564	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	8.0	VDC
646565	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	8.0	VDC
646566	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
646567	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
646568	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Foundation Condition	Good	
646569	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
646570	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
646571	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	General Comments	Arrester on circuit 1709 Blown	
646572	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
646573	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
646574	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
646575	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
646576	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
646577	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
646578	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
646579	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
646580	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
646581	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
646582	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
646583	1/8/2019 11:56	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
646584	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
646585	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
646586	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Follow-up Action Required?	n	
646587	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
646588	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
646589	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	General Comments		
646590	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	General Comments		
646591	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
646592	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	LTC Totalizer Reading	13440.00	kw
646593	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
646594	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
646595	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Oil Temp Max	55	°C
646596	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Oil Temp Present	50	°C
646597	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
646598	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
646599	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
646600	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
646601	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
646602	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
646603	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
646604	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
646605	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Totalizer Meter Reading	.5600	
646606	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8166	
646607	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
646608	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
646609	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Winding Temp Max	45	°C
646610	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Winding Temp Present	30	°C
646611	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
646612	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
646613	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
646614	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
646615	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
646616	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
646617	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
646618	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
646619	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
646620	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
646621	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
646622	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
646623	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
646624	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	Follow-up Action Required?	n	
646625	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
646626	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
646627	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	General Comments		
646628	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	General Comments		
646629	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
646630	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
646631	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
646632	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
646633	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	Oil Temp Max	20	°C
646634	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	Oil Temp Present	10	°C
646635	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
646636	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
646637	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
646638	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
646639	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
646640	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
646641	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
646642	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
646643	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
646644	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
646645	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
646646	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	Winding Temp Max	10	°C
646647	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	Winding Temp Present	10	°C
646648	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
646649	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
646650	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
646651	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
646652	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
646653	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
646654	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
646655	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
646656	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
646657	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
646658	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
646659	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
646660	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	General Comments		
646661	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
646662	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
646663	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
646664	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
646665	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Foundation Condition	Good	
646666	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
646667	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
646668	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Gauge(s) Condition	Good	
646669	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
646670	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	General Comments	ok	
646671	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	General Comments	ok	
646672	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	General Comments	ok	
646673	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Grounds in Place?	y	
646674	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	General Comments	ok	
646675	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
646676	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
646677	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.8	psi
646678	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
646679	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	Oil Temp Max	65	°C
646680	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
646681	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
646682	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Broken skirts	
646683	1/8/2019 9:32	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
646684	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Unknown Operations	0	
646685	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Heaters (All) Functioning?	y	
646686	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Maintenance Operations	2	
646687	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Moisture and Leak Free?	y	
646688	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
646689	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Bushing Condition	Good	
646690	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Bushing Oil Level	Good	
646691	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
646692	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
646693	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Bushings Connection/Risers	Good	
646694	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
646695	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
646696	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
646697	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Cabinet Paint Condition	Good	
646698	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Equipment Properly Labeled?	y	
646699	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
646700	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Tank Leaks	None	
646701	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
646702	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
646703	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Regulator As Left Counter	7721	
646704	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.0	volts
646705	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
646706	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
646707	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
646708	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
646709	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
646710	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
646711	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
646712	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
646713	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
646714	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
646715	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
646716	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	General Comments		
646717	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
646718	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
646719	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
646720	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
646721	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
646722	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
646723	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
646724	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
646725	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
646726	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
646727	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
646728	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
646729	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
646730	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
646731	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	General Comments	broken strand	
646732	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
646733	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
646734	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
646735	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
646736	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
646737	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
646738	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
646739	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
646740	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Fault Operations	0	
646741	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Follow-up Action Required?	n	
646742	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
646743	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
646744	1/8/2019 9:09	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Follow-up Action Required?	n	
646745	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
646746	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
646747	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
646748	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
646749	1/9/2019 7:37	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
646750	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
646751	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
646752	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
646753	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
646754	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Tank Paint Condition	Good	
646755	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Unknown Operations	0	
646756	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	Oil Temp Present	30	°C
646757	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	Oil Temp Max	30	°C
646758	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
646759	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
646760	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
646761	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
646762	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
646763	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
646764	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
646765	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	General Comments		
646766	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	General Comments		
646767	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
646768	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
646769	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
646770	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
646771	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
646772	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
646773	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
646774	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	9 Month Operations	1	
646775	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
646776	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
646777	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
646778	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000552	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
646779	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000552	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
646780	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000552	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
646781	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000552	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
646782	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000552	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
646783	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000552	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
646784	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000552	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
646785	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
646786	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
646787	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
646788	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Amps A Ø	0.0	
646789	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Amps B Ø	0.0	
646790	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Amps C Ø	0.0	
646791	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Bushing Condition	Good	
646792	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
646793	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
646794	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
646795	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
646796	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
646797	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
646798	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
646799	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
646800	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
646801	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
646802	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	General Comments		
646803	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
646804	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
646805	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
646806	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
646807	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Totalizer Meter Reading	.3138	
646808	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
646809	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
646810	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	General Comments		
646811	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
646812	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
646813	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
646814	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	General Comments		
646815	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
646816	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
646817	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
646818	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
646819	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Amps B Ø	43.0	
646820	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Amps C Ø	34.0	
646821	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Bushing Condition	Good	
646822	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
646823	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Foundation Condition	Good	
646824	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	General Comments	ok	
646825	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
646826	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	127.38	kw
646827	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
646828	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Bushings Connection/Risers	Good	
646829	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
646830	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
646831	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
646832	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
646833	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
646834	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
646835	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	General Comments	ok	
646836	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Grounds in Place?	y	
646837	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Heaters (All) Functioning?	y	
646838	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Maintenance Operations	0	
646839	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Moisture and Leak Free?	y	
646840	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Operations Counter AF	206	
646841	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Operations Counter AL	206	
646842	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
646843	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Switching Operations	0	
646844	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
646845	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
646846	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Amps C Ø	80.0	
646847	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Amps B Ø	70.0	
646848	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
646849	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
646850	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
646851	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
646852	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
646853	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
646854	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Steel Structures Rust Free?	y	
646855	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
646856	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
646857	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
646858	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
646859	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
646860	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
646861	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Top Oil Temperature Max	55	°C
646862	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
646863	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
646864	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
646865	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
646866	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
646867	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
646868	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
646869	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
646870	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
646871	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	General Comments		
646872	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	General Comments		
646873	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
646874	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
646875	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
646876	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
646877	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
646878	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Site Service Trans Condition	OK	
646879	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
646880	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	Oil Temp Max	32	°C
646881	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	Oil Temp Present	32	°C
646882	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
646883	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
646884	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
646885	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
646886	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
646887	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
646888	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
646889	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
646890	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
646891	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
646892	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
646893	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
646894	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Operations A Ø	0	
646895	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Operations B Ø	0	
646896	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Operations C Ø	0	
646897	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Operations Ground	0	
646898	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Follow-up Action Required?	n	
646899	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Follow-up Action Required?	n	
646900	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Foundation Condition	Good	
646901	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	General Comments		
646902	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	General Comments		
646903	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Grounds in Place?	y	
646904	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
646905	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
646906	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
646907	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
646908	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
646909	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
646910	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
646911	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
646912	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	307	
646913	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	307	
646914	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
646915	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
646916	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
646917	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC As Found Counter	50928	
646918	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Maintenance Operations	0	
646919	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Moisture and Leak Free?	y	
646920	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Operations Counter AF	188	
646921	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Bushings Connection/Risers	Good	
646922	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
646923	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Follow-up Action Required?	n	
646924	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
646925	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
646926	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
646927	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	General Comments		
646928	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
646929	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
646930	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	General Comments		
646931	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	General Comments		
646932	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
646933	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.8	psi
646934	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	600	psi
646935	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
646936	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
646937	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	General Comments		
646938	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Bushing Condition	Good	
646939	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
646940	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Foundation Condition	Good	
646941	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000552	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
646942	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000552	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
646943	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	General Comments		
646944	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
646945	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	General Comments		
646946	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Grounds in Place?	y	
646947	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Heaters (All) Functioning?	y	
646948	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	General Comments		
646949	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
646950	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
646951	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Vegetation	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
646952	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
646953	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
646954	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
646955	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
646956	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
646957	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
646958	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
646959	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
646960	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
646961	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
646962	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
646963	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
646964	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Vegetation	None	
646965	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
646966	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
646967	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
646968	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Tank Leaks	None	
646969	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
646970	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
646971	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
646972	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
646973	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
646974	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
646975	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Regulator As Left Counter	89981	
646976	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
646977	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
646978	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
646979	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
646980	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
646981	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
646982	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
646983	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
646984	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
646985	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
646986	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
646987	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
646988	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
646989	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
646990	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
646991	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
646992	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	11.82	%
646993	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	5.46	%
646994	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
646995	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
646996	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
646997	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
646998	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
646999	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
647000	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
647001	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
647002	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
647003	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
647004	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
647005	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
647006	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Operations A Ø	0	
647007	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Operations B Ø	0	
647008	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Operations C Ø	0	
647009	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Operations Ground	0	
647010	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Follow-up Action Required?	n	
647011	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Oil Temp Max	30	°C
647012	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Follow-up Action Required?	n	
647013	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
647014	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
647015	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
647016	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
647017	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
647018	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
647019	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
647020	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
647021	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
647022	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LTCC000520	LTCControl	HC-TRANS 1	LTC Control Insp	All Connections OK?	y	
647023	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LTCC000520	LTCControl	HC-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
647024	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Oil Temp Present	30	°C
647025	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
647026	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LTCC000520	LTCControl	HC-TRANS 1	LTC Control Insp	General Comments	ok	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
647027	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
647028	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
647029	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	9 Month Operations	3	
647030	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LTCC000520	LTCControl	HC-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
647031	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	6.37	%
647032	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
647033	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
647034	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
647035	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
647036	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
647037	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
647038	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
647039	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
647040	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
647041	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
647042	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
647043	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
647044	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
647045	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Amps A Ø	28.0	
647046	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Amps B Ø	22.0	
647047	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Amps C Ø	25.0	
647048	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Bushing Condition	Good	
647049	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Bushings Connection/Risers	Good	
647050	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
647051	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
647052	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
647053	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Cabinet Paint Condition	Good	
647054	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Equipment Properly Labeled?	y	
647055	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
647056	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
647057	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
647058	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Operations A Ø	0	
647059	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Operations B Ø	0	
647060	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Operations C Ø	0	
647061	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	LTC Totalizer Reading	1506.24	kw
647062	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Operations Ground	0	
647063	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Follow-up Action Required?	n	
647064	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Follow-up Action Required?	n	
647065	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
647066	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
647067	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	General Comments	ok	
647068	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	General Comments	ok	
647069	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
647070	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
647071	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
647072	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	General Comments		
647073	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	9 Month Operations	2	
647074	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
647075	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
647076	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
647077	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Amps A Ø	29.0	
647078	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
647079	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
647080	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
647081	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
647082	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
647083	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
647084	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
647085	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
647086	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
647087	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	General Comments	no 911 sign	
647088	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
647089	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	Follow-up Action Required?	n	
647090	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
647091	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
647092	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Clear of Trash?	y	
647093	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
647094	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	General Comments	ok	
647095	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
647096	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
647097	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
647098	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	General Comments	ok	
647099	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
647100	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
647101	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Ambient Temp	55	°F

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
647102	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
647103	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
647104	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
647105	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
647106	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
647107	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Clear of Trash?	y	
647108	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
647109	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
647110	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Ambient Temp	59	°F
647111	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
647112	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
647113	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
647114	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
647115	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
647116	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
647117	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Equipment Properly Labeled?	y	
647118	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Cabinet Paint Condition	Good	
647119	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
647120	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
647121	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
647122	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
647123	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
647124	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
647125	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
647126	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
647127	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
647128	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
647129	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
647130	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
647131	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
647132	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Accumulated Fault Duty A Ph V	4.99	%
647133	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
647134	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
647135	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
647136	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
647137	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
647138	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
647139	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Oil Temp Max	50	°C
647140	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
647141	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
647142	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
647143	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC As Left Counter	30413	
647144	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
647145	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC As Found Counter	30413	
647146	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
647147	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
647148	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
647149	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
647150	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	General Comments		
647151	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
647152	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
647153	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	9 Month Operations	12	
647154	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
647155	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Operations A Ø	0	
647156	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Operations B Ø	0	
647157	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	General Comments		
647158	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
647159	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Totalizer Meter Reading	.3650	
647160	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Winding Temp Max	30	°C
647161	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
647162	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
647163	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Oil Temp Max	60	°C
647164	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
647165	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
647166	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
647167	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
647168	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
647169	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	LTC Totalizer Reading	2480.64	kw
647170	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
647171	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Unknown Operations	0	
647172	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
647173	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
647174	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Accumulated Fault Duty B Ph V	4.49	%
647175	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
647176	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.2123	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
647177	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	o	
647178	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
647179	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
647180	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6618	
647181	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
647182	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
647183	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
647184	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
647185	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
647186	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
647187	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	General Comments	no transformer	
647188	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
647189	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
647190	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
647191	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
647192	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
647193	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
647194	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
647195	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
647196	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
647197	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
647198	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Oil Temp Present	45	°C
647199	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
647200	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
647201	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
647202	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	LTC Totalizer Reading	8760.00	kw
647203	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
647204	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	General Comments		
647205	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
647206	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
647207	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
647208	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
647209	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
647210	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	General Comments	ok	
647211	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC As Found Counter	44150	
647212	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
647213	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
647214	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC As Left Counter	44150	
647215	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
647216	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC Current Tap Position	4L	
647217	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
647218	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Oil Temp Max	70	°C
647219	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
647220	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC Max Tap Position	2R	
647221	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC Min Tap Position	10L	
647222	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC Operations Since Last Insp	269	
647223	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Follow-up Action Required?	n	
647224	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
647225	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
647226	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
647227	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
647228	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
647229	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
647230	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
647231	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
647232	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
647233	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
647234	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
647235	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
647236	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	Follow-up Action Required?	n	
647237	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
647238	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Operations C Ø	0	
647239	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Operations Ground	0	
647240	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Follow-up Action Required?	n	
647241	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Follow-up Action Required?	n	
647242	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
647243	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
647244	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
647245	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Unknown Operations	0	
647246	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
647247	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
647248	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Tank Paint Condition	Good	
647249	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Switching Operations	0	
647250	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Operations Counter AL	172	
647251	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Fans Operational?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
647252	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
647253	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Operations Counter AF	172	
647254	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Moisture and Leak Free?	y	
647255	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Follow-up Action Required?	n	
647256	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
647257	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
647258	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Unknown Operations	0	
647259	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Tank Paint Condition	Good	
647260	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Switching Operations	0	
647261	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
647262	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Foundation Condition	Good	
647263	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	General Comments	ok	
647264	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Operations Counter AL	159	
647265	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Operations Counter AF	159	
647266	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Moisture and Leak Free?	y	
647267	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Maintenance Operations	0	
647268	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Heaters (All) Functioning?	y	
647269	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Grounds in Place?	y	
647270	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	General Comments	ok	
647271	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
647272	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
647273	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
647274	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
647275	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
647276	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
647277	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
647278	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
647279	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Panels Dusted?	y	
647280	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
647281	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
647282	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	General Comments		
647283	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
647284	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
647285	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Floor Swept?	y	
647286	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
647287	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
647288	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
647289	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	227.50	
647290	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4764.96	kw
647291	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
647292	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
647293	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
647294	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	681	
647295	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	677	
647296	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
647297	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
647298	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
647299	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	General Comments	ok	
647300	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	General Comments	no fans	
647301	1/8/2019 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
647302	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
647303	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
647304	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
647305	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
647306	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
647307	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
647308	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	General Comments	ok	
647309	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	General Comments	ok	
647310	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
647311	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
647312	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
647313	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
647314	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
647315	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
647316	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Tank Paint Condition	Good	
647317	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Switching Operations	4	
647318	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
647319	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Operations Counter AL	0	
647320	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
647321	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Winding Temp Max	70	°C
647322	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Winding Temp Present	30	°C
647323	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
647324	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
647325	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ok	
647326	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
647327	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
647328	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
647329	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	General Comments	ok	
647330	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
647331	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
647332	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
647333	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
647334	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
647335	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
647336	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
647337	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
647338	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC Min Tap Position	12L	
647339	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC Max Tap Position	1L	
647340	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC Current Tap Position	6L	
647341	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
647342	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
647343	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Operating Linkage OK?	y	
647344	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
647345	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Linkage Grounds in Place?	y	
647346	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
647347	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC As Left Counter	50928	
647348	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
647349	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC Current Tap Position	9L	
647350	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
647351	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	General Comments		
647352	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
647353	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
647354	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
647355	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
647356	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Unknown Operations	0	
647357	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Tank Paint Condition	Good	
647358	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Switching Operations	0	
647359	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
647360	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
647361	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	281	
647362	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
647363	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Operations Counter AL	166	
647364	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Operations Counter AF	166	
647365	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Moisture and Leak Free?	y	
647366	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Maintenance Operations	0	
647367	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7662	
647368	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
647369	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
647370	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
647371	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
647372	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
647373	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
647374	1/8/2019 13:27	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC Operations Since Last Insp	328	
647375	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
647376	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
647377	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
647378	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
647379	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
647380	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
647381	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	General Comments		
647382	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
647383	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
647384	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
647385	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
647386	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Oil Temp Present	32	°C
647387	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Oil Temp Max	65	°C
647388	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
647389	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	207.50	
647390	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2758.32	kw
647391	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
647392	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
647393	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	7.0	psi
647394	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
647395	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	General Comments		
647396	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	General Comments		
647397	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
647398	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
647399	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Foundation Condition	Good	
647400	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
647401	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
647402	1/8/2019 10:36	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
647403	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
647404	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
647405	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
647406	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
647407	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
647408	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
647409	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
647410	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
647411	1/8/2019 10:48	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
647412	1/8/2019 14:05	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Top Oil Temperature Present	30	°C
647413	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
647414	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC Operations Since Last Insp	320	
647415	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
647416	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
647417	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
647418	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
647419	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
647420	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
647421	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
647422	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Oil Temp Present	0	°C
647423	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
647424	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
647425	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
647426	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Totalizer Meter Reading	.7752	
647427	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
647428	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
647429	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
647430	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
647431	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC As Left Counter	66302	
647432	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC As Found Counter	66302	
647433	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	General Comments	ok	
647434	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
647435	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
647436	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
647437	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
647438	1/8/2019 8:32	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
647439	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
647440	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
647441	1/8/2019 10:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
647442	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	Follow-up Action Required?	n	
647443	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
647444	1/10/2019 10:03	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	General Comments		
647445	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
647446	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
647447	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
647448	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
647449	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
647450	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
647451	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
647452	1/8/2019 10:05	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
647453	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
647454	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
647455	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Equipment Properly Labeled?	y	
647456	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Cabinet Paint Condition	Good	
647457	1/8/2019 9:43	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
647458	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Accumulated Fault Duty C Ph V	6.98	%
647459	1/8/2019 14:18	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Amps A Ø	80.0	
647460	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Heaters (All) Functioning?	y	
647461	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Grounds in Place?	y	
647462	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	General Comments	ok	
647463	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	General Comments	ok	
647464	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
647465	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Foundation Condition	Good	
647466	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Foundation Condition	Good	
647467	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
647468	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Follow-up Action Required?	n	
647469	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Follow-up Action Required?	n	
647470	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Operations Ground	0	
647471	1/8/2019 12:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Operations C Ø	0	
647472	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
647473	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
647474	1/8/2019 11:23	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
647475	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
647476	1/8/2019 12:09	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
647477	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
647478	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Oil Temp Max	28	°C
647479	1/8/2019 12:26	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
647480	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	General Comments	ok	
647481	1/8/2019 9:53	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
647482	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC Min Tap Position	13L	
647483	1/8/2019 15:36	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
647484	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
647485	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.3018	
647486	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	32	°C
647487	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	45	°C
647488	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45	
647489	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	965.76	kw
647490	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
647491	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
647492	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
647493	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
647494	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
647495	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
647496	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
647497	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
647498	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
647499	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
647500	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
647501	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
647502	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
647503	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
647504	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
647505	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
647506	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
647507	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
647508	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
647509	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
647510	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
647511	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
647512	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
647513	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
647514	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
647515	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50	
647516	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
647517	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
647518	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
647519	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
647520	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
647521	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
647522	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
647523	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
647524	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
647525	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
647526	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	-70.3	VDC
647527	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	66.7	VDC
647528	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
647529	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
647530	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
647531	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
647532	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
647533	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC Operations Since Last Insp	140	
647534	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
647535	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
647536	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
647537	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
647538	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
647539	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
647540	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
647541	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Foundation Condition	Good	
647542	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Vegetation	None	
647543	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
647544	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	General Comments	ok	
647545	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
647546	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC Min Tap Position	9L	
647547	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Amps C Ø	0.0	
647548	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Amps B Ø	0.0	
647549	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Amps A Ø	0.0	
647550	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
647551	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
647552	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
647553	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	9 Month Operations	0	
647554	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
647555	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
647556	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
647557	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
647558	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC Max Tap Position	1L	
647559	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Follow-up Action Required?	y	
647560	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
647561	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
647562	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
647563	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC Current Tap Position	3L	
647564	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
647565	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
647566	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
647567	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
647568	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
647569	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC As Left Counter	31188	
647570	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
647571	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
647572	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
647573	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Clear of Trash?	y	
647574	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
647575	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
647576	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
647577	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
647578	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Vegetation	None	
647579	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC As Found Counter	31185	
647580	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	General Comments		
647581	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	General Comments		
647582	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
647583	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	Follow-up Action Required?	n	
647584	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Follow-up Action Required?	n	
647585	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Follow-up Action Required?	n	
647586	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Operations Ground	0	
647587	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Operations C Ø	0	
647588	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Operations B Ø	0	
647589	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Operations A Ø	0	
647590	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
647591	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
647592	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
647593	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
647594	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Accumulated Fault Duty C Ph V	49.48	%
647595	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Accumulated Fault Duty B Ph V	44.65	%
647596	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Accumulated Fault Duty A Ph V	44.65	%
647597	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	9 Month Operations	2	
647598	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	9 Month Operations	34	
647599	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	General Comments		
647600	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
647601	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	General Comments		
647602	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Operations A Ø	0	
647603	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
647604	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
647605	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
647606	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
647607	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Amps A Ø	0.0	
647608	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Amps B Ø	0.0	
647609	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Amps C Ø	0.0	
647610	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
647611	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
647612	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
647613	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
647614	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
647615	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
647616	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
647617	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
647618	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
647619	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
647620	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
647621	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
647622	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
647623	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
647624	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
647625	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
647626	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	9 Month Operations	9	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
647627	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
647628	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	General Comments	station needs varmint guard	
647629	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Moisture and Leak Free?	y	
647630	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Maintenance Operations	0	
647631	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
647632	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
647633	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
647634	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Grounds in Place?	y	
647635	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	General Comments		
647636	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	General Comments		
647637	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Heaters (All) Functioning?	y	
647638	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Grounds in Place?	y	
647639	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	General Comments		
647640	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	General Comments		
647641	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Foundation Condition	Good	
647642	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Heaters (All) Functioning?	y	
647643	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Operations A Ø	0	
647644	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Operations B Ø	0	
647645	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Maintenance Operations	0	
647646	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Moisture and Leak Free?	y	
647647	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
647648	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
647649	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
647650	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
647651	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
647652	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Amps C Ø	245.0	
647653	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
647654	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
647655	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
647656	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Tank Paint Condition	Good	
647657	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Unknown Operations	3	
647658	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
647659	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
647660	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments		
647661	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
647662	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
647663	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Vegetation	None	
647664	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
647665	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Operations Counter AL	142	
647666	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
647667	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Switching Operations	2	
647668	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Tank Paint Condition	Good	
647669	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Unknown Operations	0	
647670	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
647671	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
647672	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
647673	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
647674	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
647675	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Foundation Condition	Good	
647676	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
647677	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
647678	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	General Comments	ok	
647679	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
647680	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
647681	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
647682	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
647683	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
647684	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
647685	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
647686	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Follow-up Action Required?	n	
647687	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Switching Operations	7	
647688	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Tank Paint Condition	Good	
647689	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
647690	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
647691	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
647692	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
647693	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
647694	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
647695	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Unknown Operations	0	
647696	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
647697	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
647698	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
647699	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
647700	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
647701	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
647702	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
647703	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Unknown Operations	0	
647704	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Unknown Operations	0	
647705	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Switching Operations	1	
647706	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
647707	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Operations Counter AL	241	
647708	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Operations Counter AF	240	
647709	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
647710	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
647711	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
647712	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Equipment Properly Labeled?	y	
647713	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Cabinet Paint Condition	Good	
647714	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
647715	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
647716	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
647717	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
647718	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.5	VDC
647719	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.5	VDC
647720	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
647721	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
647722	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
647723	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
647724	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
647725	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
647726	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
647727	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
647728	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
647729	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
647730	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
647731	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	General Comments	ok	
647732	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
647733	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Amps A Ø	270.0	
647734	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Amps B Ø	320.0	
647735	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Operations C Ø	0	
647736	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Operations Ground	0	
647737	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
647738	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Follow-up Action Required?	n	
647739	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Foundation Condition	Good	
647740	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Bushings Connection/Risers	Good	
647741	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Bushing Condition	Good	
647742	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Amps C Ø	0.0	
647743	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Amps B Ø	0.0	
647744	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Amps A Ø	0.0	
647745	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	General Comments		
647746	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	General Comments		
647747	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Grounds in Place?	y	
647748	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
647749	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Maintenance Operations	0	
647750	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
647751	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
647752	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
647753	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	9 Month Operations	5	
647754	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Operations Counter AF	131	
647755	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Operations Counter AL	131	
647756	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
647757	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Switching Operations	0	
647758	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Operations Counter AF	140	
647759	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	General Comments		
647760	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
647761	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
647762	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
647763	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
647764	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
647765	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
647766	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Clear of Trash?	y	
647767	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
647768	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	General Comments		
647769	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Foundation Condition	Good	
647770	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Follow-up Action Required?	n	
647771	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Follow-up Action Required?	n	
647772	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Operations Ground	0	
647773	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Operations C Ø	0	
647774	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Operations B Ø	0	
647775	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
647776	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
647777	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Totalizer Meter Reading	.948	
647778	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	400.00	
647779	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Oil Temp Max	100	°C
647780	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Oil Temp Present	35	°C
647781	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
647782	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
647783	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
647784	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
647785	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
647786	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
647787	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
647788	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
647789	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
647790	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
647791	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
647792	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
647793	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
647794	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	150.0	
647795	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Operations Ground	0	
647796	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Operations C Ø	0	
647797	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Operations B Ø	0	
647798	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Operations A Ø	0	
647799	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
647800	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
647801	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
647802	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Equipment Properly Labeled?	y	
647803	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Cabinet Paint Condition	Good	
647804	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
647805	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
647806	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
647807	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Amps C Ø	0.0	
647808	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Amps B Ø	0.0	
647809	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	LTCC000137	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
647810	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	LTCC000137	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124	VAC
647811	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	LTCC000137	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124	VAC
647812	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	LTCC000137	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
647813	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Operations A Ø	0	
647814	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
647815	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	170.0	
647816	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
647817	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
647818	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	General Comments		
647819	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
647820	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
647821	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
647822	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
647823	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
647824	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
647825	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
647826	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
647827	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
647828	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
647829	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
647830	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
647831	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
647832	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
647833	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
647834	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Equipment Properly Labeled?	y	
647835	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Equipment Properly Labeled?	y	
647836	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Cabinet Paint Condition	Good	
647837	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
647838	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
647839	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
647840	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Heaters (All) Functioning?	y	
647841	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Maintenance Operations	0	
647842	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Moisture and Leak Free?	y	
647843	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	44.7	
647844	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	45.0	
647845	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	50.9	
647846	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
647847	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
647848	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Bushings Connection/Risers	Good	
647849	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Bushing Condition	Good	
647850	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Amps C Ø	140	
647851	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
647852	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Amps B Ø	140	
647853	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Amps A Ø	140	
647854	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
647855	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
647856	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments	ok	
647857	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
647858	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Accumulated Fault Duty C Ph V	0	%
647859	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Accumulated Fault Duty B Ph V	0	%
647860	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Accumulated Fault Duty A Ph V	0	%
647861	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	9 Month Operations	5	
647862	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
647863	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
647864	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
647865	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
647866	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	170.0	
647867	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Operations Counter AF	210	
647868	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Moisture and Leak Free?	y	
647869	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Maintenance Operations	0	
647870	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Heaters (All) Functioning?	y	
647871	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Grounds in Place?	y	
647872	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	General Comments		
647873	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	General Comments		
647874	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Follow-up Action Required?	n	
647875	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Follow-up Action Required?	n	
647876	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	678	
647877	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
647878	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
647879	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
647880	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
647881	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
647882	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Operations A Ø	0	
647883	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
647884	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
647885	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
647886	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
647887	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
647888	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
647889	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	General Comments	ok	
647890	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	General Comments	ok	
647891	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
647892	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
647893	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	367.68	kw
647894	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Operations B Ø	0	
647895	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Operations C Ø	0	
647896	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Operations Ground	0	
647897	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Follow-up Action Required?	n	
647898	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Follow-up Action Required?	n	
647899	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	General Comments		
647900	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	415.00	
647901	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	General Comments		
647902	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Moisture and Leak Free?	y	
647903	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Adjusted Amps C Phase V	0	
647904	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Adjusted Amps B Phase V	0	
647905	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Adjusted Amps A Phase V	0	
647906	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
647907	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Operations Counter AF	207	
647908	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Operations Counter AL	208	
647909	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
647910	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Switching Operations	1	
647911	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Unknown Operations	0	
647912	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
647913	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
647914	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
647915	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BCH000310	Charger	421-Battery Charger	Battery Charger Patrol Insp	General Comments		
647916	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BCH000310	Charger	421-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
647917	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BCH000310	Charger	421-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	56.0	VDC
647918	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
647919	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
647920	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
647921	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Bushing Condition	Good	
647922	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Amps C Ø	290	
647923	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Amps B Ø	300	
647924	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Amps A Ø	240	
647925	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
647926	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
647927	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
647928	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
647929	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
647930	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
647931	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
647932	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
647933	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
647934	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
647935	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
647936	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
647937	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
647938	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	General Comments	ok	
647939	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
647940	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
647941	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	2R	
647942	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
647943	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
647944	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
647945	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Tank Leaks	None	
647946	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
647947	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Accumulated Fault Duty C Ph V	0	%
647948	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Accumulated Fault Duty B Ph V	0	%
647949	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Accumulated Fault Duty A Ph V	0	%
647950	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
647951	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
647952	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
647953	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
647954	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	9 Month Operations	0	
647955	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments	hand position not working	
647956	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
647957	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	1R	
647958	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	LTCC000137	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
647959	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
647960	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
647961	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
647962	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	27244	
647963	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
647964	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
647965	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
647966	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
647967	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
647968	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	1R	
647969	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Cabinet Paint Condition	Good	
647970	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
647971	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
647972	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
647973	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Oil Temp Present	30	°C
647974	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Oil Temp Max	30	°C
647975	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
647976	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
647977	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	LTC Totalizer Reading	9100.8	kw
647978	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
647979	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	General Comments		
647980	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	General Comments		
647981	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
647982	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
647983	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Follow-up Action Required?	n	
647984	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
647985	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
647986	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
647987	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
647988	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
647989	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
647990	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	General Comments		
647991	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Grounds in Place?	y	
647992	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Heaters (All) Functioning?	y	
647993	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Amps A Ø	0.0	
647994	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
647995	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
647996	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
647997	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	9 Month Operations	5	
647998	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	9 Month Operations	24	
647999	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Accumulated Fault Duty A Ph V	1.83	%
648000	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Maintenance Operations	0	
648001	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
648002	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Accumulated Fault Duty B Ph V	1.22	%
648003	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Accumulated Fault Duty C Ph V	3.05	%
648004	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	LTCC000137	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
648005	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	LTCC000137	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
648006	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	LTCC000137	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
648007	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Amps A Ø	0.0	
648008	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Amps B Ø	0.0	
648009	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Amps C Ø	0.0	
648010	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
648011	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Unknown Operations	0	
648012	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Tank Paint Condition	Good	
648013	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Switching Operations	0	
648014	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Operations Counter AL	111	
648015	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Operations Counter AF	111	
648016	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
648017	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
648018	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
648019	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.1532	
648020	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Maintenance Operations	0	
648021	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
648022	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Grounds in Place?	y	
648023	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	General Comments		
648024	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	General Comments		
648025	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Foundation Condition	Good	
648026	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Follow-up Action Required?	n	
648027	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
648028	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
648029	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
648030	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
648031	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
648032	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Follow-up Action Required?	n	
648033	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Operations Ground	0	
648034	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Operations C Ø	0	
648035	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Operations B Ø	0	
648036	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Operations A Ø	0	
648037	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
648038	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
648039	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
648040	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
648041	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
648042	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
648043	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
648044	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
648045	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
648046	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Operations Counter AL	159	
648047	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Operations Counter AF	152	
648048	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
648049	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Maintenance Operations	0	
648050	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Grounds in Place?	y	
648051	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	General Comments		
648052	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	General Comments		
648053	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Foundation Condition	Good	
648054	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Follow-up Action Required?	n	
648055	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Follow-up Action Required?	n	
648056	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
648057	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
648058	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Operations Ground	0	
648059	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Operations C Ø	0	
648060	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Operations B Ø	0	
648061	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Operations A Ø	0	
648062	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
648063	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
648064	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
648065	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
648066	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
648067	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
648068	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
648069	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
648070	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Amps C Ø	150.0	
648071	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Amps B Ø	180.0	
648072	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
648073	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
648074	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
648075	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	General Comments	ok	
648076	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Amps A Ø	150.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
648077	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
648078	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
648079	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
648080	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
648081	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
648082	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
648083	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
648084	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
648085	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Maintenance Operations	4	
648086	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Moisture and Leak Free?	y	
648087	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Operations Counter AF	198	
648088	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Operations Counter AL	198	
648089	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
648090	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
648091	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
648092	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
648093	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	General Comments	ok	
648094	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
648095	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
648096	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
648097	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
648098	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
648099	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
648100	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
648101	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
648102	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
648103	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Clear of Trash?	y	
648104	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Grounds in Place?	y	
648105	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Heaters (All) Functioning?	y	
648106	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Operations B Ø	0	
648107	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Operations C Ø	0	
648108	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Operations Ground	0	
648109	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
648110	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Follow-up Action Required?	n	
648111	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
648112	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
648113	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
648114	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
648115	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
648116	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
648117	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
648118	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
648119	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
648120	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
648121	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
648122	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Switching Operations	1	
648123	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Foundation Condition	Good	
648124	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	General Comments		
648125	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	General Comments		
648126	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Grounds in Place?	y	
648127	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Maintenance Operations	0	
648128	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
648129	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Operations Counter AF	0	
648130	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Operations Counter AL	0	
648131	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	57	
648132	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
648133	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Evidence of Insects	None	
648134	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
648135	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
648136	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Switching Operations	0	
648137	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Tank Paint Condition	Good	
648138	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Unknown Operations	0	
648139	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
648140	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
648141	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
648142	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
648143	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
648144	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	General Comments	ok	
648145	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
648146	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
648147	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
648148	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
648149	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Floor Swept?	y	
648150	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
648151	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
648152	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	General Comments	ok	
648153	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
648154	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
648155	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Panels Dusted?	y	
648156	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
648157	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
648158	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
648159	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
648160	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
648161	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
648162	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Tank Leaks	None	
648163	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
648164	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
648165	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
648166	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
648167	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
648168	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
648169	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
648170	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
648171	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
648172	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
648173	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	General Comments	ok	
648174	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
648175	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
648176	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
648177	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
648178	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
648179	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
648180	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
648181	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
648182	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
648183	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
648184	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
648185	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
648186	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	General Comments		
648187	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Amps A Ø	130.0	
648188	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Amps B Ø	185.0	
648189	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Amps C Ø	125.0	
648190	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
648191	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
648192	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
648193	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Cabinet Paint Condition	Good	
648194	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Equipment Properly Labeled?	y	
648195	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
648196	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
648197	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
648198	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
648199	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Operations Counter AL	112	
648200	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
648201	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
648202	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
648203	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
648204	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
648205	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
648206	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Unknown Operations	0	
648207	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Tank Paint Condition	Good	
648208	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Switching Operations	0	
648209	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
648210	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Clear of Trash?	y	
648211	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
648212	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
648213	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Operations Counter AL	297	
648214	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Operations Counter AF	297	
648215	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Moisture and Leak Free?	y	
648216	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Maintenance Operations	0	
648217	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Heaters (All) Functioning?	y	
648218	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Grounds in Place?	y	
648219	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	General Comments		
648220	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	General Comments		
648221	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Foundation Condition	Good	
648222	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Follow-up Action Required?	n	
648223	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Follow-up Action Required?	n	
648224	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Operations Counter AF	106	
648225	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Moisture and Leak Free?	y	
648226	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
648227	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Operations Ground	0	
648228	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
648229	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
648230	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Grounds in Place?	y	
648231	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
648232	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
648233	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Operations C Ø	0	
648234	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Operations B Ø	0	
648235	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Operations A Ø	0	
648236	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Adjusted Amps C Phase V	0	
648237	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Adjusted Amps B Phase V	0	
648238	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Adjusted Amps A Phase V	0	
648239	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
648240	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
648241	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
648242	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
648243	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
648244	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
648245	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	General Comments	ok	
648246	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
648247	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
648248	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Regulator As Left Counter	23208	
648249	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
648250	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Tank Leaks	None	
648251	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
648252	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Operations Counter AL	211	
648253	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
648254	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	9 Month Operations	19	
648255	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
648256	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
648257	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
648258	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
648259	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
648260	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
648261	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
648262	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
648263	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
648264	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
648265	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
648266	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
648267	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	General Comments		
648268	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
648269	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
648270	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Foundation Condition	Good	
648271	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
648272	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
648273	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
648274	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
648275	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
648276	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
648277	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
648278	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
648279	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
648280	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Unknown Operations	0	
648281	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Tank Paint Condition	Good	
648282	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Switching Operations	6	
648283	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	9 Month Operations	7	
648284	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Accumulated Fault Duty A Ph V	.67	%
648285	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Accumulated Fault Duty B Ph V	.67	%
648286	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Switching Operations	0	
648287	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Tank Paint Condition	Good	
648288	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Unknown Operations	0	
648289	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Vegetation	None	
648290	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
648291	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
648292	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
648293	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
648294	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
648295	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
648296	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Vegetation	None	
648297	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
648298	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Accumulated Fault Duty C Ph V	.67	%
648299	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
648300	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
648301	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
648302	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
648303	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
648304	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
648305	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Foundation Condition	Good	
648306	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
648307	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Unknown Operations	0	
648308	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
648309	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
648310	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
648311	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	General Comments		
648312	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
648313	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
648314	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Foundation Condition	Good	
648315	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
648316	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
648317	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
648318	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
648319	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
648320	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
648321	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
648322	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
648323	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
648324	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
648325	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
648326	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
648327	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
648328	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
648329	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
648330	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
648331	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	General Comments		
648332	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
648333	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
648334	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
648335	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
648336	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
648337	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
648338	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
648339	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
648340	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Regulator As Left Counter	88329	
648341	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
648342	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Tank Leaks	None	
648343	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
648344	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
648345	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
648346	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Winding Temp Present	40	°C
648347	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Winding Temp Max	65	°C
648348	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Totalizer Meter Reading	.4370	
648349	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
648350	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	General Comments		
648351	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	9 Month Operations	4	
648352	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Accumulated Fault Duty A Ph V	7.72	%
648353	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Accumulated Fault Duty B Ph V	8.58	%
648354	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
648355	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
648356	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
648357	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Accumulated Fault Duty C Ph V	7.72	%
648358	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Amps A Ø	190.0	
648359	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Amps B Ø	190.0	
648360	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Amps C Ø	170.0	
648361	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
648362	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
648363	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
648364	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Cabinet Paint Condition	Good	
648365	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Equipment Properly Labeled?	y	
648366	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
648367	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
648368	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
648369	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Operations A Ø	0	
648370	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Operations B Ø	0	
648371	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Operations C Ø	0	
648372	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Operations Ground	0	
648373	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Follow-up Action Required?	n	
648374	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Follow-up Action Required?	n	
648375	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	General Comments		
648376	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
648377	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Grounds in Place?	y	
648378	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Heaters (All) Functioning?	y	
648379	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Maintenance Operations	0	
648380	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Moisture and Leak Free?	y	
648381	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Operations Counter AF	194	
648382	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
648383	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
648384	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
648385	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
648386	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
648387	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
648388	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Operations Counter AL	195	
648389	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
648390	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Switching Operations	1	
648391	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
648392	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
648393	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Cabinet Paint Condition	Good	
648394	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Equipment Properly Labeled?	y	
648395	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Adjusted Amps A Phase V	6.69	
648396	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
648397	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Adjusted Amps C Phase V	6.69	
648398	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Operations A Ø	1	
648399	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Operations B Ø	0	
648400	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Operations C Ø	1	
648401	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Operations Ground	0	
648402	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Follow-up Action Required?	n	
648403	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Follow-up Action Required?	n	
648404	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Foundation Condition	Good	
648405	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	General Comments		
648406	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	General Comments		
648407	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Grounds in Place?	y	
648408	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Maintenance Operations	0	
648409	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Moisture and Leak Free?	y	
648410	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Operations Counter AF	210	
648411	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Operations Counter AL	210	
648412	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Switching Operations	0	
648413	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Tank Paint Condition	Good	
648414	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Unknown Operations	0	
648415	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
648416	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
648417	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
648418	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
648419	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
648420	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Gates Aligned?	y	
648421	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Grounds in Place?	y	
648422	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Posts Condition OK?	y	
648423	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Ties Intact?	y	
648424	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Follow-up Action Required?	n	
648425	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
648426	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
648427	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
648428	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Tank Leaks	None	
648429	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
648430	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
648431	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Regulator As Left Counter	21039	
648432	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
648433	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
648434	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
648435	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
648436	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
648437	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
648438	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
648439	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
648440	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
648441	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Oil Temp Present	40	°C
648442	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Oil Temp Max	65	°C
648443	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1700	psi
648444	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
648445	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
648446	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	LTC Totalizer Reading	10488.00	kw
648447	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Kwh Reading	127	KwH
648448	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
648449	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	9 Month Operations	12	
648450	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Accumulated Fault Duty A Ph V	.50	%
648451	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Accumulated Fault Duty B Ph V	3.49	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
648452	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Accumulated Fault Duty C Ph V	4.49	%
648453	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Amps A Ø	170.0	
648454	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Amps B Ø	150.0	
648455	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Amps C Ø	170.0	
648456	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	General Comments		
648457	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	General Comments		
648458	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
648459	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
648460	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Follow-up Action Required?	n	
648461	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
648462	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
648463	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
648464	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
648465	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
648466	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
648467	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
648468	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
648469	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
648470	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
648471	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
648472	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
648473	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Bushing Condition	Good	
648474	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Bushings Connection/Risers	Good	
648475	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
648476	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
648477	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
648478	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
648479	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC Operations Since Last Insp	203	
648480	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
648481	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
648482	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
648483	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
648484	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC Min Tap Position	13L	
648485	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC Max Tap Position	6R	
648486	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC Current Tap Position	7L	
648487	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
648488	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC As Left Counter	2562	
648489	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC As Found Counter	2562	
648490	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	General Comments		
648491	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	General Comments		
648492	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
648493	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	Follow-up Action Required?	n	
648494	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
648495	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	General Comments	ok	
648496	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
648497	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Unknown Operations	0	
648498	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Switching Operations	1	
648499	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
648500	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Operations Counter AL	242	
648501	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Operations Counter AF	241	
648502	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Moisture and Leak Free?	y	
648503	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Maintenance Operations	0	
648504	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Heaters (All) Functioning?	y	
648505	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Grounds in Place?	y	
648506	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	General Comments		
648507	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	General Comments		
648508	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Follow-up Action Required?	n	
648509	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Follow-up Action Required?	n	
648510	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Operations Ground	0	
648511	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Operations C Ø	0	
648512	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Operations B Ø	0	
648513	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Operations A Ø	0	
648514	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
648515	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
648516	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
648517	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Equipment Properly Labeled?	y	
648518	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
648519	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
648520	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
648521	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
648522	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
648523	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
648524	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
648525	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
648526	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	General Comments	need varmint guarding	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
648527	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
648528	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
648529	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
648530	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
648531	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
648532	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
648533	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
648534	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
648535	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Regulator As Left Counter	124332	
648536	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
648537	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
648538	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Tank Leaks	None	
648539	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
648540	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Steel Structures Rust Free?	y	
648541	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Surge Arrester Condition	Good	
648542	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Operations Ground	0	
648543	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Follow-up Action Required?	n	
648544	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
648545	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	9 Month Operations	2	
648546	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Follow-up Action Required?	n	
648547	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Foundation Condition	Good	
648548	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	General Comments		
648549	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	General Comments		
648550	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Grounds in Place?	y	
648551	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Heaters (All) Functioning?	y	
648552	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Maintenance Operations	0	
648553	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Moisture and Leak Free?	y	
648554	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Operations Counter AF	375	
648555	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Operations Counter AL	375	
648556	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Switching Operations	0	
648557	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Tank Paint Condition	Good	
648558	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Unknown Operations	0	
648559	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
648560	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
648561	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
648562	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	LTC Operation Checked?	y	
648563	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	General Comments		
648564	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	Follow-up Action Required?	n	
648565	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	All Connections OK?	y	
648566	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Vegetation	None	
648567	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
648568	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
648569	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
648570	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
648571	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
648572	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
648573	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Current Tap Position	12L	
648574	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
648575	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
648576	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
648577	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
648578	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	General Comments	ok	
648579	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
648580	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Max Tap Position	10L	
648581	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Min Tap Position	15L	
648582	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
648583	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
648584	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
648585	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
648586	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	196	
648587	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Amps A Ø	6.5	
648588	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
648589	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Regulator As Left Counter	8431	
648590	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
648591	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Amps B Ø	7.2	
648592	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Amps C Ø	6.3	
648593	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	229	
648594	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
648595	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
648596	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Tank Leaks	None	
648597	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
648598	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
648599	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	192	
648600	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
648601	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
648602	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Cabinet Paint Condition	Good	
648603	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
648604	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
648605	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
648606	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
648607	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
648608	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
648609	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
648610	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Amps C Ø	245.0	
648611	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Amps B Ø	300.0	
648612	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Amps A Ø	290.0	
648613	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Accumulated Fault Duty C Ph V	6.00	%
648614	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Accumulated Fault Duty B Ph V	12.87	%
648615	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Accumulated Fault Duty A Ph V	12.01	%
648616	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	9 Month Operations	6	
648617	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
648618	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
648619	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
648620	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
648621	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
648622	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
648623	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
648624	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
648625	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
648626	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	64	°F
648627	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
648628	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	VRR Time Delay	30	Seconds
648629	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	Follow-up Action Required?	n	
648630	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
648631	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	General Comments		
648632	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	General Comments		
648633	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
648634	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
648635	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
648636	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC As Found Counter	84619	
648637	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC As Left Counter	84619	
648638	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
648639	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC Current Tap Position	5L	
648640	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
648641	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC Min Tap Position	9L	
648642	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
648643	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC Operations Since Last Insp	353	
648644	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
648645	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
648646	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
648647	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
648648	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	General Comments	ok	
648649	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
648650	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
648651	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
648652	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
648653	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
648654	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
648655	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
648656	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
648657	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
648658	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
648659	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	General Comments		
648660	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
648661	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
648662	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
648663	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
648664	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
648665	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
648666	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
648667	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
648668	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
648669	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
648670	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
648671	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
648672	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
648673	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
648674	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
648675	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
648676	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
648677	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
648678	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
648679	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
648680	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
648681	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
648682	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
648683	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
648684	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
648685	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	General Comments	ok	
648686	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	General Comments	paint is in bad condition	
648687	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Amps A Ø	110	
648688	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Accumulated Fault Duty C Ph V	0	%
648689	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Bushing Condition	Good	
648690	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Amps C Ø	98.0	
648691	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Amps B Ø	162.0	
648692	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Amps A Ø	119.0	
648693	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Accumulated Fault Duty C Ph V	.42	%
648694	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Accumulated Fault Duty B Ph V	.42	%
648695	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Accumulated Fault Duty A Ph V	.42	%
648696	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	9 Month Operations	1	
648697	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Accumulated Fault Duty B Ph V	1.01	%
648698	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Accumulated Fault Duty A Ph V	0	%
648699	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	9 Month Operations	4	
648700	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Winding Temp Present	30	°C
648701	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Winding Temp Max	30	°C
648702	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8370	
648703	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
648704	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Top Oil Temperature Present	30	°C
648705	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Top Oil Temperature Max	30	°C
648706	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
648707	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
648708	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
648709	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
648710	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
648711	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
648712	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
648713	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
648714	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
648715	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
648716	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
648717	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3013.20	kw
648718	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
648719	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
648720	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
648721	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
648722	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	General Comments	ok	
648723	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
648724	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
648725	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	BCH000298	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.5	VDC
648726	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	BCH000298	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
648727	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	BCH000298	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
648728	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
648729	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
648730	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
648731	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
648732	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
648733	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
648734	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
648735	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
648736	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
648737	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
648738	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
648739	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
648740	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
648741	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
648742	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
648743	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
648744	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
648745	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
648746	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
648747	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
648748	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC Operations Since Last Insp	293	
648749	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	Follow-up Action Required?	n	
648750	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
648751	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
648752	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	General Comments		
648753	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC As Found Counter	86695	
648754	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC As Left Counter	86698	
648755	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
648756	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC Current Tap Position	6L	
648757	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC Max Tap Position	5L	
648758	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC Min Tap Position	13L	
648759	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
648760	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
648761	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
648762	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	General Comments		
648763	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
648764	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
648765	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
648766	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
648767	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
648768	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
648769	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
648770	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	General Comments		
648771	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
648772	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
648773	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
648774	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
648775	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	Oil Temp Max	55	°C
648776	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	Oil Temp Present	35	°C
648777	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
648778	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
648779	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
648780	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
648781	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
648782	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
648783	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
648784	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
648785	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
648786	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
648787	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
648788	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Totalizer Meter Reading	.5196	
648789	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
648790	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
648791	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
648792	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
648793	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
648794	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
648795	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
648796	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
648797	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Oil Temp Present	55	°C
648798	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Oil Temp Max	35	°C
648799	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
648800	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	115.00	
648801	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	311.76	kw
648802	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
648803	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
648804	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
648805	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
648806	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
648807	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
648808	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
648809	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
648810	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
648811	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
648812	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
648813	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
648814	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Bushings Connection/Risers	Good	
648815	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
648816	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
648817	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
648818	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Cabinet Paint Condition	Good	
648819	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Equipment Properly Labeled?	y	
648820	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Adjusted Amps A Phase V	33.81	
648821	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Adjusted Amps B Phase V	33.81	
648822	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Adjusted Amps C Phase V	33.81	
648823	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Operations A Ø	0	
648824	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Operations B Ø	0	
648825	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Operations C Ø	0	
648826	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
648827	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Follow-up Action Required?	n	
648828	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
648829	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Follow-up Action Required?	n	
648830	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Foundation Condition	Good	
648831	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	General Comments	ok	
648832	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
648833	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
648834	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
648835	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
648836	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
648837	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
648838	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
648839	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
648840	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
648841	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	General Comments	ok	
648842	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
648843	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
648844	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
648845	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
648846	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	General Comments	ok	
648847	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Grounds in Place?	y	
648848	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Heaters (All) Functioning?	y	
648849	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
648850	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
648851	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
648852	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Maintenance Operations	0	
648853	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Moisture and Leak Free?	y	
648854	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Operations Counter AF	168	
648855	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Operations Counter AL	168	
648856	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
648857	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
648858	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
648859	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
648860	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Min Tap Position	16L	
648861	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Max Tap Position	10L	
648862	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
648863	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	General Comments	ok	
648864	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
648865	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
648866	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
648867	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
648868	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Current Tap Position	11L	
648869	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
648870	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
648871	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
648872	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
648873	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
648874	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
648875	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
648876	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
648877	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Gate Locks Functioning ?	y	
648878	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	General Comments		
648879	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Signage Visible, and Proper?	y	
648880	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Ambient Temp	56	°F
648881	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Clear of Obstacles?	y	
648882	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Clear of Trash?	y	
648883	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
648884	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drive/Lot Drainage	Good	
648885	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
648886	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
648887	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
648888	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Follow-up Action Required?	n	
648889	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	General Comments		
648890	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Vegetation	None	
648891	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	9 Month Operations	17	
648892	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Accumulated Fault Duty A Ph V	9.14	%
648893	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Accumulated Fault Duty B Ph V	9.01	%
648894	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Accumulated Fault Duty C Ph V	9.01	%
648895	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Amps A Ø	75.2	
648896	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Amps B Ø	77.6	
648897	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Amps C Ø	78.2	
648898	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Bushing Condition	Good	
648899	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Operations B Ø	0	
648900	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Operations A Ø	0	
648901	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
648902	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Tank Paint Condition	Good	
648903	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Switching Operations	0	
648904	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
648905	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Operations Counter AL	169	
648906	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Operations Counter AF	169	
648907	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Moisture and Leak Free?	y	
648908	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Maintenance Operations	0	
648909	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Heaters (All) Functioning?	y	
648910	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Grounds in Place?	y	
648911	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	General Comments		
648912	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	General Comments		
648913	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Foundation Condition	Good	
648914	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Follow-up Action Required?	n	
648915	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Follow-up Action Required?	n	
648916	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Operations Ground	0	
648917	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Operations C Ø	0	
648918	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Operations B Ø	0	
648919	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Operations A Ø	0	
648920	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
648921	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
648922	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
648923	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Equipment Properly Labeled?	y	
648924	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Cabinet Paint Condition	Good	
648925	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
648926	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
648927	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
648928	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Bushings Connection/Risers	Good	
648929	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Adjusted Amps C Phase V	0	
648930	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Adjusted Amps B Phase V	0	
648931	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Adjusted Amps A Phase V	0	
648932	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Equipment Properly Labeled?	y	
648933	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Cabinet Paint Condition	Good	
648934	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
648935	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
648936	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
648937	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Bushings Connection/Risers	Good	
648938	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Bushing Condition	Good	
648939	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Amps C Ø	110	
648940	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Amps B Ø	110	
648941	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
648942	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Switching Operations	0	
648943	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Tank Paint Condition	Good	
648944	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Unknown Operations	14	
648945	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Unknown Operations	0	
648946	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Tank Paint Condition	Good	
648947	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Switching Operations	0	
648948	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Operations Counter AL	329	
648949	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Operations Counter AF	329	
648950	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Moisture and Leak Free?	y	
648951	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Maintenance Operations	0	
648952	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Heaters (All) Functioning?	y	
648953	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Grounds in Place?	y	
648954	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	General Comments		
648955	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	General Comments		
648956	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Foundation Condition	Good	
648957	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
648958	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
648959	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
648960	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	14294	
648961	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
648962	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
648963	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
648964	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
648965	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
648966	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
648967	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	2L	
648968	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
648969	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments	counter does not work	
648970	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
648971	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
648972	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
648973	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
648974	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	6L	
648975	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
648976	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
648977	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
648978	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
648979	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R0687	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
648980	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Follow-up Action Required?	n	
648981	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Follow-up Action Required?	n	
648982	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Operations Ground	0	
648983	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Operations C Ø	0	
648984	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
648985	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
648986	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
648987	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
648988	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
648989	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
648990	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
648991	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Operations Ground	0	
648992	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Follow-up Action Required?	n	
648993	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Follow-up Action Required?	n	
648994	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Foundation Condition	Good	
648995	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Unknown Operations	0	
648996	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Tank Paint Condition	Good	
648997	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Switching Operations	3	
648998	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
648999	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Operations Counter AL	142	
649000	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Operations Counter AF	139	
649001	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Moisture and Leak Free?	y	
649002	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Maintenance Operations	0	
649003	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Grounds in Place?	y	
649004	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	General Comments		
649005	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	General Comments		
649006	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Foundation Condition	Good	
649007	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Follow-up Action Required?	n	
649008	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
649009	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
649010	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
649011	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
649012	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
649013	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Oil Temp Present	3640	°C
649014	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Oil Temp Max	38	°C
649015	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
649016	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
649017	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	LTC Totalizer Reading	7614	kw
649018	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
649019	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Follow-up Action Required?	n	
649020	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Fault Operations Ground	0	
649021	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Fault Operations C Ø	0	
649022	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Fault Operations B Ø	0	
649023	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Fault Operations A Ø	0	
649024	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
649025	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
649026	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	General Comments		
649027	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Foundation Condition	Good	
649028	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Follow-up Action Required?	n	
649029	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Follow-up Action Required?	n	
649030	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Fault Operations Ground	0	
649031	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Fault Operations C Ø	0	
649032	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Fault Operations B Ø	0	
649033	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Fault Operations A Ø	0	
649034	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
649035	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
649036	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
649037	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Equipment Properly Labeled?	y	
649038	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Cabinet Paint Condition	Good	
649039	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
649040	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
649041	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
649042	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Amps C Ø	60.0	
649043	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Amps B Ø	60.0	
649044	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Amps A Ø	55.0	
649045	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
649046	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
649047	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
649048	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	9 Month Operations	30	
649049	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
649050	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
649051	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
649052	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2200	psi
649053	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
649054	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
649055	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
649056	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	General Comments		
649057	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	General Comments		
649058	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
649059	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
649060	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
649061	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
649062	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
649063	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
649064	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
649065	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
649066	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
649067	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
649068	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Follow-up Action Required?	n	
649069	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
649070	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
649071	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
649072	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
649073	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
649074	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
649075	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
649076	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
649077	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
649078	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
649079	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Unknown Operations	0	
649080	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Tank Paint Condition	Good	
649081	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Switching Operations	2	
649082	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
649083	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Operations Counter AL	172	
649084	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Operations Counter AF	169	
649085	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
649086	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
649087	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Moisture and Leak Free?	y	
649088	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Maintenance Operations	0	
649089	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Grounds in Place?	y	
649090	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	General Comments		
649091	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	General Comments		
649092	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Foundation Condition	Good	
649093	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Follow-up Action Required?	n	
649094	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Follow-up Action Required?	n	
649095	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Operations Ground	0	
649096	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
649097	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
649098	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
649099	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Operations C Ø	0	
649100	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Operations B Ø	0	
649101	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Operations A Ø	0	
649102	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
649103	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
649104	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
649105	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Equipment Properly Labeled?	y	
649106	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Cabinet Paint Condition	Good	
649107	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
649108	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
649109	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
649110	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
649111	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Equipment Properly Labeled?	y	
649112	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Cabinet Paint Condition	Good	
649113	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
649114	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
649115	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
649116	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Amps C Ø	0.0	
649117	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Amps B Ø	0.0	
649118	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Amps A Ø	0.0	
649119	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
649120	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
649121	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
649122	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	9 Month Operations	34	
649123	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	General Comments	ok	
649124	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	General Comments		
649125	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	General Comments		
649126	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
649127	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
649128	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
649129	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
649130	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	General Comments		
649131	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
649132	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
649133	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
649134	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
649135	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
649136	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
649137	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
649138	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
649139	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	General Comments	ok	
649140	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Grounds in Place?	y	
649141	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Heaters (All) Functioning?	y	
649142	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Maintenance Operations	0	
649143	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Moisture and Leak Free?	y	
649144	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Operations Counter AF	109	
649145	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Operations Counter AL	109	
649146	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
649147	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Switching Operations	0	
649148	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Tank Paint Condition	Good	
649149	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Unknown Operations	0	
649150	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
649151	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
649152	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
649153	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
649154	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
649155	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
649156	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
649157	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
649158	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
649159	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Cabinet Paint Condition	Good	
649160	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Equipment Properly Labeled?	y	
649161	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
649162	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
649163	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
649164	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Operations A Ø	0	
649165	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Operations B Ø	0	
649166	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Operations C Ø	0	
649167	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
649168	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
649169	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
649170	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
649171	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
649172	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
649173	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
649174	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
649175	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
649176	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
649177	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
649178	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
649179	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
649180	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
649181	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
649182	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	General Comments		
649183	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
649184	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Unknown Operations	0	
649185	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Tank Paint Condition	Good	
649186	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Switching Operations	20	
649187	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
649188	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Operations Counter AL	176	
649189	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Operations Counter AF	174	
649190	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
649191	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Maintenance Operations	0	
649192	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Grounds in Place?	y	
649193	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	General Comments		
649194	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	General Comments		
649195	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
649196	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
649197	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Foundation Condition	Good	
649198	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
649199	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	General Comments		
649200	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
649201	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
649202	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
649203	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
649204	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Amps A Ø	25.0	
649205	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Amps B Ø	25.0	
649206	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Amps C Ø	25.0	
649207	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Bushing Condition	Good	
649208	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Bushings Connection/Risers	Good	
649209	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
649210	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
649211	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
649212	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
649213	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Foundation Condition	Good	
649214	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Follow-up Action Required?	n	
649215	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Follow-up Action Required?	n	
649216	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Operations Ground	0	
649217	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Operations C Ø	0	
649218	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Operations B Ø	0	
649219	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Operations A Ø	0	
649220	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
649221	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
649222	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
649223	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Equipment Properly Labeled?	y	
649224	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Cabinet Paint Condition	Good	
649225	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
649226	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
649227	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
649228	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Bushings Connection/Risers	Good	
649229	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Bushing Condition	Good	
649230	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Amps C Ø	34.0	
649231	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Amps B Ø	45.0	
649232	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Amps A Ø	40.0	
649233	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Accumulated Fault Duty C Ph V	4.73	%
649234	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Accumulated Fault Duty B Ph V	4.97	%
649235	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Accumulated Fault Duty A Ph V	4.73	%
649236	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	9 Month Operations	11	
649237	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
649238	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
649239	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	General Comments	ok	
649240	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
649241	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
649242	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
649243	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
649244	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
649245	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
649246	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
649247	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
649248	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
649249	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
649250	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Top Oil Temperature Max	40	°C
649251	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
649252	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
649253	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
649254	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
649255	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
649256	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
649257	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
649258	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
649259	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
649260	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
649261	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
649262	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Winding Temp Present	40	°C
649263	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Winding Temp Max	42	°C
649264	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Totalizer Meter Reading	.423	
649265	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
649266	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
649267	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
649268	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Unknown Operations	0	
649269	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Tank Paint Condition	Good	
649270	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Switching Operations	6	
649271	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
649272	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Operations Counter AL	147	
649273	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Operations Counter AF	141	
649274	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
649275	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Moisture and Leak Free?	y	
649276	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
649277	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Grounds in Place?	y	
649278	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	General Comments		
649279	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Foundation Condition	Good	
649280	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Follow-up Action Required?	n	
649281	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Follow-up Action Required?	n	
649282	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Operations Ground	0	
649283	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Operations C Ø	0	
649284	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Operations B Ø	0	
649285	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Operations A Ø	0	
649286	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
649287	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
649288	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
649289	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
649290	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
649291	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
649292	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
649293	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
649294	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Amps C Ø	270.0	
649295	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Amps B Ø	280.0	
649296	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Amps A Ø	230.0	
649297	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
649298	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
649299	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
649300	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	9 Month Operations	132	
649301	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
649302	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
649303	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
649304	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
649305	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
649306	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
649307	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
649308	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	51	
649309	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	51	
649310	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
649311	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
649312	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
649313	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
649314	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Winding Temp Present	50	°C
649315	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Winding Temp Max	60	°C
649316	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Top Oil Temperature Present	40	°C
649317	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
649318	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
649319	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
649320	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Clear of Trash?	y	
649321	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
649322	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Operations Ground	0	
649323	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
649324	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Follow-up Action Required?	n	
649325	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Cabinet Paint Condition	Good	
649326	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Equipment Properly Labeled?	y	
649327	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
649328	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
649329	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
649330	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Operations A Ø	0	
649331	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Operations B Ø	0	
649332	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Operations C Ø	0	
649333	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Operations Ground	0	
649334	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Follow-up Action Required?	n	
649335	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	General Comments		
649336	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	General Comments		
649337	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
649338	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
649339	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Maintenance Operations	0	
649340	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
649341	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Operations Counter AF	133	
649342	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Operations Counter AL	134	
649343	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
649344	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Switching Operations	1	
649345	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Unknown Operations	0	
649346	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Follow-up Action Required?	n	
649347	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	General Comments		
649348	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	General Comments		
649349	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Grounds in Place?	y	
649350	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Heaters (All) Functioning?	y	
649351	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
649352	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Moisture and Leak Free?	y	
649353	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Operations Counter AF	226	
649354	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
649355	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	9 Month Operations	8	
649356	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
649357	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
649358	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	General Comments		
649359	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
649360	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
649361	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
649362	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
649363	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
649364	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Operations Counter AF	118	
649365	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Operations Counter AL	118	
649366	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
649367	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	9 Month Operations	3	
649368	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
649369	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
649370	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
649371	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Amps A Ø	0.0	
649372	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Amps B Ø	0.0	
649373	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Switching Operations	0	
649374	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Tank Paint Condition	Good	
649375	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Unknown Operations	0	
649376	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
649377	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
649378	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
649379	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
649380	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
649381	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
649382	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
649383	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
649384	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	9 Month Operations	7	
649385	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Accumulated Fault Duty A Ph V	2.57	%
649386	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Accumulated Fault Duty B Ph V	.86	%
649387	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Accumulated Fault Duty C Ph V	1.72	%
649388	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Amps A Ø	70.0	
649389	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Amps B Ø	70.0	
649390	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Amps C Ø	70.0	
649391	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
649392	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
649393	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
649394	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Amps C Ø	0.0	
649395	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
649396	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
649397	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
649398	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
649399	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
649400	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
649401	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
649402	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
649403	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Operations A Ø	0	
649404	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Operations B Ø	0	
649405	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Operations C Ø	0	
649406	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Amps B Ø	10	
649407	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Amps C Ø	10	
649408	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Bushing Condition	Good	
649409	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Bushings Connection/Risers	Good	
649410	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
649411	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
649412	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
649413	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Cabinet Paint Condition	Good	
649414	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Equipment Properly Labeled?	y	
649415	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Adjusted Amps A Phase V	0	
649416	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Adjusted Amps B Phase V	0	
649417	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Adjusted Amps C Phase V	0	
649418	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Operations A Ø	0	
649419	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Operations B Ø	0	
649420	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Operations C Ø	0	
649421	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Ground Connections Intact?	y	
649422	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Insulators In Good Condition?	y	
649423	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Linkage Grounds in Place?	y	
649424	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Live Parts Good Condition?	y	
649425	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Operating Linkage OK?	y	
649426	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
649427	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
649428	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
649429	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
649430	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Signage Visible, and Proper?	y	
649431	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
649432	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
649433	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
649434	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
649435	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	General Comments		
649436	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
649437	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
649438	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
649439	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
649440	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
649441	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
649442	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
649443	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
649444	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
649445	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
649446	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
649447	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
649448	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
649449	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
649450	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
649451	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
649452	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
649453	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
649454	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
649455	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
649456	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Operations Counter AL	227	
649457	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
649458	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Switching Operations	1	
649459	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	All Identified and Legible?	y	
649460	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
649461	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
649462	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
649463	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
649464	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
649465	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
649466	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	General Comments		
649467	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
649468	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
649469	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	General Comments	ok	
649470	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
649471	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
649472	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
649473	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Clear of Trash?	y	
649474	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
649475	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Unknown Operations	0	
649476	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
649477	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
649478	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
649479	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
649480	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Accumulated Fault Duty A Ph V	8.04	%
649481	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Accumulated Fault Duty B Ph V	11.06	%
649482	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Conductors and Connectors OK?	y	
649483	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Contacts Engaged Properly?	y	
649484	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Equipment Properly Labeled?	y	
649485	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Follow-up Action Required?	n	
649486	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Foundation Condition	Good	
649487	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Free of Audible Arcing?	y	
649488	1/7/2019 13:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	General Comments		
649489	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Accumulated Fault Duty C Ph V	6.03	%
649490	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Amps A Ø	10	
649491	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
649492	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
649493	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Tank Leaks	None	
649494	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
649495	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
649496	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	General Comments		
649497	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
649498	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Vegetation	None	
649499	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
649500	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Unknown Operations	0	
649501	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
649502	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Switching Operations	3	
649503	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
649504	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Operations Counter AL	171	
649505	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Operations Counter AF	168	
649506	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Moisture and Leak Free?	y	
649507	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Maintenance Operations	0	
649508	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Grounds in Place?	y	
649509	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	General Comments		
649510	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	General Comments		
649511	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Foundation Condition	Good	
649512	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Follow-up Action Required?	n	
649513	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Follow-up Action Required?	n	
649514	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Operations Ground	0	
649515	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Operations C Ø	0	
649516	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Operations B Ø	0	
649517	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Operations A Ø	0	
649518	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
649519	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
649520	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
649521	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Equipment Properly Labeled?	y	
649522	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Cabinet Paint Condition	Good	
649523	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
649524	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
649525	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
649526	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Amps C Ø	115.0	
649527	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Amps B Ø	135.0	
649528	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Amps A Ø	110.0	
649529	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
649530	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
649531	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
649532	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	9 Month Operations	47	
649533	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Amps C Ø	110.0	
649534	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Amps B Ø	90.0	
649535	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Amps A Ø	80.0	
649536	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
649537	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
649538	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
649539	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
649540	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
649541	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
649542	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
649543	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
649544	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
649545	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
649546	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
649547	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	9 Month Operations	37	
649548	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
649549	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
649550	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
649551	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
649552	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
649553	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
649554	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
649555	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
649556	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
649557	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
649558	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	General Comments	need varmint guard	
649559	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
649560	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Max Tap Position	7L	
649561	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
649562	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
649563	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
649564	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
649565	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
649566	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Ambient Temp	62	°F
649567	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
649568	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Clear of Trash?	y	
649569	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
649570	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
649571	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
649572	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
649573	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
649574	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
649575	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Regulator As Left Counter	113933	
649576	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
649577	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
649578	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
649579	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
649580	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Cabinet Paint Condition	Good	
649581	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Equipment Properly Labeled?	y	
649582	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Adjusted Amps A Phase V	0	
649583	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Adjusted Amps B Phase V	0	
649584	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Adjusted Amps C Phase V	0	
649585	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Operations A Ø	0	
649586	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Operations B Ø	0	
649587	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Operations C Ø	0	
649588	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Operations Ground	0	
649589	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Follow-up Action Required?	n	
649590	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Follow-up Action Required?	n	
649591	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Foundation Condition	Good	
649592	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	General Comments		
649593	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	General Comments		
649594	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Grounds in Place?	y	
649595	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
649596	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
649597	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
649598	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
649599	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
649600	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
649601	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Foundation Condition	Good	
649602	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
649603	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	General Comments	ok	
649604	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
649605	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
649606	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
649607	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
649608	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
649609	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
649610	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
649611	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
649612	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
649613	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
649614	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
649615	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Heaters (All) Functioning?	y	
649616	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Maintenance Operations	0	
649617	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Moisture and Leak Free?	y	
649618	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
649619	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
649620	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
649621	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
649622	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
649623	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	General Comments	ok	
649624	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	General Comments	ok	
649625	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
649626	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
649627	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
649628	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
649629	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
649630	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	Oil Temp Max	55	°C
649631	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	Oil Temp Present	25	°C
649632	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
649633	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
649634	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
649635	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
649636	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
649637	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
649638	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
649639	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	9 Month Operations	8	
649640	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Accumulated Fault Duty A Ph V	50.93	%
649641	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Accumulated Fault Duty B Ph V	50.93	%
649642	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Accumulated Fault Duty C Ph V	50.93	%
649643	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Amps A Ø	10	
649644	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
649645	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Vegetation	None	
649646	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
649647	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	General Comments	ok	
649648	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
649649	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
649650	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
649651	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
649652	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
649653	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
649654	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Clear of Trash?	y	
649655	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
649656	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
649657	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
649658	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Amps B Ø	10	
649659	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Amps C Ø	10	
649660	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Bushing Condition	Good	
649661	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
649662	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
649663	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Clear of Trash?	y	
649664	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
649665	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Ambient Temp	59	°F
649666	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	BAT000336	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
649667	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	BAT000336	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
649668	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	BAT000336	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
649669	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	BAT000336	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
649670	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	BAT000336	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
649671	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	BAT000336	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
649672	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	BAT000336	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
649673	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	BAT000336	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
649674	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	BAT000336	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
649675	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	BAT000336	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	2.6	VDC
649676	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	BAT000336	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.4	VDC
649677	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	BAT000336	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
649678	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	BAT000336	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
649679	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
649680	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
649681	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
649682	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
649683	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
649684	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
649685	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Clear of Trash?	y	
649686	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
649687	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
649688	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Ambient Temp	57	°F
649689	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
649690	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
649691	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
649692	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
649693	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
649694	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
649695	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
649696	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
649697	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
649698	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
649699	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
649700	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
649701	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
649702	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	General Comments		
649703	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
649704	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
649705	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.81	%
649706	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.21	%
649707	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.81	%
649708	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10	
649709	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	15	
649710	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10	
649711	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
649712	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
649713	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
649714	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
649715	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Unknown Operations	0	
649716	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Tank Paint Condition	Good	
649717	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Switching Operations	3	
649718	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
649719	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
649720	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
649721	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
649722	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
649723	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
649724	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
649725	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
649726	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
649727	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
649728	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Vegetation	None	
649729	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
649730	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
649731	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	General Comments		
649732	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
649733	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
649734	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
649735	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
649736	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
649737	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
649738	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
649739	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
649740	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
649741	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Clear of Trash?	y	
649742	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
649743	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
649744	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
649745	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
649746	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
649747	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
649748	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124	VAC
649749	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124	VAC
649750	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
649751	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
649752	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
649753	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
649754	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
649755	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
649756	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
649757	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
649758	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
649759	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
649760	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
649761	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
649762	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
649763	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
649764	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	General Comments		
649765	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
649766	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
649767	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Foundation Condition	Good	
649768	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
649769	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
649770	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
649771	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
649772	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
649773	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
649774	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
649775	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Vegetation	None	
649776	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
649777	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
649778	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
649779	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
649780	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	General Comments		
649781	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
649782	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Vegetation	None	
649783	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
649784	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	General Comments	No spill kit.	
649785	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
649786	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
649787	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
649788	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
649789	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
649790	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
649791	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Tank Leaks	None	
649792	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
649793	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
649794	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
649795	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
649796	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
649797	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
649798	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
649799	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
649800	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
649801	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
649802	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
649803	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	General Comments	ok	
649804	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
649805	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Max Tap Position	16R	
649806	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
649807	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
649808	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
649809	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
649810	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Reg Operation Checked?	n	
649811	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
649812	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Regulator As Left Counter	23634	
649813	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
649814	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Tank Leaks	None	
649815	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
649816	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
649817	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
649818	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
649819	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Gates Aligned?	y	
649820	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Grounds in Place?	y	
649821	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Posts Condition OK?	y	
649822	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Ties Intact?	y	
649823	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Follow-up Action Required?	n	
649824	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
649825	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
649826	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
649827	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Gate Locks Functioning ?	y	
649828	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	General Comments		
649829	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Signage Visible, and Proper?	y	
649830	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
649831	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	9 Month Operations	4	
649832	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
649833	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
649834	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
649835	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Amps A Ø	0.0	
649836	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Amps B Ø	0.0	
649837	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Amps C Ø	0.0	
649838	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
649839	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
649840	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
649841	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
649842	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
649843	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
649844	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
649845	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
649846	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Operations A Ø	0	
649847	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Operations B Ø	0	
649848	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Operations C Ø	0	
649849	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Operations Ground	0	
649850	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
649851	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Follow-up Action Required?	n	
649852	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
649853	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
649854	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
649855	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
649856	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
649857	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
649858	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
649859	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
649860	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
649861	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
649862	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
649863	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
649864	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
649865	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
649866	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	146	
649867	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	151	
649868	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
649869	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
649870	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0160	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
649871	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
649872	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
649873	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
649874	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
649875	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
649876	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Current Tap Position	2L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
649877	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
649878	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Operations Counter AL	223	
649879	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Operations Counter AF	221	
649880	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Moisture and Leak Free?	y	
649881	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Maintenance Operations	0	
649882	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Heaters (All) Functioning?	y	
649883	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
649884	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
649885	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
649886	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	General Comments	ok	
649887	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
649888	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
649889	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
649890	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
649891	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
649892	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
649893	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
649894	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	24.1	volts
649895	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Regulator As Left Counter	23116	
649896	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
649897	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Tank Leaks	None	
649898	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
649899	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Regulator As Left Counter	172819	
649900	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
649901	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
649902	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
649903	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
649904	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
649905	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Min Tap Position	3R	
649906	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Max Tap Position	11R	
649907	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
649908	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	General Comments		
649909	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
649910	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
649911	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
649912	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
649913	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Current Tap Position	6R	
649914	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
649915	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
649916	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
649917	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
649918	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
649919	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
649920	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
649921	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
649922	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
649923	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
649924	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
649925	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
649926	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
649927	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
649928	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
649929	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Operations A Ø	0	
649930	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Operations B Ø	0	
649931	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
649932	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	General Comments		
649933	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	All Connections OK?	y	
649934	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	Follow-up Action Required?	n	
649935	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
649936	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
649937	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Winding Temp Present	30	°C
649938	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Winding Temp Max	45	°C
649939	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Totalizer Meter Reading	5425.0000	
649940	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Totalizer Meter Multiplier	1	
649941	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
649942	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
649943	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
649944	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
649945	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
649946	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
649947	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
649948	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
649949	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Oil Temp Present	35	°C
649950	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Oil Temp Max	45	°C
649951	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	750	psi

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
649952	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
649953	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
649954	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	General Comments		
649955	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	LTC Operation Checked?	y	
649956	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
649957	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
649958	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
649959	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	MegaWatt Demand Meter Max	6.67	MegaWatts
649960	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	VRR Time Delay	30	Seconds
649961	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	MegaVar Demand Meter Max	1.83	MegaVars
649962	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	LTC Totalizer Reading	5425.00	kw
649963	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Kwh Reading	81639	KwH
649964	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
649965	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	General Comments		
649966	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	General Comments		
649967	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
649968	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
649969	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
649970	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Operations C Ø	0	
649971	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Operations Ground	0	
649972	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Follow-up Action Required?	n	
649973	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Follow-up Action Required?	n	
649974	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	General Comments		
649975	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	General Comments		
649976	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
649977	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Follow-up Action Required?	n	
649978	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
649979	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
649980	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
649981	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
649982	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Operations Counter	86	
649983	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
649984	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
649985	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
649986	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
649987	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
649988	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
649989	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
649990	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
649991	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
649992	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
649993	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
649994	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
649995	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
649996	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
649997	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
649998	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
649999	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	VRR Time Delay	30	Seconds
650000	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
650001	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
650002	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
650003	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	LTC Operation Checked?	y	
650004	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	General Comments		
650005	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	Follow-up Action Required?	n	
650006	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	All Connections OK?	y	
650007	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
650008	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
650009	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
650010	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
650011	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
650012	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
650013	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
650014	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
650015	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	General Comments		
650016	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Clear of Trash?	y	
650017	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
650018	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
650019	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
650020	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
650021	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
650022	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
650023	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
650024	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
650025	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC Operations Since Last Insp	440	
650026	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	15	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
650027	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
650028	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC Min Tap Position	14L	
650029	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
650030	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC Current Tap Position	6L	
650031	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
650032	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC As Left Counter	16991	
650033	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC As Found Counter	16991	
650034	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	General Comments		
650035	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	General Comments		
650036	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
650037	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	Follow-up Action Required?	n	
650038	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	52.7	VDC
650039	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	52.7	VDC
650040	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
650041	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
650042	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	General Comments	ok	
650043	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
650044	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
650045	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
650046	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45	
650047	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
650048	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Oil Temp Present	26	°C
650049	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
650050	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
650051	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
650052	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
650053	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
650054	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
650055	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Totalizer Meter Reading	.325	
650056	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Winding Temp Max	26	°C
650057	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Winding Temp Present	23	°C
650058	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
650059	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
650060	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
650061	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
650062	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
650063	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
650064	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
650065	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
650066	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
650067	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
650068	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
650069	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
650070	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
650071	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
650072	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
650073	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
650074	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
650075	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
650076	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
650077	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
650078	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
650079	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	General Comments	ok	
650080	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
650081	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
650082	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
650083	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
650084	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
650085	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
650086	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
650087	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
650088	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
650089	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
650090	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
650091	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
650092	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
650093	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
650094	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
650095	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
650096	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
650097	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
650098	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
650099	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
650100	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
650101	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
650102	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	General Comments		
650103	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
650104	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
650105	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Foundation Condition	Good	
650106	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
650107	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
650108	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
650109	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
650110	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
650111	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
650112	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
650113	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
650114	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
650115	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
650116	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
650117	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
650118	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
650119	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
650120	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
650121	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
650122	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
650123	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	General Comments		
650124	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Grounds in Place?	y	
650125	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
650126	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Maintenance Operations	0	
650127	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
650128	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Operations Counter AF	208	
650129	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Operations Counter AL	209	
650130	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
650131	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Switching Operations	1	
650132	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Unknown Operations	0	
650133	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
650134	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	11	
650135	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1249	
650136	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1253	
650137	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
650138	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
650139	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
650140	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
650141	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
650142	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Amps B Ø	140.0	
650143	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Amps A Ø	135.0	
650144	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Accumulated Fault Duty C Ph V	1.00	%
650145	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Accumulated Fault Duty B Ph V	1.67	%
650146	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Accumulated Fault Duty A Ph V	3.34	%
650147	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	9 Month Operations	6	
650148	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
650149	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
650150	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
650151	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
650152	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
650153	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
650154	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
650155	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
650156	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
650157	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
650158	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
650159	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
650160	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
650161	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
650162	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
650163	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
650164	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
650165	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
650166	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
650167	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	General Comments		
650168	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	General Comments		
650169	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
650170	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
650171	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
650172	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
650173	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3120	kw
650174	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50	
650175	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Moisture and Leak Free?	y	
650176	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Operations Counter AF	212	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
650177	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Operations Counter AL	212	
650178	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
650179	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Switching Operations	0	
650180	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Tank Paint Condition	Good	
650181	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Unknown Operations	0	
650182	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
650183	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
650184	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
650185	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
650186	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
650187	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
650188	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
650189	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
650190	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
650191	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
650192	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
650193	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	General Comments		
650194	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
650195	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
650196	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
650197	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
650198	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
650199	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
650200	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
650201	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
650202	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Regulator As Left Counter	5574	
650203	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
650204	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
650205	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Tank Leaks	None	
650206	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
650207	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
650208	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
650209	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC
650210	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
650211	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
650212	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
650213	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
650214	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	General Comments		
650215	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	9 Month Operations	3	
650216	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
650217	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
650218	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
650219	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Amps A Ø	0.0	
650220	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Amps B Ø	0.0	
650221	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Amps C Ø	0.0	
650222	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
650223	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
650224	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
650225	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
650226	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
650227	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
650228	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
650229	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
650230	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
650231	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	2206	
650232	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	2202	
650233	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
650234	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
650235	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
650236	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
650237	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
650238	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Cabinet Paint Condition	Good	
650239	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
650240	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
650241	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
650242	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Regulator As Left Counter	4674	
650243	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
650244	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
650245	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Tank Leaks	None	
650246	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
650247	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	9 Month Operations	14	
650248	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Accumulated Fault Duty A Ph V	2.31	%
650249	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Accumulated Fault Duty B Ph V	2.31	%
650250	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Accumulated Fault Duty C Ph V	1.54	%
650251	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Amps A Ø	120	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
650252	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
650253	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Equipment Properly Labeled?	y	
650254	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Cabinet Paint Condition	Good	
650255	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
650256	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
650257	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
650258	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Bushings Connection/Risers	Good	
650259	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Bushing Condition	Good	
650260	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Amps C Ø	0.0	
650261	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Amps B Ø	0.0	
650262	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Amps A Ø	0.0	
650263	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Accumulated Fault Duty C Ph V	1.00	%
650264	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Accumulated Fault Duty B Ph V	1.00	%
650265	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Accumulated Fault Duty A Ph V	1.00	%
650266	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	9 Month Operations	5	
650267	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
650268	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	General Comments	ok	
650269	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
650270	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
650271	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
650272	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
650273	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
650274	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
650275	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Amps B Ø	120	
650276	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Amps C Ø	115	
650277	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Bushing Condition	Good	
650278	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Bushings Connection/Risers	Good	
650279	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
650280	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
650281	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
650282	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Cabinet Paint Condition	Good	
650283	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Equipment Properly Labeled?	y	
650284	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Adjusted Amps A Phase V	0	
650285	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Adjusted Amps B Phase V	0	
650286	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Adjusted Amps C Phase V	0	
650287	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Operations A Ø	0	
650288	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Operations B Ø	0	
650289	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Operations C Ø	0	
650290	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Operations Ground	0	
650291	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Follow-up Action Required?	n	
650292	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Follow-up Action Required?	n	
650293	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Foundation Condition	Good	
650294	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	General Comments		
650295	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	General Comments		
650296	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Grounds in Place?	y	
650297	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Heaters (All) Functioning?	y	
650298	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
650299	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
650300	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
650301	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
650302	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Maintenance Operations	0	
650303	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
650304	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drive/Lot Drainage	Good	
650305	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
650306	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Clear of Trash?	y	
650307	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Clear of Obstacles?	y	
650308	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
650309	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Ambient Temp	56	°F
650310	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
650311	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
650312	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
650313	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
650314	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
650315	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
650316	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.8	VDC
650317	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
650318	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
650319	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
650320	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
650321	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
650322	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
650323	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
650324	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
650325	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
650326	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
650327	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
650328	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	General Comments		
650329	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	General Comments		
650330	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
650331	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
650332	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
650333	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
650334	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	Oil Temp Max	45	°C
650335	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	Oil Temp Present	30	°C
650336	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
650337	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
650338	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
650339	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
650340	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
650341	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9756	
650342	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
650343	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
650344	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
650345	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
650346	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
650347	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
650348	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
650349	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
650350	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
650351	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
650352	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	585.36	kw
650353	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
650354	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
650355	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
650356	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
650357	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
650358	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	BCH000423	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
650359	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	BCH000423	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	56.1	VDC
650360	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	General Comments	ok	
650361	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	General Comments	Need new nitrogen blanket gauge.	
650362	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
650363	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
650364	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
650365	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
650366	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
650367	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Equipment Properly Labeled?	y	
650368	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
650369	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
650370	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
650371	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Operations A Ø	0	
650372	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Operations B Ø	0	
650373	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Operations C Ø	0	
650374	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Operations Ground	0	
650375	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Follow-up Action Required?	n	
650376	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Follow-up Action Required?	n	
650377	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	General Comments		
650378	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	General Comments		
650379	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Grounds in Place?	y	
650380	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Heaters (All) Functioning?	y	
650381	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Maintenance Operations	0	
650382	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Moisture and Leak Free?	y	
650383	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Operations Counter AF	181	
650384	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Operations Counter AL	182	
650385	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	General Comments		
650386	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
650387	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
650388	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Switching Operations	1	
650389	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Unknown Operations	0	
650390	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
650391	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
650392	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
650393	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
650394	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
650395	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
650396	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
650397	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
650398	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
650399	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
650400	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
650401	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
650402	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
650403	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	10	
650404	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	10	
650405	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	10	
650406	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	BCH000423	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
650407	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
650408	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
650409	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
650410	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
650411	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
650412	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
650413	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
650414	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
650415	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
650416	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.8	VDC
650417	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
650418	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
650419	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
650420	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
650421	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
650422	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
650423	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
650424	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
650425	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Yard Lights Working?	y	
650426	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Vegetation	None	
650427	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
650428	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	General Comments		
650429	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Follow-up Action Required?	n	
650430	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
650431	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
650432	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
650433	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Oil Temp Present	30	°C
650434	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Oil Temp Max	50	°C
650435	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
650436	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
650437	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	LTC Totalizer Reading	5760.00	kw
650438	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
650439	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	General Comments		
650440	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	General Comments		
650441	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
650442	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
650443	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
650444	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
650445	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Follow-up Action Required?	n	
650446	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
650447	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
650448	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
650449	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
650450	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
650451	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
650452	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
650453	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
650454	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
650455	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
650456	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
650457	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
650458	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
650459	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	259	
650460	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	259	
650461	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
650462	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
650463	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
650464	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
650465	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
650466	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
650467	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
650468	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
650469	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
650470	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
650471	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
650472	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
650473	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
650474	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
650475	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
650476	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
650477	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
650478	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
650479	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
650480	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
650481	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
650482	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
650483	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
650484	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
650485	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
650486	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
650487	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
650488	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
650489	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	General Comments		
650490	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
650491	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
650492	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Foundation Condition	Good	
650493	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Tank Leaks	None	
650494	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
650495	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Regulator As Left Counter	474457	
650496	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	General Comments		
650497	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	General Comments		
650498	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
650499	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Maintenance Operations	0	
650500	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
650501	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Operations Counter AF	111	
650502	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Operations Counter AL	113	
650503	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
650504	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Switching Operations	2	
650505	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
650506	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Unknown Operations	0	
650507	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	9 Month Operations	2	
650508	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
650509	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
650510	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
650511	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Amps A Ø	570.0	
650512	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Amps B Ø	580.0	
650513	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Amps C Ø	500.0	
650514	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
650515	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
650516	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
650517	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
650518	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
650519	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
650520	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
650521	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
650522	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Operations A Ø	0	
650523	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Operations B Ø	0	
650524	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Operations C Ø	0	
650525	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Operations Ground	0	
650526	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Follow-up Action Required?	n	
650527	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Follow-up Action Required?	n	
650528	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	General Comments		
650529	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	General Comments		
650530	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Grounds in Place?	y	
650531	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
650532	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Maintenance Operations	0	
650533	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
650534	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Grounds in Place?	y	
650535	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	General Comments		
650536	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	General Comments		
650537	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Foundation Condition	Good	
650538	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Follow-up Action Required?	n	
650539	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Follow-up Action Required?	n	
650540	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Operations Ground	0	
650541	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Operations Counter AF	193	
650542	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Operations Counter AL	195	
650543	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
650544	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Switching Operations	2	
650545	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Unknown Operations	0	
650546	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
650547	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
650548	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Winding Temp Present	35	°C
650549	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Winding Temp Max	55	°C
650550	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Totalizer Meter Reading	.4000	
650551	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
650552	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
650553	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
650554	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
650555	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
650556	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
650557	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
650558	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
650559	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
650560	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
650561	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
650562	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	General Comments		
650563	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	General Comments		
650564	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
650565	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
650566	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
650567	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
650568	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
650569	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
650570	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
650571	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
650572	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	General Comments		
650573	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
650574	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Max Tap Position	5L	
650575	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Min Tap Position	14L	
650576	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
650577	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
650578	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
650579	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
650580	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
650581	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Regulator As Left Counter	4914	
650582	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
650583	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
650584	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
650585	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
650586	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
650587	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
650588	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
650589	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
650590	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Tank Leaks	None	
650591	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
650592	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
650593	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
650594	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
650595	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
650596	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
650597	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
650598	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
650599	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
650600	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
650601	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10	
650602	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10	
650603	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10	
650604	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0	%
650605	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.01	%
650606	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0	%
650607	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
650608	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
650609	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
650610	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
650611	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
650612	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
650613	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
650614	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
650615	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
650616	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
650617	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
650618	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	General Comments		
650619	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
650620	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
650621	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
650622	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
650623	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
650624	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
650625	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
650626	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
650627	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
650628	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
650629	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
650630	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
650631	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
650632	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	General Comments	ok	
650633	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
650634	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
650635	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
650636	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
650637	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
650638	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
650639	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
650640	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
650641	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
650642	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
650643	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
650644	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
650645	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
650646	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
650647	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
650648	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
650649	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
650650	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
650651	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
650652	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
650653	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	General Comments		
650654	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
650655	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
650656	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
650657	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
650658	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Operations C Ø	0	
650659	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Operations B Ø	0	
650660	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
650661	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
650662	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
650663	1/7/2019 11:50	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
650664	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Operations A Ø	0	
650665	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
650666	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
650667	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
650668	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.8	VDC
650669	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.8	VDC
650670	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
650671	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
650672	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
650673	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
650674	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
650675	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
650676	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
650677	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
650678	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
650679	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
650680	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
650681	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
650682	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
650683	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
650684	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
650685	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	Oil Temp Present	50	°C
650686	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	Oil Temp Max	25	°C
650687	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
650688	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	115.00	
650689	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0	VDC
650690	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
650691	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
650692	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
650693	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
650694	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
650695	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Tank Leaks	None	
650696	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
650697	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
650698	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0	VDC
650699	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
650700	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
650701	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
650702	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
650703	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
650704	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Operations A Ø	2	
650705	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Operations B Ø	0	
650706	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
650707	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
650708	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
650709	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
650710	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
650711	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
650712	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
650713	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	General Comments		
650714	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
650715	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
650716	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Foundation Condition	Good	
650717	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
650718	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
650719	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
650720	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
650721	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
650722	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
650723	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
650724	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
650725	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
650726	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
650727	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	General Comments	ok	
650728	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
650729	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
650730	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
650731	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	7142.40	kw
650732	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
650733	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
650734	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
650735	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
650736	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
650737	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
650738	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
650739	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
650740	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
650741	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
650742	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
650743	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
650744	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9920	
650745	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Unknown Operations	0	
650746	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Switching Operations	1	
650747	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Adjusted Amps B Phase V	0	
650748	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Adjusted Amps A Phase V	0	
650749	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Equipment Properly Labeled?	y	
650750	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
650751	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
650752	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Amps C Ø	55.0	
650753	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Amps B Ø	75.0	
650754	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Foundation Condition	Good	
650755	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	General Comments		
650756	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	General Comments		
650757	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Grounds in Place?	y	
650758	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Amps A Ø	55.0	
650759	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Accumulated Fault Duty C Ph V	2.75	%
650760	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Accumulated Fault Duty B Ph V	2.75	%
650761	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
650762	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Heaters (All) Functioning?	y	
650763	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Maintenance Operations	0	
650764	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Moisture and Leak Free?	y	
650765	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Operations Counter AF	372	
650766	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Operations Counter AL	372	
650767	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	9 Month Operations	9	
650768	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Switching Operations	0	
650769	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Tank Paint Condition	Good	
650770	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Unknown Operations	0	
650771	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Cabinet Paint Condition	Good	
650772	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
650773	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
650774	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
650775	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Bushings Connection/Risers	Good	
650776	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
650777	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Accumulated Fault Duty A Ph V	6.84	%
650778	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Amps C Ø	120	
650779	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Amps B Ø	120	
650780	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Amps A Ø	120	
650781	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Accumulated Fault Duty B Ph V	5.70	%
650782	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Accumulated Fault Duty C Ph V	4.56	%
650783	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Amps A Ø	10.0	
650784	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	9 Month Operations	25	
650785	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Amps B Ø	5.0	
650786	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Amps C Ø	0.0	
650787	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Bushing Condition	Good	
650788	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Bushings Connection/Risers	Good	
650789	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
650790	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
650791	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
650792	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Cabinet Paint Condition	Good	
650793	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Equipment Properly Labeled?	y	
650794	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Adjusted Amps A Phase V	15.11	
650795	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
650796	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
650797	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Accumulated Fault Duty C Ph V	3.02	%
650798	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Accumulated Fault Duty B Ph V	5.03	%
650799	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Accumulated Fault Duty A Ph V	7.04	%
650800	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	9 Month Operations	0	
650801	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
650802	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
650803	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
650804	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
650805	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
650806	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
650807	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
650808	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3672	
650809	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
650810	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
650811	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
650812	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Foundation Condition	Good	
650813	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
650814	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Tank Leaks	None	
650815	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
650816	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Regulator As Left Counter	21014	
650817	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
650818	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
650819	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
650820	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
650821	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	General Comments	ok	
650822	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
650823	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
650824	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
650825	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
650826	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
650827	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
650828	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
650829	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
650830	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
650831	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Regulator As Left Counter	107725	
650832	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
650833	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
650834	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Tank Leaks	None	
650835	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
650836	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
650837	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
650838	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
650839	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
650840	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
650841	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
650842	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
650843	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
650844	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
650845	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
650846	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	General Comments		
650847	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
650848	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
650849	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
650850	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
650851	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Current Tap Position	6L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
650852	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
650853	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Current Tap Position	11L	
650854	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
650855	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
650856	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
650857	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
650858	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	General Comments	ok	
650859	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
650860	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Max Tap Position	9L	
650861	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
650862	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
650863	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
650864	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Operations Counter AL	213	
650865	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Operations Counter AF	212	
650866	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Moisture and Leak Free?	y	
650867	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Maintenance Operations	0	
650868	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Heaters (All) Functioning?	y	
650869	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Grounds in Place?	y	
650870	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	General Comments		
650871	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	General Comments		
650872	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Follow-up Action Required?	n	
650873	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Follow-up Action Required?	n	
650874	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Fault Operations Ground	0	
650875	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Fault Operations C Ø	0	
650876	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Fault Operations B Ø	0	
650877	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
650878	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
650879	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
650880	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
650881	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Fault Operations A Ø	0	
650882	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	33	
650883	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	34	
650884	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
650885	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
650886	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
650887	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
650888	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
650889	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Current Tap Position	9L	
650890	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
650891	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
650892	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
650893	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
650894	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	General Comments	needs varmint guard	
650895	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
650896	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Max Tap Position	8L	
650897	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Min Tap Position	13L	
650898	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
650899	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Vegetation	None	
650900	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Operations C Ø	0	
650901	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
650902	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Regulator As Left Counter	5428	
650903	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
650904	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
650905	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
650906	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
650907	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
650908	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
650909	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
650910	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
650911	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	General Comments		
650912	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
650913	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
650914	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Operations Ground	0	
650915	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Follow-up Action Required?	n	
650916	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Follow-up Action Required?	n	
650917	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
650918	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
650919	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
650920	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
650921	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
650922	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
650923	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
650924	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
650925	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Tank Leaks	None	
650926	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
650927	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
650928	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
650929	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
650930	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Regulator As Left Counter	5299	
650931	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
650932	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
650933	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
650934	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
650935	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
650936	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
650937	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
650938	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
650939	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
650940	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Operations Counter AL	241	
650941	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Operations Counter AF	239	
650942	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Moisture and Leak Free?	y	
650943	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Maintenance Operations	0	
650944	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Grounds in Place?	y	
650945	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	General Comments		
650946	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	General Comments		
650947	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Foundation Condition	Good	
650948	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Follow-up Action Required?	n	
650949	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Follow-up Action Required?	n	
650950	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Operations Ground	0	
650951	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Operations C Ø	0	
650952	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Operations B Ø	0	
650953	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
650954	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
650955	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
650956	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
650957	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
650958	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
650959	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
650960	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
650961	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Regulator As Left Counter	32394	
650962	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
650963	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Tank Leaks	None	
650964	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
650965	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Operations Ground	0	
650966	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Operations C Ø	0	
650967	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Operations B Ø	0	
650968	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Operations A Ø	0	
650969	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
650970	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
650971	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
650972	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Equipment Properly Labeled?	y	
650973	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Cabinet Paint Condition	Good	
650974	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
650975	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
650976	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
650977	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Amps C Ø	125.0	
650978	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Amps A Ø	28.0	
650979	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Operations A Ø	0	
650980	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
650981	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Switching Operations	2	
650982	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Tank Paint Condition	Good	
650983	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Unknown Operations	0	
650984	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
650985	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
650986	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	General Comments	ok	
650987	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	General Comments	ok	
650988	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
650989	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
650990	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2000	psi
650991	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
650992	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	62.50	
650993	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
650994	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
650995	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
650996	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
650997	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
650998	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
650999	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
651000	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
651001	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Top Oil Temperature Max	40	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
651002	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Top Oil Temperature Present	30	°C
651003	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
651004	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Winding Temp Max	40	°C
651005	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Winding Temp Present	32	°C
651006	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
651007	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
651008	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Tank Leaks	None	
651009	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
651010	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
651011	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
651012	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
651013	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
651014	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Follow-up Action Required?	n	
651015	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
651016	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
651017	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
651018	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
651019	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
651020	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
651021	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
651022	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	General Comments	ok	
651023	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Regulator As Left Counter	66873	
651024	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
651025	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
651026	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
651027	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
651028	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
651029	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Min Tap Position	1R	
651030	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Max Tap Position	4R	
651031	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
651032	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	General Comments		
651033	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
651034	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
651035	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
651036	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
651037	1/7/2019 12:39	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Current Tap Position	2R	
651038	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
651039	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
651040	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
651041	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
651042	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
651043	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	57	°F
651044	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
651045	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
651046	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
651047	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Unknown Operations	0	
651048	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Tank Paint Condition	Good	
651049	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
651050	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
651051	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
651052	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
651053	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
651054	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
651055	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
651056	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
651057	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
651058	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
651059	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Switching Operations	2	
651060	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
651061	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Operations Counter AL	204	
651062	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Operations Counter AF	202	
651063	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Moisture and Leak Free?	y	
651064	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Maintenance Operations	0	
651065	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Grounds in Place?	y	
651066	1/7/2019 15:04	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
651067	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	General Comments		
651068	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	General Comments		
651069	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Operations A Ø	0	
651070	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Operations B Ø	0	
651071	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Operations C Ø	0	
651072	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Operations Ground	0	
651073	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Follow-up Action Required?	n	
651074	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Follow-up Action Required?	n	
651075	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Foundation Condition	Good	
651076	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
651077	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Follow-up Action Required?	n	
651078	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Operations Ground	0	
651079	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Operations C Ø	0	
651080	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Operations B Ø	0	
651081	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Operations A Ø	0	
651082	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
651083	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
651084	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
651085	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Equipment Properly Labeled?	y	
651086	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Cabinet Paint Condition	Good	
651087	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
651088	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
651089	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
651090	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
651091	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	8.0	VDC
651092	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	8.0	VDC
651093	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
651094	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
651095	1/7/2019 15:34	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Adjusted Amps C Phase V	0	
651096	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
651097	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
651098	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
651099	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Equipment Properly Labeled?	y	
651100	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Cabinet Paint Condition	Good	
651101	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
651102	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
651103	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
651104	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	General Comments		
651105	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Amps B Ø	39.0	
651106	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Amps C Ø	18.0	
651107	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
651108	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
651109	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
651110	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
651111	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
651112	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
651113	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
651114	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
651115	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
651116	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	General Comments	ok	
651117	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
651118	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
651119	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
651120	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
651121	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
651122	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
651123	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
651124	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
651125	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
651126	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
651127	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Amps C Ø	95.0	
651128	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Amps B Ø	105.0	
651129	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Amps A Ø	95.0	
651130	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
651131	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
651132	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
651133	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	9 Month Operations	8	
651134	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
651135	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
651136	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
651137	1/7/2019 14:24	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
651138	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
651139	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Tank Leaks	None	
651140	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
651141	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
651142	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Regulator As Left Counter	4135	
651143	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
651144	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
651145	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
651146	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
651147	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
651148	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
651149	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
651150	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
651151	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
651152	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
651153	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
651154	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Operations Counter	81	
651155	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Bushing Condition	Good	
651156	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Bushings Connection/Risers	Good	
651157	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
651158	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Grounds in Place?	y	
651159	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
651160	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
651161	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
651162	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
651163	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
651164	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
651165	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
651166	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Cabinet Paint Condition	Good	
651167	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Operations Counter AL	173	
651168	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Operations Counter AF	170	
651169	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
651170	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Equipment Properly Labeled?	y	
651171	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
651172	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
651173	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Equipment Properly Labeled?	y	
651174	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
651175	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Operations Ground	0	
651176	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Follow-up Action Required?	n	
651177	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Follow-up Action Required?	n	
651178	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Foundation Condition	Good	
651179	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	General Comments		
651180	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	General Comments		
651181	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Grounds in Place?	y	
651182	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Maintenance Operations	0	
651183	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Cabinet Paint Condition	Good	
651184	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
651185	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
651186	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
651187	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
651188	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
651189	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Moisture and Leak Free?	y	
651190	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
651191	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	General Comments		
651192	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
651193	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
651194	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
651195	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Regulator As Left Counter	23199	
651196	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
651197	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
651198	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
651199	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
651200	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
651201	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Oil Temp Present	30	°C
651202	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
651203	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	General Comments		
651204	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	General Comments		
651205	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
651206	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
651207	1/7/2019 14:50	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
651208	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1175.04	kw
651209	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	9 Month Operations	3	
651210	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Amps C Ø	25.0	
651211	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Operations A Ø	0	
651212	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Adjusted Amps C Phase V	24.00	
651213	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Accumulated Fault Duty A Ph V	9.43	%
651214	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Accumulated Fault Duty B Ph V	12.87	%
651215	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Accumulated Fault Duty C Ph V	9.43	%
651216	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Adjusted Amps B Phase V	24.00	
651217	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
651218	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Operations B Ø	0	
651219	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Operations C Ø	0	
651220	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Amps A Ø	0.0	
651221	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Operations Ground	0	
651222	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Follow-up Action Required?	n	
651223	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Unknown Operations	0	
651224	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Follow-up Action Required?	n	
651225	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Foundation Condition	Good	
651226	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	General Comments	ok	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
651227	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Amps B Ø	0.0	
651228	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Amps C Ø	0.0	
651229	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
651230	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
651231	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	General Comments	ok	
651232	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Grounds in Place?	y	
651233	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Tank Paint Condition	Good	
651234	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Switching Operations	3	
651235	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
651236	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Operations Counter AL	222	
651237	1/7/2019 13:42	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Operations Counter AF	220	
651238	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Operations A Ø	0	
651239	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
651240	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
651241	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
651242	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Operations B Ø	0	
651243	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Operations C Ø	0	
651244	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
651245	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	General Comments	ok	
651246	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
651247	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Adjusted Amps A Phase V	24.00	
651248	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Equipment Properly Labeled?	y	
651249	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Cabinet Paint Condition	Good	
651250	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
651251	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
651252	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
651253	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
651254	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
651255	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	484.56	kw
651256	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
651257	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
651258	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Accumulated Fault Duty B Ph V	22.93	%
651259	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
651260	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	General Comments	ok	
651261	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	General Comments	ok	
651262	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Accumulated Fault Duty A Ph V	22.93	%
651263	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
651264	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
651265	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
651266	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Switching Operations	3	
651267	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Tank Paint Condition	Good	
651268	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	9 Month Operations	5	
651269	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Unknown Operations	0	
651270	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
651271	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Maintenance Operations	0	
651272	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Moisture and Leak Free?	y	
651273	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Operations Counter AF	259	
651274	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Operations Counter AL	259	
651275	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
651276	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
651277	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
651278	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Unknown Operations	0	
651279	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
651280	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.4038	
651281	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
651282	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	General Comments	ok	
651283	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
651284	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
651285	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
651286	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
651287	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Amps C Ø	0.0	
651288	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Amps B Ø	0.0	
651289	1/7/2019 11:43	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Amps A Ø	0.0	
651290	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
651291	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Amps B Ø	25.0	
651292	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
651293	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
651294	1/7/2019 11:15	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Amps A Ø	18.7	
651295	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Tank Leaks	None	
651296	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
651297	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
651298	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Amps A Ø	25.0	
651299	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
651300	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Switching Operations	0	
651301	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
651302	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Oil Temp Max	50	°C
651303	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
651304	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
651305	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
651306	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
651307	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
651308	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
651309	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
651310	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
651311	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
651312	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
651313	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
651314	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
651315	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
651316	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
651317	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
651318	1/7/2019 13:52	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
651319	1/7/2019 13:01	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Accumulated Fault Duty C Ph V	22.93	%
651320	1/7/2019 13:37	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Heaters (All) Functioning?	y	
651321	1/7/2019 11:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
651322	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LTCC000517	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
651323	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LTCC000517	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
651324	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LTCC000517	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
651325	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LTCC000517	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
651326	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
651327	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
651328	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
651329	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
651330	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Ambient Temp	47	°F
651331	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
651332	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
651333	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	General Comments		
651334	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
651335	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
651336	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Bushing Condition	Good	
651337	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Bushings Connection/Risers	Good	
651338	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Clear of Trash?	y	
651339	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Operations Counter AF	247	
651340	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
651341	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Operations Counter AL	247	
651342	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
651343	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
651344	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Switching Operations	0	
651345	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Amps C Ø	120.0	
651346	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Amps B Ø	120.0	
651347	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Amps A Ø	120.0	
651348	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
651349	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
651350	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Accumulated Fault Duty C Ph V	.75	%
651351	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Accumulated Fault Duty B Ph V	.75	%
651352	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Accumulated Fault Duty A Ph V	.75	%
651353	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	9 Month Operations	7	
651354	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
651355	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
651356	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
651357	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
651358	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
651359	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
651360	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
651361	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
651362	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
651363	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
651364	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
651365	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Amps A Ø	70.0	
651366	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Amps B Ø	75.0	
651367	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Amps C Ø	78.0	
651368	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
651369	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
651370	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
651371	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
651372	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
651373	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
651374	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	General Comments		
651375	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
651376	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
651377	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
651378	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
651379	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
651380	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
651381	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
651382	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
651383	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
651384	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
651385	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
651386	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	General Comments		
651387	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
651388	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
651389	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Vegetation	None	
651390	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
651391	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Unknown Operations	0	
651392	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Tank Paint Condition	Good	
651393	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
651394	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
651395	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
651396	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
651397	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
651398	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
651399	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
651400	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
651401	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
651402	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
651403	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
651404	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
651405	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	General Comments		
651406	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
651407	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
651408	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
651409	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
651410	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
651411	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
651412	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
651413	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
651414	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Regulator As Left Counter	5389	
651415	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Unknown Operations	0	
651416	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Ambient Temp	48	°F
651417	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
651418	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
651419	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Clear of Trash?	y	
651420	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
651421	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
651422	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
651423	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
651424	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
651425	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	General Comments		
651426	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
651427	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Vegetation	None	
651428	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
651429	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Tank Paint Condition	Good	
651430	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	9 Month Operations	5	
651431	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Accumulated Fault Duty A Ph V	30.81	%
651432	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Accumulated Fault Duty B Ph V	27.80	%
651433	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Accumulated Fault Duty C Ph V	27.05	%
651434	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Amps A Ø	195.0	
651435	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Amps B Ø	160.0	
651436	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
651437	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	General Comments		
651438	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
651439	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
651440	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
651441	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
651442	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
651443	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
651444	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Amps C Ø	190.0	
651445	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Bushing Condition	Good	
651446	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Bushings Connection/Risers	Good	
651447	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
651448	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
651449	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
651450	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
651451	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
651452	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
651453	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
651454	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Operations Counter	942	
651455	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
651456	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Tank Leaks	None	
651457	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
651458	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
651459	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
651460	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
651461	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	General Comments		
651462	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	538	
651463	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Amps A Ø	18.4	
651464	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Amps B Ø	16.1	
651465	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Amps C Ø	13.8	
651466	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Amps A Ø	71	
651467	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Amps B Ø	46	
651468	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
651469	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
651470	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
651471	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
651472	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
651473	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
651474	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
651475	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
651476	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
651477	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
651478	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
651479	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
651480	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
651481	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	General Comments		
651482	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
651483	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	388	
651484	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
651485	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
651486	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	418	
651487	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
651488	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
651489	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
651490	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	General Comments		
651491	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
651492	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Amps C Ø	35	
651493	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
651494	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
651495	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
651496	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
651497	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
651498	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
651499	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
651500	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
651501	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Clear of Trash?	y	
651502	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
651503	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Ambient Temp	42	°F
651504	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
651505	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	General Comments		
651506	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
651507	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
651508	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
651509	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
651510	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
651511	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
651512	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
651513	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
651514	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
651515	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
651516	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
651517	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
651518	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Follow-up Action Required?	n	
651519	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
651520	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
651521	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	General Comments		
651522	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	General Comments		
651523	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
651524	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	LTC Totalizer Reading	6172.8	kw
651525	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
651526	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
651527	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Oil Temp Max	60	°C
651528	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Oil Temp Present	32	°C
651529	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
651530	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
651531	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Adjusted Amps B Phase V	0	
651532	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Adjusted Amps C Phase V	0	
651533	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Operations A Ø	0	
651534	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Operations B Ø	0	
651535	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Operations C Ø	0	
651536	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Operations Ground	0	
651537	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Follow-up Action Required?	n	
651538	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Follow-up Action Required?	n	
651539	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Foundation Condition	Good	
651540	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	General Comments		
651541	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	General Comments		
651542	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Grounds in Place?	y	
651543	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
651544	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
651545	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
651546	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
651547	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Heaters (All) Functioning?	y	
651548	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Maintenance Operations	0	
651549	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Moisture and Leak Free?	y	
651550	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
651551	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
651552	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Totalizer Meter Reading	.643	
651553	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
651554	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
651555	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	275.0	
651556	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	271.0	
651557	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
651558	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
651559	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
651560	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
651561	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
651562	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
651563	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
651564	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
651565	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
651566	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
651567	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
651568	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
651569	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
651570	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
651571	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Foundation Condition	Good	
651572	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
651573	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
651574	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	General Comments		
651575	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
651576	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
651577	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
651578	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
651579	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
651580	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
651581	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
651582	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
651583	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
651584	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
651585	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
651586	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Maintenance Operations	0	
651587	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Moisture and Leak Free?	y	
651588	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Operations Counter AF	293	
651589	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Operations Counter AL	293	
651590	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Switching Operations	0	
651591	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Tank Paint Condition	Good	
651592	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Unknown Operations	0	
651593	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
651594	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	265.0	
651595	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
651596	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
651597	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
651598	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
651599	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
651600	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
651601	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
651602	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0	VDC
651603	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
651604	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
651605	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
651606	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
651607	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
651608	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Oil Temp Present	29	°C
651609	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Oil Temp Max	29	°C
651610	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
651611	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
651612	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	LTC Totalizer Reading	5276.16	kw
651613	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
651614	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	General Comments		
651615	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	General Comments		
651616	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
651617	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
651618	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Follow-up Action Required?	n	
651619	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
651620	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
651621	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
651622	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
651623	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Follow-up Action Required?	n	
651624	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Follow-up Action Required?	n	
651625	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Operations Ground	0	
651626	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Operations C Ø	0	
651627	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Operations B Ø	0	
651628	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Heaters (All) Functioning?	y	
651629	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
651630	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
651631	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Operations A Ø	0	
651632	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
651633	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
651634	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
651635	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
651636	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
651637	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	General Comments		
651638	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
651639	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
651640	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Foundation Condition	Good	
651641	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
651642	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
651643	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
651644	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
651645	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
651646	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
651647	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
651648	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
651649	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
651650	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
651651	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC Operations Since Last Insp	334	
651652	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
651653	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
651654	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC Min Tap Position	11L	
651655	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC Max Tap Position	1L	
651656	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC Current Tap Position	5L	
651657	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
651658	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC As Left Counter	17988	
651659	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC As Found Counter	17988	
651660	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	General Comments		
651661	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	General Comments		
651662	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
651663	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	Follow-up Action Required?	n	
651664	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
651665	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
651666	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
651667	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC Operations Since Last Insp	202	
651668	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC Min Tap Position	1L	
651669	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC Max Tap Position	10L	
651670	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC Current Tap Position	3L	
651671	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
651672	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC As Left Counter	101864	
651673	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC As Found Counter	101860	
651674	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	General Comments		
651675	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	General Comments		
651676	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
651677	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	Follow-up Action Required?	n	
651678	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Equipment Properly Labeled?	y	
651679	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Cabinet Paint Condition	Good	
651680	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
651681	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
651682	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
651683	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
651684	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
651685	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
651686	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
651687	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
651688	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
651689	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
651690	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
651691	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
651692	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
651693	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	General Comments		
651694	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
651695	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
651696	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Foundation Condition	Good	
651697	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
651698	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
651699	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
651700	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
651701	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
651702	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
651703	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Unknown Operations	0	
651704	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Tank Paint Condition	Good	
651705	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Switching Operations	6	
651706	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
651707	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
651708	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
651709	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
651710	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
651711	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
651712	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
651713	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
651714	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
651715	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
651716	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
651717	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
651718	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
651719	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	General Comments	Fence is new.	
651720	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
651721	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Operations Counter AL	269	
651722	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Operations Counter AF	264	
651723	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Moisture and Leak Free?	y	
651724	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Maintenance Operations	0	
651725	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Heaters (All) Functioning?	y	
651726	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Grounds in Place?	y	
651727	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	General Comments		
651728	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	General Comments		
651729	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Foundation Condition	Good	
651730	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
651731	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
651732	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
651733	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
651734	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
651735	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
651736	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
651737	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
651738	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
651739	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
651740	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Accumulated Fault Duty C Ph V	0	%
651741	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Amps A Ø	10	
651742	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Amps B Ø	10	
651743	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Amps C Ø	10	
651744	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Bushing Condition	Good	
651745	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Bushings Connection/Risers	Good	
651746	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
651747	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
651748	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
651749	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
651750	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Operations Counter AL	140	
651751	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Operations Counter AF	140	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
651752	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Moisture and Leak Free?	y	
651753	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Maintenance Operations	0	
651754	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Heaters (All) Functioning?	y	
651755	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	Follow-up Action Required?	n	
651756	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
651757	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	General Comments		
651758	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	General Comments		
651759	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Grounds in Place?	y	
651760	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	General Comments		
651761	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
651762	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	General Comments		
651763	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Unknown Operations	0	
651764	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Foundation Condition	Good	
651765	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Follow-up Action Required?	n	
651766	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Cabinet Paint Condition	Good	
651767	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Equipment Properly Labeled?	y	
651768	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Follow-up Action Required?	n	
651769	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Operations Ground	0	
651770	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
651771	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Totalizer Meter Multiplier	1000	
651772	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Totalizer Meter Reading	4.1325	
651773	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Winding Temp Max	40	°C
651774	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Winding Temp Present	20	°C
651775	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
651776	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
651777	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Operations C Ø	0	
651778	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Operations B Ø	0	
651779	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Operations A Ø	0	
651780	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Adjusted Amps C Phase V	0	
651781	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Adjusted Amps B Phase V	0	
651782	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Adjusted Amps A Phase V	0	
651783	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	General Comments		
651784	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Foundation Condition	Good	
651785	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Follow-up Action Required?	n	
651786	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Follow-up Action Required?	n	
651787	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Operations Ground	0	
651788	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Operations C Ø	0	
651789	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Cabinet Paint Condition	Good	
651790	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Equipment Properly Labeled?	y	
651791	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Adjusted Amps A Phase V	0	
651792	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Adjusted Amps B Phase V	0	
651793	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Adjusted Amps C Phase V	0	
651794	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Operations A Ø	0	
651795	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Operations B Ø	0	
651796	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Operations C Ø	0	
651797	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Operations Ground	0	
651798	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Follow-up Action Required?	n	
651799	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Follow-up Action Required?	n	
651800	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Foundation Condition	Good	
651801	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	General Comments		
651802	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
651803	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
651804	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
651805	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
651806	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
651807	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
651808	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
651809	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
651810	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	General Comments		
651811	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	General Comments		
651812	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
651813	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
651814	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
651815	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	757.44	kw
651816	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
651817	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
651818	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	General Comments		
651819	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
651820	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	LTC Totalizer Reading	4132.50	kw
651821	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
651822	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
651823	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	96.00	
651824	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
651825	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
651826	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Oil Temp Max	40	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
651827	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Oil Temp Present	20	°C
651828	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
651829	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
651830	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
651831	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
651832	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
651833	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
651834	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
651835	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Oil Temp Present	42	°C
651836	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
651837	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
651838	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
651839	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
651840	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
651841	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
651842	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
651843	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
651844	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
651845	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
651846	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6312	
651847	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Unknown Operations	0	
651848	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Tank Paint Condition	Good	
651849	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Switching Operations	0	
651850	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
651851	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
651852	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
651853	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	9 Month Operations	4	
651854	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Accumulated Fault Duty A Ph V	0	%
651855	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
651856	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Switching Operations	0	
651857	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
651858	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Operations Counter AL	239	
651859	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Operations Counter AF	239	
651860	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Moisture and Leak Free?	y	
651861	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Maintenance Operations	0	
651862	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Unknown Operations	0	
651863	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Accumulated Fault Duty B Ph V	0	%
651864	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Operations A Ø	0	
651865	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
651866	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Readings	General Comments		
651867	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Adjusted Amps C Phase V	0	
651868	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Adjusted Amps B Phase V	0	
651869	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
651870	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Vegetation	None	
651871	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Adjusted Amps A Phase V	0	
651872	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Equipment Properly Labeled?	y	
651873	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Cabinet Paint Condition	Good	
651874	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
651875	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
651876	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
651877	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Bushings Connection/Risers	Good	
651878	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Bushing Condition	Good	
651879	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
651880	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
651881	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
651882	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC Min Tap Position	7L	
651883	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	36	°C
651884	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	18	°C
651885	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC Operations Since Last Insp	251	
651886	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
651887	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
651888	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
651889	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
651890	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Amps C Ø	10	
651891	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCC000726	LTCControl	428-2	LTC Control Insp	All Connections OK?	y	
651892	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCC000726	LTCControl	428-2	LTC Control Insp	Follow-up Action Required?	n	
651893	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCC000726	LTCControl	428-2	LTC Control Insp	General Comments		
651894	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Amps B Ø	10	
651895	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCC000726	LTCControl	428-2	LTC Control Insp	LTC Operation Checked?	y	
651896	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCC000726	LTCControl	428-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
651897	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCC000726	LTCControl	428-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
651898	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCC000726	LTCControl	428-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
651899	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCC000726	LTCControl	428-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
651900	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCC000726	LTCControl	428-2	LTC Control Insp	VRR Time Delay	30	Seconds
651901	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
651902	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
651903	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Amps A Ø	10	
651904	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Accumulated Fault Duty C Ph V	2.85	%
651905	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Accumulated Fault Duty B Ph V	2.85	%
651906	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Accumulated Fault Duty A Ph V	2.85	%
651907	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	9 Month Operations	5	
651908	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Cabinet Paint Condition	Good	
651909	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Equipment Properly Labeled?	y	
651910	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Adjusted Amps A Phase V	0	
651911	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Adjusted Amps B Phase V	0	
651912	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Adjusted Amps C Phase V	0	
651913	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Operations A Ø	0	
651914	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Operations B Ø	0	
651915	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Operations C Ø	0	
651916	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
651917	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
651918	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Operations Ground	0	
651919	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Follow-up Action Required?	n	
651920	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Follow-up Action Required?	n	
651921	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Foundation Condition	Good	
651922	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	General Comments		
651923	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	General Comments		
651924	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Grounds in Place?	y	
651925	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
651926	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	General Comments		
651927	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Grounds in Place?	y	
651928	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Operations B Ø	0	
651929	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Operations A Ø	0	
651930	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC As Found Counter	305	
651931	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
651932	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
651933	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
651934	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC Operations Since Last Insp	37	
651935	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC As Left Counter	305	
651936	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
651937	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
651938	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
651939	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
651940	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
651941	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
651942	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC Current Tap Position	3L	
651943	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC Max Tap Position	2R	
651944	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
651945	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
651946	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
651947	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Clear of Trash?	y	
651948	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
651949	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
651950	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Tank Paint Condition	Good	
651951	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Switching Operations	0	
651952	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
651953	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Operations Counter AL	178	
651954	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Operations Counter AF	178	
651955	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Moisture and Leak Free?	y	
651956	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Maintenance Operations	0	
651957	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
651958	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Heaters (All) Functioning?	y	
651959	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Grounds in Place?	y	
651960	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
651961	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC Min Tap Position	6L	
651962	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
651963	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	General Comments		
651964	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	General Comments		
651965	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Foundation Condition	Good	
651966	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Follow-up Action Required?	n	
651967	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Follow-up Action Required?	n	
651968	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Operations Ground	0	
651969	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
651970	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
651971	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
651972	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	849	
651973	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	Follow-up Action Required?	n	
651974	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
651975	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Operations C Ø	0	
651976	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
651977	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	General Comments		
651978	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	General Comments		
651979	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC As Found Counter	4692	
651980	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	849	
651981	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	15	
651982	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
651983	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
651984	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC As Left Counter	4692	
651985	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
651986	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
651987	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC Max Tap Position	2R	
651988	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
651989	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
651990	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
651991	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
651992	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	General Comments		
651993	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
651994	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
651995	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
651996	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
651997	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
651998	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
651999	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
652000	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
652001	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
652002	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
652003	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	Clear of Trash?	y	
652004	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Cabinet Paint Condition	Good	
652005	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
652006	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Tank Leaks	None	
652007	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
652008	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Equipment Properly Labeled?	y	
652009	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
652010	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
652011	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
652012	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
652013	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
652014	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
652015	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	YD000454	Yard	417-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
652016	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
652017	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
652018	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Tank Leaks	None	
652019	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
652020	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	General Comments		
652021	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
652022	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
652023	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	9 Month Operations	16	
652024	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Accumulated Fault Duty A Ph V	2.85	%
652025	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Accumulated Fault Duty B Ph V	2.38	%
652026	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Accumulated Fault Duty C Ph V	1.43	%
652027	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Amps A Ø	10	
652028	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Amps B Ø	10	
652029	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Amps C Ø	10	
652030	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Bushing Condition	Good	
652031	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Bushings Connection/Risers	Good	
652032	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
652033	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
652034	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
652035	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
652036	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
652037	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
652038	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	General Comments		
652039	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
652040	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
652041	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
652042	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
652043	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
652044	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
652045	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
652046	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
652047	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
652048	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
652049	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
652050	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Clear of Trash?	y	
652051	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
652052	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
652053	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
652054	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
652055	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
652056	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	General Comments		
652057	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
652058	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Vegetation	None	
652059	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Vegetation	None	
652060	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
652061	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
652062	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
652063	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
652064	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
652065	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
652066	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
652067	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
652068	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
652069	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
652070	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
652071	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
652072	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	180	
652073	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	176	
652074	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
652075	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
652076	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
652077	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
652078	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
652079	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
652080	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
652081	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
652082	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
652083	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
652084	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
652085	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
652086	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
652087	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
652088	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
652089	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	General Comments		
652090	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
652091	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	9 Month Operations	4	
652092	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Foundation Condition	Good	
652093	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
652094	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
652095	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	General Comments		
652096	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
652097	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
652098	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
652099	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
652100	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
652101	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Tank Leaks	None	
652102	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
652103	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
652104	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Operations Counter	68	
652105	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
652106	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
652107	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
652108	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
652109	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
652110	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Vegetation	None	
652111	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
652112	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Regulator As Left Counter	5183	
652113	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
652114	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
652115	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
652116	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Tank Leaks	None	
652117	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
652118	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
652119	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
652120	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
652121	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC As Left Counter	287244	
652122	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC As Found Counter	287244	
652123	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
652124	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	General Comments		
652125	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
652126	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
652127	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
652128	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0415	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
652129	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Readings	Accumulated Fault Duty A Ph V	.7	%
652130	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Readings	Accumulated Fault Duty B Ph V	1.75	%
652131	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
652132	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
652133	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
652134	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
652135	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
652136	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Readings	Accumulated Fault Duty C Ph V	.35	%
652137	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
652138	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Readings	Amps A Ø	80	
652139	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Readings	Amps B Ø	80	
652140	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Readings	Amps C Ø	80	
652141	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Bushing Condition	Good	
652142	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
652143	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
652144	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Regulator As Left Counter	159573	
652145	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
652146	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
652147	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
652148	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
652149	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
652150	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Min Tap Position	15L	
652151	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Max Tap Position	7L	
652152	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
652153	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	General Comments		
652154	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Bushings Connection/Risers	Good	
652155	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
652156	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
652157	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
652158	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
652159	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
652160	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
652161	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
652162	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
652163	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
652164	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
652165	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
652166	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Current Tap Position	12L	
652167	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
652168	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
652169	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
652170	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
652171	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
652172	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
652173	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
652174	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
652175	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
652176	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
652177	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
652178	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
652179	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
652180	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
652181	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
652182	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
652183	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
652184	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
652185	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
652186	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
652187	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
652188	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
652189	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
652190	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
652191	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
652192	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
652193	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
652194	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
652195	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
652196	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
652197	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
652198	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
652199	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
652200	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
652201	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
652202	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
652203	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
652204	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
652205	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
652206	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
652207	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
652208	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
652209	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
652210	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	40.0	
652211	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	80.0	
652212	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	80.0	
652213	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	44	
652214	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
652215	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
652216	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
652217	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
652218	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
652219	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
652220	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	General Comments		
652221	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
652222	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
652223	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
652224	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
652225	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
652226	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
652227	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
652228	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
652229	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
652230	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
652231	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
652232	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
652233	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
652234	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
652235	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
652236	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
652237	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	365.0	
652238	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
652239	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
652240	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
652241	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Grounds in Place?	y	
652242	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	General Comments		
652243	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	General Comments		
652244	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Foundation Condition	Good	
652245	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Follow-up Action Required?	n	
652246	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Follow-up Action Required?	n	
652247	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Operations Ground	0	
652248	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Operations C Ø	0	
652249	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Operations B Ø	0	
652250	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Operations A Ø	0	
652251	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
652252	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
652253	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
652254	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
652255	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
652256	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
652257	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
652258	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
652259	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
652260	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Bushing Condition	Good	
652261	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	70	°C
652262	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	40	°C
652263	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
652264	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
652265	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
652266	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	General Comments	Y. Gauge is a pull to reset, don't need a magnet	
652267	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
652268	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
652269	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Winding Temp Present	20	°C
652270	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Winding Temp Max	30	°C
652271	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
652272	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
652273	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
652274	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
652275	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
652276	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
652277	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
652278	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	General Comments		
652279	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
652280	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
652281	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
652282	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
652283	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
652284	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
652285	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	LTCMechanism	417-1	LTC Counter Readings	Follow-up Action Required?	n	
652286	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
652287	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	LTCMechanism	417-1	LTC Counter Readings	General Comments		
652288	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
652289	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
652290	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	120.0	
652291	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
652292	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Amps C Ø	0.0	
652293	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	120.0	
652294	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	120.0	
652295	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Amps B Ø	0.0	
652296	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Amps A Ø	0.0	
652297	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Accumulated Fault Duty C Ph V	16.24	%
652298	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Accumulated Fault Duty B Ph V	16.24	%
652299	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Accumulated Fault Duty A Ph V	16.24	%
652300	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	9 Month Operations	4	
652301	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
652302	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
652303	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
652304	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
652305	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
652306	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Readings	General Comments		
652307	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	General Comments		
652308	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	General Comments		
652309	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	General Comments		
652310	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	LTCMechanism	417-1	LTC Counter Readings	LTC As Found Counter	6133	
652311	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	LTCMechanism	417-1	LTC Counter Readings	LTC As Left Counter	6137	
652312	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
652313	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	LTCMechanism	417-1	LTC Counter Readings	LTC Current Tap Position	1L	
652314	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	LTCMechanism	417-1	LTC Counter Readings	LTC Max Tap Position	9L	
652315	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
652316	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
652317	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
652318	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
652319	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
652320	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
652321	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
652322	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
652323	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
652324	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
652325	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
652326	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
652327	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	12	
652328	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	673	
652329	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	677	
652330	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
652331	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
652332	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
652333	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
652334	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
652335	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
652336	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
652337	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
652338	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000305	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
652339	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000305	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
652340	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000305	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
652341	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000305	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	122.0	VAC
652342	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000305	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
652343	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000305	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
652344	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000305	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
652345	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000305	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
652346	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
652347	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
652348	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
652349	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC Min Tap Position	3R	
652350	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC Max Tap Position	11L	
652351	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC Current Tap Position	1L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
652352	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
652353	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC As Left Counter	46247	
652354	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC As Found Counter	46243	
652355	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
652356	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
652357	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
652358	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
652359	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
652360	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
652361	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
652362	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
652363	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
652364	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
652365	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
652366	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
652367	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
652368	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	General Comments		
652369	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Unknown Operations	0	
652370	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Tank Paint Condition	Good	
652371	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
652372	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
652373	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
652374	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
652375	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
652376	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
652377	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
652378	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
652379	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
652380	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
652381	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	General Comments		
652382	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
652383	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Switching Operations	2	
652384	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Operations Counter AL	244	
652385	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Operations Counter AF	242	
652386	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
652387	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Maintenance Operations	0	
652388	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
652389	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
652390	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
652391	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
652392	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
652393	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	365.0	
652394	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	368.0	
652395	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
652396	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
652397	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
652398	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
652399	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
652400	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	LTC Totalizer Reading	1893.60	kw
652401	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
652402	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	11	
652403	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Amps A Ø	3.0	
652404	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Amps B Ø	2.0	
652405	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Amps C Ø	2.0	
652406	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	13	
652407	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
652408	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
652409	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	10	
652410	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
652411	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
652412	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
652413	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Totalizer Meter Reading	1.1250	
652414	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
652415	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
652416	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
652417	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
652418	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
652419	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
652420	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
652421	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
652422	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Oil Temp Present	38	°C
652423	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
652424	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	General Comments		
652425	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
652426	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
652427	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
652428	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	General Comments		
652429	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	General Comments		
652430	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
652431	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
652432	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
652433	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
652434	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Follow-up Action Required?	n	
652435	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
652436	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
652437	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
652438	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
652439	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
652440	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
652441	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
652442	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
652443	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
652444	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
652445	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
652446	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
652447	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
652448	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
652449	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
652450	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
652451	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
652452	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	General Comments		
652453	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	General Comments		
652454	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
652455	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	Follow-up Action Required?	n	
652456	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Grounds in Place?	y	
652457	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Heaters (All) Functioning?	y	
652458	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
652459	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
652460	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Foundation Condition	Good	
652461	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
652462	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
652463	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	General Comments	tower foundations are crumbling	
652464	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
652465	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
652466	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
652467	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
652468	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
652469	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
652470	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
652471	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
652472	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
652473	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
652474	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
652475	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
652476	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
652477	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
652478	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
652479	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	1	
652480	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	594	
652481	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	594	
652482	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
652483	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
652484	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
652485	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
652486	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
652487	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
652488	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
652489	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
652490	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
652491	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
652492	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0418	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
652493	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
652494	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
652495	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Oil Temp Present	30	°C
652496	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Oil Temp Max	40	°C
652497	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
652498	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
652499	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
652500	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
652501	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	LTC Min Tap Position	2R	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
652502	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1	psi
652503	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	LTC Operations Since Last Insp	320	
652504	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
652505	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
652506	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Totalizer Meter Reading	.2630	
652507	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
652508	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
652509	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
652510	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
652511	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
652512	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
652513	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
652514	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
652515	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
652516	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	General Comments		
652517	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	General Comments		
652518	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
652519	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
652520	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Follow-up Action Required?	n	
652521	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
652522	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
652523	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
652524	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
652525	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
652526	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
652527	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
652528	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
652529	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
652530	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
652531	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
652532	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
652533	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
652534	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Operations B Ø	0	
652535	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Operations C Ø	0	
652536	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Operations Ground	0	
652537	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Follow-up Action Required?	n	
652538	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Follow-up Action Required?	n	
652539	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Foundation Condition	Good	
652540	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
652541	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
652542	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
652543	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
652544	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
652545	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
652546	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
652547	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
652548	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Oil Temp Present	38	°C
652549	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Oil Temp Max	60	°C
652550	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
652551	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
652552	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
652553	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
652554	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
652555	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Bushings Connection/Risers	Good	
652556	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Bushing Condition	Good	
652557	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Amps C Ø	10.0	
652558	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Amps B Ø	10.0	
652559	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Amps A Ø	10.0	
652560	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
652561	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	9 Month Operations	4	
652562	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Accumulated Fault Duty A Ph V	.91	%
652563	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
652564	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Accumulated Fault Duty B Ph V	.46	%
652565	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Accumulated Fault Duty C Ph V	.46	%
652566	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Amps A Ø	10	
652567	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Amps B Ø	10	
652568	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
652569	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
652570	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
652571	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
652572	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Amps C Ø	10	
652573	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Bushing Condition	Good	
652574	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Bushings Connection/Risers	Good	
652575	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
652576	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
652577	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
652578	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
652579	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
652580	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
652581	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
652582	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	General Comments		
652583	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
652584	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
652585	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	9 Month Operations	9	
652586	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
652587	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
652588	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
652589	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
652590	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
652591	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
652592	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
652593	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
652594	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
652595	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
652596	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
652597	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
652598	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
652599	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
652600	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
652601	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	General Comments		
652602	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
652603	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
652604	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
652605	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
652606	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
652607	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
652608	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Foundation Condition	Good	
652609	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
652610	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
652611	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
652612	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
652613	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
652614	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
652615	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
652616	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC Operations Since Last Insp	310	
652617	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC Min Tap Position	11L	
652618	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC Max Tap Position	2L	
652619	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC Current Tap Position	6L	
652620	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC As Left Counter	235857	
652621	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
652622	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
652623	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
652624	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC Operations Since Last Insp	1245	
652625	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC Min Tap Position	11L	
652626	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
652627	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
652628	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
652629	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC Max Tap Position	3R	
652630	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC Current Tap Position	1R	
652631	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
652632	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC As Left Counter	51498	
652633	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
652634	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Switching Operations	5	
652635	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Operations Counter AL	255	
652636	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Operations Counter AF	250	
652637	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Moisture and Leak Free?	y	
652638	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Maintenance Operations	0	
652639	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Heaters (All) Functioning?	y	
652640	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
652641	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
652642	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
652643	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1	amps
652644	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
652645	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Grounds in Place?	y	
652646	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	General Comments		
652647	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	General Comments		
652648	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Foundation Condition	Good	
652649	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Tank Paint Condition	Good	
652650	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Follow-up Action Required?	n	
652651	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
652652	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Operations Ground	0	
652653	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Operations C Ø	0	
652654	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Operations B Ø	0	
652655	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Operations A Ø	0	
652656	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
652657	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
652658	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20	
652659	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Readings	Totalizer Meter Reading	.7506	
652660	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
652661	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
652662	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
652663	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
652664	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
652665	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
652666	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
652667	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
652668	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Readings	Oil Temp Present	30	°C
652669	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
652670	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
652671	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
652672	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	General Comments	A phase operations is correct. Think 58 was entered backwards last time.	
652673	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
652674	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
652675	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
652676	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	87	
652677	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Unknown Operations	0	
652678	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
652679	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
652680	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
652681	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
652682	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
652683	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
652684	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
652685	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
652686	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
652687	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
652688	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1844	
652689	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1940	
652690	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
652691	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
652692	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
652693	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	76	
652694	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Amps C Ø	17.0	
652695	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Amps B Ø	17.4	
652696	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Amps A Ø	7.8	
652697	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	85	
652698	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
652699	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
652700	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
652701	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
652702	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	General Comments		
652703	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
652704	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
652705	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
652706	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
652707	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
652708	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
652709	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Equipment Properly Labeled?	y	
652710	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Cabinet Paint Condition	Good	
652711	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
652712	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
652713	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
652714	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Cabinet Paint Condition	Good	
652715	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Equipment Properly Labeled?	y	
652716	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Adjusted Amps A Phase V	0	
652717	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Adjusted Amps B Phase V	0	
652718	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Adjusted Amps C Phase V	0	
652719	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Operations A Ø	0	
652720	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
652721	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
652722	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
652723	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC Operations Since Last Insp	297	
652724	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2	psi
652725	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
652726	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
652727	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
652728	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
652729	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
652730	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
652731	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
652732	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
652733	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
652734	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
652735	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
652736	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
652737	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Regulator As Left Counter	296178	
652738	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
652739	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Tank Leaks	None	
652740	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
652741	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
652742	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
652743	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
652744	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
652745	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	268	
652746	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
652747	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	270	
652748	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
652749	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
652750	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Readings	Oil Temp Max	40	°C
652751	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
652752	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
652753	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Readings	LTC Totalizer Reading	7205.76	kw
652754	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
652755	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Readings	General Comments		
652756	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	General Comments		
652757	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
652758	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
652759	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Readings	Follow-up Action Required?	n	
652760	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
652761	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
652762	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
652763	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
652764	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
652765	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
652766	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
652767	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
652768	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
652769	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
652770	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
652771	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
652772	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
652773	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
652774	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
652775	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
652776	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
652777	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
652778	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
652779	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
652780	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
652781	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
652782	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
652783	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	General Comments		
652784	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
652785	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
652786	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
652787	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
652788	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
652789	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
652790	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	General Comments		
652791	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
652792	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
652793	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC As Found Counter	235855	
652794	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	General Comments		
652795	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	Follow-up Action Required?	n	
652796	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC As Found Counter	51493	
652797	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	General Comments		
652798	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	General Comments		
652799	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
652800	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
652801	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
652802	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
652803	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
652804	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
652805	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
652806	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
652807	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
652808	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
652809	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	General Comments		
652810	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
652811	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
652812	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
652813	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	Follow-up Action Required?	n	
652814	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
652815	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
652816	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
652817	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
652818	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
652819	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	360.0	
652820	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	400.0	
652821	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	400.0	
652822	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
652823	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
652824	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
652825	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
652826	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
652827	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	Totalizer Meter Reading	.9860	
652828	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
652829	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
652830	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
652831	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
652832	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
652833	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
652834	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
652835	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
652836	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
652837	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
652838	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	LTC Totalizer Reading	5916.00	kw
652839	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
652840	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	General Comments		
652841	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	General Comments		
652842	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
652843	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
652844	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	Follow-up Action Required?	n	
652845	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
652846	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
652847	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
652848	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
652849	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
652850	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
652851	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
652852	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
652853	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
652854	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
652855	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
652856	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0	
652857	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0	
652858	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0	
652859	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
652860	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
652861	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
652862	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
652863	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
652864	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
652865	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
652866	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
652867	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
652868	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
652869	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
652870	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
652871	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
652872	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Adjusted Amps C Phase V	0	
652873	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Operations A Ø	0	
652874	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Operations B Ø	0	
652875	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Operations C Ø	0	
652876	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
652877	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Follow-up Action Required?	n	
652878	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Follow-up Action Required?	n	
652879	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Foundation Condition	Good	
652880	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
652881	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
652882	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
652883	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
652884	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	General Comments		
652885	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
652886	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
652887	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
652888	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
652889	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
652890	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Vegetation	None	
652891	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
652892	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
652893	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
652894	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
652895	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
652896	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
652897	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
652898	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
652899	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
652900	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
652901	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
652902	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	General Comments		
652903	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
652904	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
652905	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
652906	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
652907	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
652908	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
652909	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
652910	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
652911	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Regulator As Left Counter	187832	
652912	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
652913	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Tank Leaks	None	
652914	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
652915	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	General Comments		
652916	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	General Comments		
652917	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Grounds in Place?	y	
652918	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Heaters (All) Functioning?	y	
652919	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Maintenance Operations	0	
652920	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Moisture and Leak Free?	y	
652921	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Operations Counter AF	379	
652922	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Operations Counter AL	379	
652923	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
652924	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Switching Operations	0	
652925	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Tank Paint Condition	Good	
652926	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Unknown Operations	0	
652927	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Tank Paint Condition	Good	
652928	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
652929	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
652930	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
652931	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
652932	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
652933	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
652934	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
652935	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
652936	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
652937	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
652938	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
652939	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
652940	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
652941	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
652942	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
652943	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
652944	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	Follow-up Action Required?	n	
652945	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
652946	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	General Comments		
652947	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
652948	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
652949	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
652950	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
652951	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Amps A Ø	56	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
652952	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Accumulated Fault Duty C Ph V	0	%
652953	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Accumulated Fault Duty B Ph V	0	%
652954	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Accumulated Fault Duty A Ph V	0	%
652955	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	9 Month Operations	1	
652956	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Amps A Ø	30.0	
652957	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Amps B Ø	28.0	
652958	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Amps C Ø	28.0	
652959	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
652960	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
652961	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
652962	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
652963	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
652964	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
652965	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
652966	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
652967	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
652968	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
652969	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
652970	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	General Comments		
652971	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
652972	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
652973	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Operations Counter	31	
652974	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
652975	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Tank Leaks	None	
652976	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
652977	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	9 Month Operations	4	
652978	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Accumulated Fault Duty A Ph V	.35	%
652979	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Accumulated Fault Duty B Ph V	0	%
652980	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Accumulated Fault Duty C Ph V	0	%
652981	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Amps A Ø	140	
652982	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Amps B Ø	180	
652983	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Amps C Ø	120	
652984	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Clear of Trash?	y	
652985	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
652986	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Bushing Condition	Good	
652987	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Bushings Connection/Risers	Good	
652988	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
652989	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Tank Leaks	None	
652990	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
652991	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Operations Counter	57	
652992	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
652993	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
652994	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	General Comments		
652995	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
652996	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
652997	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
652998	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
652999	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
653000	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
653001	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
653002	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
653003	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
653004	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
653005	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
653006	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Amps C Ø	31	
653007	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Amps B Ø	30	
653008	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Amps A Ø	32	
653009	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
653010	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BCH000603	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
653011	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BCH000603	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
653012	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BCH000603	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
653013	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BCH000603	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
653014	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BCH000603	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
653015	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BCH000603	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
653016	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
653017	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
653018	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
653019	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Cabinet Paint Condition	Good	
653020	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Equipment Properly Labeled?	y	
653021	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Adjusted Amps A Phase V	0	
653022	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Adjusted Amps B Phase V	0	
653023	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
653024	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
653025	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
653026	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
653027	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
653028	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
653029	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
653030	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.800	millivolts
653031	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
653032	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
653033	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
653034	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
653035	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
653036	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
653037	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
653038	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
653039	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
653040	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
653041	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	5	
653042	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1236	
653043	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1236	
653044	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
653045	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
653046	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
653047	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
653048	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
653049	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
653050	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
653051	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
653052	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
653053	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	General Comments		
653054	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
653055	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
653056	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
653057	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
653058	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	14	
653059	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	232	
653060	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	232	
653061	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
653062	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	6	
653063	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
653064	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
653065	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
653066	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
653067	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
653068	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
653069	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
653070	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
653071	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	y	
653072	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
653073	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
653074	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
653075	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
653076	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Regulator As Left Counter	4327	
653077	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
653078	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
653079	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Tank Leaks	None	
653080	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
653081	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
653082	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	General Comments	There are no amp meters on GND TR-2, needs to be removed from insp	
653083	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
653084	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
653085	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Operations Counter	64	
653086	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
653087	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
653088	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
653089	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Cabinet Paint Condition	Good	
653090	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Equipment Properly Labeled?	y	
653091	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Adjusted Amps A Phase V	0	
653092	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
653093	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
653094	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
653095	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Totalizer Meter Reading	1.0992	
653096	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
653097	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	44	°F
653098	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
653099	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
653100	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
653101	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
653102	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
653103	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
653104	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
653105	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
653106	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
653107	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
653108	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
653109	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	BAT000561	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
653110	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
653111	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	General Comments		
653112	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
653113	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	General Comments		
653114	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC As Found Counter	22440	
653115	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC As Left Counter	22440	
653116	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
653117	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
653118	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
653119	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
653120	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
653121	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
653122	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
653123	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
653124	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC Current Tap Position	2R	
653125	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
653126	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	117.0	
653127	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Current Tap Position	8L	
653128	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
653129	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	96.0	
653130	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	101.0	
653131	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Moisture and Leak Free?	y	
653132	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Maintenance Operations	0	
653133	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Heaters (All) Functioning?	y	
653134	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Grounds in Place?	y	
653135	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	General Comments	counter was not working adjusted during FTCs	
653136	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
653137	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
653138	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
653139	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
653140	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
653141	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
653142	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
653143	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC Max Tap Position	6R	
653144	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC Min Tap Position	6L	
653145	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
653146	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
653147	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	General Comments		
653148	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
653149	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Max Tap Position	2L	
653150	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Min Tap Position	15L	
653151	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
653152	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
653153	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
653154	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
653155	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
653156	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Regulator As Left Counter	23430	
653157	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
653158	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
653159	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Tank Leaks	None	
653160	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
653161	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
653162	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
653163	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
653164	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
653165	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
653166	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
653167	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
653168	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
653169	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
653170	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
653171	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	9 Month Operations	6	
653172	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
653173	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
653174	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Accumulated Fault Duty A Ph V	3.56	%
653175	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Accumulated Fault Duty B Ph V	3.56	%
653176	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Accumulated Fault Duty C Ph V	3.56	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
653177	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
653178	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Amps A Ø	240	
653179	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Amps B Ø	265	
653180	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Amps C Ø	260	
653181	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Bushing Condition	Good	
653182	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Bushings Connection/Risers	Good	
653183	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
653184	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	18	°C
653185	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC Operations Since Last Insp	352	
653186	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
653187	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
653188	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0411	BreakerOil	Retired Distribution	OCB Readings	General Comments		
653189	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
653190	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	General Comments	Added nitrogen	
653191	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	General Comments		
653192	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
653193	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
653194	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
653195	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Switching Operations	0	
653196	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
653197	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
653198	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
653199	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
653200	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
653201	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	All Connections OK?	y	
653202	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	Follow-up Action Required?	n	
653203	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	General Comments		
653204	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	LTC Operation Checked?	y	
653205	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
653206	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
653207	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
653208	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	VRR Time Delay	30	Seconds
653209	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Tank Leaks	None	
653210	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
653211	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Operations Counter	251	
653212	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
653213	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
653214	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	General Comments		
653215	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
653216	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
653217	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
653218	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
653219	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
653220	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
653221	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
653222	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
653223	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
653224	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Follow-up Action Required?	n	
653225	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
653226	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
653227	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
653228	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Amps C Ø	49.0	
653229	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Amps B Ø	55.0	
653230	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Amps A Ø	41.0	
653231	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	LTCC000298	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
653232	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	LTCC000298	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
653233	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	LTCC000298	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
653234	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	LTCC000298	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
653235	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	LTCC000298	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
653236	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	LTCC000298	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124	VAC
653237	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	LTCC000298	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124	VAC
653238	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	LTCC000298	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
653239	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	All Connections OK?	y	
653240	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	Follow-up Action Required?	n	
653241	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
653242	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
653243	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
653244	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
653245	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
653246	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
653247	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
653248	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	General Comments		
653249	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	LTC Operation Checked?	y	
653250	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
653251	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
653252	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	All Connections OK?	y	
653253	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	Follow-up Action Required?	n	
653254	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	General Comments		
653255	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	LTC Operation Checked?	y	
653256	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
653257	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
653258	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
653259	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
653260	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	VRR Time Delay	30	Seconds
653261	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
653262	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
653263	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
653264	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
653265	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
653266	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	VRR Time Delay	30	Seconds
653267	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	VRR Time Delay	30	Seconds
653268	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
653269	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
653270	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
653271	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
653272	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
653273	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	410392	
653274	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
653275	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
653276	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
653277	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
653278	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
653279	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
653280	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
653281	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
653282	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Totalizer Meter Reading	1.4466	
653283	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Oil Temp Max	45	°C
653284	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
653285	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
653286	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	1R	
653287	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
653288	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
653289	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Maintenance Operations	0	
653290	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
653291	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
653292	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
653293	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
653294	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
653295	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
653296	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
653297	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
653298	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	LTC Totalizer Reading	8100.00	kw
653299	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
653300	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	General Comments	Top fan not working.	
653301	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	General Comments		
653302	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
653303	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
653304	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
653305	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Follow-up Action Required?	n	
653306	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Fans Operational?	n	
653307	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
653308	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
653309	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
653310	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
653311	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
653312	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
653313	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
653314	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
653315	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
653316	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
653317	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
653318	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
653319	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
653320	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
653321	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
653322	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
653323	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	260.00	
653324	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
653325	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Moisture and Leak Free?	y	
653326	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
653327	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
653328	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
653329	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
653330	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
653331	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
653332	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Oil Temp Present	40	°C
653333	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
653334	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
653335	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
653336	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
653337	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
653338	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
653339	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
653340	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
653341	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Oil Temp Max	65	°C
653342	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
653343	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
653344	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Operations Counter AF	152	
653345	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Operations Counter AL	152	
653346	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
653347	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	LTC Totalizer Reading	6943.68	kw
653348	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
653349	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Fault Operations B Ø	0	
653350	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Fault Operations A Ø	0	
653351	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Fault Adjusted Amps C Phase V	0	
653352	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Fault Adjusted Amps B Phase V	0	
653353	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
653354	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	General Comments		
653355	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Fault Adjusted Amps A Phase V	0	
653356	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Equipment Properly Labeled?	y	
653357	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
653358	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Cabinet Paint Condition	Good	
653359	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
653360	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
653361	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
653362	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
653363	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
653364	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
653365	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
653366	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
653367	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
653368	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
653369	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
653370	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
653371	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
653372	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
653373	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
653374	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
653375	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Bushings Connection/Risers	Good	
653376	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Bushing Condition	Good	
653377	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Amps C Ø	0	
653378	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Amps B Ø	0	
653379	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
653380	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
653381	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
653382	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
653383	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Amps A Ø	0	
653384	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Accumulated Fault Duty C Ph V	0	%
653385	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Accumulated Fault Duty B Ph V	0	%
653386	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Accumulated Fault Duty A Ph V	0	%
653387	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	9 Month Operations	1	
653388	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
653389	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
653390	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	Unknown Operations	0	
653391	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Tank Paint Condition	Good	
653392	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	Switching Operations	0	
653393	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	Operations Counter AL	187	
653394	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	Operations Counter AF	187	
653395	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Moisture and Leak Free?	y	
653396	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	Maintenance Operations	0	
653397	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Grounds in Place?	y	
653398	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	General Comments		
653399	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	General Comments		
653400	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Foundation Condition	Good	
653401	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000533	BreakerVacuum	417-2133	VCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
653402	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Follow-up Action Required?	n	
653403	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
653404	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
653405	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
653406	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
653407	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
653408	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	General Comments		
653409	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
653410	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
653411	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
653412	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Operations Ground	0	
653413	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Operations C Ø	0	
653414	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Operations B Ø	0	
653415	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Operations A Ø	0	
653416	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Adjusted Amps C Phase V	0	
653417	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Adjusted Amps B Phase V	0	
653418	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Adjusted Amps A Phase V	0	
653419	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Equipment Properly Labeled?	y	
653420	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Cabinet Paint Condition	Good	
653421	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
653422	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
653423	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
653424	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Bushings Connection/Risers	Good	
653425	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Bushing Condition	Good	
653426	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Amps C Ø	43	
653427	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Amps B Ø	34	
653428	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Unknown Operations	0	
653429	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
653430	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
653431	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	LTC Operation Checked?	y	
653432	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	General Comments		
653433	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	Follow-up Action Required?	n	
653434	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	All Connections OK?	y	
653435	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Unknown Operations	0	
653436	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Tank Paint Condition	Good	
653437	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Tank Oil Level	Good	
653438	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Tank Leaks	None	
653439	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Switching Operations	0	
653440	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Operations Counter AL	2768	
653441	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Operations Counter AF	2768	
653442	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Number of Ops last 9 Months	1	
653443	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Moisture and Leak Free?	y	
653444	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Maintenance Operations	0	
653445	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Grounds in Place?	y	
653446	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	General Comments	There is no fault data recording device on GND TR-1, needs to be removed from insp.	
653447	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	General Comments	There are no amp meters on GND TR-1, needs to be removed from insp	
653448	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Foundation Condition	Good	
653449	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Follow-up Action Required?	y	
653450	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Follow-up Action Required?	y	
653451	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Fault Operations	0	
653452	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Fault Data Recording Device	Good	
653453	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
653454	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Cabinet Paint Condition	Good	
653455	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
653456	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
653457	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
653458	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Bushings Connection/Risers	Good	
653459	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Bushing Condition	Good	
653460	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Amps C Ø	0.0	
653461	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Amps B Ø	0.0	
653462	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Amps A Ø	0.0	
653463	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Tank Paint Condition	Good	
653464	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	All Connections OK?	y	
653465	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	Follow-up Action Required?	n	
653466	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	General Comments		
653467	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	LTC Operation Checked?	y	
653468	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
653469	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
653470	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
653471	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	VRR Time Delay	30	Seconds
653472	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Switching Operations	3	
653473	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Operations Counter AL	20	
653474	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Operations Counter AF	17	
653475	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
653476	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
653477	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Unknown Operations	0	
653478	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Tank Paint Condition	Good	
653479	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Switching Operations	0	
653480	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Operations Counter AL	168	
653481	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	45	
653482	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	40	
653483	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	40	
653484	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
653485	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
653486	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	LTCC000395	LTCControl	587-1	LTC Control Insp	All Connections OK?	y	
653487	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	LTCC000395	LTCControl	587-1	LTC Control Insp	Follow-up Action Required?	n	
653488	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	LTCC000395	LTCControl	587-1	LTC Control Insp	General Comments		
653489	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	LTCC000395	LTCControl	587-1	LTC Control Insp	LTC Operation Checked?	y	
653490	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	LTCC000395	LTCControl	587-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
653491	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	LTCC000395	LTCControl	587-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
653492	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	LTCC000395	LTCControl	587-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
653493	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	LTCC000395	LTCControl	587-1	LTC Control Insp	VRR Time Delay	30	Seconds
653494	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
653495	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
653496	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
653497	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Operations Counter AF	168	
653498	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Moisture and Leak Free?	y	
653499	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Maintenance Operations	0	
653500	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Grounds in Place?	y	
653501	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	General Comments		
653502	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	General Comments		
653503	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Foundation Condition	Good	
653504	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Follow-up Action Required?	n	
653505	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Follow-up Action Required?	n	
653506	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Fault Operations Ground	0	
653507	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BK000534	BreakerVacuum	417-2135	VCB Readings	Fault Operations C Ø	0	
653508	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
653509	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	General Comments		
653510	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	General Comments	counter verified	
653511	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PF000154	PowerFuse	GR-GND TR 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
653512	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PF000154	PowerFuse	GR-GND TR 2	Disconnect Powerfuse Inspection	General Comments	OK	
653513	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PF000155	PowerFuse	GR-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
653514	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PF000155	PowerFuse	GR-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
653515	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PF000157	PowerFuse	GR-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
653516	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
653517	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
653518	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Vegetation	None	
653519	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
653520	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
653521	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	General Comments		
653522	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
653523	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
653524	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
653525	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Regulator As Left Counter	198713	
653526	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
653527	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
653528	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
653529	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
653530	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
653531	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Clear of Trash?	y	
653532	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
653533	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Tank Leaks	None	
653534	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
653535	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Tank Leaks	None	
653536	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
653537	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
653538	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Regulator As Left Counter	201136	
653539	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
653540	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
653541	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
653542	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
653543	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
653544	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
653545	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
653546	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Min Tap Position	15L	
653547	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Max Tap Position	9L	
653548	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
653549	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	General Comments		
653550	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
653551	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
653552	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
653553	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
653554	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
653555	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
653556	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
653557	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	General Comments		
653558	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
653559	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
653560	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
653561	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
653562	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
653563	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
653564	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
653565	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	General Comments		
653566	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Amps A Ø	120.0	
653567	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Amps B Ø	120.0	
653568	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Amps C Ø	120.0	
653569	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Bushing Condition	Good	
653570	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
653571	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
653572	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
653573	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
653574	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
653575	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
653576	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
653577	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Fault Operations	0	
653578	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
653579	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
653580	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	General Comments		
653581	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC As Found Counter	140125	
653582	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC As Left Counter	140125	
653583	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
653584	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC Current Tap Position	4L	
653585	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC Max Tap Position	1L	
653586	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC Min Tap Position	11L	
653587	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	3.0	psi
653588	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC Operations Since Last Insp	206	
653589	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
653590	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
653591	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Follow-up Action Required?	n	
653592	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Foundation Condition	Good	
653593	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
653594	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
653595	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
653596	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
653597	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
653598	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
653599	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
653600	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
653601	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
653602	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
653603	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
653604	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
653605	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
653606	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
653607	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	General Comments		
653608	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
653609	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
653610	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Foundation Condition	Good	
653611	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
653612	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
653613	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
653614	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
653615	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
653616	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
653617	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	General Comments	Heater not working. Need to add a new heater	
653618	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
653619	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
653620	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
653621	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Vegetation	None	
653622	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
653623	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
653624	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	General Comments		
653625	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
653626	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
653627	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
653628	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
653629	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
653630	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
653631	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Clear of Trash?	y	
653632	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
653633	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
653634	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Panels Dusted?	y	
653635	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
653636	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
653637	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
653638	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
653639	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Current Tap Position	12L	
653640	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
653641	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
653642	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
653643	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
653644	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
653645	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PF000157	PowerFuse	GR-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
653646	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PF000159	PowerFuse	GR-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
653647	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PF000159	PowerFuse	GR-GND TR 1	Disconnect Powerfuse Inspection	General Comments	OK	
653648	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	All Connections OK?	y	
653649	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Battery Area Ambient Temp	44	°F
653650	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Battery Overall Condition	Good	
653651	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
653652	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PF000160	PowerFuse	GR-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
653653	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PF000160	PowerFuse	GR-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
653654	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PF000161	PowerFuse	GR-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
653655	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PF000161	PowerFuse	GR-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
653656	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
653657	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
653658	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
653659	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
653660	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Follow-up Action Required?	n	
653661	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	General Comments		
653662	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Negative DC Ground	0	VDC
653663	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Positive DC Ground	0	VDC
653664	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
653665	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
653666	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Unknown Operations	0	
653667	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
653668	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
653669	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Broom on Site?	n	
653670	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
653671	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
653672	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
653673	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
653674	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Evidence of Insects	None	
653675	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	n	
653676	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
653677	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Floor Swept?	n	
653678	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
653679	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	44	°F
653680	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
653681	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
653682	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
653683	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
653684	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
653685	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
653686	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
653687	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
653688	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	General Comments		
653689	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
653690	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
653691	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
653692	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
653693	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Floor Swept?	y	
653694	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
653695	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
653696	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Evidence of Insects	None	
653697	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LTCC000425	LTCControl	GR-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
653698	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LTCC000425	LTCControl	GR-TRANS 1	LTC Control Insp	General Comments		
653699	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LTCC000425	LTCControl	GR-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
653700	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LTCC000425	LTCControl	GR-TRANS 1	LTC Control Insp	All Connections OK?	y	
653701	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
653702	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
653703	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
653704	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
653705	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
653706	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
653707	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC Operations Since Last Insp	341	
653708	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC Min Tap Position	9L	
653709	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC Max Tap Position	1R	
653710	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC Current Tap Position	3L	
653711	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
653712	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC As Left Counter	65964	
653713	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC As Found Counter	65964	
653714	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	General Comments		
653715	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	General Comments		
653716	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
653717	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	Follow-up Action Required?	n	
653718	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
653719	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
653720	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Maintenance Operations	0	
653721	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
653722	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Operations Counter AF	43	
653723	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
653724	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
653725	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
653726	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC Max Tap Position	16R	
653727	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC Min Tap Position	16L	
653728	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC Operations Since Last Insp	874	
653729	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
653730	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
653731	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Operations Counter AF	153	
653732	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Operations Counter AL	154	
653733	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
653734	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Switching Operations	1	
653735	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Tank Paint Condition	Good	
653736	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Unknown Operations	0	
653737	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Operations Counter AL	43	
653738	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
653739	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
653740	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
653741	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Switching Operations	0	
653742	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Tank Paint Condition	Good	
653743	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Unknown Operations	0	
653744	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
653745	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
653746	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
653747	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
653748	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
653749	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
653750	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
653751	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
653752	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
653753	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
653754	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
653755	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
653756	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
653757	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
653758	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Panels Dusted?	y	
653759	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
653760	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	General Comments		
653761	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
653762	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
653763	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
653764	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
653765	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
653766	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
653767	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Broom on Site?	y	
653768	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
653769	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
653770	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
653771	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
653772	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
653773	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
653774	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
653775	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
653776	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
653777	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
653778	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
653779	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
653780	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
653781	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
653782	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
653783	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
653784	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
653785	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	General Comments		
653786	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
653787	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
653788	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Foundation Condition	Good	
653789	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
653790	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
653791	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
653792	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
653793	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
653794	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
653795	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	Follow-up Action Required?	n	
653796	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BCH000389	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
653797	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BCH000389	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.7	VDC
653798	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BCH000389	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.7	VDC
653799	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BCH000389	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
653800	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
653801	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
653802	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
653803	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BCH000389	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
653804	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BCH000389	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
653805	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
653806	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC Operations Since Last Insp	487	
653807	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
653808	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC Min Tap Position	9L	
653809	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC Max Tap Position	4R	
653810	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
653811	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
653812	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Readings	Totalizer Meter Reading	.801	
653813	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
653814	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
653815	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
653816	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
653817	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
653818	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC Current Tap Position	1L	
653819	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
653820	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC As Left Counter	17480	
653821	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC As Found Counter	17480	
653822	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	General Comments		
653823	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	General Comments		
653824	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
653825	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	Follow-up Action Required?	n	
653826	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
653827	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
653828	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
653829	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Readings	Oil Temp Present	35	°C
653830	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Readings	Oil Temp Max	60	°C
653831	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
653832	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
653833	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Readings	LTC Totalizer Reading	3844.8	kw
653834	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
653835	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Readings	General Comments		
653836	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	General Comments		
653837	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
653838	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
653839	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Readings	Follow-up Action Required?	n	
653840	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
653841	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
653842	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
653843	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
653844	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
653845	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
653846	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
653847	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
653848	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
653849	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
653850	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	General Comments		
653851	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
653852	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Unknown Operations	0	
653853	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Tank Paint Condition	Good	
653854	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Switching Operations	4	
653855	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Operations C Ø	0	
653856	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Operations B Ø	0	
653857	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Operations A Ø	0	
653858	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Adjusted Amps C Phase V	0	
653859	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Adjusted Amps B Phase V	0	
653860	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Adjusted Amps A Phase V	0	
653861	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Equipment Properly Labeled?	y	
653862	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Cabinet Paint Condition	Good	
653863	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
653864	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
653865	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
653866	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
653867	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
653868	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	92	
653869	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
653870	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
653871	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Operations Counter AL	35	
653872	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Operations Counter AF	31	
653873	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Moisture and Leak Free?	y	
653874	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Maintenance Operations	0	
653875	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Grounds in Place?	y	
653876	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	General Comments	BFTC	
653877	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
653878	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
653879	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
653880	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
653881	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
653882	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
653883	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
653884	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
653885	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
653886	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
653887	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
653888	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
653889	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
653890	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
653891	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Operations Counter	27	
653892	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
653893	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Tank Leaks	None	
653894	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
653895	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Unknown Operations	0	
653896	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Tank Paint Condition	Good	
653897	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
653898	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
653899	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
653900	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
653901	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
653902	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
653903	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
653904	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
653905	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
653906	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
653907	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
653908	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Switching Operations	0	
653909	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
653910	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Operations Counter AL	141	
653911	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Operations Counter AF	141	
653912	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Moisture and Leak Free?	y	
653913	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Maintenance Operations	0	
653914	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Heaters (All) Functioning?	y	
653915	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Grounds in Place?	y	
653916	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
653917	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
653918	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
653919	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	General Comments		
653920	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	General Comments		
653921	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Grounds in Place?	y	
653922	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
653923	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Maintenance Operations	0	
653924	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
653925	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Number of Ops last 9 Months	9	
653926	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Operations Counter AF	2118	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
653927	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Operations Counter AL	2122	
653928	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	General Comments		
653929	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Foundation Condition	Good	
653930	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Follow-up Action Required?	n	
653931	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Follow-up Action Required?	n	
653932	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Operations Ground	0	
653933	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
653934	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
653935	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Equipment Properly Labeled?	y	
653936	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Cabinet Paint Condition	Good	
653937	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
653938	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
653939	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	20.0	
653940	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	20.0	
653941	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	20.0	
653942	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
653943	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
653944	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
653945	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
653946	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
653947	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
653948	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
653949	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
653950	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
653951	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
653952	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	General Comments	We do not load test the batteries on GR-1124	
653953	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
653954	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
653955	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Operations Counter	1689	
653956	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
653957	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
653958	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
653959	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
653960	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
653961	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
653962	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
653963	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
653964	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
653965	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
653966	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
653967	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
653968	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
653969	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	Oil Temp Present	25	°C
653970	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
653971	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
653972	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
653973	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	LV Winding Temp Present	25	°C
653974	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
653975	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
653976	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	General Comments		
653977	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
653978	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	General Comments		
653979	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
653980	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
653981	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	310	
653982	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	General Comments		
653983	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
653984	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
653985	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
653986	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
653987	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1961.60	kw
653988	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	82.50	
653989	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
653990	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
653991	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
653992	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
653993	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
653994	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
653995	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
653996	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
653997	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
653998	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Tank Paint Condition	Adequate	
653999	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Tank Leaks	None	
654000	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
654001	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Regulator As Left Counter	349195	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
654002	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
654003	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
654004	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
654005	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
654006	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
654007	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
654008	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
654009	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6130	
654010	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Foundation Condition	Good	
654011	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Follow-up Action Required?	n	
654012	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Follow-up Action Required?	n	
654013	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Operations Ground	0	
654014	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Operations C Ø	0	
654015	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Operations B Ø	0	
654016	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Operations A Ø	0	
654017	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
654018	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC Current Tap Position	6L	
654019	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC Max Tap Position	12L	
654020	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC Min Tap Position	1L	
654021	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC Operations Since Last Insp	158	
654022	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
654023	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
654024	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
654025	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
654026	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
654027	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
654028	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Bushings Connection/Risers	Good	
654029	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Bushing Condition	Good	
654030	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Amps C Ø	10	
654031	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Amps B Ø	10	
654032	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Amps A Ø	10	
654033	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Accumulated Fault Duty C Ph V	0	%
654034	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Accumulated Fault Duty B Ph V	0	%
654035	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Accumulated Fault Duty A Ph V	0	%
654036	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	9 Month Operations	6	
654037	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
654038	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Tank Leaks	None	
654039	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
654040	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
654041	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Regulator As Left Counter	25611	
654042	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
654043	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
654044	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
654045	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
654046	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
654047	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Min Tap Position	15L	
654048	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Max Tap Position	1L	
654049	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
654050	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	General Comments		
654051	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
654052	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
654053	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
654054	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
654055	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Current Tap Position	7L	
654056	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
654057	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	General Comments		
654058	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
654059	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
654060	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
654061	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
654062	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Trash Emptied?	n	
654063	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
654064	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
654065	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Tank Paint Condition	Good	
654066	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Switching Operations	0	
654067	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
654068	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Operations Counter AL	325	
654069	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Operations Counter AF	325	
654070	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Moisture and Leak Free?	y	
654071	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Maintenance Operations	0	
654072	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Heaters (All) Functioning?	y	
654073	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
654074	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
654075	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
654076	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
654077	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
654078	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
654079	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	General Comments		
654080	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
654081	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Grounds in Place?	y	
654082	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	General Comments		
654083	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	General Comments		
654084	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Foundation Condition	Good	
654085	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Follow-up Action Required?	n	
654086	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Follow-up Action Required?	n	
654087	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Operations Ground	0	
654088	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Operations C Ø	0	
654089	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Operations B Ø	0	
654090	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Operations A Ø	0	
654091	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Adjusted Amps C Phase V	0	
654092	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Adjusted Amps B Phase V	0	
654093	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Adjusted Amps A Phase V	0	
654094	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Equipment Properly Labeled?	y	
654095	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Cabinet Paint Condition	Good	
654096	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Counter Readings	Follow-up Action Required?	n	
654097	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
654098	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Counter Readings	General Comments		
654099	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	General Comments		
654100	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC As Found Counter	200792	
654101	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC As Left Counter	200795	
654102	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
654103	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
654104	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Min Tap Position	15L	
654105	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Max Tap Position	8L	
654106	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
654107	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	General Comments		
654108	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
654109	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
654110	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
654111	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
654112	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Current Tap Position	10L	
654113	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
654114	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
654115	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
654116	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
654117	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
654118	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
654119	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
654120	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
654121	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
654122	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
654123	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
654124	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Amps A Ø	41	
654125	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Amps B Ø	36	
654126	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Amps C Ø	36	
654127	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
654128	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
654129	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
654130	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
654131	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
654132	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
654133	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
654134	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
654135	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
654136	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
654137	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
654138	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
654139	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
654140	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
654141	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
654142	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
654143	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	General Comments		
654144	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
654145	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
654146	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
654147	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
654148	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
654149	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
654150	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
654151	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
654152	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
654153	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
654154	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
654155	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
654156	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
654157	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
654158	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
654159	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
654160	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	General Comments		
654161	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
654162	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
654163	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
654164	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
654165	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
654166	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
654167	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
654168	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
654169	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
654170	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
654171	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
654172	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
654173	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
654174	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
654175	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
654176	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
654177	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	43	°F
654178	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
654179	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
654180	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Tank Leaks	None	
654181	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
654182	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
654183	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Regulator As Left Counter	19826	
654184	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
654185	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
654186	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
654187	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
654188	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
654189	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
654190	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
654191	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
654192	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Top Oil Temperature Max	38	°C
654193	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Totalizer Meter Multiplier	1000	
654194	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Totalizer Meter Reading	24.4000	
654195	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Winding Temp Max	40	°C
654196	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
654197	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
654198	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X1 Winding Temp Max	40	°C
654199	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X1 Winding Temp Present	24	°C
654200	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X2 Winding Temp Max	40	°C
654201	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	2238.60	kw
654202	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
654203	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
654204	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X2 Winding Temp Present	24	°C
654205	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X3 Winding Temp Max	40	°C
654206	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X3 Winding Temp Present	24	°C
654207	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
654208	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
654209	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
654210	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
654211	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
654212	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
654213	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
654214	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	6000	
654215	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Totalizer Meter Reading	.3731	
654216	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
654217	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
654218	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
654219	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
654220	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
654221	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
654222	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
654223	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Winding Temp Max	30	°C
654224	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Winding Temp Present	20	°C
654225	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
654226	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
654227	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
654228	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
654229	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
654230	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
654231	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
654232	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
654233	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
654234	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
654235	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
654236	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
654237	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
654238	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
654239	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
654240	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
654241	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
654242	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
654243	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
654244	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
654245	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
654246	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
654247	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
654248	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	General Comments		
654249	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
654250	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	General Comments		
654251	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
654252	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
654253	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
654254	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	General Comments		
654255	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
654256	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
654257	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
654258	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
654259	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
654260	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
654261	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
654262	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
654263	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Kwh Reading	10210	KwH
654264	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	LTC Totalizer Reading	24400.00	kw
654265	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	MegaVar Demand Meter Max	36988.00	MegaVars
654266	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
654267	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
654268	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	BCH000202	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
654269	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	BCH000202	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
654270	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	BCH000202	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
654271	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
654272	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
654273	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	General Comments	There is no LTC MAX / MIN, can be removed from INSP. Only current tap position	
654274	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	LTC As Found Counter	99304	
654275	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	LTC As Left Counter	99304	
654276	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
654277	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4R	
654278	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
654279	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	LTC Min Tap Position	4R	
654280	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	530	
654281	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
654282	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
654283	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
654284	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
654285	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
654286	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
654287	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Foundation Condition	Good	
654288	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
654289	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
654290	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	General Comments		
654291	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
654292	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
654293	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
654294	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
654295	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
654296	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
654297	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
654298	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
654299	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
654300	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
654301	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
654302	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
654303	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
654304	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
654305	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
654306	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
654307	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
654308	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
654309	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
654310	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
654311	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
654312	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
654313	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	675	
654314	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	675	
654315	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
654316	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
654317	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
654318	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
654319	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	44	°F
654320	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
654321	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
654322	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
654323	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
654324	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
654325	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
654326	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
654327	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
654328	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
654329	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
654330	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
654331	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
654332	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
654333	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
654334	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
654335	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
654336	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
654337	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
654338	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
654339	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
654340	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Readings	General Comments	Normally open	
654341	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
654342	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
654343	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
654344	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
654345	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	682	
654346	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	682	
654347	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
654348	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
654349	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
654350	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
654351	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
654352	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
654353	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
654354	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0416	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
654355	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	Follow-up Action Required?	y	
654356	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
654357	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	Need to add a line for desiccant to the insp. There are 2 screw on type that need to be changed.	
654358	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
654359	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
654360	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
654361	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
654362	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
654363	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
654364	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
654365	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
654366	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
654367	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
654368	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
654369	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
654370	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
654371	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
654372	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
654373	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
654374	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
654375	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
654376	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
654377	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
654378	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
654379	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
654380	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
654381	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
654382	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
654383	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
654384	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
654385	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
654386	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
654387	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
654388	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
654389	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Vegetation	None	
654390	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
654391	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
654392	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	General Comments		
654393	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
654394	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
654395	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
654396	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
654397	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
654398	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	42	°F
654399	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
654400	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
654401	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
654402	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
654403	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
654404	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
654405	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
654406	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
654407	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
654408	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
654409	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
654410	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
654411	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
654412	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
654413	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
654414	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
654415	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
654416	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	General Comments		
654417	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
654418	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
654419	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LTCC000603	LTCControl	GR-CLASS-B TRANS 1	LTC Control Insp	All Connections OK?	y	
654420	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LTCC000603	LTCControl	GR-CLASS-B TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
654421	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LTCC000603	LTCControl	GR-CLASS-B TRANS 1	LTC Control Insp	General Comments		
654422	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Foundation Condition	Good	
654423	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
654424	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
654425	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
654426	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
654427	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
654428	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
654429	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
654430	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
654431	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
654432	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
654433	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
654434	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
654435	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
654436	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
654437	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
654438	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
654439	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
654440	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
654441	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
654442	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
654443	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
654444	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
654445	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
654446	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
654447	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
654448	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Clear of Trash?	y	
654449	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
654450	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
654451	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
654452	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
654453	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
654454	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
654455	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
654456	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
654457	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
654458	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	General Comments		
654459	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
654460	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
654461	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Vegetation	None	
654462	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
654463	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
654464	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
654465	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
654466	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
654467	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0	VDC
654468	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
654469	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Top Oil Temperature Max	55	°C
654470	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
654471	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
654472	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
654473	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
654474	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
654475	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Follow-up Action Required?	n	
654476	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
654477	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
654478	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	General Comments		
654479	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Top Oil Temperature Present	30	°C
654480	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
654481	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5526	
654482	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
654483	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0	VDC
654484	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
654485	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
654486	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
654487	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
654488	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
654489	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
654490	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Clear of Trash?	y	
654491	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
654492	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
654493	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
654494	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
654495	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
654496	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
654497	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
654498	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
654499	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
654500	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
654501	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
654502	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
654503	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
654504	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
654505	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
654506	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
654507	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
654508	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
654509	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
654510	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	General Comments		
654511	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
654512	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
654513	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
654514	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
654515	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
654516	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	General Comments		
654517	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	General Comments		
654518	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
654519	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
654520	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
654521	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
654522	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5304.96	kw
654523	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50	
654524	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45	
654525	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
654526	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
654527	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
654528	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	9 Month Operations	0	
654529	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Accumulated Fault Duty A Ph V	1.1	%
654530	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	9 Month Operations	2	
654531	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
654532	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
654533	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
654534	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Accumulated Fault Duty A Ph V	.34	%
654535	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
654536	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
654537	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
654538	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
654539	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
654540	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
654541	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
654542	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
654543	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
654544	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	General Comments		
654545	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
654546	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Foundation Condition	Good	
654547	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
654548	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
654549	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
654550	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
654551	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
654552	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
654553	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Accumulated Fault Duty B Ph V	.34	%
654554	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Accumulated Fault Duty C Ph V	.34	%
654555	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Accumulated Fault Duty B Ph V	1.1	%
654556	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
654557	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Amps A Ø	50	
654558	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Amps B Ø	50	
654559	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Amps C Ø	50	
654560	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Bushing Condition	Good	
654561	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
654562	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
654563	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
654564	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Vegetation	None	
654565	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
654566	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
654567	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
654568	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	General Comments		
654569	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
654570	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Capacitor Condition	Good	
654571	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
654572	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Bushing Condition	Good	
654573	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	All Connections OK?	y	
654574	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
654575	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
654576	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
654577	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
654578	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
654579	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
654580	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
654581	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
654582	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
654583	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
654584	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
654585	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
654586	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
654587	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	General Comments		
654588	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
654589	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
654590	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	960.12	kw
654591	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
654592	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
654593	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
654594	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	General Comments		
654595	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	General Comments		
654596	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
654597	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
654598	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
654599	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
654600	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
654601	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
654602	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
654603	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
654604	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
654605	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
654606	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
654607	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
654608	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
654609	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	14	VDC
654610	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	14	VDC
654611	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
654612	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
654613	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	General Comments		
654614	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	General Comments		
654615	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Grounds in Place?	y	
654616	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Heaters (All) Functioning?	y	
654617	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Maintenance Operations	0	
654618	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Moisture and Leak Free?	y	
654619	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
654620	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	General Comments	barb wire is rusty, and top rail is getting rusty	
654621	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
654622	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
654623	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
654624	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
654625	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
654626	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
654627	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
654628	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
654629	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
654630	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
654631	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	Follow-up Action Required?	n	
654632	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
654633	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	General Comments		
654634	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	General Comments		
654635	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC As Found Counter	49085	
654636	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC As Left Counter	49096	
654637	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
654638	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
654639	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
654640	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
654641	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
654642	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
654643	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
654644	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Operations A Ø	0	
654645	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Operations B Ø	0	
654646	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Operations C Ø	0	
654647	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Operations Ground	0	
654648	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Follow-up Action Required?	n	
654649	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Follow-up Action Required?	n	
654650	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Foundation Condition	Good	
654651	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	General Comments		
654652	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	General Comments		
654653	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Grounds in Place?	y	
654654	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
654655	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
654656	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
654657	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
654658	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
654659	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
654660	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Clear of Trash?	y	
654661	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
654662	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
654663	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Amps A Ø	0.0	
654664	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Amps B Ø	0.0	
654665	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Amps C Ø	0.0	
654666	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Bushing Condition	Good	
654667	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Bushings Connection/Risers	Good	
654668	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
654669	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
654670	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
654671	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Cabinet Paint Condition	Good	
654672	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Equipment Properly Labeled?	y	
654673	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
654674	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
654675	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
654676	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
654677	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
654678	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	General Comments		
654679	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
654680	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
654681	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
654682	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
654683	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
654684	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
654685	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
654686	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
654687	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
654688	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
654689	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
654690	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
654691	1/7/2019 7:41	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
654692	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Operations B Ø	0	
654693	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Operations C Ø	0	
654694	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Operations Ground	0	
654695	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Follow-up Action Required?	n	
654696	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Follow-up Action Required?	n	
654697	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Foundation Condition	Good	
654698	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
654699	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Cabinet Paint Condition	Good	
654700	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Equipment Properly Labeled?	y	
654701	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
654702	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
654703	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
654704	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Operations A Ø	0	
654705	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Operations B Ø	0	
654706	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Operations C Ø	0	
654707	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Operations Ground	0	
654708	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Follow-up Action Required?	n	
654709	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Follow-up Action Required?	n	
654710	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Foundation Condition	Good	
654711	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	General Comments		
654712	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	General Comments		
654713	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Grounds in Place?	y	
654714	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Maintenance Operations	0	
654715	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Moisture and Leak Free?	y	
654716	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Operations Counter AF	180	
654717	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Operations Counter AL	181	
654718	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Switching Operations	1	
654719	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Tank Paint Condition	Good	
654720	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Unknown Operations	0	
654721	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
654722	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
654723	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
654724	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
654725	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
654726	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
654727	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
654728	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Readings	General Comments		
654729	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
654730	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
654731	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
654732	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
654733	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
654734	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
654735	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
654736	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
654737	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
654738	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	9 Month Operations	48	
654739	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
654740	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	3	
654741	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
654742	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
654743	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
654744	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	General Comments		
654745	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
654746	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Amps A Ø	93.0	
654747	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Amps B Ø	96.0	
654748	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Amps C Ø	83.0	
654749	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
654750	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
654751	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
654752	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
654753	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
654754	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
654755	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
654756	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
654757	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
654758	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
654759	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
654760	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
654761	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
654762	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	General Comments		
654763	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
654764	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
654765	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Operations Counter	128	
654766	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
654767	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Tank Leaks	None	
654768	1/4/2019 9:11	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
654769	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	9 Month Operations	49	
654770	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
654771	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
654772	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
654773	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Amps A Ø	30.0	
654774	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Amps B Ø	35.0	
654775	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Amps C Ø	28.0	
654776	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
654777	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
654778	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
654779	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Bushing Condition	Good	
654780	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Bushings Connection/Risers	Good	
654781	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
654782	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
654783	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	Follow-up Action Required?	n	
654784	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	General Comments		
654785	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	LTC Operation Checked?	y	
654786	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
654787	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
654788	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
654789	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	VRR Time Delay	60	Seconds
654790	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
654791	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
654792	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	BCH001167	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
654793	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	BCH001167	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
654794	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	BCH001167	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
654795	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	BCH001167	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
654796	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	BCH001167	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
654797	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	BCH001167	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
654798	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	BCH001167	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.200	millivolts
654799	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	VRR Time Delay	30	Seconds
654800	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	VRR Base Voltage AL	124	VAC
654801	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	VRR Base Voltage AF	124	VAC
654802	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
654803	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	LTC Operation Checked?	y	
654804	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	General Comments		
654805	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	Follow-up Action Required?	n	
654806	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
654807	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Tank Leaks	None	
654808	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
654809	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Grounds in Place?	y	
654810	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	General Comments		
654811	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	All Connections OK?	y	
654812	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5334	
654813	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
654814	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
654815	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
654816	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
654817	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
654818	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
654819	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
654820	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Oil Temp Present	33	°C
654821	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Oil Temp Max	37	°C
654822	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
654823	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Follow-up Action Required?	n	
654824	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
654825	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
654826	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
654827	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
654828	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Amps A Ø	4.0	
654829	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Amps B Ø	7.0	
654830	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Amps C Ø	1.0	
654831	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Bushing Condition	Good	
654832	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Bushings Connection/Risers	Good	
654833	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
654834	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
654835	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
654836	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Cabinet Paint Condition	Good	
654837	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Equipment Properly Labeled?	y	
654838	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
654839	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
654840	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
654841	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Operations A Ø	0	
654842	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Operations B Ø	0	
654843	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Operations C Ø	0	
654844	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Operations Ground	0	
654845	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Follow-up Action Required?	n	
654846	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Follow-up Action Required?	n	
654847	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Foundation Condition	Good	
654848	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	General Comments		
654849	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	General Comments		
654850	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Grounds in Place?	y	
654851	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Maintenance Operations	0	
654852	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Moisture and Leak Free?	y	
654853	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Operations Counter AF	176	
654854	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Operations Counter AL	177	
654855	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Switching Operations	1	
654856	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Tank Paint Condition	Good	
654857	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Unknown Operations	0	
654858	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
654859	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
654860	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
654861	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
654862	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
654863	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	458.0	
654864	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	449.0	
654865	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	465.0	
654866	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
654867	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0417	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
654868	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	All Connections OK?	y	
654869	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Operations Ground	0	
654870	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
654871	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
654872	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Operations C Ø	0	
654873	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Operations B Ø	0	
654874	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Operations A Ø	0	
654875	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
654876	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	1	
654877	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
654878	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1614	
654879	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1614	
654880	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
654881	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
654882	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
654883	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
654884	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
654885	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
654886	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
654887	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
654888	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
654889	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
654890	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
654891	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
654892	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
654893	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
654894	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
654895	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	General Comments		
654896	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
654897	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
654898	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
654899	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
654900	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
654901	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
654902	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
654903	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
654904	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
654905	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Equipment Properly Labeled?	y	
654906	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Cabinet Paint Condition	Good	
654907	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
654908	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
654909	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
654910	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
654911	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
654912	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
654913	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Switching Operations	2	
654914	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Tank Paint Condition	Good	
654915	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Unknown Operations	0	
654916	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
654917	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
654918	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
654919	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Unknown Operations	0	
654920	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Totalizer Meter Reading	.6070	
654921	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Unknown Operations	0	
654922	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Tank Paint Condition	Good	
654923	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Switching Operations	5	
654924	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
654925	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
654926	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
654927	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
654928	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Operations Counter AL	192	
654929	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Operations Counter AF	187	
654930	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Moisture and Leak Free?	y	
654931	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
654932	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
654933	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
654934	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
654935	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
654936	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
654937	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
654938	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
654939	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
654940	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
654941	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	General Comments		
654942	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
654943	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
654944	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Maintenance Operations	0	
654945	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Heaters (All) Functioning?	y	
654946	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Grounds in Place?	y	
654947	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	General Comments		
654948	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	General Comments		
654949	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Foundation Condition	Good	
654950	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Follow-up Action Required?	n	
654951	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Follow-up Action Required?	n	
654952	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	LTC Totalizer Reading	5827.20	kw
654953	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
654954	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
654955	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
654956	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
654957	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
654958	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
654959	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
654960	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
654961	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
654962	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
654963	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
654964	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Battery Bank Volts	24.0	VDC
654965	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Battery Bank Amps	0.0	AMPS
654966	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
654967	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
654968	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
654969	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Vegetation	None	
654970	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
654971	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
654972	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	General Comments		
654973	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
654974	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
654975	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
654976	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
654977	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Ambient Temp	47	°F
654978	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
654979	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
654980	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Clear of Trash?	y	
654981	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
654982	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
654983	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
654984	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
654985	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
654986	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Clear of Trash?	y	
654987	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
654988	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
654989	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
654990	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	General Comments		
654991	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Exp Boom Corrected	
654992	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Vegetation	None	
654993	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
654994	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Bushings Connection/Risers	Good	
654995	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Bushing Condition	Good	
654996	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Amps C Ø	120.0	
654997	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	679	
654998	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Amps B Ø	120.0	
654999	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Amps A Ø	120.0	
655000	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Accumulated Fault Duty C Ph V	.68	%
655001	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Accumulated Fault Duty B Ph V	.34	%
655002	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Accumulated Fault Duty A Ph V	.34	%
655003	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	9 Month Operations	11	
655004	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
655005	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
655006	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Top Oil Temperature Present	29	°C
655007	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Top Oil Temperature Max	30	°C
655008	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
655009	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
655010	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
655011	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
655012	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
655013	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
655014	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
655015	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
655016	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
655017	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
655018	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
655019	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
655020	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
655021	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
655022	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
655023	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
655024	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	General Comments		
655025	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
655026	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
655027	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
655028	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
655029	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
655030	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
655031	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
655032	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
655033	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
655034	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
655035	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
655036	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	BCH000395	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
655037	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	BCH000395	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
655038	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
655039	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Tank Leaks	None	
655040	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
655041	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Regulator As Left Counter	23309	
655042	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
655043	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
655044	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
655045	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
655046	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
655047	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
655048	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
655049	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
655050	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	General Comments		
655051	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
655052	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
655053	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
655054	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
655055	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
655056	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
655057	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
655058	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
655059	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
655060	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
655061	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Amps A Ø	0.0	
655062	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Amps B Ø	0.0	
655063	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Amps C Ø	0.0	
655064	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Bushing Condition	Good	
655065	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Bushings Connection/Risers	Good	
655066	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
655067	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
655068	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
655069	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Cabinet Paint Condition	Good	
655070	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Equipment Properly Labeled?	y	
655071	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
655072	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
655073	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
655074	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20	
655075	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Winding Temp Present	30	°C
655076	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Winding Temp Max	30	°C
655077	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
655078	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
655079	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
655080	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
655081	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Operations C Ø	0	
655082	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Operations Ground	0	
655083	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Follow-up Action Required?	n	
655084	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Follow-up Action Required?	n	
655085	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Foundation Condition	Good	
655086	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	General Comments		
655087	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	General Comments		
655088	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Grounds in Place?	y	
655089	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Maintenance Operations	0	
655090	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Moisture and Leak Free?	y	
655091	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Operations Counter AF	139	
655092	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Operations Counter AL	140	
655093	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Switching Operations	1	
655094	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PF000156	PowerFuse	GR-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
655095	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PF000156	PowerFuse	GR-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
655096	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
655097	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
655098	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
655099	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	BCH000395	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
655100	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	BCH000395	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
655101	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
655102	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Tank Paint Condition	Good	
655103	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	Follow-up Action Required?	y	
655104	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
655105	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	General Comments	Found taps in manual, placed in auto. The veeder counter is very hard to read, needs to be replaced	
655106	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	TR-2 needs a screw on type desiccant that needs to be replaced	
655107	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC As Found Counter	22957	
655108	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC As Left Counter	22957	
655109	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
655110	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9R	
655111	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC Max Tap Position	9R	
655112	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9R	
655113	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
655114	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	0	
655115	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
655116	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
655117	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
655118	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
655119	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	General Comments		
655120	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
655121	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
655122	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
655123	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
655124	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
655125	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Grounds in Place?	y	
655126	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Heaters (All) Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
655127	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Maintenance Operations	0	
655128	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Moisture and Leak Free?	y	
655129	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Operations Counter AF	208	
655130	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Operations Counter AL	210	
655131	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
655132	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
655133	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
655134	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
655135	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	154.0	
655136	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	162.0	
655137	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	154.0	
655138	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
655139	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
655140	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
655141	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
655142	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
655143	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
655144	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
655145	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
655146	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
655147	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
655148	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
655149	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
655150	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
655151	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
655152	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
655153	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
655154	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
655155	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
655156	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
655157	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Readings	General Comments		
655158	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
655159	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0414	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
655160	1/4/2019 14:47	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
655161	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Totalizer Meter Reading	.1938	
655162	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
655163	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
655164	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
655165	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
655166	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
655167	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
655168	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
655169	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
655170	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Oil Temp Present	28	°C
655171	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Oil Temp Max	30	°C
655172	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
655173	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
655174	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	LTC Totalizer Reading	3488.4	kw
655175	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
655176	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	General Comments		
655177	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	General Comments		
655178	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
655179	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
655180	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Follow-up Action Required?	n	
655181	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
655182	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
655183	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
655184	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
655185	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
655186	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
655187	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
655188	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
655189	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
655190	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
655191	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Operations A Ø	0	
655192	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Operations B Ø	0	
655193	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
655194	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
655195	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
655196	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
655197	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Operations C Ø	0	
655198	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Operations Ground	0	
655199	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Follow-up Action Required?	n	
655200	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Follow-up Action Required?	n	
655201	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
655202	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	General Comments		
655203	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	General Comments		
655204	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Follow-up Action Required?	n	
655205	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Operations Ground	0	
655206	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Operations C Ø	0	
655207	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Operations B Ø	0	
655208	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Operations A Ø	0	
655209	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Adjusted Amps C Phase V	0	
655210	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Adjusted Amps B Phase V	0	
655211	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Adjusted Amps A Phase V	0	
655212	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Equipment Properly Labeled?	y	
655213	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Cabinet Paint Condition	Good	
655214	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
655215	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
655216	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
655217	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Bushings Connection/Risers	Good	
655218	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Bushing Condition	Good	
655219	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Amps C Ø	10	
655220	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Amps B Ø	10	
655221	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Amps A Ø	10	
655222	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Accumulated Fault Duty C Ph V	.48	%
655223	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Accumulated Fault Duty B Ph V	1.9	%
655224	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Accumulated Fault Duty A Ph V	6.18	%
655225	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	9 Month Operations	9	
655226	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
655227	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
655228	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
655229	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
655230	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
655231	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
655232	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
655233	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
655234	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
655235	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
655236	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
655237	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
655238	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
655239	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	114.0	
655240	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	117.0	
655241	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	113.0	
655242	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
655243	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
655244	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Heaters (All) Functioning?	y	
655245	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Grounds in Place?	y	
655246	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	General Comments		
655247	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
655248	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
655249	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
655250	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
655251	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
655252	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
655253	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Clear of Trash?	y	
655254	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
655255	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
655256	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
655257	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
655258	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
655259	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
655260	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	General Comments		
655261	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
655262	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Regulator As Left Counter	71458	
655263	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
655264	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
655265	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Tank Leaks	None	
655266	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
655267	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
655268	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Vegetation	None	
655269	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
655270	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
655271	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
655272	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
655273	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
655274	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
655275	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
655276	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
655277	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
655278	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
655279	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
655280	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	General Comments		
655281	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Foundation Condition	Good	
655282	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Follow-up Action Required?	n	
655283	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
655284	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
655285	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
655286	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	5.26	%
655287	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.25	%
655288	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.25	%
655289	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
655290	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	9 Month Operations	0	
655291	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
655292	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
655293	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
655294	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Amps A Ø	800.0	
655295	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Amps B Ø	840.0	
655296	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Amps C Ø	840.0	
655297	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Bushing Condition	Good	
655298	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Bushings Connection/Risers	Good	
655299	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
655300	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
655301	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
655302	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Cabinet Paint Condition	Good	
655303	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Equipment Properly Labeled?	y	
655304	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
655305	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
655306	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
655307	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Operations A Ø	0	
655308	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Operations B Ø	0	
655309	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Operations C Ø	0	
655310	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Operations Ground	0	
655311	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Follow-up Action Required?	n	
655312	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Follow-up Action Required?	n	
655313	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Foundation Condition	Good	
655314	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	General Comments		
655315	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	General Comments	coal dust in cabinet	
655316	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Grounds in Place?	y	
655317	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Maintenance Operations	0	
655318	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Moisture and Leak Free?	y	
655319	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Operations Counter AF	150	
655320	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Operations Counter AL	150	
655321	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
655322	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Switching Operations	0	
655323	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Tank Paint Condition	Good	
655324	1/31/2019 14:41	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Unknown Operations	0	
655325	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
655326	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Tank Leaks	None	
655327	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
655328	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
655329	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
655330	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
655331	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
655332	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
655333	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	Foundation Condition	Good	
655334	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
655335	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
655336	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
655337	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
655338	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
655339	1/4/2019 15:11	Distribution	Harrodsburg Industrial Quarterly Inspectior	ST000456	Structure	417-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
655340	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
655341	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
655342	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
655343	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
655344	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
655345	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
655346	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
655347	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
655348	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
655349	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
655350	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
655351	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
655352	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
655353	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
655354	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	General Comments		
655355	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
655356	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Max Tap Position	10L	
655357	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Min Tap Position	3L	
655358	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
655359	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
655360	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
655361	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	80	
655362	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	80	
655363	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	75	
655364	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
655365	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
655366	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
655367	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
655368	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Regulator As Left Counter	208107	
655369	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
655370	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
655371	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
655372	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
655373	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
655374	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
655375	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
655376	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Tank Leaks	None	
655377	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
655378	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
655379	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Regulator As Left Counter	66981	
655380	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
655381	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
655382	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
655383	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
655384	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
655385	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Min Tap Position	3L	
655386	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Max Tap Position	11L	
655387	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
655388	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	General Comments		
655389	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
655390	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
655391	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
655392	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
655393	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
655394	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
655395	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
655396	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
655397	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
655398	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
655399	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
655400	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
655401	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
655402	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
655403	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
655404	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
655405	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
655406	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
655407	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
655408	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
655409	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
655410	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
655411	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	General Comments		
655412	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	General Comments		
655413	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
655414	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
655415	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Follow-up Action Required?	n	
655416	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
655417	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
655418	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
655419	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
655420	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
655421	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
655422	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
655423	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
655424	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
655425	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
655426	1/4/2019 11:41	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
655427	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Bushing Condition	Good	
655428	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Amps C Ø	280.0	
655429	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Amps B Ø	260.0	
655430	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Amps A Ø	280.0	
655431	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Accumulated Fault Duty C Ph V	1.18	%
655432	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
655433	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Accumulated Fault Duty A Ph V	2.06	%
655434	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	9 Month Operations	18	
655435	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
655436	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
655437	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
655438	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
655439	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
655440	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
655441	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
655442	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
655443	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
655444	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
655445	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
655446	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
655447	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	493	
655448	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	489	
655449	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
655450	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
655451	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
655452	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
655453	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
655454	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
655455	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
655456	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Readings	General Comments		
655457	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
655458	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	96	
655459	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90	
655460	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
655461	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
655462	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
655463	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
655464	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
655465	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
655466	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
655467	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Top Oil Temperature Max	30	°C
655468	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Top Oil Temperature Present	30	°C
655469	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
655470	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9486	
655471	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Unknown Operations	0	
655472	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Tank Paint Condition	Good	
655473	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Switching Operations	0	
655474	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Operations Counter AL	99980	
655475	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Operations Counter AF	99980	
655476	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
655477	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
655478	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
655479	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
655480	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
655481	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
655482	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
655483	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
655484	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
655485	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
655486	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
655487	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
655488	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
655489	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	General Comments		
655490	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
655491	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Max Tap Position	11L	
655492	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Min Tap Position	1L	
655493	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Moisture and Leak Free?	y	
655494	1/4/2019 15:42	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Maintenance Operations	0	
655495	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
655496	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
655497	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
655498	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
655499	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
655500	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
655501	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
655502	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
655503	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	General Comments		
655504	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	General Comments		
655505	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
655506	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
655507	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
655508	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
655509	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
655510	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
655511	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
655512	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Foundation Condition	Good	
655513	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
655514	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
655515	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	General Comments		
655516	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
655517	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
655518	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
655519	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
655520	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
655521	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
655522	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
655523	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
655524	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Site Service Trans Condition	Exterior Stains	
655525	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
655526	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
655527	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
655528	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
655529	1/4/2019 15:34	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2276.64	kw
655530	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
655531	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
655532	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
655533	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
655534	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1066	
655535	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1066	
655536	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0413	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	66	
655537	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Accumulated Fault Duty C Ph V	0	%
655538	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Amps A Ø	95	
655539	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Amps B Ø	110	
655540	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Amps C Ø	99	
655541	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	9 Month Operations	4	
655542	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Bushing Condition	Good	
655543	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
655544	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	Follow-up Action Required?	n	
655545	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
655546	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
655547	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
655548	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
655549	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
655550	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
655551	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	205.0	
655552	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
655553	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	General Comments		
655554	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
655555	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
655556	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
655557	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
655558	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
655559	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
655560	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
655561	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
655562	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
655563	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
655564	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Amps A Ø	10	
655565	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Amps B Ø	10	
655566	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Amps C Ø	10	
655567	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	9 Month Operations	4	
655568	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	211.0	
655569	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	198.0	
655570	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Bushings Connection/Risers	Good	
655571	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Accumulated Fault Duty A Ph V	0	%
655572	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Bushing Condition	Good	
655573	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Bushings Connection/Risers	Good	
655574	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
655575	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
655576	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
655577	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
655578	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
655579	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
655580	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
655581	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
655582	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
655583	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
655584	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
655585	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
655586	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
655587	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
655588	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
655589	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	52	°F
655590	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
655591	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
655592	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC Current Tap Position	2L	
655593	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
655594	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC As Left Counter	9187	
655595	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC Min Tap Position	12L	
655596	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC Operations Since Last Insp	288	
655597	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
655598	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
655599	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	General Comments		
655600	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
655601	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
655602	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Switching Operations	4	
655603	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
655604	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
655605	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
655606	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
655607	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
655608	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
655609	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
655610	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Tank Leaks	None	
655611	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
655612	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
655613	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Unknown Operations	0	
655614	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
655615	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
655616	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
655617	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
655618	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
655619	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
655620	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
655621	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
655622	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
655623	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
655624	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
655625	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	9 Month Operations	3	
655626	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC As Found Counter	9176	
655627	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
655628	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	General Comments		
655629	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
655630	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
655631	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	General Comments		
655632	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	General Comments		
655633	1/4/2019 12:22	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
655634	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Accumulated Fault Duty A Ph V	0	%
655635	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Accumulated Fault Duty B Ph V	0	%
655636	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
655637	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
655638	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
655639	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
655640	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
655641	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Accumulated Fault Duty A Ph V	3.25	%
655642	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Accumulated Fault Duty B Ph V	3.25	%
655643	1/4/2019 7:43	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Accumulated Fault Duty C Ph V	3.25	%
655644	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
655645	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
655646	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	General Comments		
655647	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	BCH000395	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
655648	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
655649	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
655650	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Foundation Condition	Good	
655651	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
655652	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PF000158	PowerFuse	GR-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
655653	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	PF000158	PowerFuse	GR-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
655654	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Operations B Ø	0	
655655	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Operations A Ø	0	
655656	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Adjusted Amps C Phase V	0	
655657	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
655658	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
655659	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
655660	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Adjusted Amps B Phase V	0	
655661	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Adjusted Amps A Phase V	0	
655662	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Equipment Properly Labeled?	y	
655663	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	BCH000395	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
655664	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
655665	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
655666	1/4/2019 15:25	Distribution	Harrodsburg North Quarterly Inspection	BCH000395	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
655667	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
655668	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
655669	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
655670	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
655671	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
655672	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Vegetation	None	
655673	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
655674	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	General Comments		
655675	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
655676	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
655677	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
655678	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
655679	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
655680	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	2197	
655681	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	2197	
655682	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	General Comments		
655683	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	3	
655684	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
655685	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
655686	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
655687	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Bushings Connection/Risers	Good	
655688	1/4/2019 10:56	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
655689	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
655690	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
655691	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Accumulated Fault Duty C Ph V	0	%
655692	1/4/2019 15:54	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Accumulated Fault Duty B Ph V	0	%
655693	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
655694	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
655695	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
655696	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
655697	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
655698	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
655699	1/4/2019 14:59	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Cabinet Paint Condition	Good	
655700	1/4/2019 10:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
655701	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
655702	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
655703	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	LV Winding Temp Max	55	°C
655704	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
655705	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
655706	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
655707	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
655708	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
655709	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
655710	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Clear of Trash?	y	
655711	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
655712	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
655713	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
655714	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Readings	General Comments		
655715	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
655716	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
655717	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
655718	1/4/2019 11:03	Distribution	Grady Quarterly Inspection	LB0412	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
655719	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
655720	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
655721	1/4/2019 11:34	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
655722	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AL	641	
655723	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Switching Operations	1	
655724	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AF	641	
655725	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Num Operations Last 9 Months	2	
655726	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
655727	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	General Comments		
655728	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Follow-up Action Required?	n	
655729	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Fault Operations	0	
655730	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Bushings Connection/Risers	Good	
655731	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Ambient Temperature	42	°F
655732	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
655733	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
655734	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Paint Condition	Good	
655735	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
655736	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Follow-up Action Required?	n	
655737	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Tank Paint Condition	Good	
655738	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
655739	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Pressure Indicator	good	
655740	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Bushing Condition	Good	
655741	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Foundation Condition	Good	
655742	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Gauge(s) Condition	Good	
655743	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	General Comments		
655744	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Grounds in Place?	y	
655745	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Heaters (All) Functioning?	y	
655746	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Moisture and Leak Free?	y	
655747	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
655748	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
655749	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
655750	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
655751	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	69	
655752	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
655753	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
655754	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
655755	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
655756	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
655757	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Bushing Condition	Good	
655758	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Amps C Ø	0.0	
655759	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Amps B Ø	0.0	
655760	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Amps A Ø	0.0	
655761	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
655762	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
655763	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
655764	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
655765	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
655766	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
655767	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
655768	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
655769	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
655770	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
655771	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
655772	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	52.8	VDC
655773	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
655774	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
655775	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
655776	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	52.8	VDC
655777	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
655778	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
655779	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
655780	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
655781	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
655782	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	General Comments		
655783	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
655784	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
655785	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
655786	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
655787	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Maintenance Operations	0	
655788	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
655789	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
655790	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
655791	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	7	
655792	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
655793	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	487	
655794	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	480	
655795	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
655796	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
655797	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
655798	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
655799	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
655800	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
655801	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
655802	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
655803	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Switching Operations	1	
655804	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
655805	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	Follow-up Action Required?	n	
655806	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Operations Counter AL	160	
655807	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Operations Counter AF	159	
655808	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
655809	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Maintenance Operations	0	
655810	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
655811	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Grounds in Place?	y	
655812	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	General Comments		
655813	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	N/A	
655814	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Totalizer Meter Reading	.0932	
655815	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
655816	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
655817	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
655818	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
655819	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
655820	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
655821	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
655822	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
655823	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
655824	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
655825	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	General Comments		
655826	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	General Comments		
655827	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC As Found Counter	364657	
655828	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
655829	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
655830	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
655831	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
655832	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	21	
655833	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
655834	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
655835	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
655836	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
655837	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
655838	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
655839	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
655840	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
655841	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
655842	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	39	°F
655843	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
655844	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
655845	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
655846	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
655847	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
655848	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
655849	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
655850	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Oil Temp Max	44	°C
655851	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
655852	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
655853	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
655854	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
655855	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
655856	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
655857	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC Operations Since Last Insp	550	
655858	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC Min Tap Position	7L	
655859	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC Max Tap Position	3L	
655860	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC Current Tap Position	3R	
655861	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
655862	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
655863	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC As Left Counter	364667	
655864	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
655865	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
655866	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
655867	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
655868	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
655869	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
655870	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
655871	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
655872	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
655873	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	LTCC000454	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
655874	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	LTCC000454	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
655875	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	LTCC000454	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
655876	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	LTCC000454	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
655877	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
655878	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
655879	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	LTC Totalizer Reading	4380.48	kw
655880	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
655881	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	General Comments		
655882	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Foundation Condition	Good	
655883	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
655884	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
655885	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
655886	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
655887	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
655888	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
655889	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
655890	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	General Comments		
655891	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	General Comments		
655892	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
655893	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
655894	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Follow-up Action Required?	n	
655895	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
655896	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Grounds in Place?	y	
655897	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
655898	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	General Comments	Barbwire is rusty.	
655899	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
655900	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
655901	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	General Comments		
655902	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BCH000217	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
655903	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BCH000217	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
655904	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BCH000217	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
655905	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
655906	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
655907	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
655908	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
655909	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	General Comments		
655910	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
655911	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	General Comments		
655912	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
655913	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
655914	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
655915	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
655916	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
655917	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
655918	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
655919	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Operations A Ø	0	
655920	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Operations B Ø	0	
655921	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Operations C Ø	0	
655922	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Operations Ground	0	
655923	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Follow-up Action Required?	n	
655924	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
655925	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
655926	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
655927	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
655928	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
655929	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Vegetation	None	
655930	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	General Comments		
655931	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
655932	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
655933	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
655934	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
655935	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
655936	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
655937	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
655938	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
655939	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
655940	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
655941	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Clear of Trash?	y	
655942	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
655943	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
655944	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
655945	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Floor Swept?	y	
655946	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
655947	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
655948	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
655949	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
655950	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
655951	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
655952	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
655953	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
655954	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
655955	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
655956	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
655957	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
655958	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
655959	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
655960	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Evidence of Insects	None	
655961	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
655962	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
655963	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
655964	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
655965	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
655966	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
655967	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
655968	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
655969	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
655970	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
655971	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
655972	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
655973	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
655974	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
655975	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
655976	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
655977	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
655978	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Unknown Operations	0	
655979	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
655980	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
655981	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
655982	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Broom on Site?	y	
655983	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
655984	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
655985	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
655986	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
655987	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
655988	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
655989	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
655990	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
655991	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Trash Emptied?	y	
655992	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
655993	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
655994	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
655995	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Panels Dusted?	y	
655996	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
655997	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	205.00	
655998	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
655999	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Foundation Condition	Good	
656000	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
656001	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
656002	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Follow-up Action Required?	n	
656003	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
656004	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
656005	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
656006	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
656007	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
656008	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2	psi
656009	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1300.0	psi
656010	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
656011	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
656012	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	General Comments		
656013	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	19	°C
656014	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	28	°C
656015	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
656016	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
656017	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
656018	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
656019	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
656020	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
656021	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
656022	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
656023	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
656024	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
656025	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
656026	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
656027	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0	VDC
656028	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
656029	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
656030	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
656031	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
656032	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
656033	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	General Comments		
656034	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
656035	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
656036	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
656037	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
656038	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
656039	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
656040	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
656041	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
656042	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
656043	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
656044	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
656045	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
656046	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
656047	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
656048	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
656049	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
656050	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
656051	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
656052	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
656053	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
656054	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
656055	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
656056	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
656057	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
656058	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
656059	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
656060	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
656061	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
656062	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
656063	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
656064	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Tank Leaks	None	
656065	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
656066	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
656067	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
656068	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	VRR Time Delay	30	Seconds
656069	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
656070	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
656071	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Tank Leaks	None	
656072	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
656073	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Operations Counter	34	
656074	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
656075	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
656076	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
656077	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	General Comments		
656078	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Patrol Inspection	General Comments		
656079	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Follow-up Action Required?	n	
656080	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Patrol Inspection	Follow-up Action Required?	n	
656081	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Operations Ground	0	
656082	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Operations C Ø	0	
656083	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Operations B Ø	0	
656084	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Operations A Ø	0	
656085	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
656086	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
656087	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
656088	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
656089	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
656090	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	LTC Output Voltage Level	120.9	VAC
656091	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	General Comments	Control check and battery 27.7/25.3	
656092	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
656093	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
656094	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
656095	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
656096	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
656097	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
656098	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
656099	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
656100	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
656101	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
656102	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Amps C Ø	48.0	
656103	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Amps B Ø	54.0	
656104	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Amps A Ø	70.0	
656105	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
656106	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Unknown Operations	0	
656107	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Switching Operations	0	
656108	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Operations Counter AL	156	
656109	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Operations Counter AF	156	
656110	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Maintenance Operations	0	
656111	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	General Comments		
656112	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	General Comments		
656113	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
656114	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Follow-up Action Required?	n	
656115	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
656116	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
656117	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
656118	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	All Connections OK?	y	
656119	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	Follow-up Action Required?	n	
656120	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5R	
656121	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	General Comments		
656122	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	LTC Operation Checked?	y	
656123	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	LTC Output Voltage Level	120.9	VAC
656124	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
656125	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
656126	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	VRR Time Delay	30	Seconds
656127	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
656128	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
656129	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	8R	
656130	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7R	
656131	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
656132	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC As Left Counter	329845	
656133	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC As Found Counter	329845	
656134	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
656135	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	General Comments		
656136	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
656137	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
656138	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
656139	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
656140	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
656141	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
656142	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
656143	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
656144	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
656145	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
656146	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
656147	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	General Comments		
656148	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
656149	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
656150	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
656151	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
656152	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
656153	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Ambient Temperature	40	°F
656154	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Unknown Operations	0	
656155	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Switching Operations	0	
656156	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Operations Counter AL	13	
656157	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Operations Counter AF	13	
656158	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Maintenance Operations	0	
656159	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
656160	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
656161	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
656162	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
656163	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
656164	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
656165	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Regulator As Left Counter	76570	
656166	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
656167	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Follow-up Action Required?	y	
656168	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
656169	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
656170	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Bushing Condition	Good	
656171	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
656172	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
656173	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	General Comments		
656174	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	Follow-up Action Required?	n	
656175	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	Equipment Properly Labeled?	y	
656176	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
656177	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
656178	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
656179	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
656180	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Current Tap Position	Neutral	
656181	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
656182	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC Operations Since Last Insp	0	
656183	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC Min Tap Position	8L	
656184	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Unknown Operations	0	
656185	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Tank Paint Condition	Good	
656186	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Switching Operations	1	
656187	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
656188	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Operations Counter AL	365	
656189	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Operations Counter AF	363	
656190	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Moisture and Leak Free?	y	
656191	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Maintenance Operations	0	
656192	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Switching Operations	1	
656193	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Amps A Ø	100.0	
656194	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Amps B Ø	100.0	
656195	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Amps C Ø	100.0	
656196	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Patrol Inspection	Equipment Properly Labeled?	y	
656197	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
656198	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
656199	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
656200	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Operations A Ø	0	
656201	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Unknown Operations	0	
656202	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Switching Operations	0	
656203	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Operations Counter AL	319	
656204	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Operations Counter AF	319	
656205	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Maintenance Operations	0	
656206	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	General Comments		
656207	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	General Comments		
656208	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Follow-up Action Required?	n	
656209	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
656210	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Patrol Inspection	Equipment Properly Labeled?	y	
656211	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Amps C Ø	147.0	
656212	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Amps B Ø	132.0	
656213	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Amps A Ø	153.0	
656214	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Accumulated Fault Duty C Ph V	5.02	%
656215	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Accumulated Fault Duty B Ph V	7.17	%
656216	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	Follow-up Action Required?	n	
656217	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Operations Ground	0	
656218	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Operations C Ø	0	
656219	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	Follow-up Action Required?	n	
656220	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Operations Ground	0	
656221	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Operations C Ø	0	
656222	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Operations B Ø	0	
656223	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Operations A Ø	0	
656224	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
656225	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
656226	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
656227	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	Equipment Properly Labeled?	y	
656228	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Amps C Ø	0.0	
656229	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Amps B Ø	0.0	
656230	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Amps A Ø	0.0	
656231	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
656232	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
656233	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
656234	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
656235	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
656236	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
656237	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
656238	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
656239	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
656240	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
656241	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
656242	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
656243	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
656244	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	9 Month Operations	11	
656245	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
656246	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	9 Month Operations	0	
656247	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Accumulated Fault Duty A Ph V	15.78	%
656248	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Accumulated Fault Duty B Ph V	18.65	%
656249	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Accumulated Fault Duty C Ph V	9.33	%
656250	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Unknown Operations	4	
656251	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
656252	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
656253	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
656254	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
656255	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Tank Paint Condition	Good	
656256	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Tank Leaks	None	
656257	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Surge Arrester Condition	Good	
656258	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
656259	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Regulator As Left Counter	47854	
656260	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Reg Output Voltage Level	118.3	volts
656261	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Reg Operation Checked?	y	
656262	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Reg Oil Level	Good	
656263	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
656264	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Moisture and Leak Free?	y	
656265	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Min Tap Position	Neutral	
656266	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Max Tap Position	Neutral	
656267	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Grounds in Place?	y	
656268	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	General Comments	won't operate	
656269	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Gauge(s) Condition	Good	
656270	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Foundation Condition	Good	
656271	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
656272	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
656273	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Amps C Ø	50.0	
656274	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Amps B Ø	60.0	
656275	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Amps A Ø	60.0	
656276	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
656277	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
656278	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
656279	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
656280	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Oil Temp Present	25	°C
656281	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
656282	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
656283	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
656284	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
656285	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
656286	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
656287	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
656288	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
656289	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
656290	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	35	°C
656291	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	25	°C
656292	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	30	°C
656293	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	25	°C
656294	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	35	°C
656295	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	25	°C
656296	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
656297	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	25	°C
656298	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
656299	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
656300	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Grounds in Place?	y	
656301	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	9 Months Operations	0	
656302	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
656303	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
656304	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
656305	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Foundation Condition	Good	
656306	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
656307	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	General Comments		
656308	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Bushing Condition	Good	
656309	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
656310	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
656311	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
656312	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
656313	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
656314	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
656315	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Amps A Ø	41	
656316	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Amps B Ø	18	
656317	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Amps C Ø	12	
656318	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
656319	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
656320	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
656321	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
656322	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
656323	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	LTCC000454	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
656324	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	LTCC000454	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
656325	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	LTCC000454	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
656326	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	LTCC000454	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
656327	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	LTCC000454	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
656328	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	31	°C
656329	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
656330	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
656331	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
656332	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
656333	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Unknown Operations	0	
656334	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Switching Operations	0	
656335	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	20	°C
656336	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	28	°C
656337	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	18	°C
656338	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	32	°C
656339	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
656340	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
656341	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
656342	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
656343	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
656344	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
656345	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
656346	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
656347	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
656348	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
656349	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
656350	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
656351	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
656352	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
656353	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
656354	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	9 Month Operations	6	
656355	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Operations Counter AL	410	
656356	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Operations Counter AF	410	
656357	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Maintenance Operations	0	
656358	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
656359	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	General Comments		
656360	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Patrol Inspection	General Comments		
656361	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Follow-up Action Required?	n	
656362	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
656363	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Operations Ground	0	
656364	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Operations C Ø	0	
656365	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Operations B Ø	0	
656366	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Operations A Ø	0	
656367	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
656368	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
656369	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
656370	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
656371	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
656372	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	General Comments		
656373	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	General Comments	TR needs nitrogen.	
656374	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
656375	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Surge Arrester Condition	Good	
656376	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	General Comments		
656377	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	General Comments		
656378	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Tank Leaks	None	
656379	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
656380	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
656381	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	500	psi
656382	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
656383	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
656384	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
656385	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
656386	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
656387	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	Seeping	
656388	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
656389	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
656390	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
656391	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
656392	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
656393	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
656394	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Switching Operations	0	
656395	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Operations Counter AL	312	
656396	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Operations Counter AF	312	
656397	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Maintenance Operations	0	
656398	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	General Comments		
656399	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Patrol Inspection	General Comments		
656400	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Follow-up Action Required?	n	
656401	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
656402	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
656403	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	50	°C
656404	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
656405	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	37	°C
656406	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	15	°C
656407	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	45	°C
656408	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Operations Ground	0	
656409	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Operations C Ø	0	
656410	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Operations B Ø	0	
656411	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Operations A Ø	0	
656412	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
656413	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
656414	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
656415	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
656416	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
656417	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
656418	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
656419	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
656420	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	83	
656421	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Foundation Condition	Good	
656422	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Follow-up Action Required?	n	
656423	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Tank Paint Condition	Good	
656424	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Follow-up Action Required?	n	
656425	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Fault Operations	0	
656426	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
656427	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
656428	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
656429	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
656430	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
656431	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
656432	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
656433	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
656434	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Current Tap Position	Neutral	
656435	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
656436	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Follow-up Action Required?	n	
656437	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
656438	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
656439	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
656440	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Foundation Condition	Good	
656441	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Gauge(s) Condition	Good	
656442	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
656443	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
656444	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
656445	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
656446	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
656447	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
656448	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	General Comments		
656449	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Grounds in Place?	y	
656450	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Max Tap Position	Neutral	
656451	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
656452	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
656453	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
656454	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
656455	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
656456	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
656457	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	General Comments		
656458	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
656459	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
656460	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Operations Counter	109	
656461	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
656462	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Tank Leaks	None	
656463	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
656464	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
656465	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
656466	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
656467	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	General Comments		
656468	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Radiators are seeping oil. Small amount of oil on ground.	
656469	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
656470	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Min Tap Position	Neutral	
656471	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Moisture and Leak Free?	y	
656472	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
656473	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Reg Oil Level	Good	
656474	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Reg Operation Checked?	y	
656475	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Unknown Operations	0	
656476	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Reg Output Voltage Level	120.1	volts

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
656477	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Regulator As Left Counter	44760	
656478	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
656479	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
656480	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Clear of Trash?	y	
656481	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
656482	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
656483	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
656484	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
656485	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
656486	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
656487	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	General Comments		
656488	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
656489	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Vegetation	None	
656490	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
656491	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	General Comments		
656492	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	LTC Operation Checked?	y	
656493	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Operations Counter AF	168	
656494	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Operations Counter AL	168	
656495	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Switching Operations	0	
656496	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Tank Paint Condition	Good	
656497	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Unknown Operations	0	
656498	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	PF000184	PowerFuse	HK-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
656499	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	PF000184	PowerFuse	HK-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
656500	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
656501	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
656502	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
656503	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
656504	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
656505	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
656506	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
656507	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
656508	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
656509	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
656510	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
656511	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
656512	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
656513	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
656514	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Operations Counter AF	99997	
656515	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Moisture and Leak Free?	y	
656516	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Maintenance Operations	0	
656517	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Grounds in Place?	y	
656518	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	General Comments	BFTC	
656519	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	General Comments		
656520	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Foundation Condition	Good	
656521	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Follow-up Action Required?	n	
656522	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Follow-up Action Required?	n	
656523	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Operations Ground	0	
656524	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
656525	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
656526	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
656527	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.168	
656528	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
656529	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
656530	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	General Comments		
656531	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
656532	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	General Comments		
656533	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
656534	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
656535	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
656536	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
656537	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
656538	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
656539	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
656540	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
656541	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
656542	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
656543	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
656544	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
656545	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
656546	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	General Comments		
656547	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Grounds in Place?	y	
656548	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Maintenance Operations	0	
656549	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Moisture and Leak Free?	y	
656550	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
656551	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
656552	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
656553	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
656554	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
656555	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
656556	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
656557	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
656558	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
656559	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
656560	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	General Comments		
656561	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
656562	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
656563	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
656564	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
656565	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
656566	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
656567	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
656568	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
656569	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
656570	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Winding Temp Present	20	°C
656571	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Winding Temp Max	45	°C
656572	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Totalizer Meter Reading	.3042	
656573	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
656574	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
656575	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
656576	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	All Connections OK?	y	
656577	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	Follow-up Action Required?	n	
656578	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
656579	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
656580	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
656581	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
656582	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	PF001162	PowerFuse	HK-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
656583	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	PF001162	PowerFuse	HK-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
656584	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	PF001161	PowerFuse	HK-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
656585	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	PF001161	PowerFuse	HK-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
656586	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
656587	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
656588	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
656589	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
656590	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
656591	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
656592	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
656593	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
656594	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
656595	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
656596	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
656597	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
656598	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
656599	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
656600	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
656601	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
656602	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
656603	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
656604	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
656605	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
656606	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
656607	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
656608	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
656609	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
656610	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
656611	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
656612	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3	psi
656613	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
656614	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
656615	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	General Comments		
656616	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	General Comments		
656617	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
656618	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
656619	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
656620	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
656621	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
656622	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
656623	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
656624	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
656625	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
656626	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
656627	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.700	millivolts
656628	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
656629	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
656630	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
656631	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
656632	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
656633	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
656634	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
656635	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
656636	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
656637	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
656638	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
656639	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
656640	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Amps C Ø	0.0	
656641	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Amps B Ø	0.0	
656642	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Amps A Ø	0.0	
656643	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
656644	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
656645	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
656646	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	9 Months Operations	0	
656647	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Oil Temp Max	20	°C
656648	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45	
656649	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50	
656650	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
656651	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
656652	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Operations C Ø	0	
656653	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Operations B Ø	0	
656654	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Operations A Ø	0	
656655	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
656656	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
656657	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2803.2	kw
656658	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
656659	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Amps A Ø	0.0	
656660	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
656661	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
656662	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
656663	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
656664	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	9 Months Operations	0	
656665	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
656666	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
656667	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
656668	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
656669	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
656670	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
656671	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
656672	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
656673	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
656674	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
656675	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
656676	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
656677	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
656678	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
656679	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
656680	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
656681	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
656682	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
656683	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
656684	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
656685	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1	
656686	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1	
656687	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
656688	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
656689	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
656690	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
656691	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
656692	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
656693	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Operations Counter AL	397	
656694	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Switching Operations	0	
656695	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Unknown Operations	0	
656696	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
656697	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
656698	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
656699	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
656700	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
656701	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
656702	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
656703	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
656704	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Tank Leaks	None	
656705	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
656706	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
656707	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
656708	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
656709	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
656710	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
656711	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
656712	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	General Comments		
656713	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
656714	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
656715	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
656716	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	PF000179	PowerFuse	HL-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
656717	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	PF000179	PowerFuse	HL-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
656718	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
656719	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
656720	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Regulator As Left Counter	44335	
656721	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
656722	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
656723	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	400.0	
656724	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	400.0	
656725	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	400.0	
656726	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
656727	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
656728	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
656729	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
656730	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
656731	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
656732	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
656733	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Equipment Properly Labeled?	y	
656734	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Cabinet Paint Condition	Good	
656735	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
656736	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
656737	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
656738	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Bushings Connection/Risers	Good	
656739	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Bushing Condition	Good	
656740	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Amps C Ø	116.0	
656741	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Amps B Ø	100.0	
656742	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Amps A Ø	85.0	
656743	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Accumulated Fault Duty C Ph V	.66	%
656744	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Accumulated Fault Duty B Ph V	.66	%
656745	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Accumulated Fault Duty A Ph V	.66	%
656746	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Follow-up Action Required?	n	
656747	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	9 Month Operations	169	
656748	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
656749	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
656750	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
656751	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
656752	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
656753	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Patrol Inspection	Follow-up Action Required?	n	
656754	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Operations Ground	0	
656755	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Operations C Ø	0	
656756	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Operations B Ø	0	
656757	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
656758	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
656759	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
656760	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Vegetation	None	
656761	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
656762	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
656763	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	General Comments		
656764	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
656765	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Operations A Ø	0	
656766	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Patrol Inspection	General Comments		
656767	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Patrol Inspection	General Comments		
656768	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Patrol Inspection	Follow-up Action Required?	n	
656769	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
656770	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	General Comments		
656771	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Maintenance Operations	0	
656772	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Operations Counter AF	397	
656773	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
656774	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
656775	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
656776	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
656777	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
656778	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
656779	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
656780	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
656781	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
656782	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
656783	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
656784	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
656785	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
656786	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
656787	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
656788	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
656789	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
656790	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
656791	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
656792	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
656793	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Vegetation	None	
656794	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
656795	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
656796	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
656797	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
656798	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
656799	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
656800	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
656801	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
656802	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
656803	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
656804	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Operations Counter AL	1	
656805	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
656806	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
656807	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
656808	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
656809	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
656810	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	General Comments		
656811	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
656812	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
656813	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
656814	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
656815	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
656816	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Operations A Ø	0	
656817	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Operations B Ø	0	
656818	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Operations C Ø	0	
656819	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
656820	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
656821	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Amps C Ø	0.0	
656822	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Amps B Ø	0.0	
656823	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Operations Ground	0	
656824	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Follow-up Action Required?	n	
656825	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Follow-up Action Required?	n	
656826	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Foundation Condition	Good	
656827	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
656828	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
656829	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
656830	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
656831	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
656832	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
656833	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	PF000183	PowerFuse	HK-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
656834	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	PF000183	PowerFuse	HK-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
656835	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
656836	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
656837	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
656838	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
656839	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
656840	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
656841	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
656842	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
656843	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
656844	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
656845	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
656846	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
656847	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
656848	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
656849	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	General Comments		
656850	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
656851	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Min Tap Position	9L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
656852	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Max Tap Position	12R	
656853	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
656854	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
656855	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
656856	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
656857	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
656858	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	General Comments		
656859	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
656860	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
656861	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1609	
656862	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1605	
656863	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	6	
656864	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
656865	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
656866	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
656867	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
656868	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	General Comments		
656869	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Unknown Operations	0	
656870	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Tank Paint Condition	Good	
656871	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Switching Operations	4	
656872	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
656873	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
656874	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
656875	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
656876	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
656877	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
656878	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
656879	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
656880	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
656881	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
656882	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
656883	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
656884	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
656885	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
656886	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	General Comments		
656887	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	General Comments		
656888	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
656889	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
656890	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
656891	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
656892	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	559.20	kw
656893	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
656894	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
656895	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	DX0152	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
656896	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	DX0152	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
656897	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	DX0152	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
656898	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	DX0152	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
656899	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	DX0152	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	.7	
656900	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	DX0152	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	.7	
656901	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	DX0152	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	.5	
656902	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
656903	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
656904	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
656905	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
656906	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
656907	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
656908	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
656909	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
656910	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
656911	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Ambient Temperature	40	°F
656912	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
656913	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
656914	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
656915	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
656916	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
656917	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Bushing Condition	Good	
656918	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Amps C Ø	228.0	
656919	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Amps B Ø	237.0	
656920	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Amps A Ø	207.0	
656921	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
656922	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
656923	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Oil Temp Max	50	°C
656924	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Oil Temp Present	30	°C
656925	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
656926	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
656927	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
656928	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
656929	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
656930	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
656931	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
656932	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	6000	
656933	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
656934	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
656935	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
656936	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
656937	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
656938	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
656939	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
656940	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
656941	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
656942	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
656943	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Equipment Properly Labeled?	y	
656944	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Cabinet Paint Condition	Good	
656945	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
656946	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
656947	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
656948	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Follow-up Action Required?	n	
656949	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Follow-up Action Required?	n	
656950	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Follow-up Action Required?	n	
656951	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Fault Operations	0	
656952	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
656953	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Follow-up Action Required?	n	
656954	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Bushings Connection/Risers	Good	
656955	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Bushing Condition	Good	
656956	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Amps C Ø	12.0	
656957	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Amps B Ø	12.0	
656958	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Amps A Ø	12.0	
656959	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Accumulated Fault Duty C Ph V	8.49	%
656960	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Accumulated Fault Duty B Ph V	8.49	%
656961	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Accumulated Fault Duty A Ph V	8.49	%
656962	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	9 Month Operations	8	
656963	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Foundation Condition	Good	
656964	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	General Comments		
656965	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	General Comments		
656966	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Grounds in Place?	y	
656967	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Maintenance Operations	0	
656968	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Moisture and Leak Free?	y	
656969	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Operations Counter AF	180	
656970	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Operations Counter AL	180	
656971	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Switching Operations	0	
656972	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Tank Paint Condition	Good	
656973	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Unknown Operations	0	
656974	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
656975	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
656976	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
656977	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Foundation Condition	Good	
656978	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
656979	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
656980	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	General Comments		
656981	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Operations A Ø	0	
656982	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
656983	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
656984	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
656985	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
656986	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
656987	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	106220	
656988	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
656989	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
656990	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
656991	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
656992	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
656993	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	16L	
656994	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
656995	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
656996	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
656997	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
656998	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
656999	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
657000	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	General Comments		
657001	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
657002	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	12R	
657003	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
657004	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
657005	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
657006	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
657007	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
657008	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
657009	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
657010	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
657011	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
657012	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
657013	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
657014	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
657015	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Oil Temp Max	70	°C
657016	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
657017	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
657018	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	LTC Totalizer Reading	991.20	kw
657019	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
657020	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	General Comments		
657021	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	General Comments		
657022	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
657023	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
657024	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Follow-up Action Required?	n	
657025	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
657026	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
657027	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
657028	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
657029	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
657030	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
657031	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
657032	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
657033	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
657034	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
657035	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
657036	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
657037	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Tank Paint Condition	Good	
657038	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
657039	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
657040	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Oil Temp Present	20	°C
657041	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Switching Operations	0	
657042	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
657043	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
657044	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
657045	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
657046	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
657047	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
657048	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	9 Month Operations	1	
657049	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
657050	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
657051	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	Totalizer Meter Reading	.5424	
657052	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
657053	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
657054	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BCH000217	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
657055	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BCH000217	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
657056	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
657057	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
657058	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
657059	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	96250	
657060	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
657061	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
657062	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
657063	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
657064	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
657065	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
657066	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	8R	
657067	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
657068	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
657069	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
657070	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
657071	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
657072	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
657073	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2L	
657074	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
657075	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	SF6 Pressure	64	psi
657076	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
657077	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Operations Counter AL	79	
657078	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Operations Counter AF	79	
657079	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Num Operations Last 9 Months	0	
657080	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
657081	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
657082	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
657083	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
657084	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
657085	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
657086	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
657087	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	92237	
657088	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
657089	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
657090	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
657091	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
657092	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
657093	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
657094	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	9 Month Operations	2	
657095	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
657096	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	3L	
657097	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	1R	
657098	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
657099	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
657100	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
657101	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
657102	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
657103	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
657104	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	3L	
657105	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
657106	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
657107	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
657108	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
657109	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
657110	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Operations Counter AL	218	
657111	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
657112	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	VRR Time Delay	30	Seconds
657113	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
657114	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
657115	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
657116	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
657117	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
657118	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
657119	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
657120	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
657121	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
657122	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
657123	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
657124	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Amps A Ø	67.0	
657125	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Amps B Ø	80.0	
657126	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Amps C Ø	66.0	
657127	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Bushing Condition	Good	
657128	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Bushings Connection/Risers	Good	
657129	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Operations Counter AF	216	
657130	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
657131	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Maintenance Operations	0	
657132	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
657133	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
657134	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
657135	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
657136	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
657137	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Unknown Operations	0	
657138	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Tank Paint Condition	Good	
657139	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Switching Operations	2	
657140	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
657141	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
657142	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	General Comments		
657143	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6540	
657144	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
657145	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
657146	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
657147	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
657148	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
657149	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
657150	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
657151	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Oil Temp Present	31	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
657152	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
657153	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
657154	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	227.50	
657155	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1569.60	kw
657156	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
657157	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
657158	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
657159	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	General Comments		
657160	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	General Comments		
657161	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
657162	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
657163	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
657164	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
657165	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
657166	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
657167	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
657168	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
657169	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
657170	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
657171	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
657172	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
657173	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
657174	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
657175	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
657176	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
657177	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
657178	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LTCC000429	LTCControl	HK-TRANS 2	LTC Control Insp	All Connections OK?	y	
657179	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LTCC000429	LTCControl	HK-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
657180	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LTCC000429	LTCControl	HK-TRANS 2	LTC Control Insp	General Comments		
657181	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LTCC000429	LTCControl	HK-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
657182	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
657183	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
657184	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
657185	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
657186	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
657187	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
657188	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
657189	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
657190	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
657191	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
657192	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
657193	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
657194	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
657195	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
657196	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
657197	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
657198	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	BCH000215	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
657199	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	BCH000215	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
657200	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	BCH000215	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
657201	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	BCH000215	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
657202	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Grounds in Place?	y	
657203	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	General Comments		
657204	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	General Comments		
657205	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
657206	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Foundation Condition	Good	
657207	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
657208	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
657209	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
657210	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Cabinet Paint Condition	Good	
657211	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
657212	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
657213	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Equipment Properly Labeled?	y	
657214	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Clear of Trash?	y	
657215	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	DX0152	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
657216	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	DX0152	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
657217	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
657218	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
657219	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	DX0152	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	310	
657220	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	DX0152	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
657221	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	DX0152	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
657222	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	DX0152	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
657223	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
657224	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
657225	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
657226	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
657227	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Operations B Ø	0	
657228	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Operations C Ø	0	
657229	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Operations Ground	0	
657230	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
657231	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
657232	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Operations B Ø	0	
657233	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
657234	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
657235	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Oil Temp Present	30	°C
657236	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
657237	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
657238	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Totalizer Meter Reading	.1652	
657239	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
657240	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
657241	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Follow-up Action Required?	n	
657242	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Follow-up Action Required?	n	
657243	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Operations Ground	0	
657244	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Operations C Ø	0	
657245	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
657246	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
657247	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
657248	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
657249	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
657250	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
657251	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
657252	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
657253	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
657254	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
657255	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
657256	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
657257	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
657258	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	Follow-up Action Required?	n	
657259	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
657260	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
657261	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	General Comments		
657262	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	General Comments		
657263	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
657264	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	LTC Totalizer Reading	9763.20	kw
657265	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
657266	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	Oil Temp Max	43	°C
657267	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	Oil Temp Present	33	°C
657268	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
657269	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
657270	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
657271	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
657272	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
657273	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	BCH000215	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
657274	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Tank Paint Condition	Good	
657275	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Switching Operations	0	
657276	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
657277	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	SF6 Pressure	65	psi
657278	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
657279	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Operations Counter AL	80	
657280	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Operations Counter AF	80	
657281	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Num Operations Last 9 Months	0	
657282	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
657283	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Maintenance Operations	0	
657284	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
657285	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
657286	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
657287	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
657288	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
657289	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	VRR Time Delay	30	Seconds
657290	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	VRR X Compensation AF	0	Position
657291	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	VRR X Compensation AL	0	Position
657292	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
657293	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
657294	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
657295	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
657296	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
657297	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
657298	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
657299	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Totalizer Meter Reading	.3010	
657300	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
657301	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
657302	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
657303	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
657304	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
657305	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
657306	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
657307	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
657308	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Current Tap Position	3R	
657309	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
657310	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
657311	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
657312	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Patrol Inspection	General Comments		
657313	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
657314	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
657315	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
657316	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	General Comments	Previous counter entered in error . Corect counter now.	
657317	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
657318	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
657319	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
657320	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
657321	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
657322	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
657323	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
657324	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
657325	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Regulator As Left Counter	33956	
657326	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
657327	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Tank Leaks	None	
657328	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
657329	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
657330	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Regulator As Left Counter	116331	
657331	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.9	volts
657332	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
657333	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
657334	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
657335	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
657336	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
657337	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
657338	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
657339	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	General Comments		
657340	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
657341	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
657342	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
657343	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
657344	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
657345	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
657346	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
657347	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
657348	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
657349	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
657350	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
657351	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Tank Leaks	None	
657352	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
657353	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
657354	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Tank Leaks	None	
657355	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
657356	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
657357	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Regulator As Left Counter	85466	
657358	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
657359	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
657360	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
657361	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
657362	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
657363	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	General Comments		
657364	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
657365	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
657366	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
657367	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
657368	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
657369	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
657370	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Clear of Trash?	y	
657371	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
657372	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
657373	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
657374	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
657375	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
657376	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
657377	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
657378	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
657379	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
657380	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
657381	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
657382	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
657383	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
657384	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
657385	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
657386	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
657387	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
657388	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
657389	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
657390	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	All Connections OK?	y	
657391	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	Current Tap Position	4L	
657392	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	FCP Block Raise AF	0.0	VAC
657393	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	FCP Block Raise AL	0.0	VAC
657394	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	FCP Lower AF	0.0	VAC
657395	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	FCP Lower AL	0.0	VAC
657396	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
657397	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	n	
657398	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
657399	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
657400	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
657401	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
657402	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
657403	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	There is one light fixture not working. Needs 2 eight foot single pin bulbs or a new ballast. Also the floor is rusted on the edges.	
657404	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
657405	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	y	
657406	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
657407	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
657408	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	Yes_needs_sprayed	
657409	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
657410	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
657411	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
657412	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
657413	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	205.00	
657414	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
657415	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
657416	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
657417	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
657418	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
657419	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
657420	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
657421	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	Follow-up Action Required?	n	
657422	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	General Comments		
657423	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	Max Tap Position	Neutral	
657424	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	Min Tap Position	10L	
657425	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
657426	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
657427	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
657428	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	VRR Base Voltage AF	121.0	VAC
657429	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	VRR Base Voltage AL	121.0	VAC
657430	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	VRR Counter AF	74341	
657431	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	KRC001053	RegulatorControl	746-3 AB	Regulator Annual Control Inspection	VRR Counter AL	74341	
657432	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
657433	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
657434	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
657435	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
657436	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
657437	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
657438	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
657439	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Floor Swept?	y	
657440	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
657441	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
657442	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Evidence of Insects	None	
657443	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
657444	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
657445	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
657446	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
657447	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
657448	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
657449	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
657450	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
657451	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
657452	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
657453	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
657454	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
657455	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	General Comments		
657456	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
657457	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC As Found Counter	33660	
657458	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
657459	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
657460	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
657461	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
657462	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
657463	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
657464	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
657465	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	Follow-up Action Required?	n	
657466	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
657467	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	General Comments		
657468	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	General Comments		
657469	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC As Found Counter	37649	
657470	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC As Left Counter	37649	
657471	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
657472	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC Current Tap Position	4L	
657473	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
657474	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC Min Tap Position	12L	
657475	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC Operations Since Last Insp	256	
657476	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
657477	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
657478	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	General Comments		
657479	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
657480	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
657481	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
657482	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	General Comments		
657483	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
657484	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
657485	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
657486	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
657487	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
657488	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
657489	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
657490	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
657491	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
657492	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
657493	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
657494	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
657495	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
657496	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
657497	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
657498	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5500	
657499	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
657500	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Top Oil Temperature Present	26	°C
657501	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Top Oil Temperature Max	50	°C
657502	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
657503	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
657504	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
657505	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
657506	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
657507	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
657508	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
657509	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
657510	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
657511	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
657512	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	General Comments		
657513	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
657514	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
657515	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
657516	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
657517	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
657518	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
657519	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Totalizer Meter Reading	.3930	
657520	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
657521	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
657522	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
657523	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
657524	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
657525	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
657526	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
657527	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
657528	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
657529	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
657530	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
657531	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
657532	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Oil Temp Present	22	°C
657533	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Oil Temp Max	42	°C
657534	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
657535	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
657536	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	LTC Totalizer Reading	1886.40	kw
657537	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
657538	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	General Comments		
657539	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	General Comments		
657540	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
657541	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
657542	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Follow-up Action Required?	n	
657543	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
657544	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
657545	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Tank Leaks	None	
657546	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
657547	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
657548	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Regulator As Left Counter	99816	
657549	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
657550	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
657551	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
657552	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
657553	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
657554	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
657555	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
657556	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
657557	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	General Comments		
657558	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
657559	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
657560	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
657561	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
657562	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
657563	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
657564	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
657565	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
657566	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
657567	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
657568	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
657569	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
657570	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
657571	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Panels Dusted?	y	
657572	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
657573	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
657574	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	General Comments		
657575	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
657576	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
657577	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
657578	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
657579	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
657580	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
657581	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
657582	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
657583	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	General Comments		
657584	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
657585	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	9 Month Operations	8	
657586	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Accumulated Fault Duty A Ph V	12.49	%
657587	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Accumulated Fault Duty B Ph V	13.53	%
657588	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Accumulated Fault Duty C Ph V	11.45	%
657589	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Amps A Ø	250.0	
657590	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Amps B Ø	240.0	
657591	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Amps C Ø	240.0	
657592	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC As Found Counter	226139	
657593	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC As Left Counter	226139	
657594	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
657595	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
657596	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
657597	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
657598	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
657599	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
657600	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
657601	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
657602	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
657603	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Max Tap Position	7L	
657604	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Min Tap Position	16L	
657605	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
657606	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	512	
657607	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
657608	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
657609	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
657610	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
657611	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
657612	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
657613	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Clear of Trash?	y	
657614	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
657615	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
657616	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
657617	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
657618	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
657619	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	General Comments		
657620	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
657621	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
657622	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
657623	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
657624	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
657625	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
657626	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
657627	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
657628	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
657629	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
657630	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
657631	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
657632	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Vegetation	None	
657633	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
657634	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
657635	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
657636	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Bushing Condition	Good	
657637	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Bushings Connection/Risers	Good	
657638	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
657639	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
657640	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
657641	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Cabinet Paint Condition	Good	
657642	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Equipment Properly Labeled?	y	
657643	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
657644	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
657645	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
657646	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Operations A Ø	0	
657647	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Operations B Ø	0	
657648	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Operations C Ø	0	
657649	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Operations Ground	0	
657650	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Follow-up Action Required?	n	
657651	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
657652	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
657653	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
657654	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
657655	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
657656	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
657657	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
657658	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
657659	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	General Comments		
657660	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
657661	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
657662	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
657663	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
657664	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
657665	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Operations Ground	0	
657666	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Patrol Inspection	Follow-up Action Required?	n	
657667	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Follow-up Action Required?	n	
657668	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Patrol Inspection	General Comments		
657669	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	General Comments		
657670	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Maintenance Operations	0	
657671	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Operations Counter AF	625	
657672	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Operations Counter AL	625	
657673	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Switching Operations	0	
657674	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Unknown Operations	0	
657675	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
657676	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Fans Operational?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
657677	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
657678	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Follow-up Action Required?	n	
657679	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
657680	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
657681	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	General Comments		
657682	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	General Comments		
657683	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
657684	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	LTC Totalizer Reading	4334.40	kw
657685	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
657686	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
657687	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Oil Temp Max	35	°C
657688	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
657689	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
657690	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
657691	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
657692	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
657693	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
657694	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
657695	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
657696	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	General Comments		
657697	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	Tap changer oil is Low	
657698	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC As Found Counter	60761	
657699	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC As Left Counter	60761	
657700	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
657701	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
657702	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
657703	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	15L	
657704	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
657705	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	10	°C
657706	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	60	°C
657707	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	716	
657708	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
657709	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
657710	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
657711	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	72	
657712	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
657713	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Amps B Ø	14.3	
657714	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
657715	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	62	
657716	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
657717	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
657718	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	87	
657719	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
657720	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
657721	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
657722	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	General Comments		
657723	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
657724	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
657725	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
657726	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
657727	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
657728	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
657729	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
657730	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
657731	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
657732	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Bushing Condition	Good	
657733	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Amps C Ø	0.0	
657734	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Amps B Ø	0.0	
657735	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Amps A Ø	0.0	
657736	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
657737	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
657738	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
657739	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	9 Month Operations	4	
657740	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
657741	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Oil Temp Present	30	°C
657742	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
657743	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	225.00	
657744	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
657745	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
657746	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
657747	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
657748	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
657749	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
657750	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
657751	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
657752	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
657753	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
657754	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
657755	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
657756	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
657757	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
657758	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Clear of Trash?	y	
657759	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
657760	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
657761	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
657762	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
657763	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
657764	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
657765	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
657766	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
657767	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
657768	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
657769	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
657770	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
657771	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
657772	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	General Comments		
657773	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
657774	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Foundation Condition	Good	
657775	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
657776	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
657777	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
657778	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
657779	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
657780	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
657781	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LTCC000519	LTCControl	HK-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
657782	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LTCC000519	LTCControl	HK-TRANS 1	LTC Control Insp	General Comments		
657783	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LTCC000519	LTCControl	HK-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
657784	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LTCC000519	LTCControl	HK-TRANS 1	LTC Control Insp	All Connections OK?	y	
657785	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LTCC000518	LTCControl	HN-TRANS 1	LTC Control Insp	General Comments		
657786	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LTCC000518	LTCControl	HN-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
657787	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LTCC000518	LTCControl	HN-TRANS 1	LTC Control Insp	All Connections OK?	y	
657788	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
657789	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
657790	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
657791	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
657792	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
657793	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
657794	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
657795	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
657796	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Vegetation	None	
657797	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
657798	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
657799	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
657800	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
657801	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
657802	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
657803	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
657804	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
657805	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
657806	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
657807	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Follow-up Action Required?	n	
657808	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Foundation Condition	Good	
657809	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	General Comments		
657810	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	General Comments		
657811	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Grounds in Place?	y	
657812	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Heaters (All) Functioning?	y	
657813	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Maintenance Operations	0	
657814	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Moisture and Leak Free?	y	
657815	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Operations Counter AF	432	
657816	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Operations Counter AL	436	
657817	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
657818	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Switching Operations	4	
657819	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Tank Paint Condition	Good	
657820	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Unknown Operations	0	
657821	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
657822	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	41	°F
657823	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
657824	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	General Comments		
657825	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
657826	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
657827	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Tank Paint Condition	Good	
657828	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Switching Operations	1	
657829	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Operations Counter AL	178	
657830	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Operations Counter AF	177	
657831	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
657832	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Maintenance Operations	0	
657833	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
657834	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Grounds in Place?	y	
657835	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	General Comments	ftcs	
657836	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	General Comments		
657837	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
657838	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Foundation Condition	Good	
657839	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
657840	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
657841	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
657842	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
657843	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
657844	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
657845	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
657846	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
657847	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
657848	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
657849	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
657850	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
657851	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
657852	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
657853	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Vegetation	None	
657854	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
657855	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Foundation Condition	Good	
657856	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Follow-up Action Required?	n	
657857	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Follow-up Action Required?	n	
657858	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Operations Ground	0	
657859	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Operations C Ø	0	
657860	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Operations B Ø	0	
657861	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Operations A Ø	0	
657862	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
657863	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
657864	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
657865	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
657866	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	General Comments		
657867	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
657868	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
657869	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
657870	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
657871	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC As Left Counter	69809	
657872	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC As Found Counter	69801	
657873	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	General Comments		
657874	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	General Comments		
657875	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
657876	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
657877	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
657878	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
657879	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
657880	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
657881	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
657882	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
657883	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
657884	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
657885	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
657886	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
657887	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
657888	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
657889	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	Follow-up Action Required?	n	
657890	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
657891	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
657892	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
657893	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
657894	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
657895	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
657896	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
657897	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
657898	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
657899	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
657900	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
657901	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
657902	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
657903	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
657904	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
657905	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
657906	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
657907	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
657908	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
657909	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
657910	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
657911	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
657912	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
657913	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
657914	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
657915	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC As Left Counter	420083	
657916	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC As Found Counter	420071	
657917	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	General Comments		
657918	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	General Comments		
657919	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
657920	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
657921	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
657922	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
657923	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
657924	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
657925	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	Follow-up Action Required?	n	
657926	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
657927	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
657928	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
657929	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
657930	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
657931	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	General Comments		
657932	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
657933	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
657934	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Min Tap Position	16L	
657935	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
657936	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
657937	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
657938	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
657939	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
657940	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Regulator As Left Counter	60913	
657941	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
657942	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Operations C Ø	0	
657943	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
657944	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
657945	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC Operations Since Last Insp	1371	
657946	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC Min Tap Position	10L	
657947	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
657948	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC Max Tap Position	9R	
657949	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC Current Tap Position	4L	
657950	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
657951	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
657952	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Winding Temp Present	30	°C
657953	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Winding Temp Max	45	°C
657954	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Totalizer Meter Reading	.7850	
657955	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
657956	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
657957	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
657958	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
657959	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
657960	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
657961	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
657962	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
657963	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
657964	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
657965	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
657966	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
657967	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
657968	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
657969	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
657970	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
657971	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Oil Temp Present	25	°C
657972	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Oil Temp Max	45	°C
657973	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
657974	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
657975	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	LTC Totalizer Reading	11304.00	kw
657976	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
657977	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	General Comments	ONLY ONE GROUP OF FANS	
657978	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	General Comments		
657979	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
657980	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
657981	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
657982	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
657983	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
657984	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
657985	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
657986	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
657987	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
657988	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
657989	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
657990	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	Temp guage is seeping very slightly.	
657991	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
657992	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
657993	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
657994	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
657995	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
657996	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
657997	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	Seeping	
657998	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
657999	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
658000	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	19	
658001	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	22.90	%
658002	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Follow-up Action Required?	n	
658003	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	29.15	%
658004	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	24.99	%
658005	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	240.0	
658006	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	240.0	
658007	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	240.0	
658008	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
658009	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
658010	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
658011	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC Operations Since Last Insp	434	
658012	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
658013	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC Min Tap Position	8L	
658014	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC Max Tap Position	16R	
658015	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC Current Tap Position	4L	
658016	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	General Comments		
658017	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	General Comments		
658018	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
658019	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
658020	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
658021	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	7093.44	kw
658022	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
658023	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
658024	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
658025	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
658026	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
658027	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
658028	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Oil Temp Max	62	°C
658029	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Oil Temp Present	28	°C
658030	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
658031	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
658032	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
658033	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
658034	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
658035	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
658036	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
658037	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
658038	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Totalizer Meter Reading	.9852	
658039	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
658040	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
658041	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
658042	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
658043	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
658044	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
658045	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
658046	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
658047	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
658048	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC Operations Since Last Insp	428	
658049	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC Min Tap Position	11L	
658050	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC Max Tap Position	2R	
658051	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC Current Tap Position	3L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
658052	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
658053	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC As Left Counter	154088	
658054	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC As Found Counter	154088	
658055	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	General Comments		
658056	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	General Comments		
658057	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
658058	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	Follow-up Action Required?	n	
658059	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
658060	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	543	
658061	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
658062	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	9	
658063	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
658064	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
658065	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
658066	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
658067	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
658068	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
658069	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
658070	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
658071	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
658072	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
658073	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
658074	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
658075	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
658076	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	General Comments		
658077	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Tank Leaks	None	
658078	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
658079	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
658080	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Regulator As Left Counter	35170	
658081	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
658082	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
658083	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
658084	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
658085	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
658086	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Min Tap Position	16L	
658087	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
658088	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
658089	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Operations Ground	0	
658090	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Follow-up Action Required?	n	
658091	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Follow-up Action Required?	n	
658092	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Foundation Condition	Good	
658093	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	General Comments		
658094	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
658095	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
658096	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	General Comments		
658097	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Grounds in Place?	y	
658098	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Heaters (All) Functioning?	y	
658099	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
658100	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
658101	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
658102	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
658103	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
658104	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
658105	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
658106	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
658107	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
658108	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Maintenance Operations	0	
658109	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Moisture and Leak Free?	y	
658110	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Operations Counter AF	216	
658111	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Operations Counter AL	218	
658112	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
658113	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Switching Operations	2	
658114	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Tank Paint Condition	Good	
658115	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Unknown Operations	0	
658116	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
658117	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Tank Leaks	None	
658118	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
658119	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
658120	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
658121	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
658122	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
658123	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
658124	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
658125	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
658126	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
658127	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
658128	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0440	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	534	
658129	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
658130	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
658131	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
658132	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
658133	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
658134	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
658135	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
658136	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
658137	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
658138	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
658139	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
658140	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
658141	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
658142	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
658143	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
658144	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
658145	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
658146	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
658147	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
658148	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
658149	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
658150	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
658151	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
658152	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
658153	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
658154	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
658155	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
658156	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
658157	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
658158	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
658159	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
658160	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
658161	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
658162	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	18	
658163	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	13.81	%
658164	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	12.19	%
658165	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	11.38	%
658166	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	140.0	
658167	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	140.0	
658168	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
658169	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
658170	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
658171	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
658172	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
658173	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
658174	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
658175	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
658176	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
658177	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
658178	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
658179	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
658180	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
658181	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
658182	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
658183	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
658184	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
658185	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
658186	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
658187	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
658188	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
658189	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
658190	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
658191	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	99988	
658192	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	99992	
658193	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
658194	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
658195	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
658196	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
658197	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
658198	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
658199	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
658200	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	General Comments		
658201	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
658202	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
658203	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
658204	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
658205	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
658206	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
658207	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
658208	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
658209	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
658210	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	General Comments		
658211	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
658212	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC As Found Counter	55130	
658213	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC As Left Counter	55130	
658214	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
658215	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11L	
658216	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	9L	
658217	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	14L	
658218	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	144	
658219	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
658220	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
658221	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
658222	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
658223	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
658224	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
658225	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC As Left Counter	33660	
658226	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
658227	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC Current Tap Position	8L	
658228	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC Max Tap Position	12L	
658229	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC Min Tap Position	15L	
658230	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	21	°C
658231	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	42	°C
658232	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	389	
658233	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
658234	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
658235	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
658236	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
658237	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
658238	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
658239	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
658240	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
658241	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3960.00	kw
658242	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
658243	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
658244	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
658245	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
658246	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	General Comments		
658247	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	General Comments		
658248	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
658249	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
658250	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
658251	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
658252	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
658253	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
658254	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
658255	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
658256	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	689	
658257	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	9 Month Operations	2	
658258	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
658259	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
658260	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
658261	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Amps A Ø	355.0	
658262	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
658263	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
658264	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
658265	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
658266	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
658267	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
658268	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
658269	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
658270	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
658271	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
658272	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Amps B Ø	345.0	
658273	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Amps C Ø	325.0	
658274	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Bushing Condition	Good	
658275	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
658276	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
658277	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
658278	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
658279	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
658280	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
658281	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
658282	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
658283	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
658284	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
658285	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
658286	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Operations A Ø	0	
658287	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Operations B Ø	0	
658288	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Operations C Ø	0	
658289	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Operations Ground	0	
658290	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Follow-up Action Required?	n	
658291	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Follow-up Action Required?	n	
658292	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Foundation Condition	Good	
658293	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	General Comments		
658294	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	General Comments		
658295	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Grounds in Place?	y	
658296	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
658297	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Maintenance Operations	0	
658298	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
658299	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Operations Counter AF	175	
658300	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Operations Counter AL	176	
658301	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
658302	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Switching Operations	1	
658303	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Tank Paint Condition	Good	
658304	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Unknown Operations	0	
658305	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
658306	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
658307	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
658308	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
658309	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
658310	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
658311	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Cabinet Paint Condition	Good	
658312	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
658313	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
658314	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Vegetation	None	
658315	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
658316	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	General Comments		
658317	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
658318	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
658319	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
658320	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
658321	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
658322	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Clear of Trash?	y	
658323	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
658324	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
658325	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
658326	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
658327	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Operations A Ø	0	
658328	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Operations B Ø	0	
658329	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
658330	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
658331	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
658332	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
658333	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
658334	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
658335	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
658336	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	786	
658337	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	786	
658338	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
658339	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
658340	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	General Comments		
658341	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
658342	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
658343	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Pressure Acceptable?	y	
658344	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Oil Levels OK?	y	
658345	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Leaks	None	
658346	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
658347	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
658348	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	General Comments		
658349	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
658350	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
658351	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
658352	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
658353	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
658354	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
658355	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
658356	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
658357	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
658358	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
658359	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	General Comments	fabric is rusty	
658360	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
658361	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
658362	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
658363	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
658364	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
658365	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
658366	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
658367	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
658368	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
658369	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
658370	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
658371	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
658372	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
658373	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
658374	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	B0270	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
658375	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	B0270	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
658376	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
658377	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
658378	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	B0270	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
658379	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	B0270	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
658380	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
658381	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
658382	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
658383	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
658384	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
658385	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
658386	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
658387	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
658388	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
658389	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
658390	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
658391	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
658392	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
658393	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
658394	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
658395	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	General Comments		
658396	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
658397	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
658398	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Foundation Condition	Good	
658399	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
658400	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
658401	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
658402	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
658403	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
658404	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
658405	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
658406	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	General Comments		
658407	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
658408	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC As Found Counter	253574	
658409	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC As Left Counter	253574	
658410	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
658411	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
658412	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
658413	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
658414	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1100	
658415	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
658416	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
658417	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
658418	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
658419	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
658420	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
658421	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
658422	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
658423	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Panels Dusted?	y	
658424	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
658425	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
658426	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
658427	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
658428	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
658429	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Floor Swept?	y	
658430	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
658431	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
658432	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Evidence of Insects	None	
658433	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
658434	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
658435	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
658436	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
658437	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
658438	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
658439	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
658440	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	9 Month Operations	4	
658441	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Accumulated Fault Duty A Ph V	6.11	%
658442	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Accumulated Fault Duty B Ph V	6.11	%
658443	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Accumulated Fault Duty C Ph V	6.11	%
658444	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Amps A Ø	49.0	
658445	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC
658446	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
658447	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
658448	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
658449	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Amps B Ø	30.0	
658450	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Amps C Ø	19.0	
658451	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Bushing Condition	Good	
658452	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
658453	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Bushings Connection/Risers	Good	
658454	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Operations Counter AF	236	
658455	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Moisture and Leak Free?	y	
658456	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Maintenance Operations	0	
658457	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Heaters (All) Functioning?	y	
658458	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Grounds in Place?	y	
658459	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	General Comments		
658460	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	General Comments		
658461	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
658462	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	225.00	
658463	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
658464	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
658465	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
658466	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
658467	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Foundation Condition	Good	
658468	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Follow-up Action Required?	n	
658469	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Follow-up Action Required?	n	
658470	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Operations Ground	0	
658471	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Operations C Ø	0	
658472	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Operations B Ø	0	
658473	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Operations A Ø	0	
658474	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Adjusted Amps C Phase V	0	
658475	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Adjusted Amps B Phase V	0	
658476	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Adjusted Amps A Phase V	0	
658477	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Equipment Properly Labeled?	y	
658478	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Cabinet Paint Condition	Good	
658479	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
658480	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
658481	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
658482	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Bushings Connection/Risers	Good	
658483	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Bushing Condition	Good	
658484	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Amps C Ø	75	
658485	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Amps B Ø	60	
658486	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Amps A Ø	75	
658487	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Accumulated Fault Duty C Ph V	3.09	%
658488	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Accumulated Fault Duty B Ph V	6.17	%
658489	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Accumulated Fault Duty A Ph V	4.63	%
658490	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	9 Month Operations	12	
658491	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	LTCC000369	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
658492	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	LTCC000369	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
658493	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	LTCC000369	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
658494	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	LTCC000369	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
658495	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	LTCC000369	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
658496	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	LTCC000369	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
658497	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	LTCC000369	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
658498	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	LTCC000369	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
658499	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	LTCC000369	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
658500	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Accumulated Fault Duty A Ph V	3.42	%
658501	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	9 Month Operations	9	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
658502	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
658503	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
658504	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
658505	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
658506	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
658507	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
658508	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
658509	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
658510	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
658511	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
658512	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
658513	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
658514	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
658515	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
658516	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
658517	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
658518	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
658519	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
658520	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
658521	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	127	
658522	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
658523	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
658524	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
658525	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Follow-up Action Required?	n	
658526	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
658527	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
658528	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
658529	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Foundation Condition	Good	
658530	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
658531	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
658532	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	General Comments		
658533	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
658534	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
658535	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
658536	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
658537	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
658538	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
658539	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
658540	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
658541	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
658542	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
658543	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
658544	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
658545	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
658546	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
658547	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
658548	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
658549	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
658550	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
658551	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
658552	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
658553	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
658554	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
658555	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
658556	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
658557	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
658558	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
658559	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
658560	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
658561	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
658562	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
658563	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
658564	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
658565	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	All Connections OK?	y	
658566	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	Follow-up Action Required?	n	
658567	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	General Comments		
658568	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	LTC Operation Checked?	y	
658569	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
658570	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
658571	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
658572	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	VRR Time Delay	30	Seconds
658573	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
658574	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
658575	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
658576	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
658577	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
658578	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
658579	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
658580	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
658581	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
658582	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	80.00	
658583	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
658584	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
658585	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
658586	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
658587	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
658588	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
658589	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
658590	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
658591	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
658592	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
658593	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
658594	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
658595	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Unknown Operations	0	
658596	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Tank Paint Condition	Good	
658597	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Switching Operations	4	
658598	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
658599	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Operations Counter AL	240	
658600	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
658601	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
658602	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Unknown Operations	0	
658603	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Tank Paint Condition	Good	
658604	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Switching Operations	1	
658605	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Operations Counter AL	166	
658606	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Operations Counter AF	165	
658607	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
658608	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
658609	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
658610	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
658611	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
658612	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
658613	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Totalizer Meter Reading	.1566	
658614	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
658615	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
658616	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
658617	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
658618	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
658619	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
658620	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
658621	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Oil Temp Present	21	°C
658622	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Oil Temp Max	38	°C
658623	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
658624	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
658625	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	93.96	kw
658626	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
658627	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
658628	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	General Comments		
658629	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	General Comments		
658630	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
658631	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
658632	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
658633	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
658634	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	9 Month Operations	6	
658635	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
658636	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
658637	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
658638	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Amps A Ø	255.0	
658639	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Amps B Ø	215.0	
658640	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Amps C Ø	190.0	
658641	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Bushing Condition	Good	
658642	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Bushings Connection/Risers	Good	
658643	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
658644	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
658645	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
658646	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Cabinet Paint Condition	Good	
658647	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Equipment Properly Labeled?	y	
658648	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
658649	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
658650	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
658651	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
658652	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Operations B Ø	0	
658653	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Operations C Ø	0	
658654	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Operations Ground	0	
658655	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Follow-up Action Required?	n	
658656	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Follow-up Action Required?	n	
658657	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Foundation Condition	Good	
658658	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	General Comments		
658659	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	General Comments		
658660	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Grounds in Place?	y	
658661	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Maintenance Operations	0	
658662	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Moisture and Leak Free?	y	
658663	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Operations Counter AF	174	
658664	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Operations Counter AL	177	
658665	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Switching Operations	3	
658666	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Tank Paint Condition	Good	
658667	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Unknown Operations	0	
658668	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
658669	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
658670	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
658671	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
658672	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
658673	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
658674	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	General Comments		
658675	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
658676	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	General Comments		
658677	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
658678	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	LTC Totalizer Reading	23850.00	kw
658679	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
658680	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
658681	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
658682	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
658683	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
658684	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
658685	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
658686	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
658687	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
658688	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
658689	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Tank Leaks	None	
658690	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Regulator As Left Counter	848902	
658691	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	0.0	volts
658692	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Reg Operation Checked?	n	
658693	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
658694	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
658695	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
658696	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
658697	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	General Comments		
658698	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
658699	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
658700	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
658701	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
658702	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
658703	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
658704	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
658705	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
658706	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
658707	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
658708	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
658709	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
658710	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
658711	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
658712	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
658713	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
658714	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
658715	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
658716	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
658717	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
658718	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
658719	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
658720	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
658721	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
658722	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	270	
658723	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	266	
658724	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
658725	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
658726	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
658727	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
658728	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
658729	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
658730	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
658731	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
658732	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
658733	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
658734	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
658735	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
658736	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
658737	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
658738	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
658739	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
658740	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
658741	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
658742	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
658743	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
658744	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
658745	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
658746	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
658747	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
658748	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
658749	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
658750	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
658751	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
658752	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
658753	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
658754	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
658755	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
658756	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
658757	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	General Comments		
658758	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
658759	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
658760	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
658761	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
658762	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
658763	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
658764	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
658765	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
658766	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
658767	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
658768	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
658769	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Unknown Operations	0	
658770	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Tank Paint Condition	Good	
658771	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Switching Operations	4	
658772	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
658773	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Operations Counter AL	633	
658774	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Operations Counter AF	629	
658775	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Moisture and Leak Free?	y	
658776	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Maintenance Operations	0	
658777	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Grounds in Place?	y	
658778	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	General Comments	BFTC	
658779	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	General Comments		
658780	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
658781	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
658782	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	n	
658783	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
658784	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
658785	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
658786	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Foundation Condition	Good	
658787	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Follow-up Action Required?	n	
658788	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Follow-up Action Required?	n	
658789	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Operations Ground	0	
658790	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Operations C Ø	0	
658791	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Operations B Ø	0	
658792	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
658793	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
658794	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
658795	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
658796	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
658797	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
658798	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
658799	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
658800	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
658801	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
658802	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
658803	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
658804	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
658805	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
658806	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
658807	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
658808	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
658809	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
658810	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
658811	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
658812	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
658813	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
658814	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
658815	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
658816	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
658817	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
658818	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
658819	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Operations B Ø	0	
658820	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Operations A Ø	0	
658821	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
658822	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
658823	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
658824	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	Equipment Properly Labeled?	y	
658825	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Amps C Ø	230.0	
658826	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Amps B Ø	230.0	
658827	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Amps A Ø	250.0	
658828	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
658829	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
658830	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
658831	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	9 Month Operations	0	
658832	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	13	
658833	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	58.24	%
658834	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	60.48	%
658835	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	58.24	%
658836	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
658837	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
658838	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
658839	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
658840	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
658841	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
658842	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
658843	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
658844	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
658845	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
658846	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
658847	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
658848	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Accumulated Fault Duty A Ph V	6.46	%
658849	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	9 Month Operations	5	
658850	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BCH000906	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
658851	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BCH000906	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
658852	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BCH000906	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1	amps
658853	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BCH000906	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
658854	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BCH000906	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
658855	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BCH000906	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
658856	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0806	
658857	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
658858	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	General Comments		
658859	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	Follow-up Action Required?	n	
658860	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	Equipment Properly Labeled?	y	
658861	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
658862	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
658863	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
658864	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
658865	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
658866	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
658867	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
658868	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Oil Temp Present	28	°C
658869	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Oil Temp Max	32	°C
658870	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
658871	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	225.00	
658872	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2593.44	kw
658873	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
658874	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
658875	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
658876	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	General Comments	Added Nitrogen	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
658877	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	General Comments		
658878	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	General Comments		
658879	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
658880	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
658881	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
658882	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
658883	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Tank Leaks	None	
658884	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
658885	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Regulator As Left Counter	156165	
658886	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
658887	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
658888	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
658889	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
658890	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
658891	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
658892	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
658893	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
658894	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
658895	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
658896	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
658897	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
658898	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	General Comments		
658899	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
658900	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
658901	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Vegetation	None	
658902	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
658903	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
658904	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
658905	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
658906	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
658907	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
658908	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
658909	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	65.6	VDC
658910	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	66.4	VDC
658911	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
658912	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
658913	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Foundation Condition	Good	
658914	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
658915	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
658916	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
658917	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
658918	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
658919	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
658920	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
658921	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
658922	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
658923	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
658924	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
658925	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	General Comments		
658926	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
658927	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Operations A Ø	0	
658928	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
658929	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
658930	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
658931	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Equipment Properly Labeled?	y	
658932	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Cabinet Paint Condition	Good	
658933	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
658934	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
658935	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
658936	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Bushings Connection/Risers	Good	
658937	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Bushing Condition	Good	
658938	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Amps C Ø	20.0	
658939	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Amps B Ø	20.0	
658940	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Amps A Ø	20.0	
658941	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Accumulated Fault Duty C Ph V	3.42	%
658942	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Accumulated Fault Duty B Ph V	3.42	%
658943	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
658944	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
658945	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
658946	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
658947	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
658948	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
658949	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
658950	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
658951	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
658952	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
658953	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
658954	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
658955	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
658956	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
658957	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
658958	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
658959	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
658960	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
658961	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
658962	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
658963	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
658964	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
658965	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
658966	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
658967	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
658968	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
658969	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
658970	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
658971	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
658972	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
658973	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
658974	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
658975	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
658976	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
658977	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
658978	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
658979	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
658980	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
658981	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
658982	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
658983	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
658984	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
658985	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
658986	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
658987	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
658988	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
658989	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
658990	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	217	
658991	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	221	
658992	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
658993	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
658994	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
658995	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
658996	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
658997	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
658998	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	General Comments		
658999	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
659000	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
659001	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
659002	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
659003	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
659004	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
659005	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
659006	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
659007	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
659008	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
659009	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
659010	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
659011	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
659012	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
659013	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
659014	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
659015	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Clear of Trash?	y	
659016	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
659017	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
659018	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
659019	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
659020	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
659021	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
659022	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	Oil Temp Present	22	°C
659023	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	Oil Temp Max	38	°C
659024	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
659025	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
659026	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
659027	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
659028	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	General Comments		
659029	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	General Comments		
659030	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
659031	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
659032	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
659033	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
659034	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
659035	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
659036	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
659037	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
659038	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	Follow-up Action Required?	n	
659039	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
659040	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
659041	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
659042	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
659043	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
659044	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
659045	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	Equipment Properly Labeled?	y	
659046	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Unknown Operations	0	
659047	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Tank Paint Condition	Good	
659048	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Switching Operations	4	
659049	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
659050	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Operations Counter AL	236	
659051	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Operations Counter AF	232	
659052	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Moisture and Leak Free?	y	
659053	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Maintenance Operations	0	
659054	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Grounds in Place?	y	
659055	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	General Comments		
659056	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	General Comments		
659057	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Foundation Condition	Good	
659058	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Follow-up Action Required?	n	
659059	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Follow-up Action Required?	n	
659060	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Operations Ground	0	
659061	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Operations C Ø	0	
659062	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Operations B Ø	0	
659063	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Operations A Ø	0	
659064	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
659065	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
659066	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
659067	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Equipment Properly Labeled?	y	
659068	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Cabinet Paint Condition	Good	
659069	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
659070	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
659071	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
659072	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Bushings Connection/Risers	Good	
659073	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Bushing Condition	Good	
659074	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Amps C Ø	60.0	
659075	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Amps B Ø	90.0	
659076	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Amps A Ø	60.0	
659077	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
659078	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
659079	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
659080	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	9 Month Operations	8	
659081	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
659082	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Vegetation	None	
659083	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
659084	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
659085	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	General Comments		
659086	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
659087	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
659088	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	BCH000390	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
659089	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	BCH000390	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
659090	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	BCH000390	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
659091	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	BCH000390	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
659092	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Vegetation	None	
659093	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
659094	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Operations Counter AF	343	
659095	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Operations Counter AL	344	
659096	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
659097	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Switching Operations	1	
659098	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Tank Paint Condition	Good	
659099	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Unknown Operations	0	
659100	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
659101	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
659102	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
659103	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
659104	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	General Comments		
659105	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
659106	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
659107	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
659108	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
659109	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
659110	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
659111	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
659112	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
659113	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
659114	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
659115	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Totalizer Meter Reading	1.3250	
659116	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Winding Temp Max	105	°C
659117	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Winding Temp Present	45	°C
659118	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	85.00	
659119	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
659120	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
659121	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
659122	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
659123	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.0	amps
659124	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
659125	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
659126	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	General Comments		
659127	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
659128	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
659129	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
659130	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	Seeping	
659131	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
659132	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	Follow-up Action Required?	n	
659133	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
659134	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	General Comments		
659135	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	General Comments		
659136	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC As Found Counter	16273	
659137	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC As Left Counter	16273	
659138	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
659139	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC Current Tap Position	4L	
659140	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC Max Tap Position	2L	
659141	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC Min Tap Position	12L	
659142	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	42	°C
659143	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	17	°C
659144	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC Operations Since Last Insp	440	
659145	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
659146	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
659147	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
659148	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
659149	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
659150	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
659151	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
659152	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
659153	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
659154	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
659155	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
659156	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
659157	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
659158	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	General Comments		
659159	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
659160	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
659161	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Foundation Condition	Good	
659162	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
659163	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
659164	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
659165	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
659166	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
659167	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
659168	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
659169	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
659170	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
659171	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
659172	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
659173	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	Oil Temp Present	22	°C
659174	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	Oil Temp Max	38	°C
659175	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
659176	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
659177	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
659178	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
659179	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	General Comments	Oil leak around oil temp gauge. Needs replaced.	
659180	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	General Comments		
659181	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
659182	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
659183	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	General Comments		
659184	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
659185	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
659186	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Clear of Trash?	y	
659187	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
659188	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
659189	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
659190	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
659191	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
659192	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	General Comments		
659193	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
659194	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Vegetation	None	
659195	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
659196	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	9 Month Operations	8	
659197	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Accumulated Fault Duty A Ph V	8.61	%
659198	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Accumulated Fault Duty B Ph V	8.61	%
659199	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Accumulated Fault Duty C Ph V	5.74	%
659200	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Amps A Ø	140.0	
659201	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Amps B Ø	130.0	
659202	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	General Comments		
659203	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	Follow-up Action Required?	n	
659204	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	Equipment Properly Labeled?	y	
659205	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Amps C Ø	135.0	
659206	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Patrol Inspection	Equipment Properly Labeled?	y	
659207	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
659208	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
659209	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
659210	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
659211	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	77990	
659212	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
659213	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
659214	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
659215	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
659216	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
659217	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	9L	
659218	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	9L	
659219	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
659220	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
659221	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
659222	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
659223	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	98	
659224	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
659225	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
659226	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
659227	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
659228	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
659229	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
659230	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
659231	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
659232	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Operations A Ø	0	
659233	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Operations B Ø	0	
659234	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Operations C Ø	0	
659235	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
659236	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
659237	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
659238	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
659239	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
659240	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
659241	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	9L	
659242	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
659243	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
659244	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
659245	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
659246	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
659247	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
659248	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
659249	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
659250	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
659251	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
659252	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
659253	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
659254	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
659255	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
659256	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
659257	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Clear of Trash?	y	
659258	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
659259	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
659260	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Ambient Temp	41	°F
659261	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
659262	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
659263	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
659264	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
659265	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
659266	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Clear of Trash?	y	
659267	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
659268	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
659269	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
659270	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	BCH000390	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
659271	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	BCH000390	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
659272	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
659273	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	43	°F
659274	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
659275	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
659276	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
659277	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
659278	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	General Comments		
659279	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
659280	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
659281	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
659282	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
659283	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
659284	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
659285	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
659286	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
659287	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
659288	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
659289	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
659290	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
659291	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
659292	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	General Comments		
659293	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	Follow-up Action Required?	n	
659294	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	Equipment Properly Labeled?	y	
659295	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
659296	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
659297	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
659298	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
659299	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
659300	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
659301	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
659302	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
659303	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
659304	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
659305	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
659306	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
659307	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
659308	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
659309	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	General Comments		
659310	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
659311	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
659312	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	18.0	VDC
659313	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	24.0	VDC
659314	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
659315	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
659316	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
659317	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
659318	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Reg Operation Checked?	n	
659319	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	0.0	volts
659320	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Regulator As Left Counter	10332	
659321	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Tank Leaks	None	
659322	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
659323	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Patrol Inspection	General Comments		
659324	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Patrol Inspection	Follow-up Action Required?	n	
659325	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Patrol Inspection	Equipment Properly Labeled?	y	
659326	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
659327	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
659328	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
659329	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
659330	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
659331	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
659332	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
659333	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
659334	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
659335	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
659336	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
659337	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
659338	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Cabinet Paint Condition	Good	
659339	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
659340	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
659341	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
659342	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
659343	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
659344	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
659345	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
659346	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Equipment Properly Labeled?	y	
659347	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
659348	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
659349	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
659350	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Operations A Ø	0	
659351	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Operations B Ø	0	
659352	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Operations C Ø	0	
659353	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Operations Ground	0	
659354	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BCH000376	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
659355	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BCH000376	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
659356	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BCH000376	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
659357	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BCH000376	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
659358	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BCH000376	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
659359	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BCH000376	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
659360	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	General Comments		
659361	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	General Comments		
659362	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC As Found Counter	326569	
659363	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC As Left Counter	326569	
659364	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
659365	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC Current Tap Position	2L	
659366	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC Max Tap Position	1R	
659367	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC Min Tap Position	8L	
659368	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC Operations Since Last Insp	273	
659369	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
659370	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
659371	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Follow-up Action Required?	n	
659372	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Follow-up Action Required?	n	
659373	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Foundation Condition	Good	
659374	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	General Comments		
659375	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
659376	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	General Comments		
659377	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Grounds in Place?	y	
659378	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Heaters (All) Functioning?	y	
659379	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Maintenance Operations	0	
659380	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Moisture and Leak Free?	y	
659381	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Operations Counter AF	185	
659382	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Operations Counter AL	187	
659383	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
659384	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Switching Operations	2	
659385	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Tank Paint Condition	Good	
659386	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Unknown Operations	0	
659387	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
659388	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
659389	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
659390	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
659391	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
659392	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Top Oil Temperature Max	100	°C
659393	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Top Oil Temperature Present	40	°C
659394	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
659395	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
659396	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Maintenance Operations	0	
659397	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
659398	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	VRR Time Delay	60	Seconds
659399	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
659400	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
659401	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
659402	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
659403	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
659404	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
659405	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
659406	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
659407	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
659408	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
659409	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
659410	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
659411	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
659412	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
659413	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
659414	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	General Comments		
659415	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	General Comments		
659416	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
659417	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
659418	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
659419	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
659420	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5103.36	kw
659421	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50	
659422	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45	
659423	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
659424	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Oil Temp Present	39	°C
659425	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
659426	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
659427	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
659428	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
659429	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
659430	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
659431	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
659432	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
659433	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5316	
659434	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
659435	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
659436	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
659437	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
659438	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
659439	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
659440	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
659441	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
659442	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
659443	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
659444	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
659445	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
659446	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
659447	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
659448	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
659449	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
659450	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
659451	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
659452	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
659453	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
659454	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	240.0	
659455	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	200.0	
659456	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	150.0	
659457	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.47	%
659458	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.47	%
659459	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.47	%
659460	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
659461	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	9 Month Operations	12	
659462	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Accumulated Fault Duty A Ph V	2.00	%
659463	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Accumulated Fault Duty B Ph V	2.00	%
659464	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Accumulated Fault Duty C Ph V	1.00	%
659465	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	Follow-up Action Required?	n	
659466	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
659467	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Amps A Ø	135.0	
659468	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Amps B Ø	115.0	
659469	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Amps C Ø	150.0	
659470	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Bushing Condition	Good	
659471	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
659472	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	43	°F
659473	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
659474	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Bushings Connection/Risers	Good	
659475	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
659476	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Heaters (All) Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
659477	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Maintenance Operations	0	
659478	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Moisture and Leak Free?	y	
659479	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
659480	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	LTC Totalizer Reading	440.64	kw
659481	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
659482	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	General Comments		
659483	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	General Comments		
659484	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	Follow-up Action Required?	n	
659485	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
659486	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	General Comments		
659487	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	General Comments		
659488	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC As Found Counter	15334	
659489	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
659490	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
659491	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Follow-up Action Required?	n	
659492	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
659493	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
659494	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
659495	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC As Left Counter	15334	
659496	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
659497	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC Current Tap Position	3L	
659498	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
659499	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
659500	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
659501	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
659502	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC Min Tap Position	12L	
659503	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	41	°C
659504	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	16	°C
659505	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC Operations Since Last Insp	454	
659506	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
659507	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
659508	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
659509	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
659510	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
659511	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
659512	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
659513	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
659514	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
659515	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
659516	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
659517	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
659518	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
659519	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
659520	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Bushing Condition	Good	
659521	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Amps C Ø	119.0	
659522	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Amps B Ø	256.0	
659523	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Amps A Ø	270.0	
659524	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
659525	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	General Comments		
659526	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	Follow-up Action Required?	n	
659527	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	Equipment Properly Labeled?	y	
659528	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
659529	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
659530	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
659531	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	9 Month Operations	1	
659532	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
659533	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	39	°F
659534	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
659535	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
659536	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
659537	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
659538	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	35	°C
659539	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	25	°C
659540	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	39	°C
659541	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	25	°C
659542	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	40	°C
659543	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	21	°C
659544	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
659545	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
659546	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
659547	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
659548	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	General Comments		
659549	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	LTC Operation Checked?	y	
659550	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	General Comments		
659551	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
659552	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	All Connections OK?	y	
659553	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	General Comments		
659554	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
659555	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
659556	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
659557	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
659558	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Oil Temp Max	42	°C
659559	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Oil Temp Present	24	°C
659560	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
659561	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
659562	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Grounds in Place?	y	
659563	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	General Comments		
659564	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	General Comments		
659565	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Foundation Condition	Good	
659566	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Follow-up Action Required?	n	
659567	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Follow-up Action Required?	n	
659568	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Operations Ground	0	
659569	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Operations C Ø	0	
659570	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Operations B Ø	0	
659571	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Operations A Ø	0	
659572	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
659573	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
659574	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
659575	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
659576	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
659577	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
659578	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
659579	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
659580	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
659581	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
659582	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
659583	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
659584	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Totalizer Meter Reading	.1836	
659585	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
659586	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
659587	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
659588	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
659589	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
659590	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
659591	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
659592	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Oil Temp Present	36	°C
659593	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Oil Temp Max	47	°C
659594	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
659595	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	9 Month Operations	2	
659596	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Accumulated Fault Duty A Ph V	2.29	%
659597	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Accumulated Fault Duty B Ph V	2.29	%
659598	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Accumulated Fault Duty C Ph V	1.83	%
659599	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Amps A Ø	80.0	
659600	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Amps B Ø	80.0	
659601	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Amps C Ø	80.0	
659602	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Bushing Condition	Good	
659603	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Bushings Connection/Risers	Good	
659604	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
659605	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
659606	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
659607	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Cabinet Paint Condition	Good	
659608	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Equipment Properly Labeled?	y	
659609	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
659610	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
659611	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
659612	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Operations A Ø	0	
659613	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Operations B Ø	0	
659614	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Operations C Ø	0	
659615	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Operations Ground	0	
659616	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Follow-up Action Required?	n	
659617	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Follow-up Action Required?	n	
659618	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Foundation Condition	Good	
659619	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	General Comments		
659620	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	General Comments		
659621	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Grounds in Place?	y	
659622	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Follow-up Action Required?	n	
659623	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Follow-up Action Required?	n	
659624	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Operations Ground	0	
659625	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Operations C Ø	0	
659626	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
659627	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Operations A Ø	0	
659628	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
659629	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
659630	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
659631	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Equipment Properly Labeled?	y	
659632	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Cabinet Paint Condition	Good	
659633	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
659634	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
659635	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
659636	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Bushings Connection/Risers	Good	
659637	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Bushing Condition	Good	
659638	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Amps C Ø	119.0	
659639	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Amps B Ø	256.0	
659640	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Amps A Ø	270.0	
659641	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
659642	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
659643	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
659644	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	9 Month Operations	2	
659645	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
659646	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
659647	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
659648	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
659649	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
659650	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
659651	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
659652	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
659653	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
659654	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
659655	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	205.00	
659656	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
659657	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	Oil Temp Max	50	°C
659658	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	Oil Temp Present	30	°C
659659	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
659660	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
659661	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
659662	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
659663	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
659664	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
659665	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
659666	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
659667	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	PF000177	PowerFuse	HN-12KV SEC 1 BUS POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
659668	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
659669	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
659670	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
659671	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
659672	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
659673	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
659674	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
659675	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
659676	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	PF000177	PowerFuse	HN-12KV SEC 1 BUS POTS	Disconnect Powerfuse Inspection	General Comments	OK	
659677	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	Replaced Bottle	
659678	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
659679	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
659680	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
659681	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
659682	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
659683	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
659684	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
659685	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
659686	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
659687	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
659688	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
659689	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	34	
659690	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	38	
659691	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
659692	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
659693	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
659694	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
659695	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
659696	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Operations A Ø	0	
659697	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Operations B Ø	0	
659698	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Operations C Ø	0	
659699	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
659700	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
659701	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
659702	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
659703	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
659704	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
659705	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
659706	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
659707	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
659708	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
659709	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
659710	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
659711	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Follow-up Action Required?	n	
659712	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
659713	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
659714	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	General Comments		
659715	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	General Comments	1 bad fan on bank 2	
659716	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
659717	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	LTC Totalizer Reading	6580.80	kw
659718	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
659719	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
659720	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
659721	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Oil Temp Max	38	°C
659722	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Oil Temp Present	22	°C
659723	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
659724	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
659725	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
659726	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
659727	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
659728	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
659729	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
659730	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
659731	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Totalizer Meter Reading	.4570	
659732	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Winding Temp Max	40	°C
659733	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Winding Temp Present	22	°C
659734	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
659735	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Operations Ground	0	
659736	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	General Comments		
659737	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Foundation Condition	Good	
659738	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
659739	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Patrol Inspection	Follow-up Action Required?	n	
659740	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Patrol Inspection	General Comments		
659741	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
659742	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
659743	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Tank Leaks	None	
659744	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Foundation Condition	Good	
659745	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	General Comments		
659746	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	General Comments		
659747	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Grounds in Place?	y	
659748	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Heaters (All) Functioning?	y	
659749	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Maintenance Operations	0	
659750	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Moisture and Leak Free?	y	
659751	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Unknown Operations	0	
659752	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Tank Paint Condition	Good	
659753	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Switching Operations	2	
659754	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Operations Counter AL	161	
659755	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Operations Counter AF	159	
659756	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
659757	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Maintenance Operations	0	
659758	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Grounds in Place?	y	
659759	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	General Comments		
659760	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	General Comments		
659761	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Foundation Condition	Good	
659762	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Follow-up Action Required?	n	
659763	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Follow-up Action Required?	n	
659764	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Fault Operations Ground	0	
659765	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Fault Operations C Ø	0	
659766	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Fault Operations B Ø	0	
659767	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Fault Operations A Ø	0	
659768	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
659769	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
659770	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
659771	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
659772	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
659773	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
659774	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
659775	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
659776	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
659777	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Bushing Condition	Good	
659778	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Amps C Ø	0.0	
659779	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Amps B Ø	0.0	
659780	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Amps A Ø	0.0	
659781	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
659782	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
659783	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
659784	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	9 Month Operations	5	
659785	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Operations Counter AF	240	
659786	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Operations Counter AL	241	
659787	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
659788	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Switching Operations	1	
659789	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Tank Paint Condition	Good	
659790	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Unknown Operations	0	
659791	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Regulator As Left Counter	424080	
659792	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	0.0	volts
659793	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Reg Operation Checked?	n	
659794	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
659795	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
659796	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2200	psi
659797	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
659798	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
659799	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
659800	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
659801	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
659802	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
659803	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
659804	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
659805	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
659806	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
659807	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
659808	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
659809	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
659810	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
659811	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
659812	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Unknown Operations	0	
659813	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Tank Paint Condition	Good	
659814	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Switching Operations	1	
659815	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Operations Counter AL	162	
659816	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Operations Counter AF	161	
659817	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
659818	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Maintenance Operations	0	
659819	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Grounds in Place?	y	
659820	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	General Comments		
659821	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	General Comments		
659822	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Foundation Condition	Good	
659823	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Follow-up Action Required?	n	
659824	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Follow-up Action Required?	n	
659825	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Fault Operations Ground	0	
659826	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Fault Operations C Ø	0	
659827	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Fault Operations B Ø	0	
659828	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Fault Operations A Ø	0	
659829	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
659830	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
659831	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
659832	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
659833	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
659834	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
659835	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
659836	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
659837	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
659838	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Bushing Condition	Good	
659839	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Amps C Ø	283.0	
659840	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Amps B Ø	276.0	
659841	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Amps A Ø	302.0	
659842	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
659843	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
659844	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
659845	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	9 Month Operations	1	
659846	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Follow-up Action Required?	n	
659847	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Follow-up Action Required?	n	
659848	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	32	
659849	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
659850	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	211	
659851	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	247	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
659852	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
659853	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
659854	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
659855	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
659856	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
659857	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
659858	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	VRR Time Delay	30	Seconds
659859	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
659860	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
659861	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
659862	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Grounds in Place?	y	
659863	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	General Comments		
659864	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	General Comments		
659865	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Foundation Condition	Good	
659866	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Follow-up Action Required?	n	
659867	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Follow-up Action Required?	n	
659868	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Operations Ground	0	
659869	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Operations C Ø	0	
659870	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Operations B Ø	0	
659871	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Operations A Ø	0	
659872	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
659873	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
659874	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
659875	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Equipment Properly Labeled?	y	
659876	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
659877	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	LTC Operation Checked?	y	
659878	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	General Comments		
659879	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	Follow-up Action Required?	n	
659880	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	All Connections OK?	y	
659881	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Cabinet Paint Condition	Good	
659882	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
659883	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
659884	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
659885	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Bushings Connection/Risers	Good	
659886	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Bushing Condition	Good	
659887	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Amps C Ø	120.0	
659888	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Amps B Ø	120.0	
659889	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Amps A Ø	120.0	
659890	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Accumulated Fault Duty C Ph V	5.01	%
659891	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Accumulated Fault Duty B Ph V	5.01	%
659892	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Accumulated Fault Duty A Ph V	9.01	%
659893	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	9 Month Operations	11	
659894	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
659895	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Unknown Operations	0	
659896	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Tank Paint Condition	Good	
659897	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Switching Operations	1	
659898	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
659899	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Operations Counter AL	123	
659900	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Operations Counter AF	122	
659901	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
659902	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
659903	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
659904	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Moisture and Leak Free?	y	
659905	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Maintenance Operations	0	
659906	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Heaters (All) Functioning?	y	
659907	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Grounds in Place?	y	
659908	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	General Comments		
659909	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LTCC000099	LTCControl	HK-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
659910	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LTCC000099	LTCControl	HK-TRANS 3	LTC Control Insp	General Comments		
659911	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LTCC000099	LTCControl	HK-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
659912	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
659913	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
659914	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
659915	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
659916	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
659917	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Current Tap Position	3L	
659918	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
659919	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
659920	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
659921	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
659922	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	General Comments		
659923	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
659924	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Max Tap Position	2R	
659925	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Min Tap Position	7L	
659926	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
659927	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
659928	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
659929	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
659930	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
659931	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Tank Paint Condition	Good	
659932	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Unknown Operations	0	
659933	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
659934	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
659935	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
659936	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	65.00	
659937	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
659938	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
659939	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
659940	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
659941	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Regulator As Left Counter	134544	
659942	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
659943	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
659944	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Tank Leaks	None	
659945	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
659946	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
659947	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Clear of Trash?	y	
659948	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
659949	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Ambient Temp	41	°F
659950	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
659951	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	General Comments		
659952	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
659953	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
659954	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
659955	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
659956	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
659957	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
659958	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
659959	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
659960	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
659961	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
659962	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
659963	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
659964	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
659965	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
659966	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
659967	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
659968	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
659969	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
659970	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Amps B Ø	76.0	
659971	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Amps A Ø	92.0	
659972	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Accumulated Fault Duty C Ph V	1.93	%
659973	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Accumulated Fault Duty B Ph V	2.57	%
659974	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Accumulated Fault Duty A Ph V	1.61	%
659975	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	9 Month Operations	4	
659976	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
659977	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
659978	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	PF000180	PowerFuse	HL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
659979	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	PF000180	PowerFuse	HL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
659980	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
659981	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
659982	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
659983	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
659984	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	14.01	%
659985	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	200.0	
659986	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	200.0	
659987	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	200.0	
659988	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Patrol Inspection	General Comments		
659989	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Patrol Inspection	Follow-up Action Required?	n	
659990	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
659991	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	43	
659992	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Cabinet Paint Condition	Good	
659993	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Equipment Properly Labeled?	y	
659994	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
659995	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
659996	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
659997	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.98	%
659998	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
659999	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
660000	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	150.0	
660001	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
660002	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
660003	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
660004	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
660005	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
660006	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
660007	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	150.0	
660008	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
660009	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
660010	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
660011	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
660012	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
660013	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
660014	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
660015	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
660016	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
660017	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
660018	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
660019	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
660020	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
660021	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
660022	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
660023	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
660024	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
660025	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
660026	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	General Comments		
660027	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	General Comments		
660028	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LTCC000099	LTCControl	HK-TRANS 3	LTC Control Insp	All Connections OK?	y	
660029	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	9 Month Operations	2	
660030	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Accumulated Fault Duty A Ph V	.47	%
660031	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
660032	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
660033	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Amps A Ø	185.0	
660034	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Amps B Ø	160.0	
660035	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
660036	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	11.01	%
660037	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
660038	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Amps C Ø	135.0	
660039	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Bushing Condition	Good	
660040	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
660041	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
660042	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
660043	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Bushings Connection/Risers	Good	
660044	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
660045	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
660046	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
660047	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Patrol Inspection	Follow-up Action Required?	n	
660048	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Patrol Inspection	General Comments		
660049	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
660050	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
660051	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	9.01	%
660052	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
660053	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
660054	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
660055	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
660056	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
660057	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
660058	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Unknown Operations	0	
660059	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Tank Paint Condition	Good	
660060	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Switching Operations	1	
660061	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Operations Counter AL	213	
660062	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Operations Counter AF	212	
660063	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Moisture and Leak Free?	y	
660064	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Maintenance Operations	0	
660065	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Grounds in Place?	y	
660066	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	General Comments		
660067	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	General Comments		
660068	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Foundation Condition	Good	
660069	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Follow-up Action Required?	n	
660070	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Follow-up Action Required?	n	
660071	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Operations Ground	0	
660072	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Operations C Ø	0	
660073	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Operations B Ø	0	
660074	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Operations A Ø	1	
660075	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
660076	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
660077	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Adjusted Amps A Phase V	4.31	
660078	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Equipment Properly Labeled?	y	
660079	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Cabinet Paint Condition	Good	
660080	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
660081	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
660082	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
660083	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Bushings Connection/Risers	Good	
660084	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Bushing Condition	Good	
660085	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Amps C Ø	67.0	
660086	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Foundation Condition	Good	
660087	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Follow-up Action Required?	n	
660088	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Follow-up Action Required?	n	
660089	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Operations Ground	0	
660090	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Operations C Ø	0	
660091	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Operations B Ø	0	
660092	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Operations A Ø	0	
660093	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
660094	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Clear of Trash?	y	
660095	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
660096	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
660097	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
660098	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
660099	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
660100	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
660101	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Equipment Properly Labeled?	y	
660102	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Cabinet Paint Condition	Good	
660103	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
660104	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
660105	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
660106	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Bushings Connection/Risers	Good	
660107	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Bushing Condition	Good	
660108	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Amps C Ø	13.0	
660109	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Amps B Ø	15.0	
660110	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Amps A Ø	6.0	
660111	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Accumulated Fault Duty C Ph V	1.40	%
660112	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Accumulated Fault Duty B Ph V	1.40	%
660113	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
660114	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	9 Month Operations	10	
660115	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
660116	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
660117	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
660118	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
660119	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
660120	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
660121	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
660122	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
660123	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
660124	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
660125	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
660126	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
660127	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
660128	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Unknown Operations	0	
660129	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Trash Emptied?	y	
660130	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Moisture and Leak Free?	y	
660131	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	General Comments		
660132	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
660133	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Follow-up Action Required?	n	
660134	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Floor Swept?	y	
660135	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
660136	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
660137	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Evidence of Insects	None	
660138	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Doors and Locks Secure?	y	
660139	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
660140	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Control House Lighting OK?	y	
660141	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Broom on Site?	y	
660142	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
660143	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
660144	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Operations Counter AF	186	
660145	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Moisture and Leak Free?	y	
660146	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Maintenance Operations	2	
660147	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Grounds in Place?	y	
660148	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	General Comments		
660149	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	General Comments		
660150	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Foundation Condition	Good	
660151	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
660152	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Follow-up Action Required?	n	
660153	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Operations Ground	0	
660154	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Operations C Ø	0	
660155	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Operations B Ø	0	
660156	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Operations A Ø	0	
660157	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Adjusted Amps C Phase V	6.27	
660158	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Adjusted Amps B Phase V	6.27	
660159	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Adjusted Amps A Phase V	6.27	
660160	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Equipment Properly Labeled?	y	
660161	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Cabinet Paint Condition	Good	
660162	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
660163	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
660164	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
660165	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Bushings Connection/Risers	Good	
660166	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Bushing Condition	Good	
660167	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Amps C Ø	97.0	
660168	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Amps B Ø	105.0	
660169	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Amps A Ø	139.0	
660170	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Accumulated Fault Duty C Ph V	1.40	%
660171	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Accumulated Fault Duty B Ph V	1.40	%
660172	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Accumulated Fault Duty A Ph V	1.40	%
660173	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	9 Month Operations	5	
660174	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
660175	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
660176	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	30	°C
660177	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
660178	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
660179	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
660180	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	9 Month Operations	2	
660181	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Accumulated Fault Duty A Ph V	2.44	%
660182	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Accumulated Fault Duty B Ph V	2.93	%
660183	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Accumulated Fault Duty C Ph V	2.93	%
660184	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Amps A Ø	200.0	
660185	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Amps B Ø	200.0	
660186	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Amps C Ø	200.0	
660187	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Bushing Condition	Good	
660188	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Bushings Connection/Risers	Good	
660189	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Unknown Operations	0	
660190	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Tank Paint Condition	Good	
660191	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Switching Operations	0	
660192	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Operations Counter AL	208	
660193	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Operations Counter AF	206	
660194	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Moisture and Leak Free?	y	
660195	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Maintenance Operations	2	
660196	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Grounds in Place?	y	
660197	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
660198	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
660199	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
660200	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	General Comments		
660201	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	General Comments		
660202	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Amps C Ø	24.0	
660203	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Amps B Ø	12.0	
660204	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Amps A Ø	11.0	
660205	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
660206	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
660207	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
660208	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	9 Month Operations	4	
660209	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
660210	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	General Comments		
660211	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
660212	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
660213	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
660214	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
660215	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Min Tap Position	16L	
660216	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
660217	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
660218	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
660219	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
660220	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
660221	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Regulator As Left Counter	29358	
660222	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
660223	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
660224	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Tank Leaks	None	
660225	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
660226	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
660227	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Cabinet Paint Condition	Good	
660228	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Equipment Properly Labeled?	y	
660229	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
660230	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
660231	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
660232	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Operations A Ø	0	
660233	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Operations B Ø	0	
660234	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
660235	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Operations C Ø	0	
660236	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Operations Ground	0	
660237	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Follow-up Action Required?	n	
660238	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Follow-up Action Required?	n	
660239	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Foundation Condition	Good	
660240	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	General Comments		
660241	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	General Comments		
660242	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Grounds in Place?	y	
660243	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Heaters (All) Functioning?	y	
660244	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Maintenance Operations	0	
660245	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Moisture and Leak Free?	y	
660246	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Operations Counter AF	436	
660247	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Operations Counter AL	437	
660248	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
660249	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Switching Operations	1	
660250	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
660251	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
660252	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
660253	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
660254	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
660255	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
660256	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
660257	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	General Comments		
660258	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
660259	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
660260	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Unknown Operations	0	
660261	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Switching Operations	0	
660262	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Operations Counter AL	419	
660263	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Operations Counter AF	419	
660264	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Maintenance Operations	0	
660265	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
660266	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	General Comments		
660267	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
660268	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
660269	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
660270	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
660271	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
660272	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	Oil Temp Present	31	°C
660273	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	Oil Temp Max	33	°C
660274	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
660275	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
660276	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
660277	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	General Comments		
660278	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
660279	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
660280	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
660281	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
660282	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
660283	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
660284	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
660285	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
660286	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Tank Paint Condition	Good	
660287	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Switching Operations	0	
660288	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Operations Counter AL	199	
660289	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Operations Counter AF	197	
660290	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Moisture and Leak Free?	y	
660291	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Maintenance Operations	2	
660292	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Grounds in Place?	y	
660293	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	General Comments		
660294	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	General Comments		
660295	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Foundation Condition	Good	
660296	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Follow-up Action Required?	n	
660297	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Follow-up Action Required?	n	
660298	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Operations Ground	0	
660299	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Operations C Ø	0	
660300	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Operations B Ø	0	
660301	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
660302	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
660303	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
660304	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
660305	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
660306	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
660307	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
660308	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
660309	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
660310	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
660311	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Equipment Properly Labeled?	y	
660312	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Cabinet Paint Condition	Good	
660313	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
660314	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
660315	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
660316	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Bushings Connection/Risers	Good	
660317	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Bushing Condition	Good	
660318	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC Max Tap Position	2L	
660319	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC Min Tap Position	14L	
660320	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
660321	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
660322	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC Operations Since Last Insp	234	
660323	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
660324	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
660325	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
660326	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
660327	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	9 Month Operations	0	
660328	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
660329	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
660330	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
660331	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Amps A Ø	400.0	
660332	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Amps B Ø	350.0	
660333	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Amps C Ø	550.0	
660334	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
660335	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
660336	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
660337	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
660338	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
660339	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
660340	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
660341	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Operations Ground	0	
660342	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
660343	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
660344	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
660345	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments	MFD breather not connected	
660346	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
660347	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
660348	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
660349	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	MFD Breather green light	NotOK	
660350	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
660351	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Unknown Operations	0	
660352	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	18.74	%
660353	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	20.82	%
660354	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	10.41	%
660355	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	280.0	
660356	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	290.0	
660357	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Tank Paint Condition	Good	
660358	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	340.0	
660359	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
660360	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
660361	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
660362	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
660363	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
660364	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
660365	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
660366	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
660367	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
660368	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
660369	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Switching Operations	2	
660370	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
660371	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Operations Counter AL	241	
660372	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Operations Counter AF	239	
660373	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Moisture and Leak Free?	y	
660374	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Maintenance Operations	0	
660375	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Heaters (All) Functioning?	y	
660376	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
660377	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	General Comments		
660378	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
660379	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
660380	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
660381	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
660382	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
660383	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
660384	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
660385	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
660386	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
660387	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	Follow-up Action Required?	n	
660388	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
660389	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	General Comments		
660390	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	General Comments		
660391	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC As Found Counter	5818	
660392	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC As Left Counter	5818	
660393	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
660394	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	13	
660395	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Unknown Operations	0	
660396	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Tank Paint Condition	Good	
660397	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Switching Operations	1	
660398	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Operations Counter AL	157	
660399	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Operations Counter AF	156	
660400	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
660401	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Maintenance Operations	0	
660402	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Grounds in Place?	y	
660403	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	General Comments		
660404	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	General Comments		
660405	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Foundation Condition	Good	
660406	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Follow-up Action Required?	n	
660407	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Follow-up Action Required?	n	
660408	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
660409	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Vegetation	None	
660410	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
660411	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	General Comments		
660412	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Operations Ground	0	
660413	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Operations C Ø	0	
660414	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Operations B Ø	0	
660415	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Operations A Ø	0	
660416	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
660417	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
660418	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
660419	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
660420	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
660421	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
660422	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
660423	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
660424	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
660425	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Bushing Condition	Good	
660426	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Amps C Ø	165.0	
660427	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Amps B Ø	183.0	
660428	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Amps A Ø	153.0	
660429	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
660430	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
660431	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
660432	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	9 Month Operations	2	
660433	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC Current Tap Position	6L	
660434	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
660435	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	9 Month Operations	5	
660436	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Patrol Inspection	General Comments		
660437	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	General Comments		
660438	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Maintenance Operations	0	
660439	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Operations Counter AF	157	
660440	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Operations Counter AL	157	
660441	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Switching Operations	0	
660442	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Bushing Condition	Good	
660443	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Amps C Ø	0.0	
660444	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Amps B Ø	0.0	
660445	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Amps A Ø	0.0	
660446	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
660447	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	All Connections OK?	y	
660448	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Unknown Operations	0	
660449	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
660450	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	Follow-up Action Required?	n	
660451	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
660452	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	General Comments		
660453	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	LTC Operation Checked?	y	
660454	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
660455	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
660456	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
660457	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	VRR Time Delay	30	Seconds
660458	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
660459	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Accumulated Fault Duty A Ph V	.93	%
660460	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	9 Month Operations	4	
660461	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
660462	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	General Comments		
660463	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	General Comments		
660464	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC As Found Counter	589858	
660465	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC As Left Counter	589858	
660466	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
660467	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC Current Tap Position	9L	
660468	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC Max Tap Position	5L	
660469	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC Min Tap Position	15L	
660470	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
660471	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC Operations Since Last Insp	200	
660472	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
660473	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
660474	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
660475	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
660476	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
660477	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
660478	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
660479	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
660480	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
660481	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
660482	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
660483	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	82	
660484	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	87	
660485	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
660486	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
660487	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
660488	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Unknown Operations	1	
660489	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Tank Paint Condition	Good	
660490	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Switching Operations	0	
660491	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Operations Counter AL	188	
660492	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
660493	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
660494	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
660495	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
660496	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Unknown Operations	0	
660497	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Tank Paint Condition	Good	
660498	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Switching Operations	0	
660499	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Operations Counter AL	182	
660500	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Operations Counter AF	180	
660501	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Moisture and Leak Free?	y	
660502	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Maintenance Operations	2	
660503	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Grounds in Place?	y	
660504	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	General Comments		
660505	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Grounds in Place?	y	
660506	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	General Comments		
660507	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Foundation Condition	Good	
660508	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Follow-up Action Required?	n	
660509	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Follow-up Action Required?	n	
660510	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	General Comments		
660511	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	General Comments		
660512	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Foundation Condition	Good	
660513	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Follow-up Action Required?	n	
660514	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Follow-up Action Required?	n	
660515	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Operations Ground	0	
660516	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Operations C Ø	0	
660517	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Operations B Ø	0	
660518	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Operations A Ø	0	
660519	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
660520	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
660521	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
660522	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Equipment Properly Labeled?	y	
660523	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Cabinet Paint Condition	Good	
660524	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
660525	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
660526	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
660527	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Bushings Connection/Risers	Good	
660528	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Operations Ground	0	
660529	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Operations C Ø	0	
660530	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Operations B Ø	0	
660531	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Operations A Ø	0	
660532	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
660533	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
660534	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
660535	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
660536	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
660537	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
660538	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
660539	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Equipment Properly Labeled?	y	
660540	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Cabinet Paint Condition	Good	
660541	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
660542	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
660543	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
660544	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Bushings Connection/Risers	Good	
660545	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Bushing Condition	Good	
660546	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Amps C Ø	162.0	
660547	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Amps B Ø	159.0	
660548	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Amps A Ø	151.0	
660549	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
660550	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
660551	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Operations Ground	2	
660552	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Operations Ground	0	
660553	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Patrol Inspection	Follow-up Action Required?	n	
660554	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Follow-up Action Required?	n	
660555	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Operations C Ø	0	
660556	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Operations B Ø	0	
660557	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Operations A Ø	0	
660558	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
660559	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
660560	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
660561	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
660562	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
660563	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	General Comments		
660564	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
660565	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Vegetation	None	
660566	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
660567	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Adjusted Amps C Phase V	6.09	
660568	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Adjusted Amps B Phase V	6.09	
660569	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Adjusted Amps A Phase V	6.09	
660570	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Equipment Properly Labeled?	y	
660571	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Cabinet Paint Condition	Good	
660572	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
660573	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
660574	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Patrol Inspection	General Comments		
660575	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	General Comments		
660576	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Maintenance Operations	0	
660577	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Operations Counter AF	234	
660578	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Operations Counter AL	234	
660579	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Switching Operations	0	
660580	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Unknown Operations	0	
660581	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
660582	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
660583	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
660584	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	VRR Time Delay	30	Seconds
660585	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
660586	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
660587	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Bushings Connection/Risers	Good	
660588	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Bushing Condition	Good	
660589	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Amps C Ø	60.0	
660590	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
660591	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
660592	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
660593	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
660594	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
660595	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments		
660596	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
660597	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
660598	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
660599	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Good	
660600	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
660601	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Amps B Ø	60.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
660602	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Amps A Ø	60.0	
660603	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Accumulated Fault Duty C Ph V	13.66	%
660604	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Accumulated Fault Duty B Ph V	9.27	%
660605	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Accumulated Fault Duty A Ph V	13.67	%
660606	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	9 Month Operations	11	
660607	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Unknown Operations	0	
660608	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Tank Paint Condition	Good	
660609	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
660610	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
660611	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
660612	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
660613	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
660614	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
660615	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
660616	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
660617	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
660618	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
660619	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
660620	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
660621	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
660622	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
660623	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
660624	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
660625	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
660626	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
660627	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
660628	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
660629	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
660630	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
660631	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
660632	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	General Comments		
660633	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
660634	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
660635	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
660636	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	General Comments		
660637	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
660638	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
660639	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
660640	1/3/2019 13:59	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
660641	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
660642	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
660643	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
660644	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
660645	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Clear of Trash?	y	
660646	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	All Connections OK?	y	
660647	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	Follow-up Action Required?	n	
660648	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	General Comments		
660649	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	LTC Operation Checked?	y	
660650	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	9 Month Operations	0	
660651	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
660652	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
660653	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
660654	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Amps A Ø	0.0	
660655	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Amps B Ø	0.0	
660656	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Amps C Ø	0.0	
660657	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Patrol Inspection	Equipment Properly Labeled?	y	
660658	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
660659	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
660660	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
660661	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Follow-up Action Required?	n	
660662	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Follow-up Action Required?	n	
660663	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
660664	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Operations A Ø	0	
660665	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Operations B Ø	0	
660666	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Operations C Ø	0	
660667	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Patrol Inspection	Follow-up Action Required?	n	
660668	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Patrol Inspection	General Comments		
660669	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Unknown Operations	0	
660670	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Tank Paint Condition	Good	
660671	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Switching Operations	1	
660672	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
660673	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Operations Counter AL	232	
660674	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Operations Counter AF	231	
660675	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Moisture and Leak Free?	y	
660676	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
660677	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Heaters (All) Functioning?	y	
660678	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Grounds in Place?	y	
660679	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	General Comments		
660680	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	General Comments		
660681	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Foundation Condition	Good	
660682	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Follow-up Action Required?	n	
660683	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Follow-up Action Required?	n	
660684	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Operations Ground	0	
660685	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Operations C Ø	0	
660686	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Operations B Ø	0	
660687	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Operations A Ø	0	
660688	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
660689	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	9 Month Operations	3	
660690	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Accumulated Fault Duty A Ph V	.36	%
660691	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Accumulated Fault Duty B Ph V	0	%
660692	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
660693	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
660694	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Equipment Properly Labeled?	y	
660695	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Cabinet Paint Condition	Good	
660696	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
660697	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
660698	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
660699	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Bushings Connection/Risers	Good	
660700	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Bushing Condition	Good	
660701	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Amps C Ø	190.0	
660702	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Amps B Ø	185.0	
660703	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Amps A Ø	175.0	
660704	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Accumulated Fault Duty C Ph V	.47	%
660705	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Accumulated Fault Duty B Ph V	.93	%
660706	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Accumulated Fault Duty A Ph V	1.87	%
660707	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	9 Month Operations	2	
660708	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BCH001236	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
660709	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BCH001236	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
660710	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BCH001236	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
660711	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BCH001236	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
660712	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BCH001236	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
660713	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BCH001236	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
660714	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BCH001236	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
660715	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BCH001236	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.100	millivolts
660716	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Accumulated Fault Duty C Ph V	0	%
660717	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Amps A Ø	141	
660718	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Amps B Ø	145	
660719	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Amps C Ø	150	
660720	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Bushing Condition	Good	
660721	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Bushings Connection/Risers	Good	
660722	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
660723	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Unknown Operations	0	
660724	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Tank Paint Condition	Good	
660725	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Switching Operations	1	
660726	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Operations Counter AL	177	
660727	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Operations Counter AF	176	
660728	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Moisture and Leak Free?	y	
660729	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Maintenance Operations	0	
660730	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Grounds in Place?	y	
660731	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	General Comments	BFTC	
660732	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	General Comments		
660733	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Foundation Condition	Good	
660734	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Follow-up Action Required?	n	
660735	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Follow-up Action Required?	n	
660736	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Operations Ground	0	
660737	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Operations C Ø	0	
660738	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Operations B Ø	0	
660739	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Operations A Ø	0	
660740	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
660741	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
660742	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
660743	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Equipment Properly Labeled?	y	
660744	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Cabinet Paint Condition	Good	
660745	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
660746	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
660747	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
660748	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Bushings Connection/Risers	Good	
660749	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Bushing Condition	Good	
660750	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Amps C Ø	163.0	
660751	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Amps B Ø	165.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
660752	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Amps A Ø	160.0	
660753	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
660754	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
660755	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
660756	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	9 Month Operations	53	
660757	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Unknown Operations	0	
660758	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Switching Operations	0	
660759	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Operations Counter AL	675	
660760	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Operations Counter AF	675	
660761	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Maintenance Operations	0	
660762	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
660763	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	General Comments		
660764	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Patrol Inspection	General Comments		
660765	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Follow-up Action Required?	n	
660766	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
660767	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Operations Ground	0	
660768	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Operations C Ø	0	
660769	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Operations B Ø	0	
660770	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Operations A Ø	0	
660771	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
660772	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
660773	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
660774	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
660775	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Amps C Ø	140.0	
660776	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Amps B Ø	50.0	
660777	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Amps A Ø	50.0	
660778	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
660779	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
660780	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
660781	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	9 Months Operations	0	
660782	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
660783	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
660784	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Operations A Ø	0	
660785	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Operations B Ø	0	
660786	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Operations C Ø	0	
660787	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Operations Ground	0	
660788	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Follow-up Action Required?	n	
660789	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Follow-up Action Required?	n	
660790	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Foundation Condition	Good	
660791	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	General Comments		
660792	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
660793	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
660794	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
660795	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
660796	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
660797	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
660798	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
660799	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
660800	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC Operations Since Last Insp	444	
660801	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	20	°C
660802	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
660803	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
660804	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
660805	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC Min Tap Position	12L	
660806	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC Max Tap Position	Neutral	
660807	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC Current Tap Position	2L	
660808	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
660809	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC As Left Counter	30535	
660810	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC As Found Counter	30535	
660811	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	General Comments		
660812	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	General Comments		
660813	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
660814	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
660815	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
660816	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	Follow-up Action Required?	n	
660817	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	General Comments		
660818	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
660819	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
660820	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
660821	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
660822	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Grounds in Place?	y	
660823	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Heaters (All) Functioning?	y	
660824	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Maintenance Operations	2	
660825	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
660826	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
660827	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
660828	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
660829	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
660830	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
660831	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
660832	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
660833	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Moisture and Leak Free?	y	
660834	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Operations Counter AF	227	
660835	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Operations Counter AL	229	
660836	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	All Connections OK?	y	
660837	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	Follow-up Action Required?	n	
660838	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	General Comments		
660839	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	LTC Operation Checked?	y	
660840	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
660841	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Current Tap Position	4L	
660842	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
660843	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
660844	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
660845	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
660846	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Follow-up Action Required?	n	
660847	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Foundation Condition	Good	
660848	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Gauge(s) Condition	Good	
660849	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	General Comments		
660850	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Grounds in Place?	y	
660851	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Max Tap Position	Neutral	
660852	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Min Tap Position	10L	
660853	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Moisture and Leak Free?	y	
660854	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
660855	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Reg Oil Level	Good	
660856	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Reg Operation Checked?	y	
660857	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Reg Output Voltage Level	121.6	volts
660858	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Regulator As Left Counter	74341	
660859	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
660860	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Surge Arrester Condition	Good	
660861	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Tank Leaks	None	
660862	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Tank Paint Condition	Good	
660863	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
660864	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Bushing Condition	Good	
660865	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	9 Month Operations	8	
660866	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Accumulated Fault Duty A Ph V	.76	%
660867	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
660868	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	General Comments		
660869	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
660870	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
660871	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
660872	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
660873	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
660874	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
660875	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
660876	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
660877	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
660878	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
660879	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
660880	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
660881	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
660882	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
660883	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
660884	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
660885	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Accumulated Fault Duty B Ph V	1.13	%
660886	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Accumulated Fault Duty C Ph V	1.51	%
660887	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Amps A Ø	88.0	
660888	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Amps B Ø	88.0	
660889	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Amps C Ø	85.0	
660890	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Bushing Condition	Good	
660891	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Bushings Connection/Risers	Good	
660892	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
660893	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
660894	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
660895	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Cabinet Paint Condition	Good	
660896	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Equipment Properly Labeled?	y	
660897	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
660898	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
660899	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Operations B Ø	0	
660900	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Operations A Ø	0	
660901	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Adjusted Amps C Phase V	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
660902	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Adjusted Amps B Phase V	0	
660903	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Adjusted Amps A Phase V	0	
660904	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Equipment Properly Labeled?	y	
660905	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Cabinet Paint Condition	Good	
660906	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	VRR Time Delay	30	Seconds
660907	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
660908	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
660909	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
660910	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
660911	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	LTC Operation Checked?	y	
660912	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	General Comments		
660913	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	Follow-up Action Required?	n	
660914	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	All Connections OK?	y	
660915	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
660916	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
660917	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
660918	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
660919	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Bushings Connection/Risers	Good	
660920	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Bushing Condition	Good	
660921	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Amps C Ø	3	
660922	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Amps B Ø	10	
660923	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Amps A Ø	23	
660924	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Accumulated Fault Duty C Ph V	.14	%
660925	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Accumulated Fault Duty B Ph V	.14	%
660926	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
660927	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
660928	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Accumulated Fault Duty A Ph V	0	%
660929	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	9 Month Operations	4	
660930	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Unknown Operations	0	
660931	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Tank Paint Condition	Good	
660932	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Switching Operations	4	
660933	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
660934	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Operations Counter AL	674	
660935	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
660936	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
660937	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC Operations Since Last Insp	77	
660938	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
660939	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC Min Tap Position	8L	
660940	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC Max Tap Position	12R	
660941	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC Current Tap Position	4R	
660942	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Operations Counter AF	670	
660943	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
660944	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Moisture and Leak Free?	y	
660945	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Maintenance Operations	0	
660946	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Grounds in Place?	y	
660947	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	General Comments	BFTC	
660948	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	General Comments		
660949	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Foundation Condition	Good	
660950	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC As Left Counter	14557	
660951	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC As Found Counter	14557	
660952	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	General Comments	LTC COUNTER NOT WORKING . BLACK ONE. AC WIRED	
660953	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	General Comments		
660954	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	Follow-up Action Required?	y	
660955	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
660956	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
660957	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
660958	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
660959	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Switching Operations	0	
660960	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Tank Paint Condition	Good	
660961	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
660962	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
660963	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	VRR Time Delay	30	Seconds
660964	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
660965	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
660966	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
660967	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
660968	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
660969	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
660970	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
660971	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
660972	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Unknown Operations	0	
660973	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Unknown Operations	0	
660974	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Tank Paint Condition	Good	
660975	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Amps A Ø	46.0	
660976	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Amps B Ø	46.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
660977	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Amps C Ø	45.0	
660978	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Switching Operations	1	
660979	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	PF001229	PowerFuse	549-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	2	
660980	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	PF001229	PowerFuse	549-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
660981	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	PF001228	PowerFuse	549-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	2	
660982	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	PF001228	PowerFuse	549-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
660983	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
660984	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
660985	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
660986	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
660987	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
660988	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
660989	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
660990	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
660991	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	PF001227	PowerFuse	549-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	2	
660992	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	PF001227	PowerFuse	549-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
660993	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
660994	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
660995	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Operations Counter AL	151	
660996	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Operations Counter AF	150	
660997	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Moisture and Leak Free?	y	
660998	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Maintenance Operations	0	
660999	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	PF001218	PowerFuse	529-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	YES	
661000	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	PF001218	PowerFuse	529-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
661001	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Grounds in Place?	y	
661002	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	General Comments		
661003	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	General Comments		
661004	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Foundation Condition	Good	
661005	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	General Comments	Control check and battery 27.6/25.3	
661006	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
661007	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
661008	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Operations Counter	9	
661009	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
661010	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Tank Leaks	None	
661011	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
661012	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Follow-up Action Required?	n	
661013	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Follow-up Action Required?	n	
661014	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Operations Ground	0	
661015	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Operations C Ø	0	
661016	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
661017	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Bushings Connection/Risers	Good	
661018	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Bushing Condition	Good	
661019	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Amps C Ø	20.0	
661020	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Amps B Ø	20.0	
661021	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Amps A Ø	20.0	
661022	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Accumulated Fault Duty C Ph V	4.88	%
661023	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Accumulated Fault Duty B Ph V	5.37	%
661024	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Accumulated Fault Duty A Ph V	4.39	%
661025	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	9 Month Operations	2	
661026	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Unknown Operations	0	
661027	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
661028	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
661029	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
661030	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Tank Paint Condition	Good	
661031	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Switching Operations	6	
661032	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
661033	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Operations Counter AL	619	
661034	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Operations Counter AF	613	
661035	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Moisture and Leak Free?	y	
661036	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Maintenance Operations	0	
661037	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
661038	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Unknown Operations	0	
661039	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Tank Paint Condition	Good	
661040	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	PF000181	PowerFuse	HK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
661041	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	PF000181	PowerFuse	HK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
661042	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Switching Operations	8	
661043	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
661044	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Operations Counter AL	193	
661045	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Operations Counter AF	185	
661046	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Moisture and Leak Free?	y	
661047	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Maintenance Operations	0	
661048	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Grounds in Place?	y	
661049	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	General Comments		
661050	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	General Comments		
661051	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
661052	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Follow-up Action Required?	n	
661053	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Follow-up Action Required?	n	
661054	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Operations Ground	0	
661055	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Operations C Ø	0	
661056	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Operations B Ø	0	
661057	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	PF000182	PowerFuse	HK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
661058	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	PF000182	PowerFuse	HK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
661059	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Operations A Ø	0	
661060	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
661061	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
661062	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
661063	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
661064	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
661065	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
661066	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
661067	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
661068	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
661069	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
661070	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
661071	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
661072	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
661073	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
661074	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
661075	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
661076	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
661077	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
661078	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
661079	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	General Comments		
661080	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
661081	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
661082	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Foundation Condition	Good	
661083	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
661084	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
661085	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
661086	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
661087	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
661088	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Positive DC Ground	15	VDC
661089	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Negative DC Ground	6	VDC
661090	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	General Comments		
661091	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
661092	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
661093	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
661094	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
661095	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
661096	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
661097	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
661098	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
661099	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	4115	°F
661100	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
661101	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
661102	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
661103	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
661104	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Unknown Operations	0	
661105	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Tank Paint Condition	Good	
661106	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Switching Operations	1	
661107	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
661108	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Operations Counter AL	381	
661109	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Operations Counter AF	380	
661110	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Moisture and Leak Free?	y	
661111	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Maintenance Operations	0	
661112	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Heaters (All) Functioning?	y	
661113	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Grounds in Place?	y	
661114	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	General Comments		
661115	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	General Comments		
661116	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Foundation Condition	Good	
661117	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Follow-up Action Required?	n	
661118	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Follow-up Action Required?	n	
661119	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Operations Ground	0	
661120	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Operations C Ø	0	
661121	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Operations B Ø	0	
661122	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Operations A Ø	0	
661123	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
661124	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
661125	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
661126	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
661127	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
661128	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Equipment Properly Labeled?	y	
661129	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Cabinet Paint Condition	Good	
661130	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
661131	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
661132	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	9 Month Operations	16	
661133	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	9 Month Operations	18	
661134	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
661135	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
661136	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
661137	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Amps A Ø	0.0	
661138	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Amps B Ø	0.0	
661139	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Amps C Ø	0.0	
661140	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Bushing Condition	Good	
661141	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Bushings Connection/Risers	Good	
661142	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
661143	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
661144	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
661145	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Cabinet Paint Condition	Good	
661146	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Equipment Properly Labeled?	y	
661147	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
661148	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
661149	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
661150	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Operations A Ø	0	
661151	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Operations B Ø	0	
661152	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Operations C Ø	0	
661153	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Operations Ground	0	
661154	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Follow-up Action Required?	n	
661155	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Follow-up Action Required?	n	
661156	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Foundation Condition	Good	
661157	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	General Comments		
661158	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	General Comments	Changed counter	
661159	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Grounds in Place?	y	
661160	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Maintenance Operations	10	
661161	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Moisture and Leak Free?	y	
661162	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Operations Counter AF	540	
661163	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Operations Counter AL	2104	
661164	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
661165	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	VRR Time Delay	60	Seconds
661166	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
661167	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
661168	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Switching Operations	4	
661169	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
661170	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
661171	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
661172	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
661173	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
661174	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
661175	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	LTC Operation Checked?	y	
661176	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
661177	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Vegetation	None	
661178	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	General Comments		
661179	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	Follow-up Action Required?	n	
661180	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	All Connections OK?	y	
661181	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
661182	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
661183	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
661184	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
661185	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
661186	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	General Comments		
661187	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
661188	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
661189	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
661190	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
661191	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Current Tap Position	4R	
661192	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
661193	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
661194	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
661195	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
661196	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	General Comments	Previous counter entered in error. Correct counter now.	
661197	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
661198	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
661199	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
661200	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
661201	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
661202	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
661203	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
661204	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
661205	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Patrol Inspection	General Comments		
661206	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Patrol Inspection	Follow-up Action Required?	n	
661207	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
661208	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Regulator As Left Counter	178836	
661209	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
661210	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	General Comments		
661211	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
661212	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
661213	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Foundation Condition	Good	
661214	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
661215	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
661216	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Equipment Properly Labeled?	y	
661217	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Cabinet Paint Condition	Good	
661218	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
661219	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Tank Leaks	None	
661220	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
661221	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
661222	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
661223	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Bushings Connection/Risers	Good	
661224	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Bushing Condition	Good	
661225	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Amps C Ø	120.0	
661226	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Amps B Ø	100.0	
661227	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
661228	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
661229	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Regulator As Left Counter	94668	
661230	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
661231	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
661232	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
661233	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
661234	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
661235	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
661236	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Max Tap Position	16R	
661237	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
661238	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	General Comments		
661239	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
661240	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
661241	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
661242	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Tank Leaks	None	
661243	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
661244	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Amps A Ø	120.0	
661245	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Accumulated Fault Duty C Ph V	2.64	%
661246	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Accumulated Fault Duty B Ph V	3.33	%
661247	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Accumulated Fault Duty A Ph V	3.21	%
661248	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	9 Month Operations	2	
661249	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Accumulated Fault Duty A Ph V	2.51	%
661250	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Accumulated Fault Duty B Ph V	2.51	%
661251	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
661252	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
661253	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	General Comments		
661254	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
661255	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
661256	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Foundation Condition	Good	
661257	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
661258	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
661259	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
661260	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
661261	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
661262	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	General Comments		
661263	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
661264	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
661265	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.9	amps
661266	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.3	VDC
661267	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Accumulated Fault Duty C Ph V	2.51	%
661268	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Amps A Ø	790.0	
661269	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.3	VDC
661270	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.600	millivolts
661271	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
661272	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
661273	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
661274	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
661275	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Trash Emptied?	n	
661276	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
661277	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	General Comments		
661278	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Amps B Ø	803.0	
661279	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Amps C Ø	842.0	
661280	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Bushing Condition	Good	
661281	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
661282	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
661283	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
661284	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Cabinet Paint Condition	Good	
661285	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Equipment Properly Labeled?	y	
661286	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Adjusted Amps A Phase V	0	
661287	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Adjusted Amps B Phase V	0	
661288	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Adjusted Amps C Phase V	0	
661289	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Operations A Ø	0	
661290	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Operations B Ø	0	
661291	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Operations C Ø	0	
661292	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Operations Ground	0	
661293	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Follow-up Action Required?	n	
661294	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Follow-up Action Required?	n	
661295	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Foundation Condition	Good	
661296	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	General Comments		
661297	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
661298	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
661299	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Floor Swept?	y	
661300	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
661301	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
661302	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Evidence of Insects	None	
661303	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
661304	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
661305	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
661306	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Switching Operations	1	
661307	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
661308	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Operations Counter AL	111	
661309	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Operations Counter AF	110	
661310	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Moisture and Leak Free?	y	
661311	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Maintenance Operations	0	
661312	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Heaters (All) Functioning?	y	
661313	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Grounds in Place?	y	
661314	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
661315	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
661316	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
661317	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
661318	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
661319	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
661320	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
661321	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
661322	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
661323	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
661324	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
661325	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
661326	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
661327	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	General Comments		
661328	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
661329	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
661330	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
661331	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
661332	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	General Comments		
661333	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	General Comments		
661334	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Foundation Condition	Good	
661335	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Follow-up Action Required?	n	
661336	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Follow-up Action Required?	n	
661337	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Operations Ground	0	
661338	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Operations C Ø	0	
661339	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Operations B Ø	0	
661340	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Operations A Ø	0	
661341	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
661342	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
661343	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
661344	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Equipment Properly Labeled?	y	
661345	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Cabinet Paint Condition	Good	
661346	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
661347	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
661348	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
661349	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Bushings Connection/Risers	Good	
661350	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Bushing Condition	Good	
661351	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Amps C Ø	228.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
661352	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Amps B Ø	237.0	
661353	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Amps A Ø	207.0	
661354	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
661355	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
661356	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
661357	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	9 Month Operations	2	
661358	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
661359	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
661360	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
661361	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
661362	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
661363	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
661364	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
661365	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
661366	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
661367	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
661368	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	General Comments		
661369	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
661370	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	LTCC000074	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
661371	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	LTCC000074	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
661372	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	LTCC000074	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
661373	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	LTCC000074	LTCControl	932-Offline Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
661374	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	LTCC000074	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
661375	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	LTCC000074	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Operation Checked?	y	
661376	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Adjusted Amps B Phase V	33.73	
661377	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Adjusted Amps C Phase V	33.73	
661378	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Operations A Ø	0	
661379	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Operations B Ø	0	
661380	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Operations C Ø	0	
661381	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Operations Ground	0	
661382	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Follow-up Action Required?	n	
661383	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Follow-up Action Required?	n	
661384	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Foundation Condition	Good	
661385	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	General Comments		
661386	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	General Comments		
661387	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	LTCC000074	LTCControl	932-Offline Distribution	LTC Control Insp	General Comments		
661388	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	LTCC000074	LTCControl	932-Offline Distribution	LTC Control Insp	Follow-up Action Required?	n	
661389	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	LTCC000074	LTCControl	932-Offline Distribution	LTC Control Insp	All Connections OK?	y	
661390	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
661391	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Grounds in Place?	y	
661392	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
661393	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Maintenance Operations	0	
661394	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
661395	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Operations Counter AF	159	
661396	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Operations Counter AL	159	
661397	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
661398	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
661399	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
661400	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
661401	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
661402	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
661403	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	General Comments		
661404	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
661405	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
661406	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Foundation Condition	Good	
661407	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
661408	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
661409	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
661410	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
661411	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
661412	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Switching Operations	0	
661413	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Tank Paint Condition	Good	
661414	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Unknown Operations	1	
661415	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
661416	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
661417	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
661418	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
661419	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
661420	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
661421	1/3/2019 15:07	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
661422	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Broom on Site?	y	
661423	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
661424	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
661425	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
661426	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
661427	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
661428	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
661429	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
661430	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
661431	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
661432	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Trash Emptied?	n	
661433	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Panels Dusted?	y	
661434	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
661435	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	General Comments		
661436	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
661437	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
661438	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	General Comments		
661439	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
661440	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Grounds in Place?	y	
661441	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Maintenance Operations	0	
661442	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Moisture and Leak Free?	y	
661443	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Operations Counter AF	177	
661444	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Operations Counter AL	178	
661445	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Switching Operations	1	
661446	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Tank Paint Condition	Good	
661447	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Unknown Operations	0	
661448	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
661449	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Floor Swept?	y	
661450	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
661451	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
661452	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
661453	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
661454	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
661455	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
661456	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Adjusted Amps A Phase V	33.73	
661457	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Evidence of Insects	None	
661458	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
661459	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
661460	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
661461	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Broom on Site?	y	
661462	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
661463	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
661464	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
661465	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
661466	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
661467	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
661468	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
661469	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
661470	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
661471	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
661472	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
661473	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
661474	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
661475	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
661476	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
661477	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
661478	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
661479	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
661480	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
661481	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
661482	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
661483	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
661484	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
661485	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
661486	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	General Comments		
661487	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
661488	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
661489	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
661490	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
661491	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
661492	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
661493	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
661494	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
661495	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
661496	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
661497	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
661498	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Unknown Operations	0	
661499	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
661500	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
661501	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
661502	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
661503	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
661504	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
661505	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	General Comments		
661506	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
661507	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
661508	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
661509	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
661510	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
661511	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
661512	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
661513	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
661514	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	General Comments		
661515	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
661516	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
661517	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
661518	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
661519	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
661520	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
661521	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
661522	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
661523	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
661524	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
661525	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
661526	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	LTC Totalizer Reading	21636.00	kw
661527	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
661528	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	779	
661529	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	783	
661530	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
661531	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
661532	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
661533	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
661534	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
661535	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	80.00	
661536	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
661537	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
661538	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
661539	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
661540	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	General Comments		
661541	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	General Comments		
661542	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
661543	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
661544	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
661545	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
661546	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
661547	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Follow-up Action Required?	n	
661548	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
661549	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
661550	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	General Comments		
661551	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	General Comments		
661552	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
661553	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
661554	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
661555	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
661556	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
661557	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
661558	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
661559	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
661560	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
661561	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
661562	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Bushing Condition	Good	
661563	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
661564	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
661565	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
661566	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
661567	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
661568	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Bushing Condition	Good	
661569	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Bushings Connection/Risers	Good	
661570	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
661571	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
661572	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
661573	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Cabinet Paint Condition	Good	
661574	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Equipment Properly Labeled?	y	
661575	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
661576	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
661577	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
661578	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
661579	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
661580	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
661581	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
661582	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
661583	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Fault Operations A Ø	0	
661584	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Fault Operations B Ø	0	
661585	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Fault Operations C Ø	0	
661586	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Fault Operations Ground	0	
661587	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
661588	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
661589	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
661590	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
661591	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
661592	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
661593	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
661594	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
661595	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
661596	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
661597	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Follow-up Action Required?	n	
661598	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Follow-up Action Required?	n	
661599	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
661600	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
661601	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
661602	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
661603	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Foundation Condition	Good	
661604	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
661605	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
661606	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	General Comments		
661607	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	General Comments		
661608	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Grounds in Place?	y	
661609	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
661610	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
661611	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
661612	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Heaters (All) Functioning?	y	
661613	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Maintenance Operations	0	
661614	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Moisture and Leak Free?	y	
661615	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Operations Counter AF	221	
661616	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Operations Counter AL	224	
661617	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
661618	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
661619	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
661620	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
661621	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
661622	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Switching Operations	3	
661623	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Tank Paint Condition	Good	
661624	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
661625	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
661626	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
661627	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
661628	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
661629	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
661630	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
661631	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
661632	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
661633	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
661634	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
661635	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
661636	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	General Comments		
661637	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
661638	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
661639	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
661640	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
661641	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
661642	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
661643	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Oil Temp Max	70	°C
661644	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Oil Temp Present	40	°C
661645	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
661646	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
661647	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
661648	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
661649	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
661650	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
661651	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
661652	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Operations A Ø	0	
661653	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Operations B Ø	0	
661654	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Operations C Ø	0	
661655	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Operations Ground	0	
661656	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Follow-up Action Required?	n	
661657	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Follow-up Action Required?	n	
661658	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	9 Month Operations	0	
661659	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
661660	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
661661	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
661662	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Foundation Condition	Good	
661663	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	General Comments		
661664	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	General Comments		
661665	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Grounds in Place?	y	
661666	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
661667	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
661668	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
661669	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
661670	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Maintenance Operations	0	
661671	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
661672	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Operations Counter AF	139	
661673	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Operations Counter AL	140	
661674	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Switching Operations	2	
661675	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Tank Paint Condition	Good	
661676	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Unknown Operations	0	
661677	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
661678	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
661679	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
661680	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
661681	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
661682	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
661683	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Totalizer Meter Reading	1.2020	
661684	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
661685	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
661686	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	3L	
661687	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
661688	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
661689	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
661690	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Winding Temp Max	80	°C
661691	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Winding Temp Present	80	°C
661692	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
661693	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
661694	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Unknown Operations	0	
661695	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
661696	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Switching Operations	3	
661697	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
661698	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Operations Counter AL	267	
661699	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Operations Counter AF	264	
661700	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
661701	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Maintenance Operations	0	
661702	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
661703	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
661704	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	General Comments		
661705	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
661706	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
661707	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
661708	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	1L	
661709	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
661710	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
661711	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
661712	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
661713	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
661714	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
661715	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
661716	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
661717	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Oil Temp Present	36	°C
661718	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
661719	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	Oil Temp Max	35	°C
661720	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	Oil Temp Present	35	°C
661721	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
661722	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
661723	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	LTC Totalizer Reading	4798.08	kw
661724	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
661725	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Oil Temp Max	52	°C
661726	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
661727	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
661728	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	LTC Totalizer Reading	5256.00	kw
661729	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
661730	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	General Comments		
661731	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	General Comments		
661732	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
661733	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
661734	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
661735	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
661736	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
661737	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
661738	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
661739	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
661740	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
661741	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Oil Temp Max	50	°C
661742	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Oil Temp Present	27	°C
661743	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
661744	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
661745	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Readings	Oil Temp Present	35	°C
661746	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Readings	Oil Temp Max	35	°C
661747	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
661748	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
661749	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC Current Tap Position	4L	
661750	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC Max Tap Position	4R	
661751	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
661752	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
661753	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
661754	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
661755	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
661756	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
661757	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
661758	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
661759	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
661760	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
661761	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
661762	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
661763	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
661764	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Totalizer Meter Reading	.4998	
661765	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
661766	1/3/2019 11:00	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
661767	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Readings	General Comments		
661768	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	General Comments		
661769	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
661770	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
661771	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
661772	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
661773	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	9 Month Operations	3	
661774	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
661775	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
661776	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
661777	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Amps A Ø	715.0	
661778	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Amps B Ø	720.0	
661779	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Amps C Ø	710.0	
661780	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Bushing Condition	Good	
661781	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
661782	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
661783	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
661784	1/3/2019 7:50	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
661785	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
661786	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
661787	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
661788	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
661789	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
661790	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
661791	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
661792	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
661793	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
661794	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC Current Tap Position	4L	
661795	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC Max Tap Position	2L	
661796	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Maintenance Operations	0	
661797	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Moisture and Leak Free?	y	
661798	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Operations Counter AF	91461	
661799	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Operations Counter AL	91462	
661800	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
661801	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Switching Operations	1	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
661802	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Tank Paint Condition	Good	
661803	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Unknown Operations	0	
661804	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
661805	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
661806	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
661807	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
661808	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
661809	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
661810	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
661811	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
661812	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
661813	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
661814	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
661815	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
661816	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
661817	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
661818	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
661819	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
661820	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
661821	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
661822	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	General Comments		
661823	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
661824	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC Min Tap Position	10L	
661825	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC Operations Since Last Insp	333	
661826	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
661827	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
661828	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
661829	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
661830	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
661831	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
661832	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
661833	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
661834	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
661835	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
661836	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	LTC Totalizer Reading	12968.64	kw
661837	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
661838	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	General Comments		
661839	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BAT000167	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
661840	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BAT000167	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
661841	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BAT000167	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
661842	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
661843	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
661844	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
661845	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
661846	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
661847	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
661848	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
661849	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
661850	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	12.0	
661851	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
661852	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
661853	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
661854	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
661855	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
661856	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
661857	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
661858	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
661859	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
661860	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
661861	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
661862	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
661863	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
661864	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
661865	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
661866	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
661867	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
661868	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
661869	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
661870	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	General Comments	Trees beside fence on right hand side of lot.	
661871	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Bushing Condition	Good	
661872	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Amps C Ø	100.0	
661873	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Amps B Ø	90.0	
661874	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
661875	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
661876	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
661877	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
661878	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Amps A Ø	80.0	
661879	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Oil Temp Max	50	°C
661880	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Oil Temp Present	30	°C
661881	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
661882	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
661883	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Accumulated Fault Duty C Ph V	2.28	%
661884	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Accumulated Fault Duty B Ph V	2.28	%
661885	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Accumulated Fault Duty A Ph V	4.57	%
661886	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	9 Month Operations	2	
661887	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
661888	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
661889	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
661890	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
661891	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
661892	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
661893	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
661894	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
661895	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
661896	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Bushings Connection/Risers	Good	
661897	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
661898	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Totalizer Meter Reading	.9006	
661899	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Winding Temp Max	55	°C
661900	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Winding Temp Present	30	°C
661901	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
661902	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
661903	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BAT000167	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
661904	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BAT000167	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
661905	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BAT000167	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
661906	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BAT000167	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
661907	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BAT000167	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
661908	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BAT000167	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
661909	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BAT000167	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
661910	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BAT000167	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
661911	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BAT000167	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
661912	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BAT000167	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
661913	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	BAT000167	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
661914	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
661915	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
661916	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
661917	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
661918	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
661919	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
661920	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
661921	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
661922	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
661923	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
661924	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
661925	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
661926	1/3/2019 11:32	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
661927	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	Follow-up Action Required?	n	
661928	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
661929	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	General Comments		
661930	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Mechanism Patrol Inspection	General Comments		
661931	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC As Found Counter	138536	
661932	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC As Left Counter	138536	
661933	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Cabinet Paint Condition	Good	
661934	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Equipment Properly Labeled?	y	
661935	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
661936	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
661937	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
661938	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Operations A Ø	0	
661939	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Operations B Ø	0	
661940	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Operations C Ø	0	
661941	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Operations Ground	0	
661942	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Follow-up Action Required?	n	
661943	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Follow-up Action Required?	n	
661944	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Foundation Condition	Good	
661945	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	General Comments		
661946	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	General Comments		
661947	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Grounds in Place?	y	
661948	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Heaters (All) Functioning?	y	
661949	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
661950	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Amps A Ø	260.0	
661951	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Amps B Ø	240.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
661952	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Amps C Ø	240.0	
661953	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
661954	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
661955	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
661956	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
661957	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
661958	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
661959	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
661960	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
661961	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
661962	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
661963	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
661964	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
661965	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Tank Paint Condition	Good	
661966	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Tank Leaks	None	
661967	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Surge Arrester Condition	Good	
661968	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
661969	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Regulator As Left Counter	14376	
661970	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Reg Output Voltage Level	122.0	volts
661971	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Reg Operation Checked?	y	
661972	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Reg Oil Level	Good	
661973	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
661974	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
661975	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
661976	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Moisture and Leak Free?	y	
661977	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Min Tap Position	10L	
661978	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
661979	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
661980	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
661981	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
661982	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Max Tap Position	Neutral	
661983	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Grounds in Place?	y	
661984	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	General Comments		
661985	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Gauge(s) Condition	Good	
661986	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Foundation Condition	Good	
661987	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
661988	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
661989	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
661990	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Regulator As Left Counter	115813	
661991	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
661992	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
661993	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
661994	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
661995	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
661996	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
661997	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
661998	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
661999	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
662000	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
662001	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
662002	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
662003	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Tank Leaks	Seeping	
662004	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
662005	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
662006	1/3/2019 16:10	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Follow-up Action Required?	n	
662007	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
662008	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments	Free breather	
662009	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
662010	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
662011	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
662012	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
662013	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
662014	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
662015	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Follow-up Action Required?	n	
662016	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
662017	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Current Tap Position	3L	
662018	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
662019	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
662020	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
662021	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
662022	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
662023	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	General Comments		
662024	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
662025	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
662026	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
662027	1/3/2019 11:49	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
662028	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
662029	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
662030	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	Follow-up Action Required?	n	
662031	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
662032	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	General Comments		
662033	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	General Comments	counter not working	
662034	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
662035	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
662036	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
662037	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
662038	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
662039	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
662040	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
662041	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
662042	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
662043	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
662044	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	Follow-up Action Required?	n	
662045	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
662046	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
662047	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	General Comments		
662048	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	General Comments		
662049	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
662050	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	General Comments		
662051	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
662052	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	LTC Totalizer Reading	1067.52	kw
662053	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
662054	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
662055	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	Oil Temp Max	55	°C
662056	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	Oil Temp Present	25	°C
662057	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
662058	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
662059	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
662060	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
662061	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
662062	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
662063	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
662064	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
662065	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	Totalizer Meter Reading	.3336	
662066	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
662067	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
662068	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
662069	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
662070	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
662071	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
662072	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
662073	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
662074	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
662075	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
662076	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
662077	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC As Found Counter	29256	
662078	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC As Left Counter	29256	
662079	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
662080	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
662081	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	General Comments		
662082	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
662083	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
662084	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Follow-up Action Required?	n	
662085	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
662086	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
662087	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
662088	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
662089	1/3/2019 15:13	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
662090	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
662091	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
662092	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
662093	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	12.0	
662094	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	12.0	
662095	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	15.44	%
662096	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	18.69	%
662097	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	16.25	%
662098	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
662099	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
662100	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	9 Month Operations	6	
662101	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
662102	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
662103	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
662104	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
662105	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Foundation Condition	Good	
662106	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	General Comments		
662107	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	General Comments		
662108	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Grounds in Place?	y	
662109	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	General Comments		
662110	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Follow-up Action Required?	n	
662111	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Follow-up Action Required?	n	
662112	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Foundation Condition	Good	
662113	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	General Comments		
662114	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	General Comments		
662115	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Grounds in Place?	y	
662116	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Heaters (All) Functioning?	y	
662117	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Maintenance Operations	0	
662118	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Moisture and Leak Free?	y	
662119	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Operations Counter AF	180	
662120	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
662121	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	Follow-up Action Required?	n	
662122	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Heaters (All) Functioning?	y	
662123	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
662124	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
662125	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
662126	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
662127	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
662128	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
662129	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
662130	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
662131	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
662132	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Min Tap Position	9L	
662133	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Max Tap Position	1L	
662134	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
662135	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	General Comments		
662136	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
662137	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
662138	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
662139	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
662140	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Current Tap Position	5L	
662141	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
662142	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
662143	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
662144	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
662145	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
662146	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
662147	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
662148	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
662149	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Grounds in Place?	y	
662150	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	General Comments		
662151	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
662152	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
662153	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	General Comments		
662154	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Foundation Condition	Good	
662155	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
662156	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
662157	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
662158	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
662159	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	225.00	
662160	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
662161	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
662162	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
662163	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
662164	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	General Comments	Added Nitrogen	
662165	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	General Comments		
662166	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
662167	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
662168	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
662169	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Follow-up Action Required?	n	
662170	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Follow-up Action Required?	n	
662171	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
662172	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
662173	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
662174	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
662175	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Operations Ground	0	
662176	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
662177	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
662178	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
662179	1/3/2019 14:03	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
662180	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Operations Counter AL	186	
662181	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Switching Operations	5	
662182	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Tank Paint Condition	Good	
662183	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Operations A Ø	0	
662184	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Operations B Ø	0	
662185	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Operations C Ø	0	
662186	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Operations Ground	0	
662187	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
662188	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Tank Leaks	None	
662189	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	9 Months Operations	0	
662190	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
662191	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
662192	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
662193	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Amps A Ø	290.0	
662194	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Amps B Ø	300.0	
662195	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Amps C Ø	290.0	
662196	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
662197	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Follow-up Action Required?	n	
662198	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Follow-up Action Required?	n	
662199	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
662200	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
662201	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
662202	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
662203	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
662204	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
662205	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
662206	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
662207	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
662208	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Patrol Inspection	General Comments		
662209	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	General Comments		
662210	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Maintenance Operations	0	
662211	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Operations Counter AF	510	
662212	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Operations Counter AL	510	
662213	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Switching Operations	0	
662214	1/3/2019 12:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Unknown Operations	0	
662215	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Foundation Condition	Good	
662216	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Amps A Ø	180.0	
662217	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Amps B Ø	190.0	
662218	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Amps C Ø	190.0	
662219	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Bushing Condition	Good	
662220	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Bushings Connection/Risers	Good	
662221	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
662222	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
662223	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
662224	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
662225	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
662226	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
662227	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	General Comments		
662228	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
662229	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Cabinet Paint Condition	Good	
662230	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Equipment Properly Labeled?	y	
662231	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
662232	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
662233	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Adjusted Amps C Phase V	6.55	
662234	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Regulator As Left Counter	152553	
662235	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
662236	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
662237	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
662238	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	General Comments		
662239	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
662240	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
662241	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
662242	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
662243	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Vegetation	None	
662244	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
662245	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Unknown Operations	0	
662246	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Tank Paint Condition	Good	
662247	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Switching Operations	1	
662248	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Operations Counter AL	158	
662249	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Operations Counter AF	157	
662250	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
662251	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Totalizer Meter Reading	.2544	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
662252	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Winding Temp Max	46	°C
662253	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Winding Temp Present	20	°C
662254	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Operations A Ø	0	
662255	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Operations B Ø	0	
662256	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Operations C Ø	1	
662257	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Operations Ground	0	
662258	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Maintenance Operations	0	
662259	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Follow-up Action Required?	n	
662260	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Follow-up Action Required?	n	
662261	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
662262	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
662263	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Operations A Ø	0	
662264	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Operations B Ø	0	
662265	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Grounds in Place?	y	
662266	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
662267	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Maintenance Operations	0	
662268	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
662269	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Operations Counter AF	449	
662270	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Operations C Ø	0	
662271	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Operations Ground	0	
662272	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Follow-up Action Required?	n	
662273	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
662274	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
662275	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Vegetation	None	
662276	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
662277	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Operations A Ø	0	
662278	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Operations B Ø	0	
662279	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Operations C Ø	0	
662280	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Operations Ground	0	
662281	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
662282	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Follow-up Action Required?	n	
662283	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Follow-up Action Required?	n	
662284	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Foundation Condition	Good	
662285	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	General Comments		
662286	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
662287	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
662288	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	General Comments		
662289	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Grounds in Place?	y	
662290	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Maintenance Operations	1	
662291	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Moisture and Leak Free?	y	
662292	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Operations Counter AF	205	
662293	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Operations Counter AL	207	
662294	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Switching Operations	0	
662295	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Tank Paint Condition	Good	
662296	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Unknown Operations	0	
662297	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Patrol Inspection	General Comments		
662298	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
662299	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
662300	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
662301	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
662302	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
662303	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
662304	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
662305	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
662306	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Operations Counter AL	450	
662307	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
662308	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Switching Operations	1	
662309	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Tank Paint Condition	Good	
662310	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Unknown Operations	0	
662311	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	General Comments		
662312	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	General Comments		
662313	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Grounds in Place?	y	
662314	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Maintenance Operations	0	
662315	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Moisture and Leak Free?	y	
662316	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Operations Counter AF	188	
662317	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Operations Counter AL	189	
662318	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Unknown Operations	0	
662319	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Unknown Operations	0	
662320	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Tank Paint Condition	Good	
662321	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Switching Operations	0	
662322	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Operations Counter AL	480	
662323	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Operations Counter AF	480	
662324	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Maintenance Operations	0	
662325	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	General Comments		
662326	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
662327	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Follow-up Action Required?	n	
662328	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Patrol Inspection	Follow-up Action Required?	n	
662329	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Operations Ground	0	
662330	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Operations C Ø	0	
662331	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Operations B Ø	0	
662332	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
662333	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
662334	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
662335	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
662336	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
662337	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
662338	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Foundation Condition	Good	
662339	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Operations C Ø	0	
662340	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Operations B Ø	0	
662341	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Operations A Ø	0	
662342	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Unknown Operations	0	
662343	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
662344	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
662345	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
662346	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
662347	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
662348	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
662349	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
662350	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
662351	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
662352	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
662353	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
662354	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
662355	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
662356	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
662357	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Bushing Condition	Good	
662358	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Amps C Ø	295.0	
662359	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Amps B Ø	300.0	
662360	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Amps A Ø	302.0	
662361	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
662362	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
662363	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
662364	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
662365	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
662366	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
662367	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	9 Month Operations	2	
662368	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	9 Months Operations	0	
662369	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
662370	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
662371	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
662372	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Amps A Ø	10.0	
662373	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Amps B Ø	50.0	
662374	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Amps C Ø	30.0	
662375	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
662376	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
662377	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
662378	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
662379	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
662380	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
662381	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
662382	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
662383	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
662384	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	9 Month Operations	5	
662385	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	General Comments		
662386	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
662387	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
662388	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
662389	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
662390	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
662391	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
662392	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
662393	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Operations A Ø	0	
662394	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Operations B Ø	0	
662395	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Operations C Ø	0	
662396	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Operations Ground	0	
662397	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Follow-up Action Required?	n	
662398	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	9 Month Operations	3	
662399	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
662400	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
662401	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
662402	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Follow-up Action Required?	n	
662403	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Amps A Ø	57.0	
662404	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Amps B Ø	74.0	
662405	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Amps C Ø	80.0	
662406	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Bushing Condition	Good	
662407	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Bushings Connection/Risers	Good	
662408	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
662409	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
662410	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
662411	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Cabinet Paint Condition	Good	
662412	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Equipment Properly Labeled?	y	
662413	1/3/2019 12:13	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
662414	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Foundation Condition	Good	
662415	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	General Comments		
662416	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	General Comments		
662417	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Oil Temp Present	25	°C
662418	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
662419	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
662420	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
662421	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
662422	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
662423	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
662424	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
662425	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
662426	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Unknown Operations	0	
662427	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Switching Operations	0	
662428	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Operations Counter AL	559	
662429	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Operations Counter AF	559	
662430	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	All Connections OK?	y	
662431	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
662432	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Maintenance Operations	0	
662433	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	General Comments		
662434	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Patrol Inspection	General Comments		
662435	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Follow-up Action Required?	n	
662436	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Totalizer Meter Reading	1.0350	
662437	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Winding Temp Max	50	°C
662438	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Winding Temp Present	25	°C
662439	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
662440	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
662441	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
662442	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
662443	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
662444	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
662445	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
662446	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
662447	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
662448	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Follow-up Action Required?	n	
662449	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
662450	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Patrol Inspection	Follow-up Action Required?	n	
662451	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
662452	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	Oil Temp Present	35	°C
662453	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	Oil Temp Max	45	°C
662454	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
662455	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
662456	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
662457	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
662458	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
662459	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
662460	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
662461	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
662462	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
662463	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
662464	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
662465	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
662466	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
662467	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Follow-up Action Required?	n	
662468	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
662469	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
662470	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	General Comments		
662471	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
662472	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Amps C Ø	330.0	
662473	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Amps B Ø	330.0	
662474	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Amps A Ø	400.0	
662475	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
662476	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
662477	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
662478	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
662479	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	VRR Time Delay	30	Seconds
662480	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
662481	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
662482	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	LTC Output Voltage Level	120.5	VAC
662483	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	LTC Operation Checked?	y	
662484	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	General Comments		
662485	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
662486	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
662487	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
662488	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
662489	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	Follow-up Action Required?	n	
662490	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
662491	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
662492	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
662493	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	General Comments		
662494	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
662495	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
662496	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
662497	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
662498	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	LTC Totalizer Reading	14904.00	kw
662499	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
662500	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
662501	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
662502	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Oil Temp Max	45	°C
662503	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Totalizer Meter Reading	.7300	
662504	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
662505	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
662506	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
662507	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Patrol Inspection	Equipment Properly Labeled?	y	
662508	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Operations A Ø	0	
662509	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Operations B Ø	0	
662510	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Operations C Ø	0	
662511	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Operations Ground	0	
662512	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Amps C Ø	0.0	
662513	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Amps B Ø	0.0	
662514	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Amps A Ø	0.0	
662515	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
662516	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
662517	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
662518	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	19	
662519	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
662520	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
662521	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Tank Leaks	None	
662522	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
662523	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
662524	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Regulator As Left Counter	246558	
662525	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Follow-up Action Required?	n	
662526	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
662527	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	General Comments		
662528	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
662529	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
662530	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
662531	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
662532	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
662533	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
662534	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
662535	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
662536	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	General Comments		
662537	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
662538	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
662539	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
662540	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
662541	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
662542	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
662543	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
662544	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
662545	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
662546	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	365475	
662547	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
662548	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
662549	1/3/2019 14:54	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
662550	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Operations Ground	0	
662551	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
662552	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
662553	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
662554	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
662555	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
662556	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Operations B Ø	0	
662557	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Operations A Ø	0	
662558	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
662559	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
662560	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
662561	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
662562	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
662563	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
662564	1/3/2019 9:28	Distribution	Pineville Substation Department Transform	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
662565	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
662566	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
662567	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
662568	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	General Comments		
662569	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	General Comments		
662570	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
662571	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
662572	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
662573	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
662574	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
662575	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
662576	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
662577	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
662578	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
662579	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
662580	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
662581	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
662582	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
662583	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
662584	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
662585	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
662586	1/3/2019 10:10	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
662587	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
662588	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
662589	1/3/2019 13:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
662590	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	General Comments		
662591	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
662592	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
662593	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Readings	General Comments		
662594	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
662595	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	Follow-up Action Required?	n	
662596	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Adjusted Amps C Phase V	6.13	
662597	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Operations A Ø	0	
662598	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Operations B Ø	0	
662599	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Operations C Ø	1	
662600	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Operations Ground	0	
662601	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
662602	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
662603	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Amps C Ø	0.0	
662604	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Amps B Ø	0.0	
662605	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
662606	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
662607	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Clear of Trash?	y	
662608	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
662609	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
662610	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Amps A Ø	0.0	
662611	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
662612	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	General Comments		
662613	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
662614	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
662615	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
662616	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
662617	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC Operations Since Last Insp	358	
662618	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
662619	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC Min Tap Position	10R	
662620	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC Max Tap Position	1R	
662621	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC Current Tap Position	3L	
662622	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
662623	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC As Left Counter	55564	
662624	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC As Found Counter	55564	
662625	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
662626	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
662627	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Bushing Condition	Good	
662628	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
662629	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
662630	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	9 Month Operations	8	
662631	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Accumulated Fault Duty A Ph V	3.91	%
662632	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Accumulated Fault Duty B Ph V	3.42	%
662633	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Accumulated Fault Duty C Ph V	5.37	%
662634	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Follow-up Action Required?	n	
662635	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
662636	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
662637	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
662638	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
662639	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
662640	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	General Comments		
662641	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	General Comments		
662642	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
662643	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	LTC Totalizer Reading	3663.36	kw
662644	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
662645	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
662646	1/3/2019 14:46	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
662647	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
662648	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Oil Temp Max	46	°C
662649	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Oil Temp Present	19	°C
662650	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
662651	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
662652	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Cabinet Paint Condition	Good	
662653	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
662654	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Equipment Properly Labeled?	y	
662655	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Adjusted Amps A Phase V	35.67	
662656	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
662657	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
662658	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Adjusted Amps B Phase V	35.67	
662659	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Adjusted Amps C Phase V	35.67	
662660	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
662661	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC Current Tap Position	7L	
662662	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC Max Tap Position	1R	
662663	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC Min Tap Position	8L	
662664	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC Operations Since Last Insp	366	
662665	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
662666	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
662667	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
662668	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
662669	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	General Comments		
662670	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Amps A Ø	210.0	
662671	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
662672	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
662673	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Accumulated Fault Duty C Ph V	.98	%
662674	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	9 Month Operations	2	
662675	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
662676	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
662677	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
662678	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Accumulated Fault Duty B Ph V	.98	%
662679	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Accumulated Fault Duty A Ph V	4.92	%
662680	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	9 Month Operations	14	
662681	1/3/2019 10:52	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
662682	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Bushings Connection/Risers	Good	
662683	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Bushing Condition	Good	
662684	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Amps C Ø	142.0	
662685	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Amps B Ø	170.0	
662686	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Amps A Ø	132.0	
662687	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Accumulated Fault Duty C Ph V	2.66	%
662688	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Accumulated Fault Duty B Ph V	2.66	%
662689	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Accumulated Fault Duty A Ph V	2.66	%
662690	1/3/2019 14:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	9 Month Operations	7	
662691	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	LTC Operation Checked?	y	
662692	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	General Comments		
662693	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	Follow-up Action Required?	n	
662694	1/3/2019 10:41	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	All Connections OK?	y	
662695	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
662696	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
662697	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
662698	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
662699	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
662700	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
662701	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
662702	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
662703	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
662704	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
662705	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
662706	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
662707	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	General Comments		
662708	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC As Found Counter	90541	
662709	1/3/2019 12:02	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC As Left Counter	90541	
662710	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
662711	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
662712	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
662713	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
662714	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Readings	Oil Temp Max	35	°C
662715	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
662716	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Equipment Properly Labeled?	y	
662717	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Cabinet Paint Condition	Good	
662718	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
662719	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
662720	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
662721	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Bushings Connection/Risers	Good	
662722	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Bushing Condition	Good	
662723	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Amps C Ø	180.0	
662724	1/3/2019 14:13	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Amps B Ø	150.0	
662725	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Readings	Oil Temp Present	35	°C
662726	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
662727	1/3/2019 15:18	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
662728	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
662729	1/3/2019 9:05	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
662730	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
662731	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
662732	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
662733	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	5788.80	kw
662734	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	45	°C
662735	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	20	°C
662736	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
662737	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.6030	
662738	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
662739	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
662740	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
662741	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
662742	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
662743	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
662744	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
662745	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
662746	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
662747	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
662748	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
662749	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
662750	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
662751	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
662752	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
662753	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
662754	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
662755	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
662756	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
662757	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
662758	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
662759	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
662760	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
662761	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
662762	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
662763	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
662764	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
662765	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
662766	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	16L	
662767	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
662768	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
662769	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
662770	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
662771	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
662772	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
662773	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
662774	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	General Comments		
662775	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Cabinet Paint Condition	Good	
662776	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
662777	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
662778	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
662779	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
662780	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Operations A Ø	0	
662781	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Operations B Ø	0	
662782	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Operations C Ø	0	
662783	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Operations Ground	0	
662784	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
662785	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
662786	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
662787	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
662788	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Vegetation	None	
662789	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	BAT000813	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
662790	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	BAT000813	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
662791	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	BAT000813	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
662792	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	BAT000813	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
662793	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Follow-up Action Required?	n	
662794	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Follow-up Action Required?	n	
662795	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Foundation Condition	Good	
662796	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	General Comments		
662797	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	BAT000813	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
662798	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
662799	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
662800	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
662801	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
662802	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
662803	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
662804	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Foundation Condition	Good	
662805	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
662806	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
662807	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	General Comments		
662808	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
662809	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
662810	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Amps C Ø	120.0	
662811	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
662812	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
662813	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
662814	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
662815	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
662816	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
662817	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
662818	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	General Comments		
662819	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
662820	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
662821	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
662822	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
662823	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
662824	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
662825	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
662826	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
662827	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
662828	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
662829	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
662830	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
662831	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
662832	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	11L	
662833	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
662834	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
662835	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
662836	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
662837	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
662838	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
662839	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
662840	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
662841	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Tank Leaks	None	
662842	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
662843	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
662844	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
662845	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
662846	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Clear of Trash?	y	
662847	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
662848	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
662849	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
662850	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
662851	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
662852	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
662853	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
662854	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Clear of Trash?	y	
662855	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
662856	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	General Comments		
662857	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
662858	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
662859	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
662860	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
662861	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
662862	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
662863	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
662864	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
662865	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
662866	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
662867	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Foundation Condition	Good	
662868	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Free of Audible Arcing?	n	
662869	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
662870	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
662871	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Vegetation	None	
662872	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Exp Boom Corrected	
662873	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	General Comments		
662874	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	General Comments		
662875	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
662876	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.700	millivolts
662877	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	As Found Float Voltage	52.1	VDC
662878	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	As Left Float Voltage	52.1	VDC
662879	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	Battery Charger Current	10.3	amps
662880	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
662881	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	Follow-up Action Required?	n	
662882	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
662883	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
662884	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	General Comments		
662885	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
662886	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
662887	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
662888	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
662889	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
662890	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
662891	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
662892	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
662893	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	General Comments		
662894	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
662895	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
662896	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
662897	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
662898	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
662899	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
662900	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
662901	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
662902	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
662903	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
662904	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Operations A Ø	0	
662905	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
662906	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
662907	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
662908	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
662909	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
662910	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
662911	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
662912	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	BAT000813	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
662913	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	BAT000813	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
662914	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	BAT000813	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
662915	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	BAT000813	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
662916	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	General Comments		
662917	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
662918	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Vegetation	None	
662919	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Operations B Ø	0	
662920	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Operations C Ø	0	
662921	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Operations Ground	0	
662922	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
662923	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
662924	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
662925	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Follow-up Action Required?	n	
662926	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
662927	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	General Comments		
662928	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
662929	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Maintenance Operations	0	
662930	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Operations Counter AF	495	
662931	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Operations Counter AL	495	
662932	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
662933	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
662934	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
662935	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
662936	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
662937	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
662938	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	General Comments		
662939	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Switching Operations	0	
662940	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
662941	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
662942	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
662943	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Unknown Operations	0	
662944	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
662945	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
662946	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
662947	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
662948	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
662949	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
662950	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Totalizer Meter Reading	.5136	
662951	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
662952	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
662953	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
662954	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
662955	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
662956	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
662957	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
662958	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
662959	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Oil Temp Max	32	°C
662960	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
662961	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
662962	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
662963	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	General Comments		
662964	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	General Comments	No Surge Arrester Counter	
662965	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
662966	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
662967	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.4	psi
662968	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
662969	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Oil Temp Max	47	°C
662970	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Oil Temp Present	29	°C
662971	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
662972	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
662973	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
662974	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	General Comments		
662975	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
662976	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
662977	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
662978	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
662979	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
662980	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
662981	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
662982	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
662983	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
662984	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Oil Temp Present	34	°C
662985	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Oil Temp Max	53	°C
662986	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
662987	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Counter A Ø	0	
662988	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Counter B Ø	0	
662989	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Counter C Ø	0	
662990	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
662991	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
662992	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
662993	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Tank Leaks	Seeping	
662994	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
662995	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	All Identified and Legible?	y	
662996	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
662997	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
662998	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
662999	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
663000	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
663001	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
663002	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
663003	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	General Comments		
663004	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
663005	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
663006	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
663007	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
663008	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
663009	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
663010	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
663011	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
663012	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
663013	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	General Comments		
663014	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
663015	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
663016	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Tank Leaks	None	
663017	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
663018	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
663019	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	158599	
663020	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
663021	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
663022	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
663023	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
663024	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
663025	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Wood Structures OK?	y	
663026	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	9 Months Operations	0	
663027	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Accumulated Fault Duty A Ph AM	2.13	%
663028	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
663029	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Regulator As Left Counter	41328	
663030	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
663031	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
663032	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
663033	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
663034	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	312.48	kw
663035	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	227.50	
663036	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
663037	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
663038	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
663039	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
663040	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
663041	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
663042	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
663043	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
663044	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
663045	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
663046	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
663047	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
663048	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
663049	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
663050	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
663051	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
663052	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
663053	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
663054	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
663055	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
663056	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
663057	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
663058	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
663059	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
663060	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
663061	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
663062	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
663063	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
663064	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
663065	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	476	
663066	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	476	
663067	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
663068	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
663069	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
663070	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
663071	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	16L	
663072	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
663073	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
663074	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
663075	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
663076	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
663077	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
663078	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
663079	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
663080	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
663081	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
663082	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
663083	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
663084	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Amps A Ø	120.0	
663085	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Amps B Ø	120.0	
663086	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
663087	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
663088	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
663089	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
663090	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
663091	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
663092	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
663093	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
663094	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
663095	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
663096	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
663097	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
663098	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	General Comments		
663099	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	LTC Totalizer Reading	2465.28	kw
663100	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
663101	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	General Comments		
663102	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	General Comments		
663103	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
663104	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
663105	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Follow-up Action Required?	n	
663106	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
663107	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Maintenance Operations	0	
663108	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
663109	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Operations Counter AF	166	
663110	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Operations Counter AL	166	
663111	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Switching Operations	0	
663112	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
663113	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Unknown Operations	0	
663114	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
663115	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Totalizer Meter Reading	.1302	
663116	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
663117	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
663118	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
663119	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
663120	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
663121	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
663122	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Top Oil Temperature Max	47	°C
663123	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Top Oil Temperature Present	29	°C
663124	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
663125	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
663126	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	51	°C
663127	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
663128	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	51	°C
663129	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
663130	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	51	°C
663131	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
663132	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
663133	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
663134	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
663135	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
663136	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
663137	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Amps B Ø	17.0	
663138	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Amps A Ø	10.0	
663139	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
663140	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
663141	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
663142	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
663143	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
663144	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	BCH000800	Charger	362-1 Charger 1	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
663145	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
663146	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
663147	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
663148	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
663149	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
663150	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Current Tap Position	13L	
663151	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
663152	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
663153	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
663154	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
663155	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
663156	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
663157	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
663158	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
663159	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
663160	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
663161	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Tank Leaks	None	
663162	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
663163	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Regulator As Left Counter	93424	
663164	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
663165	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
663166	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Vegetation	None	
663167	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
663168	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
663169	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
663170	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	General Comments		
663171	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
663172	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
663173	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	BCH000800	Charger	362-1 Charger 1	Battery Charger Patrol Insp	Follow-up Action Required?	n	
663174	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	BCH000800	Charger	362-1 Charger 1	Battery Charger Patrol Insp	General Comments		
663175	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
663176	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
663177	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
663178	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
663179	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
663180	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Tank Leaks	None	
663181	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
663182	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
663183	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Operations Counter	13	
663184	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
663185	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
663186	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	General Comments		
663187	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
663188	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
663189	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
663190	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
663191	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
663192	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
663193	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
663194	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
663195	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
663196	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
663197	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
663198	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0006	
663199	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
663200	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
663201	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
663202	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
663203	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
663204	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
663205	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
663206	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
663207	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
663208	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
663209	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Amps C Ø	28.0	
663210	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
663211	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Oil Temp Max	47	°C
663212	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
663213	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Amps B Ø	20.0	
663214	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Amps C Ø	20.0	
663215	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Patrol Inspection	Equipment Properly Labeled?	y	
663216	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
663217	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
663218	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
663219	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	.96	kw
663220	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
663221	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
663222	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
663223	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	General Comments		
663224	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	General Comments		
663225	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
663226	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
663227	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	General Comments		
663228	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
663229	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Max Tap Position	9L	
663230	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Min Tap Position	16L	
663231	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
663232	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
663233	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
663234	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
663235	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
663236	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
663237	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Tank Paint Condition	Good	
663238	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Switching Operations	0	
663239	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
663240	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
663241	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Regulator As Left Counter	54865	
663242	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
663243	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
663244	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
663245	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
663246	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
663247	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
663248	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
663249	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
663250	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Tank Leaks	None	
663251	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
663252	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
663253	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Operations Counter AF	316	
663254	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
663255	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Maintenance Operations	0	
663256	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
663257	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
663258	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
663259	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
663260	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Maintenance Operations	0	
663261	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
663262	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	General Comments		
663263	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	General Comments		
663264	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	
663265	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Operations Counter AF	170	
663266	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Operations Counter AL	170	
663267	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Switching Operations	0	
663268	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Unknown Operations	0	
663269	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Follow-up Action Required?	n	
663270	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
663271	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Unknown Operations	0	
663272	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
663273	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
663274	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
663275	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
663276	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
663277	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
663278	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
663279	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	BCH000801	Charger	362-2 Charger 2	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
663280	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	BCH000801	Charger	362-2 Charger 2	Battery Charger Patrol Insp	Follow-up Action Required?	n	
663281	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
663282	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
663283	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
663284	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
663285	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
663286	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	General Comments		
663287	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	BCH000801	Charger	362-2 Charger 2	Battery Charger Patrol Insp	General Comments		
663288	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
663289	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
663290	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	General Comments		
663291	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
663292	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
663293	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
663294	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
663295	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
663296	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Operations A Ø	0	
663297	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Operations B Ø	0	
663298	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Operations C Ø	0	
663299	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Operations Ground	0	
663300	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Patrol Inspection	Follow-up Action Required?	n	
663301	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
663302	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Patrol Inspection	General Comments		
663303	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	General Comments		
663304	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
663305	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
663306	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	General Comments		
663307	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
663308	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
663309	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Foundation Condition	Good	
663310	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
663311	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
663312	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
663313	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
663314	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
663315	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
663316	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
663317	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Oil Temp Present	29	°C
663318	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
663319	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
663320	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
663321	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	General Comments		
663322	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Patrol Inspection	Follow-up Action Required?	n	
663323	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
663324	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
663325	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
663326	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
663327	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Operations Ground	0	
663328	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
663329	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
663330	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
663331	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
663332	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
663333	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	Follow-up Action Required?	n	
663334	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
663335	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	General Comments		
663336	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
663337	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Operations C Ø	0	
663338	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
663339	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
663340	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
663341	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Operations B Ø	0	
663342	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Operations A Ø	0	
663343	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	9 Month Operations	10	
663344	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Accumulated Fault Duty A Ph V	15.98	%
663345	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Accumulated Fault Duty B Ph V	14.14	%
663346	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Accumulated Fault Duty C Ph V	13.52	%
663347	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
663348	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
663349	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	General Comments		
663350	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC As Found Counter	20644	
663351	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
663352	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Patrol Inspection	Equipment Properly Labeled?	y	
663353	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC As Left Counter	20651	
663354	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
663355	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC Current Tap Position	8L	
663356	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC Max Tap Position	1L	
663357	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC Min Tap Position	13L	
663358	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC Operations Since Last Insp	537	
663359	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
663360	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
663361	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	LTCC000189	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
663362	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	LTCC000189	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
663363	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
663364	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
663365	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
663366	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
663367	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Regulator As Left Counter	41131	
663368	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
663369	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	VRR Time Delay	30	Seconds
663370	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
663371	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
663372	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	544	
663373	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
663374	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
663375	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	412	
663376	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
663377	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Clear of Trash?	y	
663378	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
663379	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
663380	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
663381	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Unknown Operations	0	
663382	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Switching Operations	1	
663383	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Operations Counter AL	157	
663384	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Operations Counter AF	157	
663385	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	14.3	
663386	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	9.4	
663387	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	.4	
663388	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	571	
663389	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
663390	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
663391	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Maintenance Operations	0	
663392	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	LTC Operation Checked?	y	
663393	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	General Comments		
663394	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	Follow-up Action Required?	n	
663395	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	All Connections OK?	y	
663396	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	General Comments		
663397	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Patrol Inspection	General Comments		
663398	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Follow-up Action Required?	n	
663399	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
663400	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
663401	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
663402	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
663403	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
663404	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
663405	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
663406	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	206.00	
663407	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
663408	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Oil Temp Max	47	°C
663409	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Regulator As Left Counter	42850	
663410	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
663411	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
663412	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
663413	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
663414	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
663415	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
663416	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
663417	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	BAT000814	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
663418	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
663419	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Tank Leaks	None	
663420	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	BAT000814	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
663421	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
663422	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
663423	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	General Comments	1- No door alarms, 2- No aisles, 3- No filters. Outdoor Switchgear	
663424	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
663425	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
663426	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	n	
663427	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Unknown Operations	0	
663428	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Tank Paint Condition	Good	
663429	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Switching Operations	0	
663430	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
663431	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Operations Counter AL	316	
663432	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	n	
663433	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
663434	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
663435	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BCH000605	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
663436	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BCH000605	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
663437	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BCH000605	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
663438	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BCH000605	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
663439	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BCH000605	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
663440	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
663441	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
663442	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
663443	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BCH000605	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
663444	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BCH000605	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
663445	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
663446	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	n	
663447	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	n	
663448	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
663449	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
663450	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
663451	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
663452	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	General Comments		
663453	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
663454	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
663455	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	LTCC000189	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
663456	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	LTCC000189	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
663457	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	LTCC000189	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
663458	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	LTCC000189	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
663459	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	LTCC000189	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
663460	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	LTCC000189	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
663461	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Amps C Ø	90.0	
663462	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Amps B Ø	100.0	
663463	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Amps A Ø	105.0	
663464	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	BAT000814	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
663465	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	BAT000814	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
663466	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	BAT000814	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
663467	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
663468	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
663469	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
663470	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
663471	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	BAT000814	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
663472	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	BAT000814	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
663473	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	BAT000814	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
663474	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	BAT000814	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
663475	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
663476	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
663477	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
663478	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
663479	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Accumulated Fault Duty C Ph V	11.06	%
663480	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Accumulated Fault Duty B Ph V	13.52	%
663481	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Accumulated Fault Duty A Ph V	15.98	%
663482	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	9 Month Operations	9	
663483	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
663484	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
663485	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
663486	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
663487	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	All Connections OK?	y	
663488	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	Follow-up Action Required?	n	
663489	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	General Comments		
663490	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
663491	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	LTC Operation Checked?	y	
663492	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
663493	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
663494	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Amps A Ø	20.0	
663495	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Bushing Condition	Good	
663496	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Bushings Connection/Risers	Good	
663497	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
663498	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
663499	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
663500	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
663501	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	VRR Time Delay	60	Seconds
663502	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Switching Operations	3	
663503	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Tank Paint Condition	Good	
663504	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Unknown Operations	0	
663505	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
663506	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
663507	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
663508	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
663509	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	General Comments		
663510	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
663511	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
663512	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
663513	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
663514	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	48	°C
663515	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
663516	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
663517	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
663518	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
663519	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
663520	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
663521	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
663522	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
663523	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
663524	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Current Tap Position	10L	
663525	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
663526	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
663527	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
663528	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
663529	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	General Comments		
663530	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
663531	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Max Tap Position	7L	
663532	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Min Tap Position	16L	
663533	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
663534	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
663535	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
663536	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Grounds in Place?	y	
663537	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
663538	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
663539	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
663540	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
663541	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
663542	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	General Comments		
663543	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
663544	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
663545	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
663546	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
663547	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
663548	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
663549	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	LTC Totalizer Reading	5539.20	kw
663550	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
663551	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
663552	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Oil Temp Max	55	°C
663553	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Oil Temp Present	32	°C
663554	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
663555	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	Oil Temp Max	55	°C
663556	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	Oil Temp Present	40	°C
663557	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
663558	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
663559	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Operations B Ø	0	
663560	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
663561	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
663562	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
663563	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
663564	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
663565	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
663566	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
663567	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
663568	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
663569	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	60	°C
663570	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	48	°C
663571	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	62	°C
663572	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	48	°C
663573	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	65	°C
663574	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Operations C Ø	0	
663575	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Operations Ground	0	
663576	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Follow-up Action Required?	n	
663577	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Follow-up Action Required?	n	
663578	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
663579	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
663580	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
663581	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
663582	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
663583	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
663584	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
663585	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Foundation Condition	Good	
663586	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	General Comments		
663587	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	General Comments		
663588	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Grounds in Place?	y	
663589	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Heaters (All) Functioning?	y	
663590	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Maintenance Operations	0	
663591	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Moisture and Leak Free?	y	
663592	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Operations Counter AF	226	
663593	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Operations Counter AL	228	
663594	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
663595	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
663596	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Oil Temp Max	55	°C
663597	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
663598	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
663599	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
663600	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
663601	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
663602	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
663603	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
663604	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
663605	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
663606	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
663607	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
663608	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
663609	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
663610	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
663611	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
663612	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
663613	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
663614	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
663615	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
663616	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
663617	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
663618	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Operations Counter AL	253	
663619	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Operations Counter AF	253	
663620	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
663621	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
663622	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
663623	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
663624	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
663625	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
663626	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Grounds in Place?	y	
663627	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Heaters (All) Functioning?	y	
663628	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Maintenance Operations	0	
663629	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Moisture and Leak Free?	y	
663630	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Follow-up Action Required?	n	
663631	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
663632	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
663633	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
663634	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
663635	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
663636	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Moisture and Leak Free?	y	
663637	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	General Comments		
663638	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
663639	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
663640	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
663641	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
663642	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
663643	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
663644	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
663645	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
663646	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
663647	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	General Comments		
663648	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
663649	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
663650	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
663651	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
663652	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
663653	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
663654	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
663655	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
663656	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
663657	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
663658	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	General Comments		
663659	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
663660	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Totalizer Meter Reading	1.1540	
663661	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
663662	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
663663	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
663664	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
663665	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
663666	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Regulator As Left Counter	50808	
663667	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
663668	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
663669	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Tank Leaks	None	
663670	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
663671	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Unknown Operations	0	
663672	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Tank Paint Condition	Good	
663673	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Switching Operations	0	
663674	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
663675	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
663676	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
663677	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
663678	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
663679	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
663680	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
663681	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
663682	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
663683	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
663684	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
663685	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
663686	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
663687	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
663688	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
663689	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	General Comments		
663690	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Foundation Condition	Good	
663691	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Follow-up Action Required?	n	
663692	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Equipment Properly Labeled?	y	
663693	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Cabinet Paint Condition	Good	
663694	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
663695	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
663696	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
663697	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
663698	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
663699	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
663700	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
663701	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
663702	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
663703	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Amps A Ø	430.0	
663704	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Accumulated Fault Duty C Ph V	5.68	%
663705	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Accumulated Fault Duty B Ph V	5.68	%
663706	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
663707	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Bushings Connection/Risers	Good	
663708	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Bushing Condition	Good	
663709	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Amps A Ø	84.0	
663710	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Amps B Ø	105.0	
663711	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Amps C Ø	102.0	
663712	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
663713	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
663714	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
663715	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
663716	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
663717	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
663718	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
663719	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
663720	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
663721	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
663722	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	General Comments		
663723	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
663724	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
663725	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Operations Counter	7	
663726	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
663727	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Amps C Ø	85.0	
663728	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Amps B Ø	95.0	
663729	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Amps A Ø	90.0	
663730	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Accumulated Fault Duty C Ph V	2.27	%
663731	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Accumulated Fault Duty B Ph V	5.68	%
663732	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
663733	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
663734	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Equipment Properly Labeled?	y	
663735	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Cabinet Paint Condition	Good	
663736	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
663737	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
663738	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
663739	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Bushings Connection/Risers	Good	
663740	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Bushing Condition	Good	
663741	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Amps C Ø	430.0	
663742	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Amps B Ø	420.0	
663743	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
663744	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
663745	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
663746	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
663747	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
663748	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
663749	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
663750	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
663751	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
663752	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
663753	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Operations A Ø	0	
663754	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Operations B Ø	0	
663755	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Operations C Ø	0	
663756	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Operations Ground	0	
663757	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Follow-up Action Required?	n	
663758	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Follow-up Action Required?	n	
663759	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
663760	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
663761	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
663762	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
663763	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Foundation Condition	Good	
663764	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Foundation Condition	Good	
663765	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	General Comments		
663766	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
663767	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
663768	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
663769	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	General Comments		
663770	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
663771	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
663772	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
663773	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
663774	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
663775	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
663776	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
663777	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
663778	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
663779	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
663780	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Panel Lights OK?	y	
663781	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Moisture and Leak Free?	y	
663782	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	General Comments		
663783	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
663784	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Follow-up Action Required?	n	
663785	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Floor Swept?	y	
663786	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Floor Condition Acceptable?	y	
663787	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
663788	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
663789	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Tank Leaks	None	
663790	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
663791	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Evidence of Insects	None	
663792	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Doors and Locks Secure?	y	
663793	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Door Alarms OK?	y	
663794	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
663795	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Control House Lighting OK?	y	
663796	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Broom on Site?	y	
663797	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
663798	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
663799	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
663800	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
663801	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Cabinet Paint Condition	Good	
663802	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Equipment Properly Labeled?	y	
663803	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
663804	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
663805	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
663806	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
663807	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
663808	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
663809	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
663810	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
663811	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
663812	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
663813	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
663814	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Operations A Ø	0	
663815	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
663816	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
663817	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
663818	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
663819	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
663820	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
663821	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	General Comments		
663822	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
663823	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
663824	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
663825	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	9 Month Operations	5	
663826	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Accumulated Fault Duty A Ph V	5.68	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
663827	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
663828	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
663829	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	General Comments		
663830	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
663831	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	9 Month Operations	5	
663832	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
663833	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
663834	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
663835	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
663836	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
663837	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
663838	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
663839	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
663840	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Follow-up Action Required?	n	
663841	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
663842	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
663843	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	General Comments		
663844	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	General Comments		
663845	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
663846	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	General Comments		
663847	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
663848	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
663849	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
663850	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
663851	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
663852	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
663853	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
663854	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
663855	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
663856	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
663857	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
663858	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
663859	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
663860	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
663861	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
663862	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
663863	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
663864	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
663865	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Ventilation Free of Debris?	y	
663866	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Trash Emptied?	y	
663867	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Switch Diagram Present/Current	y	
663868	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Station Ground Set On Site?	y	
663869	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Panels Dusted?	y	
663870	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
663871	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
663872	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
663873	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
663874	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
663875	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
663876	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
663877	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Ambient Temp	44	°F
663878	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
663879	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
663880	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
663881	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
663882	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
663883	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Follow-up Action Required?	n	
663884	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
663885	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
663886	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
663887	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
663888	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	General Comments		
663889	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	General Comments		
663890	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
663891	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
663892	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
663893	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Vegetation	None	
663894	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
663895	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
663896	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
663897	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	LTC Totalizer Reading	6134.40	kw
663898	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
663899	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	Seeping	
663900	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
663901	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
663902	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
663903	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Oil Temp Max	55	°C
663904	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Oil Temp Present	45	°C
663905	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
663906	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
663907	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
663908	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
663909	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Clear of Trash?	y	
663910	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
663911	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
663912	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
663913	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
663914	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
663915	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
663916	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
663917	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
663918	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
663919	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Switching Operations	3	
663920	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
663921	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
663922	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
663923	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	751	
663924	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
663925	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Clear of Trash?	y	
663926	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
663927	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
663928	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
663929	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
663930	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LTCC000475	LTCControl	BR-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
663931	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LTCC000475	LTCControl	BR-TRANS 3	LTC Control Insp	General Comments		
663932	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LTCC000475	LTCControl	BR-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
663933	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Tank Paint Condition	Good	
663934	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	751	
663935	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Unknown Operations	0	
663936	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	264	
663937	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
663938	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
663939	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
663940	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	General Comments		
663941	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
663942	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
663943	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
663944	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
663945	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
663946	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
663947	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
663948	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
663949	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
663950	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
663951	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
663952	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
663953	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
663954	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
663955	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
663956	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
663957	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
663958	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
663959	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
663960	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
663961	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
663962	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
663963	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	General Comments		
663964	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
663965	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	LTCC000513	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
663966	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	LTCC000513	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
663967	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	LTCC000513	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
663968	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	LTCC000513	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
663969	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	LTCC000513	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
663970	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	LTCC000513	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
663971	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	LTCC000513	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
663972	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
663973	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Totalizer Meter Reading	1.2780	
663974	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
663975	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Tank Paint Condition	Good	
663976	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
663977	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
663978	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
663979	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Moisture and Leak Free?	y	
663980	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
663981	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Heaters (All) Functioning?	y	
663982	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Grounds in Place?	y	
663983	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	General Comments		
663984	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Foundation Condition	Good	
663985	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Follow-up Action Required?	n	
663986	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Equipment Properly Labeled?	y	
663987	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Cabinet Paint Condition	Good	
663988	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
663989	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
663990	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
663991	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Bushings Connection/Risers	Good	
663992	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Bushing Condition	Good	
663993	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
663994	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
663995	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
663996	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
663997	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
663998	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
663999	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
664000	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
664001	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
664002	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
664003	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
664004	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
664005	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
664006	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
664007	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	LTCC000513	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
664008	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
664009	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
664010	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
664011	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	General Comments		
664012	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
664013	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
664014	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
664015	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
664016	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
664017	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
664018	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
664019	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
664020	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
664021	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	9 Month Operations	0	
664022	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
664023	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
664024	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
664025	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
664026	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Vegetation	None	
664027	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Yard Lights Working?	y	
664028	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Amps A Ø	249.0	
664029	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Amps B Ø	237.0	
664030	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
664031	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
664032	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
664033	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Amps C Ø	240.0	
664034	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
664035	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
664036	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	General Comments		
664037	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	General Comments	Oil seeping around the liquid level gauge	
664038	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
664039	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
664040	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
664041	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
664042	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
664043	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
664044	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
664045	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
664046	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
664047	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
664048	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
664049	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
664050	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Operations Ground	0	
664051	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
664052	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
664053	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
664054	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	General Comments		
664055	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
664056	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
664057	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
664058	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
664059	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
664060	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Totalizer Meter Reading	.8796	
664061	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
664062	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
664063	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Clear of Trash?	y	
664064	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
664065	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Tank Paint Condition	Good	
664066	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Tank Oil Level	Good	
664067	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Tank Leaks	None	
664068	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Operations Counter AF	221	
664069	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Operations Counter AL	224	
664070	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
664071	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Moisture and Leak Free?	y	
664072	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
664073	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
664074	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	264	
664075	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
664076	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
664077	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
664078	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
664079	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
664080	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
664081	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
664082	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
664083	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
664084	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
664085	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
664086	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
664087	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
664088	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
664089	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
664090	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
664091	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	General Comments		
664092	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
664093	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Vegetation	None	
664094	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
664095	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
664096	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Operations Ground	0	
664097	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
664098	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
664099	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
664100	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	General Comments		
664101	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
664102	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
664103	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	General Comments		
664104	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Maintenance Operations	0	
664105	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Heaters (All) Functioning?	y	
664106	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Grounds in Place?	y	
664107	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	General Comments		
664108	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
664109	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
664110	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
664111	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
664112	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
664113	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
664114	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
664115	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
664116	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
664117	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	9 Month Operations	1	
664118	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
664119	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
664120	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
664121	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Amps A Ø	250.0	
664122	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
664123	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
664124	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
664125	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC Operations Since Last Insp	706	
664126	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Ambient Temp	45	°F

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
664127	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
664128	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Amps B Ø	238.0	
664129	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Amps C Ø	242.0	
664130	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
664131	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
664132	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
664133	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
664134	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
664135	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
664136	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
664137	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	General Comments		
664138	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
664139	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	LTC Totalizer Reading	4222.08	kw
664140	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
664141	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
664142	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Oil Temp Max	55	°C
664143	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Oil Temp Present	35	°C
664144	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
664145	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
664146	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
664147	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
664148	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
664149	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
664150	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
664151	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
664152	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
664153	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
664154	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
664155	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Accumulated Fault Duty B Ph V	7.12	%
664156	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Accumulated Fault Duty C Ph V	7.83	%
664157	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Amps A Ø	75.0	
664158	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Amps B Ø	75.0	
664159	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
664160	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
664161	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
664162	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
664163	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
664164	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
664165	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
664166	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
664167	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
664168	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
664169	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Amps C Ø	60.0	
664170	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Bushing Condition	Good	
664171	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Bushings Connection/Risers	Good	
664172	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Heaters (All) Functioning?	y	
664173	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Grounds in Place?	y	
664174	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	General Comments		
664175	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Foundation Condition	Good	
664176	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
664177	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
664178	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
664179	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
664180	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
664181	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Follow-up Action Required?	n	
664182	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Equipment Properly Labeled?	y	
664183	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Cabinet Paint Condition	Good	
664184	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
664185	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
664186	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
664187	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
664188	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
664189	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
664190	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Bushings Connection/Risers	Good	
664191	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
664192	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Bushing Condition	Good	
664193	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	General Comments		
664194	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
664195	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
664196	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
664197	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC Min Tap Position	12L	
664198	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC Max Tap Position	2L	
664199	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC Current Tap Position	2L	
664200	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
664201	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC As Left Counter	9480	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
664202	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC As Found Counter	9480	
664203	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	General Comments		
664204	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	General Comments		
664205	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
664206	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	Follow-up Action Required?	n	
664207	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
664208	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
664209	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
664210	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
664211	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
664212	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
664213	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
664214	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
664215	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
664216	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
664217	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
664218	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Maintenance Operations	0	
664219	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
664220	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Tank Paint Condition	Good	
664221	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
664222	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Moisture and Leak Free?	y	
664223	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
664224	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Operations Counter AF	128	
664225	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Operations Counter AL	128	
664226	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Switching Operations	0	
664227	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
664228	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Unknown Operations	0	
664229	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
664230	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
664231	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
664232	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
664233	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
664234	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
664235	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
664236	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
664237	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
664238	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	9 Month Operations	5	
664239	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Accumulated Fault Duty A Ph V	7.83	%
664240	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
664241	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
664242	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
664243	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
664244	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
664245	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
664246	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
664247	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
664248	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
664249	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
664250	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
664251	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
664252	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
664253	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
664254	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
664255	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
664256	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
664257	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	726	
664258	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	726	
664259	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
664260	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
664261	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
664262	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
664263	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
664264	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
664265	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
664266	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
664267	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
664268	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
664269	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
664270	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
664271	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
664272	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
664273	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
664274	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
664275	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
664276	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
664277	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
664278	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
664279	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
664280	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
664281	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	General Comments		
664282	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Nitro bottle needs to be filled	
664283	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
664284	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Operations Ground	0	
664285	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Operations C Ø	0	
664286	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Operations B Ø	0	
664287	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Operations A Ø	0	
664288	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
664289	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
664290	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
664291	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
664292	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Amps C Ø	0.0	
664293	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Amps B Ø	0.0	
664294	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Amps A Ø	0.0	
664295	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
664296	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
664297	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
664298	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	9 Months Operations	0	
664299	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
664300	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	General Comments		
664301	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
664302	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	General Comments		
664303	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
664304	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
664305	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
664306	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
664307	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
664308	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
664309	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
664310	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
664311	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
664312	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
664313	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
664314	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
664315	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
664316	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
664317	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
664318	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
664319	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
664320	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
664321	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
664322	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
664323	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
664324	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
664325	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
664326	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
664327	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC As Found Counter	10410	
664328	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC As Left Counter	10410	
664329	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
664330	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10R	
664331	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC Max Tap Position	11R	
664332	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8R	
664333	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
664334	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	92	
664335	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
664336	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
664337	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
664338	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
664339	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	General Comments	2 arresters blowed on cir,414.and one arrester blown on cir.415	
664340	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
664341	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
664342	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Foundation Condition	Good	
664343	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
664344	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
664345	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
664346	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
664347	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
664348	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
664349	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
664350	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
664351	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
664352	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
664353	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
664354	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
664355	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	General Comments		
664356	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
664357	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
664358	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
664359	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
664360	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
664361	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
664362	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
664363	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
664364	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
664365	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
664366	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
664367	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
664368	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
664369	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
664370	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
664371	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
664372	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.4	psi
664373	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
664374	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
664375	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
664376	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
664377	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
664378	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
664379	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
664380	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
664381	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
664382	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
664383	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
664384	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
664385	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
664386	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
664387	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
664388	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
664389	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
664390	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
664391	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
664392	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
664393	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
664394	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
664395	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
664396	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	General Comments		
664397	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
664398	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
664399	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
664400	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
664401	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
664402	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Tank Leaks	None	
664403	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
664404	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
664405	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
664406	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
664407	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
664408	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
664409	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
664410	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
664411	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
664412	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	General Comments		
664413	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
664414	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3	psi
664415	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Oil Temp Max	55	°C
664416	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Oil Temp Present	24	°C
664417	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
664418	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
664419	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
664420	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	9 Month Operations	8	
664421	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Accumulated Fault Duty A Ph V	49.90	%
664422	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Accumulated Fault Duty B Ph V	53.86	%
664423	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
664424	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
664425	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
664426	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
664427	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
664428	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Totalizer Meter Reading	.4854	
664429	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
664430	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
664431	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
664432	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Amps A Ø	36.0	
664433	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Amps B Ø	48.0	
664434	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Amps C Ø	48.0	
664435	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
664436	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
664437	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
664438	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
664439	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
664440	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
664441	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
664442	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
664443	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
664444	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
664445	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	General Comments		
664446	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
664447	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LTCC000838	LTCControl	BR-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
664448	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LTCC000838	LTCControl	BR-TRANS 1	LTC Control Insp	General Comments		
664449	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LTCC000838	LTCControl	BR-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
664450	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
664451	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
664452	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LTCC000839	LTCControl	BR-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
664453	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LTCC000839	LTCControl	BR-TRANS 2	LTC Control Insp	General Comments		
664454	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LTCC000839	LTCControl	BR-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
664455	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
664456	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
664457	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Patrol Inspection	Follow-up Action Required?	n	
664458	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Follow-up Action Required?	n	
664459	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Patrol Inspection	General Comments		
664460	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	General Comments		
664461	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Maintenance Operations	0	
664462	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Operations Counter AF	245	
664463	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Operations Counter AL	245	
664464	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Switching Operations	0	
664465	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Unknown Operations	0	
664466	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Operations A Ø	0	
664467	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
664468	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
664469	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
664470	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
664471	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Amps C Ø	0.0	
664472	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Amps B Ø	0.0	
664473	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Amps A Ø	0.0	
664474	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
664475	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
664476	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
664477	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	9 Months Operations	0	
664478	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
664479	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
664480	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
664481	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
664482	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
664483	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
664484	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
664485	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
664486	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
664487	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
664488	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
664489	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
664490	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
664491	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
664492	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
664493	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Follow-up Action Required?	n	
664494	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
664495	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
664496	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	General Comments		
664497	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	General Comments		
664498	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
664499	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	LTC Totalizer Reading	1553.28	kw
664500	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
664501	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
664502	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
664503	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
664504	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
664505	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
664506	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
664507	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
664508	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
664509	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
664510	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
664511	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Tank Leaks	None	
664512	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
664513	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
664514	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124	VAC
664515	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124	VAC
664516	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
664517	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
664518	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
664519	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	General Comments		
664520	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Amps C Ø	12.0	
664521	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Bushing Condition	Good	
664522	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Bushings Connection/Risers	Good	
664523	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
664524	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
664525	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
664526	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Cabinet Paint Condition	Good	
664527	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Equipment Properly Labeled?	y	
664528	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
664529	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
664530	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
664531	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
664532	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
664533	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
664534	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
664535	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
664536	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.2	psi
664537	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
664538	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
664539	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	41	°F
664540	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
664541	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
664542	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Patrol Inspection	General Comments		
664543	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Follow-up Action Required?	n	
664544	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
664545	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
664546	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
664547	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
664548	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Vegetation	None	
664549	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
664550	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	General Comments		
664551	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
664552	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
664553	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	Oil Temp Present	25	°C
664554	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	Oil Temp Max	54	°C
664555	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Unknown Operations	0	
664556	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Switching Operations	0	
664557	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Operations Counter AL	524	
664558	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Operations Counter AF	524	
664559	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Maintenance Operations	0	
664560	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
664561	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
664562	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
664563	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Clear of Trash?	y	
664564	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
664565	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
664566	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
664567	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
664568	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Operations Counter	1851	
664569	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
664570	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
664571	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
664572	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0	VDC
664573	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0	VDC
664574	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
664575	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
664576	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
664577	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
664578	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
664579	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BAT000602	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
664580	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Accumulated Fault Duty C Ph V	48.31	%
664581	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Amps A Ø	12.0	
664582	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Amps B Ø	12.0	
664583	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
664584	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
664585	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
664586	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
664587	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
664588	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Operations Counter AF	99984	
664589	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Operations Counter AL	99989	
664590	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
664591	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	General Comments		
664592	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
664593	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
664594	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
664595	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
664596	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
664597	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
664598	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
664599	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
664600	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Tank Leaks	None	
664601	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
664602	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
664603	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Regulator As Left Counter	28090	
664604	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
664605	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
664606	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
664607	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
664608	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
664609	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
664610	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
664611	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
664612	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Switching Operations	6	
664613	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Tank Paint Condition	Good	
664614	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Unknown Operations	0	
664615	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
664616	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
664617	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
664618	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	General Comments		
664619	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
664620	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
664621	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
664622	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
664623	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
664624	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
664625	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
664626	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
664627	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
664628	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
664629	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
664630	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
664631	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	Follow-up Action Required?	n	
664632	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
664633	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	General Comments		
664634	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	General Comments		
664635	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC As Found Counter	11006	
664636	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC As Left Counter	11006	
664637	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
664638	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC Current Tap Position	1L	
664639	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC Max Tap Position	1L	
664640	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC Min Tap Position	12L	
664641	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC Operations Since Last Insp	628	
664642	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
664643	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
664644	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
664645	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	9 Month Operations	10	
664646	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Accumulated Fault Duty A Ph V	.49	%
664647	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Accumulated Fault Duty B Ph V	.49	%
664648	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
664649	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Amps A Ø	24.0	
664650	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Amps B Ø	24.0	
664651	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Amps C Ø	24.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
664652	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Bushing Condition	Good	
664653	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Bushings Connection/Risers	Good	
664654	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
664655	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
664656	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
664657	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
664658	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Cabinet Paint Condition	Good	
664659	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Equipment Properly Labeled?	y	
664660	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
664661	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
664662	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
664663	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Operations A Ø	0	
664664	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Operations B Ø	0	
664665	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Operations C Ø	0	
664666	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Operations Ground	0	
664667	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Follow-up Action Required?	n	
664668	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Follow-up Action Required?	n	
664669	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Foundation Condition	Good	
664670	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	General Comments		
664671	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	General Comments	1 blown arrestor	
664672	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Grounds in Place?	y	
664673	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Maintenance Operations	0	
664674	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Moisture and Leak Free?	y	
664675	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Amps B Ø	0.0	
664676	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Amps C Ø	0.0	
664677	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
664678	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
664679	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
664680	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
664681	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
664682	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
664683	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
664684	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
664685	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
664686	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
664687	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
664688	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
664689	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
664690	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
664691	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
664692	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	General Comments		
664693	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
664694	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
664695	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
664696	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	Follow-up Action Required?	n	
664697	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
664698	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	General Comments		
664699	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	General Comments		
664700	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC As Found Counter	7228	
664701	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC As Left Counter	7228	
664702	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
664703	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC Current Tap Position	4L	
664704	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
664705	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC Min Tap Position	4L	
664706	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC Operations Since Last Insp	411	
664707	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
664708	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
664709	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
664710	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
664711	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
664712	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	356	
664713	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	356	
664714	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
664715	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
664716	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
664717	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
664718	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
664719	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
664720	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
664721	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
664722	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
664723	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1	psi
664724	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
664725	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
664726	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
664727	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
664728	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
664729	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
664730	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
664731	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
664732	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
664733	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
664734	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
664735	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
664736	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
664737	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
664738	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
664739	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
664740	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
664741	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
664742	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
664743	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
664744	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
664745	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
664746	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
664747	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Tank Leaks	None	
664748	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
664749	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Radiator Leaks	None	
664750	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
664751	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Grounds in Place?	y	
664752	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	General Comments		
664753	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
664754	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Foundation Condition	Good	
664755	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
664756	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
664757	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	9 Months Operations	0	
664758	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
664759	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
664760	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
664761	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Amps A Ø	0.0	
664762	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
664763	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
664764	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
664765	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Clear of Trash?	y	
664766	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
664767	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
664768	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
664769	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
664770	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	2	
664771	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	466	
664772	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	466	
664773	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
664774	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
664775	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Moisture and Leak Free?	y	
664776	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Operations Counter AF	427	
664777	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Operations Counter AL	427	
664778	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
664779	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
664780	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
664781	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
664782	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
664783	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
664784	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
664785	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
664786	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
664787	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
664788	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
664789	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
664790	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	262.0	
664791	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	248.0	
664792	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	225.0	
664793	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
664794	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
664795	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
664796	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
664797	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
664798	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
664799	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
664800	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
664801	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
664802	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Current Tap Position	11L	
664803	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
664804	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
664805	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
664806	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
664807	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
664808	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
664809	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
664810	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
664811	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
664812	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
664813	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
664814	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Operations A Ø	0	
664815	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Operations B Ø	0	
664816	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Operations C Ø	0	
664817	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Operations Ground	0	
664818	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Follow-up Action Required?	n	
664819	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Follow-up Action Required?	n	
664820	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Foundation Condition	Good	
664821	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	General Comments		
664822	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	General Comments		
664823	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Grounds in Place?	y	
664824	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Maintenance Operations	0	
664825	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
664826	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
664827	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
664828	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
664829	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Vegetation	None	
664830	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Exp Boom Corrected	
664831	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	General Comments		
664832	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
664833	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
664834	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
664835	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
664836	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
664837	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
664838	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
664839	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
664840	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
664841	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
664842	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
664843	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
664844	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
664845	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
664846	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
664847	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
664848	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	General Comments		
664849	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
664850	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Vegetation	None	
664851	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
664852	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
664853	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
664854	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
664855	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1R	
664856	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
664857	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
664858	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
664859	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
664860	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
664861	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
664862	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
664863	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
664864	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
664865	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
664866	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	PF000039	PowerFuse	BR-GND TR 1	Disconnect Powerfuse Inspection	General Comments	OK	
664867	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	PF000039	PowerFuse	BR-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
664868	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	PF000038	PowerFuse	BR-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
664869	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	PF000038	PowerFuse	BR-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
664870	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Switching Operations	0	
664871	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Tank Paint Condition	Good	
664872	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Unknown Operations	0	
664873	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
664874	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
664875	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
664876	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
664877	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
664878	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
664879	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
664880	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
664881	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
664882	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
664883	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
664884	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
664885	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
664886	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
664887	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
664888	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
664889	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
664890	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	General Comments		
664891	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
664892	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
664893	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
664894	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	General Comments		
664895	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
664896	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Max Tap Position	5L	
664897	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Min Tap Position	16L	
664898	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
664899	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
664900	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
664901	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
664902	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
664903	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Regulator As Left Counter	58242	
664904	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
664905	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
664906	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Tank Leaks	None	
664907	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
664908	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
664909	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
664910	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
664911	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Clear of Trash?	y	
664912	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
664913	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
664914	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
664915	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
664916	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
664917	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	General Comments		
664918	1/2/2019 15:03	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
664919	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	PF000071	PowerFuse	CY-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
664920	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	PF000071	PowerFuse	CY-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
664921	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	PF000042	PowerFuse	BR-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
664922	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	PF000042	PowerFuse	BR-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
664923	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
664924	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
664925	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
664926	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
664927	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	480212	
664928	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
664929	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
664930	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
664931	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
664932	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
664933	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
664934	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	2R	
664935	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
664936	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	General Comments		
664937	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
664938	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	General Comments		
664939	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
664940	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
664941	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
664942	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
664943	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
664944	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
664945	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
664946	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
664947	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	PF000048	PowerFuse	BR-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
664948	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
664949	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	PF000048	PowerFuse	BR-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	OK	
664950	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
664951	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
664952	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
664953	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
664954	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
664955	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC Operations Since Last Insp	564	
664956	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
664957	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC Min Tap Position	11L	
664958	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC Max Tap Position	1R	
664959	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC Current Tap Position	6L	
664960	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
664961	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC As Left Counter	133986	
664962	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC As Found Counter	133975	
664963	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	General Comments		
664964	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	General Comments		
664965	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
664966	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	Follow-up Action Required?	n	
664967	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	Follow-up Action Required?	n	
664968	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
664969	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Tank Leaks	None	
664970	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
664971	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
664972	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Regulator As Left Counter	20774	
664973	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
664974	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
664975	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
664976	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
664977	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
664978	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Min Tap Position	10L	
664979	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
664980	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
664981	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
664982	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
664983	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
664984	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
664985	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
664986	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
664987	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
664988	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Oil Temp Max	24	°C
664989	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Operations Counter AF	224	
664990	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Operations Counter AL	224	
664991	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Switching Operations	0	
664992	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Tank Paint Condition	Good	
664993	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Unknown Operations	0	
664994	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
664995	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Tank Leaks	None	
664996	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
664997	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
664998	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Regulator As Left Counter	23711	
664999	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
665000	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
665001	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
665002	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
665003	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
665004	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Min Tap Position	9L	
665005	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Max Tap Position	1R	
665006	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
665007	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	General Comments		
665008	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
665009	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
665010	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
665011	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
665012	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Current Tap Position	3L	
665013	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
665014	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
665015	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
665016	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
665017	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
665018	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
665019	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
665020	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
665021	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
665022	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
665023	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
665024	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
665025	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
665026	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
665027	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
665028	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
665029	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
665030	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
665031	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
665032	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
665033	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
665034	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
665035	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
665036	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Foundation Condition	Good	
665037	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
665038	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
665039	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	General Comments		
665040	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
665041	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
665042	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
665043	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
665044	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
665045	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
665046	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
665047	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
665048	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
665049	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
665050	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
665051	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
665052	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
665053	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
665054	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
665055	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
665056	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
665057	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
665058	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
665059	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
665060	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
665061	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
665062	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
665063	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
665064	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
665065	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	9 Month Operations	2	
665066	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Max Tap Position	1L	
665067	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
665068	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	General Comments		
665069	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
665070	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
665071	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
665072	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
665073	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Current Tap Position	4L	
665074	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
665075	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
665076	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
665077	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
665078	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
665079	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
665080	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	General Comments		
665081	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	General Comments		
665082	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC As Found Counter	273394	
665083	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC As Left Counter	273401	
665084	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
665085	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC Current Tap Position	9L	
665086	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC Max Tap Position	5L	
665087	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC Min Tap Position	13L	
665088	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC Operations Since Last Insp	494	
665089	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	VRR Time Delay	60	Seconds
665090	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
665091	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
665092	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
665093	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	LTC Operation Checked?	y	
665094	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	General Comments		
665095	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
665096	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
665097	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	Follow-up Action Required?	n	
665098	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	All Connections OK?	y	
665099	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	PF000047	PowerFuse	BR-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
665100	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	PF000047	PowerFuse	BR-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	OK	
665101	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LTCC000538	LTCControl	CY-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
665102	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LTCC000538	LTCControl	CY-TRANS 1	LTC Control Insp	General Comments		
665103	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LTCC000538	LTCControl	CY-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
665104	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
665105	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
665106	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	497	
665107	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	497	
665108	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
665109	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
665110	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Accumulated Fault Duty B Ph V	.34	%
665111	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Accumulated Fault Duty C Ph V	1.36	%
665112	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Amps A Ø	20.0	
665113	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Amps B Ø	40.0	
665114	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Amps C Ø	50.0	
665115	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Bushing Condition	Good	
665116	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Bushings Connection/Risers	Good	
665117	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
665118	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
665119	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
665120	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Cabinet Paint Condition	Good	
665121	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Equipment Properly Labeled?	y	
665122	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
665123	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Operations Ground	0	
665124	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Operations C Ø	0	
665125	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Operations B Ø	0	
665126	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Operations A Ø	0	
665127	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
665128	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
665129	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Operations A Ø	0	
665130	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Operations B Ø	0	
665131	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Operations C Ø	0	
665132	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Operations Ground	0	
665133	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Follow-up Action Required?	n	
665134	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Follow-up Action Required?	n	
665135	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Foundation Condition	Good	
665136	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	General Comments		
665137	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	General Comments		
665138	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Grounds in Place?	y	
665139	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Maintenance Operations	0	
665140	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Moisture and Leak Free?	y	
665141	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Operations Counter AF	188	
665142	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Operations Counter AL	190	
665143	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Tank Paint Condition	Good	
665144	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
665145	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Moisture and Leak Free?	y	
665146	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Heaters (All) Functioning?	y	
665147	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Grounds in Place?	y	
665148	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	General Comments		
665149	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Foundation Condition	Good	
665150	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Follow-up Action Required?	n	
665151	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Equipment Properly Labeled?	y	
665152	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Cabinet Paint Condition	Good	
665153	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
665154	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
665155	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
665156	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
665157	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
665158	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
665159	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
665160	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
665161	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
665162	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
665163	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
665164	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
665165	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Follow-up Action Required?	n	
665166	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
665167	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
665168	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	General Comments		
665169	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	General Comments		
665170	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
665171	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	LTC Totalizer Reading	5664.00	kw
665172	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
665173	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
665174	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Oil Temp Max	45	°C
665175	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Oil Temp Present	30	°C
665176	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
665177	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
665178	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
665179	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
665180	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Tank Paint Condition	Good	
665181	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
665182	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Moisture and Leak Free?	y	
665183	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Heaters (All) Functioning?	y	
665184	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Grounds in Place?	y	
665185	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	General Comments		
665186	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Foundation Condition	Good	
665187	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Follow-up Action Required?	n	
665188	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Equipment Properly Labeled?	y	
665189	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Cabinet Paint Condition	Good	
665190	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
665191	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
665192	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
665193	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Bushings Connection/Risers	Good	
665194	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Bushing Condition	Good	
665195	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	9 Month Operations	11	
665196	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Accumulated Fault Duty A Ph V	1.36	%
665197	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
665198	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
665199	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
665200	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
665201	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
665202	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
665203	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	9 Month Operations	6	
665204	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
665205	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
665206	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
665207	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
665208	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Totalizer Meter Reading	.5900	
665209	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
665210	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
665211	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
665212	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
665213	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
665214	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
665215	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
665216	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
665217	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
665218	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
665219	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
665220	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
665221	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
665222	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
665223	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
665224	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
665225	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
665226	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
665227	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
665228	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
665229	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
665230	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Follow-up Action Required?	n	
665231	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Follow-up Action Required?	n	
665232	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Foundation Condition	Good	
665233	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	General Comments		
665234	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	General Comments		
665235	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Grounds in Place?	y	
665236	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Maintenance Operations	0	
665237	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Moisture and Leak Free?	y	
665238	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Winding Temp Present	20	°C
665239	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Winding Temp Max	24	°C
665240	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
665241	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
665242	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	General Comments		
665243	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	Follow-up Action Required?	n	
665244	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
665245	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
665246	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	All Lights Functioning?	y	
665247	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
665248	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Bushings Connection/Risers	Good	
665249	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Bushing Condition	Good	
665250	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
665251	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
665252	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	LTCC000321	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
665253	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	LTCC000321	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
665254	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	LTCC000321	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
665255	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	LTCC000321	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
665256	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	LTCC000321	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
665257	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	LTCC000321	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
665258	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	LTCC000321	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
665259	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	LTCC000321	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
665260	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
665261	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Equipment Properly Labeled?	y	
665262	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Cabinet Paint Condition	Good	
665263	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
665264	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
665265	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
665266	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Bushings Connection/Risers	Good	
665267	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Bushing Condition	Good	
665268	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Amps C Ø	80.0	
665269	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Amps B Ø	63.0	
665270	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Amps A Ø	85.0	
665271	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
665272	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Accumulated Fault Duty B Ph V	3.18	%
665273	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Accumulated Fault Duty A Ph V	2.38	%
665274	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Switching Operations	2	
665275	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Tank Paint Condition	Good	
665276	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Unknown Operations	0	
665277	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
665278	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
665279	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
665280	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
665281	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
665282	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
665283	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
665284	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
665285	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
665286	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Operations A Ø	0	
665287	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	57	°C
665288	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Operations B Ø	0	
665289	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Operations C Ø	0	
665290	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Operations Ground	0	
665291	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Follow-up Action Required?	n	
665292	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Follow-up Action Required?	n	
665293	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Foundation Condition	Good	
665294	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	General Comments		
665295	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	General Comments	2 blown arrestors	
665296	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Grounds in Place?	y	
665297	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Maintenance Operations	0	
665298	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Moisture and Leak Free?	y	
665299	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Operations Counter AF	1265	
665300	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
665301	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	General Comments		
665302	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
665303	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
665304	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
665305	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
665306	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
665307	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
665308	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
665309	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
665310	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
665311	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
665312	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
665313	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Operations Counter AL	1269	
665314	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
665315	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	Follow-up Action Required?	n	
665316	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
665317	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Switching Operations	5	
665318	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Tank Paint Condition	Good	
665319	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Unknown Operations	0	
665320	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	General Comments		
665321	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	General Comments		
665322	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC As Found Counter	147895	
665323	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	25	°C
665324	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	57	°C
665325	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
665326	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
665327	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
665328	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
665329	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
665330	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC As Found Counter	30554	
665331	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	General Comments		
665332	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	General Comments		
665333	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
665334	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	Follow-up Action Required?	n	
665335	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
665336	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
665337	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Bushing Condition	Good	
665338	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
665339	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
665340	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Oil Temp Present	29	°C
665341	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Oil Temp Max	31	°C
665342	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
665343	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
665344	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	7508.16	kw
665345	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	100.00	
665346	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
665347	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
665348	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
665349	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	General Comments	Added Nitrogen	
665350	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	General Comments		
665351	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
665352	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
665353	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
665354	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
665355	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
665356	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Cabinet Paint Condition	Good	
665357	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
665358	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
665359	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
665360	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
665361	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
665362	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
665363	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
665364	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
665365	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
665366	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
665367	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
665368	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
665369	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Equipment Properly Labeled?	y	
665370	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
665371	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50	
665372	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45	
665373	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
665374	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Oil Temp Present	22	°C
665375	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
665376	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
665377	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
665378	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
665379	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
665380	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
665381	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
665382	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
665383	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
665384	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
665385	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Totalizer Meter Reading	.478	
665386	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Winding Temp Max	30	°C
665387	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Winding Temp Present	25	°C
665388	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Switching Operations	0	
665389	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Operations Counter AL	433	
665390	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Operations Counter AF	433	
665391	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Maintenance Operations	0	
665392	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	General Comments		
665393	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Patrol Inspection	General Comments		
665394	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Follow-up Action Required?	n	
665395	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Patrol Inspection	Follow-up Action Required?	n	
665396	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Operations Ground	0	
665397	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	9 Month Operations	8	
665398	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Operations C Ø	0	
665399	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Operations B Ø	0	
665400	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Accumulated Fault Duty A Ph V	33.80	%
665401	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Accumulated Fault Duty B Ph V	34.42	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
665402	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Accumulated Fault Duty C Ph V	31.96	%
665403	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Amps A Ø	120.0	
665404	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Amps B Ø	120.0	
665405	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Amps C Ø	130.0	
665406	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Patrol Inspection	Equipment Properly Labeled?	y	
665407	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
665408	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
665409	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
665410	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Operations A Ø	0	
665411	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Operations B Ø	0	
665412	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Operations C Ø	0	
665413	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Operations Ground	0	
665414	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
665415	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
665416	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
665417	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
665418	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
665419	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	445	
665420	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
665421	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Unknown Operations	0	
665422	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC As Left Counter	147895	
665423	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
665424	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC Current Tap Position	2L	
665425	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC Max Tap Position	1R	
665426	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC Min Tap Position	6L	
665427	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC Operations Since Last Insp	327	
665428	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
665429	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
665430	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	General Comments		
665431	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
665432	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
665433	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
665434	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
665435	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
665436	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
665437	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	PF000051	PowerFuse	BR-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
665438	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	PF000051	PowerFuse	BR-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	OK	
665439	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
665440	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
665441	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
665442	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
665443	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
665444	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
665445	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
665446	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
665447	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
665448	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
665449	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
665450	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
665451	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	General Comments		
665452	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	General Comments		
665453	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
665454	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
665455	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
665456	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
665457	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2294.4	kw
665458	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
665459	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Foundation Condition	Good	
665460	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
665461	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
665462	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Tank Leaks	None	
665463	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
665464	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Operations Counter	1418	
665465	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
665466	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
665467	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	General Comments		
665468	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
665469	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
665470	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Accumulated Fault Duty C Ph V	0	%
665471	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Amps A Ø	89	
665472	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Amps B Ø	81	
665473	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Amps C Ø	118	
665474	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
665475	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Bushing Condition	Good	
665476	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
665477	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
665478	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
665479	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Equipment Properly Labeled?	y	
665480	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Adjusted Amps A Phase V	0	
665481	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Adjusted Amps B Phase V	0	
665482	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Adjusted Amps C Phase V	0	
665483	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Operations A Ø	0	
665484	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Operations B Ø	0	
665485	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Operations C Ø	0	
665486	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	126	
665487	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Amps A Ø	2.1	
665488	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Amps B Ø	2.0	
665489	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Amps C Ø	2.0	
665490	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Operations Ground	0	
665491	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Follow-up Action Required?	n	
665492	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Follow-up Action Required?	n	
665493	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Foundation Condition	Good	
665494	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	General Comments		
665495	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	General Comments		
665496	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Grounds in Place?	y	
665497	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Heaters (All) Functioning?	y	
665498	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Maintenance Operations	0	
665499	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Moisture and Leak Free?	y	
665500	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	199	
665501	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Accumulated Fault Duty A Ph V	0	%
665502	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Accumulated Fault Duty B Ph V	0	%
665503	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Accumulated Fault Duty C Ph V	.65	%
665504	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Amps A Ø	164	
665505	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Amps B Ø	105	
665506	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Amps C Ø	161	
665507	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Bushing Condition	Good	
665508	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Bushings Connection/Risers	Good	
665509	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
665510	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
665511	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Equipment Properly Labeled?	y	
665512	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Adjusted Amps A Phase V	0	
665513	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Adjusted Amps B Phase V	0	
665514	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Adjusted Amps C Phase V	0	
665515	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Operations A Ø	0	
665516	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Operations B Ø	0	
665517	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Operations C Ø	0	
665518	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Operations Ground	0	
665519	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Follow-up Action Required?	n	
665520	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Follow-up Action Required?	n	
665521	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Foundation Condition	Good	
665522	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	General Comments		
665523	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	General Comments		
665524	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Grounds in Place?	y	
665525	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Heaters (All) Functioning?	y	
665526	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Maintenance Operations	0	
665527	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Moisture and Leak Free?	y	
665528	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Operations Counter AF	150	
665529	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Operations Counter AL	151	
665530	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Switching Operations	1	
665531	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Tank Paint Condition	Good	
665532	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Unknown Operations	0	
665533	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
665534	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	9 Month Operations	2	
665535	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Accumulated Fault Duty A Ph V	0	%
665536	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Accumulated Fault Duty B Ph V	0	%
665537	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
665538	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
665539	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Tank Leaks	None	
665540	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
665541	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Radiator Leaks	None	
665542	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
665543	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Grounds in Place?	y	
665544	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	General Comments		
665545	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Amps B Ø	192.0	
665546	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	9 Month Operations	10	
665547	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Accumulated Fault Duty A Ph V	.49	%
665548	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Accumulated Fault Duty B Ph V	.98	%
665549	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
665550	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC Operations Since Last Insp	1369	
665551	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC Min Tap Position	11L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
665552	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC Max Tap Position	3L	
665553	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC Current Tap Position	4L	
665554	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
665555	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Accumulated Fault Duty C Ph V	.98	%
665556	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Amps A Ø	12.0	
665557	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Amps B Ø	12.0	
665558	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Amps C Ø	12.0	
665559	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Amps A Ø	185.0	
665560	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
665561	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	25	°C
665562	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	57	°C
665563	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC As Left Counter	30557	
665564	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	25	°C
665565	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
665566	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
665567	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
665568	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
665569	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2R	
665570	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
665571	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
665572	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
665573	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
665574	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
665575	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
665576	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
665577	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
665578	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
665579	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
665580	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.5	volts
665581	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	13959	
665582	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
665583	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
665584	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
665585	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
665586	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Bushing Condition	Good	
665587	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Bushings Connection/Risers	Good	
665588	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
665589	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
665590	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Operations Counter AF	159	
665591	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Operations Counter AL	160	
665592	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Switching Operations	1	
665593	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Tank Paint Condition	Good	
665594	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Unknown Operations	0	
665595	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
665596	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
665597	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
665598	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
665599	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
665600	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
665601	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
665602	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	General Comments		
665603	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
665604	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
665605	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
665606	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
665607	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LTCC000529	LTCControl	BR-TRANS 5	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
665608	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LTCC000529	LTCControl	BR-TRANS 5	LTC Control Insp	General Comments		
665609	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
665610	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
665611	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
665612	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
665613	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
665614	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LTCC000529	LTCControl	BR-TRANS 5	LTC Control Insp	Follow-up Action Required?	n	
665615	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Winding Temp Present	29	°C
665616	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Winding Temp Max	29	°C
665617	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Totalizer Meter Reading	1.0428	
665618	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
665619	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
665620	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
665621	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
665622	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
665623	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
665624	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
665625	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
665626	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
665627	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
665628	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
665629	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
665630	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
665631	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Amps C Ø	192.0	
665632	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
665633	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Operations Counter	394	
665634	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
665635	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	General Comments		
665636	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
665637	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
665638	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
665639	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
665640	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
665641	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Amps C Ø	22.0	
665642	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Amps B Ø	12.6	
665643	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Amps A Ø	25.0	
665644	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
665645	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
665646	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
665647	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
665648	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
665649	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
665650	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
665651	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
665652	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
665653	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
665654	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
665655	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
665656	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
665657	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
665658	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
665659	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
665660	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
665661	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
665662	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
665663	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
665664	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
665665	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
665666	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
665667	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
665668	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Verify vc	
665669	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
665670	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	284	
665671	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	284	
665672	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
665673	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
665674	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
665675	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
665676	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Bushings Connection/Risers	Good	
665677	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
665678	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
665679	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
665680	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Cabinet Paint Condition	Good	
665681	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Equipment Properly Labeled?	y	
665682	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
665683	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
665684	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
665685	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Operations A Ø	0	
665686	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Operations B Ø	0	
665687	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Operations C Ø	0	
665688	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Operations Ground	0	
665689	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Follow-up Action Required?	n	
665690	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Follow-up Action Required?	n	
665691	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Foundation Condition	Good	
665692	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	General Comments		
665693	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	General Comments		
665694	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Grounds in Place?	y	
665695	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
665696	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
665697	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Heaters (All) Functioning?	y	
665698	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Maintenance Operations	0	
665699	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Moisture and Leak Free?	y	
665700	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Operations Counter AF	337	
665701	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Operations Counter AL	337	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
665702	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
665703	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	7.2	VDC
665704	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	8.7	VDC
665705	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
665706	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Switching Operations	0	
665707	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Tank Paint Condition	Good	
665708	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Unknown Operations	0	
665709	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
665710	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
665711	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
665712	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
665713	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
665714	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
665715	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
665716	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
665717	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
665718	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	BAT000554	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
665719	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
665720	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1009	
665721	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1009	
665722	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
665723	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
665724	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
665725	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
665726	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
665727	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
665728	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
665729	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
665730	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
665731	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
665732	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
665733	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
665734	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
665735	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
665736	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
665737	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
665738	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
665739	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
665740	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LTCC000496	LTCControl	BR-TRANS 4	LTC Control Insp	General Comments		
665741	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LTCC000496	LTCControl	BR-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
665742	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
665743	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Vegetation	None	
665744	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
665745	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	9 Month Operations	12	
665746	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Accumulated Fault Duty A Ph V	4.76	%
665747	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
665748	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Accumulated Fault Duty B Ph V	5.56	%
665749	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	General Comments		
665750	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
665751	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Accumulated Fault Duty C Ph V	4.37	%
665752	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Amps A Ø	104.0	
665753	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Amps B Ø	142.0	
665754	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Amps C Ø	104.0	
665755	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Bushing Condition	Good	
665756	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Bushings Connection/Risers	Good	
665757	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
665758	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
665759	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
665760	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Cabinet Paint Condition	Good	
665761	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Equipment Properly Labeled?	y	
665762	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
665763	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
665764	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
665765	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
665766	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
665767	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
665768	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
665769	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
665770	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
665771	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
665772	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
665773	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
665774	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
665775	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
665776	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
665777	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Readings	General Comments		
665778	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
665779	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
665780	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
665781	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
665782	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
665783	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
665784	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
665785	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
665786	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
665787	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
665788	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
665789	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
665790	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
665791	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	General Comments		
665792	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
665793	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
665794	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Foundation Condition	Good	
665795	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
665796	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
665797	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
665798	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
665799	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
665800	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
665801	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	9 Month Operations	13	
665802	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
665803	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
665804	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LTCC000496	LTCControl	BR-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
665805	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
665806	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
665807	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0103	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
665808	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Operations B Ø	0	
665809	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Operations A Ø	0	
665810	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
665811	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
665812	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
665813	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Patrol Inspection	Equipment Properly Labeled?	y	
665814	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Amps C Ø	85.0	
665815	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Amps B Ø	80.0	
665816	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Amps A Ø	90.0	
665817	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Accumulated Fault Duty C Ph V	29.50	%
665818	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Accumulated Fault Duty B Ph V	35.03	%
665819	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Accumulated Fault Duty A Ph V	35.65	%
665820	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	9 Month Operations	8	
665821	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
665822	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Vegetation	None	
665823	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
665824	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
665825	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
665826	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
665827	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
665828	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
665829	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
665830	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
665831	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	417	
665832	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	417	
665833	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
665834	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
665835	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
665836	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
665837	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
665838	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
665839	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Min Tap Position	10L	
665840	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Max Tap Position	2L	
665841	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
665842	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	General Comments		
665843	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
665844	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
665845	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
665846	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
665847	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
665848	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
665849	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
665850	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
665851	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
665852	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
665853	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
665854	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
665855	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
665856	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
665857	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
665858	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Ambient Temp	41	°F
665859	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
665860	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
665861	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Clear of Trash?	y	
665862	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
665863	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
665864	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
665865	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Unknown Operations	0	
665866	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Switching Operations	1	
665867	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Operations Counter AL	354	
665868	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Operations Counter AF	354	
665869	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
665870	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
665871	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
665872	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	General Comments		
665873	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
665874	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
665875	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
665876	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
665877	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
665878	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Vegetation	None	
665879	1/4/2019 15:38	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
665880	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	PF000050	PowerFuse	BR-12KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	OK	
665881	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	PF000050	PowerFuse	BR-12KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
665882	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
665883	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Tank Leaks	None	
665884	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
665885	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
665886	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Regulator As Left Counter	20631	
665887	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
665888	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
665889	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Maintenance Operations	0	
665890	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	General Comments		
665891	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Patrol Inspection	General Comments		
665892	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Follow-up Action Required?	n	
665893	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Patrol Inspection	Follow-up Action Required?	n	
665894	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Operations Ground	0	
665895	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Operations C Ø	0	
665896	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
665897	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
665898	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99965	
665899	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99965	
665900	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
665901	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
665902	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
665903	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
665904	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
665905	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
665906	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
665907	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
665908	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Regulator As Left Counter	27480	
665909	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
665910	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
665911	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Tank Leaks	None	
665912	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
665913	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
665914	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
665915	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
665916	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
665917	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
665918	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
665919	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
665920	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
665921	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
665922	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
665923	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	9 Month Operations	6	
665924	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Accumulated Fault Duty A Ph V	7.83	%
665925	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Accumulated Fault Duty B Ph V	9.96	%
665926	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Accumulated Fault Duty C Ph V	11.39	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
665927	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Amps A Ø	180.0	
665928	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
665929	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
665930	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
665931	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
665932	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
665933	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
665934	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
665935	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
665936	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
665937	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Amps B Ø	175.0	
665938	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Amps C Ø	180.0	
665939	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Bushing Condition	Good	
665940	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
665941	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
665942	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
665943	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
665944	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
665945	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
665946	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
665947	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
665948	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
665949	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	General Comments		
665950	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
665951	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
665952	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
665953	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
665954	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
665955	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
665956	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
665957	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
665958	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
665959	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
665960	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
665961	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
665962	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	General Comments		
665963	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
665964	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
665965	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
665966	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
665967	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
665968	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
665969	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Clear of Trash?	y	
665970	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
665971	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Ambient Temp	41	°F
665972	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
665973	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
665974	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Current Tap Position	6L	
665975	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
665976	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
665977	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
665978	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
665979	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
665980	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
665981	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
665982	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	General Comments		
665983	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
665984	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Amps A Ø	67	
665985	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LTCC000737	LTCControl	CY-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
665986	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LTCC000737	LTCControl	CY-TRANS 2	LTC Control Insp	General Comments		
665987	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LTCC000737	LTCControl	CY-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
665988	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Amps B Ø	73	
665989	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	8	°C
665990	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	46	°C
665991	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	8	°C
665992	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	46	°C
665993	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	8	°C
665994	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	46	°C
665995	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
665996	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
665997	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Amps C Ø	69	
665998	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
665999	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
666000	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
666001	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
666002	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
666003	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
666004	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
666005	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
666006	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	139	
666007	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	19	°C
666008	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	31	°C
666009	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
666010	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
666011	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5L	
666012	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
666013	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
666014	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC As Left Counter	10925	
666015	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC As Found Counter	10925	
666016	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
666017	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	General Comments		
666018	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
666019	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
666020	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
666021	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
666022	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
666023	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
666024	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
666025	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
666026	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
666027	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	General Comments		
666028	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Operations Counter AF	219	
666029	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Moisture and Leak Free?	y	
666030	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Maintenance Operations	4	
666031	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Grounds in Place?	y	
666032	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	General Comments		
666033	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	General Comments		
666034	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Foundation Condition	Good	
666035	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
666036	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
666037	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Foundation Condition	Good	
666038	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
666039	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	General Comments		
666040	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Grounds in Place?	y	
666041	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
666042	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Follow-up Action Required?	n	
666043	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Follow-up Action Required?	n	
666044	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Operations Ground	0	
666045	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Operations C Ø	0	
666046	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Operations B Ø	0	
666047	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Operations A Ø	0	
666048	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
666049	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
666050	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
666051	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Equipment Properly Labeled?	y	
666052	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Cabinet Paint Condition	Good	
666053	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
666054	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
666055	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Radiator Leaks	None	
666056	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
666057	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Tank Leaks	None	
666058	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
666059	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Amps C Ø	67.9	
666060	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Amps B Ø	59.0	
666061	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Amps A Ø	53.0	
666062	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Grounds in Place?	y	
666063	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Maintenance Operations	0	
666064	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Moisture and Leak Free?	y	
666065	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Operations Counter AF	206	
666066	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Operations Counter AL	206	
666067	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Switching Operations	0	
666068	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Tank Paint Condition	Good	
666069	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Unknown Operations	0	
666070	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
666071	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
666072	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Bushing Condition	Good	
666073	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Amps C Ø	0.0	
666074	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Amps B Ø	0.0	
666075	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Amps A Ø	0.0	
666076	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Accumulated Fault Duty C Ph V	.42	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
666077	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Accumulated Fault Duty B Ph V	.42	%
666078	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Accumulated Fault Duty A Ph V	.42	%
666079	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	9 Month Operations	14	
666080	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
666081	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	PF000072	PowerFuse	CY-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
666082	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1310	psi
666083	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
666084	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
666085	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
666086	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	General Comments	There is oil seeping out of where the oil temp wells where blanked off	
666087	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	General Comments		
666088	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
666089	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
666090	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
666091	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
666092	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
666093	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
666094	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
666095	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
666096	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
666097	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
666098	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
666099	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
666100	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
666101	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
666102	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
666103	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
666104	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
666105	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
666106	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
666107	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Operations A Ø	0	
666108	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Operations B Ø	0	
666109	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Operations C Ø	0	
666110	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Operations Ground	0	
666111	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	
666112	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
666113	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
666114	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
666115	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
666116	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
666117	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
666118	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
666119	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
666120	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
666121	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
666122	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
666123	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
666124	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
666125	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
666126	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
666127	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
666128	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
666129	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
666130	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
666131	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
666132	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
666133	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
666134	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	Oil Temp Present	8	°C
666135	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	Oil Temp Max	46	°C
666136	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Operations Counter	6	
666137	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
666138	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
666139	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
666140	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Tank Leaks	None	
666141	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
666142	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	PF000040	PowerFuse	BR-GND TR 2	Disconnect Powerfuse Inspection	General Comments	OK	
666143	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	PF000040	PowerFuse	BR-GND TR 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
666144	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
666145	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
666146	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
666147	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Clear of Trash?	y	
666148	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
666149	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
666150	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
666151	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
666152	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
666153	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
666154	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Bushings Connection/Risers	Good	
666155	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	PF000074	PowerFuse	CY-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
666156	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	PF000074	PowerFuse	CY-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
666157	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	PF000073	PowerFuse	CY-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
666158	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	PF000073	PowerFuse	CY-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
666159	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	PF000072	PowerFuse	CY-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
666160	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Amps B Ø	0.0	
666161	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Amps C Ø	0.0	
666162	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Bushing Condition	Good	
666163	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Bushings Connection/Risers	Good	
666164	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
666165	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
666166	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
666167	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Cabinet Paint Condition	Good	
666168	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Equipment Properly Labeled?	y	
666169	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
666170	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
666171	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
666172	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Operations A Ø	0	
666173	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Operations B Ø	0	
666174	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Operations C Ø	0	
666175	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Operations Ground	0	
666176	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Follow-up Action Required?	n	
666177	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Bushing Condition	Good	
666178	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
666179	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Panels Dusted?	y	
666180	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
666181	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	General Comments		
666182	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
666183	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
666184	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Floor Swept?	y	
666185	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
666186	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
666187	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Evidence of Insects	None	
666188	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Follow-up Action Required?	n	
666189	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
666190	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
666191	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
666192	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
666193	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
666194	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
666195	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	PF000049	PowerFuse	BR-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	OK	
666196	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	PF000049	PowerFuse	BR-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
666197	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
666198	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
666199	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
666200	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	9 Month Operations	12	
666201	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	43.99	%
666202	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	43.99	%
666203	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	43.99	%
666204	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
666205	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
666206	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
666207	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
666208	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
666209	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
666210	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
666211	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
666212	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
666213	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
666214	1/2/2019 11:34	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
666215	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
666216	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
666217	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Operations A Ø	0	
666218	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Operations B Ø	0	
666219	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
666220	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
666221	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	544	
666222	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	544	
666223	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
666224	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
666225	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
666226	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
666227	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
666228	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
666229	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
666230	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
666231	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
666232	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
666233	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	General Comments		
666234	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
666235	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
666236	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
666237	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
666238	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
666239	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Clear of Trash?	y	
666240	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
666241	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
666242	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Ambient Temp	42	°F
666243	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
666244	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
666245	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
666246	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
666247	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Amps A Ø	0.0	
666248	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
666249	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
666250	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
666251	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
666252	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Tank Leaks	None	
666253	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
666254	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Operations Counter	1132	
666255	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
666256	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
666257	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	General Comments		
666258	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
666259	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
666260	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
666261	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
666262	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
666263	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
666264	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
666265	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
666266	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
666267	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Operations C Ø	0	
666268	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Operations Ground	0	
666269	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Follow-up Action Required?	n	
666270	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Follow-up Action Required?	n	
666271	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Foundation Condition	Good	
666272	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	General Comments		
666273	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	General Comments		
666274	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
666275	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
666276	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
666277	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
666278	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
666279	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	PF000045	PowerFuse	BR-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
666280	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	PF000045	PowerFuse	BR-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
666281	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	PF000044	PowerFuse	BR-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
666282	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	PF000044	PowerFuse	BR-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
666283	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	PF000043	PowerFuse	BR-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
666284	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	PF000043	PowerFuse	BR-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
666285	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	PF000041	PowerFuse	BR-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
666286	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	PF000041	PowerFuse	BR-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
666287	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Unknown Operations	0	
666288	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Tank Paint Condition	Good	
666289	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Switching Operations	0	
666290	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
666291	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Operations Counter AL	223	
666292	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Foundation Condition	Good	
666293	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	General Comments		
666294	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	General Comments		
666295	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Grounds in Place?	y	
666296	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Maintenance Operations	4	
666297	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Amps A Ø	0.0	
666298	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	PF000046	PowerFuse	BR-12KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	OK	
666299	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	PF000046	PowerFuse	BR-12KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
666300	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Amps B Ø	0.0	
666301	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Amps C Ø	0.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
666302	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Bushing Condition	Good	
666303	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
666304	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
666305	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
666306	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
666307	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Moisture and Leak Free?	y	
666308	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Operations Counter AF	277	
666309	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Operations Counter AL	281	
666310	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
666311	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
666312	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
666313	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
666314	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
666315	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
666316	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	Oil Temp Max	42	°C
666317	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
666318	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
666319	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
666320	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
666321	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
666322	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	General Comments	only one bank of fans came on when put in manual	
666323	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
666324	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
666325	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
666326	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
666327	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
666328	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
666329	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
666330	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
666331	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	General Comments		
666332	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
666333	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
666334	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
666335	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
666336	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Amps C Ø	110.0	
666337	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
666338	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
666339	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
666340	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
666341	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	General Comments		
666342	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
666343	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
666344	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
666345	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
666346	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
666347	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
666348	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
666349	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
666350	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Amps B Ø	110.0	
666351	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Amps A Ø	100.0	
666352	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
666353	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
666354	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
666355	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
666356	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
666357	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
666358	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
666359	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Unknown Operations	0	
666360	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Switching Operations	0	
666361	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Operations Counter AL	166	
666362	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Operations Counter AF	166	
666363	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Maintenance Operations	0	
666364	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	General Comments		
666365	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Patrol Inspection	General Comments		
666366	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Follow-up Action Required?	n	
666367	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Patrol Inspection	Follow-up Action Required?	n	
666368	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Operations Ground	0	
666369	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Operations C Ø	0	
666370	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Operations B Ø	0	
666371	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Operations A Ø	0	
666372	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
666373	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
666374	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
666375	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
666376	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
666377	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
666378	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
666379	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
666380	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
666381	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
666382	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
666383	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
666384	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
666385	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Unknown Operations	0	
666386	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Switching Operations	1	
666387	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Operations Counter AL	308	
666388	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Operations Counter AF	308	
666389	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
666390	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
666391	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
666392	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
666393	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
666394	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Oil Temp Present	23	°C
666395	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Oil Temp Max	50	°C
666396	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
666397	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Maintenance Operations	0	
666398	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	General Comments		
666399	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Patrol Inspection	General Comments		
666400	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Follow-up Action Required?	n	
666401	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Patrol Inspection	Follow-up Action Required?	n	
666402	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Operations Ground	0	
666403	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Operations C Ø	0	
666404	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Operations B Ø	0	
666405	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
666406	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	LTC Totalizer Reading	2192.00	kw
666407	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
666408	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Operations A Ø	0	
666409	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
666410	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
666411	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	General Comments		
666412	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	General Comments		
666413	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
666414	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
666415	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Follow-up Action Required?	n	
666416	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
666417	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
666418	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
666419	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Patrol Inspection	Equipment Properly Labeled?	y	
666420	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	1739.52	kw
666421	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	225.00	
666422	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
666423	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Oil Temp Max	40	°C
666424	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Oil Temp Present	35	°C
666425	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
666426	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
666427	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
666428	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
666429	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	High	
666430	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
666431	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
666432	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Totalizer Meter Reading	.7248	
666433	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
666434	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
666435	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
666436	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	54	
666437	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
666438	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC Max Tap Position	9L	
666439	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Accumulated Fault Duty C Ph V	28.27	%
666440	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Accumulated Fault Duty B Ph V	35.65	%
666441	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Accumulated Fault Duty A Ph V	35.03	%
666442	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	9 Month Operations	9	
666443	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
666444	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
666445	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC As Left Counter	254158	
666446	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC As Found Counter	254158	
666447	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
666448	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	General Comments		
666449	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
666450	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
666451	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
666452	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
666453	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
666454	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
666455	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
666456	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
666457	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
666458	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
666459	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
666460	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
666461	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
666462	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
666463	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
666464	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
666465	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
666466	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
666467	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
666468	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
666469	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
666470	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
666471	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
666472	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
666473	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
666474	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
666475	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
666476	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
666477	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
666478	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
666479	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
666480	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
666481	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Switching Operations	9	
666482	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Tank Paint Condition	Good	
666483	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Unknown Operations	0	
666484	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	General Comments		
666485	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	General Comments		
666486	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
666487	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
666488	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
666489	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
666490	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
666491	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
666492	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
666493	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
666494	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Oil Temp Max	60	°C
666495	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
666496	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
666497	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
666498	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
666499	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
666500	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
666501	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
666502	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
666503	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
666504	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
666505	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	Oil Temp Max	29	°C
666506	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
666507	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
666508	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	LTC Totalizer Reading	6059.52	kw
666509	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
666510	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	General Comments		
666511	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	General Comments		
666512	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
666513	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
666514	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
666515	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
666516	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
666517	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
666518	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
666519	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	Follow-up Action Required?	n	
666520	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
666521	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
666522	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
666523	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
666524	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
666525	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
666526	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Current Tap Position	3L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
666527	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
666528	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
666529	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
666530	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
666531	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
666532	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
666533	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
666534	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
666535	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
666536	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
666537	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
666538	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	9 Month Operations	17	
666539	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Accumulated Fault Duty A Ph V	11.55	%
666540	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Accumulated Fault Duty B Ph V	11.55	%
666541	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Accumulated Fault Duty C Ph V	10.26	%
666542	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Amps A Ø	300.0	
666543	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Amps B Ø	300.0	
666544	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Amps C Ø	300.0	
666545	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Bushing Condition	Good	
666546	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Bushings Connection/Risers	Good	
666547	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
666548	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
666549	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
666550	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
666551	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
666552	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
666553	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
666554	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
666555	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
666556	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
666557	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	208.0	
666558	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	209.0	
666559	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	211.0	
666560	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
666561	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
666562	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Bushing Condition	Good	
666563	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
666564	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
666565	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	Totalizer Meter Reading	.6312	
666566	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
666567	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
666568	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
666569	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Operations A Ø	0	
666570	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Operations B Ø	0	
666571	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Operations C Ø	0	
666572	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Operations Ground	0	
666573	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Patrol Inspection	Follow-up Action Required?	n	
666574	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Follow-up Action Required?	n	
666575	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Patrol Inspection	General Comments		
666576	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	General Comments		
666577	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Maintenance Operations	0	
666578	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
666579	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Operations Counter AF	99968	
666580	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Operations Counter AL	99968	
666581	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Switching Operations	0	
666582	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Unknown Operations	0	
666583	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
666584	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
666585	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
666586	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
666587	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
666588	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	Oil Temp Present	29	°C
666589	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
666590	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Follow-up Action Required?	n	
666591	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Foundation Condition	Good	
666592	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	General Comments		
666593	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	General Comments		
666594	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Grounds in Place?	y	
666595	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Maintenance Operations	0	
666596	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Moisture and Leak Free?	y	
666597	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Operations Counter AF	223	
666598	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Operations Counter AL	232	
666599	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
666600	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
666601	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Wood Structures OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
666602	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
666603	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
666604	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
666605	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
666606	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
666607	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
666608	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
666609	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
666610	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
666611	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
666612	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
666613	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	General Comments		
666614	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
666615	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
666616	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Tank Leaks	None	
666617	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
666618	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
666619	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
666620	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Totalizer Meter Reading	.6850	
666621	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
666622	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
666623	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
666624	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
666625	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
666626	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
666627	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
666628	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
666629	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
666630	1/31/2019 14:38	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
666631	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
666632	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
666633	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
666634	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Cabinet Paint Condition	Good	
666635	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Equipment Properly Labeled?	y	
666636	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
666637	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
666638	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
666639	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Operations A Ø	0	
666640	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Operations B Ø	0	
666641	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Operations C Ø	0	
666642	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Operations Ground	0	
666643	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Follow-up Action Required?	n	
666644	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
666645	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
666646	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1235	
666647	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1235	
666648	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
666649	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
666650	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
666651	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
666652	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
666653	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
666654	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
666655	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	General Comments		
666656	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	General Comments		
666657	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
666658	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Max Tap Position	9R	
666659	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
666660	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
666661	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
666662	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
666663	1/2/2019 12:24	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
666664	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
666665	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
666666	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
666667	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
666668	1/2/2019 15:03	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Regulator As Left Counter	85165	
666669	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
666670	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
666671	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
666672	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
666673	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
666674	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	General Comments	needs 1 screw on desicant fliter ontop of LTC	
666675	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	General Comments		
666676	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
666677	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
666678	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
666679	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
666680	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
666681	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
666682	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
666683	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
666684	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
666685	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
666686	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
666687	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
666688	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
666689	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
666690	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Evidence of Insects	None	
666691	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
666692	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
666693	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Floor Swept?	y	
666694	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
666695	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
666696	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
666697	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
666698	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
666699	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	General Comments		
666700	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
666701	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
666702	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
666703	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
666704	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	5277	
666705	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC Min Tap Position	3R	
666706	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4R	
666707	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC Current Tap Position	4R	
666708	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
666709	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC As Left Counter	85180	
666710	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC As Found Counter	85180	
666711	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
666712	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	General Comments		
666713	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
666714	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
666715	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
666716	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
666717	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
666718	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
666719	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
666720	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
666721	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
666722	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
666723	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
666724	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
666725	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
666726	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
666727	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
666728	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
666729	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
666730	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
666731	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
666732	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
666733	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	338	
666734	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
666735	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC Min Tap Position	15L	
666736	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC Max Tap Position	1L	
666737	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC Current Tap Position	12L	
666738	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
666739	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC As Left Counter	162440	
666740	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC As Found Counter	162440	
666741	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
666742	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
666743	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
666744	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
666745	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
666746	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
666747	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
666748	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	General Comments	added nitro	
666749	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	General Comments	couldn't reset with magnet	
666750	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
666751	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
666752	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
666753	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
666754	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
666755	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
666756	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
666757	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
666758	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
666759	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
666760	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
666761	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
666762	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
666763	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
666764	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
666765	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
666766	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	5275	
666767	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4R	
666768	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
666769	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	LTC As Left Counter	47112	
666770	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	LTC As Found Counter	47112	
666771	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
666772	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	General Comments		
666773	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
666774	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
666775	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
666776	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
666777	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
666778	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
666779	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
666780	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
666781	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
666782	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
666783	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	BCH000396	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
666784	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	BCH000396	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
666785	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	BCH000396	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
666786	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	BCH000396	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
666787	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	BCH000396	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
666788	1/2/2019 13:54	Distribution	Springfield Quarterly Inspection	BCH000396	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
666789	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
666790	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
666791	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
666792	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
666793	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
666794	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
666795	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
666796	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
666797	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
666798	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	482.0	
666799	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	475.0	
666800	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	460.0	
666801	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
666802	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
666803	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
666804	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
666805	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
666806	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
666807	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
666808	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
666809	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
666810	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	General Comments	Heater was not on. Turned on heater	
666811	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
666812	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
666813	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
666814	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
666815	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
666816	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Trash Emptied?	n	
666817	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
666818	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
666819	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
666820	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
666821	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
666822	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
666823	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
666824	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
666825	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
666826	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
666827	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
666828	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	General Comments	open, lineside also open One operation from trip check	
666829	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
666830	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
666831	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Operations Counter	85	
666832	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
666833	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
666834	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
666835	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
666836	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	General Comments	station supply transformer fuse looking somewhat frayed	
666837	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
666838	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
666839	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
666840	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
666841	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
666842	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
666843	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	250	
666844	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC Min Tap Position	14L	
666845	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC Max Tap Position	6L	
666846	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC Current Tap Position	8L	
666847	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
666848	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC As Left Counter	174558	
666849	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC As Found Counter	174558	
666850	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	General Comments	The glass has a lot of moister on it, need to check if there is a heater not working or try and stop water from getting in	
666851	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
666852	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	Follow-up Action Required?	y	
666853	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
666854	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
666855	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
666856	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
666857	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
666858	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
666859	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
666860	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
666861	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
666862	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
666863	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
666864	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
666865	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
666866	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
666867	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Bushing Condition	Good	
666868	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Bushings Connection/Risers	Good	
666869	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
666870	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	General Comments		
666871	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
666872	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
666873	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
666874	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Cabinet Paint Condition	Good	
666875	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Equipment Properly Labeled?	y	
666876	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
666877	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
666878	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
666879	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Operations A Ø	0	
666880	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Operations B Ø	0	
666881	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Operations C Ø	0	
666882	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Operations Ground	0	
666883	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Follow-up Action Required?	n	
666884	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	EI-Battery Charger	Battery Charger Patrol Insp	General Comments		
666885	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Follow-up Action Required?	n	
666886	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
666887	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
666888	1/2/2019 13:28	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
666889	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	BCH000269	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
666890	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	BCH000269	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
666891	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	BCH000269	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
666892	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	EI-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
666893	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	EI-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
666894	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	EI-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
666895	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	EI-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
666896	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	EI-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
666897	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	EI-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.300	millivolts
666898	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Foundation Condition	Good	
666899	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	General Comments		
666900	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
666901	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
666902	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
666903	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	EI-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
666904	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	EI-Yard	Yard Patrol Inspection	Vegetation	None	
666905	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	EI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
666906	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	EI-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
666907	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Patrol Inspection	Equipment Properly Labeled?	y	
666908	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Amps C Ø	140.0	
666909	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Amps B Ø	140.0	
666910	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Amps A Ø	140.0	
666911	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Accumulated Fault Duty C Ph V	7.38	%
666912	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Accumulated Fault Duty B Ph V	7.99	%
666913	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Accumulated Fault Duty A Ph V	7.99	%
666914	1/2/2019 10:48	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	9 Month Operations	2	
666915	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
666916	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
666917	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	EI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
666918	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	EI-Yard	Yard Patrol Inspection	General Comments		
666919	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
666920	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
666921	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
666922	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
666923	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
666924	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
666925	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
666926	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
666927	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
666928	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
666929	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
666930	1/2/2019 12:28	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
666931	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	9 Month Operations	9	
666932	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Accumulated Fault Duty A Ph V	2.04	%
666933	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	EI-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
666934	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	EI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
666935	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	EI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
666936	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Accumulated Fault Duty B Ph V	1.70	%
666937	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	EI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
666938	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	EI-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
666939	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Accumulated Fault Duty C Ph V	2.38	%
666940	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Amps A Ø	125.0	
666941	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Amps B Ø	135.0	
666942	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Amps C Ø	135.0	
666943	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
666944	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	General Comments		
666945	1/2/2019 11:19	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
666946	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	General Comments		
666947	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
666948	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
666949	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Switching Operations	2	
666950	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Tank Paint Condition	Good	
666951	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Unknown Operations	0	
666952	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Unknown Operations	0	
666953	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Switching Operations	0	
666954	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Operations Counter AL	281	
666955	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Operations Counter AF	281	
666956	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Maintenance Operations	0	
666957	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
666958	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	General Comments		
666959	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Patrol Inspection	General Comments		
666960	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Follow-up Action Required?	n	
666961	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
666962	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Operations Ground	0	
666963	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Operations C Ø	0	
666964	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Operations B Ø	0	
666965	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Operations A Ø	0	
666966	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
666967	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
666968	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
666969	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
666970	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
666971	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Amps C Ø	30.0	
666972	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Amps B Ø	30.0	
666973	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Amps A Ø	30.0	
666974	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
666975	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
666976	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
666977	1/2/2019 9:05	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	9 Months Operations	0	
666978	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Tank Leaks	None	
666979	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
666980	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Regulator As Left Counter	374273	
666981	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
666982	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
666983	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
666984	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
666985	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
666986	1/2/2019 15:01	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	General Comments		
666987	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
666988	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	General Comments		
666989	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC As Found Counter	170825	
666990	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC As Left Counter	170825	
666991	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
666992	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC Current Tap Position	10L	
666993	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC Max Tap Position	6L	
666994	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC Min Tap Position	13L	
666995	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
666996	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	303	
666997	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
666998	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
666999	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
667000	1/2/2019 13:32	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
667001	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Operations Counter AL	272	
667002	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Operations Counter AF	270	
667003	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
667004	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
667005	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Moisture and Leak Free?	y	
667006	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Maintenance Operations	0	
667007	1/2/2019 15:58	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Grounds in Place?	y	
667008	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
667009	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Site Service Trans Condition	Exterior Stains	
667010	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
667011	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
667012	1/2/2019 9:58	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
667013	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
667014	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Bushings Connection/Risers	Good	
667015	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Bushing Condition	Good	
667016	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Follow-up Action Required?	n	
667017	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	General Comments		
667018	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
667019	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Prove All BFI DC Paths	na	
667020	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 1 or Aux Rly	n	
667021	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 2 or Aux Rly	na	
667022	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Paint Condition	Good	
667023	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Alarm Operation Correct?	n	
667024	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Follow-up Action Required?	n	
667025	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	General Comments		
667026	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Prove All BFI DC Paths	na	
667027	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Equipment Properly Labeled?	y	
667028	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Follow-up Action Required?	n	
667029	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Foundation Condition	Good	
667030	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	General Comments	ok	
667031	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Grounds in Place?	y	
667032	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Heaters (All) Functioning?	y	
667033	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Moisture and Leak Free?	y	
667034	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
667035	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Relay Trip Targets OK?	na	
667036	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 1 or Aux Rly	n	
667037	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 2 or Aux Rly	na	
667038	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Tank Paint Condition	Good	
667039	3/11/2019 8:17	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	